

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	231996
Document Title:	Roseville Energy Park Q4 2019 - Quarterly Air Quality Report
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Applicant
Submission Date:	2/10/2020 9:34:38 AM
Docketed Date:	2/10/2020

**City of Roseville
Roseville Energy Park
(03-AFC-1)**

**California Energy Commission
Quarterly Air Quality Report
Fourth Quarter 2019**

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly Sox AQ-SC6

AQ34 – Start Up and Shut downs

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12 month summary

AQ47 – All nuisance violations

N/A for this report period

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOX, PM-10, SOX, and VOC

AQ59 – Emission limit exceedances – NOX, CO, VOC, PM-10, SO2

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NO_x, CO, VOCs, PM₁₀, Sox

AQ63 – Total facility emission exceedances – NO_x, CO, VOC, PM-10, SO₂

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

None

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

N/A for this report period

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built deigns or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6



California Gas Transmission

Pipe Ranger

Go

Log in

About CGT

Products

Tools & Services

Operating Data

Reference/Library

Current Pipeline Status

Forecasts

Historical Archives

Gas Quality/Heating Values

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2019				
Fourth Quarter	5.2	0.33	4.1	0.26
Third Quarter	5.2	0.33	4.0	0.25
Second Quarter	5.8	0.36	3.75	0.23
First Quarter	5.1	0.32	3.75	0.23

AQ20 ROSEVILLE ENERGY PARK

4Q19

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	OCT	NOV	DEC
1	1044.98	1050.55	1045.44
2	1044.98	1050.67	1045.41
3	1054.35	1049.53	1045.52
4	1052.23	1049.00	1046.09
5	1049.24	1047.21	1045.03
6	1053.35	1044.33	1044.01
7	1063.40	1042.80	1044.28
8	1067.39	1043.19	1043.82
9	1066.58	1043.58	1043.82
10	1066.48	1046.21	1049.00
11	1069.39	1043.72	1045.16
12	1072.88	1042.93	1042.89
13	1073.73	1,043.79	1042.08
14	1074.21	1045.36	1043.22
15	1074.21	1046.61	1042.68
16	1071.48	1045.48	1042.75
17	1065.66	1044.90	1044.60
18	1064.72	1047.01	1044.16
19	1067.18	1049.41	1043.36
20	1070.42	1048.10	1043.27
21	1065.27	1047.25	1043.26
22	1049.62	1046.48	1042.22
23	1050.41	1047.42	1043.00
24	1049.72	1046.41	1043.00
25	1053.79	1042.85	1040.55
26	1052.79	1045.13	1042.12
27	1053.74	1046.94	1041.17
28	1055.11	1046.11	1041.45
29	1052.09	1046.05	1041.85
30	1050.89	1046.58	1042.02
31	1050.88	N/A	1041.19

baseline/operations/gas_quality/p01_2_weeks.shtml

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019	0.0	0.0	0.0	0.0
10/02/2019	0.0	0.0	0.0	0.0
10/03/2019	0.0	0.0	0.0	0.0
10/04/2019	0.0	0.0	0.0	0.0
10/05/2019	0.0	0.0	0.0	0.0
10/06/2019	0.0	0.0	0.0	0.0
10/07/2019	0.0	0.0	0.0	0.0
10/08/2019	0.0	0.0	0.0	0.0
10/09/2019	0.0	0.0	0.0	0.0
10/10/2019	0.0	0.0	0.0	0.0
10/11/2019	0.0	0.0	0.0	0.0
10/12/2019	0.0	0.0	0.0	0.0
10/13/2019	0.0	0.0	0.0	0.0
10/14/2019	0.0	0.0	0.0	0.0
10/15/2019	0.0	0.0	0.0	0.0
10/16/2019	0.0	0.0	0.0	0.0
10/17/2019	0.0	0.0	0.0	0.0
10/18/2019	0.0	0.0	0.0	0.0
10/19/2019	0.0	0.0	0.0	0.0
10/20/2019	0.0	0.0	0.0	0.0
10/21/2019	0.0	0.0	32.0	14.5
10/22/2019	0.0	0.0	0.0	0.0
10/23/2019	0.0	0.0	0.0	0.0
10/24/2019	24.2	13.8	8.5	1.7
10/25/2019	0.0	0.0	29.9	14.3
10/26/2019	0.0	0.0	0.0	0.0
10/27/2019	0.0	0.0	0.0	0.0
10/28/2019	0.0	0.0	0.0	0.0
10/29/2019	0.0	0.0	294.3	17.8
10/30/2019	0.0	0.0	6.9	1.2
10/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	24.2 *	13.8 *	371.6 *	49.5 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	24.2	13.8	294.3	17.8
Oct 2019 - Oct 2019	24.2	13.8	371.6	49.5
QTD:	24.2 *	13.8 *	371.6 *	49.5 *
YTD 2019:	510.0 *	177.6 *	1,020.0 *	319.5 *

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOx_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOx_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019	0.0	0.0	0.0	0.0
11/02/2019	0.0	0.0	0.0	0.0
11/03/2019	0.0	0.0	0.0	0.0
11/04/2019	0.0	0.0	0.0	0.0
11/05/2019	0.0	0.0	20.9	12.7
11/06/2019	0.0	0.0	2.2	1.1
11/07/2019	0.0	0.0	41.7	13.2
11/08/2019	0.0	0.0	26.6	12.7
11/09/2019	0.0	0.0	8.1	0.7
11/10/2019	0.0	0.0	0.0	0.0
11/11/2019	0.0	0.0	24.7	10.0
11/12/2019	10.2	1.0	0.2	2.2
11/13/2019	35.2	11.5	0.0	0.0
11/14/2019	9.6	1.1	0.0	0.0
11/15/2019	0.0	0.0	9.2	1.2
11/16/2019	0.0	0.0	0.0	0.0
11/17/2019	0.0	0.0	0.0	0.0
11/18/2019	0.0	0.0	0.0	0.0
11/19/2019	0.0	0.0	0.0	0.0
11/20/2019	0.0	0.0	36.7	14.9
11/21/2019	38.5	12.4	29.2	13.8
11/22/2019	0.0	0.1	0.0	0.0
11/23/2019	0.0	0.0	9.3	1.3
11/24/2019	0.0	0.0	0.0	0.0
11/25/2019	0.0	0.0	0.0	0.0
11/26/2019	53.5	12.9	31.0	15.0
11/27/2019	0.0	0.0	0.0	0.0
11/28/2019	0.0	0.0	0.0	0.0
11/29/2019	0.0	0.0	0.0	0.0
11/30/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	147.0 *	39.0 *	239.8 *	98.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	53.5	12.9	41.7	15.0
Oct 2019 - Nov 2019	171.2	52.8	611.4	148.3
QTD:	171.2 *	52.8 *	611.4 *	148.3 *
YTD 2019:	657.0 *	216.6 *	1,259.8 *	418.3 *

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019	0.0	0.0	0.0	0.0
12/02/2019	0.0	0.0	0.0	0.0
12/03/2019	0.0	0.0	0.0	0.0
12/04/2019	0.0	0.1	0.0	0.1
12/05/2019	9.4	1.0	8.9	1.0
12/06/2019	0.0	0.0	0.0	0.0
12/07/2019	0.0	0.0	0.0	0.0
12/08/2019	0.0	0.0	0.0	0.0
12/09/2019	0.0	0.0	0.0	0.0
12/10/2019	0.0	0.0	0.0	0.0
12/11/2019	0.0	0.0	0.0	0.0
12/12/2019	0.0	0.0	0.0	0.0
12/13/2019	0.0	0.0	0.0	0.0
12/14/2019	0.0	0.0	0.0	0.0
12/15/2019	0.0	0.0	0.0	0.0
12/16/2019	0.0	0.0	0.0	0.0
12/17/2019	0.0	0.0	0.0	0.0
12/18/2019	0.0	0.0	0.0	0.0
12/19/2019	0.0	0.0	0.0	0.0
12/20/2019	0.0	0.0	0.0	0.0
12/21/2019	0.0	0.0	0.0	0.0
12/22/2019	0.0	0.0	0.0	0.0
12/23/2019	0.0	0.0	0.0	0.0
12/24/2019	0.0	0.0	0.0	0.0
12/25/2019	0.0	0.0	0.0	0.0
12/26/2019	0.0	0.0	0.0	0.0
12/27/2019	0.0	0.0	0.0	0.0
12/28/2019	0.0	0.0	0.0	0.0
12/29/2019	0.0	0.0	0.0	0.0
12/30/2019	0.0	0.0	0.0	0.0
12/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	9.4 *	1.1 *	8.9 *	1.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	9.4	1.0	8.9	1.0
Oct 2019 - Dec 2019	180.6	53.9	620.3	149.4
QTD:	180.6 *	53.9 *	620.3 *	149.4 *
YTD 2019:	666.4 *	217.7 *	1,268.7 *	419.4 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.00	0.00	0.00
10/02/2019	0.00	0.00	0.00	0.00	0.00
10/03/2019	0.00	0.00	0.00	0.00	0.00
10/04/2019	0.00	0.00	0.00	0.00	0.00
10/05/2019	0.00	0.00	0.00	0.00	0.00
10/06/2019	0.00	0.00	0.00	0.00	0.00
10/07/2019	0.00	0.00	0.00	0.00	0.00
10/08/2019	0.00	0.00	0.00	0.00	0.00
10/09/2019	0.00	0.00	0.00	0.00	0.00
10/10/2019	0.00	0.00	0.00	0.00	0.00
10/11/2019	0.00	0.00	0.00	0.00	0.00
10/12/2019	0.00	0.00	0.00	0.00	0.00
10/13/2019	0.00	0.00	0.00	0.00	0.00
10/14/2019	0.00	0.00	0.00	0.00	0.00
10/15/2019	0.00	0.00	0.00	0.00	0.00
10/16/2019	0.00	0.00	0.00	0.00	0.00
10/17/2019	0.00	0.00	0.00	0.00	0.00
10/18/2019	0.00	0.00	0.00	0.00	0.00
10/19/2019	0.00	0.00	0.00	0.00	0.00
10/20/2019	0.00	0.00	0.00	0.00	0.00
10/21/2019	46.26	65.45	5.04	10.08	16.78
10/22/2019	18.36	60.33	5.92	11.84	19.73
10/23/2019	17.21	63.08	6.02	12.05	20.07
10/24/2019	54.98	85.19	6.82	13.72	22.83
10/25/2019	62.93	85.06	6.91	13.82	22.98
10/26/2019	19.60	50.83	4.86	9.69	16.16
10/27/2019	17.37	52.71	5.05	10.06	16.77
10/28/2019	22.77	62.36	5.98	11.99	20.01
10/29/2019	338.32	102.83	8.10	16.22	27.04
10/30/2019	45.65	75.70	7.38	14.74	24.57
10/31/2019	18.36	79.67	7.63	15.28	25.48
Monthly Avg/Sum*:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
Daily Min:	17.21	50.83	4.86	9.69	16.16
Daily Max:	338.32	102.83	8.10	16.22	27.04
Oct 2019 - Oct 2019	661.81	783.21	69.71	139.49	232.42
QTD:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
YTD 2019:	5,142.90 *	13,106.22 *	1,216.27 *	2,433.64 *	4,055.91 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.00	13.94	23.22
11/02/2019	22.69	65.84	6.26	12.58	20.98
11/03/2019	21.34	61.80	5.88	11.73	19.64
11/04/2019	18.26	69.40	6.64	13.25	22.10
11/05/2019	52.08	100.71	8.53	17.03	28.37
11/06/2019	42.42	126.86	11.97	23.94	39.94
11/07/2019	83.67	109.38	9.41	18.78	31.34
11/08/2019	62.35	113.46	9.84	19.71	32.81
11/09/2019	36.76	59.05	5.65	11.25	18.79
11/10/2019	23.22	57.70	5.53	10.99	18.37
11/11/2019	48.40	72.13	6.02	12.04	20.05
11/12/2019	40.18	63.34	5.81	11.64	19.40
11/13/2019	72.57	112.30	9.86	19.70	32.85
11/14/2019	58.46	111.34	10.52	21.00	35.12
11/15/2019	19.85	1.69	0.04	0.08	0.13
11/16/2019	0.00	0.00	0.00	0.00	0.00
11/17/2019	0.00	0.00	0.00	0.00	0.00
11/18/2019	0.00	0.00	0.00	0.00	0.00
11/19/2019	0.00	0.00	0.00	0.00	0.00
11/20/2019	41.86	21.26	0.75	1.51	2.52
11/21/2019	97.32	110.63	8.34	16.73	27.87
11/22/2019	41.89	125.41	11.96	23.91	39.92
11/23/2019	13.86	1.69	0.04	0.07	0.12
11/24/2019	0.00	0.00	0.00	0.00	0.00
11/25/2019	0.00	0.00	0.00	0.00	0.00
11/26/2019	128.07	128.26	9.81	19.66	32.75
11/27/2019	38.45	115.86	11.04	22.08	36.74
11/28/2019	36.18	104.67	9.95	19.92	33.17
11/29/2019	38.55	113.72	10.82	21.67	36.10
11/30/2019	37.78	110.86	10.67	21.38	35.55
Monthly Avg/Sum*:	1,101.16 *	2,030.35 *	182.34 *	364.59 *	607.85 *
Daily Min:	13.86	1.69	0.04	0.07	0.12
Daily Max:	128.07	128.26	11.97	23.94	39.94
Oct 2019 - Nov 2019	1,762.97	2,813.56	252.05	504.08	840.27
QTD:	1,762.97 *	2,813.56 *	252.05 *	504.08 *	840.27 *
YTD 2019:	6,244.06 *	15,136.57 *	1,398.61 *	2,798.23 *	4,663.76 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2019	38.31	107.26	10.49	20.91	34.80
12/02/2019	35.09	125.41	11.96	23.89	39.79
12/03/2019	35.34	116.36	11.06	22.04	36.78
12/04/2019	31.69	132.56	12.65	25.26	42.06
12/05/2019	29.57	2.15	0.02	0.04	0.08
12/06/2019	0.00	0.00	0.00	0.00	0.00
12/07/2019	0.00	0.00	0.00	0.00	0.00
12/08/2019	0.00	0.00	0.00	0.00	0.00
12/09/2019	0.00	0.00	0.00	0.00	0.00
12/10/2019	0.00	0.00	0.00	0.00	0.00
12/11/2019	0.00	0.00	0.00	0.00	0.00
12/12/2019	0.00	0.00	0.00	0.00	0.00
12/13/2019	0.00	0.00	0.00	0.00	0.00
12/14/2019	0.00	0.00	0.00	0.00	0.00
12/15/2019	0.00	0.00	0.00	0.00	0.00
12/16/2019	0.00	0.00	0.00	0.00	0.00
12/17/2019	0.00	0.00	0.00	0.00	0.00
12/18/2019	0.00	0.00	0.00	0.00	0.00
12/19/2019	0.00	0.00	0.00	0.00	0.00
12/20/2019	0.00	0.00	0.00	0.00	0.00
12/21/2019	0.00	0.00	0.00	0.00	0.00
12/22/2019	0.00	0.00	0.00	0.00	0.00
12/23/2019	0.00	0.00	0.00	0.00	0.00
12/24/2019	0.00	0.00	0.00	0.00	0.00
12/25/2019	0.00	0.00	0.00	0.00	0.00
12/26/2019	0.00	0.00	0.00	0.00	0.00
12/27/2019	0.00	0.00	0.00	0.00	0.00
12/28/2019	0.00	0.00	0.00	0.00	0.00
12/29/2019	0.00	0.00	0.00	0.00	0.00
12/30/2019	0.00	0.00	0.00	0.00	0.00
12/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	170.00 *	483.74 *	46.18 *	92.14 *	153.51 *
Daily Min:	29.57	2.15	0.02	0.04	0.08
Daily Max:	38.31	132.56	12.65	25.26	42.06
Oct 2019 - Dec 2019	1,932.97	3,297.30	298.23	596.22	993.78
QTD:	1,932.97 *	3,297.30 *	298.23 *	596.22 *	993.78 *
YTD 2019:	6,414.06 *	15,620.31 *	1,444.79 *	2,890.37 *	4,817.27 *

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/01/2019 00:00	10/24/2019 12:00	565
11/12/2019 01:00	11/13/2019 05:00	29
11/15/2019 00:00	11/21/2019 04:00	149
11/23/2019 00:00	11/26/2019 05:00	78
12/05/2019 01:00	12/31/2019 23:00	647

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,468.00 Hour(s)
Offline Percentage:	66.49 %
Total Online:	740.00 Hour(s)
Online Percentage:	33.51 %

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/24/2019 13:43	10/24/2019 14:44	Cold Startup	62
2	11/12/2019 00:16	11/12/2019 00:24	Shutdown	9
3	11/13/2019 06:44	11/13/2019 07:39	Cold Startup	56
4	11/14/2019 23:49	11/14/2019 23:58	Shutdown	10
5	11/21/2019 05:43	11/21/2019 06:36	Cold Startup	54
6	11/22/2019 23:56	11/22/2019 23:59	Shutdown	4
7	11/26/2019 06:03	11/26/2019 06:56	Cold Startup	54
8	12/04/2019 23:58	12/05/2019 00:06	Shutdown	9

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	226	0.51
Warm Startup	0		0.00
Shutdown	4	32	0.07
Total Process Events:	8	258	0.58

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	736.30 Hour(s)
Total Startup Time:	226 Minute(s)
Total Shutdown Time:	32 Minute(s)
Total Startup/Shutdown Time:	258 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.58 %

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/01/2019 00:00	10/21/2019 04:00	485
10/24/2019 20:00	10/25/2019 12:00	17
10/25/2019 19:00	10/29/2019 02:00	80
10/29/2019 06:00	10/29/2019 08:00	3
10/29/2019 14:00	10/30/2019 06:00	17
10/30/2019 12:00	11/05/2019 12:00	145
11/07/2019 01:00	11/07/2019 09:00	9
11/07/2019 22:00	11/08/2019 08:00	11
11/09/2019 01:00	11/11/2019 22:00	70
11/15/2019 01:00	11/20/2019 02:00	122
11/20/2019 08:00	11/21/2019 05:00	22
11/23/2019 01:00	11/26/2019 02:00	74
12/05/2019 01:00	12/31/2019 23:00	647

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,702.00 Hour(s)
Offline Percentage:	77.08 %
Total Online:	506.00 Hour(s)
Online Percentage:	22.92 %

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/21/2019 05:43	10/21/2019 06:33	Cold Startup	51
2	10/24/2019 18:50	10/24/2019 19:03	Shutdown	14
3	10/25/2019 13:43	10/25/2019 14:33	Cold Startup	51
4	10/25/2019 18:50	10/25/2019 18:59	Shutdown	10
5	10/29/2019 03:44	10/29/2019 04:02	Cold Startup	19
6	10/29/2019 04:02	10/29/2019 04:02	Shutdown	1
7	10/29/2019 04:12	10/29/2019 04:34	Cold Startup	23
8	10/29/2019 04:34	10/29/2019 04:34	Shutdown	1
9	10/29/2019 05:44	10/29/2019 05:52	Cold Startup	9
10	10/29/2019 05:51	10/29/2019 05:52	Shutdown	2
11	10/29/2019 09:04	10/29/2019 09:12	Cold Startup	9
12	10/29/2019 09:12	10/29/2019 09:12	Shutdown	1
13	10/29/2019 10:59	10/29/2019 11:06	Cold Startup	8
14	10/29/2019 11:06	10/29/2019 11:06	Shutdown	1
15	10/29/2019 11:17	10/29/2019 11:17	Cold Startup	1
16	10/29/2019 11:17	10/29/2019 11:17	Shutdown	1
17	10/29/2019 12:56	10/29/2019 13:03	Cold Startup	8
18	10/29/2019 13:02	10/29/2019 13:03	Shutdown	2
19	10/29/2019 13:13	10/29/2019 13:17	Cold Startup	5
20	10/29/2019 13:17	10/29/2019 13:17	Shutdown	1
21	10/30/2019 07:22	10/30/2019 08:50	Cold Startup	89
22	10/30/2019 11:46	10/30/2019 11:54	Shutdown	9

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	11/05/2019 13:44	11/05/2019 14:35	cold Startup	52
24	11/06/2019 23:52	11/07/2019 00:01	Shutdown	10
25	11/07/2019 10:43	11/07/2019 11:31	cold Startup	49
26	11/07/2019 21:06	11/07/2019 21:14	Shutdown	9
27	11/08/2019 09:43	11/08/2019 10:32	cold Startup	50
28	11/08/2019 23:55	11/09/2019 00:04	Shutdown	10
29	11/11/2019 23:29	11/12/2019 00:22	cold Startup	54
30	11/15/2019 00:07	11/15/2019 00:16	Shutdown	10
31	11/20/2019 03:44	11/20/2019 04:37	cold Startup	54
32	11/20/2019 07:01	11/20/2019 07:09	Shutdown	9
33	11/21/2019 06:45	11/21/2019 07:33	cold Startup	49
34	11/23/2019 00:06	11/23/2019 00:14	Shutdown	9
35	11/26/2019 03:45	11/26/2019 04:40	cold Startup	56
36	12/04/2019 23:58	12/05/2019 00:06	Shutdown	9

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	18	637	2.19
Warm Startup	0		0.00
Shutdown	18	109	0.37
Total Process Events:	36	746	2.56

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	485.83 Hour(s)
Total Startup Time:	637 Minute(s)
Total Shutdown Time:	109 Minute(s)
Total Startup/Shutdown Time:	746 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.56 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 13:38	0			0			0			0			0			0		
10/24/19 13:39	0			0			0			0			0			0		
10/24/19 13:40	0			0			0			0			0			0		
10/24/19 13:41	0			0			0			0			0			0		
10/24/19 13:42	0			0			0			0			0			0		
10/24/19 13:43	0			0.3			0			0			0			0		1
10/24/19 13:44	8240.7			0.3			0			0			0			0		1
10/24/19 13:45	29189.1			1			0.1			0			0			0		1
10/24/19 13:46	43128.9			558.1			18.29			62.72			3.38			1		1
10/24/19 13:47	57607.9			416.9			20.32			60.94			4.89			1		1
10/24/19 13:48	87490.1			222.4			25.96			47.4			9.1			1		1
10/24/19 13:49	131004.2			112.9			37.55			35.41			19.38			1		1
10/24/19 13:50	137935.6			37.1			59.42			12.26			32.33			1		1
10/24/19 13:51	153569.8			908.2			56.79			331.18			34.08			1		1
10/24/19 13:52	174441.2			1600			52.38			664.72			35.82			1		1
10/24/19 13:53	198778.2			393.6			65.83			185.9			51.17			1		1
10/24/19 13:54	222961.2			25.9			70.8			13.71			61.71			1		1
10/24/19 13:55	243524.5			2.5			72.92			1.43			69.28			1		1
10/24/19 13:56	269324.8			1.8			67.85			1.13			70.69			1		1
10/24/19 13:57	289272			1.7			52.72			1.17			59.02			1		1
10/24/19 13:58	293276.8			1.9			27.09			1.29			30.62			1		1
10/24/19 13:59	293584.9			2			19.61			1.38			22.23			1		1
10/24/19 14:00	292583.7			1.9			16.52			1.31			18.75			1		1
10/24/19 14:01	291890.5			1.7			13.89			1.18			15.67			1		1
10/24/19 14:02	291043.3			1.7			12.26			1.14			13.82			1		1
10/24/19 14:03	290658.3			1.6			10.51			1.08			11.88			1		1
10/24/19 14:04	295279.3			1.5			9.5			1.03			10.87			1		1
10/24/19 14:05	302672.8			1.4			8.76			0.98			10.26			1		1
10/24/19 14:06	303597			1.3			8.48			0.92			9.98			1		1
10/24/19 14:07	305060.3			1.2			8.3			0.86			9.8			1		1
10/24/19 14:08	315149.3			1.2			7.84			0.89			9.53			1		1
10/24/19 14:09	315842.5			1.1			7.28			0.83			8.97			1		1
10/24/19 14:10	315688.5			1.1			7.1			0.82			8.66			1		1
10/24/19 14:11	315534.4			1.1			7.01			0.83			8.6			1		1
10/24/19 14:12	314610.3			1			6.91			0.76			8.49			1		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 14:13	318846.1			1			6.82			0.77			8.53			1		
10/24/19 14:14	325854.6			1			6.56			0.8			8.39			1		
10/24/19 14:15	326547.7			0.9			6.37			0.73			8.17			1		
10/24/19 14:16	326470.7			0.9			6.46			0.73			8.29			1		
10/24/19 14:17	326547.7			0.9			6.56			0.73			8.42			1		
10/24/19 14:18	326239.7			0.9			6.56			0.73			8.41			1		
10/24/19 14:19	326316.7			0.9			6.65			0.73			8.53			1		
10/24/19 14:20	325238.4			0.9			6.74			0.73			8.61			1		
10/24/19 14:21	321310.6			0.8			6.84			0.65			8.63			1		
10/24/19 14:22	305214.3			0.8			7.12			0.61			8.54			1		
10/24/19 14:23	299669.2			0.9			7.84			0.66			9.23			1		
10/24/19 14:24	298976			0.9			7.96			0.67			9.35			1		
10/24/19 14:25	299284.1			0.9			7.96			0.67			9.37			1		
10/24/19 14:26	299130			0.8			8.15			0.6			9.59			1		
10/24/19 14:27	290889.3			0.8			6.27			0.59			7.19			1		
10/24/19 14:28	284497			0.8			3			0.57			3.36			1		
10/24/19 14:29	284728.1			0.9			2.47			0.58			2.77			1		
10/24/19 14:30	286345.4			0.7			2.34			0.51			2.64			1		
10/24/19 14:31	292044.6			0.7			2.34			0.52			2.68			1		
10/24/19 14:32	291274.4			0.7			2.49			0.51			2.85			1		
10/24/19 14:33	290504.3			0.7			2.86			0.51			3.26			1		
10/24/19 14:34	290196.2			0.7			3.04			0.51			3.46			1		
10/24/19 14:35	290119.2			0.7			3.23			0.51			3.67			1		
10/24/19 14:36	290581.3			0.7			3.13			0.51			3.57			1		
10/24/19 14:37	290966.3			0.7			2.95			0.51			3.35			1		
10/24/19 14:38	289195			0.7			2.67			0.51			3.03			1		
10/24/19 14:39	288039.8			0.7			2.4			0.5			2.7			1		
10/24/19 14:40	288886.9			0.7			2.3			0.51			2.6			1		
10/24/19 14:41	288501.8			0.7			2.12			0.51			2.4			1		
10/24/19 14:42	288578.8			0.7			2.03			0.51			2.29			1		
10/24/19 14:43	288270.8			0.7			1.94			0.51			2.18			1		
10/24/19 14:44	288501.8			0.7			1.84			0.5			2.08			1		
10/24/19 14:45	288732.9			0.7			1.75			0.51			1.98			0		
10/24/19 14:46	288963.9			0.7			1.66			0.51			1.88			0		
10/24/19 14:47	288886.9			0.7			1.66			0.51			1.88			0		
10/24/19 14:48	288578.8			0.7			1.66			0.51			1.88			0		
10/24/19 14:49	288655.9			0.7			1.57			0.51			1.77			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 0:11	294509.1			1			1.27			0.71			1.48			0		
11/12/19 0:12	294355			1			1.27			0.71			1.48			0		
11/12/19 0:13	294355			1			1.36			0.7			1.58			0		
11/12/19 0:14	294047			1			1.36			0.71			1.58			0		
11/12/19 0:15	293892.9			1			1.45			0.7			1.69			0		
11/12/19 0:16	289811.1			1			1.45			0.69			1.66			1		
11/12/19 0:17	270018			1			1.54			0.65			1.65			1		
11/12/19 0:18	246143			1			4.06			0.6			3.97			1		
11/12/19 0:19	227274.1			1			7.61			0.52			6.85			1		
11/12/19 0:20	201396.8			0.8			12.32			0.4			9.89			1		
11/12/19 0:21	177213.8			3			14.64			1.27			10.38			1		
11/12/19 0:22	155572.3			96.6			16.93			36.77			10.61			1		
11/12/19 0:23	137242.5			857.6			18.44			288.71			10.22			1		
11/12/19 0:24	59148.3			1776.7			19.22			264.88			4.71			1		
11/12/19 0:25	0			0			21.03			17.26			0.26			0		
11/12/19 0:26	0			0			0.3			0			0			0		
11/12/19 0:27	0			0			0.1			0			0			0		
11/12/19 0:28	0			0			0.1			0			0			0		
11/12/19 0:29	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/13/19 6:39	0			0			0			0			0			0		
11/13/19 6:40	0			0			0			0			0			0		
11/13/19 6:41	0			0			0			0			0			0		
11/13/19 6:42	0			0			0			0			0			0		
11/13/19 6:43	0			0			0			0			0			0		
11/13/19 6:44	0			0.5			0			0			0			0		1
11/13/19 6:45	0			0.5			0			0			0			0		1
11/13/19 6:46	0			45.2			31.47			0.05			0.06			0		1
11/13/19 6:47	27263.7			623.7			16.66			40.35			1.77			0		1
11/13/19 6:48	52139.8			468.3			21.74			58.8			4.49			0		1
11/13/19 6:49	99042.5			295.9			27.44			69.81			10.65			0		1
11/13/19 6:50	135471.1			157.2			39.5			50.69			20.96			0		1
11/13/19 6:51	140477.1			99.7			57.82			33.5			31.97			0		1
11/13/19 6:52	158113.8			1683.7			49.41			631.67			30.51			0		1
11/13/19 6:53	178292			1836.1			53.45			780.09			37.37			0		1
11/13/19 6:54	202552			747.3			58.85			359.84			46.63			0		1
11/13/19 6:55	226966.1			63.7			60.84			34.39			54.03			0		1
11/13/19 6:56	246220.1			6			58.65			3.53			56.67			0		1
11/13/19 6:57	274639			2.4			51.52			1.59			55.48			0		1
11/13/19 6:58	293122.8			2.2			36.54			1.52			41.83			0		1
11/13/19 6:59	294971.2			2.1			22.54			1.48			25.97			0		1
11/13/19 7:00	294278			2.3			15.53			1.58			17.85			0		1
11/13/19 7:01	297512.7			2.2			12.75			1.53			14.84			0		1
11/13/19 7:02	310297.3			2			10.83			1.49			13.12			0		1
11/13/19 7:03	313069.9			1.9			8.45			1.44			10.34			0		1
11/13/19 7:04	313840.1			1.8			7.98			1.36			9.78			0		1
11/13/19 7:05	327548.9			1.7			7.29			1.35			9.32			0		1
11/13/19 7:06	332323.9			1.6			6.77			1.3			8.78			0		1
11/13/19 7:07	332940.1			1.6			6.25			1.25			8.13			0		1
11/13/19 7:08	335096.5			1.5			6.25			1.19			8.18			0		1
11/13/19 7:09	342104.9			1.4			5.99			1.14			8			0		1
11/13/19 7:10	347727.1			1.4			5.46			1.16			7.41			0		1
11/13/19 7:11	361204.9			1.3			5.36			1.15			7.57			0		1
11/13/19 7:12	369137.6			1.3			4.63			1.11			6.67			0		1
11/13/19 7:13	371833.1			1.2			4.79			1.06			6.96			0		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/13/19 7:14	375067.8			1.2			4.9			1.05			7.18			1		
11/13/19 7:15	378148.4			1.1			5.08			0.98			7.51			1		
11/13/19 7:16	378533.5			1.1			5.17			0.98			7.65			1		
11/13/19 7:17	364208.5			1.1			5.54			0.94			7.88			1		
11/13/19 7:18	345108.6			1.1			6.17			0.88			8.31			1		
11/13/19 7:19	326316.7			1.1			6.16			0.89			7.85			1		
11/13/19 7:20	325777.6			1.1			6.16			0.88			7.84			1		
11/13/19 7:21	333710.2			1.1			6.08			0.91			7.92			1		
11/13/19 7:22	334788.4			1.2			6.08			0.92			7.95			1		
11/13/19 7:23	335019.5			1.2			6.08			0.92			7.95			1		
11/13/19 7:24	334865.4			1.2			6.08			0.92			7.96			1		
11/13/19 7:25	334249.3			1.2			5.01			0.92			6.53			1		
11/13/19 7:26	333325.1			1.2			3.31			0.92			4.3			1		
11/13/19 7:27	328781.2			1.2			2.77			0.91			3.56			1		
11/13/19 7:28	327240.9			1.1			2.73			0.89			3.49			1		
11/13/19 7:29	327471.9			1.1			2.77			0.83			3.55			1		
11/13/19 7:30	327703			1.1			2.77			0.83			3.55			1		
11/13/19 7:31	327625.9			1.1			2.77			0.84			3.55			1		
11/13/19 7:32	327086.8			1.1			2.68			0.83			3.43			1		
11/13/19 7:33	327086.8			1.1			2.59			0.83			3.31			1		
11/13/19 7:34	327471.9			1.1			2.41			0.83			3.09			1		
11/13/19 7:35	327471.9			1.1			2.23			0.83			2.86			1		
11/13/19 7:36	327317.9			1.1			2.06			0.83			2.63			1		
11/13/19 7:37	325854.6			1.1			1.97			0.83			2.51			1		
11/13/19 7:38	325315.5			1.2			1.79			0.9			2.27			1		
11/13/19 7:39	325084.4			1.2			1.7			0.9			2.16			1		
11/13/19 7:40	324930.4			1.2			1.61			0.9			2.04			0		
11/13/19 7:41	325084.4			1.2			1.61			0.9			2.04			0		
11/13/19 7:42	324391.3			1.2			1.61			0.89			2.04			0		
11/13/19 7:43	324391.3			1.2			1.52			0.9			1.93			0		
11/13/19 7:44	324622.3			1.2			1.61			0.9			2.04			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 23:44	296357.5			0.9			1.72			0.65			2.03			0		
11/14/19 23:45	297050.6			0.9			1.72			0.65			2.02			0		
11/14/19 23:46	296742.5			0.9			1.72			0.65			2.02			0		
11/14/19 23:47	296742.5			0.9			1.63			0.65			1.92			0		
11/14/19 23:48	296357.5			0.9			1.72			0.64			2.02			0		
11/14/19 23:49	296665.5			0.9			1.72			0.65			2.03			1		
11/14/19 23:50	285113.1			0.9			1.72			0.62			1.95			1		
11/14/19 23:51	262316.4			0.9			2			0.57			2.07			1		
11/14/19 23:52	238518.5			0.9			5.99			0.54			5.67			1		
11/14/19 23:53	218494.3			0.9			9.34			0.47			8.08			1		
11/14/19 23:54	192077.8			0.7			15.49			0.34			11.84			1		
11/14/19 23:55	168433.9			4			18.05			1.64			12.16			1		
11/14/19 23:56	149257			237.5			19.58			86.01			11.67			1		
11/14/19 23:57	131081.2			1313.7			20.03			419.04			10.51			1		
11/14/19 23:58	6623.4			1870.1			21.1			45.63			0.85			1		
11/14/19 23:59	0			0			23.01			18.21			0.2			0		
11/15/19 0:00	0			0			0.2			0			0			0		
11/15/19 0:01	0			0			0.1			0			0			0		
11/15/19 0:02	0			0			0.1			0			0			0		
11/15/19 0:03	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 5:38	0			0			0			0			0			0		
11/21/19 5:39	0			0			0			0			0			0		
11/21/19 5:40	0			0			0			0			0			0		
11/21/19 5:41	0			0			0			0			0			0		
11/21/19 5:42	0			0			0			0			0			0		
11/21/19 5:43	0			0.5			0			0			0			0		1
11/21/19 5:44	0			0.5			0			0			0			0		1
11/21/19 5:45	4389.9			39.3			29.5			0.45			0.55			0		1
11/21/19 5:46	31037.4			609.8			16.66			44.91			2.02			0		1
11/21/19 5:47	55374.5			490.4			21.63			64.43			4.68			0		1
11/21/19 5:48	105742.9			293.2			25.96			73.58			10.72			0		1
11/21/19 5:49	134855			149.5			37.37			47.98			19.74			0		1
11/21/19 5:50	137396.5			174.1			52.31			56.92			28.16			0		1
11/21/19 5:51	156265.4			1883.4			38.06			698.17			23.22			0		1
11/21/19 5:52	177598.8			1860.1			39.74			784.02			27.57			0		1
11/21/19 5:53	200780.6			876.4			49.02			418.44			38.52			0		1
11/21/19 5:54	225656.8			109.7			58.2			58.83			51.37			0		1
11/21/19 5:55	245603.9			7.4			61.6			4.34			59.18			0		1
11/21/19 5:56	273098.6			2.7			58.89			1.74			62.9			0		1
11/21/19 5:57	297358.7			2.4			46.43			1.71			54.05			0		1
11/21/19 5:58	316612.7			2.3			27.39			1.72			33.9			0		1
11/21/19 5:59	335096.5			2.5			15.65			1.98			20.53			0		1
11/21/19 6:00	352348.1			2.6			13.6			2.14			18.71			0		1
11/21/19 6:01	370369.8			2.4			10.76			2.14			15.56			0		1
11/21/19 6:02	392165.3			2.2			9.12			2.08			13.98			0		1
11/21/19 6:03	410957.2			2			8.35			1.95			13.4			0		1
11/21/19 6:04	417965.7			1.8			7.44			1.8			12.15			0		1
11/21/19 6:05	419737.1			1.6			7.08			1.63			11.6			0		1
11/21/19 6:06	419660			1.5			6.72			1.54			11.02			0		1
11/21/19 6:07	419814.1			1.6			6.36			1.56			10.43			0		1
11/21/19 6:08	419352			1.5			6.27			1.47			10.27			0		1
11/21/19 6:09	418735.8			1.5			6.27			1.47			10.25			0		1
11/21/19 6:10	417580.6			1.4			6.08			1.37			9.93			0		1
11/21/19 6:11	417195.5			1.3			5.99			1.28			9.76			0		1
11/21/19 6:12	416348.3			1.3			5.9			1.27			9.59			0		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 6:13	416040.3			1.2			5.9			1.19			9.6			1		
11/21/19 6:14	415578.2			1.2			5.81			1.18			9.42			1		
11/21/19 6:15	415347.1			1.2			5.81			1.18			9.42			1		
11/21/19 6:16	415347.1			1.1			5.81			1.09			9.44			1		
11/21/19 6:17	414808			1.1			5.9			1.09			9.56			1		
11/21/19 6:18	414500			1.1			5.9			1.09			9.56			1		
11/21/19 6:19	414037.9			1.1			5.99			1.09			9.69			1		
11/21/19 6:20	413806.8			1.1			6.08			1.09			9.84			1		
11/21/19 6:21	413883.8			1.1			6.18			1.09			9.99			1		
11/21/19 6:22	413729.8			1.1			5.99			1.09			9.69			1		
11/21/19 6:23	413267.7			1.1			4.06			1.08			6.55			1		
11/21/19 6:24	413036.7			1.1			2.67			1.08			4.31			1		
11/21/19 6:25	413113.7			1.1			2.58			1.08			4.16			1		
11/21/19 6:26	412882.6			1.1			2.58			1.09			4.17			1		
11/21/19 6:27	412574.6			1.2			2.67			1.17			4.31			1		
11/21/19 6:28	412497.6			1.2			2.86			1.17			4.6			1		
11/21/19 6:29	412728.6			1.2			2.86			1.18			4.62			1		
11/21/19 6:30	412651.6			1.1			2.86			1.09			4.61			1		
11/21/19 6:31	412343.5			1.1			2.58			1.08			4.16			1		
11/21/19 6:32	412266.5			1.1			2.4			1.08			3.86			1		
11/21/19 6:33	412035.4			1.1			2.12			1.08			3.42			1		
11/21/19 6:34	411958.4			1.1			1.94			1.08			3.11			1		
11/21/19 6:35	411727.4			1.1			1.84			1.08			2.96			1		
11/21/19 6:36	411804.4			1.1			1.75			1.08			2.82			1		
11/21/19 6:37	411804.4			1.1			1.75			1.09			2.83			0		
11/21/19 6:38	411111.3			1.1			1.66			1.08			2.67			0		
11/21/19 6:39	411727.4			1.1			1.66			1.08			2.68			0		
11/21/19 6:40	411419.3			1.1			1.66			1.08			2.67			0		
11/21/19 6:41	411650.4			1.1			1.66			1.08			2.67			0		

CT1 SUSD EVENT 6

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/19 23:51	399250.8			1			1.75			0.97			2.75			0		
11/22/19 23:52	380689.9			1			1.82			0.91			2.72			0		
11/22/19 23:53	362052.1			1.1			1.88			0.93			2.68			0		
11/22/19 23:54	338485.2			1.1			2.03			0.86			2.7			0		
11/22/19 23:55	313917.1			1.1			2.11			0.86			2.6			0		
11/22/19 23:56	301286.5			1.1			2.03			0.82			2.4			1		
11/22/19 23:57	280800.3			1.1			1.76			0.77			1.95			1		
11/22/19 23:58	258773.7			1.1			2.72			0.68			2.78			1		
11/22/19 23:59	22180.6			1			7.02			0.06			0.69			1		
11/23/19 0:00	0			0			11.11			0.12			0.11			0		
11/23/19 0:01	0			0			0.1			0			0			0		
11/23/19 0:02	0			0			0.1			0			0			0		
11/23/19 0:03	0			0			0.1			0			0			0		
11/23/19 0:04	0			0			0			0			0			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 5:58	0			0			0			0			0			0		
11/26/19 5:59	0			0			0			0			0			0		
11/26/19 6:00	0			0			0			0			0			0		
11/26/19 6:01	0			0			0			0			0			0		
11/26/19 6:02	0			0			0			0			0			0		
11/26/19 6:03	0			0.4			0			0			0			0		1
11/26/19 6:04	0			1.4			0.1			0			0			0		1
11/26/19 6:05	8240.7			790.6			19.67			16.99			0.7			0		1
11/26/19 6:06	38431			593.8			18.05			54.76			2.74			0		1
11/26/19 6:07	73550.3			419.9			23.6			73.69			6.82			0		1
11/26/19 6:08	125690.1			249.9			27.14			74.72			13.36			0		1
11/26/19 6:09	138474.7			116.3			46.49			38.47			25.3			0		1
11/26/19 6:10	143403.7			838.2			47.58			285.19			26.64			0		1
11/26/19 6:11	148024.7			2008.5			43.01			709			24.99			0		1
11/26/19 6:12	164275.1			1945.2			45.36			758.06			29.09			0		1
11/26/19 6:13	184299.2			1778.4			55.97			777.88			40.29			0		1
11/26/19 6:14	208944.3			665.8			71.25			330.11			58.14			0		1
11/26/19 6:15	232126.1			66.3			73.03			36.61			66.32			0		1
11/26/19 6:16	252458.4			6.4			66.67			3.82			65.85			0		1
11/26/19 6:17	279799			3			58.89			2			64.44			0		1
11/26/19 6:18	304136.1			2.6			40.24			1.89			47.85			0		1
11/26/19 6:19	323236			2.5			23.69			1.89			29.9			0		1
11/26/19 6:20	340718.7			2.6			13.08			2.08			17.43			0		1
11/26/19 6:21	358817.4			2.6			10.52			2.19			14.77			0		1
11/26/19 6:22	376531.1			2.4			8.81			2.13			12.99			0		1
11/26/19 6:23	398711.7			2.1			7.24			2.03			11.3			0		1
11/26/19 6:24	414654			1.9			6.35			1.88			10.33			0		1
11/26/19 6:25	418889.9			1.7			6.08			1.66			9.99			0		1
11/26/19 6:26	419583			1.5			5.9			1.45			9.69			0		1
11/26/19 6:27	419429			1.4			5.81			1.36			9.51			0		1
11/26/19 6:28	419352			1.3			5.63			1.27			9.23			0		1
11/26/19 6:29	417195.5			1.2			5.54			1.17			9.02			0		1
11/26/19 6:30	400714.1			1.2			5.54			1.12			8.68			0		1
11/26/19 6:31	381999.2			1.2			5.99			1.05			8.93			0		1
11/26/19 6:32	373450.4			1.2			6.26			1.03			9.15			0		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 6:33	371756.1			1.2			5.72			1.03			8.32			1		
11/26/19 6:34	370754.9			1.2			5.63			1.02			8.16			1		
11/26/19 6:35	370292.8			1.2			5.54			1.03			8.06			1		
11/26/19 6:36	370292.8			1.1			5.54			0.94			8.01			1		
11/26/19 6:37	370292.8			1.1			5.45			0.94			7.89			1		
11/26/19 6:38	370061.8			1.1			5.45			0.94			7.89			1		
11/26/19 6:39	369137.6			1.1			5.54			0.94			7.99			1		
11/26/19 6:40	371756.1			1.1			5.63			0.96			8.2			1		
11/26/19 6:41	373065.4			1.1			5.54			0.97			8.09			1		
11/26/19 6:42	373604.5			1.1			5.63			0.97			8.24			1		
11/26/19 6:43	375760.9			1.1			4.99			0.97			7.34			1		
11/26/19 6:44	376454.1			1.1			3.27			0.98			4.81			1		
11/26/19 6:45	376762.1			1.1			2.72			0.97			4.01			1		
11/26/19 6:46	379919.8			1.1			2.72			0.98			4.05			1		
11/26/19 6:47	377070.2			1.1			2.72			0.98			4.02			1		
11/26/19 6:48	368829.5			1.1			2.77			0.94			4.01			1		
11/26/19 6:49	363746.4			1.2			2.86			1			4.07			1		
11/26/19 6:50	361281.9			1.2			2.77			1			3.91			1		
11/26/19 6:51	360896.8			1.2			2.59			1			3.65			1		
11/26/19 6:52	364901.7			1.3			2.32			1.09			3.32			1		
11/26/19 6:53	372295.2			1.3			2.09			1.12			3.03			1		
11/26/19 6:54	375221.8			1.3			1.91			1.13			2.79			1		
11/26/19 6:55	386543.2			1.2			1.72			1.08			2.61			1		
11/26/19 6:56	395323			1.2			1.82			1.11			2.8			1		
11/26/19 6:57	403332.7			1.2			1.84			1.15			2.9			0		
11/26/19 6:58	410726.2			1.2			1.84			1.17			2.96			0		
11/26/19 6:59	412574.6			1.2			1.84			1.18			2.98			0		
11/26/19 7:00	412959.7			1.1			1.75			1.08			2.82			0		
11/26/19 7:01	412035.4			1.1			1.75			1.08			2.82			0		

CT1 SUSD EVENT 8

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 23:53	362899.3			0.6			2			0.55			2.83			0		
12/04/19 23:54	341796.9			0.7			2.06			0.58			2.75			0		
12/04/19 23:55	328704.2			0.7			2.11			0.55			2.72			0		
12/04/19 23:56	319000.2			0.8			2.11			0.6			2.63			0		
12/04/19 23:57	299207.1			0.8			2.03			0.56			2.37			0		
12/04/19 23:58	280107.1			0.8			1.88			0.54			2.06			1		
12/04/19 23:59	260314			0.7			2.18			0.45			2.23			1		
12/05/19 0:00	236439			0.7			5.81			0.37			5.41			1		
12/05/19 0:01	215182.6			0.5			9.24			0.25			7.83			1		
12/05/19 0:02	189305.3			0.3			14.91			0.15			11.18			1		
12/05/19 0:03	165969.4			3.4			17.1			1.35			11.24			1		
12/05/19 0:04	145483.2			227.2			18.24			79.58			10.51			1		
12/05/19 0:05	127307.4			1232.5			18.94			380.17			9.62			1		
12/05/19 0:06	10166.1			1893.4			19.49			65.27			1.11			1		
12/05/19 0:07	0			0			17.04			34.65			0.31			0		
12/05/19 0:08	0			0			0.2			0			0			0		
12/05/19 0:09	0			0			0.1			0			0			0		
12/05/19 0:10	0			0			0.1			0			0			0		
12/05/19 0:11	0			0			0.1			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 5:38	0			0			0			0			0			0		
10/21/19 5:39	0			0			0			0			0			0		
10/21/19 5:40	0			0			0			0			0			0		
10/21/19 5:41	0			0			0			0			0			0		
10/21/19 5:42	4852			0			0			0			0			0		
10/21/19 5:43	3003.6			0.6			0			0			0			0		1
10/21/19 5:44	20101.2			0.6			0			0			0			0		1
10/21/19 5:45	35350.3			2			0.3			0			0			0		1
10/21/19 5:46	46209.6			573.7			17.25			62.02			3.07			1		1
10/21/19 5:47	55759.6			498.1			18.32			65			3.93			1		1
10/21/19 5:48	77324			351.6			23.9			63.6			7.11			1		1
10/21/19 5:49	121069.1			224.2			25.75			63.49			12			1		1
10/21/19 5:50	135471.1			109.6			44.25			34.74			23.08			1		1
10/21/19 5:51	143557.8			373.2			49.97			125.3			27.61			1		1
10/21/19 5:52	161502.5			1866.8			38.35			705.37			23.85			1		1
10/21/19 5:53	180756.5			1337			42.78			565.35			29.77			1		1
10/21/19 5:54	202321			349			52.67			165.13			41.02			1		1
10/21/19 5:55	224116.5			28.7			55.74			15.07			48.09			1		1
10/21/19 5:56	242908.4			3.6			63.08			2.06			58.98			1		1
10/21/19 5:57	268477.7			2.6			65.41			1.66			67.61			1		1
10/21/19 5:58	290119.2			2.4			47.29			1.65			52.83			1		1
10/21/19 5:59	307370.8			2.4			26.81			1.75			31.72			1		1
10/21/19 6:00	324237.3			2.7			20.3			2.04			25.34			1		1
10/21/19 6:01	341642.8			2.7			16.4			2.15			21.57			1		1
10/21/19 6:02	355659.8			2.5			13.12			2.05			17.97			1		1
10/21/19 6:03	372141.2			2.2			11.8			1.95			16.91			1		1
10/21/19 6:04	392165.3			2			11.16			1.83			16.86			1		1
10/21/19 6:05	410957.2			1.9			10.23			1.86			16.19			1		1
10/21/19 6:06	409570.9			1.8			11.15			1.68			17.59			1		1
10/21/19 6:07	407799.6			1.8			10.88			1.67			17.08			1		1
10/21/19 6:08	408723.8			1.7			10.51			1.59			16.54			1		1
10/21/19 6:09	408184.7			1.6			10.42			1.5			16.37			1		1
10/21/19 6:10	409185.9			1.6			10.42			1.5			16.41			1		1
10/21/19 6:11	408877.8			1.5			10.51			1.41			16.54			1		1
10/21/19 6:12	407029.4			1.5			10.79			1.4			16.9			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 6:13	405874.2			1.5			10.88			1.4			17			1		
10/21/19 6:14	405412.1			1.5			10.97			1.4			17.12			1		
10/21/19 6:15	404873			1.5			11.06			1.4			17.24			1		
10/21/19 6:16	405181			1.5			11.25			1.4			17.54			1		
10/21/19 6:17	405951.2			1.5			11.43			1.4			17.86			1		
10/21/19 6:18	404950			1.4			11.71			1.31			18.25			1		
10/21/19 6:19	403486.7			1.4			12.08			1.31			18.76			1		
10/21/19 6:20	403255.6			1.4			12.35			1.3			19.18			1		
10/21/19 6:21	403948.8			1.4			10.79			1.31			16.77			1		
10/21/19 6:22	404795.9			1.4			5.07			1.31			7.9			1		
10/21/19 6:23	406875.4			1.4			3.78			1.32			5.92			1		
10/21/19 6:24	405181			1.4			3.5			1.31			5.46			1		
10/21/19 6:25	405951.2			1.4			3.32			1.31			5.19			1		
10/21/19 6:26	403640.7			1.4			3.04			1.31			4.73			1		
10/21/19 6:27	404564.9			1.4			2.77			1.31			4.31			1		
10/21/19 6:28	405335.1			1.4			2.43			1.33			3.8			1		
10/21/19 6:29	405566.1			1.4			2.12			1.31			3.31			1		
10/21/19 6:30	405104			1.4			1.94			1.31			3.02			1		
10/21/19 6:31	406490.3			1.4			1.75			1.31			2.74			1		
10/21/19 6:32	404333.8			1.4			1.66			1.31			2.58			1		
10/21/19 6:33	405181			1.4			1.48			1.31			2.3			1		
10/21/19 6:34	403794.8			1.4			1.38			1.31			2.15			0		
10/21/19 6:35	403255.6			1.4			1.38			1.3			2.15			0		
10/21/19 6:36	403024.6			1.4			1.29			1.3			2			0		
10/21/19 6:37	402331.4			1.4			1.29			1.3			2			0		
10/21/19 6:38	405104			1.4			1.2			1.31			1.87			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 18:45	378533.5			0.7			1.75			0.65			2.55			0		
10/24/19 18:46	376146			0.7			1.75			0.65			2.54			0		
10/24/19 18:47	376069			0.7			1.75			0.65			2.54			0		
10/24/19 18:48	373450.4			0.7			1.66			0.64			2.39			0		
10/24/19 18:49	374913.8			0.8			1.66			0.73			2.4			0		
10/24/19 18:50	373373.4			0.8			1.66			0.72			2.39			1		
10/24/19 18:51	359895.6			0.8			1.75			0.7			2.43			1		
10/24/19 18:52	339563.4			0.8			1.82			0.65			2.37			1		
10/24/19 18:53	317690.9			0.8			2.23			0.6			2.73			1		
10/24/19 18:54	296203.4			0.9			2.55			0.61			2.91			1		
10/24/19 18:55	275640.2			0.9			2.73			0.57			2.9			1		
10/24/19 18:56	255153.9			0.9			3.09			0.54			3.03			1		
10/24/19 18:57	233512.4			0.9			4.89			0.5			4.39			1		
10/24/19 18:58	217262.1			0.8			8.8			0.39			7.36			1		
10/24/19 18:59	192539.9			0.6			21.01			0.28			15.57			1		
10/24/19 19:00	170898.4			0.6			24.39			0.23			16.05			1		
10/24/19 19:01	150797.3			7.4			26.55			2.62			15.41			1		
10/24/19 19:02	133776.8			631.6			28.47			197.65			14.66			1		
10/24/19 19:03	77863.1			1659.2			28.83			302.33			8.64			1		
10/24/19 19:04	0			0			31.22			0			0			0		
10/24/19 19:05	0			0			11.8			0			0			0		
10/24/19 19:06	0			0			0.2			0			0			0		
10/24/19 19:07	0			0			0.1			0			0			0		
10/24/19 19:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 13:38	0			0			0			0			0			0		
10/25/19 13:39	0			0			0			0			0			0		
10/25/19 13:40	0			0			0			0			0			0		
10/25/19 13:41	0			0			0			0			0			0		
10/25/19 13:42	0			0			0			0			0			0		
10/25/19 13:43	10089.1			0			0			0			0			0		1
10/25/19 13:44	21872.5			0			0			0			0			0		1
10/25/19 13:45	34811.2			135.7			82.6			11.06			11.08			4.03		1
10/25/19 13:46	45054.3			458			23.23			48.29			4.03			5.51		1
10/25/19 13:47	55759.6			348.7			25.67			45.5			5.51			10.24		1
10/25/19 13:48	78248.2			202.6			34			37.09			10.24			19.34		1
10/25/19 13:49	117988.5			112.4			42.58			31.01			19.34			30.33		1
10/25/19 13:50	129925.9			37.2			60.63			11.32			30.33			34.3		1
10/25/19 13:51	135779.2			18.2			65.62			5.79			34.3			33.84		1
10/25/19 13:52	149025.9			1637.2			59			570.6			33.84			39.5		1
10/25/19 13:53	170128.3			994			60.31			395.61			39.5			45.74		1
10/25/19 13:54	191615.7			192.3			62.02			86.16			45.74			51.78		1
10/25/19 13:55	213026.2			11.9			63.14			5.94			51.78			61.19		1
10/25/19 13:56	234667.7			2.2			67.74			1.18			61.19			61.45		1
10/25/19 13:57	258080.5			1.8			61.85			1.11			61.45			42.68		1
10/25/19 13:58	275178.1			1.8			40.29			1.13			42.68			22.23		1
10/25/19 13:59	280184.1			1.8			20.6			1.19			22.23			18.13		1
10/25/19 14:00	288270.8			1.8			16.34			1.22			18.13			18.06		1
10/25/19 14:01	290427.2			1.7			16.16			1.17			18.06			17.86		1
10/25/19 14:02	302441.7			1.5			15.34			1.09			17.86			16.57		1
10/25/19 14:03	310605.4			1.4			13.86			1.04			16.57			14.83		1
10/25/19 14:04	316766.7			1.5			12.16			1.08			14.83			14.17		1
10/25/19 14:05	324468.3			1.4			11.34			1.05			14.17			12.84		1
10/25/19 14:06	338177.1			1.3			9.86			1.02			12.84			12.53		1
10/25/19 14:07	346032.8			1.1			9.4			0.9			12.53			12.47		1
10/25/19 14:08	347727.1			1			9.31	X		0.82			12.47	X		12.41		1
10/25/19 14:09	349575.5			0.9			9.22			0.75			12.41			12.6		1
10/25/19 14:10	351346.9			0.9			9.31			0.76			12.6			12.55		1
10/25/19 14:11	350037.6			0.9			9.31			0.75			12.55			12.65		1
10/25/19 14:12	353041.2			0.8			9.31			0.69			12.65					1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 14:13	351577.9			0.8			9.5			0.68			12.85			1		
10/25/19 14:14	350268.7			0.8			9.59			0.68			12.93			1		
10/25/19 14:15	351423.9			0.8			9.68			0.68			13.09			1		
10/25/19 14:16	350268.7			0.8			9.59			0.68			12.93			1		
10/25/19 14:17	349883.6			0.8			9.77			0.68			13.16			1		
10/25/19 14:18	349421.5			0.8			9.86			0.68			13.27			1		
10/25/19 14:19	343029.1			0.8			9.86			0.67			13.03			1		
10/25/19 14:20	324699.3			0.8			6.9			0.62			8.62			1		
10/25/19 14:21	316458.6			0.8			4.29			0.6			5.23			1		
10/25/19 14:22	319154.2			0.9			3.75			0.67			4.61			1		
10/25/19 14:23	319000.2			0.9			3.18			0.68			3.9			1		
10/25/19 14:24	308063.9			0.9			3.09			0.65			3.66			1		
10/25/19 14:25	302133.7			0.9			2.86			0.63			3.33			1		
10/25/19 14:26	301517.5			0.9			2.68			0.63			3.11			1		
10/25/19 14:27	299361.1			0.9			2.59			0.63			2.99			1		
10/25/19 14:28	297050.6			0.9			2.41			0.62			2.76			1		
10/25/19 14:29	296357.5			0.9			2.23			0.62			2.55			1		
10/25/19 14:30	298513.9			0.9			2.06			0.62			2.36			1		
10/25/19 14:31	297512.7			0.9			1.97			0.62			2.25			1		
10/25/19 14:32	296742.5			0.9			1.79			0.62			2.04			1		
10/25/19 14:33	295125.2			0.9			1.7			0.62			1.93			1		
10/25/19 14:34	295510.3			0.8			1.52			0.56			1.73			0		
10/25/19 14:35	294894.2			0.8			1.43			0.56			1.62			0		
10/25/19 14:36	292891.8			0.8			1.34			0.55			1.51			0		
10/25/19 14:37	294355			0.8			1.34			0.55			1.52			0		
10/25/19 14:38	295510.3			0.8			1.34			0.56			1.53			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 18:45	288270.8			0.8			1.63			0.55			1.81			0		
10/25/19 18:46	287269.6			0.8			1.63			0.55			1.81			0		
10/25/19 18:47	288578.8			0.8			1.63			0.55			1.82			0		
10/25/19 18:48	287115.5			0.8			1.63			0.55			1.81			0		
10/25/19 18:49	287192.6			0.8			1.72			0.55			1.91			0		
10/25/19 18:50	286037.3			0.8			1.72			0.55			1.9			1		
10/25/19 18:51	267630.5			0.8			1.72			0.51			1.78			1		
10/25/19 18:52	248299.5			0.7			1.82			0.42			1.74			1		
10/25/19 18:53	229969.7			0.7			4.68			0.4			4.15			1		
10/25/19 18:54	209406.4			0.7			8.46			0.34			6.82			1		
10/25/19 18:55	186763.7			0.5			17.08			0.23			12.28			1		
10/25/19 18:56	163273.9			2.2			20.01			0.84			12.58			1		
10/25/19 18:57	144559			122.3			22.55			41.37			12.55			1		
10/25/19 18:58	128385.6			860.8			25.26			258.58			12.49			1		
10/25/19 18:59	49675.3			1821.5			27.59			211.62			5.28			1		
10/25/19 19:00	0			0			36.58			0			0			0		
10/25/19 19:01	0			0			11.8			0			0			0		
10/25/19 19:02	0			0			0.1			0			0			0		
10/25/19 19:03	0			0			0.1			0			0			0		
10/25/19 19:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 3:39	0			0			0			0			0			0		
10/29/19 3:40	0			0			0			0			0			0		
10/29/19 3:41	0			0			0			0			0			0		
10/29/19 3:42	0			0			0			0			0			0		
10/29/19 3:43	0			0			0			0			0			0		
10/29/19 3:44	6238.3			0.1			0			0			0			1		
10/29/19 3:45	26262.4			0			0			0			0			1		
10/29/19 3:46	38431			73.8			29.5			6.64			4.37			1		
10/29/19 3:47	48597.1			573.8			15.86			65.25			2.97			1		
10/29/19 3:48	59533.3			494.9			19.67			68.91			4.51			1		
10/29/19 3:49	90185.7			335.7			25.15			70.78			8.73			1		
10/29/19 3:50	145637.2			202.7			25.48			69.07			14.29			1		
10/29/19 3:51	139861			432.9			45.37			141.68			24.44			1		
10/29/19 3:52	136703.3			1664.8			40.43			532.54			21.29			1		
10/29/19 3:53	134855			1987.7			43.7			626.93			22.68			1		
10/29/19 3:54	134007.8			2052.2			51.39			643.14			26.5			1		
10/29/19 3:55	133160.6			2053.6			61.09			639.88			31.33			1		
10/29/19 3:56	131312.2			2053.6			68.33			630.69			34.53			1		
10/29/19 3:57	130234			2122			71.39			646.49			35.79			1		
10/29/19 3:58	128308.6			2121.8			65.29			636.93			32.26			1		
10/29/19 3:59	127769.5			2121.2			61.36			633.9			30.18			1		
10/29/19 4:00	127384.4			2196.6			62.66			654.46			30.73			1		
10/29/19 4:01	136164.2			2198.9			62.05			700.41			32.53			1		
10/29/19 4:02	11321.3			2126			64.51			56.15			2.8			1		
10/29/19 4:03	0			0			78.01			0			0			0		
10/29/19 4:04	0			0			1.1			0			0			0		
10/29/19 4:05	0			0			0.9			0			0			0		
10/29/19 4:06	0			0			0.7			0			0			0		
10/29/19 4:07	0			0			0.6			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 3:57	130234			2122			71.39			646.49			35.79			1		
10/29/19 3:58	128308.6			2121.8			65.29			636.93			32.26			1		
10/29/19 3:59	127769.5			2121.2			61.36			633.9			30.18			1		
10/29/19 4:00	127384.4			2196.6			62.66			654.46			30.73			1		
10/29/19 4:01	136164.2			2198.9			62.05			700.41			32.53			1		
10/29/19 4:02	11321.3			2126			64.51			56.15			2.8			1		
10/29/19 4:03	0			0			78.01			0			0			0		
10/29/19 4:04	0			0			1.1			0			0			0		
10/29/19 4:05	0			0			0.9			0			0			0		
10/29/19 4:06	0			0			0.7			0			0			0		
10/29/19 4:07	0			0			0.6			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 4:07	0			0			0.6			0			0			0		
10/29/19 4:08	0			0			0.5			0			0			0		
10/29/19 4:09	0			0			0.4			0			0			0		
10/29/19 4:10	0			0			0.3			0			0			0		
10/29/19 4:11	0			0			0.3			0			0			0		
10/29/19 4:12	14479			10.8			0.3			0			0			1		
10/29/19 4:13	29728.2			9.9			0.3			0			0			1		
10/29/19 4:14	41049.5			64.9			41.3			6.23			6.53			1		
10/29/19 4:15	51908.8			427.4			26.88			51.86			5.37			1		
10/29/19 4:16	66926.9			379.6			31.47			59.39			8.1			1		
10/29/19 4:17	108361.5			254.6			37.17			64.51			15.5			1		
10/29/19 4:18	141786.4			133.5			53.84			44.28			29.39			1		
10/29/19 4:19	134315.9			409.8			66.04			128.78			34.16			1		
10/29/19 4:20	131620.3			1869.9			54.58			575.54			27.64			1		
10/29/19 4:21	131543.3			2051.9			55.76			631.54			28.25			1		
10/29/19 4:22	130927.2			2051.9			55.38			628.33			27.91			1		
10/29/19 4:23	129925.9			2120.3			56.84			644.52			28.43			1		
10/29/19 4:24	136857.4			2120.3			56.64			678.7			29.84			1		
10/29/19 4:25	133699.7			2051.9			58.24			641.65			29.97			1		
10/29/19 4:26	133622.7			2051.9			56.34			641.19			28.97			1		
10/29/19 4:27	132467.5			2051.9			55.19			635.68			28.14			1		
10/29/19 4:28	132005.4			2051.9			54.24			633.84			27.58			1		
10/29/19 4:29	129694.9			2051.9			53.86			622.36			26.89			1		
10/29/19 4:30	129848.9			2120.3			55.26			644.05			27.63			1		
10/29/19 4:31	128924.7			2120.3			55.46			639.3			27.52			1		
10/29/19 4:32	126614.3			2120.3			56.25			627.91			27.41			1		
10/29/19 4:33	126537.2			2120.3			56.84			627.44			27.68			1		
10/29/19 4:34	93805.5			2193.4			59.41			481.16			21.45			1		
10/29/19 4:35	0			0			61.19			0			0			0		
10/29/19 4:36	0			0			88.5			0			0			0		
10/29/19 4:37	0			0			0.5			0			0			0		
10/29/19 4:38	0			0			0.4			0			0			0		
10/29/19 4:39	0			0			0.4			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 4:29	129694.9			2051.9			53.86			622.36			26.89			1		
10/29/19 4:30	129848.9			2120.3			55.26			644.05			27.63			1		
10/29/19 4:31	128924.7			2120.3			55.46			639.3			27.52			1		
10/29/19 4:32	126614.3			2120.3			56.25			627.91			27.41			1		
10/29/19 4:33	126537.2			2120.3			56.84			627.44			27.68			1		
10/29/19 4:34	93805.5			2193.4			59.41			481.16			21.45			1		
10/29/19 4:35	0			0			61.19			0			0			0		
10/29/19 4:36	0			0			88.5			0			0			0		
10/29/19 4:37	0			0			0.5			0			0			0		
10/29/19 4:38	0			0			0.4			0			0			0		
10/29/19 4:39	0			0			0.4			0			0			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 5:39	0			0			0			0			0			0		
10/29/19 5:40	0			0			0			0			0			0		
10/29/19 5:41	0			0			0			0			0			0		
10/29/19 5:42	0			0			0			0			0			0		
10/29/19 5:43	0			0			0			0			0			0		
10/29/19 5:44	11706.4			0.7			0			3.25			7.71			1		
10/29/19 5:45	25338.3			0.7			0			48.1			4.49			1		
10/29/19 5:46	37737.8			36.9			53.1			57.28			7.04			1		
10/29/19 5:47	48058			428.1			24.26			59.84			12.69			1		
10/29/19 5:48	61304.7			399.2			29.83			51.29			25.47			1		
10/29/19 5:49	97964.3			261.1			33.63			249.97			31.09			1		
10/29/19 5:50	144867			151.3			45.66			0			0			1		
10/29/19 5:51	135471.1			788.6			59.59			0			0			1		
10/29/19 5:52	0			1900.7			53.99			0			0			1		
10/29/19 5:53	0			0			62.93			0			0			0		
10/29/19 5:54	0			0			0.5			0			0			0		
10/29/19 5:55	0			0			0.4			0			0			0		
10/29/19 5:56	0			0			0.3			0			0			0		
10/29/19 5:57	0			0			0.2			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 5:46	37737.8			36.9			53.1			3.25			7.71			1		
10/29/19 5:47	48058			428.1			24.26			48.1			4.49			1		
10/29/19 5:48	61304.7			399.2			29.83			57.28			7.04			1		
10/29/19 5:49	97964.3			261.1			33.63			59.84			12.69			1		
10/29/19 5:50	144867			151.3			45.66			51.29			25.47			1		
10/29/19 5:51	135471.1			788.6			59.59			249.97			31.09			1		
10/29/19 5:52	0			1900.7			53.99			0			0			1		
10/29/19 5:53	0			0			62.93			0			0			0		
10/29/19 5:54	0			0			0.5			0			0			0		
10/29/19 5:55	0			0			0.4			0			0			0		
10/29/19 5:56	0			0			0.3			0			0			0		
10/29/19 5:57	0			0			0.2			0			0			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 8:59	0			0			0			0			0			0		
10/29/19 9:00	0			0			0			0			0			0		
10/29/19 9:01	0			0			0			0			0			0		
10/29/19 9:02	0			0			0			0			0			0		
10/29/19 9:03	0			0			0			0			0			0		
10/29/19 9:04	12014.5			0.2			0			5.72			6.63			1		
10/29/19 9:05	28649.9			0.4			0			63.27			5.39			1		
10/29/19 9:06	40818.5			59.8			42.14			59.92			7.38			1		
10/29/19 9:07	50830.5			532.3			27.53			63.82			14.89			1		
10/29/19 9:08	62922.1			406.8			30.43			49.35			29.53			1		
10/29/19 9:09	101584.1			268.5			38.06			256.15			32.22			1		
10/29/19 9:10	146638.4			143.9			52.33			161.31			8.39			1		
10/29/19 9:11	135548.1			808.1			61.77			0			0			0		
10/29/19 9:12	36813.6			1871.7			59.18			0			0			0		
10/29/19 9:13	0			0			64.9			0			0			0		
10/29/19 9:14	0			0			1			0			0			0		
10/29/19 9:15	0			0			0.7			0			0			0		
10/29/19 9:16	0			0			0.5			0			0			0		
10/29/19 9:17	0			0			0.5			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 9:07	50830.5			532.3			27.53			63.27			5.39			1		
10/29/19 9:08	62922.1			406.8			30.43			59.92			7.38			1		
10/29/19 9:09	101584.1			268.5			38.06			63.82			14.89			1		
10/29/19 9:10	146638.4			143.9			52.33			49.35			29.53			1		
10/29/19 9:11	135548.1			808.1			61.77			256.15			32.22			1		
10/29/19 9:12	36813.6			1871.7			59.18			161.31			8.39			1		
10/29/19 9:13	0			0			64.9			0			0			0		
10/29/19 9:14	0			0			1			0			0			0		
10/29/19 9:15	0			0			0.7			0			0			0		
10/29/19 9:16	0			0			0.5			0			0			0		
10/29/19 9:17	0			0			0.5			0			0			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 10:54	0			0			0			0			0			0		
10/29/19 10:55	0			0			0			0			0			0		
10/29/19 10:56	0			0			0			0			0			0		
10/29/19 10:57	0			0			0			0			0			0		
10/29/19 10:58	4543.9			0			0			0			0			0		
10/29/19 10:59	15326.2			0.4			0			0			0			0		
10/29/19 11:00	30729.4			1.2	X		0.2	X		0	X		0	X		1		
10/29/19 11:01	41896.7			522.7	X		43.07	X		51.25	X		6.95	X		1		
10/29/19 11:02	52524.9			445.6	X		28.57	X		54.76	X		5.78	X		1		
10/29/19 11:03	68621.2			315.8	X		38.19	X		50.69	X		10.09	X		1		
10/29/19 11:04	115138.9			203.4	X		43.55	X		54.78	X		19.3	X		1		
10/29/19 11:05	142094.5			109.7	X		63.01	X		36.48	X		34.47	X		1		
10/29/19 11:06	109362.7			1053.2	X		64.03	X		269.46	X		26.96	X		1		
10/29/19 11:07	0			0	X		63.98	X		0	X		0	X		0		
10/29/19 11:08	0			0	X		224.2	X		0	X		0	X		0		
10/29/19 11:09	0			0	X		0.8	X		0	X		0	X		0		
10/29/19 11:10	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 11:11	0			0	X		0.5	X		0	X		0	X		0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:01	41896.7			522.7	X		43.07	X		51.25	X		6.95	X		1		
10/29/19 11:02	52524.9			445.6	X		28.57	X		54.76	X		5.78	X		1		
10/29/19 11:03	68621.2			315.8	X		38.19	X		50.69	X		10.09	X		1		
10/29/19 11:04	115138.9			203.4	X		43.55	X		54.78	X		19.3	X		1		
10/29/19 11:05	142094.5			109.7	X		63.01	X		36.48	X		34.47	X		1		
10/29/19 11:06	109362.7			1053.2	X		64.03	X		269.46	X		26.96	X		1		
10/29/19 11:07	0			0	X		63.98	X		0	X		0	X		0		
10/29/19 11:08	0			0	X		224.2	X		0	X		0	X		0		
10/29/19 11:09	0			0	X		0.8	X		0	X		0	X		0		
10/29/19 11:10	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 11:11	0			0	X		0.5	X		0	X		0	X		0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:12	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 11:13	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 11:14	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:15	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:16	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:17	0			4	X		0.2	X		0	X		0	X		0		1
10/29/19 11:18	0			0	X		0.1	X		0	X		0	X		0		
10/29/19 11:19	0			0	X		59	X		0	X		0	X		0		
10/29/19 11:20	0			0	X		22.13	X		0	X		0	X		0		
10/29/19 11:21	0			0	X		29.5	X		0	X		0	X		0		
10/29/19 11:22	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:12	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 11:13	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 11:14	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:15	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:16	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:17	0			4	X		0.2	X		0	X		0	X		0		1
10/29/19 11:18	0			0	X		0.1	X		0	X		0	X		0		
10/29/19 11:19	0			0	X		59	X		0	X		0	X		0		
10/29/19 11:20	0			0	X		22.13	X		0	X		0	X		0		
10/29/19 11:21	0			0	X		29.5	X		0	X		0	X		0		
10/29/19 11:22	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 17

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 12:51	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:52	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:53	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:54	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:55	1232.3			0	X		0	X		0	X		0	X		0		
10/29/19 12:56	22565.7			0.3	X		0	X		0	X		0	X		0		1
10/29/19 12:57	33656			1.4	X		1	X		0	X		0	X		0		1
10/29/19 12:58	44746.3			496.1	X		38.12	X		51.97	X		6.57	X		0		1
10/29/19 12:59	54142.2			429.4	X		31.47	X		54.4	X		6.56	X		0		1
10/29/19 13:00	74936.5			273.6	X		41.3	X		47.95	X		11.91	X		0		1
10/29/19 13:01	130311			164.6	X		48.6	X		50.19	X		24.39	X		0		1
10/29/19 13:02	135625.1			129.8	X		67.09	X		41.17	X		35.02	X		0		1
10/29/19 13:03	0			1206	X		65.59	X		0	X		0	X		0		1
10/29/19 13:04	0			0	X		99.12	X		0	X		0	X		0		0
10/29/19 13:05	0			0	X		0.9	X		0	X		0	X		0		0
10/29/19 13:06	0			0	X		0.7	X		0	X		0	X		0		0
10/29/19 13:07	0			0	X		0.5	X		0	X		0	X		0		0
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		0

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 12:57	33656			1.4	X		1	X		0	X		0	X		1		
10/29/19 12:58	44746.3			496.1	X		38.12	X		51.97	X		6.57	X		1		
10/29/19 12:59	54142.2			429.4	X		31.47	X		54.4	X		6.56	X		1		
10/29/19 13:00	74936.5			273.6	X		41.3	X		47.95	X		11.91	X		1		
10/29/19 13:01	130311			164.6	X		48.6	X		50.19	X		24.39	X		1		
10/29/19 13:02	135625.1			129.8	X		67.09	X		41.17	X		35.02	X		1		
10/29/19 13:03	0			1206	X		65.59	X		0	X		0	X		1		
10/29/19 13:04	0			0	X		99.12	X		0	X		0	X		0		
10/29/19 13:05	0			0	X		0.9	X		0	X		0	X		0		
10/29/19 13:06	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 13:07	0			0	X		0.5	X		0	X		0	X		0		
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 13:09	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:10	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:11	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:12	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:13	15711.3			2.1	X		0.2	X		0	X		0	X		0		1
10/29/19 13:14	29959.2			2.7	X		0.3	X		0	X		0	X		0		1
10/29/19 13:15	41511.6			15.9	X		47.79	X		1.55	X		7.64	X		0		1
10/29/19 13:16	51754.7			377.9	X		29.81	X		45.77	X		5.94	X		0		1
10/29/19 13:17	30267.3			277.3	X		39.44	X		19.61	X		4.59	X		0		1
10/29/19 13:18	0			0	X		39.61	X		0	X		0	X		0		0
10/29/19 13:19	0			0	X		12.54	X		0	X		0	X		0		0
10/29/19 13:20	0			0	X		0.4	X		0	X		0	X		0		0
10/29/19 13:21	0			0	X		0.3	X		0	X		0	X		0		0
10/29/19 13:22	0			0	X		0.2	X		0	X		0	X		0		0

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 13:12	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:13	15711.3			2.1	X		0.2	X		0	X		0	X		1		
10/29/19 13:14	29959.2			2.7	X		0.3	X		0	X		0	X		1		
10/29/19 13:15	41511.6			15.9	X		47.79	X		1.55	X		7.64	X		1		
10/29/19 13:16	51754.7			377.9	X		29.81	X		45.77	X		5.94	X		1		
10/29/19 13:17	30267.3			277.3	X		39.44	X		19.61	X		4.59	X		1		
10/29/19 13:18	0			0	X		39.61	X		0	X		0	X		0		
10/29/19 13:19	0			0	X		12.54	X		0	X		0	X		0		
10/29/19 13:20	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 13:21	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:22	0			0	X		0.2	X		0	X		0	X		0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 7:17	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:18	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:19	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:20	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:21	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:22	16250.4			0.1	X		0	X		0	X		0	X		0		1
10/30/19 7:23	31422.5			0.8	X		0	X		0	X		0	X		0		1
10/30/19 7:24	42897.9			5.9	X		25.81	X		0.59	X		4.26	X		0		1
10/30/19 7:25	53526.1			592.4	X		20.82	X		74.13	X		4.29	X		0		1
10/30/19 7:26	66618.8			451.7	X		26.55	X		70.37	X		6.81	X		0		1
10/30/19 7:27	104741.7			305.2	X		29.81	X		74.82	X		12.03	X		0		1
10/30/19 7:28	138089.6			159.6	X		45.4	X		51.54	X		24.14	X		0		1
10/30/19 7:29	139861			128	X		62.15	X		41.9	X		33.47	X		0		1
10/30/19 7:30	152260.6			1695	X		55.38	X		603.66	X		32.46	X		0		1
10/30/19 7:31	169589.2			1865.3	X		57.03	X		739.88	X		37.23	X		0		1
10/30/19 7:32	189536.3			1012.6	X		63.15	X		449.01	X		46.08	X		0		1
10/30/19 7:33	213103.2			172.1	X		60.4	X		85.78	X		49.56	X		0		1
10/30/19 7:34	231587			13.6	X		53.98	X		7.34	X		48.12	X		0		1
10/30/19 7:35	251996.3			2.7	X		47.87	X		1.57	X		46.43	X		0		1
10/30/19 7:36	277719.6			2.1	X		43.74	X		1.39	X		46.76	X		0		1
10/30/19 7:37	298051.8			2	X		39.64	X		1.41	X		45.49	X		0		1
10/30/19 7:38	302364.7			2.1	X		26.03	X		1.47	X		30.3	X		0		1
10/30/19 7:39	300978.4			2.2	X		20.82	X		1.53	X		24.13	X		0		1
10/30/19 7:40	299515.1			2.2	X		20.39	X		1.52	X		23.51	X		0		1
10/30/19 7:41	298590.9			2	X		19.73	X		1.41	X		22.67	X		0		1
10/30/19 7:42	298051.8			1.8	X		18.76	X		1.29	X		21.52	X		0		1
10/30/19 7:43	298513.9			1.8	X		18.06	X		1.25	X		20.75	X		0		1
10/30/19 7:44	297512.7			1.6	X		17.43	X		1.12	X		19.97	X		0		1
10/30/19 7:45	298051.8			1.5	X		16.81	X		1.06	X		19.29	X		0		1
10/30/19 7:46	297050.6			1.5	X		16.45	X		1.06	X		18.81	X		0		1
10/30/19 7:47	297358.7			1.4	X		16.09	X		0.99	X		18.42	X		0		1
10/30/19 7:48	309758.3			1.4	X		15.82	X		1.04	X		18.87	X		0		1
10/30/19 7:49	315765.5			1.3	X		15.73	X		0.99	X		19.13	X		0		1
10/30/19 7:50	316766.7			1.3	X		15.55	X		0.99	X		18.97	X		0		1
10/30/19 7:51	320848.5			1.3	X		15.02	X		0.94	X		18.55	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 7:52	319385.3			1.3	X		14.16	X		0.95	X		17.41	X		1		
10/30/19 7:53	320540.5			1.2	X		14.16	X		0.88	X		17.48	X		1		
10/30/19 7:54	317536.8			1.3	X		14.16	X		0.94	X		17.31	X		1		
10/30/19 7:55	314764.3			1.3	X		14.52	X		0.94	X		17.6	X		1		
10/30/19 7:56	313840.1			1.2	X		14.8	X		0.87	X		17.88	X		1		
10/30/19 7:57	313686.1			1.2	X		15.02	X		0.85	X		18.14	X		1		
10/30/19 7:58	313301			1.2	X		15.43	X		0.86	X		18.61	X		1		
10/30/19 7:59	312453.8			1.2	X		15.52	X		0.86	X		18.67	X		1		
10/30/19 8:00	312376.8			1.2	X		15.43	X		0.86	X		18.55	X		1		
10/30/19 8:01	313301			1.1	X		15.43	X		0.8	X		18.61	X		1		
10/30/19 8:02	312607.8			1.1	X		15.52	X		0.8	X		18.68	X		1		
10/30/19 8:03	313455			1	X		15.2	X		0.72	X		18.34	X		1		
10/30/19 8:04	311144.5			1	X		10.62	X		0.73	X		12.72	X		1		
10/30/19 8:05	311837.7			1	X		8.35	X		0.73	X		10.03	X		1		
10/30/19 8:06	313146.9			1	X		7.35	X		0.73	X		8.86	X		1		
10/30/19 8:07	309989.3			1	X		6.9	X		0.72	X		8.23	X		1		
10/30/19 8:08	297127.6			0.9	X		6.44	X		0.63	X		7.37	X		1		
10/30/19 8:09	291967.6			0.9	X		6.44	X		0.62	X		7.24	X		1		
10/30/19 8:10	289503			0.9	X		6.26	X		0.61	X		6.98	X		1		
10/30/19 8:11	283418.8			0.9	X		5.72	X		0.6	X		6.24	X		1		
10/30/19 8:12	282186.5			0.8	X		6.18	X		0.55	X		6.71	X		1		
10/30/19 8:13	277950.7			0.8	X		6.73	X		0.54	X		7.2	X		1		
10/30/19 8:14	277642.6			0.8	X		6.91	X		0.54	X		7.39	X		1		
10/30/19 8:15	279336.9			0.8	X		6.73	X		0.54	X		7.24	X		1		
10/30/19 8:16	277334.5			0.8	X		6.55	X		0.54	X		6.99	X		1		
10/30/19 8:17	287192.6			0.8	X		6.27	X		0.56	X		6.93	X		1		
10/30/19 8:18	291582.5			0.8	X		5.35	X		0.57	X		6	X		1		
10/30/19 8:19	291582.5			0.8	X		4.36	X		0.56	X		4.89	X		1		
10/30/19 8:20	291890.5			0.8	X		4.18	X		0.56	X		4.69	X		1		
10/30/19 8:21	291659.5			0.9	X		4.18	X		0.62	X		4.69	X		1		
10/30/19 8:22	291736.5			0.9	X		4.18	X		0.62	X		4.69	X		1		
10/30/19 8:23	291274.4			0.9	X		4.08	X		0.62	X		4.58	X		1		
10/30/19 8:24	292352.6			0.9	X		4.08	X		0.62	X		4.6	X		1		
10/30/19 8:25	293199.8			0.9	X		4.08	X		0.62	X		4.61	X		1		
10/30/19 8:26	292044.6			0.9	X		4.08	X		0.62	X		4.59	X		1		
10/30/19 8:27	293276.8			0.9	X		3.99	X		0.62	X		4.51	X		1		
10/30/19 8:28	292583.7			0.9	X		3.99	X		0.62	X		4.5	X		1		
10/30/19 8:29	292121.6			0.9	X		3.9	X		0.62	X		4.39	X		1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 8:30	292352.6			0.9	X		3.9	X		0.62	X		4.39	X		1		
10/30/19 8:31	291043.3			0.9	X		3.81	X		0.62	X		4.27	X		1		
10/30/19 8:32	292429.7			0.8	X		3.81	X		0.56	X		4.29	X		1		
10/30/19 8:33	291197.4			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:34	290812.3			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:35	291197.4			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:36	292121.6			0.8	X		3.81	X		0.56	X		4.29	X		1		
10/30/19 8:37	291659.5			0.8	X		3.72	X		0.56	X		4.18	X		1		
10/30/19 8:38	290735.3			0.8	X		3.72	X		0.56	X		4.17	X		1		
10/30/19 8:39	290504.3			0.8	X		3.72	X		0.56	X		4.16	X		1		
10/30/19 8:40	290966.3			0.8	X		3.72	X		0.56	X		4.17	X		1		
10/30/19 8:41	291582.5			0.8	X		3.63	X		0.56	X		4.08	X		1		
10/30/19 8:42	291813.5			0.8	X		3.45	X		0.56	X		3.87	X		1		
10/30/19 8:43	291274.4			0.8	X		3.18	X		0.56	X		3.56	X		1		
10/30/19 8:44	291582.5			0.8	X		2.9	X		0.56	X		3.26	X		1		
10/30/19 8:45	290735.3			0.8	X		2.54	X		0.56	X		2.84	X		1		
10/30/19 8:46	290581.3			0.8	X		2.3	X		0.56	X		2.58	X		1		
10/30/19 8:47	291120.4			0.8	X		2	X		0.56	X		2.24	X		1		
10/30/19 8:48	292044.6			0.8	X		1.82	X		0.56	X		2.04	X		1		
10/30/19 8:49	291197.4			0.8	X		1.66	X		0.57	X		1.86	X		1		
10/30/19 8:50	291120.4			0.8	X		1.57	X		0.56	X		1.76	X		1		
10/30/19 8:51	291043.3			0.8	X		1.48	X		0.56	X		1.65	X		0		
10/30/19 8:52	291043.3			0.8	X		1.38	X		0.56	X		1.55	X		0		
10/30/19 8:53	290427.2			0.9	X		1.29	X		0.63	X		1.44	X		0		
10/30/19 8:54	291351.4			0.8	X		1.29	X		0.57	X		1.45	X		0		
10/30/19 8:55	292275.6			0.8	X		1.2	X		0.57	X		1.35	X		0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 11:41	283341.8			0.8			1.78			0.56			1.94			0		
10/30/19 11:42	282879.7			0.8			1.69			0.56			1.84			0		
10/30/19 11:43	282417.6			0.8			1.69			0.56			1.83			0		
10/30/19 11:44	282956.7			0.8			1.69			0.56			1.84			0		
10/30/19 11:45	281801.4			0.8			1.69			0.56			1.83			0		
10/30/19 11:46	276564.3			0.7			1.69			0.48			1.79			1		
10/30/19 11:47	254922.9			0.8			1.69			0.5			1.65			1		
10/30/19 11:48	235745.9			0.8			3.52			0.42			3.2			1		
10/30/19 11:49	218571.3			0.7			7.67			0.35			6.45			1		
10/30/19 11:50	194773.4			0.6			16.77			0.28			12.57			1		
10/30/19 11:51	172284.7			0.5			20.76			0.18			13.77			1		
10/30/19 11:52	150566.2			5			23.22			1.76			13.45			1		
10/30/19 11:53	133083.6			456.8			25.96			142.24			13.3			1		
10/30/19 11:54	76707.9			1488.3			26.63			267.19			7.87			1		
10/30/19 11:55	0			0			28.96			0			0			0		
10/30/19 11:56	0			0			0.3			0			0			0		
10/30/19 11:57	0			0			0.1			0			0			0		
10/30/19 11:58	0			0			0.1			0			0			0		
10/30/19 11:59	0			0			0.1			0			0			0		

CT2 SUSD EVENT 23

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/19 13:39	0			0			0			0			0			0		
11/05/19 13:40	0			0			0			0			0			0		
11/05/19 13:41	0			0			0			0			0			0		
11/05/19 13:42	0			0			0			0			0			0		
11/05/19 13:43	0			0			0			0			0			0		
11/05/19 13:44	16404.4			0.2			0			0			0			0		1
11/05/19 13:45	31345.5			0.8			0			0			0			0		1
11/05/19 13:46	42974.9			5.2			19.01			0.53			3.19			0		1
11/05/19 13:47	52293.8			444.7			17.7			55.14			3.61			0		1
11/05/19 13:48	69622.4			287.9			23.9			47.56			6.5			0		1
11/05/19 13:49	111442.1			169.5			26.01			44.81			11.32			0		1
11/05/19 13:50	130619.1			69.7			44.48			21.6			22.69			0		1
11/05/19 13:51	139090.8			164.6			57.71			54.33			31.34			0		1
11/05/19 13:52	158113.8			1536.1			42.02			576.31			25.94			0		1
11/05/19 13:53	180448.4			830.9			52.3			355.82			36.86			0		1
11/05/19 13:54	201088.7			125.3			62.23			59.8			48.88			0		1
11/05/19 13:55	222730.2			7.1			66.62			3.77			57.95			0		1
11/05/19 13:56	243909.6			1.9			72.22			1.07			68.78			0		1
11/05/19 13:57	267938.6			1.8			63.62			1.13			66.56			0		1
11/05/19 13:58	288116.8			1.7			41.57			1.18			46.77			0		1
11/05/19 13:59	307755.8			1.9			22.62			1.37			27.18			0		1
11/05/19 14:00	322542.9			1.9			20.43			1.48			25.73			0		1
11/05/19 14:01	327471.9			1.9			15.82			1.46			20.23			0		1
11/05/19 14:02	327703			1.8			14.25			1.41			18.24			0		1
11/05/19 14:03	329089.3			1.6			12.98			1.28			16.68			0		1
11/05/19 14:04	338023.1			1.5			11.89			1.24			15.7			0		1
11/05/19 14:05	345724.7			1.4			10.42			1.13			14.07			0		1
11/05/19 14:06	347881.2			1.3			9.86			1.07			13.4			0		1
11/05/19 14:07	348035.2			1.2			9.65			1.01			13.11			0		1
11/05/19 14:08	346109.8			1.1			9.46			0.92			12.78			0		1
11/05/19 14:09	346417.8			1.1			9.37			0.92			12.67			0		1
11/05/19 14:10	344492.4			1.1			9.55	X		0.92			12.85	X		0		1
11/05/19 14:11	344954.5			1			9.55	X		0.84			12.87	X		0		1
11/05/19 14:12	345647.7			1			9.55	X		0.84			12.89	X		0		1
11/05/19 14:13	343414.2			0.9			9.65	X		0.76			12.94	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/19 14:14	344569.5			1			9.55	X		0.84			12.85	X		1		
11/05/19 14:15	341950.9			1			9.37			0.84			12.51			1		
11/05/19 14:16	342721.1			1			9.46			0.84			12.66			1		
11/05/19 14:17	341026.7			1			9.55			0.83			12.72			1		
11/05/19 14:18	343876.3			0.9			9.55			0.76			12.83			1		
11/05/19 14:19	342567			0.9			9.65			0.76			12.9			1		
11/05/19 14:20	343183.2			0.9			9.74			0.76			13.05			1		
11/05/19 14:21	338947.3			0.9			9.93			0.75			13.14			1		
11/05/19 14:22	326162.7			0.9			10.02			0.72			12.76			1		
11/05/19 14:23	321464.7			0.9			6.36			0.7			7.98			1		
11/05/19 14:24	320694.5			1			3.6			0.77			4.5			1		
11/05/19 14:25	319847.3			1			3.13			0.77			3.91			1		
11/05/19 14:26	320232.4			1			3.04			0.77			3.8			1		
11/05/19 14:27	319385.3			0.9			2.86			0.7			3.56			1		
11/05/19 14:28	314148.2			0.9			2.77			0.69			3.39			1		
11/05/19 14:29	306908.7			0.9			2.58			0.67			3.09			1		
11/05/19 14:30	307447.8			0.9			2.4			0.67			2.88			1		
11/05/19 14:31	306523.6			0.9			2.21			0.67			2.65			1		
11/05/19 14:32	305676.4			1			2.03			0.74			2.42			1		
11/05/19 14:33	305830.4			1			1.84			0.74			2.2			1		
11/05/19 14:34	305599.4			0.9			1.66			0.67			1.98			1		
11/05/19 14:35	305907.4			0.9			1.57			0.67			1.87			1		
11/05/19 14:36	306985.7			0.9			1.38			0.67			1.66			0		
11/05/19 14:37	305984.5			1			1.29			0.74			1.54			0		
11/05/19 14:38	305291.3			0.9			1.29			0.67			1.54			0		
11/05/19 14:39	306061.5			0.9			1.2			0.67			1.43			0		
11/05/19 14:40	306138.5			0.9			1.2			0.67			1.43			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/19 23:47	286422.4			0.9			1.82			0.62			2.03			0		
11/06/19 23:48	286191.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:49	286576.4			0.9			1.82			0.62			2.03			0		
11/06/19 23:50	286037.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:51	285960.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:52	283649.8			1			1.82			0.67			2.01			1		
11/06/19 23:53	263933.8			1			1.82			0.63			1.87			1		
11/06/19 23:54	242215.2			1			3.23			0.58			3.05			1		
11/06/19 23:55	224655.6			0.9			6.95			0.46			6.09			1		
11/06/19 23:56	204477.4			0.8			14.4			0.39			11.5			1		
11/06/19 23:57	180063.3			0.7			19.23			0.28			13.52			1		
11/06/19 23:58	158961			5.4			21.63			2.04			13.43			1		
11/06/19 23:59	141786.4			383.4			23.46			128.98			12.99			1		
11/07/19 0:00	114753.8			1407.1			25.04			383			11.22			1		
11/07/19 0:01	0			0			28.58			0			0			1		
11/07/19 0:02	0			0			39.33			0			0			0		
11/07/19 0:03	0			0			0.2			0			0			0		
11/07/19 0:04	0			0			0.2			0			0			0		
11/07/19 0:05	0			0			0.1			0			0			0		
11/07/19 0:06	0			0			0.1			0			0			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 10:38	0			0			0			0			0			0		
11/07/19 10:39	0			0			0			0			0			0		
11/07/19 10:40	0			0			0			0			0			0		
11/07/19 10:41	0			0			0			0			0			0		
11/07/19 10:42	0			0			0			0			0			0		
11/07/19 10:43	6623.4			0.2			0			0			0			0		1
11/07/19 10:44	24722.1			0.2			0			0			0			0		1
11/07/19 10:45	37506.8			40.3			26.55			3.59			3.89			18.09		1
11/07/19 10:46	47980.9			564.5			15.84			64.32			2.97			26.87		1
11/07/19 10:47	58994.2			472.6			22.05			66.12			5.08			18.09		1
11/07/19 10:48	87490.1			286.3			25.85			59.41			8.83			18.09		1
11/07/19 10:49	129001.8			169.6			35.91			51.89			18.09			18.09		1
11/07/19 10:50	137781.6			62			49.95			20.25			26.87			18.09		1
11/07/19 10:51	153877.9			888.8			48.27			324.48			29			18.09		1
11/07/19 10:52	171437.5			1505.7			48.89			612.4			32.72			18.09		1
11/07/19 10:53	194003.2			494.1			48.53			227.41			36.76			18.09		1
11/07/19 10:54	215259.6			49.5			49.38			25.29			41.51			18.09		1
11/07/19 10:55	234898.7			3.8			51.71			2.13			47.44			18.09		1
11/07/19 10:56	258388.6			1.8			54.05			1.1			54.54			18.09		1
11/07/19 10:57	282263.5			1.6			41.97			1.08			46.26			18.09		1
11/07/19 10:58	297204.6			1.7			23.6			1.18			27.39			18.09		1
11/07/19 10:59	312530.8			1.8			15.01			1.35			18.32			18.09		1
11/07/19 11:00	318923.2			1.8			14.66			1.38			18.26			18.09		1
11/07/19 11:01	325238.4			1.7			12.75			1.34			16.2			18.09		1
11/07/19 11:02	330783.6			1.7			11.36			1.31			14.67			18.09		1
11/07/19 11:03	329936.4			1.5			10.91			1.19			14.05			18.09		1
11/07/19 11:04	328473.1			1.3			11.08			1.05			14.22			18.09		1
11/07/19 11:05	329243.3			1.3			11			1.05			14.14			18.09		1
11/07/19 11:06	331630.8			1.3			10.73			0.98			13.89			18.09		1
11/07/19 11:07	332246.9			1.3			10.44			1			13.54			18.09		1
11/07/19 11:08	333325.1			1.2			10.35			0.93			13.47			18.09		1
11/07/19 11:09	333864.3			1.2			10.35			0.93			13.49			18.09		1
11/07/19 11:10	338254.2			1.1			10.26			0.87			13.55			18.09		1
11/07/19 11:11	340256.6			1.1			9.89			0.88			13.15			18.09		1
11/07/19 11:12	337561			1			10.05			0.81			13.25			18.09		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 11:13	340025.5			1			10.23			0.82			13.59			1		
11/07/19 11:14	339794.5			1			10.42			0.82			13.82			1		
11/07/19 11:15	338870.3			1			10.51			0.82			13.91			1		
11/07/19 11:16	338639.2			1			10.51			0.81			13.9			1		
11/07/19 11:17	336867.9			0.9			10.6			0.74			13.95			1		
11/07/19 11:18	327703			0.9			8.94			0.72			11.44			1		
11/07/19 11:19	319308.2			1			4.54			0.76			5.66			1		
11/07/19 11:20	314995.3			1			3.63			0.75			4.47			1		
11/07/19 11:21	311144.5			1			3.45			0.74			4.19			1		
11/07/19 11:22	308140.9			1			3.27			0.73			3.93			1		
11/07/19 11:23	304675.2			1			3			0.72			3.56			1		
11/07/19 11:24	298899			1			2.63			0.71			3.07			1		
11/07/19 11:25	298282.9			1			2.54			0.71			2.96			1		
11/07/19 11:26	297512.7			1			2.36			0.7			2.74			1		
11/07/19 11:27	296357.5			1			2.18			0.7			2.52			1		
11/07/19 11:28	297435.7			1			2			0.7			2.32			1		
11/07/19 11:29	297050.6			1			1.82			0.7			2.11			1		
11/07/19 11:30	295972.4			1.1			1.63			0.76			1.89			1		
11/07/19 11:31	290812.3			1			1.54			0.69			1.75			1		
11/07/19 11:32	291274.4			1			1.45			0.69			1.65			0		
11/07/19 11:33	290581.3			0.9			1.38			0.64			1.57			0		
11/07/19 11:34	289657.1			0.9			1.29			0.63			1.46			0		
11/07/19 11:35	290735.3			0.9			1.29			0.64			1.47			0		
11/07/19 11:36	291582.5			0.9			1.2			0.64			1.36			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:01	342952.1			1.2			1.72			0.96			2.31			0		
11/07/19 21:02	341796.9			1.2			1.72			0.96			2.3			0		
11/07/19 21:03	332400.9			1.3			1.72			1			2.24			0		
11/07/19 21:04	312530.8			1.3			1.7			0.93			2.07			0		
11/07/19 21:05	292506.7			1.2			1.76			0.86			2.01			0		
11/07/19 21:06	271250.3			1.3			1.85			0.85			1.96			1		
11/07/19 21:07	249685.8			1.4			1.91			0.81			1.86			1		
11/07/19 21:08	232203.2			1.3			4.4			0.72			3.99			1		
11/07/19 21:09	211639.9			1.2			8.46			0.59			6.99			1		
11/07/19 21:10	187379.9			0.9			17.81			0.42			13.03			1		
11/07/19 21:11	164506.1			2.4			20.77			0.92			13.34			1		
11/07/19 21:12	146176.3			212.5			23.2			73.74			13.25			1		
11/07/19 21:13	129309.8			1131.2			25.77			347.17			13.02			1		
11/07/19 21:14	45054.3			1846.4			27.59			197.56			4.86			1		
11/07/19 21:15	0			0			31.47			0			0			0		
11/07/19 21:16	0			0			11.8			0			0			0		
11/07/19 21:17	0			0			0.2			0			0			0		
11/07/19 21:18	0			0			0.1			0			0			0		
11/07/19 21:19	0			0			0.1			0			0			0		

CT2 SUSD EVENT 27

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 9:38	0			0			0			0			0			0		
11/08/19 9:39	0			0			0			0			0			0		
11/08/19 9:40	0			0			0			0			0			0		
11/08/19 9:41	0			0			0			0			0			0		
11/08/19 9:42	0			0			0			0			0			0		
11/08/19 9:43	9704			0.2			0			0			0			0		1
11/08/19 9:44	27186.6			0.5			0			0			0			0		1
11/08/19 9:45	39509.2			54.6			27.29			5.12			4.21			1		1
11/08/19 9:46	50137.4			567			20.18			67.4			3.95			1		1
11/08/19 9:47	61689.8			462.4			26.08			67.69			6.28			1		1
11/08/19 9:48	94267.5			291.1			27.81			65.09			10.24			1		1
11/08/19 9:49	132467.5			163.5			39.83			51.38			20.6			1		1
11/08/19 9:50	140323.1			64.1			55.66			21.34			30.49			1		1
11/08/19 9:51	157728.7			1142.3			51.13			427.52			31.5			1		1
11/08/19 9:52	177290.8			1463			52.93			615.36			36.64			1		1
11/08/19 9:53	199240.3			446.2			50.51			210.97			39.3			1		1
11/08/19 9:54	220111.7			47.1			52.07			24.58			44.76			1		1
11/08/19 9:55	241830.2			3.3			53.33			1.89			50.35			1		1
11/08/19 9:56	264857.9			2			55.17			1.24			57.07			1		1
11/08/19 9:57	286807.5			1.9			40.27			1.27			45.1			1		1
11/08/19 9:58	305984.5			1.8			21.95			1.32			26.23			1		1
11/08/19 9:59	319231.2			2			15.18			1.51			18.93			1		1
11/08/19 10:00	320232.4			2			14.28			1.49			17.85			1		1
11/08/19 10:01	319693.3			1.9			13.45			1.45			16.79			1		1
11/08/19 10:02	319077.2			1.7			12.49			1.31			15.57			1		1
11/08/19 10:03	317767.9			1.6			11.8			1.24			14.64			1		1
11/08/19 10:04	316458.6			1.6			11.54			1.19			14.25			1		1
11/08/19 10:05	317228.8			1.5			11.1			1.13			13.75			1		1
11/08/19 10:06	316766.7			1.4			10.92			1.06			13.51			1		1
11/08/19 10:07	323775.2			1.3			10.48			1.01			13.25			1		1
11/08/19 10:08	328011			1.3			9.65			0.97			12.37			1		1
11/08/19 10:09	332863			1.2			9.8			0.93			12.74			1		1
11/08/19 10:10	334095.3			1.2			9.71			0.94			12.67			1		1
11/08/19 10:11	331938.8			1.1			9.8			0.86			12.71			1		1
11/08/19 10:12	334403.3			1.1			9.89			0.86			12.92			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 10:13	332477.9			1			9.98			0.79			12.96			1		
11/08/19 10:14	333248.1			1			10.08			0.79			13.11			1		
11/08/19 10:15	332786			1			10.17			0.79			13.21			1		
11/08/19 10:16	332786			1			10.17			0.79			13.21			1		
11/08/19 10:17	331938.8			1			10.26			0.79			13.3			1		
11/08/19 10:18	321695.7			1			10.44			0.76			13.11			1		
11/08/19 10:19	318769.1			1			10.8			0.76			13.45			1		
11/08/19 10:20	314841.3			1			5.45			0.75			6.7			1		
11/08/19 10:21	312299.8			1			3.9			0.74			4.76			1		
11/08/19 10:22	310913.5			1			3.45			0.74			4.19			1		
11/08/19 10:23	308063.9			1			3.18			0.73			3.82			1		
11/08/19 10:24	299284.1			1			3			0.71			3.5			1		
11/08/19 10:25	299361.1			1			2.86			0.7			3.34			1		
11/08/19 10:26	298667.9			1.1			2.77			0.76			3.23			1		
11/08/19 10:27	299361.1			1.1			2.54			0.77			2.97			1		
11/08/19 10:28	297435.7			1.1			2.27			0.77			2.64			1		
11/08/19 10:29	297435.7			1.1			2.09			0.77			2.42			1		
11/08/19 10:30	297204.6			1			1.91			0.7			2.21			1		
11/08/19 10:31	296819.6			1			1.72			0.7			2			1		
11/08/19 10:32	297127.6			1			1.54			0.7			1.79			1		
11/08/19 10:33	296896.6			1			1.45			0.7			1.68			0		
11/08/19 10:34	296896.6			1			1.36			0.7			1.58			0		
11/08/19 10:35	297974.8			1			1.27			0.71			1.48			0		
11/08/19 10:36	298822			1			1.27			0.71			1.48			0		
11/08/19 10:37	297204.6			1			1.27			0.7			1.47			0		

CT2 SUSD EVENT 28

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 23:50	275101.1			0.8			1.48			0.54			1.58			0		
11/08/19 23:51	274484.9			0.8			1.48			0.54			1.58			0		
11/08/19 23:52	274484.9			0.8			1.48			0.54			1.58			0		
11/08/19 23:53	275640.2			0.8			1.48			0.54			1.59			0		
11/08/19 23:54	274639			0.8			1.48			0.54			1.58			0		
11/08/19 23:55	275255.1			0.9			1.48			0.6			1.59			1		
11/08/19 23:56	262624.5			0.9			1.48			0.57			1.51			1		
11/08/19 23:57	242600.3			0.9			2.25			0.54			2.13			1		
11/08/19 23:58	225733.8			0.9			5.61			0.46			4.95			1		
11/08/19 23:59	203322.2			0.8			9.3			0.39			7.38			1		
11/09/19 0:00	178908.1			0.7			14.75			0.28			10.3			1		
11/09/19 0:01	157035.6			4.2			16.72			1.56			10.25			1		
11/09/19 0:02	139861			356.8			18.68			118.45			10.21			1		
11/09/19 0:03	113213.5			1360.3			20.25			365.41			8.95			1		
11/09/19 0:04	0			1958.4			22.86			0			0			1		
11/09/19 0:05	0			0			25.57			0			0			0		
11/09/19 0:06	0			0			0.2			0			0			0		
11/09/19 0:07	0			0			0.1			0			0			0		
11/09/19 0:08	0			0			0.1			0			0			0		
11/09/19 0:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 29

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 23:24	0			0			0			0			0			0		
11/11/19 23:25	0			0			0			0			0			0		
11/11/19 23:26	0			0			0			0			0			0		
11/11/19 23:27	0			0			0			0			0			0		
11/11/19 23:28	2156.4			0			0			0			0			0		
11/11/19 23:29	13400.8			0.3			0			0			0			0		1
11/11/19 23:30	28958			0.6			0			0			0			0		1
11/11/19 23:31	41203.5			59.7			19.91			5.84			3.21			1		1
11/11/19 23:32	52524.9			506.8			16.46			63.19			3.38			1		1
11/11/19 23:33	67312			374.9			20.95			59.84			5.5			1		1
11/11/19 23:34	106051			244.1			25.29			61.43			10.47			1		1
11/11/19 23:35	134161.8			119.4			37.52			38.01			19.66			1		1
11/11/19 23:36	141170.3			81.1			51.63			27.17			28.45			1		1
11/11/19 23:37	160270.2			1464.1			42.91			556.82			26.86			1		1
11/11/19 23:38	179139.2			1228.7			53.76			522.29			37.61			1		1
11/11/19 23:39	203091.1			244.3			62.23			117.73			49.36			1		1
11/11/19 23:40	224039.5			16.3			61.83			8.69			54.1			1		1
11/11/19 23:41	242985.4			2.3			64.12			1.35			60.85			1		1
11/11/19 23:42	267784.5			1.8			57.4			1.14			60.01			1		1
11/11/19 23:43	286345.4			1.8			38.9			1.19			43.5			1		1
11/11/19 23:44	286884.5			1.9			21.17			1.3			23.72			1		1
11/11/19 23:45	286653.4			2			15.67			1.38			17.54			1		1
11/11/19 23:46	286268.4			1.9			13.91			1.32			15.55			1		1
11/11/19 23:47	290119.2			1.8			12.6			1.23			14.28			1		1
11/11/19 23:48	291274.4			1.7			11.62			1.17			13.22			1		1
11/11/19 23:49	291890.5			1.6			11.26			1.11			12.84			1		1
11/11/19 23:50	290889.3			1.5			10.19			1.05			11.57			1		1
11/11/19 23:51	289734.1			1.4			9.39			0.98			10.62			1		1
11/11/19 23:52	289349			1.3			9.21			0.92			10.4			1		1
11/11/19 23:53	288886.9			1.3			9.03			0.86			10.18			1		1
11/11/19 23:54	289118			1.3			8.94			0.86			10.09			1		1
11/11/19 23:55	289349			1.2			8.99			0.81			10.15			1		1
11/11/19 23:56	288193.8			1.2			8.99			0.81			10.11			1		1
11/11/19 23:57	288270.8			1.2			9.08			0.81			10.22			1		1
11/11/19 23:58	287885.7			1.2			8.35			0.81			9.39			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 23:59	287346.6			1.1			8.99			0.74			10.08			1		
11/12/19 0:00	287500.6			1.1			8.99			0.74			10.09			1		
11/12/19 0:01	287962.7			1.1			8.99			0.74			10.1			1		
11/12/19 0:02	286191.3			1			9.08			0.68			10.15			1		
11/12/19 0:03	287346.6			1			9.17		X	0.68			10.29		X	1		
11/12/19 0:04	287346.6			1			9.17		X	0.68			10.29		X	1		
11/12/19 0:05	286730.5			1			9.08			0.68			10.16			1		
11/12/19 0:06	286499.4			0.9			9.26			0.62			10.36			1		
11/12/19 0:07	286730.5			0.9			9.35			0.62			10.47			1		
11/12/19 0:08	286807.5			1			9.44			0.68			10.57			1		
11/12/19 0:09	286961.5			1			9.71			0.68			10.88			1		
11/12/19 0:10	286422.4			1			9.89			0.68			11.07			1		
11/12/19 0:11	285575.2			0.9			6.9			0.62			7.69			1		
11/12/19 0:12	285498.2			0.9			4.18			0.61			4.65			1		
11/12/19 0:13	285883.3			1			3.63			0.68			4.05			1		
11/12/19 0:14	285344.2			1			3.36			0.68			3.74			1		
11/12/19 0:15	285806.3			1			3.09			0.68			3.44			1		
11/12/19 0:16	285190.2			1			2.81			0.68			3.13			1		
11/12/19 0:17	285498.2			1			2.54			0.68			2.83			1		
11/12/19 0:18	285806.3			0.9			2.36			0.62			2.63			1		
11/12/19 0:19	285267.2			0.9			2.09			0.61			2.33			1		
11/12/19 0:20	285113.1			0.9			2			0.61			2.22			1		
11/12/19 0:21	289965.1			0.9			1.82			0.62			2.06			1		
11/12/19 0:22	290812.3			0.9			1.63			0.63			1.86			1		
11/12/19 0:23	292814.7			1			1.54			0.69			1.76			0		
11/12/19 0:24	291736.5			1			1.54			0.69			1.76			0		
11/12/19 0:25	293122.8			1			1.45			0.69			1.66			0		
11/12/19 0:26	292814.7			1			1.36			0.69			1.56			0		
11/12/19 0:27	292352.6			1			1.36			0.69			1.55			0		

CT2 SUSD EVENT 30

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/19 0:02	281724.4			0.9			1.72			0.61			1.9			0		
11/15/19 0:03	282186.5			0.9			1.63			0.61			1.8			0		
11/15/19 0:04	280723.2			0.9			1.63			0.6			1.79			0		
11/15/19 0:05	282648.6			0.8			1.54			0.55			1.7			0		
11/15/19 0:06	282340.6			0.8			1.63			0.55			1.8			0		
11/15/19 0:07	282032.5			0.9			1.72			0.61			1.9			1		
11/15/19 0:08	265705.1			0.9			1.63			0.57			1.7			1		
11/15/19 0:09	245372.9			0.8			2.77			0.48			2.65			1		
11/15/19 0:10	227428.2			0.8			6.85			0.41			6.09			1		
11/15/19 0:11	205170.5			0.8			13.3			0.39			10.66			1		
11/15/19 0:12	181603.7			0.6			17.49			0.28			12.4			1		
11/15/19 0:13	159885.2			4.1			19.51			1.55			12.18			1		
11/15/19 0:14	142479.5			377.2			21.4			127.49			11.91			1		
11/15/19 0:15	126152.2			1396.4			22.96			417.91			11.31			1		
11/15/19 0:16	0			1961.8			25.44			0			0			1		
11/15/19 0:17	0			0			28.32			0			0			0		
11/15/19 0:18	0			0			0.2			0			0			0		
11/15/19 0:19	0			0			0.1			0			0			0		
11/15/19 0:20	0			0			0.1			0			0			0		
11/15/19 0:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 31

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 3:39	0			0			0			0			0			0		
11/20/19 3:40	0			0			0			0			0			0		
11/20/19 3:41	0			0			0			0			0			0		
11/20/19 3:42	0			0			0			0			0			0		
11/20/19 3:43	2772.6			0			0			0			0			0		
11/20/19 3:44	12861.7			0.1			0			0			0			0		1
11/20/19 3:45	29343.1			0.1			0			0			0			0		1
11/20/19 3:46	41819.7			46.4			21.07			4.6			3.44			1		
11/20/19 3:47	51985.8			520.1			16.77			64.15			3.4			1		
11/20/19 3:48	67620			381.4			21.54			61.22			5.69			1		
11/20/19 3:49	107129.2			254			25.57			64.58			10.7			1		
11/20/19 3:50	133314.6			123.2			39.41			38.96			20.52			1		
11/20/19 3:51	139398.9			144.4			50.52			47.76			27.51			1		
11/20/19 3:52	155341.2			1642.3			37.37			605.49			22.67			1		
11/20/19 3:53	176058.5			1369.8			42.45			572.15			29.18			1		
11/20/19 3:54	197391.9			357			53.96			167.19			41.59			1		
11/20/19 3:55	219341.5			30			61.05			15.62			52.29			1		
11/20/19 3:56	239057.6			2.7			65.13			1.54			60.8			1		
11/20/19 3:57	264087.8			1.9			64.18			1.17			66.17			1		
11/20/19 3:58	285344.2			1.8			46.45			1.2			51.76			1		
11/20/19 3:59	295356.3			1.8			26.03			1.28			30.02			1		
11/20/19 4:00	296665.5			2.1			19.96			1.47			23.12			1		
11/20/19 4:01	296203.4			2.1			19.35			1.46			22.38			1		
11/20/19 4:02	308526			1.9			17.44			1.4			21.01			1		
11/20/19 4:03	325469.5			1.8			14.84			1.41			18.86			1		
11/20/19 4:04	343260.2			1.8			11.27			1.43			15.11			1		
11/20/19 4:05	362437.2			1.6			10.08			1.41			14.26			1		
11/20/19 4:06	384078.7			1.4			9.59			1.26			14.38			1		
11/20/19 4:07	395400			1.2			9.31			1.12			14.38			1		
11/20/19 4:08	398018.5			1.1			9.55	X		1.06			14.85	X		1		
11/20/19 4:09	398711.7			1			9.46			0.97			14.73			1		
11/20/19 4:10	400329			0.9			9.65			0.89			15.08			1		
11/20/19 4:11	398018.5			1			9.74			0.97			15.14			1		
11/20/19 4:12	398403.6			1			9.74			0.97			15.15			1		
11/20/19 4:13	397171.4			0.9			9.74			0.88			15.11			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 4:14	396401.2			0.9			9.65			0.88			14.93			1		
11/20/19 4:15	396324.2			0.9			9.65			0.88			14.93			1		
11/20/19 4:16	394937.9			0.8			9.74			0.79			15.02			1		
11/20/19 4:17	392781.5			0.8			9.93			0.79			15.22			1		
11/20/19 4:18	393474.6			0.9			9.93			0.87			15.25			1		
11/20/19 4:19	394398.8			0.9			10.11			0.88			15.58			1		
11/20/19 4:20	394167.8			0.8			10.21			0.79			15.71			1		
11/20/19 4:21	392473.4			0.8			10.4			0.78			15.93			1		
11/20/19 4:22	393474.6			0.8			10.4			0.79			15.97			1		
11/20/19 4:23	393474.6			0.8			7.96			0.79			12.23			1		
11/20/19 4:24	392935.5			0.8			5.15			0.79			7.9			1		
11/20/19 4:25	393012.5			0.8			4.78			0.79			7.33			1		
11/20/19 4:26	391472.2			0.8			4.59			0.78			7.02			1		
11/20/19 4:27	390316.9			0.8			4.31			0.78			6.57			1		
11/20/19 4:28	390933.1			0.8			4.03			0.78			6.15			1		
11/20/19 4:29	392550.4			0.8			3.84			0.79			5.89			1		
11/20/19 4:30	391395.2			0.8			3.65			0.78			5.58			1		
11/20/19 4:31	390625			0.8			3.28			0.78			5			1		
11/20/19 4:32	389546.8			0.8			2.81			0.78			4.27			1		
11/20/19 4:33	391626.2			0.8			2.43			0.78			3.72			1		
11/20/19 4:34	392396.4			0.8			2.06			0.78			3.16			1		
11/20/19 4:35	391780.3			0.8			1.78			0.78			2.72			1		
11/20/19 4:36	390856.1			0.8			1.59			0.78			2.43			1		
11/20/19 4:37	390239.9			0.8			1.5			0.78			2.28			1		
11/20/19 4:38	388853.7			0.8			1.4			0.78			2.13			0		
11/20/19 4:39	390471			0.8			1.31			0.78			2			0		
11/20/19 4:40	388930.7			0.8			1.22			0.78			1.85			0		
11/20/19 4:41	389238.7			0.8			1.31			0.78			1.99			0		
11/20/19 4:42	389700.8			0.8			1.31			0.78			2			0		

CT2 SUSD EVENT 32

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 6:56	339640.4			0.9			0.82			0.73			1.08			0		
11/20/19 6:57	338716.3			0.9			0.82			0.73			1.08			0		
11/20/19 6:58	335019.5			0.9			0.82			0.72			1.07			0		
11/20/19 6:59	319693.3			0.9			0.82			0.69			1.02			0		
11/20/19 7:00	297743.8			0.9			0.8			0.63			0.94			0		
11/20/19 7:01	275948.2			1			0.72			0.64			0.77			1		
11/20/19 7:02	257233.3			1			0.72			0.6			0.72			1		
11/20/19 7:03	236670.1			0.9			0.92			0.52			0.85			1		
11/20/19 7:04	219341.5			0.9			2.19			0.45			1.87			1		
11/20/19 7:05	196852.8			0.7			4.98			0.33			3.83			1		
11/20/19 7:06	173131.9			0.6			8.02			0.23			5.42			1		
11/20/19 7:07	151413.4			6.5			10.42			2.35			6.16			1		
11/20/19 7:08	135471.1			456.7			12.81			146.82			6.78			1		
11/20/19 7:09	102046.2			1524			15.73			369.12			6.27			1		
11/20/19 7:10	0			0			20.75			0			0			0		
11/20/19 7:11	0			0			53.1			0			0			0		
11/20/19 7:12	0			0			0.2			0			0			0		
11/20/19 7:13	0			0			0.2			0			0			0		
11/20/19 7:14	0			0			0.1			0			0			0		

CT2 SUSD EVENT 33

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 6:40	0			0			0			0			0			0		
11/21/19 6:41	0			0			0			0			0			0		
11/21/19 6:42	0			0			0			0			0			0		
11/21/19 6:43	0			0			0			0			0			0		
11/21/19 6:44	0			0			0			0			0			0		
11/21/19 6:45	16250.4			0.2			0			0			0			0		1
11/21/19 6:46	30421.3			1.1			0			0			0			0		1
11/21/19 6:47	41896.7			577.6			21.24			57.41			3.47			11.18		1
11/21/19 6:48	52987			554.3			18.01			69.73			3.73			22.99		1
11/21/19 6:49	66464.8			413			23.6			65.08			6.12			31.57		1
11/21/19 6:50	106128			273.9			26.97			68.98			11.18			32.26		1
11/21/19 6:51	136318.3			138.3			43.19			44.73			22.99			39.82		1
11/21/19 6:52	142864.6			114.7			56.6			38.87			31.57			45.17		1
11/21/19 6:53	158806.9			1603.2			52.03			603.98			32.26			48.93		1
11/21/19 6:54	180833.5			1335.5			56.38			573.09			39.82			54.74		1
11/21/19 6:55	200472.6			362.2			57.7			172.29			45.17			60.68		1
11/21/19 6:56	221343.9			34.5			56.61			18.13			48.93			61.52		1
11/21/19 6:57	242754.3			3.1			57.75			1.76			54.74			61.52		1
11/21/19 6:58	266629.3			1.8			58.29			1.16			60.68			61.52		1
11/21/19 6:59	282032.5			1.9			41.39			1.25			45.6			61.52		1
11/21/19 7:00	281493.4			2			25.08			1.33			27.56			61.52		1
11/21/19 7:01	280338.1			2.2			21.43			1.44			23.46			61.52		1
11/21/19 7:02	279491			2.2			19.64			1.46			21.44			61.52		1
11/21/19 7:03	277257.5			2			19.02			1.33			20.59			61.52		1
11/21/19 7:04	283264.8			1.8			18.14			1.24			20.07			61.52		1
11/21/19 7:05	300285.3			1.7			15.38			1.21			18.03			61.52		1
11/21/19 7:06	318846.1			1.6			10.92			1.2			13.6			61.52		1
11/21/19 7:07	337330			1.5			10.04			1.2			13.23			61.52		1
11/21/19 7:08	354735.6			1.4			8.31			1.2			11.52			61.52		1
11/21/19 7:09	376146			1.4			7.72			1.22			11.33			61.52		1
11/21/19 7:10	395400			1.2			8.11			1.12			12.53			61.52		1
11/21/19 7:11	412035.4			1.2			8.39			1.17			13.5			61.52		1
11/21/19 7:12	412651.6			1.2			9.03			1.17			14.56			61.52		1
11/21/19 7:13	411573.3			1.1			9.96			1.08			16			61.52		1
11/21/19 7:14	406721.3			1.1			9.96			1.07			15.81			61.52		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 7:15	410187.1			1.1			10.14			1.08			16.24			1		
11/21/19 7:16	411034.3			1.1			10.33			1.08			16.57			1		
11/21/19 7:17	411881.4			1.1			10.6			1.08			17.05			1		
11/21/19 7:18	411342.3			1.1			10.97			1.08			17.62			1		
11/21/19 7:19	408492.7			1.1			11.34			1.07			18.09			1		
11/21/19 7:20	407414.5			1			11.43			0.98			18.19			1		
11/21/19 7:21	406182.3			1			10.4			0.99			16.49			1		
11/21/19 7:22	407183.4			1			4.87			1			7.74			1		
11/21/19 7:23	405951.2			0.9			3.28			0.9			5.2			1		
11/21/19 7:24	406567.3			0.9			3			0.9			4.76			1		
11/21/19 7:25	404718.9			0.9			3			0.9			4.74			1		
11/21/19 7:26	404718.9			0.9			2.9			0.9			4.59			1		
11/21/19 7:27	404564.9			0.9			2.81			0.9			4.44			1		
11/21/19 7:28	405566.1			0.9			2.53			0.9			4			1		
11/21/19 7:29	405412.1			1			2.34			0.99			3.71			1		
11/21/19 7:30	405951.2			1			2.06			0.99			3.27			1		
11/21/19 7:31	403486.7			1			1.84			0.97			2.91			1		
11/21/19 7:32	403178.6			1			1.66			0.97			2.61			1		
11/21/19 7:33	404487.9			0.9			1.57			0.88			2.48			1		
11/21/19 7:34	404025.8			0.9			1.48			0.88			2.33			0		
11/21/19 7:35	400252			0.9			1.38			0.88			2.16			0		
11/21/19 7:36	402408.5			0.9			1.29			0.88			2.03			0		
11/21/19 7:37	404564.9			0.9			1.2			0.88			1.89			0		
11/21/19 7:38	403332.7			0.8			1.2			0.79			1.89			0		

CT2 SUSD EVENT 34

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/19 0:01	277180.5			1			1.54			0.66			1.67			0		
11/23/19 0:02	278335.7			0.9			1.75			0.61			1.9			0		
11/23/19 0:03	277719.6			0.9			1.94			0.61			2.1			0		
11/23/19 0:04	278104.7			0.8			2.03			0.55			2.2			0		
11/23/19 0:05	277565.6			0.8			2.03			0.55			2.2			0		
11/23/19 0:06	276102.3			0.8			2.03			0.54			2.19			1		
11/23/19 0:07	257079.3			0.8			2.21			0.51			2.22			1		
11/23/19 0:08	238210.4			0.8			4.79			0.47			4.46			1		
11/23/19 0:09	219418.5			0.8			8.03			0.4			6.88			1		
11/23/19 0:10	195081.5			0.7			16.66			0.34			12.7			1		
11/23/19 0:11	172438.8			1.7			20.01			0.71			13.48			1		
11/23/19 0:12	153030.7			11.9			21.8			4.33			13.03			1		
11/23/19 0:13	136857.4			706.5			24.34			229.48			13.01			1		
11/23/19 0:14	78864.4			1722.6			26.3			322.37			8.1			1		
11/23/19 0:15	0			0			29.05			0			0			0		
11/23/19 0:16	0			0			23.6			0			0			0		
11/23/19 0:17	0			0			0.2			0			0			0		
11/23/19 0:18	0			0			0.2			0			0			0		
11/23/19 0:19	0			0			0.1			0			0			0		

CT2 SUSD EVENT 35

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 3:40	0			0			0			0			0			0		
11/26/19 3:41	0			0			0			0			0			0		
11/26/19 3:42	0			0			0			0			0			0		
11/26/19 3:43	0			0			0			0			0			0		
11/26/19 3:44	3080.6			0			0			0			0			0		
11/26/19 3:45	15018.1			0.1			0			0			0			0		1
11/26/19 3:46	23566.9			0.1			0			0			0			0		1
11/26/19 3:47	37814.8			70.8			59			6.36			8.72			1		
11/26/19 3:48	49444.3			601.8			15.86			70.59			3.06			1		
11/26/19 3:49	59302.3			516.3			19.67			72.69			4.56			1		
11/26/19 3:50	88106.3			359			24.53			75.05			8.44			1		
11/26/19 3:51	131620.3			221.7			26.41			69.22			13.57			1		
11/26/19 3:52	140169.1			94.4			47.2			31.4			25.84			1		
11/26/19 3:53	155726.3			840.4			46.46			310.58			28.26			1		
11/26/19 3:54	173285.9			1812.2			46.13			745.18			31.22			1		
11/26/19 3:55	194080.3			829.1			56.36			381.76			42.71			1		
11/26/19 3:56	215336.7			107.3			63.02			54.82			53.01			1		
11/26/19 3:57	237132.2			6.6			64.06			3.73			59.33			1		
11/26/19 3:58	258311.6			2.2			67.09			1.34			67.67			1		
11/26/19 3:59	283649.8			1.9			58			1.28			64.25			1		
11/26/19 4:00	299207.1			1.7			38.85			1.22			45.4			1		
11/26/19 4:01	300362.3			1.9			22.3			1.36			26.16			1		
11/26/19 4:02	301209.5			2.1			19.26			1.49			22.66			1		
11/26/19 4:03	299361.1			2			17.96			1.42			20.99			1		
11/26/19 4:04	298822			1.9			16.14			1.35			18.83			1		
11/26/19 4:05	297897.8			1.8			15.06			1.31			17.52			1		
11/26/19 4:06	297820.8			1.7			13.74			1.18			15.98			1		
11/26/19 4:07	298205.8			1.6			12.68			1.12			14.77			1		
11/26/19 4:08	297512.7			1.4			11.98			0.99			13.92			1		
11/26/19 4:09	298051.8			1.3			11.62			0.93			13.53			1		
11/26/19 4:10	297820.8			1.3			11.27			0.93			13.11			1		
11/26/19 4:11	296357.5			1.3			11.26			0.88			13.03			1		
11/26/19 4:12	296357.5			1.3			11.08			0.88			12.83			1		
11/26/19 4:13	296357.5			1.3			11			0.88			12.72			1		
11/26/19 4:14	296511.5			1.3			10.91			0.88			12.63			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 4:15	295279.3			1.2			10.91			0.81			12.58			1		
11/26/19 4:16	296511.5			1.2			10.82			0.82			12.52			1		
11/26/19 4:17	295048.2			1.1			10.82			0.75			12.46			1		
11/26/19 4:18	295356.3			1.1			10.82			0.75			12.48			1		
11/26/19 4:19	295048.2			1			10.73			0.69			12.36			1		
11/26/19 4:20	295048.2			1			10.73			0.69			12.36			1		
11/26/19 4:21	293892.9			1			10.73			0.69			12.31			1		
11/26/19 4:22	295279.3			1			10.91			0.69			12.58			1		
11/26/19 4:23	295510.3			1			11.08			0.69			12.79			1		
11/26/19 4:24	295972.4			1			11.26			0.69			13.02			1		
11/26/19 4:25	295741.3			0.9			11.44			0.63			13.22			1		
11/26/19 4:26	293815.9			0.9			11.62			0.62			13.33			1		
11/26/19 4:27	293892.9			0.9			11.89			0.62			13.64			1		
11/26/19 4:28	295202.2			1			11.8			0.69			13.6			1		
11/26/19 4:29	293892.9			1			7.78			0.69			8.92			1		
11/26/19 4:30	294509.1			0.9			4.56			0.62			5.24			1		
11/26/19 4:31	294817.2			0.9			3.58			0.63			4.12			1		
11/26/19 4:32	293970			0.9			3.13			0.62			3.59			1		
11/26/19 4:33	294047			0.9			3.04			0.62			3.49			1		
11/26/19 4:34	292968.8			0.9			2.77			0.62			3.17			1		
11/26/19 4:35	293045.8			0.9			2.59			0.62			2.97			1		
11/26/19 4:36	294278			0.9			2.32			0.62			2.67			1		
11/26/19 4:37	291890.5			0.9			2.15			0.62			2.45			1		
11/26/19 4:38	293507.9			0.9			1.88			0.62			2.15			1		
11/26/19 4:39	294278			0.9			1.7			0.62			1.95			1		
11/26/19 4:40	292814.7			0.9			1.61			0.62			1.84			1		
11/26/19 4:41	291967.6			0.9			1.52			0.62			1.73			0		
11/26/19 4:42	293584.9			0.9			1.43			0.62			1.64			0		
11/26/19 4:43	294432.1			0.9			1.34			0.62			1.54			0		
11/26/19 4:44	292814.7			0.9			1.25			0.62			1.43			0		
11/26/19 4:45	293507.9			0.9			1.25			0.62			1.43			0		

CT2 SUSD EVENT 36

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 23:53	344184.4			0.8			2			0.66			2.65			0		
12/04/19 23:54	325161.4			0.9			1.91			0.69			2.39			0		
12/04/19 23:55	311221.5			0.9			1.88			0.65			2.25			0		
12/04/19 23:56	303519.9			1			1.85			0.69			2.16			0		
12/04/19 23:57	286191.3			1			1.79			0.66			1.97			0		
12/04/19 23:58	267399.5			1			1.79			0.62			1.84			1		
12/04/19 23:59	248222.5			0.9			2.21			0.54			2.12			1		
12/05/19 0:00	231433			0.9			4.96			0.51			4.43			1		
12/05/19 0:01	208790.3			0.8			8.95			0.38			7.2			1		
12/05/19 0:02	186224.6			0.5			16.86			0.23			12.1			1		
12/05/19 0:03	163273.9			3			19.12			1.13			12.03			1		
12/05/19 0:04	144636			195.5			21.19			66.21			11.81			1		
12/05/19 0:05	127461.4			1044.1			23.6			311.56			11.59			1		
12/05/19 0:06	36274.5			1848.8			25.34			156.85			3.54			1		
12/05/19 0:07	0			0			28.32			0			0			0		
12/05/19 0:08	0			0			11.8			0			0			0		
12/05/19 0:09	0			0			0.2			0			0			0		
12/05/19 0:10	0			0			0.1			0			0			0		
12/05/19 0:11	0			0			0.1			0			0			0		

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:32 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2019	0.3310	3.6667	0.3916	8.6208	0.0696	1.5963	0.0349	0.7982	0.1162	2.6610
Nov 2019	0.5504	3.5681	1.0151	8.9063	0.1824	1.6530	0.0911	0.8264	0.3043	2.7560
Dec 2019	0.0850	3.2072	0.2419	7.8108	0.0460	1.4448	0.0230	0.7223	0.0767	2.4089
Sum/Avg	3.2072		7.8108		1.4448		0.7223		2.4089	
Limit Value										

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
10/01/19 0:00	0			0			0			0								
10/02/19 0:00	0			0			0			0								
10/03/19 0:00	0			0			0			0								
10/04/19 0:00	0			0			0			0								
10/05/19 0:00	0			0			0			0								
10/06/19 0:00	0			0			0			0								
10/07/19 0:00	0			0			0			0								
10/08/19 0:00	0			0			0			0								
10/09/19 0:00	0			0			0			0								
10/10/19 0:00	0			0			0			0								
10/11/19 0:00	0			0			0			0								
10/12/19 0:00	0			0			0			0								
10/13/19 0:00	0			0			0			0								
10/14/19 0:00	0			0			0			0								
10/15/19 0:00	0			0			0			0								
10/16/19 0:00	0			0			0			0								
10/17/19 0:00	0			0			0			0								
10/18/19 0:00	0			0			0			0								
10/19/19 0:00	0			0			0			0								
10/20/19 0:00	0			0			0			0								
10/21/19 0:00	0			0			46.26			65.45								
10/22/19 0:00	0			0			18.36			60.33								
10/23/19 0:00	0			0			17.21			63.08								
10/24/19 0:00	31.75			39.81			23.23			45.38								
10/25/19 0:00	21.05			60.97			41.88			24.09								
10/26/19 0:00	19.6			50.83			0			0								
10/27/19 0:00	17.37			52.71			0			0								
10/28/19 0:00	22.77			62.36			0			0								
10/29/19 0:00	15.49			84.49			321.22			18.34								
10/30/19 0:00	23.09			68.72			13.71			6.98								
10/31/19 0:00	18.36			79.67			0			0								
11/01/19 0:00	24.95			72.99			0			0								
11/02/19 0:00	22.69			65.84			0			0								
11/03/19 0:00	21.34			61.8			0			0								
11/04/19 0:00	18.26			69.4			0			0								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
11/05/19 0:00	22.88			64.88			29.2			35.83								
11/06/19 0:00	20.58			63.42			21.84			63.44								
11/07/19 0:00	22.95			74.68			60.72			34.7								
11/08/19 0:00	25.46			68.64			36.89			44.82								
11/09/19 0:00	23.42			58.39			13.34			0.66								
11/10/19 0:00	23.22			57.7			0			0								
11/11/19 0:00	24.65			62.2			23.75			9.93								
11/12/19 0:00	17.3			1.6			22.88			61.74								
11/13/19 0:00	48.91			50.61			23.66			61.69								
11/14/19 0:00	40.62			56.12			17.84			55.22								
11/15/19 0:00	0			0			19.85			1.69								
11/16/19 0:00	0			0			0			0								
11/17/19 0:00	0			0			0			0								
11/18/19 0:00	0			0			0			0								
11/19/19 0:00	0			0			0			0								
11/20/19 0:00	0			0			41.86			21.26								
11/21/19 0:00	53.98			55.97			43.34			54.66								
11/22/19 0:00	22.36			63.98			19.53			61.43								
11/23/19 0:00	0			0			13.86			1.69								
11/24/19 0:00	0			0			0			0								
11/25/19 0:00	0			0			0			0								
11/26/19 0:00	80.36			61.71			47.71			66.55								
11/27/19 0:00	20.26			58.06			18.19			57.8								
11/28/19 0:00	18.99			52.68			17.19			51.99								
11/29/19 0:00	19.98			56.81			18.57			56.91								
11/30/19 0:00	19.96			57.25			17.82			53.61								
12/01/19 0:00	20.19			56.13			18.12			51.13								
12/02/19 0:00	16.62			64.16			18.47			61.25								
12/03/19 0:00	15.21			59.59			20.13			56.77								
12/04/19 0:00	13.39			68.07			18.3			64.49								
12/05/19 0:00	15.25			1			14.32			1.15								
12/06/19 0:00	0			0			0			0								
12/07/19 0:00	0			0			0			0								
12/08/19 0:00	0			0			0			0								
12/09/19 0:00	0			0			0			0								
12/10/19 0:00	0			0			0			0								
12/11/19 0:00	0			0			0			0								
12/12/19 0:00	0			0			0			0								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
12/13/19 0:00	0			0			0			0								
12/14/19 0:00	0			0			0			0								
12/15/19 0:00	0			0			0			0								
12/16/19 0:00	0			0			0			0								
12/17/19 0:00	0			0			0			0								
12/18/19 0:00	0			0			0			0								
12/19/19 0:00	0			0			0			0								
12/20/19 0:00	0			0			0			0								
12/21/19 0:00	0			0			0			0								
12/22/19 0:00	0			0			0			0								
12/23/19 0:00	0			0			0			0								
12/24/19 0:00	0			0			0			0								
12/25/19 0:00	0			0			0			0								
12/26/19 0:00	0			0			0			0								
12/27/19 0:00	0			0			0			0								
12/28/19 0:00	0			0			0			0								
12/29/19 0:00	0			0			0			0								
12/30/19 0:00	0			0			0			0								
12/31/19 0:00	0			0			0			0								

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/01/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/02/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/03/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/04/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/05/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/06/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/07/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/08/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/09/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/10/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/11/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/12/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/13/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/14/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/15/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/16/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/17/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
10/21/19 5:00	0	X		0	X		0	X	1	0			0			17.8		1
10/21/19 6:00	0	X		0	X		0	X	1	1.4			1.6			14.5		1
10/21/19 7:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
10/21/19 8:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
10/21/19 9:00	0	X		0	X		0	X	1	0.8			1.6			12.9		1
10/21/19 10:00	0	X		0	X		0	X	1	1.5			1.7			14		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 11:00	0	X		0	X		0	X	1	1			1.7			13.4		1
10/21/19 12:00	0	X		0	X		0	X	1	0.7			1.7			12.8		1
10/21/19 13:00	0	X		0	X		0	X	1	0.7			1.7			12.7		1
10/21/19 14:00	0	X		0	X		0	X	1	0.7			1.7			12.7		1
10/21/19 15:00	0	X		0	X		0	X	1	0.6			1.7			13.3		1
10/21/19 16:00	0	X		0	X		0	X	1	0.5			1.7			13.2		1
10/21/19 17:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
10/21/19 18:00	0	X		0	X		0	X	1	0.5			1.7			13.1		1
10/21/19 19:00	0	X		0	X		0	X	1	0.8			1.8			14.5		1
10/21/19 20:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
10/21/19 21:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
10/21/19 22:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
10/21/19 23:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
10/22/19 0:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
10/22/19 1:00	0	X		0	X		0	X	1	1			1.7			14.4		1
10/22/19 2:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
10/22/19 3:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
10/22/19 4:00	0	X		0	X		0	X	1	1.2			1.6			14.4		1
10/22/19 5:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
10/22/19 6:00	0	X		0	X		0	X	1	1.3			1.8			14.4		1
10/22/19 7:00	0	X		0	X		0	X	1	1.7			1.7			14.3		1
10/22/19 8:00	0	X		0	X		0	X	1	0.7			1.6			13.1		1
10/22/19 9:00	0	X		0	X		0	X	1	0.9			1.8			14.5		1
10/22/19 10:00	0	X		0	X		0	X	1	0.5			1.6			13.1		1
10/22/19 11:00	0	X		0	X		0	X	1	0.3			1.6			12.8		1
10/22/19 12:00	0	X		0	X		0	X	1	0.5			1.7			13.4		1
10/22/19 13:00	0	X		0	X		0	X	1	0.5			1.6			13.2		1
10/22/19 14:00	0	X		0	X		0	X	1	0.4			1.6			12.8		1
10/22/19 15:00	0	X		0	X		0	X	1	0.7			1.6			13.6		1
10/22/19 16:00	0	X		0	X		0	X	1	0.9			1.6			13.8		1
10/22/19 17:00	0	X		0	X		0	X	1	0.6			1.6			13.3		1
10/22/19 18:00	0	X		0	X		0	X	1	0.8			1.7			13.5		1
10/22/19 19:00	0	X		0	X		0	X	1	1			1.7			13.7		1
10/22/19 20:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
10/22/19 21:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
10/22/19 22:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
10/22/19 23:00	0	X		0	X		0	X	1	1			1.7			14.3		1
10/23/19 0:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/19 1:00	0	X		0	X		0	X	1	1			1.7			14.4		1
10/23/19 2:00	0	X		0	X		0	X	1	1			1.7			14.4		1
10/23/19 3:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
10/23/19 4:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
10/23/19 5:00	0	X		0	X		0	X	1	1			1.7			14.3		1
10/23/19 6:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
10/23/19 7:00	0	X		0	X		0	X	1	1			1.6			13.8		1
10/23/19 8:00	0	X		0	X		0	X	1	0.4			1.7			12.8		1
10/23/19 9:00	0	X		0	X		0	X	1	0.4			1.7			13.1		1
10/23/19 10:00	0	X		0	X		0	X	1	0.3			1.7			12.9		1
10/23/19 11:00	0	X		0	X		0	X	1	0.4			1.7			13.2		1
10/23/19 12:00	0	X		0	X		0	X	1	0.7			1.7			13.6		1
10/23/19 13:00	0	X		0	X		0	X	1	1.1			1.7			14.2		1
10/23/19 14:00	0	X		0	X		0	X	1	1.1			1.7			14.2		1
10/23/19 15:00	0	X		0	X		0	X	1	0.8			1.7			13.8		1
10/23/19 16:00	0	X		0	X		0	X	1	1			1.7			14		1
10/23/19 17:00	0	X		0	X		0	X	1	0.3			1.7			12.8		1
10/23/19 18:00	0	X		0	X		0	X	1	0.8			1.7			13.7		1
10/23/19 19:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
10/23/19 20:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
10/23/19 21:00	0	X		0	X		0	X	1	1.2			1.7			14.1		1
10/23/19 22:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
10/23/19 23:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 0:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
10/24/19 1:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 2:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 3:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 4:00	0	X		0	X		0	X	1	0.8			1.8			14.4		1
10/24/19 5:00	0	X		0	X		0	X	1	0.9			1.7			13.7		1
10/24/19 6:00	0	X		0	X		0	X	1	0.7			1.7			13.5		1
10/24/19 7:00	0	X		0	X		0	X	1	0.8			1.8			14.6		1
10/24/19 8:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
10/24/19 9:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
10/24/19 10:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 11:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
10/24/19 12:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
10/24/19 13:00	0			0			17.7		1	0.8			1.7			14.4		1
10/24/19 14:00	0.7			1.6			14.5		1	0.7			1.7			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 15:00	0.9			1.7			14.4		1	0.8			1.7			14.3		1
10/24/19 16:00	0.8			1.7			14.6		1	0.8			1.7			14.6		1
10/24/19 17:00	1.1			1.7			13.8		1	0.9			1.7			13.8		1
10/24/19 18:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
10/24/19 19:00	0.5			1.6			12.8		1	0			0			16.6		1
10/24/19 20:00	1.3			1.8			14.1		1	0	X		0	X		0	X	1
10/24/19 21:00	1.3			1.7			14.1		1	0	X		0	X		0	X	1
10/24/19 22:00	0.7			1.7			13.3		1	0	X		0	X		0	X	1
10/24/19 23:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
10/25/19 0:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 1:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 2:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 3:00	1.3			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 4:00	1.4			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 5:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
10/25/19 6:00	1.3			1.7			14.1		1	0	X		0	X		0	X	1
10/25/19 7:00	1.2			1.7			14.6		1	0	X		0	X		0	X	1
10/25/19 8:00	1.2			1.7			14.5		1	0	X		0	X		0	X	1
10/25/19 9:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 10:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/25/19 11:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/25/19 12:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/25/19 13:00	0.8			1.7			14.5		1	0			0			17.7		1
10/25/19 14:00	0.9			1.7			14.4		1	0.8			1.5			14.4		1
10/25/19 15:00	0.9			1.7			14.4		1	0.8			1.7			14.3		1
10/25/19 16:00	0.8			1.7			14.5		1	0.7			1.8			14.6		1
10/25/19 17:00	0.8			1.7			14.6		1	0.7			1.7			14.6		1
10/25/19 18:00	0.8			1.7			14.4		1	0.8			1.7			14.6		1
10/25/19 19:00	0.8			1.7			13.4		1	0	X		0	X		0	X	1
10/25/19 20:00	0.6			1.7			13		1	0	X		0	X		0	X	1
10/25/19 21:00	0.7			1.7			13.2		1	0	X		0	X		0	X	1
10/25/19 22:00	0.8			1.7			13.2		1	0	X		0	X		0	X	1
10/25/19 23:00	1.3			1.8			14.3		1	0	X		0	X		0	X	1
10/26/19 0:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
10/26/19 1:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
10/26/19 2:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 3:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 4:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/19 5:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
10/26/19 6:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
10/26/19 7:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
10/26/19 8:00	1.5			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 9:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 10:00	1			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 11:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 12:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/26/19 13:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/26/19 14:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 15:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 16:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 17:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 18:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 19:00	1			1.7			14.5		1	0	X		0	X		0	X	1
10/26/19 20:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 21:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 22:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/26/19 23:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 0:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 1:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 2:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 3:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 4:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 5:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 6:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 7:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 8:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 9:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 10:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 11:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 12:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 13:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 14:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 15:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
10/27/19 16:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 17:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/27/19 18:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/19 19:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 20:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 21:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 22:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/27/19 23:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/28/19 0:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/28/19 1:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/28/19 2:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/28/19 3:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/28/19 4:00	1.3			1.6			14.2		1	0	X		0	X		0	X	1
10/28/19 5:00	1.2			1.7			13.9		1	0	X		0	X		0	X	1
10/28/19 6:00	0.7			1.7			13.1		1	0	X		0	X		0	X	1
10/28/19 7:00	0.7			1.7			13.1		1	0	X		0	X		0	X	1
10/28/19 8:00	1			1.8			14.3		1	0	X		0	X		0	X	1
10/28/19 9:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/28/19 10:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/28/19 11:00	0.9			1.7			14.7		1	0	X		0	X		0	X	1
10/28/19 12:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/28/19 13:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/28/19 14:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/28/19 15:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/28/19 16:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/28/19 17:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/28/19 18:00	1.1			1.7			14.1		1	0	X		0	X		0	X	1
10/28/19 19:00	1.3			1.7			14.4		1	0	X		0	X		0	X	1
10/28/19 20:00	1			1.7			14.5		1	0	X		0	X		0	X	1
10/28/19 21:00	1.3			1.7			14.1		1	0	X		0	X		0	X	1
10/28/19 22:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
10/28/19 23:00	1			1.7			14.6		1	0	X		0	X		0	X	1
10/29/19 0:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/29/19 1:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
10/29/19 2:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
10/29/19 3:00	1			1.7			14.4		1	0			0		18.7			1
10/29/19 4:00	0.8			1.7			12.8		1	0			0		18.3			1
10/29/19 5:00	0.7			1.7			11.8		1	0			0		19.3			1
10/29/19 6:00	0.3			1.7			11.8		1	0	X		0	X	0	X		1
10/29/19 7:00	0.3			1.7			11.8		1	0	X		0	X	0	X		1
10/29/19 8:00	0.3			1.7			12		1	0	X		0	X	0	X		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 9:00	0.3			1.7			12		1	0			0			19.2		1
10/29/19 10:00	0.3			1.7			11.9		1	0			0			21		1
10/29/19 11:00	0.3			1.7			12		1	0	X		0	X		0	X	0
10/29/19 12:00	0.3			1.7			12		1	0	X		0	X		0	X	0
10/29/19 13:00	0.3			1.7			12		1	0	X		0	X		0	X	0
10/29/19 14:00	0.7			1.7			12.9		1	0	X		0	X		0	X	1
10/29/19 15:00	0.3			1.7			12.1		1	0	X		0	X		0	X	1
10/29/19 16:00	0.4			1.7			12.8		1	0	X		0	X		0	X	1
10/29/19 17:00	0.4			1.7			12.9		1	0	X		0	X		0	X	1
10/29/19 18:00	0.5			1.7			13.2		1	0	X		0	X		0	X	1
10/29/19 19:00	0.7			1.7			13.4		1	0	X		0	X		0	X	1
10/29/19 20:00	0.6			1.7			13.2		1	0	X		0	X		0	X	1
10/29/19 21:00	0.5			1.7			13		1	0	X		0	X		0	X	1
10/29/19 22:00	0.6			1.7			13		1	0	X		0	X		0	X	1
10/29/19 23:00	0.9			1.8			14.5		1	0	X		0	X		0	X	1
10/30/19 0:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/30/19 1:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/30/19 2:00	1			1.7			14.3		1	0	X		0	X		0	X	1
10/30/19 3:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/30/19 4:00	0.9			1.5			13.3		1	0	X		0	X		0	X	1
10/30/19 5:00	1.1			1.7			13.6		1	0	X		0	X		0	X	1
10/30/19 6:00	1.1			1.7			13.7		1	0	X		0	X		0	X	1
10/30/19 7:00	1			1.7			13.7		1	0	X		0	X		0	X	0
10/30/19 8:00	0.9			1.7			14.5		1	0	X		0	X		0	X	0
10/30/19 9:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
10/30/19 10:00	0.9			1.7			14.5		1	0.8			1.7			14.6		1
10/30/19 11:00	0.9			1.7			14.5		1	0.8			1.7			14.8		1
10/30/19 12:00	1.1			1.7			14		1	0	X		0	X		0	X	1
10/30/19 13:00	1			1.7			13.9		1	0	X		0	X		0	X	1
10/30/19 14:00	0.4			1.7			12.6		1	0	X		0	X		0	X	1
10/30/19 15:00	0.3			1.7			12.5		1	0	X		0	X		0	X	1
10/30/19 16:00	1			1.7			13.9		1	0	X		0	X		0	X	1
10/30/19 17:00	0.6			1.7			13.1		1	0	X		0	X		0	X	1
10/30/19 18:00	0.7			1.7			13.4		1	0	X		0	X		0	X	1
10/30/19 19:00	1.2			1.7			14		1	0	X		0	X		0	X	1
10/30/19 20:00	1			1.7			13.5		1	0	X		0	X		0	X	1
10/30/19 21:00	1.6			1.7			14		1	0	X		0	X		0	X	1
10/30/19 22:00	1.2			1.7			14.6		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 23:00	1.2			1.7			14.5		1	0	X		0	X		0	X	1
10/31/19 0:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
10/31/19 1:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
10/31/19 2:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
10/31/19 3:00	1			1.7			14.4		1	0	X		0	X		0	X	1
10/31/19 4:00	1.2			1.5			13.7		1	0	X		0	X		0	X	1
10/31/19 5:00	0.9			1.7			13.2		1	0	X		0	X		0	X	1
10/31/19 6:00	0.4			1.7			12.4		1	0	X		0	X		0	X	1
10/31/19 7:00	0.3			1.7			12.2		1	0	X		0	X		0	X	1
10/31/19 8:00	0.3			1.7			12.3		1	0	X		0	X		0	X	1
10/31/19 9:00	0.3			1.7			12.2		1	0	X		0	X		0	X	1
10/31/19 10:00	0.4			1.7			12.6		1	0	X		0	X		0	X	1
10/31/19 11:00	0.5			1.7			13.1		1	0	X		0	X		0	X	1
10/31/19 12:00	0.7			1.7			13.5		1	0	X		0	X		0	X	1
10/31/19 13:00	0.3			1.7			12.1		1	0	X		0	X		0	X	1
10/31/19 14:00	0.3			1.7			12.4		1	0	X		0	X		0	X	1
10/31/19 15:00	0.3			1.7			12.4		1	0	X		0	X		0	X	1
10/31/19 16:00	0.2			1.7			12		1	0	X		0	X		0	X	1
10/31/19 17:00	0.2			1.7			12		1	0	X		0	X		0	X	1
10/31/19 18:00	0.3			1.7			12.2		1	0	X		0	X		0	X	1
10/31/19 19:00	1.2			1.8			14.1		1	0	X		0	X		0	X	1
10/31/19 20:00	1.4			1.7			14.2		1	0	X		0	X		0	X	1
10/31/19 21:00	1.5			1.7			14.2		1	0	X		0	X		0	X	1
10/31/19 22:00	1.1			1.7			14.5		1	0	X		0	X		0	X	1
10/31/19 23:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/01/19 0:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/01/19 1:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/01/19 2:00	1			1.7			14.3		1	0	X		0	X		0	X	1
11/01/19 3:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/01/19 4:00	1.2			1.6			13.7		1	0	X		0	X		0	X	1
11/01/19 5:00	0.7			1.7			13		1	0	X		0	X		0	X	1
11/01/19 6:00	0.3			1.7			12.3		1	0	X		0	X		0	X	1
11/01/19 7:00	1.2			1.7			13.7		1	0	X		0	X		0	X	1
11/01/19 8:00	1.1			1.7			13.7		1	0	X		0	X		0	X	1
11/01/19 9:00	0.8			1.7			13.4		1	0	X		0	X		0	X	1
11/01/19 10:00	0.6			1.7			13.2		1	0	X		0	X		0	X	1
11/01/19 11:00	1.2			1.7			14.1		1	0	X		0	X		0	X	1
11/01/19 12:00	1.1			1.7			14.6		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/19 13:00	1			1.7			14.7		1	0	X		0	X		0	X	1
11/01/19 14:00	1.1			1.7			14.2		1	0	X		0	X		0	X	1
11/01/19 15:00	0.8			1.7			13.6		1	0	X		0	X		0	X	1
11/01/19 16:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/01/19 17:00	1.1			1.7			14		1	0	X		0	X		0	X	1
11/01/19 18:00	1.1			1.7			14.6		1	0	X		0	X		0	X	1
11/01/19 19:00	1			1.7			14.6		1	0	X		0	X		0	X	1
11/01/19 20:00	1.1			1.7			14.6		1	0	X		0	X		0	X	1
11/01/19 21:00	0.8			1.7			13.2		1	0	X		0	X		0	X	1
11/01/19 22:00	0.8			1.7			13.2		1	0	X		0	X		0	X	1
11/01/19 23:00	1.1			1.7			13.7		1	0	X		0	X		0	X	1
11/02/19 0:00	1.1			1.7			14.5		1	0	X		0	X		0	X	1
11/02/19 1:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 2:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 3:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 4:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/02/19 5:00	1.5			1.7			13.8		1	0	X		0	X		0	X	1
11/02/19 6:00	0.8			1.7			13.2		1	0	X		0	X		0	X	1
11/02/19 7:00	1.2			1.8			14.4		1	0	X		0	X		0	X	1
11/02/19 8:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 9:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 10:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/02/19 11:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
11/02/19 12:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/02/19 13:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
11/02/19 14:00	1			1.7			14.6		1	0	X		0	X		0	X	1
11/02/19 15:00	0.4			1.7			12.1		1	0	X		0	X		0	X	1
11/02/19 16:00	0.9			1.7			13.8		1	0	X		0	X		0	X	1
11/02/19 17:00	0.3			1.6			12.1		1	0	X		0	X		0	X	1
11/02/19 18:00	1			1.8			14.6		1	0	X		0	X		0	X	1
11/02/19 19:00	1			1.7			14.6		1	0	X		0	X		0	X	1
11/02/19 20:00	1.6			1.7			14.3		1	0	X		0	X		0	X	1
11/02/19 21:00	0.9			1.7			13.4		1	0	X		0	X		0	X	1
11/02/19 22:00	1			1.7			13.6		1	0	X		0	X		0	X	1
11/02/19 23:00	1.3			1.8			14.3		1	0	X		0	X		0	X	1
11/03/19 0:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 1:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 2:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/19 3:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 4:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 5:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 6:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 7:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/03/19 8:00	1.1			1.7			14.5		1	0	X		0	X		0	X	1
11/03/19 9:00	1.4			1.7			14.4		1	0	X		0	X		0	X	1
11/03/19 10:00	1.1			1.7			14.2		1	0	X		0	X		0	X	1
11/03/19 11:00	0.6			1.7			13.2		1	0	X		0	X		0	X	1
11/03/19 12:00	1			1.7			13.8		1	0	X		0	X		0	X	1
11/03/19 13:00	0.6			1.7			13.2		1	0	X		0	X		0	X	1
11/03/19 14:00	0.6			1.7			13.3		1	0	X		0	X		0	X	1
11/03/19 15:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
11/03/19 16:00	0.4			1.7			12.8		1	0	X		0	X		0	X	1
11/03/19 17:00	1			1.8			14.3		1	0	X		0	X		0	X	1
11/03/19 18:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/03/19 19:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/03/19 20:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/03/19 21:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/03/19 22:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/03/19 23:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 0:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 1:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/04/19 2:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/04/19 3:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/04/19 4:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/04/19 5:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 6:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 7:00	1.1			1.7			14.5		1	0	X		0	X		0	X	1
11/04/19 8:00	0.6			1.6			12.8		1	0	X		0	X		0	X	1
11/04/19 9:00	0.3			1.7			12		1	0	X		0	X		0	X	1
11/04/19 10:00	0.3			1.7			12		1	0	X		0	X		0	X	1
11/04/19 11:00	0.4			1.7			12.5		1	0	X		0	X		0	X	1
11/04/19 12:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
11/04/19 13:00	0.4			1.7			12.5		1	0	X		0	X		0	X	1
11/04/19 14:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
11/04/19 15:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
11/04/19 16:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/19 17:00	1.1			1.8			14		1	0	X		0	X		0	X	1
11/04/19 18:00	1			1.7			14.6		1	0	X		0	X		0	X	1
11/04/19 19:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/04/19 20:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 21:00	1.1			1.7			14.5		1	0	X		0	X		0	X	1
11/04/19 22:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/04/19 23:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/05/19 0:00	1.3			1.7			14.4		1	0	X		0	X		0	X	1
11/05/19 1:00	1.4			1.7			14.3		1	0	X		0	X		0	X	1
11/05/19 2:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/05/19 3:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/05/19 4:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/05/19 5:00	1.3			1.7			14.4		1	0	X		0	X		0	X	1
11/05/19 6:00	0.9			1.7			13.3		1	0	X		0	X		0	X	1
11/05/19 7:00	1			1.7			13.5		1	0	X		0	X		0	X	1
11/05/19 8:00	0.8			1.7			13.3		1	0	X		0	X		0	X	1
11/05/19 9:00	0.5			1.7			12.9		1	0	X		0	X		0	X	1
11/05/19 10:00	1			1.7			13.7		1	0	X		0	X		0	X	1
11/05/19 11:00	1			1.7			13.7		1	0	X		0	X		0	X	1
11/05/19 12:00	1			1.7			13.8		1	0	X		0	X		0	X	1
11/05/19 13:00	0.9			1.7			13.9		1	0			0			17.6		1
11/05/19 14:00	1			1.7			14.6		1	0.9			1.4			14.5		1
11/05/19 15:00	1			1.7			14.5		1	1			1.7			14.5		1
11/05/19 16:00	0.7			1.7			13.8		1	0.6			1.8			13.8		1
11/05/19 17:00	0.9			1.7			14.5		1	0.9			1.6			14.5		1
11/05/19 18:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/05/19 19:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/05/19 20:00	1			1.7			14.4		1	1			1.7			14.4		1
11/05/19 21:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
11/05/19 22:00	1.1			1.7			14.4		1	1.1			1.7			14.3		1
11/05/19 23:00	1.1			1.7			14.4		1	1.1			1.7			14.4		1
11/06/19 0:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/06/19 1:00	1			1.7			14.5		1	1			1.7			14.4		1
11/06/19 2:00	1			1.7			14.5		1	1			1.7			14.4		1
11/06/19 3:00	1			1.7			14.5		1	1			1.7			14.4		1
11/06/19 4:00	1.1			1.7			14.5		1	1.2			1.7			14.4		1
11/06/19 5:00	1.7			1.7			14.5		1	1.6			1.7			14.4		1
11/06/19 6:00	1.6			1.7			14.4		1	1.6			1.7			14.4		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/19 7:00	1.2			1.7			14.4		1	1.1			1.7			14.4		1
11/06/19 8:00	1.2			1.7			14.3		1	1.2			1.7			14.4		1
11/06/19 9:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/06/19 10:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/06/19 11:00	1			1.7			14.5		1	0.9			1.7			14.4		1
11/06/19 12:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/06/19 13:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/06/19 14:00	0.9			1.7			14.5		1	0.8			1.7			14.6		1
11/06/19 15:00	1.2			1.7			13.8		1	1.1			1.7			13.8		1
11/06/19 16:00	1.1			1.7			13.7		1	0.9			1.7			13.7		1
11/06/19 17:00	0.3			1.7			12.5		1	0.3			1.7			12.5		1
11/06/19 18:00	0.3			1.7			12.4		1	0.3			1.7			12.4		1
11/06/19 19:00	0.4			1.7			12.6		1	0.4			1.7			12.6		1
11/06/19 20:00	0.4			1.7			12.5		1	0.4			1.7			12.5		1
11/06/19 21:00	0.8			1.7			13.3		1	0.7			1.7			13.3		1
11/06/19 22:00	1.1			1.7			14.3		1	1			1.7			14.4		1
11/06/19 23:00	1.1			1.7			14.4		1	1			1.7			14.5		1
11/07/19 0:00	0.6			1.7			12.8		1	0			0			17.2		1
11/07/19 1:00	0.9			1.7			13.4		1	0	X		0	X		0	X	1
11/07/19 2:00	0.9			1.7			13.5		1	0	X		0	X		0	X	1
11/07/19 3:00	1			1.7			13.5		1	0	X		0	X		0	X	1
11/07/19 4:00	1.1			1.6			13.6		1	0	X		0	X		0	X	1
11/07/19 5:00	0.7			1.7			12.6		1	0	X		0	X		0	X	1
11/07/19 6:00	0.4			1.7			12.2		1	0	X		0	X		0	X	1
11/07/19 7:00	0.4			1.7			12.2		1	0	X		0	X		0	X	1
11/07/19 8:00	0.8			1.7			13.3		1	0	X		0	X		0	X	1
11/07/19 9:00	0.6			1.7			12.9		1	0	X		0	X		0	X	1
11/07/19 10:00	0.6			1.7			13		1	0			0			17.5		1
11/07/19 11:00	1			1.8			14.5		1	0.9			1.6			14.4		1
11/07/19 12:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/07/19 13:00	0.9			1.7			14.5		1	0.8			1.7			14.6		1
11/07/19 14:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/07/19 15:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/07/19 16:00	0.9			1.7			14.6		1	0.8			1.7			14.6		1
11/07/19 17:00	1			1.7			14.6		1	1			1.7			14.5		1
11/07/19 18:00	1.6			1.7			14.3		1	1.7			1.7			14.3		1
11/07/19 19:00	1.8			1.7			14.3		1	2			1.7			14.3		1
11/07/19 20:00	1.4			1.7			14.4		1	1.5			1.7			14.4		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:00	0.8			1.7			12.8		1	1.2			1.7			15.1		1
11/07/19 22:00	0.4			1.7			12		1	0	X		0	X		0	X	1
11/07/19 23:00	0.9			1.7			13.4		1	0	X		0	X		0	X	1
11/08/19 0:00	1			1.7			13.5		1	0	X		0	X		0	X	1
11/08/19 1:00	1.5			1.7			14.1		1	0	X		0	X		0	X	1
11/08/19 2:00	1.7			1.7			14.2		1	0	X		0	X		0	X	1
11/08/19 3:00	1.6			1.7			14.1		1	0	X		0	X		0	X	1
11/08/19 4:00	1.7			1.7			14.1		1	0	X		0	X		0	X	1
11/08/19 5:00	1.1			1.7			12.9		1	0	X		0	X		0	X	1
11/08/19 6:00	1			1.7			13.2		1	0	X		0	X		0	X	1
11/08/19 7:00	0.5			1.7			12.2		1	0	X		0	X		0	X	1
11/08/19 8:00	1.1			1.7			13.3		1	0	X		0	X		0	X	1
11/08/19 9:00	0.8			1.7			13.2		1	0			0			17.5		1
11/08/19 10:00	1.1			1.8			14.4		1	1			1.5			14.4		1
11/08/19 11:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/08/19 12:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/08/19 13:00	1			1.7			14.4		1	1			1.7			14.4		1
11/08/19 14:00	1			1.7			14.3		1	0.9			1.7			14.4		1
11/08/19 15:00	1.3			1.7			14.4		1	1.5			1.7			14.4		1
11/08/19 16:00	1.4			1.7			14.3		1	1.6			1.7			14.3		1
11/08/19 17:00	0.5			1.7			12.9		1	0.5			1.7			12.9		1
11/08/19 18:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
11/08/19 19:00	0.6			1.7			12.9		1	0.5			1.7			12.9		1
11/08/19 20:00	1			1.8			14.5		1	0.9			1.7			14.4		1
11/08/19 21:00	1			1.7			14.4		1	1			1.7			14.3		1
11/08/19 22:00	1			1.8			14.4		1	1			1.8			14.3		1
11/08/19 23:00	1			1.6			14.5		1	0.9			1.6			14.5		1
11/09/19 0:00	1.2			1.7			14.3		1	0			0			16.6		1
11/09/19 1:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 2:00	1.1			1.6			14.4		1	0	X		0	X		0	X	1
11/09/19 3:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 4:00	1.1			1.6			14.4		1	0	X		0	X		0	X	1
11/09/19 5:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 6:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 7:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 8:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 9:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 10:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/19 11:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 12:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 13:00	1			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 14:00	1			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 15:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
11/09/19 16:00	0.8			1.7			13.5		1	0	X		0	X		0	X	1
11/09/19 17:00	0.9			1.7			13.5		1	0	X		0	X		0	X	1
11/09/19 18:00	1.1			1.7			13.7		1	0	X		0	X		0	X	1
11/09/19 19:00	1.3			1.7			14		1	0	X		0	X		0	X	1
11/09/19 20:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 21:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/09/19 22:00	1.8			1.7			14.3		1	0	X		0	X		0	X	1
11/09/19 23:00	1.2			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 0:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 1:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 2:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 3:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 4:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 5:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 6:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 7:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 8:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 9:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 10:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 11:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/10/19 12:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/10/19 13:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 14:00	1			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 15:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
11/10/19 16:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/10/19 17:00	1.3			1.7			13.9		1	0	X		0	X		0	X	1
11/10/19 18:00	1.4			1.7			14		1	0	X		0	X		0	X	1
11/10/19 19:00	1.4			1.7			14.2		1	0	X		0	X		0	X	1
11/10/19 20:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 21:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/10/19 22:00	1.6			1.7			14.3		1	0	X		0	X		0	X	1
11/10/19 23:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 0:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 1:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 2:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 3:00	1.5			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 4:00	1.7			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 5:00	1.3			1.7			14.5		1	0	X		0	X		0	X	1
11/11/19 6:00	1.3			1.7			14.5		1	0	X		0	X		0	X	1
11/11/19 7:00	2.1			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 8:00	1.3			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 9:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 10:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 11:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 12:00	1			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 13:00	1			1.7			14.5		1	0	X		0	X		0	X	1
11/11/19 14:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
11/11/19 15:00	1			1.7			14.6		1	0	X		0	X		0	X	1
11/11/19 16:00	0.7			1.7			13.1		1	0	X		0	X		0	X	1
11/11/19 17:00	0.6			1.8			13.1		1	0	X		0	X		0	X	1
11/11/19 18:00	0.7			1.6			13.1		1	0	X		0	X		0	X	1
11/11/19 19:00	0.8			1.7			13.1		1	0	X		0	X		0	X	1
11/11/19 20:00	1.3			1.8			14.3		1	0	X		0	X		0	X	1
11/11/19 21:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
11/11/19 22:00	1.1			1.7			14.4		1	0	X		0	X		0	X	1
11/11/19 23:00	1.1			1.6			14.3		1	0			0			16		1
11/12/19 0:00	1			1.2			14.8		1	1			1.6			14.4		1
11/12/19 1:00	0	X		0	X		0	X	1	1			1.7			14.3		1
11/12/19 2:00	0	X		0	X		0	X	1	1			1.7			14.3		1
11/12/19 3:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/12/19 4:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
11/12/19 5:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/12/19 6:00	0	X		0	X		0	X	1	1.2			1.6			13.7		1
11/12/19 7:00	0	X		0	X		0	X	1	1.4			1.7			13.9		1
11/12/19 8:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
11/12/19 9:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/12/19 10:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/12/19 11:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/12/19 12:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/12/19 13:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/12/19 14:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 15:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/12/19 16:00	0	X		0	X		0	X	1	1.4			1.7			14.1		1
11/12/19 17:00	0	X		0	X		0	X	1	1.2			1.7			13.9		1
11/12/19 18:00	0	X		0	X		0	X	1	0.6			1.7			13.2		1
11/12/19 19:00	0	X		0	X		0	X	1	0.6			1.7			13.1		1
11/12/19 20:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
11/12/19 21:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/12/19 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/12/19 23:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
11/13/19 0:00	0	X		0	X		0	X	1	1.4			1.7			13.8		1
11/13/19 1:00	0	X		0	X		0	X	1	1.4			1.7			14.1		1
11/13/19 2:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/13/19 3:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/13/19 4:00	0	X		0	X		0	X	1	1.4			1.7			14		1
11/13/19 5:00	0	X		0	X		0	X	1	0.7			1.7			13.1		1
11/13/19 6:00	0			0			17.8		1	0.7			1.7			13.1		1
11/13/19 7:00	1.3			1.6			14.3		1	1.3			1.7			14.3		1
11/13/19 8:00	1.3			1.7			14.4		1	1.2			1.7			14.4		1
11/13/19 9:00	1			1.7			14.5		1	1			1.7			14.5		1
11/13/19 10:00	1			1.8			14.5		1	0.9			1.7			14.5		1
11/13/19 11:00	1			1.4			14.5		1	0.9			1.7			14.6		1
11/13/19 12:00	1			1.7			14.5		1	0.9			1.7			14.6		1
11/13/19 13:00	1			1.7			14.5		1	0.9			1.7			14.6		1
11/13/19 14:00	1			1.7			14.4		1	0.9			1.7			14.6		1
11/13/19 15:00	0.9			1.7			14.6		1	0.9			1.7			14.5		1
11/13/19 16:00	0.9			1.7			14.6		1	0.9			1.7			14.5		1
11/13/19 17:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/13/19 18:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/13/19 19:00	0.9			1.7			14.5		1	1			1.7			14.5		1
11/13/19 20:00	1.1			1.7			14.5		1	1.1			1.7			14.5		1
11/13/19 21:00	1			1.7			14.5		1	1			1.7			14.5		1
11/13/19 22:00	1.1			1.7			14.4		1	1.1			1.7			14.4		1
11/13/19 23:00	1			1.7			14.4		1	1			1.7			14.4		1
11/14/19 0:00	1			1.7			14.5		1	1			1.7			14.5		1
11/14/19 1:00	1.1			1.7			14.5		1	1			1.7			14.6		1
11/14/19 2:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 3:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/14/19 4:00	0.9			1.6			14.5		1	0.8			1.7			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 5:00	1.1			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 6:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 7:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/14/19 8:00	1			1.7			14.3		1	0.9			1.7			14.4		1
11/14/19 9:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/14/19 10:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/14/19 11:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/14/19 12:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/14/19 13:00	0.9			1.7			14.4		1	0.8			1.7			14.5		1
11/14/19 14:00	0.9			1.7			14.4		1	0.8			1.7			14.6		1
11/14/19 15:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/14/19 16:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/14/19 17:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 18:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 19:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 20:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
11/14/19 21:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/14/19 22:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/14/19 23:00	0.9			1.7			14.6		1	0.9			1.7			14.4		1
11/15/19 0:00	0	X		0	X		0	X	1	0.9			1.7			15.1		1
11/15/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/15/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/16/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/17/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 3:00	0	X		0	X		0	X	1	0			0			17.7		1
11/20/19 4:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
11/20/19 5:00	0	X		0	X		0	X	1	0.8			1.8			14.5		1
11/20/19 6:00	0	X		0	X		0	X	1	0.9			1.6			14.4		1
11/20/19 7:00	0	X		0	X		0	X	1	0.9			0.8			15.3		1
11/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/21/19 5:00	0			0			17.6		1	0	X		0	X		0	X	1
11/21/19 6:00	1.1			1.6			14.5		1	0			0			17.9		1
11/21/19 7:00	1			1.7			14.5		1	0.8			1.5			14.5		1
11/21/19 8:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/21/19 9:00	1.1			1.7			14.4		1	0.9			1.7			14.4		1
11/21/19 10:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/21/19 11:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/21/19 12:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/21/19 13:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/21/19 14:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/21/19 15:00	0.9			1.7			14.5		1	0.8			1.7			14.6		1
11/21/19 16:00	0.9			1.7			14.5		1	0.8			1.7			14.6		1
11/21/19 17:00	0.9			1.7			14.6		1	0.8			1.7			14.6		1
11/21/19 18:00	0.9			1.7			14.6		1	0.8			1.7			14.5		1
11/21/19 19:00	1.8			1.7			14.5		1	1.7			1.7			14.5		1
11/21/19 20:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/21/19 21:00	1			1.7			14.6		1	0.9			1.7			14.5		1
11/21/19 22:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/21/19 23:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/22/19 0:00	1			1.7			14.5		1	0.9			1.7			14.4		1
11/22/19 1:00	1.1			1.7			14.4		1	0.9			1.7			14.5		1
11/22/19 2:00	1.1			1.7			14.4		1	1			1.7			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/19 3:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/22/19 4:00	1.2			1.7			14.4		1	1			1.6			14.4		1
11/22/19 5:00	1.3			1.7			14.3		1	1.2			1.7			14.4		1
11/22/19 6:00	1.4			1.7			14.4		1	1.3			1.7			14.4		1
11/22/19 7:00	1.3			1.7			14.3		1	1.3			1.7			14.3		1
11/22/19 8:00	1.2			1.7			14.4		1	1.1			1.7			14.4		1
11/22/19 9:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/22/19 10:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/22/19 11:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/22/19 12:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/22/19 13:00	0.9			1.7			14.6		1	0.8			1.7			14.6		1
11/22/19 14:00	0.9			1.7			14.6		1	0.8			1.7			14.5		1
11/22/19 15:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/22/19 16:00	0.5			1.7			12.7		1	0.4			1.7			12.7		1
11/22/19 17:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
11/22/19 18:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
11/22/19 19:00	0.5			1.7			12.7		1	0.4			1.7			12.8		1
11/22/19 20:00	0.7			1.7			12.8		1	0.5			1.7			12.8		1
11/22/19 21:00	2.2			1.8			14.5		1	2.1			1.8			14.5		1
11/22/19 22:00	1.4			1.7			14.5		1	1.7			1.7			14.5		1
11/22/19 23:00	1.3			1.7			14.5		1	1.1			1.7			14.5		1
11/23/19 0:00	0	X		0	X		0	X	1	0.9			1.8			15.1		1
11/23/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/23/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/24/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/25/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/19 3:00	0	X		0	X		0	X	1	0			0			18.2		1
11/26/19 4:00	0	X		0	X		0	X	1	0.9			1.3			14.3		1
11/26/19 5:00	0	X		0	X		0	X	1	0.9			1.8			14.5		1
11/26/19 6:00	1.2			1.8			15.4		1	1			1.7			14.4		1
11/26/19 7:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/26/19 8:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/26/19 9:00	1.4			1.7			14.5		1	1.1			1.7			14.5		1
11/26/19 10:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/26/19 11:00	1			1.7			14.5		1	0.9			1.7			14.6		1
11/26/19 12:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/26/19 13:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/26/19 14:00	0.9			1.7			14.6		1	0.8			1.7			14.5		1
11/26/19 15:00	1.7			1.7			14.2		1	0.8			1.7			14.5		1
11/26/19 16:00	1.7			1.7			14.2		1	1.5			1.7			14.2		1
11/26/19 17:00	0.3			1.6			12.3		1	0.3			1.7			12.4		1
11/26/19 18:00	0.4			1.7			12.6		1	0.4			1.7			12.6		1
11/26/19 19:00	1			1.8			14.4		1	0.8			1.8			14.4		1
11/26/19 20:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 21:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/26/19 22:00	1			1.7			14.4		1	0.9			1.7			14.3		1
11/26/19 23:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/27/19 0:00	1.1			1.7			14.3		1	0.9			1.7			14.4		1
11/27/19 1:00	0.9			1.7			14.4		1	0.8			1.7			14.5		1
11/27/19 2:00	1			1.7			14.4		1	0.8			1.7			14.5		1
11/27/19 3:00	0.9			1.7			14.4		1	0.8			1.7			14.5		1
11/27/19 4:00	1			1.7			14.4		1	0.8			1.7			14.4		1
11/27/19 5:00	1.1			1.7			14.3		1	1			1.6			14.3		1
11/27/19 6:00	1			1.7			14.5		1	0.8			1.7			14.5		1
11/27/19 7:00	1			1.7			14.3		1	0.9			1.7			14.4		1
11/27/19 8:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/27/19 9:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/27/19 10:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/27/19 11:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/27/19 12:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/27/19 13:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/27/19 14:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/27/19 15:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/27/19 16:00	1			1.7			14.5		1	1.1			1.7			14.5		1
11/27/19 17:00	0.6			1.7			13		1	0.5			1.7			13		1
11/27/19 18:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/27/19 19:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/27/19 20:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/27/19 21:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/27/19 22:00	1.1			1.7			14.3		1	0.9			1.7			14.4		1
11/27/19 23:00	1			1.7			14.4		1	1			1.7			14.3		1
11/28/19 0:00	1			1.7			14.4		1	1			1.7			14.3		1
11/28/19 1:00	0.9			1.7			14.4		1	0.9			1.8			14.4		1
11/28/19 2:00	1			1.7			14.4		1	0.8			1.7			14.5		1
11/28/19 3:00	1			1.7			14.4		1	0.8			1.7			14.5		1
11/28/19 4:00	1.2			1.7			14.4		1	1.1			1.8			14.4		1
11/28/19 5:00	1.2			1.7			14.3		1	1.1			1.7			14.3		1
11/28/19 6:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/28/19 7:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/28/19 8:00	1			1.7			14.4		1	0.9			1.7			14.3		1
11/28/19 9:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/28/19 10:00	1			1.7			14.4		1	0.9			1.7			14.4		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/19 11:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/28/19 12:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/28/19 13:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/28/19 14:00	1.1			1.7			14.3		1	0.9			1.7			14.4		1
11/28/19 15:00	1.1			1.7			14.3		1	0.9			1.7			14.4		1
11/28/19 16:00	0.9			1.7			14.4		1	1			1.7			14.3		1
11/28/19 17:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/28/19 18:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/28/19 19:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
11/28/19 20:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/28/19 21:00	1			1.7			14.3		1	0.9			1.7			14.4		1
11/28/19 22:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/28/19 23:00	1			1.7			14.4		1	1			1.7			14.3		1
11/29/19 0:00	1.1			1.7			14.4		1	1.1			1.7			14.3		1
11/29/19 1:00	1			1.7			14.4		1	1.1			1.7			14.3		1
11/29/19 2:00	1			1.7			14.4		1	1.1			1.7			14.3		1
11/29/19 3:00	1			1.7			14.4		1	1.1			1.7			14.3		1
11/29/19 4:00	1			1.6			14.4		1	1.1			1.6			14.3		1
11/29/19 5:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
11/29/19 6:00	1.1			1.7			14.3		1	1			1.7			14.3		1
11/29/19 7:00	1.2			1.7			14.3		1	1			1.7			14.4		1
11/29/19 8:00	1.2			1.7			14.3		1	1			1.7			14.4		1
11/29/19 9:00	1.1			1.7			14.4		1	1			1.7			14.4		1
11/29/19 10:00	1			1.7			14.4		1	0.9			1.7			14.5		1
11/29/19 11:00	1.1			1.7			14.4		1	0.9			1.7			14.4		1
11/29/19 12:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/29/19 13:00	1.1			1.7			14.4		1	0.9			1.7			14.5		1
11/29/19 14:00	1.1			1.7			14.4		1	0.9			1.7			14.4		1
11/29/19 15:00	1.1			1.7			14.4		1	0.9			1.7			14.5		1
11/29/19 16:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/29/19 17:00	0.8			1.7			13.3		1	0.7			1.7			13.3		1
11/29/19 18:00	0.7			1.7			13.1		1	0.6			1.7			13.1		1
11/29/19 19:00	0.7			1.7			13.2		1	0.6			1.7			13.2		1
11/29/19 20:00	1			1.8			14.5		1	0.9			1.7			14.5		1
11/29/19 21:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/29/19 22:00	1.1			1.7			14.3		1	1			1.7			14.4		1
11/29/19 23:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
11/30/19 0:00	1			1.7			14.5		1	1			1.7			14.3		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/19 1:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 2:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
11/30/19 3:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 4:00	0.9			1.7			14.5		1	0.9			1.8			14.5		1
11/30/19 5:00	1			1.7			14.4		1	1			1.7			14.3		1
11/30/19 6:00	1			1.7			14.4		1	1.1			1.7			14.3		1
11/30/19 7:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
11/30/19 8:00	1			1.7			14.4		1	1			1.7			14.4		1
11/30/19 9:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 10:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 11:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 12:00	1			1.7			14.5		1	0.9			1.7			14.5		1
11/30/19 13:00	1			1.7			14.5		1	0.9			1.7			14.6		1
11/30/19 14:00	1			1.7			14.5		1	0.9			1.7			14.6		1
11/30/19 15:00	1			1.7			14.5		1	0.8			1.7			14.6		1
11/30/19 16:00	1			1.7			14.4		1	0.9			1.7			14.4		1
11/30/19 17:00	0.6			1.7			12.5		1	0.5			1.5			12.6		1
11/30/19 18:00	1.1			1.8			14.4		1	0.9			1.6			14.4		1
11/30/19 19:00	1			1.7			14.4		1	1			1.6			14.3		1
11/30/19 20:00	1			1.7			14.5		1	1			1.6			14.4		1
11/30/19 21:00	1			1.7			14.5		1	0.9			1.6			14.4		1
11/30/19 22:00	1			1.7			14.4		1	1			1.6			14.3		1
11/30/19 23:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 0:00	1.1			1.7			14.3		1	0.8			1.7			14.5		1
12/01/19 1:00	0.9			1.7			14.5		1	0.8			1.6			14.5		1
12/01/19 2:00	0.9			1.7			14.5		1	0.8			1.6			14.5		1
12/01/19 3:00	0.9			1.7			14.5		1	0.8			1.6			14.5		1
12/01/19 4:00	0.9			1.7			14.5		1	0.8			1.5			14.5		1
12/01/19 5:00	1			1.7			14.4		1	0.8			1.6			14.4		1
12/01/19 6:00	1			1.7			14.4		1	0.9			1.6			14.4		1
12/01/19 7:00	1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 8:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 9:00	1			1.7			14.3		1	1.1			1.6			14.3		1
12/01/19 10:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 11:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 12:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 13:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 14:00	1.1			1.7			14.3		1	1			1.6			14.3		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/19 15:00	1			1.7			14.4		1	0.9			1.6			14.5		1
12/01/19 16:00	1.1			1.7			14.3		1	1			1.6			14.3		1
12/01/19 17:00	0.7			1.7			13.1		1	0.7			1.6			13.1		1
12/01/19 18:00	0.4			1.7			12.5		1	0.4			1.7			12.5		1
12/01/19 19:00	1.5			1.8			14.2		1	1.6			1.8			14.3		1
12/01/19 20:00	1.5			1.7			14.3		1	1.8			1.7			14.3		1
12/01/19 21:00	1.1			1.7			14.4		1	0.9			1.7			14.5		1
12/01/19 22:00	1.1			1.7			14.3		1	1			1.7			14.3		1
12/01/19 23:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
12/02/19 0:00	1.1			1.7			14.3		1	1			1.7			14.3		1
12/02/19 1:00	1			1.8			14.5		1	0.8			1.7			14.5		1
12/02/19 2:00	1			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 3:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 4:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 5:00	1.1			1.7			14.3		1	1			1.7			14.3		1
12/02/19 6:00	1.6			1.7			14.3		1	1.8			1.7			14.4		1
12/02/19 7:00	1.1			1.7			14.5		1	1			1.7			14.4		1
12/02/19 8:00	1			1.7			14.4		1	0.9			1.7			14.4		1
12/02/19 9:00	1			1.7			14.5		1	0.9			1.7			14.5		1
12/02/19 10:00	1			1.7			14.5		1	0.9			1.7			14.5		1
12/02/19 11:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 12:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 13:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 14:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/02/19 15:00	0.7			1.7			14.6		1	1			1.7			14.5		1
12/02/19 16:00	0.4			1.7			13.1		1	0.6			1.7			13.1		1
12/02/19 17:00	0.3			1.7			13.1		1	0.5			1.7			13.1		1
12/02/19 18:00	0.3			1.7			13.1		1	0.5			1.7			13.1		1
12/02/19 19:00	0.4			1.7			13.2		1	0.6			1.7			13.2		1
12/02/19 20:00	0.3			1.7			13.1		1	0.5			1.7			13.1		1
12/02/19 21:00	0.7			1.8			14.4		1	0.9			1.7			14.4		1
12/02/19 22:00	0.6			1.7			14.3		1	1			1.7			14.3		1
12/02/19 23:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/03/19 0:00	0.5			1.7			14.4		1	0.8			1.7			14.4		1
12/03/19 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/03/19 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/03/19 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/03/19 4:00	0.6			1.7			14.5		1	0.8			1.6			14.5		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/19 5:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
12/03/19 6:00	0.7			1.7			14.3		1	1			1.7			14.3		1
12/03/19 7:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/03/19 8:00	0.6			1.7			14.4		1	1			1.7			14.4		1
12/03/19 9:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/03/19 10:00	0.6			1.7			14.4		1	0.9			1.7			14.5		1
12/03/19 11:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
12/03/19 12:00	0.6			1.7			14.4		1	0.9			1.7			14.5		1
12/03/19 13:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
12/03/19 14:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/03/19 15:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/03/19 16:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/03/19 17:00	1			1.7			14		1	1.3			1.7			14		1
12/03/19 18:00	1.2			1.7			14.2		1	1.4			1.7			14.1		1
12/03/19 19:00	0.8			1.7			14.3		1	1.1			1.7			14.3		1
12/03/19 20:00	1			1.7			14		1	1.3			1.7			14		1
12/03/19 21:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
12/03/19 22:00	0.9			1.7			14.5		1	1.2			1.7			14.4		1
12/03/19 23:00	0.6			1.7			14.4		1	1			1.7			14.3		1
12/04/19 0:00	0.7			1.7			14.3		1	1			1.7			14.3		1
12/04/19 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 4:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 5:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
12/04/19 6:00	0.6			1.7			14.5		1	1			1.7			14.5		1
12/04/19 7:00	0.8			1.7			13.6		1	1.2			1.6			13.6		1
12/04/19 8:00	0.5			1.7			13.1		1	0.7			1.7			13.2		1
12/04/19 9:00	0.5			1.7			13.2		1	0.7			1.7			13.2		1
12/04/19 10:00	0.7			1.8			14.4		1	1			1.8			14.4		1
12/04/19 11:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 12:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 13:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 14:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
12/04/19 15:00	0.6			1.7			14.5		1	0.9			1.7			14.5		1
12/04/19 16:00	0.4			1.6			13.1		1	0.6			1.6			13.1		1
12/04/19 17:00	0.3			1.7			12.9		1	0.4			1.7			13		1
12/04/19 18:00	0.3			1.7			13		1	0.5			1.7			13		1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 19:00	0.3			1.7			13		1	0.5			1.7			13		1
12/04/19 20:00	0.4			1.7			13		1	0.6			1.7			13		1
12/04/19 21:00	0.9			1.7			13.8		1	1.1			1.7			13.8		1
12/04/19 22:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
12/04/19 23:00	0.6			1.7			14.3		1	0.8			1.7			14.4		1
12/05/19 0:00	0			0			16		1	0			0			16		1
12/05/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/19 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/19 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:32 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2019	0.3310	3.6667	0.3916	8.6208	0.0696	1.5963	0.0349	0.7982	0.1162	2.6610
Nov 2019	0.5504	3.5681	1.0151	8.9063	0.1824	1.6530	0.0911	0.8264	0.3043	2.7560
Dec 2019	0.0850	3.2072	0.2419	7.8108	0.0460	1.4448	0.0230	0.7223	0.0767	2.4089
Sum/Avg	3.2072		7.8108		1.4448		0.7223		2.4089	
Limit Value										

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/19 0:00	0			0														
10/02/19 0:00	0			0														
10/03/19 0:00	0			0														
10/04/19 0:00	0			0														
10/05/19 0:00	0			0														
10/06/19 0:00	0			0														
10/07/19 0:00	0			0														
10/08/19 0:00	0			0														
10/09/19 0:00	0			0														
10/10/19 0:00	0			0														
10/11/19 0:00	0			0														
10/12/19 0:00	0			0														
10/13/19 0:00	0			0														
10/14/19 0:00	0			0														
10/15/19 0:00	0			0														
10/16/19 0:00	0			0														
10/17/19 0:00	0			0														
10/18/19 0:00	0			0														
10/19/19 0:00	0			0														
10/20/19 0:00	0			0														
10/21/19 0:00	0			4.9														
10/22/19 0:00	0			5.8														
10/23/19 0:00	0			6.1														
10/24/19 0:00	2.6			4.2														
10/25/19 0:00	5.5			1														
10/26/19 0:00	4.8			0														
10/27/19 0:00	4.8			0														
10/28/19 0:00	5.8			0														
10/29/19 0:00	7.8			0														
10/30/19 0:00	6.6			0.9														
10/31/19 0:00	7.7			0														
11/01/19 0:00	7.1			0														
11/02/19 0:00	6.1			0														
11/03/19 0:00	5.7			0														
11/04/19 0:00	6.6			0														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/19 0:00	6.1			2.4														
11/06/19 0:00	6			5.9														
11/07/19 0:00	7.2			2.2														
11/08/19 0:00	6.6			3.3														
11/09/19 0:00	5.5			0														
11/10/19 0:00	5.4			0														
11/11/19 0:00	5.7			0.1														
11/12/19 0:00	0.1			5.5														
11/13/19 0:00	4			6.1														
11/14/19 0:00	5.4			5.7														
11/15/19 0:00	0			0														
11/16/19 0:00	0			0														
11/17/19 0:00	0			0														
11/18/19 0:00	0			0														
11/19/19 0:00	0			0														
11/20/19 0:00	0			0.6														
11/21/19 0:00	4.6			4														
11/22/19 0:00	6.2			5.7														
11/23/19 0:00	0			0														
11/24/19 0:00	0			0														
11/25/19 0:00	0			0														
11/26/19 0:00	5.1			4.8														
11/27/19 0:00	5.3			5.6														
11/28/19 0:00	4.9			4.8														
11/29/19 0:00	5.2			5.1														
11/30/19 0:00	5.3			5.1														
12/01/19 0:00	5.4			5.3														
12/02/19 0:00	6.3			6														
12/03/19 0:00	5.7			5.3														
12/04/19 0:00	6.6			6														
12/05/19 0:00	0			0														
12/06/19 0:00	0			0														
12/07/19 0:00	0			0														
12/08/19 0:00	0			0														
12/09/19 0:00	0			0														
12/10/19 0:00	0			0														
12/11/19 0:00	0			0														
12/12/19 0:00	0			0														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/13/19 0:00	0			0														
12/14/19 0:00	0			0														
12/15/19 0:00	0			0														
12/16/19 0:00	0			0														
12/17/19 0:00	0			0														
12/18/19 0:00	0			0														
12/19/19 0:00	0			0														
12/20/19 0:00	0			0														
12/21/19 0:00	0			0														
12/22/19 0:00	0			0														
12/23/19 0:00	0			0														
12/24/19 0:00	0			0														
12/25/19 0:00	0			0														
12/26/19 0:00	0			0														
12/27/19 0:00	0			0														
12/28/19 0:00	0			0														
12/29/19 0:00	0			0														
12/30/19 0:00	0			0														
12/31/19 0:00	0			0														

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/01/19 0:00	0	X		0	X		0											
10/01/19 1:00	0	X		0	X		0											
10/01/19 2:00	0	X		0	X		0											
10/01/19 3:00	0	X		0	X		0											
10/01/19 4:00	0	X		0	X		0											
10/01/19 5:00	0	X		0	X		0											
10/01/19 6:00	0	X		0	X		0											
10/01/19 7:00	0	X		0	X		0											
10/01/19 8:00	0	X		0	X		0											
10/01/19 9:00	0	X		0	X		0											
10/01/19 10:00	0	X		0	X		0											
10/01/19 11:00	0	X		0	X		0											
10/01/19 12:00	0	X		0	X		0											
10/01/19 13:00	0	X		0	X		0											
10/01/19 14:00	0	X		0	X		0											
10/01/19 15:00	0	X		0	X		0											
10/01/19 16:00	0	X		0	X		0											
10/01/19 17:00	0	X		0	X		0											
10/01/19 18:00	0	X		0	X		0											
10/01/19 19:00	0	X		0	X		0											
10/01/19 20:00	0	X		0	X		0											
10/01/19 21:00	0	X		0	X		0											
10/01/19 22:00	0	X		0	X		0											
10/01/19 23:00	0	X		0	X		0											
10/02/19 0:00	0	X		0	X		0											
10/02/19 1:00	0	X		0	X		0											
10/02/19 2:00	0	X		0	X		0											
10/02/19 3:00	0	X		0	X		0											
10/02/19 4:00	0	X		0	X		0											
10/02/19 5:00	0	X		0	X		0											
10/02/19 6:00	0	X		0	X		0											
10/02/19 7:00	0	X		0	X		0											
10/02/19 8:00	0	X		0	X		0											
10/02/19 9:00	0	X		0	X		0											
10/02/19 10:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/02/19 11:00	0	X		0	X		0											
10/02/19 12:00	0	X		0	X		0											
10/02/19 13:00	0	X		0	X		0											
10/02/19 14:00	0	X		0	X		0											
10/02/19 15:00	0	X		0	X		0											
10/02/19 16:00	0	X		0	X		0											
10/02/19 17:00	0	X		0	X		0											
10/02/19 18:00	0	X		0	X		0											
10/02/19 19:00	0	X		0	X		0											
10/02/19 20:00	0	X		0	X		0											
10/02/19 21:00	0	X		0	X		0											
10/02/19 22:00	0	X		0	X		0											
10/02/19 23:00	0	X		0	X		0											
10/03/19 0:00	0	X		0	X		0											
10/03/19 1:00	0	X		0	X		0											
10/03/19 2:00	0	X		0	X		0											
10/03/19 3:00	0	X		0	X		0											
10/03/19 4:00	0	X		0	X		0											
10/03/19 5:00	0	X		0	X		0											
10/03/19 6:00	0	X		0	X		0											
10/03/19 7:00	0	X		0	X		0											
10/03/19 8:00	0	X		0	X		0											
10/03/19 9:00	0	X		0	X		0											
10/03/19 10:00	0	X		0	X		0											
10/03/19 11:00	0	X		0	X		0											
10/03/19 12:00	0	X		0	X		0											
10/03/19 13:00	0	X		0	X		0											
10/03/19 14:00	0	X		0	X		0											
10/03/19 15:00	0	X		0	X		0											
10/03/19 16:00	0	X		0	X		0											
10/03/19 17:00	0	X		0	X		0											
10/03/19 18:00	0	X		0	X		0											
10/03/19 19:00	0	X		0	X		0											
10/03/19 20:00	0	X		0	X		0											
10/03/19 21:00	0	X		0	X		0											
10/03/19 22:00	0	X		0	X		0											
10/03/19 23:00	0	X		0	X		0											
10/04/19 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/04/19 1:00	0	X		0	X		0											
10/04/19 2:00	0	X		0	X		0											
10/04/19 3:00	0	X		0	X		0											
10/04/19 4:00	0	X		0	X		0											
10/04/19 5:00	0	X		0	X		0											
10/04/19 6:00	0	X		0	X		0											
10/04/19 7:00	0	X		0	X		0											
10/04/19 8:00	0	X		0	X		0											
10/04/19 9:00	0	X		0	X		0											
10/04/19 10:00	0	X		0	X		0											
10/04/19 11:00	0	X		0	X		0											
10/04/19 12:00	0	X		0	X		0											
10/04/19 13:00	0	X		0	X		0											
10/04/19 14:00	0	X		0	X		0											
10/04/19 15:00	0	X		0	X		0											
10/04/19 16:00	0	X		0	X		0											
10/04/19 17:00	0	X		0	X		0											
10/04/19 18:00	0	X		0	X		0											
10/04/19 19:00	0	X		0	X		0											
10/04/19 20:00	0	X		0	X		0											
10/04/19 21:00	0	X		0	X		0											
10/04/19 22:00	0	X		0	X		0											
10/04/19 23:00	0	X		0	X		0											
10/05/19 0:00	0	X		0	X		0											
10/05/19 1:00	0	X		0	X		0											
10/05/19 2:00	0	X		0	X		0											
10/05/19 3:00	0	X		0	X		0											
10/05/19 4:00	0	X		0	X		0											
10/05/19 5:00	0	X		0	X		0											
10/05/19 6:00	0	X		0	X		0											
10/05/19 7:00	0	X		0	X		0											
10/05/19 8:00	0	X		0	X		0											
10/05/19 9:00	0	X		0	X		0											
10/05/19 10:00	0	X		0	X		0											
10/05/19 11:00	0	X		0	X		0											
10/05/19 12:00	0	X		0	X		0											
10/05/19 13:00	0	X		0	X		0											
10/05/19 14:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/05/19 15:00	0	X		0	X		0											
10/05/19 16:00	0	X		0	X		0											
10/05/19 17:00	0	X		0	X		0											
10/05/19 18:00	0	X		0	X		0											
10/05/19 19:00	0	X		0	X		0											
10/05/19 20:00	0	X		0	X		0											
10/05/19 21:00	0	X		0	X		0											
10/05/19 22:00	0	X		0	X		0											
10/05/19 23:00	0	X		0	X		0											
10/06/19 0:00	0	X		0	X		0											
10/06/19 1:00	0	X		0	X		0											
10/06/19 2:00	0	X		0	X		0											
10/06/19 3:00	0	X		0	X		0											
10/06/19 4:00	0	X		0	X		0											
10/06/19 5:00	0	X		0	X		0											
10/06/19 6:00	0	X		0	X		0											
10/06/19 7:00	0	X		0	X		0											
10/06/19 8:00	0	X		0	X		0											
10/06/19 9:00	0	X		0	X		0											
10/06/19 10:00	0	X		0	X		0											
10/06/19 11:00	0	X		0	X		0											
10/06/19 12:00	0	X		0	X		0											
10/06/19 13:00	0	X		0	X		0											
10/06/19 14:00	0	X		0	X		0											
10/06/19 15:00	0	X		0	X		0											
10/06/19 16:00	0	X		0	X		0											
10/06/19 17:00	0	X		0	X		0											
10/06/19 18:00	0	X		0	X		0											
10/06/19 19:00	0	X		0	X		0											
10/06/19 20:00	0	X		0	X		0											
10/06/19 21:00	0	X		0	X		0											
10/06/19 22:00	0	X		0	X		0											
10/06/19 23:00	0	X		0	X		0											
10/07/19 0:00	0	X		0	X		0											
10/07/19 1:00	0	X		0	X		0											
10/07/19 2:00	0	X		0	X		0											
10/07/19 3:00	0	X		0	X		0											
10/07/19 4:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/07/19 5:00	0	X		0	X		0											
10/07/19 6:00	0	X		0	X		0											
10/07/19 7:00	0	X		0	X		0											
10/07/19 8:00	0	X		0	X		0											
10/07/19 9:00	0	X		0	X		0											
10/07/19 10:00	0	X		0	X		0											
10/07/19 11:00	0	X		0	X		0											
10/07/19 12:00	0	X		0	X		0											
10/07/19 13:00	0	X		0	X		0											
10/07/19 14:00	0	X		0	X		0											
10/07/19 15:00	0	X		0	X		0											
10/07/19 16:00	0	X		0	X		0											
10/07/19 17:00	0	X		0	X		0											
10/07/19 18:00	0	X		0	X		0											
10/07/19 19:00	0	X		0	X		0											
10/07/19 20:00	0	X		0	X		0											
10/07/19 21:00	0	X		0	X		0											
10/07/19 22:00	0	X		0	X		0											
10/07/19 23:00	0	X		0	X		0											
10/08/19 0:00	0	X		0	X		0											
10/08/19 1:00	0	X		0	X		0											
10/08/19 2:00	0	X		0	X		0											
10/08/19 3:00	0	X		0	X		0											
10/08/19 4:00	0	X		0	X		0											
10/08/19 5:00	0	X		0	X		0											
10/08/19 6:00	0	X		0	X		0											
10/08/19 7:00	0	X		0	X		0											
10/08/19 8:00	0	X		0	X		0											
10/08/19 9:00	0	X		0	X		0											
10/08/19 10:00	0	X		0	X		0											
10/08/19 11:00	0	X		0	X		0											
10/08/19 12:00	0	X		0	X		0											
10/08/19 13:00	0	X		0	X		0											
10/08/19 14:00	0	X		0	X		0											
10/08/19 15:00	0	X		0	X		0											
10/08/19 16:00	0	X		0	X		0											
10/08/19 17:00	0	X		0	X		0											
10/08/19 18:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/08/19 19:00	0	X		0	X		0											
10/08/19 20:00	0	X		0	X		0											
10/08/19 21:00	0	X		0	X		0											
10/08/19 22:00	0	X		0	X		0											
10/08/19 23:00	0	X		0	X		0											
10/09/19 0:00	0	X		0	X		0											
10/09/19 1:00	0	X		0	X		0											
10/09/19 2:00	0	X		0	X		0											
10/09/19 3:00	0	X		0	X		0											
10/09/19 4:00	0	X		0	X		0											
10/09/19 5:00	0	X		0	X		0											
10/09/19 6:00	0	X		0	X		0											
10/09/19 7:00	0	X		0	X		0											
10/09/19 8:00	0	X		0	X		0											
10/09/19 9:00	0	X		0	X		0											
10/09/19 10:00	0	X		0	X		0											
10/09/19 11:00	0	X		0	X		0											
10/09/19 12:00	0	X		0	X		0											
10/09/19 13:00	0	X		0	X		0											
10/09/19 14:00	0	X		0	X		0											
10/09/19 15:00	0	X		0	X		0											
10/09/19 16:00	0	X		0	X		0											
10/09/19 17:00	0	X		0	X		0											
10/09/19 18:00	0	X		0	X		0											
10/09/19 19:00	0	X		0	X		0											
10/09/19 20:00	0	X		0	X		0											
10/09/19 21:00	0	X		0	X		0											
10/09/19 22:00	0	X		0	X		0											
10/09/19 23:00	0	X		0	X		0											
10/10/19 0:00	0	X		0	X		0											
10/10/19 1:00	0	X		0	X		0											
10/10/19 2:00	0	X		0	X		0											
10/10/19 3:00	0	X		0	X		0											
10/10/19 4:00	0	X		0	X		0											
10/10/19 5:00	0	X		0	X		0											
10/10/19 6:00	0	X		0	X		0											
10/10/19 7:00	0	X		0	X		0											
10/10/19 8:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/10/19 9:00	0	X		0	X		0											
10/10/19 10:00	0	X		0	X		0											
10/10/19 11:00	0	X		0	X		0											
10/10/19 12:00	0	X		0	X		0											
10/10/19 13:00	0	X		0	X		0											
10/10/19 14:00	0	X		0	X		0											
10/10/19 15:00	0	X		0	X		0											
10/10/19 16:00	0	X		0	X		0											
10/10/19 17:00	0	X		0	X		0											
10/10/19 18:00	0	X		0	X		0											
10/10/19 19:00	0	X		0	X		0											
10/10/19 20:00	0	X		0	X		0											
10/10/19 21:00	0	X		0	X		0											
10/10/19 22:00	0	X		0	X		0											
10/11/19 0:00	0	X		0	X		0											
10/11/19 1:00	0	X		0	X		0											
10/11/19 2:00	0	X		0	X		0											
10/11/19 3:00	0	X		0	X		0											
10/11/19 4:00	0	X		0	X		0											
10/11/19 5:00	0	X		0	X		0											
10/11/19 6:00	0	X		0	X		0											
10/11/19 7:00	0	X		0	X		0											
10/11/19 8:00	0	X		0	X		0											
10/11/19 9:00	0	X		0	X		0											
10/11/19 10:00	0	X		0	X		0											
10/11/19 11:00	0	X		0	X		0											
10/11/19 12:00	0	X		0	X		0											
10/11/19 13:00	0	X		0	X		0											
10/11/19 14:00	0	X		0	X		0											
10/11/19 15:00	0	X		0	X		0											
10/11/19 16:00	0	X		0	X		0											
10/11/19 17:00	0	X		0	X		0											
10/11/19 18:00	0	X		0	X		0											
10/11/19 19:00	0	X		0	X		0											
10/11/19 20:00	0	X		0	X		0											
10/11/19 21:00	0	X		0	X		0											
10/11/19 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/11/19 23:00	0	X		0	X		0											
10/12/19 0:00	0	X		0	X		0											
10/12/19 1:00	0	X		0	X		0											
10/12/19 2:00	0	X		0	X		0											
10/12/19 3:00	0	X		0	X		0											
10/12/19 4:00	0	X		0	X		0											
10/12/19 5:00	0	X		0	X		0											
10/12/19 6:00	0	X		0	X		0											
10/12/19 7:00	0	X		0	X		0											
10/12/19 8:00	0	X		0	X		0											
10/12/19 9:00	0	X		0	X		0											
10/12/19 10:00	0	X		0	X		0											
10/12/19 11:00	0	X		0	X		0											
10/12/19 12:00	0	X		0	X		0											
10/12/19 13:00	0	X		0	X		0											
10/12/19 14:00	0	X		0	X		0											
10/12/19 15:00	0	X		0	X		0											
10/12/19 16:00	0	X		0	X		0											
10/12/19 17:00	0	X		0	X		0											
10/12/19 18:00	0	X		0	X		0											
10/12/19 19:00	0	X		0	X		0											
10/12/19 20:00	0	X		0	X		0											
10/12/19 21:00	0	X		0	X		0											
10/12/19 22:00	0	X		0	X		0											
10/12/19 23:00	0	X		0	X		0											
10/13/19 0:00	0	X		0	X		0											
10/13/19 1:00	0	X		0	X		0											
10/13/19 2:00	0	X		0	X		0											
10/13/19 3:00	0	X		0	X		0											
10/13/19 4:00	0	X		0	X		0											
10/13/19 5:00	0	X		0	X		0											
10/13/19 6:00	0	X		0	X		0											
10/13/19 7:00	0	X		0	X		0											
10/13/19 8:00	0	X		0	X		0											
10/13/19 9:00	0	X		0	X		0											
10/13/19 10:00	0	X		0	X		0											
10/13/19 11:00	0	X		0	X		0											
10/13/19 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/13/19 13:00	0	X		0	X		0											
10/13/19 14:00	0	X		0	X		0											
10/13/19 15:00	0	X		0	X		0											
10/13/19 16:00	0	X		0	X		0											
10/13/19 17:00	0	X		0	X		0											
10/13/19 18:00	0	X		0	X		0											
10/13/19 19:00	0	X		0	X		0											
10/13/19 20:00	0	X		0	X		0											
10/13/19 21:00	0	X		0	X		0											
10/13/19 22:00	0	X		0	X		0											
10/13/19 23:00	0	X		0	X		0											
10/14/19 0:00	0	X		0	X		0											
10/14/19 1:00	0	X		0	X		0											
10/14/19 2:00	0	X		0	X		0											
10/14/19 3:00	0	X		0	X		0											
10/14/19 4:00	0	X		0	X		0											
10/14/19 5:00	0	X		0	X		0											
10/14/19 6:00	0	X		0	X		0											
10/14/19 7:00	0	X		0	X		0											
10/14/19 8:00	0	X		0	X		0											
10/14/19 9:00	0	X		0	X		0											
10/14/19 10:00	0	X		0	X		0											
10/14/19 11:00	0	X		0	X		0											
10/14/19 12:00	0	X		0	X		0											
10/14/19 13:00	0	X		0	X		0											
10/14/19 14:00	0	X		0	X		0											
10/14/19 15:00	0	X		0	X		0											
10/14/19 16:00	0	X		0	X		0											
10/14/19 17:00	0	X		0	X		0											
10/14/19 18:00	0	X		0	X		0											
10/14/19 19:00	0	X		0	X		0											
10/14/19 20:00	0	X		0	X		0											
10/14/19 21:00	0	X		0	X		0											
10/14/19 22:00	0	X		0	X		0											
10/14/19 23:00	0	X		0	X		0											
10/15/19 0:00	0	X		0	X		0											
10/15/19 1:00	0	X		0	X		0											
10/15/19 2:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/15/19 3:00	0	X		0	X		0											
10/15/19 4:00	0	X		0	X		0											
10/15/19 5:00	0	X		0	X		0											
10/15/19 6:00	0	X		0	X		0											
10/15/19 7:00	0	X		0	X		0											
10/15/19 8:00	0	X		0	X		0											
10/15/19 9:00	0	X		0	X		0											
10/15/19 10:00	0	X		0	X		0											
10/15/19 11:00	0	X		0	X		0											
10/15/19 12:00	0	X		0	X		0											
10/15/19 13:00	0	X		0	X		0											
10/15/19 14:00	0	X		0	X		0											
10/15/19 15:00	0	X		0	X		0											
10/15/19 16:00	0	X		0	X		0											
10/15/19 17:00	0	X		0	X		0											
10/15/19 18:00	0	X		0	X		0											
10/15/19 19:00	0	X		0	X		0											
10/15/19 20:00	0	X		0	X		0											
10/15/19 21:00	0	X		0	X		0											
10/15/19 22:00	0	X		0	X		0											
10/15/19 23:00	0	X		0	X		0											
10/16/19 0:00	0	X		0	X		0											
10/16/19 1:00	0	X		0	X		0											
10/16/19 2:00	0	X		0	X		0											
10/16/19 3:00	0	X		0	X		0											
10/16/19 4:00	0	X		0	X		0											
10/16/19 5:00	0	X		0	X		0											
10/16/19 6:00	0	X		0	X		0											
10/16/19 7:00	0	X		0	X		0											
10/16/19 8:00	0	X		0	X		0											
10/16/19 9:00	0	X		0	X		0											
10/16/19 10:00	0	X		0	X		0											
10/16/19 11:00	0	X		0	X		0											
10/16/19 12:00	0	X		0	X		0											
10/16/19 13:00	0	X		0	X		0											
10/16/19 14:00	0	X		0	X		0											
10/16/19 15:00	0	X		0	X		0											
10/16/19 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/16/19 17:00	0	X		0	X		0											
10/16/19 18:00	0	X		0	X		0											
10/16/19 19:00	0	X		0	X		0											
10/16/19 20:00	0	X		0	X		0											
10/16/19 21:00	0	X		0	X		0											
10/16/19 22:00	0	X		0	X		0											
10/16/19 23:00	0	X		0	X		0											
10/17/19 0:00	0	X		0	X		0											
10/17/19 1:00	0	X		0	X		0											
10/17/19 2:00	0	X		0	X		0											
10/17/19 3:00	0	X		0	X		0											
10/17/19 4:00	0	X		0	X		0											
10/17/19 5:00	0	X		0	X		0											
10/17/19 6:00	0	X		0	X		0											
10/17/19 7:00	0	X		0	X		0											
10/17/19 8:00	0	X		0	X		0											
10/17/19 9:00	0	X		0	X		0											
10/17/19 10:00	0	X		0	X		0											
10/17/19 11:00	0	X		0	X		0											
10/17/19 12:00	0	X		0	X		0											
10/17/19 13:00	0	X		0	X		0											
10/17/19 14:00	0	X		0	X		0											
10/17/19 15:00	0	X		0	X		0											
10/17/19 16:00	0	X		0	X		0											
10/17/19 17:00	0	X		0	X		0											
10/17/19 18:00	0	X		0	X		0											
10/17/19 19:00	0	X		0	X		0											
10/17/19 20:00	0	X		0	X		0											
10/17/19 21:00	0	X		0	X		0											
10/17/19 22:00	0	X		0	X		0											
10/17/19 23:00	0	X		0	X		0											
10/18/19 0:00	0	X		0	X		0											
10/18/19 1:00	0	X		0	X		0											
10/18/19 2:00	0	X		0	X		0											
10/18/19 3:00	0	X		0	X		0											
10/18/19 4:00	0	X		0	X		0											
10/18/19 5:00	0	X		0	X		0											
10/18/19 6:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/18/19 7:00	0	X		0	X		0											
10/18/19 8:00	0	X		0	X		0											
10/18/19 9:00	0	X		0	X		0											
10/18/19 10:00	0	X		0	X		0											
10/18/19 11:00	0	X		0	X		0											
10/18/19 12:00	0	X		0	X		0											
10/18/19 13:00	0	X		0	X		0											
10/18/19 14:00	0	X		0	X		0											
10/18/19 15:00	0	X		0	X		0											
10/18/19 16:00	0	X		0	X		0											
10/18/19 17:00	0	X		0	X		0											
10/18/19 18:00	0	X		0	X		0											
10/18/19 19:00	0	X		0	X		0											
10/18/19 20:00	0	X		0	X		0											
10/18/19 21:00	0	X		0	X		0											
10/18/19 22:00	0	X		0	X		0											
10/18/19 23:00	0	X		0	X		0											
10/19/19 0:00	0	X		0	X		0											
10/19/19 1:00	0	X		0	X		0											
10/19/19 2:00	0	X		0	X		0											
10/19/19 3:00	0	X		0	X		0											
10/19/19 4:00	0	X		0	X		0											
10/19/19 5:00	0	X		0	X		0											
10/19/19 6:00	0	X		0	X		0											
10/19/19 7:00	0	X		0	X		0											
10/19/19 8:00	0	X		0	X		0											
10/19/19 9:00	0	X		0	X		0											
10/19/19 10:00	0	X		0	X		0											
10/19/19 11:00	0	X		0	X		0											
10/19/19 12:00	0	X		0	X		0											
10/19/19 13:00	0	X		0	X		0											
10/19/19 14:00	0	X		0	X		0											
10/19/19 15:00	0	X		0	X		0											
10/19/19 16:00	0	X		0	X		0											
10/19/19 17:00	0	X		0	X		0											
10/19/19 18:00	0	X		0	X		0											
10/19/19 19:00	0	X		0	X		0											
10/19/19 20:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/19/19 21:00	0	X		0	X		0											
10/19/19 22:00	0	X		0	X		0											
10/19/19 23:00	0	X		0	X		0											
10/20/19 0:00	0	X		0	X		0											
10/20/19 1:00	0	X		0	X		0											
10/20/19 2:00	0	X		0	X		0											
10/20/19 3:00	0	X		0	X		0											
10/20/19 4:00	0	X		0	X		0											
10/20/19 5:00	0	X		0	X		0											
10/20/19 6:00	0	X		0	X		0											
10/20/19 7:00	0	X		0	X		0											
10/20/19 8:00	0	X		0	X		0											
10/20/19 9:00	0	X		0	X		0											
10/20/19 10:00	0	X		0	X		0											
10/20/19 11:00	0	X		0	X		0											
10/20/19 12:00	0	X		0	X		0											
10/20/19 13:00	0	X		0	X		0											
10/20/19 14:00	0	X		0	X		0											
10/20/19 15:00	0	X		0	X		0											
10/20/19 16:00	0	X		0	X		0											
10/20/19 17:00	0	X		0	X		0											
10/20/19 18:00	0	X		0	X		0											
10/20/19 19:00	0	X		0	X		0											
10/20/19 20:00	0	X		0	X		0											
10/20/19 21:00	0	X		0	X		0											
10/20/19 22:00	0	X		0	X		0											
10/20/19 23:00	0	X		0	X		0											
10/21/19 0:00	0	X		0	X		0											
10/21/19 1:00	0	X		0	X		0											
10/21/19 2:00	0	X		0	X		0											
10/21/19 3:00	0	X		0	X		0											
10/21/19 4:00	0	X		0	X		0											
10/21/19 5:00	0	X		0.09276			0.03											
10/21/19 6:00	0	X		0.25164			0.25											
10/21/19 7:00	0	X		0.25338			0.25											
10/21/19 8:00	0	X		0.24444			0.24											
10/21/19 9:00	0	X		0.32856			0.33											
10/21/19 10:00	0	X		0.27054			0.27											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/21/19 11:00	0	X		0.3021			0.3											
10/21/19 12:00	0	X		0.33042			0.33											
10/21/19 13:00	0	X		0.32994			0.33											
10/21/19 14:00	0	X		0.327			0.33											
10/21/19 15:00	0	X		0.29946			0.3											
10/21/19 16:00	0	X		0.31002			0.31											
10/21/19 17:00	0	X		0.35784			0.36											
10/21/19 18:00	0	X		0.31512			0.32											
10/21/19 19:00	0	X		0.24894			0.25											
10/21/19 20:00	0	X		0.23952			0.24											
10/21/19 21:00	0	X		0.2277			0.23											
10/21/19 22:00	0	X		0.18924			0.19											
10/21/19 23:00	0	X		0.183			0.18											
10/22/19 0:00	0	X		0.18264			0.18											
10/22/19 1:00	0	X		0.17958			0.18											
10/22/19 2:00	0	X		0.17934			0.18											
10/22/19 3:00	0	X		0.17976			0.18											
10/22/19 4:00	0	X		0.18708			0.19											
10/22/19 5:00	0	X		0.20466			0.2											
10/22/19 6:00	0	X		0.20964			0.21											
10/22/19 7:00	0	X		0.22224			0.22											
10/22/19 8:00	0	X		0.31458			0.31											
10/22/19 9:00	0	X		0.18768			0.19											
10/22/19 10:00	0	X		0.315			0.32											
10/22/19 11:00	0	X		0.32634			0.33											
10/22/19 12:00	0	X		0.23838			0.24											
10/22/19 13:00	0	X		0.3066			0.31											
10/22/19 14:00	0	X		0.32844			0.33											
10/22/19 15:00	0	X		0.29394			0.29											
10/22/19 16:00	0	X		0.28386			0.28											
10/22/19 17:00	0	X		0.3075			0.31											
10/22/19 18:00	0	X		0.29628			0.3											
10/22/19 19:00	0	X		0.2874			0.29											
10/22/19 20:00	0	X		0.23412			0.23											
10/22/19 21:00	0	X		0.231			0.23											
10/22/19 22:00	0	X		0.23088			0.23											
10/22/19 23:00	0	X		0.18828			0.19											
10/23/19 0:00	0	X		0.18258			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/23/19 1:00	0	X		0.17904			0.18											
10/23/19 2:00	0	X		0.17904			0.18											
10/23/19 3:00	0	X		0.17952			0.18											
10/23/19 4:00	0	X		0.1887			0.19											
10/23/19 5:00	0	X		0.19062			0.19											
10/23/19 6:00	0	X		0.21204			0.21											
10/23/19 7:00	0	X		0.28344			0.28											
10/23/19 8:00	0	X		0.3327			0.33											
10/23/19 9:00	0	X		0.3165			0.32											
10/23/19 10:00	0	X		0.32136			0.32											
10/23/19 11:00	0	X		0.3063			0.31											
10/23/19 12:00	0	X		0.2874			0.29											
10/23/19 13:00	0	X		0.2634			0.26											
10/23/19 14:00	0	X		0.25572			0.26											
10/23/19 15:00	0	X		0.2829			0.28											
10/23/19 16:00	0	X		0.27576			0.28											
10/23/19 17:00	0	X		0.3306			0.33											
10/23/19 18:00	0	X		0.28794			0.29											
10/23/19 19:00	0	X		0.24282			0.24											
10/23/19 20:00	0	X		0.23286			0.23											
10/23/19 21:00	0	X		0.26856			0.27											
10/23/19 22:00	0	X		0.21516			0.22											
10/23/19 23:00	0	X		0.19878			0.2											
10/24/19 0:00	0	X		0.18954			0.19											
10/24/19 1:00	0	X		0.18936			0.19											
10/24/19 2:00	0	X		0.19014			0.19											
10/24/19 3:00	0	X		0.19014			0.19											
10/24/19 4:00	0	X		0.21702			0.22											
10/24/19 5:00	0	X		0.29376			0.29											
10/24/19 6:00	0	X		0.30348			0.3											
10/24/19 7:00	0	X		0.25338			0.25											
10/24/19 8:00	0	X		0.22506			0.23											
10/24/19 9:00	0	X		0.19878			0.2											
10/24/19 10:00	0	X		0.19368			0.19											
10/24/19 11:00	0	X		0.19434			0.19											
10/24/19 12:00	0	X		0.19482			0.19											
10/24/19 13:00	0.09714			0.19482			0.22											
10/24/19 14:00	0.18714			0.17652			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/24/19 15:00	0.19356			0.18642			0.38											
10/24/19 16:00	0.24786			0.24198			0.49											
10/24/19 17:00	0.30138			0.28512			0.59											
10/24/19 18:00	0.26406			0.22896			0.49											
10/24/19 19:00	0.3486			0.08358			0.35											
10/24/19 20:00	0.28818			0	X		0.29											
10/24/19 21:00	0.29268			0	X		0.29											
10/24/19 22:00	0.32484			0	X		0.32											
10/24/19 23:00	0.22404			0	X		0.22											
10/25/19 0:00	0.2091			0	X		0.21											
10/25/19 1:00	0.20838			0	X		0.21											
10/25/19 2:00	0.2082			0	X		0.21											
10/25/19 3:00	0.20766			0	X		0.21											
10/25/19 4:00	0.20778			0	X		0.21											
10/25/19 5:00	0.2079			0	X		0.21											
10/25/19 6:00	0.27582			0	X		0.28											
10/25/19 7:00	0.26046			0	X		0.26											
10/25/19 8:00	0.23118			0	X		0.23											
10/25/19 9:00	0.22716			0	X		0.23											
10/25/19 10:00	0.22494			0	X		0.22											
10/25/19 11:00	0.24198			0	X		0.24											
10/25/19 12:00	0.24198			0	X		0.24											
10/25/19 13:00	0.24402			0.08856			0.27											
10/25/19 14:00	0.20946			0.19512			0.4											
10/25/19 15:00	0.19356			0.18792			0.38											
10/25/19 16:00	0.24126			0.23838			0.48											
10/25/19 17:00	0.25854			0.24942			0.51											
10/25/19 18:00	0.19986			0.18108			0.38											
10/25/19 19:00	0.31584			0	X		0.32											
10/25/19 20:00	0.33702			0	X		0.34											
10/25/19 21:00	0.32814			0	X		0.33											
10/25/19 22:00	0.32868			0	X		0.33											
10/25/19 23:00	0.21426			0	X		0.21											
10/26/19 0:00	0.20112			0	X		0.2											
10/26/19 1:00	0.19998			0	X		0.2											
10/26/19 2:00	0.19974			0	X		0.2											
10/26/19 3:00	0.1968			0	X		0.2											
10/26/19 4:00	0.20772			0	X		0.21											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/26/19 5:00	0.20154			0	X					0.2								
10/26/19 6:00	0.21084			0	X					0.21								
10/26/19 7:00	0.20316			0	X					0.2								
10/26/19 8:00	0.20022			0	X					0.2								
10/26/19 9:00	0.20052			0	X					0.2								
10/26/19 10:00	0.19788			0	X					0.2								
10/26/19 11:00	0.19788			0	X					0.2								
10/26/19 12:00	0.2121			0	X					0.21								
10/26/19 13:00	0.21174			0	X					0.21								
10/26/19 14:00	0.20622			0	X					0.21								
10/26/19 15:00	0.1902			0	X					0.19								
10/26/19 16:00	0.19002			0	X					0.19								
10/26/19 17:00	0.21132			0	X					0.21								
10/26/19 18:00	0.2067			0	X					0.21								
10/26/19 19:00	0.20622			0	X					0.21								
10/26/19 20:00	0.1986			0	X					0.2								
10/26/19 21:00	0.1986			0	X					0.2								
10/26/19 22:00	0.19824			0	X					0.2								
10/26/19 23:00	0.19758			0	X					0.2								
10/27/19 0:00	0.2229			0	X					0.22								
10/27/19 1:00	0.2049			0	X					0.2								
10/27/19 2:00	0.2157			0	X					0.22								
10/27/19 3:00	0.23052			0	X					0.23								
10/27/19 4:00	0.23088			0	X					0.23								
10/27/19 5:00	0.2193			0	X					0.22								
10/27/19 6:00	0.23052			0	X					0.23								
10/27/19 7:00	0.2307			0	X					0.23								
10/27/19 8:00	0.23064			0	X					0.23								
10/27/19 9:00	0.19548			0	X					0.2								
10/27/19 10:00	0.18606			0	X					0.19								
10/27/19 11:00	0.18636			0	X					0.19								
10/27/19 12:00	0.18846			0	X					0.19								
10/27/19 13:00	0.19032			0	X					0.19								
10/27/19 14:00	0.18894			0	X					0.19								
10/27/19 15:00	0.22584			0	X					0.23								
10/27/19 16:00	0.2055			0	X					0.21								
10/27/19 17:00	0.2049			0	X					0.2								
10/27/19 18:00	0.21432			0	X					0.21								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/27/19 19:00	0.1956			0	X					0.2								
10/27/19 20:00	0.20562			0	X					0.21								
10/27/19 21:00	0.21918			0	X					0.22								
10/27/19 22:00	0.21018			0	X					0.21								
10/27/19 23:00	0.2001			0	X					0.2								
10/28/19 0:00	0.2001			0	X					0.2								
10/28/19 1:00	0.19962			0	X					0.2								
10/28/19 2:00	0.19998			0	X					0.2								
10/28/19 3:00	0.20298			0	X					0.2								
10/28/19 4:00	0.28662			0	X					0.29								
10/28/19 5:00	0.30138			0	X					0.3								
10/28/19 6:00	0.3414			0	X					0.34								
10/28/19 7:00	0.342			0	X					0.34								
10/28/19 8:00	0.24846			0	X					0.25								
10/28/19 9:00	0.24378			0	X					0.24								
10/28/19 10:00	0.24264			0	X					0.24								
10/28/19 11:00	0.26184			0	X					0.26								
10/28/19 12:00	0.22476			0	X					0.22								
10/28/19 13:00	0.22362			0	X					0.22								
10/28/19 14:00	0.22506			0	X					0.23								
10/28/19 15:00	0.2349			0	X					0.23								
10/28/19 16:00	0.23178			0	X					0.23								
10/28/19 17:00	0.19548			0	X					0.2								
10/28/19 18:00	0.28206			0	X					0.28								
10/28/19 19:00	0.27162			0	X					0.27								
10/28/19 20:00	0.22392			0	X					0.22								
10/28/19 21:00	0.28584			0	X					0.29								
10/28/19 22:00	0.27324			0	X					0.27								
10/28/19 23:00	0.25644			0	X					0.26								
10/29/19 0:00	0.21678			0	X					0.22								
10/29/19 1:00	0.2073			0	X					0.21								
10/29/19 2:00	0.19938			0	X					0.2								
10/29/19 3:00	0.23754			0.06312						0.25								
10/29/19 4:00	0.3405			0.06732						0.37								
10/29/19 5:00	0.39984			0.03918						0.41								
10/29/19 6:00	0.4026			0	X					0.4								
10/29/19 7:00	0.40194			0	X					0.4								
10/29/19 8:00	0.39084			0	X					0.39								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/29/19 9:00	0.38808			0.0429			0.39											
10/29/19 10:00	0.39114			0.0096			0.39											
10/29/19 11:00	0.38388			0.04392			0.39											
10/29/19 12:00	0.3813			0.0243			0.38											
10/29/19 13:00	0.3807			0.03552			0.39											
10/29/19 14:00	0.32826			0	X		0.33											
10/29/19 15:00	0.37758			0	X		0.38											
10/29/19 16:00	0.34494			0	X		0.34											
10/29/19 17:00	0.34392			0	X		0.34											
10/29/19 18:00	0.33192			0	X		0.33											
10/29/19 19:00	0.3207			0	X		0.32											
10/29/19 20:00	0.33462			0	X		0.33											
10/29/19 21:00	0.34158			0	X		0.34											
10/29/19 22:00	0.33984			0	X		0.34											
10/29/19 23:00	0.25656			0	X		0.26											
10/30/19 0:00	0.2085			0	X		0.21											
10/30/19 1:00	0.2094			0	X		0.21											
10/30/19 2:00	0.21684			0	X		0.22											
10/30/19 3:00	0.2466			0	X		0.25											
10/30/19 4:00	0.3336			0	X		0.33											
10/30/19 5:00	0.31962			0	X		0.32											
10/30/19 6:00	0.31494			0	X		0.31											
10/30/19 7:00	0.27024			0.15102			0.37											
10/30/19 8:00	0.18684			0.1836			0.37											
10/30/19 9:00	0.18768			0.17832			0.37											
10/30/19 10:00	0.18756			0.17766			0.37											
10/30/19 11:00	0.20094			0.16794			0.36											
10/30/19 12:00	0.29412			0	X		0.29											
10/30/19 13:00	0.30066			0	X		0.3											
10/30/19 14:00	0.35712			0	X		0.36											
10/30/19 15:00	0.36192			0	X		0.36											
10/30/19 16:00	0.297			0	X		0.3											
10/30/19 17:00	0.33288			0	X		0.33											
10/30/19 18:00	0.32118			0	X		0.32											
10/30/19 19:00	0.2991			0	X		0.3											
10/30/19 20:00	0.31896			0	X		0.32											
10/30/19 21:00	0.29658			0	X		0.3											
10/30/19 22:00	0.26442			0	X		0.26											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 23:00	0.25164			0	X													
10/31/19 0:00	0.21618			0	X													
10/31/19 1:00	0.21216			0	X													
10/31/19 2:00	0.21378			0	X													
10/31/19 3:00	0.2331			0	X													
10/31/19 4:00	0.32022			0	X													
10/31/19 5:00	0.34098			0	X													
10/31/19 6:00	0.37836			0	X													
10/31/19 7:00	0.38556			0	X													
10/31/19 8:00	0.38292			0	X													
10/31/19 9:00	0.38262			0	X													
10/31/19 10:00	0.36168			0	X													
10/31/19 11:00	0.33834			0	X													
10/31/19 12:00	0.31692			0	X													
10/31/19 13:00	0.38196			0	X													
10/31/19 14:00	0.36264			0	X													
10/31/19 15:00	0.363			0	X													
10/31/19 16:00	0.38508			0	X													
10/31/19 17:00	0.38406			0	X													
10/31/19 18:00	0.37554			0	X													
10/31/19 19:00	0.2913			0	X													
10/31/19 20:00	0.28962			0	X													
10/31/19 21:00	0.28542			0	X													
10/31/19 22:00	0.23136			0	X													
10/31/19 23:00	0.20436			0	X													
11/01/19 0:00	0.18936			0	X													
11/01/19 1:00	0.19266			0	X													
11/01/19 2:00	0.20064			0	X													
11/01/19 3:00	0.25542			0	X													
11/01/19 4:00	0.31794			0	X													
11/01/19 5:00	0.35028			0	X													
11/01/19 6:00	0.38868			0	X													
11/01/19 7:00	0.31638			0	X													
11/01/19 8:00	0.31602			0	X													
11/01/19 9:00	0.33066			0	X													
11/01/19 10:00	0.3357			0	X													
11/01/19 11:00	0.29028			0	X													
11/01/19 12:00	0.26778			0	X													

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/01/19 13:00	0.26412			0	X					0.26								
11/01/19 14:00	0.28614			0	X					0.29								
11/01/19 15:00	0.3129			0	X					0.31								
11/01/19 16:00	0.28068			0	X					0.28								
11/01/19 17:00	0.29562			0	X					0.3								
11/01/19 18:00	0.26778			0	X					0.27								
11/01/19 19:00	0.25698			0	X					0.26								
11/01/19 20:00	0.25974			0	X					0.26								
11/01/19 21:00	0.33822			0	X					0.34								
11/01/19 22:00	0.33636			0	X					0.34								
11/01/19 23:00	0.31524			0	X					0.32								
11/02/19 0:00	0.2604			0	X					0.26								
11/02/19 1:00	0.2301			0	X					0.23								
11/02/19 2:00	0.23466			0	X					0.23								
11/02/19 3:00	0.22524			0	X					0.23								
11/02/19 4:00	0.26112			0	X					0.26								
11/02/19 5:00	0.31128			0	X					0.31								
11/02/19 6:00	0.34362			0	X					0.34								
11/02/19 7:00	0.24396			0	X					0.24								
11/02/19 8:00	0.23712			0	X					0.24								
11/02/19 9:00	0.19458			0	X					0.19								
11/02/19 10:00	0.1938			0	X					0.19								
11/02/19 11:00	0.19164			0	X					0.19								
11/02/19 12:00	0.201			0	X					0.2								
11/02/19 13:00	0.21288			0	X					0.21								
11/02/19 14:00	0.24246			0	X					0.24								
11/02/19 15:00	0.37854			0	X					0.38								
11/02/19 16:00	0.30006			0	X					0.3								
11/02/19 17:00	0.37602			0	X					0.38								
11/02/19 18:00	0.26298			0	X					0.26								
11/02/19 19:00	0.24798			0	X					0.25								
11/02/19 20:00	0.28446			0	X					0.28								
11/02/19 21:00	0.32442			0	X					0.32								
11/02/19 22:00	0.31974			0	X					0.32								
11/02/19 23:00	0.21096			0	X					0.21								
11/03/19 0:00	0.19956			0	X					0.2								
11/03/19 1:00	0.20124			0	X					0.2								
11/03/19 2:00	0.20106			0	X					0.2								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/03/19 3:00	0.20088			0	X					0.2								
11/03/19 4:00	0.20058			0	X					0.2								
11/03/19 5:00	0.21252			0	X					0.21								
11/03/19 6:00	0.20562			0	X					0.21								
11/03/19 7:00	0.21816			0	X					0.22								
11/03/19 8:00	0.24396			0	X					0.24								
11/03/19 9:00	0.28188			0	X					0.28								
11/03/19 10:00	0.28968			0	X					0.29								
11/03/19 11:00	0.32964			0	X					0.33								
11/03/19 12:00	0.30174			0	X					0.3								
11/03/19 13:00	0.3273			0	X					0.33								
11/03/19 14:00	0.32142			0	X					0.32								
11/03/19 15:00	0.35058			0	X					0.35								
11/03/19 16:00	0.3468			0	X					0.35								
11/03/19 17:00	0.2217			0	X					0.22								
11/03/19 18:00	0.21216			0	X					0.21								
11/03/19 19:00	0.19086			0	X					0.19								
11/03/19 20:00	0.19218			0	X					0.19								
11/03/19 21:00	0.1974			0	X					0.2								
11/03/19 22:00	0.23712			0	X					0.24								
11/03/19 23:00	0.19938			0	X					0.2								
11/04/19 0:00	0.19908			0	X					0.2								
11/04/19 1:00	0.19974			0	X					0.2								
11/04/19 2:00	0.20106			0	X					0.2								
11/04/19 3:00	0.20118			0	X					0.2								
11/04/19 4:00	0.20412			0	X					0.2								
11/04/19 5:00	0.22752			0	X					0.23								
11/04/19 6:00	0.23964			0	X					0.24								
11/04/19 7:00	0.26058			0	X					0.26								
11/04/19 8:00	0.35568			0	X					0.36								
11/04/19 9:00	0.3882			0	X					0.39								
11/04/19 10:00	0.38742			0	X					0.39								
11/04/19 11:00	0.36258			0	X					0.36								
11/04/19 12:00	0.35298			0	X					0.35								
11/04/19 13:00	0.35622			0	X					0.36								
11/04/19 14:00	0.34752			0	X					0.35								
11/04/19 15:00	0.3489			0	X					0.35								
11/04/19 16:00	0.34716			0	X					0.35								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/04/19 17:00	0.2865			0	X					0.29								
11/04/19 18:00	0.26118			0	X					0.26								
11/04/19 19:00	0.22842			0	X					0.23								
11/04/19 20:00	0.20988			0	X					0.21								
11/04/19 21:00	0.24246			0	X					0.24								
11/04/19 22:00	0.22572			0	X					0.23								
11/04/19 23:00	0.19242			0	X					0.19								
11/05/19 0:00	0.20664			0	X					0.21								
11/05/19 1:00	0.20334			0	X					0.2								
11/05/19 2:00	0.20262			0	X					0.2								
11/05/19 3:00	0.20172			0	X					0.2								
11/05/19 4:00	0.207			0	X					0.21								
11/05/19 5:00	0.23802			0	X					0.24								
11/05/19 6:00	0.33354			0	X					0.33								
11/05/19 7:00	0.32604			0	X					0.33								
11/05/19 8:00	0.33162			0	X					0.33								
11/05/19 9:00	0.3495			0	X					0.35								
11/05/19 10:00	0.30852			0	X					0.31								
11/05/19 11:00	0.30546			0	X					0.31								
11/05/19 12:00	0.2991			0	X					0.3								
11/05/19 13:00	0.28536			0.09792						0.31								
11/05/19 14:00	0.22062			0.207						0.43								
11/05/19 15:00	0.26586			0.25032						0.52								
11/05/19 16:00	0.28308			0.2676						0.55								
11/05/19 17:00	0.27084			0.25584						0.53								
11/05/19 18:00	0.27048			0.25578						0.53								
11/05/19 19:00	0.25758			0.24408						0.5								
11/05/19 20:00	0.2499			0.23688						0.49								
11/05/19 21:00	0.1971			0.18858						0.39								
11/05/19 22:00	0.19266			0.18948						0.38								
11/05/19 23:00	0.19026			0.19254						0.38								
11/06/19 0:00	0.1914			0.19824						0.39								
11/06/19 1:00	0.18942			0.2004						0.39								
11/06/19 2:00	0.18732			0.20262						0.39								
11/06/19 3:00	0.1851			0.20496						0.39								
11/06/19 4:00	0.18246			0.20712						0.39								
11/06/19 5:00	0.18378			0.2085						0.39								
11/06/19 6:00	0.22956			0.2241						0.45								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
11/06/19 7:00	0.23562			0.225			0.46								
11/06/19 8:00	0.21186			0.2055			0.42								
11/06/19 9:00	0.21858			0.21786			0.44								
11/06/19 10:00	0.21888			0.22032			0.44								
11/06/19 11:00	0.2283			0.2166			0.44								
11/06/19 12:00	0.23934			0.231			0.47								
11/06/19 13:00	0.24084			0.23676			0.48								
11/06/19 14:00	0.25344			0.25044			0.5								
11/06/19 15:00	0.30528			0.28896			0.59								
11/06/19 16:00	0.31188			0.29586			0.61								
11/06/19 17:00	0.36792			0.3516			0.72								
11/06/19 18:00	0.37182			0.35622			0.73								
11/06/19 19:00	0.36246			0.3471			0.71								
11/06/19 20:00	0.36726			0.35112			0.72								
11/06/19 21:00	0.32418			0.3087			0.63								
11/06/19 22:00	0.22308			0.21546			0.44								
11/06/19 23:00	0.2025			0.17802			0.38								
11/07/19 0:00	0.35454			0.07296			0.36								
11/07/19 1:00	0.32574			0	X		0.33								
11/07/19 2:00	0.32448			0	X		0.32								
11/07/19 3:00	0.3234			0	X		0.32								
11/07/19 4:00	0.3207			0	X		0.32								
11/07/19 5:00	0.37428			0	X		0.37								
11/07/19 6:00	0.38742			0	X		0.39								
11/07/19 7:00	0.38688			0	X		0.39								
11/07/19 8:00	0.33372			0	X		0.33								
11/07/19 9:00	0.35046			0	X		0.35								
11/07/19 10:00	0.33138			0.09912			0.36								
11/07/19 11:00	0.20568			0.19476			0.4								
11/07/19 12:00	0.19296			0.18204			0.38								
11/07/19 13:00	0.19104			0.17976			0.37								
11/07/19 14:00	0.1908			0.1812			0.37								
11/07/19 15:00	0.19638			0.19092			0.39								
11/07/19 16:00	0.2559			0.2466			0.5								
11/07/19 17:00	0.26922			0.25686			0.53								
11/07/19 18:00	0.28566			0.26484			0.55								
11/07/19 19:00	0.27942			0.24648			0.53								
11/07/19 20:00	0.24096			0.2148			0.46								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/07/19 21:00	0.33654			0.1527			0.37											
11/07/19 22:00	0.39126			0	X		0.39											
11/07/19 23:00	0.3294			0	X		0.33											
11/08/19 0:00	0.32718			0	X		0.33											
11/08/19 1:00	0.29742			0	X		0.3											
11/08/19 2:00	0.29328			0	X		0.29											
11/08/19 3:00	0.29484			0	X		0.29											
11/08/19 4:00	0.30108			0	X		0.3											
11/08/19 5:00	0.35496			0	X		0.35											
11/08/19 6:00	0.34038			0	X		0.34											
11/08/19 7:00	0.38664			0	X		0.39											
11/08/19 8:00	0.33252			0	X		0.33											
11/08/19 9:00	0.33306			0.10206			0.36											
11/08/19 10:00	0.20844			0.19566			0.4											
11/08/19 11:00	0.18942			0.1812			0.37											
11/08/19 12:00	0.19104			0.1863			0.38											
11/08/19 13:00	0.19614			0.19452			0.39											
11/08/19 14:00	0.19932			0.20166			0.4											
11/08/19 15:00	0.27072			0.25602			0.53											
11/08/19 16:00	0.2862			0.26478			0.55											
11/08/19 17:00	0.34794			0.33258			0.68											
11/08/19 18:00	0.35952			0.34428			0.7											
11/08/19 19:00	0.34548			0.33048			0.68											
11/08/19 20:00	0.18858			0.18522			0.37											
11/08/19 21:00	0.1884			0.1881			0.38											
11/08/19 22:00	0.18576			0.18894			0.37											
11/08/19 23:00	0.18294			0.17232			0.36											
11/09/19 0:00	0.21006			0.07494			0.22											
11/09/19 1:00	0.19242			0	X		0.19											
11/09/19 2:00	0.18882			0	X		0.19											
11/09/19 3:00	0.19068			0	X		0.19											
11/09/19 4:00	0.19026			0	X		0.19											
11/09/19 5:00	0.20958			0	X		0.21											
11/09/19 6:00	0.2181			0	X		0.22											
11/09/19 7:00	0.23568			0	X		0.24											
11/09/19 8:00	0.21036			0	X		0.21											
11/09/19 9:00	0.20628			0	X		0.21											
11/09/19 10:00	0.20436			0	X		0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/19 11:00	0.20406			0	X					0.2					
11/09/19 12:00	0.20508			0	X					0.21					
11/09/19 13:00	0.20598			0	X					0.21					
11/09/19 14:00	0.20904			0	X					0.21					
11/09/19 15:00	0.26646			0	X					0.27					
11/09/19 16:00	0.32184			0	X					0.32					
11/09/19 17:00	0.31854			0	X					0.32					
11/09/19 18:00	0.31224			0	X					0.31					
11/09/19 19:00	0.29376			0	X					0.29					
11/09/19 20:00	0.24672			0	X					0.25					
11/09/19 21:00	0.25104			0	X					0.25					
11/09/19 22:00	0.2871			0	X					0.29					
11/09/19 23:00	0.24756			0	X					0.25					
11/10/19 0:00	0.22626			0	X					0.23					
11/10/19 1:00	0.19788			0	X					0.2					
11/10/19 2:00	0.1971			0	X					0.2					
11/10/19 3:00	0.19716			0	X					0.2					
11/10/19 4:00	0.19776			0	X					0.2					
11/10/19 5:00	0.20166			0	X					0.2					
11/10/19 6:00	0.2115			0	X					0.21					
11/10/19 7:00	0.22812			0	X					0.23					
11/10/19 8:00	0.20706			0	X					0.21					
11/10/19 9:00	0.22062			0	X					0.22					
11/10/19 10:00	0.21192			0	X					0.21					
11/10/19 11:00	0.21534			0	X					0.22					
11/10/19 12:00	0.21312			0	X					0.21					
11/10/19 13:00	0.21912			0	X					0.22					
11/10/19 14:00	0.21516			0	X					0.22					
11/10/19 15:00	0.26028			0	X					0.26					
11/10/19 16:00	0.25392			0	X					0.25					
11/10/19 17:00	0.30198			0	X					0.3					
11/10/19 18:00	0.29652			0	X					0.3					
11/10/19 19:00	0.26814			0	X					0.27					
11/10/19 20:00	0.22716			0	X					0.23					
11/10/19 21:00	0.22866			0	X					0.23					
11/10/19 22:00	0.27756			0	X					0.28					
11/10/19 23:00	0.22692			0	X					0.23					
11/11/19 0:00	0.21888			0	X					0.22					

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/11/19 1:00	0.21798			0	X					0.22								
11/11/19 2:00	0.20928			0	X					0.21								
11/11/19 3:00	0.20922			0	X					0.21								
11/11/19 4:00	0.22638			0	X					0.23								
11/11/19 5:00	0.25686			0	X					0.26								
11/11/19 6:00	0.27048			0	X					0.27								
11/11/19 7:00	0.28722			0	X					0.29								
11/11/19 8:00	0.21408			0	X					0.21								
11/11/19 9:00	0.21156			0	X					0.21								
11/11/19 10:00	0.20448			0	X					0.2								
11/11/19 11:00	0.19848			0	X					0.2								
11/11/19 12:00	0.22074			0	X					0.22								
11/11/19 13:00	0.24276			0	X					0.24								
11/11/19 14:00	0.26766			0	X					0.27								
11/11/19 15:00	0.26928			0	X					0.27								
11/11/19 16:00	0.3381			0	X					0.34								
11/11/19 17:00	0.33894			0	X					0.34								
11/11/19 18:00	0.34104			0	X					0.34								
11/11/19 19:00	0.33426			0	X					0.33								
11/11/19 20:00	0.20616			0	X					0.21								
11/11/19 21:00	0.21786			0	X					0.22								
11/11/19 22:00	0.22806			0	X					0.23								
11/11/19 23:00	0.2064			0.1389						0.28								
11/12/19 0:00	0.16452			0.1938						0.26								
11/12/19 1:00	0	X		0.19446						0.19								
11/12/19 2:00	0	X		0.18852						0.19								
11/12/19 3:00	0	X		0.18786						0.19								
11/12/19 4:00	0	X		0.20652						0.21								
11/12/19 5:00	0	X		0.23802						0.24								
11/12/19 6:00	0	X		0.3						0.3								
11/12/19 7:00	0	X		0.28218						0.28								
11/12/19 8:00	0	X		0.20232						0.2								
11/12/19 9:00	0	X		0.22578						0.23								
11/12/19 10:00	0	X		0.23484						0.23								
11/12/19 11:00	0	X		0.21672						0.22								
11/12/19 12:00	0	X		0.24882						0.25								
11/12/19 13:00	0	X		0.23196						0.23								
11/12/19 14:00	0	X		0.23184						0.23								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/12/19 15:00	0	X		0.23376			0.23											
11/12/19 16:00	0	X		0.27648			0.28											
11/12/19 17:00	0	X		0.28446			0.28											
11/12/19 18:00	0	X		0.32004			0.32											
11/12/19 19:00	0	X		0.32154			0.32											
11/12/19 20:00	0	X		0.21342			0.21											
11/12/19 21:00	0	X		0.2511			0.25											
11/12/19 22:00	0	X		0.24966			0.25											
11/12/19 23:00	0	X		0.21924			0.22											
11/13/19 0:00	0	X		0.28818			0.29											
11/13/19 1:00	0	X		0.27792			0.28											
11/13/19 2:00	0	X		0.261			0.26											
11/13/19 3:00	0	X		0.26316			0.26											
11/13/19 4:00	0	X		0.28602			0.29											
11/13/19 5:00	0	X		0.32928			0.33											
11/13/19 6:00	0.09258			0.32574			0.35											
11/13/19 7:00	0.2121			0.21258			0.42											
11/13/19 8:00	0.22218			0.21612			0.44											
11/13/19 9:00	0.2262			0.22398			0.45											
11/13/19 10:00	0.22248			0.22458			0.45											
11/13/19 11:00	0.22296			0.22932			0.45											
11/13/19 12:00	0.22038			0.2313			0.45											
11/13/19 13:00	0.22218			0.23772			0.46											
11/13/19 14:00	0.2322			0.2499			0.48											
11/13/19 15:00	0.25992			0.25476			0.51											
11/13/19 16:00	0.2595			0.25554			0.52											
11/13/19 17:00	0.25806			0.25626			0.51											
11/13/19 18:00	0.25908			0.25728			0.52											
11/13/19 19:00	0.2577			0.25734			0.52											
11/13/19 20:00	0.25686			0.2553			0.51											
11/13/19 21:00	0.18546			0.18			0.37											
11/13/19 22:00	0.19134			0.18588			0.38											
11/13/19 23:00	0.18504			0.17772			0.36											
11/14/19 0:00	0.1821			0.17238			0.35											
11/14/19 1:00	0.18156			0.17238			0.35											
11/14/19 2:00	0.1815			0.17244			0.35											
11/14/19 3:00	0.18156			0.17244			0.35											
11/14/19 4:00	0.18162			0.17256			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/14/19 5:00	0.18528			0.17616			0.36											
11/14/19 6:00	0.25926			0.2514			0.51											
11/14/19 7:00	0.20652			0.20568			0.41											
11/14/19 8:00	0.22104			0.22446			0.45											
11/14/19 9:00	0.22602			0.23388			0.46											
11/14/19 10:00	0.2238			0.23718			0.46											
11/14/19 11:00	0.22932			0.24774			0.48											
11/14/19 12:00	0.22722			0.2493			0.48											
11/14/19 13:00	0.22572			0.25176			0.48											
11/14/19 14:00	0.22458			0.25392			0.48											
11/14/19 15:00	0.26148			0.25776			0.52											
11/14/19 16:00	0.2604			0.25746			0.52											
11/14/19 17:00	0.25698			0.25848			0.52											
11/14/19 18:00	0.2556			0.2592			0.51											
11/14/19 19:00	0.25428			0.25962			0.51											
11/14/19 20:00	0.24984			0.2565			0.51											
11/14/19 21:00	0.1893			0.18528			0.37											
11/14/19 22:00	0.18978			0.18594			0.38											
11/14/19 23:00	0.17658			0.18042			0.36											
11/15/19 0:00	0	X		0.14238			0.04											
11/15/19 1:00	0	X		0	X		0											
11/15/19 2:00	0	X		0	X		0											
11/15/19 3:00	0	X		0	X		0											
11/15/19 4:00	0	X		0	X		0											
11/15/19 5:00	0	X		0	X		0											
11/15/19 6:00	0	X		0	X		0											
11/15/19 7:00	0	X		0	X		0											
11/15/19 8:00	0	X		0	X		0											
11/15/19 9:00	0	X		0	X		0											
11/15/19 10:00	0	X		0	X		0											
11/15/19 11:00	0	X		0	X		0											
11/15/19 12:00	0	X		0	X		0											
11/15/19 13:00	0	X		0	X		0											
11/15/19 14:00	0	X		0	X		0											
11/15/19 15:00	0	X		0	X		0											
11/15/19 16:00	0	X		0	X		0											
11/15/19 17:00	0	X		0	X		0											
11/15/19 18:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/15/19 19:00	0	X		0	X		0											
11/15/19 20:00	0	X		0	X		0											
11/15/19 21:00	0	X		0	X		0											
11/15/19 22:00	0	X		0	X		0											
11/15/19 23:00	0	X		0	X		0											
11/16/19 0:00	0	X		0	X		0											
11/16/19 1:00	0	X		0	X		0											
11/16/19 2:00	0	X		0	X		0											
11/16/19 3:00	0	X		0	X		0											
11/16/19 4:00	0	X		0	X		0											
11/16/19 5:00	0	X		0	X		0											
11/16/19 6:00	0	X		0	X		0											
11/16/19 7:00	0	X		0	X		0											
11/16/19 8:00	0	X		0	X		0											
11/16/19 9:00	0	X		0	X		0											
11/16/19 10:00	0	X		0	X		0											
11/16/19 11:00	0	X		0	X		0											
11/16/19 12:00	0	X		0	X		0											
11/16/19 13:00	0	X		0	X		0											
11/16/19 14:00	0	X		0	X		0											
11/16/19 15:00	0	X		0	X		0											
11/16/19 16:00	0	X		0	X		0											
11/16/19 17:00	0	X		0	X		0											
11/16/19 18:00	0	X		0	X		0											
11/16/19 19:00	0	X		0	X		0											
11/16/19 20:00	0	X		0	X		0											
11/16/19 21:00	0	X		0	X		0											
11/16/19 22:00	0	X		0	X		0											
11/16/19 23:00	0	X		0	X		0											
11/17/19 0:00	0	X		0	X		0											
11/17/19 1:00	0	X		0	X		0											
11/17/19 2:00	0	X		0	X		0											
11/17/19 3:00	0	X		0	X		0											
11/17/19 4:00	0	X		0	X		0											
11/17/19 5:00	0	X		0	X		0											
11/17/19 6:00	0	X		0	X		0											
11/17/19 7:00	0	X		0	X		0											
11/17/19 8:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/17/19 9:00	0	X		0	X		0											
11/17/19 10:00	0	X		0	X		0											
11/17/19 11:00	0	X		0	X		0											
11/17/19 12:00	0	X		0	X		0											
11/17/19 13:00	0	X		0	X		0											
11/17/19 14:00	0	X		0	X		0											
11/17/19 15:00	0	X		0	X		0											
11/17/19 16:00	0	X		0	X		0											
11/17/19 17:00	0	X		0	X		0											
11/17/19 18:00	0	X		0	X		0											
11/17/19 19:00	0	X		0	X		0											
11/17/19 20:00	0	X		0	X		0											
11/17/19 21:00	0	X		0	X		0											
11/17/19 22:00	0	X		0	X		0											
11/18/19 0:00	0	X		0	X		0											
11/18/19 1:00	0	X		0	X		0											
11/18/19 2:00	0	X		0	X		0											
11/18/19 3:00	0	X		0	X		0											
11/18/19 4:00	0	X		0	X		0											
11/18/19 5:00	0	X		0	X		0											
11/18/19 6:00	0	X		0	X		0											
11/18/19 7:00	0	X		0	X		0											
11/18/19 8:00	0	X		0	X		0											
11/18/19 9:00	0	X		0	X		0											
11/18/19 10:00	0	X		0	X		0											
11/18/19 11:00	0	X		0	X		0											
11/18/19 12:00	0	X		0	X		0											
11/18/19 13:00	0	X		0	X		0											
11/18/19 14:00	0	X		0	X		0											
11/18/19 15:00	0	X		0	X		0											
11/18/19 16:00	0	X		0	X		0											
11/18/19 17:00	0	X		0	X		0											
11/18/19 18:00	0	X		0	X		0											
11/18/19 19:00	0	X		0	X		0											
11/18/19 20:00	0	X		0	X		0											
11/18/19 21:00	0	X		0	X		0											
11/18/19 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/18/19 23:00	0	X		0	X		0											
11/19/19 0:00	0	X		0	X		0											
11/19/19 1:00	0	X		0	X		0											
11/19/19 2:00	0	X		0	X		0											
11/19/19 3:00	0	X		0	X		0											
11/19/19 4:00	0	X		0	X		0											
11/19/19 5:00	0	X		0	X		0											
11/19/19 6:00	0	X		0	X		0											
11/19/19 7:00	0	X		0	X		0											
11/19/19 8:00	0	X		0	X		0											
11/19/19 9:00	0	X		0	X		0											
11/19/19 10:00	0	X		0	X		0											
11/19/19 11:00	0	X		0	X		0											
11/19/19 12:00	0	X		0	X		0											
11/19/19 13:00	0	X		0	X		0											
11/19/19 14:00	0	X		0	X		0											
11/19/19 15:00	0	X		0	X		0											
11/19/19 16:00	0	X		0	X		0											
11/19/19 17:00	0	X		0	X		0											
11/19/19 18:00	0	X		0	X		0											
11/19/19 19:00	0	X		0	X		0											
11/19/19 20:00	0	X		0	X		0											
11/19/19 21:00	0	X		0	X		0											
11/19/19 22:00	0	X		0	X		0											
11/19/19 23:00	0	X		0	X		0											
11/20/19 0:00	0	X		0	X		0											
11/20/19 1:00	0	X		0	X		0											
11/20/19 2:00	0	X		0	X		0											
11/20/19 3:00	0	X		0.096			0.03											
11/20/19 4:00	0	X		0.24492			0.24											
11/20/19 5:00	0	X		0.2475			0.25											
11/20/19 6:00	0	X		0.21324			0.21											
11/20/19 7:00	0	X		0.13014			0.02											
11/20/19 8:00	0	X		0	X		0											
11/20/19 9:00	0	X		0	X		0											
11/20/19 10:00	0	X		0	X		0											
11/20/19 11:00	0	X		0	X		0											
11/20/19 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/20/19 13:00	0	X		0	X		0											
11/20/19 14:00	0	X		0	X		0											
11/20/19 15:00	0	X		0	X		0											
11/20/19 16:00	0	X		0	X		0											
11/20/19 17:00	0	X		0	X		0											
11/20/19 18:00	0	X		0	X		0											
11/20/19 19:00	0	X		0	X		0											
11/20/19 20:00	0	X		0	X		0											
11/20/19 21:00	0	X		0	X		0											
11/20/19 22:00	0	X		0	X		0											
11/20/19 23:00	0	X		0	X		0											
11/21/19 0:00	0	X		0	X		0											
11/21/19 1:00	0	X		0	X		0											
11/21/19 2:00	0	X		0	X		0											
11/21/19 3:00	0	X		0	X		0											
11/21/19 4:00	0	X		0	X		0											
11/21/19 5:00	0.10092			0	X		0.03											
11/21/19 6:00	0.26154			0.09102			0.28											
11/21/19 7:00	0.2691			0.2472			0.52											
11/21/19 8:00	0.27282			0.2583			0.53											
11/21/19 9:00	0.22878			0.2181			0.45											
11/21/19 10:00	0.22608			0.21858			0.44											
11/21/19 11:00	0.22482			0.22158			0.45											
11/21/19 12:00	0.22518			0.22542			0.45											
11/21/19 13:00	0.22476			0.22842			0.45											
11/21/19 14:00	0.22134			0.2286			0.45											
11/21/19 15:00	0.25494			0.24954			0.5											
11/21/19 16:00	0.25962			0.25398			0.51											
11/21/19 17:00	0.25734			0.25554			0.51											
11/21/19 18:00	0.25548			0.25776			0.51											
11/21/19 19:00	0.25176			0.2586			0.51											
11/21/19 20:00	0.25032			0.25932			0.51											
11/21/19 21:00	0.26166			0.24846			0.51											
11/21/19 22:00	0.19146			0.18156			0.37											
11/21/19 23:00	0.18342			0.17682			0.36											
11/22/19 0:00	0.1845			0.1779			0.36											
11/22/19 1:00	0.18588			0.17688			0.36											
11/22/19 2:00	0.18588			0.17688			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/22/19 3:00	0.1863			0.17694			0.36											
11/22/19 4:00	0.18696			0.17772			0.36											
11/22/19 5:00	0.1959			0.18642			0.38											
11/22/19 6:00	0.23244			0.22194			0.45											
11/22/19 7:00	0.21594			0.20796			0.42											
11/22/19 8:00	0.2298			0.22434			0.45											
11/22/19 9:00	0.23064			0.22716			0.46											
11/22/19 10:00	0.2307			0.23052			0.46											
11/22/19 11:00	0.2313			0.23556			0.47											
11/22/19 12:00	0.23376			0.2427			0.48											
11/22/19 13:00	0.2457			0.23748			0.48											
11/22/19 14:00	0.24732			0.23898			0.49											
11/22/19 15:00	0.27306			0.25944			0.53											
11/22/19 16:00	0.36186			0.3459			0.71											
11/22/19 17:00	0.36288			0.34698			0.71											
11/22/19 18:00	0.36216			0.34656			0.71											
11/22/19 19:00	0.36114			0.3456			0.71											
11/22/19 20:00	0.35658			0.33948			0.7											
11/22/19 21:00	0.26784			0.25224			0.52											
11/22/19 22:00	0.26364			0.25362			0.52											
11/22/19 23:00	0.26178			0.25254			0.51											
11/23/19 0:00	0	X		0.14388			0.04											
11/23/19 1:00	0	X		0	X		0											
11/23/19 2:00	0	X		0	X		0											
11/23/19 3:00	0	X		0	X		0											
11/23/19 4:00	0	X		0	X		0											
11/23/19 5:00	0	X		0	X		0											
11/23/19 6:00	0	X		0	X		0											
11/23/19 7:00	0	X		0	X		0											
11/23/19 8:00	0	X		0	X		0											
11/23/19 9:00	0	X		0	X		0											
11/23/19 10:00	0	X		0	X		0											
11/23/19 11:00	0	X		0	X		0											
11/23/19 12:00	0	X		0	X		0											
11/23/19 13:00	0	X		0	X		0											
11/23/19 14:00	0	X		0	X		0											
11/23/19 15:00	0	X		0	X		0											
11/23/19 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/23/19 17:00	0	X		0	X		0											
11/23/19 18:00	0	X		0	X		0											
11/23/19 19:00	0	X		0	X		0											
11/23/19 20:00	0	X		0	X		0											
11/23/19 21:00	0	X		0	X		0											
11/23/19 22:00	0	X		0	X		0											
11/23/19 23:00	0	X		0	X		0											
11/24/19 0:00	0	X		0	X		0											
11/24/19 1:00	0	X		0	X		0											
11/24/19 2:00	0	X		0	X		0											
11/24/19 3:00	0	X		0	X		0											
11/24/19 4:00	0	X		0	X		0											
11/24/19 5:00	0	X		0	X		0											
11/24/19 6:00	0	X		0	X		0											
11/24/19 7:00	0	X		0	X		0											
11/24/19 8:00	0	X		0	X		0											
11/24/19 9:00	0	X		0	X		0											
11/24/19 10:00	0	X		0	X		0											
11/24/19 11:00	0	X		0	X		0											
11/24/19 12:00	0	X		0	X		0											
11/24/19 13:00	0	X		0	X		0											
11/24/19 14:00	0	X		0	X		0											
11/24/19 15:00	0	X		0	X		0											
11/24/19 16:00	0	X		0	X		0											
11/24/19 17:00	0	X		0	X		0											
11/24/19 18:00	0	X		0	X		0											
11/24/19 19:00	0	X		0	X		0											
11/24/19 20:00	0	X		0	X		0											
11/24/19 21:00	0	X		0	X		0											
11/24/19 22:00	0	X		0	X		0											
11/24/19 23:00	0	X		0	X		0											
11/25/19 0:00	0	X		0	X		0											
11/25/19 1:00	0	X		0	X		0											
11/25/19 2:00	0	X		0	X		0											
11/25/19 3:00	0	X		0	X		0											
11/25/19 4:00	0	X		0	X		0											
11/25/19 5:00	0	X		0	X		0											
11/25/19 6:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/25/19 7:00	0	X		0	X		0											
11/25/19 8:00	0	X		0	X		0											
11/25/19 9:00	0	X		0	X		0											
11/25/19 10:00	0	X		0	X		0											
11/25/19 11:00	0	X		0	X		0											
11/25/19 12:00	0	X		0	X		0											
11/25/19 13:00	0	X		0	X		0											
11/25/19 14:00	0	X		0	X		0											
11/25/19 15:00	0	X		0	X		0											
11/25/19 16:00	0	X		0	X		0											
11/25/19 17:00	0	X		0	X		0											
11/25/19 18:00	0	X		0	X		0											
11/25/19 19:00	0	X		0	X		0											
11/25/19 20:00	0	X		0	X		0											
11/25/19 21:00	0	X		0	X		0											
11/25/19 22:00	0	X		0	X		0											
11/25/19 23:00	0	X		0	X		0											
11/26/19 0:00	0	X		0	X		0											
11/26/19 1:00	0	X		0	X		0											
11/26/19 2:00	0	X		0	X		0											
11/26/19 3:00	0	X		0.08748			0.02											
11/26/19 4:00	0	X		0.19332			0.19											
11/26/19 5:00	0	X		0.24894			0.25											
11/26/19 6:00	0.20016			0.23754			0.43											
11/26/19 7:00	0.24624			0.2337			0.48											
11/26/19 8:00	0.24894			0.23952			0.49											
11/26/19 9:00	0.25374			0.24756			0.5											
11/26/19 10:00	0.25542			0.25254			0.51											
11/26/19 11:00	0.25452			0.25524			0.51											
11/26/19 12:00	0.25278			0.25794			0.51											
11/26/19 13:00	0.25716			0.25248			0.51											
11/26/19 14:00	0.26154			0.2484			0.51											
11/26/19 15:00	0.27162			0.24864			0.52											
11/26/19 16:00	0.28992			0.27366			0.56											
11/26/19 17:00	0.3771			0.36204			0.74											
11/26/19 18:00	0.36384			0.34854			0.71											
11/26/19 19:00	0.27168			0.24372			0.52											
11/26/19 20:00	0.27282			0.24636			0.52											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
11/26/19 21:00	0.2676			0.2451			0.51								
11/26/19 22:00	0.22614			0.20748			0.43								
11/26/19 23:00	0.20586			0.18906			0.39								
11/27/19 0:00	0.1917			0.17838			0.37								
11/27/19 1:00	0.18288			0.17226			0.36								
11/27/19 2:00	0.1827			0.17238			0.36								
11/27/19 3:00	0.1827			0.1719			0.35								
11/27/19 4:00	0.18708			0.1785			0.37								
11/27/19 5:00	0.19992			0.19494			0.39								
11/27/19 6:00	0.25824			0.25446			0.51								
11/27/19 7:00	0.22386			0.2253			0.45								
11/27/19 8:00	0.22626			0.23088			0.46								
11/27/19 9:00	0.23496			0.24456			0.48								
11/27/19 10:00	0.24912			0.25608			0.51								
11/27/19 11:00	0.24612			0.25368			0.5								
11/27/19 12:00	0.24078			0.25188			0.49								
11/27/19 13:00	0.23658			0.25044			0.49								
11/27/19 14:00	0.22638			0.24276			0.47								
11/27/19 15:00	0.22434			0.24288			0.47								
11/27/19 16:00	0.24192			0.25704			0.5								
11/27/19 17:00	0.3435			0.32844			0.67								
11/27/19 18:00	0.2727			0.25788			0.53								
11/27/19 19:00	0.25812			0.24852			0.51								
11/27/19 20:00	0.25338			0.2481			0.5								
11/27/19 21:00	0.23952			0.23802			0.48								
11/27/19 22:00	0.21528			0.21774			0.43								
11/27/19 23:00	0.18906			0.19884			0.39								
11/28/19 0:00	0.1833			0.19602			0.38								
11/28/19 1:00	0.18306			0.1791			0.36								
11/28/19 2:00	0.18318			0.17382			0.36								
11/28/19 3:00	0.18318			0.17262			0.36								
11/28/19 4:00	0.1872			0.17742			0.36								
11/28/19 5:00	0.19512			0.18966			0.38								
11/28/19 6:00	0.198			0.19752			0.4								
11/28/19 7:00	0.20556			0.19674			0.4								
11/28/19 8:00	0.2274			0.21318			0.44								
11/28/19 9:00	0.23148			0.22044			0.45								
11/28/19 10:00	0.2379			0.22998			0.47								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/28/19 11:00	0.23286			0.22818			0.46											
11/28/19 12:00	0.22542			0.2259			0.45											
11/28/19 13:00	0.21486			0.2214			0.44											
11/28/19 14:00	0.20376			0.21678			0.42											
11/28/19 15:00	0.20136			0.21918			0.42											
11/28/19 16:00	0.1884			0.1917			0.38											
11/28/19 17:00	0.25026			0.24138			0.49											
11/28/19 18:00	0.24534			0.23982			0.49											
11/28/19 19:00	0.18474			0.17514			0.36											
11/28/19 20:00	0.23256			0.22422			0.46											
11/28/19 21:00	0.22398			0.21948			0.44											
11/28/19 22:00	0.20358			0.20556			0.41											
11/28/19 23:00	0.18372			0.18474			0.37											
11/29/19 0:00	0.18906			0.19302			0.38											
11/29/19 1:00	0.18522			0.19326			0.38											
11/29/19 2:00	0.18354			0.18894			0.37											
11/29/19 3:00	0.1845			0.19128			0.38											
11/29/19 4:00	0.18594			0.19536			0.38											
11/29/19 5:00	0.19332			0.20424			0.4											
11/29/19 6:00	0.19872			0.2121			0.41											
11/29/19 7:00	0.20064			0.21822			0.42											
11/29/19 8:00	0.2085			0.2259			0.43											
11/29/19 9:00	0.23064			0.2214			0.45											
11/29/19 10:00	0.23244			0.22644			0.46											
11/29/19 11:00	0.22272			0.22074			0.44											
11/29/19 12:00	0.21984			0.22026			0.44											
11/29/19 13:00	0.21774			0.22104			0.44											
11/29/19 14:00	0.21276			0.21984			0.43											
11/29/19 15:00	0.20754			0.21864			0.43											
11/29/19 16:00	0.1944			0.18576			0.38											
11/29/19 17:00	0.33744			0.32118			0.66											
11/29/19 18:00	0.3444			0.32994			0.67											
11/29/19 19:00	0.33708			0.32268			0.66											
11/29/19 20:00	0.26028			0.2493			0.51											
11/29/19 21:00	0.24216			0.23466			0.48											
11/29/19 22:00	0.21828			0.21336			0.43											
11/29/19 23:00	0.19728			0.19734			0.39											
11/30/19 0:00	0.18462			0.18936			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
11/30/19 1:00	0.18456			0.1782			0.36								
11/30/19 2:00	0.18366			0.17376			0.36								
11/30/19 3:00	0.18402			0.1743			0.36								
11/30/19 4:00	0.1851			0.17964			0.36								
11/30/19 5:00	0.18918			0.18774			0.38								
11/30/19 6:00	0.19302			0.19542			0.39								
11/30/19 7:00	0.20676			0.19668			0.4								
11/30/19 8:00	0.22896			0.2205			0.45								
11/30/19 9:00	0.23646			0.23016			0.47								
11/30/19 10:00	0.24312			0.24084			0.48								
11/30/19 11:00	0.23724			0.23832			0.48								
11/30/19 12:00	0.2331			0.23802			0.47								
11/30/19 13:00	0.23808			0.24762			0.49								
11/30/19 14:00	0.2364			0.24942			0.49								
11/30/19 15:00	0.23172			0.2478			0.48								
11/30/19 16:00	0.19818			0.19452			0.39								
11/30/19 17:00	0.3693			0.354			0.72								
11/30/19 18:00	0.27474			0.25302			0.53								
11/30/19 19:00	0.23424			0.18942			0.42								
11/30/19 20:00	0.27			0.231			0.5								
11/30/19 21:00	0.25644			0.22284			0.48								
11/30/19 22:00	0.23076			0.19836			0.43								
11/30/19 23:00	0.21888			0.18744			0.41								
12/01/19 0:00	0.20448			0.17472			0.38								
12/01/19 1:00	0.18384			0.1722			0.36								
12/01/19 2:00	0.18324			0.17214			0.36								
12/01/19 3:00	0.18324			0.1722			0.36								
12/01/19 4:00	0.18372			0.17244			0.36								
12/01/19 5:00	0.18798			0.17772			0.37								
12/01/19 6:00	0.1881			0.18174			0.37								
12/01/19 7:00	0.19338			0.19056			0.38								
12/01/19 8:00	0.1935			0.19476			0.39								
12/01/19 9:00	0.19302			0.19656			0.39								
12/01/19 10:00	0.20772			0.19794			0.41								
12/01/19 11:00	0.20532			0.20004			0.41								
12/01/19 12:00	0.20292			0.20226			0.41								
12/01/19 13:00	0.20454			0.1977			0.4								
12/01/19 14:00	0.21456			0.21096			0.43								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
12/01/19 15:00	0.24318			0.24258			0.49								
12/01/19 16:00	0.20436			0.19914			0.4								
12/01/19 17:00	0.33222			0.31674			0.65								
12/01/19 18:00	0.36606			0.35082			0.72								
12/01/19 19:00	0.28722			0.25452			0.54								
12/01/19 20:00	0.2895			0.25908			0.55								
12/01/19 21:00	0.27102			0.24744			0.52								
12/01/19 22:00	0.22242			0.2079			0.43								
12/01/19 23:00	0.20856			0.1977			0.41								
12/02/19 0:00	0.19734			0.19002			0.39								
12/02/19 1:00	0.1839			0.17334			0.36								
12/02/19 2:00	0.18366			0.17262			0.36								
12/02/19 3:00	0.18402			0.17274			0.36								
12/02/19 4:00	0.18552			0.1752			0.36								
12/02/19 5:00	0.198			0.19098			0.39								
12/02/19 6:00	0.28236			0.25872			0.54								
12/02/19 7:00	0.25674			0.24144			0.5								
12/02/19 8:00	0.24372			0.23532			0.48								
12/02/19 9:00	0.26184			0.25608			0.52								
12/02/19 10:00	0.25464			0.25176			0.51								
12/02/19 11:00	0.25248			0.25224			0.5								
12/02/19 12:00	0.26232			0.25308			0.52								
12/02/19 13:00	0.25524			0.2481			0.5								
12/02/19 14:00	0.25344			0.24882			0.5								
12/02/19 15:00	0.27102			0.25722			0.53								
12/02/19 16:00	0.34398			0.32844			0.67								
12/02/19 17:00	0.34302			0.32778			0.67								
12/02/19 18:00	0.3423			0.32688			0.67								
12/02/19 19:00	0.3384			0.32334			0.66								
12/02/19 20:00	0.34062			0.32562			0.67								
12/02/19 21:00	0.26628			0.25284			0.52								
12/02/19 22:00	0.21354			0.20376			0.42								
12/02/19 23:00	0.1854			0.17694			0.36								
12/03/19 0:00	0.18738			0.18024			0.37								
12/03/19 1:00	0.18234			0.1734			0.36								
12/03/19 2:00	0.18234			0.17388			0.36								
12/03/19 3:00	0.18222			0.1737			0.36								
12/03/19 4:00	0.18228			0.17388			0.36								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/19 5:00	0.19086			0.18444			0.38											
12/03/19 6:00	0.20154			0.19758			0.4											
12/03/19 7:00	0.25548			0.24606			0.5											
12/03/19 8:00	0.24456			0.23352			0.48											
12/03/19 9:00	0.26448			0.25494			0.52											
12/03/19 10:00	0.25122			0.24474			0.5											
12/03/19 11:00	0.23946			0.23544			0.47											
12/03/19 12:00	0.23382			0.23292			0.47											
12/03/19 13:00	0.23424			0.22446			0.46											
12/03/19 14:00	0.24228			0.23166			0.47											
12/03/19 15:00	0.2412			0.23472			0.48											
12/03/19 16:00	0.25452			0.2478			0.5											
12/03/19 17:00	0.29628			0.28128			0.58											
12/03/19 18:00	0.2877			0.27306			0.56											
12/03/19 19:00	0.2235			0.21192			0.44											
12/03/19 20:00	0.29154			0.27654			0.57											
12/03/19 21:00	0.27438			0.25746			0.53											
12/03/19 22:00	0.27096			0.22614			0.5											
12/03/19 23:00	0.24384			0.20112			0.44											
12/04/19 0:00	0.1995			0.18342			0.38											
12/04/19 1:00	0.18414			0.17412			0.36											
12/04/19 2:00	0.1839			0.17286			0.36											
12/04/19 3:00	0.18354			0.17262			0.36											
12/04/19 4:00	0.186			0.17484			0.36											
12/04/19 5:00	0.2511			0.24252			0.49											
12/04/19 6:00	0.25506			0.2481			0.5											
12/04/19 7:00	0.31812			0.30162			0.62											
12/04/19 8:00	0.33684			0.32058			0.66											
12/04/19 9:00	0.3348			0.3189			0.65											
12/04/19 10:00	0.26112			0.24912			0.51											
12/04/19 11:00	0.2574			0.249			0.51											
12/04/19 12:00	0.25494			0.25104			0.51											
12/04/19 13:00	0.25344			0.2532			0.51											
12/04/19 14:00	0.25842			0.24822			0.51											
12/04/19 15:00	0.25974			0.25038			0.51											
12/04/19 16:00	0.34128			0.3258			0.67											
12/04/19 17:00	0.34548			0.32976			0.68											
12/04/19 18:00	0.34542			0.32964			0.68											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/04/19 19:00	0.34116			0.32472			0.67											
12/04/19 20:00	0.33804			0.32226			0.66											
12/04/19 21:00	0.30048			0.28488			0.59											
12/04/19 22:00	0.26316			0.24294			0.51											
12/04/19 23:00	0.2028			0.18498			0.39											
12/05/19 0:00	0.09774			0.09846			0.02											
12/05/19 1:00	0	X		0	X		0											
12/05/19 2:00	0	X		0	X		0											
12/05/19 3:00	0	X		0	X		0											
12/05/19 4:00	0	X		0	X		0											
12/05/19 5:00	0	X		0	X		0											
12/05/19 6:00	0	X		0	X		0											
12/05/19 7:00	0	X		0	X		0											
12/05/19 8:00	0	X		0	X		0											
12/05/19 9:00	0	X		0	X		0											
12/05/19 10:00	0	X		0	X		0											
12/05/19 11:00	0	X		0	X		0											
12/05/19 12:00	0	X		0	X		0											
12/05/19 13:00	0	X		0	X		0											
12/05/19 14:00	0	X		0	X		0											
12/05/19 15:00	0	X		0	X		0											
12/05/19 16:00	0	X		0	X		0											
12/05/19 17:00	0	X		0	X		0											
12/05/19 18:00	0	X		0	X		0											
12/05/19 19:00	0	X		0	X		0											
12/05/19 20:00	0	X		0	X		0											
12/05/19 21:00	0	X		0	X		0											
12/05/19 22:00	0	X		0	X		0											
12/05/19 23:00	0	X		0	X		0											
12/06/19 0:00	0	X		0	X		0											
12/06/19 1:00	0	X		0	X		0											
12/06/19 2:00	0	X		0	X		0											
12/06/19 3:00	0	X		0	X		0											
12/06/19 4:00	0	X		0	X		0											
12/06/19 5:00	0	X		0	X		0											
12/06/19 6:00	0	X		0	X		0											
12/06/19 7:00	0	X		0	X		0											
12/06/19 8:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/06/19 9:00	0	X		0	X		0											
12/06/19 10:00	0	X		0	X		0											
12/06/19 11:00	0	X		0	X		0											
12/06/19 12:00	0	X		0	X		0											
12/06/19 13:00	0	X		0	X		0											
12/06/19 14:00	0	X		0	X		0											
12/06/19 15:00	0	X		0	X		0											
12/06/19 16:00	0	X		0	X		0											
12/06/19 17:00	0	X		0	X		0											
12/06/19 18:00	0	X		0	X		0											
12/06/19 19:00	0	X		0	X		0											
12/06/19 20:00	0	X		0	X		0											
12/06/19 21:00	0	X		0	X		0											
12/06/19 22:00	0	X		0	X		0											
12/06/19 23:00	0	X		0	X		0											
12/07/19 0:00	0	X		0	X		0											
12/07/19 1:00	0	X		0	X		0											
12/07/19 2:00	0	X		0	X		0											
12/07/19 3:00	0	X		0	X		0											
12/07/19 4:00	0	X		0	X		0											
12/07/19 5:00	0	X		0	X		0											
12/07/19 6:00	0	X		0	X		0											
12/07/19 7:00	0	X		0	X		0											
12/07/19 8:00	0	X		0	X		0											
12/07/19 9:00	0	X		0	X		0											
12/07/19 10:00	0	X		0	X		0											
12/07/19 11:00	0	X		0	X		0											
12/07/19 12:00	0	X		0	X		0											
12/07/19 13:00	0	X		0	X		0											
12/07/19 14:00	0	X		0	X		0											
12/07/19 15:00	0	X		0	X		0											
12/07/19 16:00	0	X		0	X		0											
12/07/19 17:00	0	X		0	X		0											
12/07/19 18:00	0	X		0	X		0											
12/07/19 19:00	0	X		0	X		0											
12/07/19 20:00	0	X		0	X		0											
12/07/19 21:00	0	X		0	X		0											
12/07/19 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/07/19 23:00	0	X		0	X		0											
12/08/19 0:00	0	X		0	X		0											
12/08/19 1:00	0	X		0	X		0											
12/08/19 2:00	0	X		0	X		0											
12/08/19 3:00	0	X		0	X		0											
12/08/19 4:00	0	X		0	X		0											
12/08/19 5:00	0	X		0	X		0											
12/08/19 6:00	0	X		0	X		0											
12/08/19 7:00	0	X		0	X		0											
12/08/19 8:00	0	X		0	X		0											
12/08/19 9:00	0	X		0	X		0											
12/08/19 10:00	0	X		0	X		0											
12/08/19 11:00	0	X		0	X		0											
12/08/19 12:00	0	X		0	X		0											
12/08/19 13:00	0	X		0	X		0											
12/08/19 14:00	0	X		0	X		0											
12/08/19 15:00	0	X		0	X		0											
12/08/19 16:00	0	X		0	X		0											
12/08/19 17:00	0	X		0	X		0											
12/08/19 18:00	0	X		0	X		0											
12/08/19 19:00	0	X		0	X		0											
12/08/19 20:00	0	X		0	X		0											
12/08/19 21:00	0	X		0	X		0											
12/08/19 22:00	0	X		0	X		0											
12/08/19 23:00	0	X		0	X		0											
12/09/19 0:00	0	X		0	X		0											
12/09/19 1:00	0	X		0	X		0											
12/09/19 2:00	0	X		0	X		0											
12/09/19 3:00	0	X		0	X		0											
12/09/19 4:00	0	X		0	X		0											
12/09/19 5:00	0	X		0	X		0											
12/09/19 6:00	0	X		0	X		0											
12/09/19 7:00	0	X		0	X		0											
12/09/19 8:00	0	X		0	X		0											
12/09/19 9:00	0	X		0	X		0											
12/09/19 10:00	0	X		0	X		0											
12/09/19 11:00	0	X		0	X		0											
12/09/19 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/09/19 13:00	0	X		0	X		0											
12/09/19 14:00	0	X		0	X		0											
12/09/19 15:00	0	X		0	X		0											
12/09/19 16:00	0	X		0	X		0											
12/09/19 17:00	0	X		0	X		0											
12/09/19 18:00	0	X		0	X		0											
12/09/19 19:00	0	X		0	X		0											
12/09/19 20:00	0	X		0	X		0											
12/09/19 21:00	0	X		0	X		0											
12/09/19 22:00	0	X		0	X		0											
12/09/19 23:00	0	X		0	X		0											
12/10/19 0:00	0	X		0	X		0											
12/10/19 1:00	0	X		0	X		0											
12/10/19 2:00	0	X		0	X		0											
12/10/19 3:00	0	X		0	X		0											
12/10/19 4:00	0	X		0	X		0											
12/10/19 5:00	0	X		0	X		0											
12/10/19 6:00	0	X		0	X		0											
12/10/19 7:00	0	X		0	X		0											
12/10/19 8:00	0	X		0	X		0											
12/10/19 9:00	0	X		0	X		0											
12/10/19 10:00	0	X		0	X		0											
12/10/19 11:00	0	X		0	X		0											
12/10/19 12:00	0	X		0	X		0											
12/10/19 13:00	0	X		0	X		0											
12/10/19 14:00	0	X		0	X		0											
12/10/19 15:00	0	X		0	X		0											
12/10/19 16:00	0	X		0	X		0											
12/10/19 17:00	0	X		0	X		0											
12/10/19 18:00	0	X		0	X		0											
12/10/19 19:00	0	X		0	X		0											
12/10/19 20:00	0	X		0	X		0											
12/10/19 21:00	0	X		0	X		0											
12/10/19 22:00	0	X		0	X		0											
12/10/19 23:00	0	X		0	X		0											
12/11/19 0:00	0	X		0	X		0											
12/11/19 1:00	0	X		0	X		0											
12/11/19 2:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/11/19 3:00	0	X		0	X		0											
12/11/19 4:00	0	X		0	X		0											
12/11/19 5:00	0	X		0	X		0											
12/11/19 6:00	0	X		0	X		0											
12/11/19 7:00	0	X		0	X		0											
12/11/19 8:00	0	X		0	X		0											
12/11/19 9:00	0	X		0	X		0											
12/11/19 10:00	0	X		0	X		0											
12/11/19 11:00	0	X		0	X		0											
12/11/19 12:00	0	X		0	X		0											
12/11/19 13:00	0	X		0	X		0											
12/11/19 14:00	0	X		0	X		0											
12/11/19 15:00	0	X		0	X		0											
12/11/19 16:00	0	X		0	X		0											
12/11/19 17:00	0	X		0	X		0											
12/11/19 18:00	0	X		0	X		0											
12/11/19 19:00	0	X		0	X		0											
12/11/19 20:00	0	X		0	X		0											
12/11/19 21:00	0	X		0	X		0											
12/11/19 22:00	0	X		0	X		0											
12/11/19 23:00	0	X		0	X		0											
12/12/19 0:00	0	X		0	X		0											
12/12/19 1:00	0	X		0	X		0											
12/12/19 2:00	0	X		0	X		0											
12/12/19 3:00	0	X		0	X		0											
12/12/19 4:00	0	X		0	X		0											
12/12/19 5:00	0	X		0	X		0											
12/12/19 6:00	0	X		0	X		0											
12/12/19 7:00	0	X		0	X		0											
12/12/19 8:00	0	X		0	X		0											
12/12/19 9:00	0	X		0	X		0											
12/12/19 10:00	0	X		0	X		0											
12/12/19 11:00	0	X		0	X		0											
12/12/19 12:00	0	X		0	X		0											
12/12/19 13:00	0	X		0	X		0											
12/12/19 14:00	0	X		0	X		0											
12/12/19 15:00	0	X		0	X		0											
12/12/19 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/12/19 17:00	0	X		0	X		0											
12/12/19 18:00	0	X		0	X		0											
12/12/19 19:00	0	X		0	X		0											
12/12/19 20:00	0	X		0	X		0											
12/12/19 21:00	0	X		0	X		0											
12/12/19 22:00	0	X		0	X		0											
12/12/19 23:00	0	X		0	X		0											
12/13/19 0:00	0	X		0	X		0											
12/13/19 1:00	0	X		0	X		0											
12/13/19 2:00	0	X		0	X		0											
12/13/19 3:00	0	X		0	X		0											
12/13/19 4:00	0	X		0	X		0											
12/13/19 5:00	0	X		0	X		0											
12/13/19 6:00	0	X		0	X		0											
12/13/19 7:00	0	X		0	X		0											
12/13/19 8:00	0	X		0	X		0											
12/13/19 9:00	0	X		0	X		0											
12/13/19 10:00	0	X		0	X		0											
12/13/19 11:00	0	X		0	X		0											
12/13/19 12:00	0	X		0	X		0											
12/13/19 13:00	0	X		0	X		0											
12/13/19 14:00	0	X		0	X		0											
12/13/19 15:00	0	X		0	X		0											
12/13/19 16:00	0	X		0	X		0											
12/13/19 17:00	0	X		0	X		0											
12/13/19 18:00	0	X		0	X		0											
12/13/19 19:00	0	X		0	X		0											
12/13/19 20:00	0	X		0	X		0											
12/13/19 21:00	0	X		0	X		0											
12/13/19 22:00	0	X		0	X		0											
12/13/19 23:00	0	X		0	X		0											
12/14/19 0:00	0	X		0	X		0											
12/14/19 1:00	0	X		0	X		0											
12/14/19 2:00	0	X		0	X		0											
12/14/19 3:00	0	X		0	X		0											
12/14/19 4:00	0	X		0	X		0											
12/14/19 5:00	0	X		0	X		0											
12/14/19 6:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/14/19 7:00	0	X		0	X		0											
12/14/19 8:00	0	X		0	X		0											
12/14/19 9:00	0	X		0	X		0											
12/14/19 10:00	0	X		0	X		0											
12/14/19 11:00	0	X		0	X		0											
12/14/19 12:00	0	X		0	X		0											
12/14/19 13:00	0	X		0	X		0											
12/14/19 14:00	0	X		0	X		0											
12/14/19 15:00	0	X		0	X		0											
12/14/19 16:00	0	X		0	X		0											
12/14/19 17:00	0	X		0	X		0											
12/14/19 18:00	0	X		0	X		0											
12/14/19 19:00	0	X		0	X		0											
12/14/19 20:00	0	X		0	X		0											
12/14/19 21:00	0	X		0	X		0											
12/14/19 22:00	0	X		0	X		0											
12/14/19 23:00	0	X		0	X		0											
12/15/19 0:00	0	X		0	X		0											
12/15/19 1:00	0	X		0	X		0											
12/15/19 2:00	0	X		0	X		0											
12/15/19 3:00	0	X		0	X		0											
12/15/19 4:00	0	X		0	X		0											
12/15/19 5:00	0	X		0	X		0											
12/15/19 6:00	0	X		0	X		0											
12/15/19 7:00	0	X		0	X		0											
12/15/19 8:00	0	X		0	X		0											
12/15/19 9:00	0	X		0	X		0											
12/15/19 10:00	0	X		0	X		0											
12/15/19 11:00	0	X		0	X		0											
12/15/19 12:00	0	X		0	X		0											
12/15/19 13:00	0	X		0	X		0											
12/15/19 14:00	0	X		0	X		0											
12/15/19 15:00	0	X		0	X		0											
12/15/19 16:00	0	X		0	X		0											
12/15/19 17:00	0	X		0	X		0											
12/15/19 18:00	0	X		0	X		0											
12/15/19 19:00	0	X		0	X		0											
12/15/19 20:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/15/19 21:00	0	X		0	X		0											
12/15/19 22:00	0	X		0	X		0											
12/15/19 23:00	0	X		0	X		0											
12/16/19 0:00	0	X		0	X		0											
12/16/19 1:00	0	X		0	X		0											
12/16/19 2:00	0	X		0	X		0											
12/16/19 3:00	0	X		0	X		0											
12/16/19 4:00	0	X		0	X		0											
12/16/19 5:00	0	X		0	X		0											
12/16/19 6:00	0	X		0	X		0											
12/16/19 7:00	0	X		0	X		0											
12/16/19 8:00	0	X		0	X		0											
12/16/19 9:00	0	X		0	X		0											
12/16/19 10:00	0	X		0	X		0											
12/16/19 11:00	0	X		0	X		0											
12/16/19 12:00	0	X		0	X		0											
12/16/19 13:00	0	X		0	X		0											
12/16/19 14:00	0	X		0	X		0											
12/16/19 15:00	0	X		0	X		0											
12/16/19 16:00	0	X		0	X		0											
12/16/19 17:00	0	X		0	X		0											
12/16/19 18:00	0	X		0	X		0											
12/16/19 19:00	0	X		0	X		0											
12/16/19 20:00	0	X		0	X		0											
12/16/19 21:00	0	X		0	X		0											
12/16/19 22:00	0	X		0	X		0											
12/16/19 23:00	0	X		0	X		0											
12/17/19 0:00	0	X		0	X		0											
12/17/19 1:00	0	X		0	X		0											
12/17/19 2:00	0	X		0	X		0											
12/17/19 3:00	0	X		0	X		0											
12/17/19 4:00	0	X		0	X		0											
12/17/19 5:00	0	X		0	X		0											
12/17/19 6:00	0	X		0	X		0											
12/17/19 7:00	0	X		0	X		0											
12/17/19 8:00	0	X		0	X		0											
12/17/19 9:00	0	X		0	X		0											
12/17/19 10:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/17/19 11:00	0	X		0	X		0											
12/17/19 12:00	0	X		0	X		0											
12/17/19 13:00	0	X		0	X		0											
12/17/19 14:00	0	X		0	X		0											
12/17/19 15:00	0	X		0	X		0											
12/17/19 16:00	0	X		0	X		0											
12/17/19 17:00	0	X		0	X		0											
12/17/19 18:00	0	X		0	X		0											
12/17/19 19:00	0	X		0	X		0											
12/17/19 20:00	0	X		0	X		0											
12/17/19 21:00	0	X		0	X		0											
12/17/19 22:00	0	X		0	X		0											
12/17/19 23:00	0	X		0	X		0											
12/18/19 0:00	0	X		0	X		0											
12/18/19 1:00	0	X		0	X		0											
12/18/19 2:00	0	X		0	X		0											
12/18/19 3:00	0	X		0	X		0											
12/18/19 4:00	0	X		0	X		0											
12/18/19 5:00	0	X		0	X		0											
12/18/19 6:00	0	X		0	X		0											
12/18/19 7:00	0	X		0	X		0											
12/18/19 8:00	0	X		0	X		0											
12/18/19 9:00	0	X		0	X		0											
12/18/19 10:00	0	X		0	X		0											
12/18/19 11:00	0	X		0	X		0											
12/18/19 12:00	0	X		0	X		0											
12/18/19 13:00	0	X		0	X		0											
12/18/19 14:00	0	X		0	X		0											
12/18/19 15:00	0	X		0	X		0											
12/18/19 16:00	0	X		0	X		0											
12/18/19 17:00	0	X		0	X		0											
12/18/19 18:00	0	X		0	X		0											
12/18/19 19:00	0	X		0	X		0											
12/18/19 20:00	0	X		0	X		0											
12/18/19 21:00	0	X		0	X		0											
12/18/19 22:00	0	X		0	X		0											
12/18/19 23:00	0	X		0	X		0											
12/19/19 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/19/19 1:00	0	X		0	X		0											
12/19/19 2:00	0	X		0	X		0											
12/19/19 3:00	0	X		0	X		0											
12/19/19 4:00	0	X		0	X		0											
12/19/19 5:00	0	X		0	X		0											
12/19/19 6:00	0	X		0	X		0											
12/19/19 7:00	0	X		0	X		0											
12/19/19 8:00	0	X		0	X		0											
12/19/19 9:00	0	X		0	X		0											
12/19/19 10:00	0	X		0	X		0											
12/19/19 11:00	0	X		0	X		0											
12/19/19 12:00	0	X		0	X		0											
12/19/19 13:00	0	X		0	X		0											
12/19/19 14:00	0	X		0	X		0											
12/19/19 15:00	0	X		0	X		0											
12/19/19 16:00	0	X		0	X		0											
12/19/19 17:00	0	X		0	X		0											
12/19/19 18:00	0	X		0	X		0											
12/19/19 19:00	0	X		0	X		0											
12/19/19 20:00	0	X		0	X		0											
12/19/19 21:00	0	X		0	X		0											
12/19/19 22:00	0	X		0	X		0											
12/19/19 23:00	0	X		0	X		0											
12/20/19 0:00	0	X		0	X		0											
12/20/19 1:00	0	X		0	X		0											
12/20/19 2:00	0	X		0	X		0											
12/20/19 3:00	0	X		0	X		0											
12/20/19 4:00	0	X		0	X		0											
12/20/19 5:00	0	X		0	X		0											
12/20/19 6:00	0	X		0	X		0											
12/20/19 7:00	0	X		0	X		0											
12/20/19 8:00	0	X		0	X		0											
12/20/19 9:00	0	X		0	X		0											
12/20/19 10:00	0	X		0	X		0											
12/20/19 11:00	0	X		0	X		0											
12/20/19 12:00	0	X		0	X		0											
12/20/19 13:00	0	X		0	X		0											
12/20/19 14:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/20/19 15:00	0	X		0	X		0											
12/20/19 16:00	0	X		0	X		0											
12/20/19 17:00	0	X		0	X		0											
12/20/19 18:00	0	X		0	X		0											
12/20/19 19:00	0	X		0	X		0											
12/20/19 20:00	0	X		0	X		0											
12/20/19 21:00	0	X		0	X		0											
12/20/19 22:00	0	X		0	X		0											
12/20/19 23:00	0	X		0	X		0											
12/21/19 0:00	0	X		0	X		0											
12/21/19 1:00	0	X		0	X		0											
12/21/19 2:00	0	X		0	X		0											
12/21/19 3:00	0	X		0	X		0											
12/21/19 4:00	0	X		0	X		0											
12/21/19 5:00	0	X		0	X		0											
12/21/19 6:00	0	X		0	X		0											
12/21/19 7:00	0	X		0	X		0											
12/21/19 8:00	0	X		0	X		0											
12/21/19 9:00	0	X		0	X		0											
12/21/19 10:00	0	X		0	X		0											
12/21/19 11:00	0	X		0	X		0											
12/21/19 12:00	0	X		0	X		0											
12/21/19 13:00	0	X		0	X		0											
12/21/19 14:00	0	X		0	X		0											
12/21/19 15:00	0	X		0	X		0											
12/21/19 16:00	0	X		0	X		0											
12/21/19 17:00	0	X		0	X		0											
12/21/19 18:00	0	X		0	X		0											
12/21/19 19:00	0	X		0	X		0											
12/21/19 20:00	0	X		0	X		0											
12/21/19 21:00	0	X		0	X		0											
12/21/19 22:00	0	X		0	X		0											
12/21/19 23:00	0	X		0	X		0											
12/22/19 0:00	0	X		0	X		0											
12/22/19 1:00	0	X		0	X		0											
12/22/19 2:00	0	X		0	X		0											
12/22/19 3:00	0	X		0	X		0											
12/22/19 4:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/22/19 5:00	0	X		0	X		0											
12/22/19 6:00	0	X		0	X		0											
12/22/19 7:00	0	X		0	X		0											
12/22/19 8:00	0	X		0	X		0											
12/22/19 9:00	0	X		0	X		0											
12/22/19 10:00	0	X		0	X		0											
12/22/19 11:00	0	X		0	X		0											
12/22/19 12:00	0	X		0	X		0											
12/22/19 13:00	0	X		0	X		0											
12/22/19 14:00	0	X		0	X		0											
12/22/19 15:00	0	X		0	X		0											
12/22/19 16:00	0	X		0	X		0											
12/22/19 17:00	0	X		0	X		0											
12/22/19 18:00	0	X		0	X		0											
12/22/19 19:00	0	X		0	X		0											
12/22/19 20:00	0	X		0	X		0											
12/22/19 21:00	0	X		0	X		0											
12/22/19 22:00	0	X		0	X		0											
12/22/19 23:00	0	X		0	X		0											
12/23/19 0:00	0	X		0	X		0											
12/23/19 1:00	0	X		0	X		0											
12/23/19 2:00	0	X		0	X		0											
12/23/19 3:00	0	X		0	X		0											
12/23/19 4:00	0	X		0	X		0											
12/23/19 5:00	0	X		0	X		0											
12/23/19 6:00	0	X		0	X		0											
12/23/19 7:00	0	X		0	X		0											
12/23/19 8:00	0	X		0	X		0											
12/23/19 9:00	0	X		0	X		0											
12/23/19 10:00	0	X		0	X		0											
12/23/19 11:00	0	X		0	X		0											
12/23/19 12:00	0	X		0	X		0											
12/23/19 13:00	0	X		0	X		0											
12/23/19 14:00	0	X		0	X		0											
12/23/19 15:00	0	X		0	X		0											
12/23/19 16:00	0	X		0	X		0											
12/23/19 17:00	0	X		0	X		0											
12/23/19 18:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/23/19 19:00	0	X		0	X		0											
12/23/19 20:00	0	X		0	X		0											
12/23/19 21:00	0	X		0	X		0											
12/23/19 22:00	0	X		0	X		0											
12/23/19 23:00	0	X		0	X		0											
12/24/19 0:00	0	X		0	X		0											
12/24/19 1:00	0	X		0	X		0											
12/24/19 2:00	0	X		0	X		0											
12/24/19 3:00	0	X		0	X		0											
12/24/19 4:00	0	X		0	X		0											
12/24/19 5:00	0	X		0	X		0											
12/24/19 6:00	0	X		0	X		0											
12/24/19 7:00	0	X		0	X		0											
12/24/19 8:00	0	X		0	X		0											
12/24/19 9:00	0	X		0	X		0											
12/24/19 10:00	0	X		0	X		0											
12/24/19 11:00	0	X		0	X		0											
12/24/19 12:00	0	X		0	X		0											
12/24/19 13:00	0	X		0	X		0											
12/24/19 14:00	0	X		0	X		0											
12/24/19 15:00	0	X		0	X		0											
12/24/19 16:00	0	X		0	X		0											
12/24/19 17:00	0	X		0	X		0											
12/24/19 18:00	0	X		0	X		0											
12/24/19 19:00	0	X		0	X		0											
12/24/19 20:00	0	X		0	X		0											
12/24/19 21:00	0	X		0	X		0											
12/24/19 22:00	0	X		0	X		0											
12/24/19 23:00	0	X		0	X		0											
12/25/19 0:00	0	X		0	X		0											
12/25/19 1:00	0	X		0	X		0											
12/25/19 2:00	0	X		0	X		0											
12/25/19 3:00	0	X		0	X		0											
12/25/19 4:00	0	X		0	X		0											
12/25/19 5:00	0	X		0	X		0											
12/25/19 6:00	0	X		0	X		0											
12/25/19 7:00	0	X		0	X		0											
12/25/19 8:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/25/19 9:00	0	X		0	X		0											
12/25/19 10:00	0	X		0	X		0											
12/25/19 11:00	0	X		0	X		0											
12/25/19 12:00	0	X		0	X		0											
12/25/19 13:00	0	X		0	X		0											
12/25/19 14:00	0	X		0	X		0											
12/25/19 15:00	0	X		0	X		0											
12/25/19 16:00	0	X		0	X		0											
12/25/19 17:00	0	X		0	X		0											
12/25/19 18:00	0	X		0	X		0											
12/25/19 19:00	0	X		0	X		0											
12/25/19 20:00	0	X		0	X		0											
12/25/19 21:00	0	X		0	X		0											
12/25/19 22:00	0	X		0	X		0											
12/26/19 0:00	0	X		0	X		0											
12/26/19 1:00	0	X		0	X		0											
12/26/19 2:00	0	X		0	X		0											
12/26/19 3:00	0	X		0	X		0											
12/26/19 4:00	0	X		0	X		0											
12/26/19 5:00	0	X		0	X		0											
12/26/19 6:00	0	X		0	X		0											
12/26/19 7:00	0	X		0	X		0											
12/26/19 8:00	0	X		0	X		0											
12/26/19 9:00	0	X		0	X		0											
12/26/19 10:00	0	X		0	X		0											
12/26/19 11:00	0	X		0	X		0											
12/26/19 12:00	0	X		0	X		0											
12/26/19 13:00	0	X		0	X		0											
12/26/19 14:00	0	X		0	X		0											
12/26/19 15:00	0	X		0	X		0											
12/26/19 16:00	0	X		0	X		0											
12/26/19 17:00	0	X		0	X		0											
12/26/19 18:00	0	X		0	X		0											
12/26/19 19:00	0	X		0	X		0											
12/26/19 20:00	0	X		0	X		0											
12/26/19 21:00	0	X		0	X		0											
12/26/19 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/26/19 23:00	0	X		0	X		0											
12/27/19 0:00	0	X		0	X		0											
12/27/19 1:00	0	X		0	X		0											
12/27/19 2:00	0	X		0	X		0											
12/27/19 3:00	0	X		0	X		0											
12/27/19 4:00	0	X		0	X		0											
12/27/19 5:00	0	X		0	X		0											
12/27/19 6:00	0	X		0	X		0											
12/27/19 7:00	0	X		0	X		0											
12/27/19 8:00	0	X		0	X		0											
12/27/19 9:00	0	X		0	X		0											
12/27/19 10:00	0	X		0	X		0											
12/27/19 11:00	0	X		0	X		0											
12/27/19 12:00	0	X		0	X		0											
12/27/19 13:00	0	X		0	X		0											
12/27/19 14:00	0	X		0	X		0											
12/27/19 15:00	0	X		0	X		0											
12/27/19 16:00	0	X		0	X		0											
12/27/19 17:00	0	X		0	X		0											
12/27/19 18:00	0	X		0	X		0											
12/27/19 19:00	0	X		0	X		0											
12/27/19 20:00	0	X		0	X		0											
12/27/19 21:00	0	X		0	X		0											
12/27/19 22:00	0	X		0	X		0											
12/27/19 23:00	0	X		0	X		0											
12/28/19 0:00	0	X		0	X		0											
12/28/19 1:00	0	X		0	X		0											
12/28/19 2:00	0	X		0	X		0											
12/28/19 3:00	0	X		0	X		0											
12/28/19 4:00	0	X		0	X		0											
12/28/19 5:00	0	X		0	X		0											
12/28/19 6:00	0	X		0	X		0											
12/28/19 7:00	0	X		0	X		0											
12/28/19 8:00	0	X		0	X		0											
12/28/19 9:00	0	X		0	X		0											
12/28/19 10:00	0	X		0	X		0											
12/28/19 11:00	0	X		0	X		0											
12/28/19 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/28/19 13:00	0	X		0	X		0											
12/28/19 14:00	0	X		0	X		0											
12/28/19 15:00	0	X		0	X		0											
12/28/19 16:00	0	X		0	X		0											
12/28/19 17:00	0	X		0	X		0											
12/28/19 18:00	0	X		0	X		0											
12/28/19 19:00	0	X		0	X		0											
12/28/19 20:00	0	X		0	X		0											
12/28/19 21:00	0	X		0	X		0											
12/28/19 22:00	0	X		0	X		0											
12/28/19 23:00	0	X		0	X		0											
12/29/19 0:00	0	X		0	X		0											
12/29/19 1:00	0	X		0	X		0											
12/29/19 2:00	0	X		0	X		0											
12/29/19 3:00	0	X		0	X		0											
12/29/19 4:00	0	X		0	X		0											
12/29/19 5:00	0	X		0	X		0											
12/29/19 6:00	0	X		0	X		0											
12/29/19 7:00	0	X		0	X		0											
12/29/19 8:00	0	X		0	X		0											
12/29/19 9:00	0	X		0	X		0											
12/29/19 10:00	0	X		0	X		0											
12/29/19 11:00	0	X		0	X		0											
12/29/19 12:00	0	X		0	X		0											
12/29/19 13:00	0	X		0	X		0											
12/29/19 14:00	0	X		0	X		0											
12/29/19 15:00	0	X		0	X		0											
12/29/19 16:00	0	X		0	X		0											
12/29/19 17:00	0	X		0	X		0											
12/29/19 18:00	0	X		0	X		0											
12/29/19 19:00	0	X		0	X		0											
12/29/19 20:00	0	X		0	X		0											
12/29/19 21:00	0	X		0	X		0											
12/29/19 22:00	0	X		0	X		0											
12/29/19 23:00	0	X		0	X		0											
12/30/19 0:00	0	X		0	X		0											
12/30/19 1:00	0	X		0	X		0											
12/30/19 2:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/30/19 3:00	0	X		0	X		0											
12/30/19 4:00	0	X		0	X		0											
12/30/19 5:00	0	X		0	X		0											
12/30/19 6:00	0	X		0	X		0											
12/30/19 7:00	0	X		0	X		0											
12/30/19 8:00	0	X		0	X		0											
12/30/19 9:00	0	X		0	X		0											
12/30/19 10:00	0	X		0	X		0											
12/30/19 11:00	0	X		0	X		0											
12/30/19 12:00	0	X		0	X		0											
12/30/19 13:00	0	X		0	X		0											
12/30/19 14:00	0	X		0	X		0											
12/30/19 15:00	0	X		0	X		0											
12/30/19 16:00	0	X		0	X		0											
12/30/19 17:00	0	X		0	X		0											
12/30/19 18:00	0	X		0	X		0											
12/30/19 19:00	0	X		0	X		0											
12/30/19 20:00	0	X		0	X		0											
12/30/19 21:00	0	X		0	X		0											
12/30/19 22:00	0	X		0	X		0											
12/30/19 23:00	0	X		0	X		0											
12/31/19 0:00	0	X		0	X		0											
12/31/19 1:00	0	X		0	X		0											
12/31/19 2:00	0	X		0	X		0											
12/31/19 3:00	0	X		0	X		0											
12/31/19 4:00	0	X		0	X		0											
12/31/19 5:00	0	X		0	X		0											
12/31/19 6:00	0	X		0	X		0											
12/31/19 7:00	0	X		0	X		0											
12/31/19 8:00	0	X		0	X		0											
12/31/19 9:00	0	X		0	X		0											
12/31/19 10:00	0	X		0	X		0											
12/31/19 11:00	0	X		0	X		0											
12/31/19 12:00	0	X		0	X		0											
12/31/19 13:00	0	X		0	X		0											
12/31/19 14:00	0	X		0	X		0											
12/31/19 15:00	0	X		0	X		0											
12/31/19 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value			SI			Modc			
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/31/19 17:00	0	X		0	X		0												
12/31/19 18:00	0	X		0	X		0												
12/31/19 19:00	0	X		0	X		0												
12/31/19 20:00	0	X		0	X		0												
12/31/19 21:00	0	X		0	X		0												
12/31/19 22:00	0	X		0	X		0												
12/31/19 23:00	0	X		0	X		0												

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:32 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2019	0.3310	3.6667	0.3916	8.6208	0.0696	1.5963	0.0349	0.7982	0.1162	2.6610
Nov 2019	0.5504	3.5681	1.0151	8.9063	0.1824	1.6530	0.0911	0.8264	0.3043	2.7560
Dec 2019	0.0850	3.2072	0.2419	7.8108	0.0460	1.4448	0.0230	0.7223	0.0767	2.4089
Sum/Avg	3.2072		7.8108		1.4448		0.7223		2.4089	
Limit Value										

Monthly Summary Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:33 Location: Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Oct 19	178.28	178.28	67.45	67.45	96.55	96.55	36.82	36.82
Nov 19	461.92	640.20	114.94	182.39	293.17	389.72	40.42	77.24
Dec 19	96.12	736.32	22.32	204.71	96.12	485.84	21.58	98.82
Sum/Avg	736.32		204.71		485.84		98.82	

AQ34 3HR AVG LOAD

Date/Time	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/01/19 0:00	0			0			0											
10/01/19 1:00	0			0			0											
10/01/19 2:00	0			0			0											
10/01/19 3:00	0			0			0											
10/01/19 4:00	0			0			0											
10/01/19 5:00	0			0			0											
10/01/19 6:00	0			0			0											
10/01/19 7:00	0			0			0											
10/01/19 8:00	0			0			0											
10/01/19 9:00	0			0			0											
10/01/19 10:00	0			0			0											
10/01/19 11:00	0			0			0											
10/01/19 12:00	0			0			0											
10/01/19 13:00	0			0			0											
10/01/19 14:00	0			0			0											
10/01/19 15:00	0			0			0											
10/01/19 16:00	0			0			0											
10/01/19 17:00	0			0			0											
10/01/19 18:00	0			0			0											
10/01/19 19:00	0			0			0											
10/01/19 20:00	0			0			0											
10/01/19 21:00	0			0			0											
10/01/19 22:00	0			0			0											
10/01/19 23:00	0			0			0											
10/02/19 0:00	0			0			0											
10/02/19 1:00	0			0			0											
10/02/19 2:00	0			0			0											
10/02/19 3:00	0			0			0											
10/02/19 4:00	0			0			0											
10/02/19 5:00	0			0			0											
10/02/19 6:00	0			0			0											
10/02/19 7:00	0			0			0											
10/02/19 8:00	0			0			0											
10/02/19 9:00	0			0			0											
10/02/19 10:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/02/19 11:00	0			0			0												
10/02/19 12:00	0			0			0												
10/02/19 13:00	0			0			0												
10/02/19 14:00	0			0			0												
10/02/19 15:00	0			0			0												
10/02/19 16:00	0			0			0												
10/02/19 17:00	0			0			0												
10/02/19 18:00	0			0			0												
10/02/19 19:00	0			0			0												
10/02/19 20:00	0			0			0												
10/02/19 21:00	0			0			0												
10/02/19 22:00	0			0			0												
10/02/19 23:00	0			0			0												
10/03/19 0:00	0			0			0												
10/03/19 1:00	0			0			0												
10/03/19 2:00	0			0			0												
10/03/19 3:00	0			0			0												
10/03/19 4:00	0			0			0												
10/03/19 5:00	0			0			0												
10/03/19 6:00	0			0			0												
10/03/19 7:00	0			0			0												
10/03/19 8:00	0			0			0												
10/03/19 9:00	0			0			0												
10/03/19 10:00	0			0			0												
10/03/19 11:00	0			0			0												
10/03/19 12:00	0			0			0												
10/03/19 13:00	0			0			0												
10/03/19 14:00	0			0			0												
10/03/19 15:00	0			0			0												
10/03/19 16:00	0			0			0												
10/03/19 17:00	0			0			0												
10/03/19 18:00	0			0			0												
10/03/19 19:00	0			0			0												
10/03/19 20:00	0			0			0												
10/03/19 21:00	0			0			0												
10/03/19 22:00	0			0			0												
10/03/19 23:00	0			0			0												
10/04/19 0:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/04/19 1:00	0			0			0												
10/04/19 2:00	0			0			0												
10/04/19 3:00	0			0			0												
10/04/19 4:00	0			0			0												
10/04/19 5:00	0			0			0												
10/04/19 6:00	0			0			0												
10/04/19 7:00	0			0			0												
10/04/19 8:00	0			0			0												
10/04/19 9:00	0			0			0												
10/04/19 10:00	0			0			0												
10/04/19 11:00	0			0			0												
10/04/19 12:00	0			0			0												
10/04/19 13:00	0			0			0												
10/04/19 14:00	0			0			0												
10/04/19 15:00	0			0			0												
10/04/19 16:00	0			0			0												
10/04/19 17:00	0			0			0												
10/04/19 18:00	0			0			0												
10/04/19 19:00	0			0			0												
10/04/19 20:00	0			0			0												
10/04/19 21:00	0			0			0												
10/04/19 22:00	0			0			0												
10/04/19 23:00	0			0			0												
10/05/19 0:00	0			0			0												
10/05/19 1:00	0			0			0												
10/05/19 2:00	0			0			0												
10/05/19 3:00	0			0			0												
10/05/19 4:00	0			0			0												
10/05/19 5:00	0			0			0												
10/05/19 6:00	0			0			0												
10/05/19 7:00	0			0			0												
10/05/19 8:00	0			0			0												
10/05/19 9:00	0			0			0												
10/05/19 10:00	0			0			0												
10/05/19 11:00	0			0			0												
10/05/19 12:00	0			0			0												
10/05/19 13:00	0			0			0												
10/05/19 14:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/19 15:00	0			0			0											
10/05/19 16:00	0			0			0											
10/05/19 17:00	0			0			0											
10/05/19 18:00	0			0			0											
10/05/19 19:00	0			0			0											
10/05/19 20:00	0			0			0											
10/05/19 21:00	0			0			0											
10/05/19 22:00	0			0			0											
10/05/19 23:00	0			0			0											
10/06/19 0:00	0			0			0											
10/06/19 1:00	0			0			0											
10/06/19 2:00	0			0			0											
10/06/19 3:00	0			0			0											
10/06/19 4:00	0			0			0											
10/06/19 5:00	0			0			0											
10/06/19 6:00	0			0			0											
10/06/19 7:00	0			0			0											
10/06/19 8:00	0			0			0											
10/06/19 9:00	0			0			0											
10/06/19 10:00	0			0			0											
10/06/19 11:00	0			0			0											
10/06/19 12:00	0			0			0											
10/06/19 13:00	0			0			0											
10/06/19 14:00	0			0			0											
10/06/19 15:00	0			0			0											
10/06/19 16:00	0			0			0											
10/06/19 17:00	0			0			0											
10/06/19 18:00	0			0			0											
10/06/19 19:00	0			0			0											
10/06/19 20:00	0			0			0											
10/06/19 21:00	0			0			0											
10/06/19 22:00	0			0			0											
10/06/19 23:00	0			0			0											
10/07/19 0:00	0			0			0											
10/07/19 1:00	0			0			0											
10/07/19 2:00	0			0			0											
10/07/19 3:00	0			0			0											
10/07/19 4:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/07/19 5:00	0			0			0												
10/07/19 6:00	0			0			0												
10/07/19 7:00	0			0			0												
10/07/19 8:00	0			0			0												
10/07/19 9:00	0			0			0												
10/07/19 10:00	0			0			0												
10/07/19 11:00	0			0			0												
10/07/19 12:00	0			0			0												
10/07/19 13:00	0			0			0												
10/07/19 14:00	0			0			0												
10/07/19 15:00	0			0			0												
10/07/19 16:00	0			0			0												
10/07/19 17:00	0			0			0												
10/07/19 18:00	0			0			0												
10/07/19 19:00	0			0			0												
10/07/19 20:00	0			0			0												
10/07/19 21:00	0			0			0												
10/07/19 22:00	0			0			0												
10/07/19 23:00	0			0			0												
10/08/19 0:00	0			0			0												
10/08/19 1:00	0			0			0												
10/08/19 2:00	0			0			0												
10/08/19 3:00	0			0			0												
10/08/19 4:00	0			0			0												
10/08/19 5:00	0			0			0												
10/08/19 6:00	0			0			0												
10/08/19 7:00	0			0			0												
10/08/19 8:00	0			0			0												
10/08/19 9:00	0			0			0												
10/08/19 10:00	0			0			0												
10/08/19 11:00	0			0			0												
10/08/19 12:00	0			0			0												
10/08/19 13:00	0			0			0												
10/08/19 14:00	0			0			0												
10/08/19 15:00	0			0			0												
10/08/19 16:00	0			0			0												
10/08/19 17:00	0			0			0												
10/08/19 18:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/19 19:00	0			0			0											
10/08/19 20:00	0			0			0											
10/08/19 21:00	0			0			0											
10/08/19 22:00	0			0			0											
10/08/19 23:00	0			0			0											
10/09/19 0:00	0			0			0											
10/09/19 1:00	0			0			0											
10/09/19 2:00	0			0			0											
10/09/19 3:00	0			0			0											
10/09/19 4:00	0			0			0											
10/09/19 5:00	0			0			0											
10/09/19 6:00	0			0			0											
10/09/19 7:00	0			0			0											
10/09/19 8:00	0			0			0											
10/09/19 9:00	0			0			0											
10/09/19 10:00	0			0			0											
10/09/19 11:00	0			0			0											
10/09/19 12:00	0			0			0											
10/09/19 13:00	0			0			0											
10/09/19 14:00	0			0			0											
10/09/19 15:00	0			0			0											
10/09/19 16:00	0			0			0											
10/09/19 17:00	0			0			0											
10/09/19 18:00	0			0			0											
10/09/19 19:00	0			0			0											
10/09/19 20:00	0			0			0											
10/09/19 21:00	0			0			0											
10/09/19 22:00	0			0			0											
10/09/19 23:00	0			0			0											
10/10/19 0:00	0			0			0											
10/10/19 1:00	0			0			0											
10/10/19 2:00	0			0			0											
10/10/19 3:00	0			0			0											
10/10/19 4:00	0			0			0											
10/10/19 5:00	0			0			0											
10/10/19 6:00	0			0			0											
10/10/19 7:00	0			0			0											
10/10/19 8:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/19 9:00	0			0			0											
10/10/19 10:00	0			0			0											
10/10/19 11:00	0			0			0											
10/10/19 12:00	0			0			0											
10/10/19 13:00	0			0			0											
10/10/19 14:00	0			0			0											
10/10/19 15:00	0			0			0											
10/10/19 16:00	0			0			0											
10/10/19 17:00	0			0			0											
10/10/19 18:00	0			0			0											
10/10/19 19:00	0			0			0											
10/10/19 20:00	0			0			0											
10/10/19 21:00	0			0			0											
10/10/19 22:00	0			0			0											
10/11/19 0:00	0			0			0											
10/11/19 1:00	0			0			0											
10/11/19 2:00	0			0			0											
10/11/19 3:00	0			0			0											
10/11/19 4:00	0			0			0											
10/11/19 5:00	0			0			0											
10/11/19 6:00	0			0			0											
10/11/19 7:00	0			0			0											
10/11/19 8:00	0			0			0											
10/11/19 9:00	0			0			0											
10/11/19 10:00	0			0			0											
10/11/19 11:00	0			0			0											
10/11/19 12:00	0			0			0											
10/11/19 13:00	0			0			0											
10/11/19 14:00	0			0			0											
10/11/19 15:00	0			0			0											
10/11/19 16:00	0			0			0											
10/11/19 17:00	0			0			0											
10/11/19 18:00	0			0			0											
10/11/19 19:00	0			0			0											
10/11/19 20:00	0			0			0											
10/11/19 21:00	0			0			0											
10/11/19 22:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/11/19 23:00	0			0			0												
10/12/19 0:00	0			0			0												
10/12/19 1:00	0			0			0												
10/12/19 2:00	0			0			0												
10/12/19 3:00	0			0			0												
10/12/19 4:00	0			0			0												
10/12/19 5:00	0			0			0												
10/12/19 6:00	0			0			0												
10/12/19 7:00	0			0			0												
10/12/19 8:00	0			0			0												
10/12/19 9:00	0			0			0												
10/12/19 10:00	0			0			0												
10/12/19 11:00	0			0			0												
10/12/19 12:00	0			0			0												
10/12/19 13:00	0			0			0												
10/12/19 14:00	0			0			0												
10/12/19 15:00	0			0			0												
10/12/19 16:00	0			0			0												
10/12/19 17:00	0			0			0												
10/12/19 18:00	0			0			0												
10/12/19 19:00	0			0			0												
10/12/19 20:00	0			0			0												
10/12/19 21:00	0			0			0												
10/12/19 22:00	0			0			0												
10/12/19 23:00	0			0			0												
10/13/19 0:00	0			0			0												
10/13/19 1:00	0			0			0												
10/13/19 2:00	0			0			0												
10/13/19 3:00	0			0			0												
10/13/19 4:00	0			0			0												
10/13/19 5:00	0			0			0												
10/13/19 6:00	0			0			0												
10/13/19 7:00	0			0			0												
10/13/19 8:00	0			0			0												
10/13/19 9:00	0			0			0												
10/13/19 10:00	0			0			0												
10/13/19 11:00	0			0			0												
10/13/19 12:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/13/19 13:00	0			0			0												
10/13/19 14:00	0			0			0												
10/13/19 15:00	0			0			0												
10/13/19 16:00	0			0			0												
10/13/19 17:00	0			0			0												
10/13/19 18:00	0			0			0												
10/13/19 19:00	0			0			0												
10/13/19 20:00	0			0			0												
10/13/19 21:00	0			0			0												
10/13/19 22:00	0			0			0												
10/13/19 23:00	0			0			0												
10/14/19 0:00	0			0			0												
10/14/19 1:00	0			0			0												
10/14/19 2:00	0			0			0												
10/14/19 3:00	0			0			0												
10/14/19 4:00	0			0			0												
10/14/19 5:00	0			0			0												
10/14/19 6:00	0			0			0												
10/14/19 7:00	0			0			0												
10/14/19 8:00	0			0			0												
10/14/19 9:00	0			0			0												
10/14/19 10:00	0			0			0												
10/14/19 11:00	0			0			0												
10/14/19 12:00	0			0			0												
10/14/19 13:00	0			0			0												
10/14/19 14:00	0			0			0												
10/14/19 15:00	0			0			0												
10/14/19 16:00	0			0			0												
10/14/19 17:00	0			0			0												
10/14/19 18:00	0			0			0												
10/14/19 19:00	0			0			0												
10/14/19 20:00	0			0			0												
10/14/19 21:00	0			0			0												
10/14/19 22:00	0			0			0												
10/14/19 23:00	0			0			0												
10/15/19 0:00	0			0			0												
10/15/19 1:00	0			0			0												
10/15/19 2:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/15/19 3:00	0			0			0												
10/15/19 4:00	0			0			0												
10/15/19 5:00	0			0			0												
10/15/19 6:00	0			0			0												
10/15/19 7:00	0			0			0												
10/15/19 8:00	0			0			0												
10/15/19 9:00	0			0			0												
10/15/19 10:00	0			0			0												
10/15/19 11:00	0			0			0												
10/15/19 12:00	0			0			0												
10/15/19 13:00	0			0			0												
10/15/19 14:00	0			0			0												
10/15/19 15:00	0			0			0												
10/15/19 16:00	0			0			0												
10/15/19 17:00	0			0			0												
10/15/19 18:00	0			0			0												
10/15/19 19:00	0			0			0												
10/15/19 20:00	0			0			0												
10/15/19 21:00	0			0			0												
10/15/19 22:00	0			0			0												
10/15/19 23:00	0			0			0												
10/16/19 0:00	0			0			0												
10/16/19 1:00	0			0			0												
10/16/19 2:00	0			0			0												
10/16/19 3:00	0			0			0												
10/16/19 4:00	0			0			0												
10/16/19 5:00	0			0			0												
10/16/19 6:00	0			0			0												
10/16/19 7:00	0			0			0												
10/16/19 8:00	0			0			0												
10/16/19 9:00	0			0			0												
10/16/19 10:00	0			0			0												
10/16/19 11:00	0			0			0												
10/16/19 12:00	0			0			0												
10/16/19 13:00	0			0			0												
10/16/19 14:00	0			0			0												
10/16/19 15:00	0			0			0												
10/16/19 16:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/16/19 17:00	0			0			0												
10/16/19 18:00	0			0			0												
10/16/19 19:00	0			0			0												
10/16/19 20:00	0			0			0												
10/16/19 21:00	0			0			0												
10/16/19 22:00	0			0			0												
10/16/19 23:00	0			0			0												
10/17/19 0:00	0			0			0												
10/17/19 1:00	0			0			0												
10/17/19 2:00	0			0			0												
10/17/19 3:00	0			0			0												
10/17/19 4:00	0			0			0												
10/17/19 5:00	0			0			0												
10/17/19 6:00	0			0			0												
10/17/19 7:00	0			0			0												
10/17/19 8:00	0			0			0												
10/17/19 9:00	0			0			0												
10/17/19 10:00	0			0			0												
10/17/19 11:00	0			0			0												
10/17/19 12:00	0			0			0												
10/17/19 13:00	0			0			0												
10/17/19 14:00	0			0			0												
10/17/19 15:00	0			0			0												
10/17/19 16:00	0			0			0												
10/17/19 17:00	0			0			0												
10/17/19 18:00	0			0			0												
10/17/19 19:00	0			0			0												
10/17/19 20:00	0			0			0												
10/17/19 21:00	0			0			0												
10/17/19 22:00	0			0			0												
10/17/19 23:00	0			0			0												
10/18/19 0:00	0			0			0												
10/18/19 1:00	0			0			0												
10/18/19 2:00	0			0			0												
10/18/19 3:00	0			0			0												
10/18/19 4:00	0			0			0												
10/18/19 5:00	0			0			0												
10/18/19 6:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/18/19 7:00	0			0			0												
10/18/19 8:00	0			0			0												
10/18/19 9:00	0			0			0												
10/18/19 10:00	0			0			0												
10/18/19 11:00	0			0			0												
10/18/19 12:00	0			0			0												
10/18/19 13:00	0			0			0												
10/18/19 14:00	0			0			0												
10/18/19 15:00	0			0			0												
10/18/19 16:00	0			0			0												
10/18/19 17:00	0			0			0												
10/18/19 18:00	0			0			0												
10/18/19 19:00	0			0			0												
10/18/19 20:00	0			0			0												
10/18/19 21:00	0			0			0												
10/18/19 22:00	0			0			0												
10/18/19 23:00	0			0			0												
10/19/19 0:00	0			0			0												
10/19/19 1:00	0			0			0												
10/19/19 2:00	0			0			0												
10/19/19 3:00	0			0			0												
10/19/19 4:00	0			0			0												
10/19/19 5:00	0			0			0												
10/19/19 6:00	0			0			0												
10/19/19 7:00	0			0			0												
10/19/19 8:00	0			0			0												
10/19/19 9:00	0			0			0												
10/19/19 10:00	0			0			0												
10/19/19 11:00	0			0			0												
10/19/19 12:00	0			0			0												
10/19/19 13:00	0			0			0												
10/19/19 14:00	0			0			0												
10/19/19 15:00	0			0			0												
10/19/19 16:00	0			0			0												
10/19/19 17:00	0			0			0												
10/19/19 18:00	0			0			0												
10/19/19 19:00	0			0			0												
10/19/19 20:00	0			0			0												

ALL_UnitOn_TF_1H CT1_Load_Total_3Hr_MWe_1H CT2_Load_Total_3Hr_MWe_1H

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/19/19 21:00	0			0			0												
10/19/19 22:00	0			0			0												
10/19/19 23:00	0			0			0												
10/20/19 0:00	0			0			0												
10/20/19 1:00	0			0			0												
10/20/19 2:00	0			0			0												
10/20/19 3:00	0			0			0												
10/20/19 4:00	0			0			0												
10/20/19 5:00	0			0			0												
10/20/19 6:00	0			0			0												
10/20/19 7:00	0			0			0												
10/20/19 8:00	0			0			0												
10/20/19 9:00	0			0			0												
10/20/19 10:00	0			0			0												
10/20/19 11:00	0			0			0												
10/20/19 12:00	0			0			0												
10/20/19 13:00	0			0			0												
10/20/19 14:00	0			0			0												
10/20/19 15:00	0			0			0												
10/20/19 16:00	0			0			0												
10/20/19 17:00	0			0			0												
10/20/19 18:00	0			0			0												
10/20/19 19:00	0			0			0												
10/20/19 20:00	0			0			0												
10/20/19 21:00	0			0			0												
10/20/19 22:00	0			0			0												
10/20/19 23:00	0			0			0												
10/21/19 0:00	0			0			0												
10/21/19 1:00	0			0			0												
10/21/19 2:00	0			0			0												
10/21/19 3:00	0			0			0												
10/21/19 4:00	0			0			0												
10/21/19 5:00	1			0			2												
10/21/19 6:00	1			0			16												
10/21/19 7:00	1			0			31												
10/21/19 8:00	1			0			47												
10/21/19 9:00	1			0			56												
10/21/19 10:00	1			0			62												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 11:00	1			0			66											
10/21/19 12:00	1			0			66											
10/21/19 13:00	1			0			69											
10/21/19 14:00	1			0			71											
10/21/19 15:00	1			0			69											
10/21/19 16:00	1			0			68											
10/21/19 17:00	1			0			70											
10/21/19 18:00	1			0			71											
10/21/19 19:00	1			0			68											
10/21/19 20:00	1			0			61											
10/21/19 21:00	1			0			55											
10/21/19 22:00	1			0			49											
10/21/19 23:00	1			0			43											
10/22/19 0:00	1			0			39											
10/22/19 1:00	1			0			38											
10/22/19 2:00	1			0			37											
10/22/19 3:00	1			0			37											
10/22/19 4:00	1			0			38											
10/22/19 5:00	1			0			40											
10/22/19 6:00	1			0			43											
10/22/19 7:00	1			0			47											
10/22/19 8:00	1			0			55											
10/22/19 9:00	1			0			53											
10/22/19 10:00	1			0			59											
10/22/19 11:00	1			0			60											
10/22/19 12:00	1			0			65											
10/22/19 13:00	1			0			65											
10/22/19 14:00	1			0			65											
10/22/19 15:00	1			0			68											
10/22/19 16:00	1			0			67											
10/22/19 17:00	1			0			65											
10/22/19 18:00	1			0			65											
10/22/19 19:00	1			0			65											
10/22/19 20:00	1			0			61											
10/22/19 21:00	1			0			56											
10/22/19 22:00	1			0			52											
10/22/19 23:00	1			0			48											
10/23/19 0:00	1			0			43											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/23/19 1:00	1			0			38												
10/23/19 2:00	1			0			37												
10/23/19 3:00	1			0			37												
10/23/19 4:00	1			0			38												
10/23/19 5:00	1			0			39												
10/23/19 6:00	1			0			43												
10/23/19 7:00	1			0			50												
10/23/19 8:00	1			0			60												
10/23/19 9:00	1			0			68												
10/23/19 10:00	1			0			70												
10/23/19 11:00	1			0			68												
10/23/19 12:00	1			0			66												
10/23/19 13:00	1			0			63												
10/23/19 14:00	1			0			61												
10/23/19 15:00	1			0			61												
10/23/19 16:00	1			0			61												
10/23/19 17:00	1			0			65												
10/23/19 18:00	1			0			66												
10/23/19 19:00	1			0			63												
10/23/19 20:00	1			0			57												
10/23/19 21:00	1			0			56												
10/23/19 22:00	1			0			53												
10/23/19 23:00	1			0			50												
10/24/19 0:00	1			0			43												
10/24/19 1:00	1			0			41												
10/24/19 2:00	1			0			40												
10/24/19 3:00	1			0			40												
10/24/19 4:00	1			0			43												
10/24/19 5:00	1			0			51												
10/24/19 6:00	1			0			60												
10/24/19 7:00	1			0			63												
10/24/19 8:00	1			0			58												
10/24/19 9:00	1			0			50												
10/24/19 10:00	1			0			45												
10/24/19 11:00	1			0			42												
10/24/19 12:00	1			0			41												
10/24/19 13:00	1			3			41												
10/24/19 14:00	1			15			38												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/24/19 15:00	1			28			38												
10/24/19 16:00	1			44			44												
10/24/19 17:00	1			54			54												
10/24/19 18:00	1			61			59												
10/24/19 19:00	1			67			41												
10/24/19 20:00	1			65			20												
10/24/19 21:00	1			65			2												
10/24/19 22:00	1			63			0												
10/24/19 23:00	1			59			0												
10/25/19 0:00	1			52			0												
10/25/19 1:00	1			44			0												
10/25/19 2:00	1			43			0												
10/25/19 3:00	1			43			0												
10/25/19 4:00	1			43			0												
10/25/19 5:00	1			42			0												
10/25/19 6:00	1			48			0												
10/25/19 7:00	1			52			0												
10/25/19 8:00	1			55			0												
10/25/19 9:00	1			51			0												
10/25/19 10:00	1			48			0												
10/25/19 11:00	1			48			0												
10/25/19 12:00	1			50			0												
10/25/19 13:00	1			51			3												
10/25/19 14:00	1			48			16												
10/25/19 15:00	1			44			30												
10/25/19 16:00	1			46			46												
10/25/19 17:00	1			51			53												
10/25/19 18:00	1			52			52												
10/25/19 19:00	1			56			33												
10/25/19 20:00	1			60			13												
10/25/19 21:00	1			68			0												
10/25/19 22:00	1			69			0												
10/25/19 23:00	1			60			0												
10/26/19 0:00	1			51			0												
10/26/19 1:00	1			41			0												
10/26/19 2:00	1			40			0												
10/26/19 3:00	1			40			0												
10/26/19 4:00	1			40			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/26/19 5:00	1			41			0												
10/26/19 6:00	1			42			0												
10/26/19 7:00	1			42			0												
10/26/19 8:00	1			42			0												
10/26/19 9:00	1			41			0												
10/26/19 10:00	1			40			0												
10/26/19 11:00	1			40			0												
10/26/19 12:00	1			41			0												
10/26/19 13:00	1			43			0												
10/26/19 14:00	1			43			0												
10/26/19 15:00	1			41			0												
10/26/19 16:00	1			39			0												
10/26/19 17:00	1			40			0												
10/26/19 18:00	1			41			0												
10/26/19 19:00	1			43			0												
10/26/19 20:00	1			41			0												
10/26/19 21:00	1			41			0												
10/26/19 22:00	1			40			0												
10/26/19 23:00	1			40			0												
10/27/19 0:00	1			42			0												
10/27/19 1:00	1			43			0												
10/27/19 2:00	1			45			0												
10/27/19 3:00	1			45			0												
10/27/19 4:00	1			48			0												
10/27/19 5:00	1			48			0												
10/27/19 6:00	1			48			0												
10/27/19 7:00	1			48			0												
10/27/19 8:00	1			49			0												
10/27/19 9:00	1			46			0												
10/27/19 10:00	1			42			0												
10/27/19 11:00	1			38			0												
10/27/19 12:00	1			37			0												
10/27/19 13:00	1			37			0												
10/27/19 14:00	1			37			0												
10/27/19 15:00	1			40			0												
10/27/19 16:00	1			42			0												
10/27/19 17:00	1			44			0												
10/27/19 18:00	1			43			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/19 19:00	1			41			0											
10/27/19 20:00	1			41			0											
10/27/19 21:00	1			42			0											
10/27/19 22:00	1			43			0											
10/27/19 23:00	1			43			0											
10/28/19 0:00	1			41			0											
10/28/19 1:00	1			40			0											
10/28/19 2:00	1			40			0											
10/28/19 3:00	1			40			0											
10/28/19 4:00	1			48			0											
10/28/19 5:00	1			56			0											
10/28/19 6:00	1			66			0											
10/28/19 7:00	1			69			0											
10/28/19 8:00	1			65			0											
10/28/19 9:00	1			59			0											
10/28/19 10:00	1			53			0											
10/28/19 11:00	1			54			0											
10/28/19 12:00	1			52			0											
10/28/19 13:00	1			50			0											
10/28/19 14:00	1			47			0											
10/28/19 15:00	1			48			0											
10/28/19 16:00	1			49			0											
10/28/19 17:00	1			46			0											
10/28/19 18:00	1			49			0											
10/28/19 19:00	1			52			0											
10/28/19 20:00	1			55			0											
10/28/19 21:00	1			55			0											
10/28/19 22:00	1			56			0											
10/28/19 23:00	1			58			0											
10/29/19 0:00	1			53			0											
10/29/19 1:00	1			47			0											
10/29/19 2:00	1			42			0											
10/29/19 3:00	1			44			0											
10/29/19 4:00	1			53			1											
10/29/19 5:00	1			66			1											
10/29/19 6:00	1			77			1											
10/29/19 7:00	1			80			0											
10/29/19 8:00	1			80			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/29/19 9:00	1			79			0												
10/29/19 10:00	1			78			0												
10/29/19 11:00	1			77			1												
10/29/19 12:00	1			77			0												
10/29/19 13:00	1			76			0												
10/29/19 14:00	1			74			0												
10/29/19 15:00	1			74			0												
10/29/19 16:00	1			72			0												
10/29/19 17:00	1			72			0												
10/29/19 18:00	1			70			0												
10/29/19 19:00	1			68			0												
10/29/19 20:00	1			68			0												
10/29/19 21:00	1			69			0												
10/29/19 22:00	1			70			0												
10/29/19 23:00	1			65			0												
10/30/19 0:00	1			56			0												
10/30/19 1:00	1			47			0												
10/30/19 2:00	1			43			0												
10/30/19 3:00	1			47			0												
10/30/19 4:00	1			56			0												
10/30/19 5:00	1			63			0												
10/30/19 6:00	1			68			0												
10/30/19 7:00	1			63			8												
10/30/19 8:00	1			53			21												
10/30/19 9:00	1			44			34												
10/30/19 10:00	1			39			39												
10/30/19 11:00	1			40			38												
10/30/19 12:00	1			48			25												
10/30/19 13:00	1			56			12												
10/30/19 14:00	1			65			0												
10/30/19 15:00	1			69			0												
10/30/19 16:00	1			70			0												
10/30/19 17:00	1			69			0												
10/30/19 18:00	1			66			0												
10/30/19 19:00	1			66			0												
10/30/19 20:00	1			65			0												
10/30/19 21:00	1			64			0												
10/30/19 22:00	1			62			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
10/30/19 23:00	1			58			0												
10/31/19 0:00	1			52			0												
10/31/19 1:00	1			47			0												
10/31/19 2:00	1			44			0												
10/31/19 3:00	1			46			0												
10/31/19 4:00	1			53			0												
10/31/19 5:00	1			62			0												
10/31/19 6:00	1			71			0												
10/31/19 7:00	1			75			0												
10/31/19 8:00	1			78			0												
10/31/19 9:00	1			78			0												
10/31/19 10:00	1			76			0												
10/31/19 11:00	1			74			0												
10/31/19 12:00	1			70			0												
10/31/19 13:00	1			71			0												
10/31/19 14:00	1			72			0												
10/31/19 15:00	1			74			0												
10/31/19 16:00	1			75			0												
10/31/19 17:00	1			76			0												
10/31/19 18:00	1			77			0												
10/31/19 19:00	1			72			0												
10/31/19 20:00	1			66			0												
10/31/19 21:00	1			61			0												
10/31/19 22:00	1			57			0												
10/31/19 23:00	1			50			0												
11/01/19 0:00	1			42			0												
11/01/19 1:00	1			38			0												
11/01/19 2:00	1			38			0												
11/01/19 3:00	1			43			0												
11/01/19 4:00	1			53			0												
11/01/19 5:00	1			63			0												
11/01/19 6:00	1			71			0												
11/01/19 7:00	1			71			0												
11/01/19 8:00	1			69			0												
11/01/19 9:00	1			66			0												
11/01/19 10:00	1			67			0												
11/01/19 11:00	1			65			0												
11/01/19 12:00	1			62			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/01/19 13:00	1			58			0												
11/01/19 14:00	1			58			0												
11/01/19 15:00	1			60			0												
11/01/19 16:00	1			61			0												
11/01/19 17:00	1			62			0												
11/01/19 18:00	1			59			0												
11/01/19 19:00	1			58			0												
11/01/19 20:00	1			56			0												
11/01/19 21:00	1			59			0												
11/01/19 22:00	1			64			0												
11/01/19 23:00	1			67			0												
11/02/19 0:00	1			63			0												
11/02/19 1:00	1			56			0												
11/02/19 2:00	1			50			0												
11/02/19 3:00	1			47			0												
11/02/19 4:00	1			50			0												
11/02/19 5:00	1			55			0												
11/02/19 6:00	1			63			0												
11/02/19 7:00	1			62			0												
11/02/19 8:00	1			57			0												
11/02/19 9:00	1			46			0												
11/02/19 10:00	1			41			0												
11/02/19 11:00	1			37			0												
11/02/19 12:00	1			38			0												
11/02/19 13:00	1			40			0												
11/02/19 14:00	1			44			0												
11/02/19 15:00	1			56			0												
11/02/19 16:00	1			62			0												
11/02/19 17:00	1			71			0												
11/02/19 18:00	1			64			0												
11/02/19 19:00	1			61			0												
11/02/19 20:00	1			56			0												
11/02/19 21:00	1			60			0												
11/02/19 22:00	1			64			0												
11/02/19 23:00	1			59			0												
11/03/19 0:00	1			49			0												
11/03/19 1:00	1			41			0												
11/03/19 2:00	1			40			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/19 3:00	1			40			0											
11/03/19 4:00	1			40			0											
11/03/19 5:00	1			41			0											
11/03/19 6:00	1			41			0											
11/03/19 7:00	1			43			0											
11/03/19 8:00	1			45			0											
11/03/19 9:00	1			51			0											
11/03/19 10:00	1			57			0											
11/03/19 11:00	1			62			0											
11/03/19 12:00	1			63			0											
11/03/19 13:00	1			65			0											
11/03/19 14:00	1			64			0											
11/03/19 15:00	1			67			0											
11/03/19 16:00	1			68			0											
11/03/19 17:00	1			62			0											
11/03/19 18:00	1			53			0											
11/03/19 19:00	1			42			0											
11/03/19 20:00	1			38			0											
11/03/19 21:00	1			37			0											
11/03/19 22:00	1			41			0											
11/03/19 23:00	1			42			0											
11/04/19 0:00	1			42			0											
11/04/19 1:00	1			39			0											
11/04/19 2:00	1			39			0											
11/04/19 3:00	1			39			0											
11/04/19 4:00	1			39			0											
11/04/19 5:00	1			42			0											
11/04/19 6:00	1			46			0											
11/04/19 7:00	1			51			0											
11/04/19 8:00	1			59			0											
11/04/19 9:00	1			68			0											
11/04/19 10:00	1			75			0											
11/04/19 11:00	1			76			0											
11/04/19 12:00	1			74			0											
11/04/19 13:00	1			72			0											
11/04/19 14:00	1			70			0											
11/04/19 15:00	1			70			0											
11/04/19 16:00	1			69			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/04/19 17:00	1			66			0												
11/04/19 18:00	1			61			0												
11/04/19 19:00	1			54			0												
11/04/19 20:00	1			48			0												
11/04/19 21:00	1			46			0												
11/04/19 22:00	1			46			0												
11/04/19 23:00	1			44			0												
11/05/19 0:00	1			41			0												
11/05/19 1:00	1			38			0												
11/05/19 2:00	1			39			0												
11/05/19 3:00	1			39			0												
11/05/19 4:00	1			40			0												
11/05/19 5:00	1			43			0												
11/05/19 6:00	1			53			0												
11/05/19 7:00	1			62			0												
11/05/19 8:00	1			68			0												
11/05/19 9:00	1			68			0												
11/05/19 10:00	1			67			0												
11/05/19 11:00	1			65			0												
11/05/19 12:00	1			62			0												
11/05/19 13:00	1			61			3												
11/05/19 14:00	1			54			17												
11/05/19 15:00	1			54			37												
11/05/19 16:00	1			52			51												
11/05/19 17:00	1			51			51												
11/05/19 18:00	1			45			45												
11/05/19 19:00	1			40			40												
11/05/19 20:00	1			40			40												
11/05/19 21:00	1			40			40												
11/05/19 22:00	1			40			41												
11/05/19 23:00	1			40			41												
11/06/19 0:00	1			39			42												
11/06/19 1:00	1			39			43												
11/06/19 2:00	1			38			44												
11/06/19 3:00	1			38			45												
11/06/19 4:00	1			37			46												
11/06/19 5:00	1			37			47												
11/06/19 6:00	1			41			48												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/06/19 7:00	1			46			50												
11/06/19 8:00	1			49			50												
11/06/19 9:00	1			48			49												
11/06/19 10:00	1			46			49												
11/06/19 11:00	1			48			50												
11/06/19 12:00	1			50			51												
11/06/19 13:00	1			52			52												
11/06/19 14:00	1			54			56												
11/06/19 15:00	1			59			60												
11/06/19 16:00	1			64			63												
11/06/19 17:00	1			71			69												
11/06/19 18:00	1			74			72												
11/06/19 19:00	1			77			75												
11/06/19 20:00	1			78			76												
11/06/19 21:00	1			75			74												
11/06/19 22:00	1			66			65												
11/06/19 23:00	1			54			52												
11/07/19 0:00	1			54			29												
11/07/19 1:00	1			60			13												
11/07/19 2:00	1			69			0												
11/07/19 3:00	1			67			0												
11/07/19 4:00	1			67			0												
11/07/19 5:00	1			70			0												
11/07/19 6:00	1			73			0												
11/07/19 7:00	1			76			0												
11/07/19 8:00	1			74			0												
11/07/19 9:00	1			72			0												
11/07/19 10:00	1			68			3												
11/07/19 11:00	1			59			16												
11/07/19 12:00	1			49			29												
11/07/19 13:00	1			40			39												
11/07/19 14:00	1			39			39												
11/07/19 15:00	1			40			40												
11/07/19 16:00	1			46			46												
11/07/19 17:00	1			53			53												
11/07/19 18:00	1			60			60												
11/07/19 19:00	1			62			60												
11/07/19 20:00	1			60			56												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:00	1			63			43											
11/07/19 22:00	1			68			24											
11/07/19 23:00	1			73			7											
11/08/19 0:00	1			71			0											
11/08/19 1:00	1			66			0											
11/08/19 2:00	1			64			0											
11/08/19 3:00	1			62			0											
11/08/19 4:00	1			62			0											
11/08/19 5:00	1			66			0											
11/08/19 6:00	1			68			0											
11/08/19 7:00	1			73			0											
11/08/19 8:00	1			72			0											
11/08/19 9:00	1			70			3											
11/08/19 10:00	1			58			16											
11/08/19 11:00	1			49			29											
11/08/19 12:00	1			40			40											
11/08/19 13:00	1			40			41											
11/08/19 14:00	1			40			43											
11/08/19 15:00	1			48			49											
11/08/19 16:00	1			55			56											
11/08/19 17:00	1			66			65											
11/08/19 18:00	1			71			70											
11/08/19 19:00	1			75			73											
11/08/19 20:00	1			63			63											
11/08/19 21:00	1			51			51											
11/08/19 22:00	1			38			41											
11/08/19 23:00	1			38			39											
11/09/19 0:00	1			39			27											
11/09/19 1:00	1			39			13											
11/09/19 2:00	1			38			1											
11/09/19 3:00	1			36			0											
11/09/19 4:00	1			36			0											
11/09/19 5:00	1			38			0											
11/09/19 6:00	1			40			0											
11/09/19 7:00	1			44			0											
11/09/19 8:00	1			44			0											
11/09/19 9:00	1			43			0											
11/09/19 10:00	1			41			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/19 11:00	1			40			0											
11/09/19 12:00	1			40			0											
11/09/19 13:00	1			40			0											
11/09/19 14:00	1			40			0											
11/09/19 15:00	1			46			0											
11/09/19 16:00	1			54			0											
11/09/19 17:00	1			62			0											
11/09/19 18:00	1			65			0											
11/09/19 19:00	1			64			0											
11/09/19 20:00	1			59			0											
11/09/19 21:00	1			55			0											
11/09/19 22:00	1			55			0											
11/09/19 23:00	1			55			0											
11/10/19 0:00	1			53			0											
11/10/19 1:00	1			46			0											
11/10/19 2:00	1			41			0											
11/10/19 3:00	1			38			0											
11/10/19 4:00	1			38			0											
11/10/19 5:00	1			38			0											
11/10/19 6:00	1			40			0											
11/10/19 7:00	1			42			0											
11/10/19 8:00	1			43			0											
11/10/19 9:00	1			44			0											
11/10/19 10:00	1			42			0											
11/10/19 11:00	1			43			0											
11/10/19 12:00	1			43			0											
11/10/19 13:00	1			43			0											
11/10/19 14:00	1			43			0											
11/10/19 15:00	1			47			0											
11/10/19 16:00	1			50			0											
11/10/19 17:00	1			57			0											
11/10/19 18:00	1			59			0											
11/10/19 19:00	1			61			0											
11/10/19 20:00	1			55			0											
11/10/19 21:00	1			50			0											
11/10/19 22:00	1			50			0											
11/10/19 23:00	1			50			0											
11/11/19 0:00	1			49			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/11/19 1:00	1			45			0												
11/11/19 2:00	1			43			0												
11/11/19 3:00	1			42			0												
11/11/19 4:00	1			43			0												
11/11/19 5:00	1			47			0												
11/11/19 6:00	1			52			0												
11/11/19 7:00	1			57			0												
11/11/19 8:00	1			54			0												
11/11/19 9:00	1			49			0												
11/11/19 10:00	1			42			0												
11/11/19 11:00	1			40			0												
11/11/19 12:00	1			41			0												
11/11/19 13:00	1			44			0												
11/11/19 14:00	1			50			0												
11/11/19 15:00	1			54			0												
11/11/19 16:00	1			61			0												
11/11/19 17:00	1			65			0												
11/11/19 18:00	1			69			0												
11/11/19 19:00	1			69			0												
11/11/19 20:00	1			59			0												
11/11/19 21:00	1			51			0												
11/11/19 22:00	1			43			0												
11/11/19 23:00	1			42			6												
11/12/19 0:00	1			35			19												
11/12/19 1:00	1			20			32												
11/12/19 2:00	1			8			39												
11/12/19 3:00	1			0			39												
11/12/19 4:00	1			0			40												
11/12/19 5:00	1			0			45												
11/12/19 6:00	1			0			54												
11/12/19 7:00	1			0			61												
11/12/19 8:00	1			0			57												
11/12/19 9:00	1			0			52												
11/12/19 10:00	1			0			48												
11/12/19 11:00	1			0			50												
11/12/19 12:00	1			0			52												
11/12/19 13:00	1			0			51												
11/12/19 14:00	1			0			53												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 15:00	1			0			51											
11/12/19 16:00	1			0			55											
11/12/19 17:00	1			0			58											
11/12/19 18:00	1			0			64											
11/12/19 19:00	1			0			67											
11/12/19 20:00	1			0			61											
11/12/19 21:00	1			0			57											
11/12/19 22:00	1			0			53											
11/12/19 23:00	1			0			53											
11/13/19 0:00	1			0			56											
11/13/19 1:00	1			0			58											
11/13/19 2:00	1			0			62											
11/13/19 3:00	1			0			61											
11/13/19 4:00	1			0			61											
11/13/19 5:00	1			0			64											
11/13/19 6:00	1			3			67											
11/13/19 7:00	1			17			61											
11/13/19 8:00	1			33			54											
11/13/19 9:00	1			46			48											
11/13/19 10:00	1			48			51											
11/13/19 11:00	1			48			52											
11/13/19 12:00	1			48			53											
11/13/19 13:00	1			48			54											
11/13/19 14:00	1			49			56											
11/13/19 15:00	1			52			58											
11/13/19 16:00	1			56			60											
11/13/19 17:00	1			58			60											
11/13/19 18:00	1			58			60											
11/13/19 19:00	1			58			60											
11/13/19 20:00	1			58			60											
11/13/19 21:00	1			51			53											
11/13/19 22:00	1			45			46											
11/13/19 23:00	1			38			39											
11/14/19 0:00	1			38			38											
11/14/19 1:00	1			37			37											
11/14/19 2:00	1			37			36											
11/14/19 3:00	1			37			36											
11/14/19 4:00	1			37			36											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 5:00	1			37			36											
11/14/19 6:00	1			44			44											
11/14/19 7:00	1			46			47											
11/14/19 8:00	1			49			52											
11/14/19 9:00	1			46			50											
11/14/19 10:00	1			48			53											
11/14/19 11:00	1			49			56											
11/14/19 12:00	1			49			57											
11/14/19 13:00	1			49			59											
11/14/19 14:00	1			49			59											
11/14/19 15:00	1			52			60											
11/14/19 16:00	1			55			60											
11/14/19 17:00	1			58			60											
11/14/19 18:00	1			57			60											
11/14/19 19:00	1			57			61											
11/14/19 20:00	1			56			61											
11/14/19 21:00	1			50			54											
11/14/19 22:00	1			44			47											
11/14/19 23:00	1			38			39											
11/15/19 0:00	1			25			32											
11/15/19 1:00	0			12			19											
11/15/19 2:00	0			0			6											
11/15/19 3:00	0			0			0											
11/15/19 4:00	0			0			0											
11/15/19 5:00	0			0			0											
11/15/19 6:00	0			0			0											
11/15/19 7:00	0			0			0											
11/15/19 8:00	0			0			0											
11/15/19 9:00	0			0			0											
11/15/19 10:00	0			0			0											
11/15/19 11:00	0			0			0											
11/15/19 12:00	0			0			0											
11/15/19 13:00	0			0			0											
11/15/19 14:00	0			0			0											
11/15/19 15:00	0			0			0											
11/15/19 16:00	0			0			0											
11/15/19 17:00	0			0			0											
11/15/19 18:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/15/19 19:00	0			0			0												
11/15/19 20:00	0			0			0												
11/15/19 21:00	0			0			0												
11/15/19 22:00	0			0			0												
11/15/19 23:00	0			0			0												
11/16/19 0:00	0			0			0												
11/16/19 1:00	0			0			0												
11/16/19 2:00	0			0			0												
11/16/19 3:00	0			0			0												
11/16/19 4:00	0			0			0												
11/16/19 5:00	0			0			0												
11/16/19 6:00	0			0			0												
11/16/19 7:00	0			0			0												
11/16/19 8:00	0			0			0												
11/16/19 9:00	0			0			0												
11/16/19 10:00	0			0			0												
11/16/19 11:00	0			0			0												
11/16/19 12:00	0			0			0												
11/16/19 13:00	0			0			0												
11/16/19 14:00	0			0			0												
11/16/19 15:00	0			0			0												
11/16/19 16:00	0			0			0												
11/16/19 17:00	0			0			0												
11/16/19 18:00	0			0			0												
11/16/19 19:00	0			0			0												
11/16/19 20:00	0			0			0												
11/16/19 21:00	0			0			0												
11/16/19 22:00	0			0			0												
11/16/19 23:00	0			0			0												
11/17/19 0:00	0			0			0												
11/17/19 1:00	0			0			0												
11/17/19 2:00	0			0			0												
11/17/19 3:00	0			0			0												
11/17/19 4:00	0			0			0												
11/17/19 5:00	0			0			0												
11/17/19 6:00	0			0			0												
11/17/19 7:00	0			0			0												
11/17/19 8:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/17/19 9:00	0			0			0												
11/17/19 10:00	0			0			0												
11/17/19 11:00	0			0			0												
11/17/19 12:00	0			0			0												
11/17/19 13:00	0			0			0												
11/17/19 14:00	0			0			0												
11/17/19 15:00	0			0			0												
11/17/19 16:00	0			0			0												
11/17/19 17:00	0			0			0												
11/17/19 18:00	0			0			0												
11/17/19 19:00	0			0			0												
11/17/19 20:00	0			0			0												
11/17/19 21:00	0			0			0												
11/17/19 22:00	0			0			0												
11/18/19 0:00	0			0			0												
11/18/19 1:00	0			0			0												
11/18/19 2:00	0			0			0												
11/18/19 3:00	0			0			0												
11/18/19 4:00	0			0			0												
11/18/19 5:00	0			0			0												
11/18/19 6:00	0			0			0												
11/18/19 7:00	0			0			0												
11/18/19 8:00	0			0			0												
11/18/19 9:00	0			0			0												
11/18/19 10:00	0			0			0												
11/18/19 11:00	0			0			0												
11/18/19 12:00	0			0			0												
11/18/19 13:00	0			0			0												
11/18/19 14:00	0			0			0												
11/18/19 15:00	0			0			0												
11/18/19 16:00	0			0			0												
11/18/19 17:00	0			0			0												
11/18/19 18:00	0			0			0												
11/18/19 19:00	0			0			0												
11/18/19 20:00	0			0			0												
11/18/19 21:00	0			0			0												
11/18/19 22:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/18/19 23:00	0			0			0												
11/19/19 0:00	0			0			0												
11/19/19 1:00	0			0			0												
11/19/19 2:00	0			0			0												
11/19/19 3:00	0			0			0												
11/19/19 4:00	0			0			0												
11/19/19 5:00	0			0			0												
11/19/19 6:00	0			0			0												
11/19/19 7:00	0			0			0												
11/19/19 8:00	0			0			0												
11/19/19 9:00	0			0			0												
11/19/19 10:00	0			0			0												
11/19/19 11:00	0			0			0												
11/19/19 12:00	0			0			0												
11/19/19 13:00	0			0			0												
11/19/19 14:00	0			0			0												
11/19/19 15:00	0			0			0												
11/19/19 16:00	0			0			0												
11/19/19 17:00	0			0			0												
11/19/19 18:00	0			0			0												
11/19/19 19:00	0			0			0												
11/19/19 20:00	0			0			0												
11/19/19 21:00	0			0			0												
11/19/19 22:00	0			0			0												
11/19/19 23:00	0			0			0												
11/20/19 0:00	0			0			0												
11/20/19 1:00	0			0			0												
11/20/19 2:00	0			0			0												
11/20/19 3:00	1			0			3												
11/20/19 4:00	1			0			16												
11/20/19 5:00	1			0			29												
11/20/19 6:00	1			0			40												
11/20/19 7:00	1			0			32												
11/20/19 8:00	0			0			18												
11/20/19 9:00	0			0			4												
11/20/19 10:00	0			0			0												
11/20/19 11:00	0			0			0												
11/20/19 12:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/20/19 13:00	0			0			0												
11/20/19 14:00	0			0			0												
11/20/19 15:00	0			0			0												
11/20/19 16:00	0			0			0												
11/20/19 17:00	0			0			0												
11/20/19 18:00	0			0			0												
11/20/19 19:00	0			0			0												
11/20/19 20:00	0			0			0												
11/20/19 21:00	0			0			0												
11/20/19 22:00	0			0			0												
11/20/19 23:00	0			0			0												
11/21/19 0:00	0			0			0												
11/21/19 1:00	0			0			0												
11/21/19 2:00	0			0			0												
11/21/19 3:00	0			0			0												
11/21/19 4:00	0			0			0												
11/21/19 5:00	1			3			0												
11/21/19 6:00	1			16			2												
11/21/19 7:00	1			30			15												
11/21/19 8:00	1			44			32												
11/21/19 9:00	1			47			46												
11/21/19 10:00	1			50			50												
11/21/19 11:00	1			50			50												
11/21/19 12:00	1			49			51												
11/21/19 13:00	1			49			52												
11/21/19 14:00	1			49			53												
11/21/19 15:00	1			51			55												
11/21/19 16:00	1			54			57												
11/21/19 17:00	1			58			59												
11/21/19 18:00	1			58			60												
11/21/19 19:00	1			57			60												
11/21/19 20:00	1			56			61												
11/21/19 21:00	1			57			60												
11/21/19 22:00	1			51			52												
11/21/19 23:00	1			45			44												
11/22/19 0:00	1			38			37												
11/22/19 1:00	1			37			37												
11/22/19 2:00	1			38			37												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/22/19 3:00	1			38			37												
11/22/19 4:00	1			38			37												
11/22/19 5:00	1			39			38												
11/22/19 6:00	1			43			42												
11/22/19 7:00	1			46			45												
11/22/19 8:00	1			49			49												
11/22/19 9:00	1			49			50												
11/22/19 10:00	1			50			52												
11/22/19 11:00	1			50			53												
11/22/19 12:00	1			50			54												
11/22/19 13:00	1			52			55												
11/22/19 14:00	1			53			55												
11/22/19 15:00	1			56			56												
11/22/19 16:00	1			64			63												
11/22/19 17:00	1			71			70												
11/22/19 18:00	1			77			75												
11/22/19 19:00	1			77			75												
11/22/19 20:00	1			77			75												
11/22/19 21:00	1			71			69												
11/22/19 22:00	1			65			64												
11/22/19 23:00	1			59			58												
11/23/19 0:00	1			39			45												
11/23/19 1:00	0			19			25												
11/23/19 2:00	0			0			6												
11/23/19 3:00	0			0			0												
11/23/19 4:00	0			0			0												
11/23/19 5:00	0			0			0												
11/23/19 6:00	0			0			0												
11/23/19 7:00	0			0			0												
11/23/19 8:00	0			0			0												
11/23/19 9:00	0			0			0												
11/23/19 10:00	0			0			0												
11/23/19 11:00	0			0			0												
11/23/19 12:00	0			0			0												
11/23/19 13:00	0			0			0												
11/23/19 14:00	0			0			0												
11/23/19 15:00	0			0			0												
11/23/19 16:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/23/19 17:00	0			0			0												
11/23/19 18:00	0			0			0												
11/23/19 19:00	0			0			0												
11/23/19 20:00	0			0			0												
11/23/19 21:00	0			0			0												
11/23/19 22:00	0			0			0												
11/23/19 23:00	0			0			0												
11/24/19 0:00	0			0			0												
11/24/19 1:00	0			0			0												
11/24/19 2:00	0			0			0												
11/24/19 3:00	0			0			0												
11/24/19 4:00	0			0			0												
11/24/19 5:00	0			0			0												
11/24/19 6:00	0			0			0												
11/24/19 7:00	0			0			0												
11/24/19 8:00	0			0			0												
11/24/19 9:00	0			0			0												
11/24/19 10:00	0			0			0												
11/24/19 11:00	0			0			0												
11/24/19 12:00	0			0			0												
11/24/19 13:00	0			0			0												
11/24/19 14:00	0			0			0												
11/24/19 15:00	0			0			0												
11/24/19 16:00	0			0			0												
11/24/19 17:00	0			0			0												
11/24/19 18:00	0			0			0												
11/24/19 19:00	0			0			0												
11/24/19 20:00	0			0			0												
11/24/19 21:00	0			0			0												
11/24/19 22:00	0			0			0												
11/24/19 23:00	0			0			0												
11/25/19 0:00	0			0			0												
11/25/19 1:00	0			0			0												
11/25/19 2:00	0			0			0												
11/25/19 3:00	0			0			0												
11/25/19 4:00	0			0			0												
11/25/19 5:00	0			0			0												
11/25/19 6:00	0			0			0												

ALL_UnitOn_TF_1H CT1_Load_Total_3Hr_MWe_1H CT2_Load_Total_3Hr_MWe_1H

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/19 7:00	0			0			0											
11/25/19 8:00	0			0			0											
11/25/19 9:00	0			0			0											
11/25/19 10:00	0			0			0											
11/25/19 11:00	0			0			0											
11/25/19 12:00	0			0			0											
11/25/19 13:00	0			0			0											
11/25/19 14:00	0			0			0											
11/25/19 15:00	0			0			0											
11/25/19 16:00	0			0			0											
11/25/19 17:00	0			0			0											
11/25/19 18:00	0			0			0											
11/25/19 19:00	0			0			0											
11/25/19 20:00	0			0			0											
11/25/19 21:00	0			0			0											
11/25/19 22:00	0			0			0											
11/25/19 23:00	0			0			0											
11/26/19 0:00	0			0			0											
11/26/19 1:00	0			0			0											
11/26/19 2:00	0			0			0											
11/26/19 3:00	1			0			2											
11/26/19 4:00	1			0			11											
11/26/19 5:00	1			0			24											
11/26/19 6:00	1			11			37											
11/26/19 7:00	1			28			45											
11/26/19 8:00	1			47			50											
11/26/19 9:00	1			54			55											
11/26/19 10:00	1			56			57											
11/26/19 11:00	1			57			59											
11/26/19 12:00	1			57			60											
11/26/19 13:00	1			57			60											
11/26/19 14:00	1			58			59											
11/26/19 15:00	1			59			58											
11/26/19 16:00	1			62			60											
11/26/19 17:00	1			68			66											
11/26/19 18:00	1			73			72											
11/26/19 19:00	1			72			70											
11/26/19 20:00	1			66			63											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 21:00	1			61			57											
11/26/19 22:00	1			57			53											
11/26/19 23:00	1			51			48											
11/27/19 0:00	1			44			42											
11/27/19 1:00	1			40			38											
11/27/19 2:00	1			38			37											
11/27/19 3:00	1			37			36											
11/27/19 4:00	1			37			37											
11/27/19 5:00	1			39			39											
11/27/19 6:00	1			46			47											
11/27/19 7:00	1			49			51											
11/27/19 8:00	1			52			55											
11/27/19 9:00	1			50			54											
11/27/19 10:00	1			52			57											
11/27/19 11:00	1			54			59											
11/27/19 12:00	1			54			60											
11/27/19 13:00	1			53			59											
11/27/19 14:00	1			52			58											
11/27/19 15:00	1			50			58											
11/27/19 16:00	1			51			58											
11/27/19 17:00	1			59			63											
11/27/19 18:00	1			63			65											
11/27/19 19:00	1			64			64											
11/27/19 20:00	1			58			59											
11/27/19 21:00	1			55			57											
11/27/19 22:00	1			51			54											
11/27/19 23:00	1			45			49											
11/28/19 0:00	1			40			45											
11/28/19 1:00	1			37			42											
11/28/19 2:00	1			37			39											
11/28/19 3:00	1			37			36											
11/28/19 4:00	1			37			36											
11/28/19 5:00	1			38			38											
11/28/19 6:00	1			40			41											
11/28/19 7:00	1			41			43											
11/28/19 8:00	1			44			45											
11/28/19 9:00	1			48			47											
11/28/19 10:00	1			51			50											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/28/19 11:00	1			51			52												
11/28/19 12:00	1			51			53												
11/28/19 13:00	1			49			52												
11/28/19 14:00	1			46			51												
11/28/19 15:00	1			44			50												
11/28/19 16:00	1			41			47												
11/28/19 17:00	1			45			49												
11/28/19 18:00	1			49			51												
11/28/19 19:00	1			49			50												
11/28/19 20:00	1			47			48												
11/28/19 21:00	1			45			46												
11/28/19 22:00	1			47			49												
11/28/19 23:00	1			43			45												
11/29/19 0:00	1			39			43												
11/29/19 1:00	1			37			41												
11/29/19 2:00	1			37			42												
11/29/19 3:00	1			37			42												
11/29/19 4:00	1			37			42												
11/29/19 5:00	1			38			43												
11/29/19 6:00	1			39			45												
11/29/19 7:00	1			41			48												
11/29/19 8:00	1			42			50												
11/29/19 9:00	1			45			51												
11/29/19 10:00	1			48			51												
11/29/19 11:00	1			50			51												
11/29/19 12:00	1			49			51												
11/29/19 13:00	1			47			50												
11/29/19 14:00	1			46			50												
11/29/19 15:00	1			45			50												
11/29/19 16:00	1			43			47												
11/29/19 17:00	1			52			53												
11/29/19 18:00	1			62			61												
11/29/19 19:00	1			73			71												
11/29/19 20:00	1			68			67												
11/29/19 21:00	1			61			61												
11/29/19 22:00	1			53			53												
11/29/19 23:00	1			47			48												
11/30/19 0:00	1			42			44												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
11/30/19 1:00	1			38			40												
11/30/19 2:00	1			37			38												
11/30/19 3:00	1			37			36												
11/30/19 4:00	1			37			37												
11/30/19 5:00	1			38			38												
11/30/19 6:00	1			39			40												
11/30/19 7:00	1			41			42												
11/30/19 8:00	1			45			45												
11/30/19 9:00	1			49			49												
11/30/19 10:00	1			52			53												
11/30/19 11:00	1			53			55												
11/30/19 12:00	1			52			56												
11/30/19 13:00	1			52			57												
11/30/19 14:00	1			52			58												
11/30/19 15:00	1			52			58												
11/30/19 16:00	1			48			53												
11/30/19 17:00	1			56			59												
11/30/19 18:00	1			60			59												
11/30/19 19:00	1			64			59												
11/30/19 20:00	1			59			51												
11/30/19 21:00	1			57			48												
11/30/19 22:00	1			57			49												
11/30/19 23:00	1			52			45												
12/01/19 0:00	1			47			40												
12/01/19 1:00	1			43			37												
12/01/19 2:00	1			39			36												
12/01/19 3:00	1			37			36												
12/01/19 4:00	1			37			36												
12/01/19 5:00	1			37			36												
12/01/19 6:00	1			38			37												
12/01/19 7:00	1			39			39												
12/01/19 8:00	1			40			41												
12/01/19 9:00	1			40			43												
12/01/19 10:00	1			41			43												
12/01/19 11:00	1			42			44												
12/01/19 12:00	1			43			44												
12/01/19 13:00	1			43			44												
12/01/19 14:00	1			44			46												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/19 15:00	1			48			49											
12/01/19 16:00	1			48			49											
12/01/19 17:00	1			56			57											
12/01/19 18:00	1			64			63											
12/01/19 19:00	1			71			69											
12/01/19 20:00	1			69			66											
12/01/19 21:00	1			63			60											
12/01/19 22:00	1			58			55											
12/01/19 23:00	1			51			49											
12/02/19 0:00	1			44			43											
12/02/19 1:00	1			41			40											
12/02/19 2:00	1			38			38											
12/02/19 3:00	1			37			36											
12/02/19 4:00	1			37			36											
12/02/19 5:00	1			39			38											
12/02/19 6:00	1			47			46											
12/02/19 7:00	1			54			53											
12/02/19 8:00	1			58			57											
12/02/19 9:00	1			57			57											
12/02/19 10:00	1			56			58											
12/02/19 11:00	1			57			59											
12/02/19 12:00	1			57			59											
12/02/19 13:00	1			57			59											
12/02/19 14:00	1			58			58											
12/02/19 15:00	1			58			59											
12/02/19 16:00	1			64			63											
12/02/19 17:00	1			69			68											
12/02/19 18:00	1			74			72											
12/02/19 19:00	1			73			72											
12/02/19 20:00	1			73			72											
12/02/19 21:00	1			68			68											
12/02/19 22:00	1			60			59											
12/02/19 23:00	1			48			48											
12/03/19 0:00	1			41			40											
12/03/19 1:00	1			38			37											
12/03/19 2:00	1			37			37											
12/03/19 3:00	1			37			36											
12/03/19 4:00	1			37			36											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/03/19 5:00	1			38			37												
12/03/19 6:00	1			39			39												
12/03/19 7:00	1			46			46												
12/03/19 8:00	1			51			51												
12/03/19 9:00	1			57			56												
12/03/19 10:00	1			56			56												
12/03/19 11:00	1			56			57												
12/03/19 12:00	1			53			55												
12/03/19 13:00	1			52			53												
12/03/19 14:00	1			52			53												
12/03/19 15:00	1			52			53												
12/03/19 16:00	1			54			55												
12/03/19 17:00	1			58			59												
12/03/19 18:00	1			62			62												
12/03/19 19:00	1			59			58												
12/03/19 20:00	1			59			58												
12/03/19 21:00	1			59			58												
12/03/19 22:00	1			63			59												
12/03/19 23:00	1			59			52												
12/04/19 0:00	1			53			45												
12/04/19 1:00	1			45			40												
12/04/19 2:00	1			39			37												
12/04/19 3:00	1			37			36												
12/04/19 4:00	1			37			36												
12/04/19 5:00	1			44			43												
12/04/19 6:00	1			50			50												
12/04/19 7:00	1			61			60												
12/04/19 8:00	1			66			65												
12/04/19 9:00	1			71			70												
12/04/19 10:00	1			68			67												
12/04/19 11:00	1			63			63												
12/04/19 12:00	1			58			59												
12/04/19 13:00	1			57			59												
12/04/19 14:00	1			57			59												
12/04/19 15:00	1			57			59												
12/04/19 16:00	1			63			63												
12/04/19 17:00	1			68			67												
12/04/19 18:00	1			73			72												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 19:00	1			74			72											
12/04/19 20:00	1			74			72											
12/04/19 21:00	1			72			70											
12/04/19 22:00	1			67			65											
12/04/19 23:00	1			55			53											
12/05/19 0:00	1			35			33											
12/05/19 1:00	0			15			14											
12/05/19 2:00	0			2			3											
12/05/19 3:00	0			0			0											
12/05/19 4:00	0			0			0											
12/05/19 5:00	0			0			0											
12/05/19 6:00	0			0			0											
12/05/19 7:00	0			0			0											
12/05/19 8:00	0			0			0											
12/05/19 9:00	0			0			0											
12/05/19 10:00	0			0			0											
12/05/19 11:00	0			0			0											
12/05/19 12:00	0			0			0											
12/05/19 13:00	0			0			0											
12/05/19 14:00	0			0			0											
12/05/19 15:00	0			0			0											
12/05/19 16:00	0			0			0											
12/05/19 17:00	0			0			0											
12/05/19 18:00	0			0			0											
12/05/19 19:00	0			0			0											
12/05/19 20:00	0			0			0											
12/05/19 21:00	0			0			0											
12/05/19 22:00	0			0			0											
12/05/19 23:00	0			0			0											
12/06/19 0:00	0			0			0											
12/06/19 1:00	0			0			0											
12/06/19 2:00	0			0			0											
12/06/19 3:00	0			0			0											
12/06/19 4:00	0			0			0											
12/06/19 5:00	0			0			0											
12/06/19 6:00	0			0			0											
12/06/19 7:00	0			0			0											
12/06/19 8:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/06/19 9:00	0			0			0												
12/06/19 10:00	0			0			0												
12/06/19 11:00	0			0			0												
12/06/19 12:00	0			0			0												
12/06/19 13:00	0			0			0												
12/06/19 14:00	0			0			0												
12/06/19 15:00	0			0			0												
12/06/19 16:00	0			0			0												
12/06/19 17:00	0			0			0												
12/06/19 18:00	0			0			0												
12/06/19 19:00	0			0			0												
12/06/19 20:00	0			0			0												
12/06/19 21:00	0			0			0												
12/06/19 22:00	0			0			0												
12/06/19 23:00	0			0			0												
12/07/19 0:00	0			0			0												
12/07/19 1:00	0			0			0												
12/07/19 2:00	0			0			0												
12/07/19 3:00	0			0			0												
12/07/19 4:00	0			0			0												
12/07/19 5:00	0			0			0												
12/07/19 6:00	0			0			0												
12/07/19 7:00	0			0			0												
12/07/19 8:00	0			0			0												
12/07/19 9:00	0			0			0												
12/07/19 10:00	0			0			0												
12/07/19 11:00	0			0			0												
12/07/19 12:00	0			0			0												
12/07/19 13:00	0			0			0												
12/07/19 14:00	0			0			0												
12/07/19 15:00	0			0			0												
12/07/19 16:00	0			0			0												
12/07/19 17:00	0			0			0												
12/07/19 18:00	0			0			0												
12/07/19 19:00	0			0			0												
12/07/19 20:00	0			0			0												
12/07/19 21:00	0			0			0												
12/07/19 22:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/07/19 23:00	0			0			0												
12/08/19 0:00	0			0			0												
12/08/19 1:00	0			0			0												
12/08/19 2:00	0			0			0												
12/08/19 3:00	0			0			0												
12/08/19 4:00	0			0			0												
12/08/19 5:00	0			0			0												
12/08/19 6:00	0			0			0												
12/08/19 7:00	0			0			0												
12/08/19 8:00	0			0			0												
12/08/19 9:00	0			0			0												
12/08/19 10:00	0			0			0												
12/08/19 11:00	0			0			0												
12/08/19 12:00	0			0			0												
12/08/19 13:00	0			0			0												
12/08/19 14:00	0			0			0												
12/08/19 15:00	0			0			0												
12/08/19 16:00	0			0			0												
12/08/19 17:00	0			0			0												
12/08/19 18:00	0			0			0												
12/08/19 19:00	0			0			0												
12/08/19 20:00	0			0			0												
12/08/19 21:00	0			0			0												
12/08/19 22:00	0			0			0												
12/08/19 23:00	0			0			0												
12/09/19 0:00	0			0			0												
12/09/19 1:00	0			0			0												
12/09/19 2:00	0			0			0												
12/09/19 3:00	0			0			0												
12/09/19 4:00	0			0			0												
12/09/19 5:00	0			0			0												
12/09/19 6:00	0			0			0												
12/09/19 7:00	0			0			0												
12/09/19 8:00	0			0			0												
12/09/19 9:00	0			0			0												
12/09/19 10:00	0			0			0												
12/09/19 11:00	0			0			0												
12/09/19 12:00	0			0			0												

ALL_UnitOn_TF_1H CT1_Load_Total_3Hr_MWe_1H CT2_Load_Total_3Hr_MWe_1H

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/19 13:00	0			0			0											
12/09/19 14:00	0			0			0											
12/09/19 15:00	0			0			0											
12/09/19 16:00	0			0			0											
12/09/19 17:00	0			0			0											
12/09/19 18:00	0			0			0											
12/09/19 19:00	0			0			0											
12/09/19 20:00	0			0			0											
12/09/19 21:00	0			0			0											
12/09/19 22:00	0			0			0											
12/09/19 23:00	0			0			0											
12/10/19 0:00	0			0			0											
12/10/19 1:00	0			0			0											
12/10/19 2:00	0			0			0											
12/10/19 3:00	0			0			0											
12/10/19 4:00	0			0			0											
12/10/19 5:00	0			0			0											
12/10/19 6:00	0			0			0											
12/10/19 7:00	0			0			0											
12/10/19 8:00	0			0			0											
12/10/19 9:00	0			0			0											
12/10/19 10:00	0			0			0											
12/10/19 11:00	0			0			0											
12/10/19 12:00	0			0			0											
12/10/19 13:00	0			0			0											
12/10/19 14:00	0			0			0											
12/10/19 15:00	0			0			0											
12/10/19 16:00	0			0			0											
12/10/19 17:00	0			0			0											
12/10/19 18:00	0			0			0											
12/10/19 19:00	0			0			0											
12/10/19 20:00	0			0			0											
12/10/19 21:00	0			0			0											
12/10/19 22:00	0			0			0											
12/10/19 23:00	0			0			0											
12/11/19 0:00	0			0			0											
12/11/19 1:00	0			0			0											
12/11/19 2:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/11/19 3:00	0			0			0												
12/11/19 4:00	0			0			0												
12/11/19 5:00	0			0			0												
12/11/19 6:00	0			0			0												
12/11/19 7:00	0			0			0												
12/11/19 8:00	0			0			0												
12/11/19 9:00	0			0			0												
12/11/19 10:00	0			0			0												
12/11/19 11:00	0			0			0												
12/11/19 12:00	0			0			0												
12/11/19 13:00	0			0			0												
12/11/19 14:00	0			0			0												
12/11/19 15:00	0			0			0												
12/11/19 16:00	0			0			0												
12/11/19 17:00	0			0			0												
12/11/19 18:00	0			0			0												
12/11/19 19:00	0			0			0												
12/11/19 20:00	0			0			0												
12/11/19 21:00	0			0			0												
12/11/19 22:00	0			0			0												
12/11/19 23:00	0			0			0												
12/12/19 0:00	0			0			0												
12/12/19 1:00	0			0			0												
12/12/19 2:00	0			0			0												
12/12/19 3:00	0			0			0												
12/12/19 4:00	0			0			0												
12/12/19 5:00	0			0			0												
12/12/19 6:00	0			0			0												
12/12/19 7:00	0			0			0												
12/12/19 8:00	0			0			0												
12/12/19 9:00	0			0			0												
12/12/19 10:00	0			0			0												
12/12/19 11:00	0			0			0												
12/12/19 12:00	0			0			0												
12/12/19 13:00	0			0			0												
12/12/19 14:00	0			0			0												
12/12/19 15:00	0			0			0												
12/12/19 16:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/19 17:00	0			0			0											
12/12/19 18:00	0			0			0											
12/12/19 19:00	0			0			0											
12/12/19 20:00	0			0			0											
12/12/19 21:00	0			0			0											
12/12/19 22:00	0			0			0											
12/12/19 23:00	0			0			0											
12/13/19 0:00	0			0			0											
12/13/19 1:00	0			0			0											
12/13/19 2:00	0			0			0											
12/13/19 3:00	0			0			0											
12/13/19 4:00	0			0			0											
12/13/19 5:00	0			0			0											
12/13/19 6:00	0			0			0											
12/13/19 7:00	0			0			0											
12/13/19 8:00	0			0			0											
12/13/19 9:00	0			0			0											
12/13/19 10:00	0			0			0											
12/13/19 11:00	0			0			0											
12/13/19 12:00	0			0			0											
12/13/19 13:00	0			0			0											
12/13/19 14:00	0			0			0											
12/13/19 15:00	0			0			0											
12/13/19 16:00	0			0			0											
12/13/19 17:00	0			0			0											
12/13/19 18:00	0			0			0											
12/13/19 19:00	0			0			0											
12/13/19 20:00	0			0			0											
12/13/19 21:00	0			0			0											
12/13/19 22:00	0			0			0											
12/13/19 23:00	0			0			0											
12/14/19 0:00	0			0			0											
12/14/19 1:00	0			0			0											
12/14/19 2:00	0			0			0											
12/14/19 3:00	0			0			0											
12/14/19 4:00	0			0			0											
12/14/19 5:00	0			0			0											
12/14/19 6:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/14/19 7:00	0			0			0												
12/14/19 8:00	0			0			0												
12/14/19 9:00	0			0			0												
12/14/19 10:00	0			0			0												
12/14/19 11:00	0			0			0												
12/14/19 12:00	0			0			0												
12/14/19 13:00	0			0			0												
12/14/19 14:00	0			0			0												
12/14/19 15:00	0			0			0												
12/14/19 16:00	0			0			0												
12/14/19 17:00	0			0			0												
12/14/19 18:00	0			0			0												
12/14/19 19:00	0			0			0												
12/14/19 20:00	0			0			0												
12/14/19 21:00	0			0			0												
12/14/19 22:00	0			0			0												
12/14/19 23:00	0			0			0												
12/15/19 0:00	0			0			0												
12/15/19 1:00	0			0			0												
12/15/19 2:00	0			0			0												
12/15/19 3:00	0			0			0												
12/15/19 4:00	0			0			0												
12/15/19 5:00	0			0			0												
12/15/19 6:00	0			0			0												
12/15/19 7:00	0			0			0												
12/15/19 8:00	0			0			0												
12/15/19 9:00	0			0			0												
12/15/19 10:00	0			0			0												
12/15/19 11:00	0			0			0												
12/15/19 12:00	0			0			0												
12/15/19 13:00	0			0			0												
12/15/19 14:00	0			0			0												
12/15/19 15:00	0			0			0												
12/15/19 16:00	0			0			0												
12/15/19 17:00	0			0			0												
12/15/19 18:00	0			0			0												
12/15/19 19:00	0			0			0												
12/15/19 20:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/15/19 21:00	0			0			0												
12/15/19 22:00	0			0			0												
12/15/19 23:00	0			0			0												
12/16/19 0:00	0			0			0												
12/16/19 1:00	0			0			0												
12/16/19 2:00	0			0			0												
12/16/19 3:00	0			0			0												
12/16/19 4:00	0			0			0												
12/16/19 5:00	0			0			0												
12/16/19 6:00	0			0			0												
12/16/19 7:00	0			0			0												
12/16/19 8:00	0			0			0												
12/16/19 9:00	0			0			0												
12/16/19 10:00	0			0			0												
12/16/19 11:00	0			0			0												
12/16/19 12:00	0			0			0												
12/16/19 13:00	0			0			0												
12/16/19 14:00	0			0			0												
12/16/19 15:00	0			0			0												
12/16/19 16:00	0			0			0												
12/16/19 17:00	0			0			0												
12/16/19 18:00	0			0			0												
12/16/19 19:00	0			0			0												
12/16/19 20:00	0			0			0												
12/16/19 21:00	0			0			0												
12/16/19 22:00	0			0			0												
12/16/19 23:00	0			0			0												
12/17/19 0:00	0			0			0												
12/17/19 1:00	0			0			0												
12/17/19 2:00	0			0			0												
12/17/19 3:00	0			0			0												
12/17/19 4:00	0			0			0												
12/17/19 5:00	0			0			0												
12/17/19 6:00	0			0			0												
12/17/19 7:00	0			0			0												
12/17/19 8:00	0			0			0												
12/17/19 9:00	0			0			0												
12/17/19 10:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/19 11:00	0			0			0											
12/17/19 12:00	0			0			0											
12/17/19 13:00	0			0			0											
12/17/19 14:00	0			0			0											
12/17/19 15:00	0			0			0											
12/17/19 16:00	0			0			0											
12/17/19 17:00	0			0			0											
12/17/19 18:00	0			0			0											
12/17/19 19:00	0			0			0											
12/17/19 20:00	0			0			0											
12/17/19 21:00	0			0			0											
12/17/19 22:00	0			0			0											
12/17/19 23:00	0			0			0											
12/18/19 0:00	0			0			0											
12/18/19 1:00	0			0			0											
12/18/19 2:00	0			0			0											
12/18/19 3:00	0			0			0											
12/18/19 4:00	0			0			0											
12/18/19 5:00	0			0			0											
12/18/19 6:00	0			0			0											
12/18/19 7:00	0			0			0											
12/18/19 8:00	0			0			0											
12/18/19 9:00	0			0			0											
12/18/19 10:00	0			0			0											
12/18/19 11:00	0			0			0											
12/18/19 12:00	0			0			0											
12/18/19 13:00	0			0			0											
12/18/19 14:00	0			0			0											
12/18/19 15:00	0			0			0											
12/18/19 16:00	0			0			0											
12/18/19 17:00	0			0			0											
12/18/19 18:00	0			0			0											
12/18/19 19:00	0			0			0											
12/18/19 20:00	0			0			0											
12/18/19 21:00	0			0			0											
12/18/19 22:00	0			0			0											
12/18/19 23:00	0			0			0											
12/19/19 0:00	0			0			0											

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/19/19 1:00	0			0			0												
12/19/19 2:00	0			0			0												
12/19/19 3:00	0			0			0												
12/19/19 4:00	0			0			0												
12/19/19 5:00	0			0			0												
12/19/19 6:00	0			0			0												
12/19/19 7:00	0			0			0												
12/19/19 8:00	0			0			0												
12/19/19 9:00	0			0			0												
12/19/19 10:00	0			0			0												
12/19/19 11:00	0			0			0												
12/19/19 12:00	0			0			0												
12/19/19 13:00	0			0			0												
12/19/19 14:00	0			0			0												
12/19/19 15:00	0			0			0												
12/19/19 16:00	0			0			0												
12/19/19 17:00	0			0			0												
12/19/19 18:00	0			0			0												
12/19/19 19:00	0			0			0												
12/19/19 20:00	0			0			0												
12/19/19 21:00	0			0			0												
12/19/19 22:00	0			0			0												
12/19/19 23:00	0			0			0												
12/20/19 0:00	0			0			0												
12/20/19 1:00	0			0			0												
12/20/19 2:00	0			0			0												
12/20/19 3:00	0			0			0												
12/20/19 4:00	0			0			0												
12/20/19 5:00	0			0			0												
12/20/19 6:00	0			0			0												
12/20/19 7:00	0			0			0												
12/20/19 8:00	0			0			0												
12/20/19 9:00	0			0			0												
12/20/19 10:00	0			0			0												
12/20/19 11:00	0			0			0												
12/20/19 12:00	0			0			0												
12/20/19 13:00	0			0			0												
12/20/19 14:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/20/19 15:00	0			0			0												
12/20/19 16:00	0			0			0												
12/20/19 17:00	0			0			0												
12/20/19 18:00	0			0			0												
12/20/19 19:00	0			0			0												
12/20/19 20:00	0			0			0												
12/20/19 21:00	0			0			0												
12/20/19 22:00	0			0			0												
12/20/19 23:00	0			0			0												
12/21/19 0:00	0			0			0												
12/21/19 1:00	0			0			0												
12/21/19 2:00	0			0			0												
12/21/19 3:00	0			0			0												
12/21/19 4:00	0			0			0												
12/21/19 5:00	0			0			0												
12/21/19 6:00	0			0			0												
12/21/19 7:00	0			0			0												
12/21/19 8:00	0			0			0												
12/21/19 9:00	0			0			0												
12/21/19 10:00	0			0			0												
12/21/19 11:00	0			0			0												
12/21/19 12:00	0			0			0												
12/21/19 13:00	0			0			0												
12/21/19 14:00	0			0			0												
12/21/19 15:00	0			0			0												
12/21/19 16:00	0			0			0												
12/21/19 17:00	0			0			0												
12/21/19 18:00	0			0			0												
12/21/19 19:00	0			0			0												
12/21/19 20:00	0			0			0												
12/21/19 21:00	0			0			0												
12/21/19 22:00	0			0			0												
12/21/19 23:00	0			0			0												
12/22/19 0:00	0			0			0												
12/22/19 1:00	0			0			0												
12/22/19 2:00	0			0			0												
12/22/19 3:00	0			0			0												
12/22/19 4:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/22/19 5:00	0			0			0												
12/22/19 6:00	0			0			0												
12/22/19 7:00	0			0			0												
12/22/19 8:00	0			0			0												
12/22/19 9:00	0			0			0												
12/22/19 10:00	0			0			0												
12/22/19 11:00	0			0			0												
12/22/19 12:00	0			0			0												
12/22/19 13:00	0			0			0												
12/22/19 14:00	0			0			0												
12/22/19 15:00	0			0			0												
12/22/19 16:00	0			0			0												
12/22/19 17:00	0			0			0												
12/22/19 18:00	0			0			0												
12/22/19 19:00	0			0			0												
12/22/19 20:00	0			0			0												
12/22/19 21:00	0			0			0												
12/22/19 22:00	0			0			0												
12/22/19 23:00	0			0			0												
12/23/19 0:00	0			0			0												
12/23/19 1:00	0			0			0												
12/23/19 2:00	0			0			0												
12/23/19 3:00	0			0			0												
12/23/19 4:00	0			0			0												
12/23/19 5:00	0			0			0												
12/23/19 6:00	0			0			0												
12/23/19 7:00	0			0			0												
12/23/19 8:00	0			0			0												
12/23/19 9:00	0			0			0												
12/23/19 10:00	0			0			0												
12/23/19 11:00	0			0			0												
12/23/19 12:00	0			0			0												
12/23/19 13:00	0			0			0												
12/23/19 14:00	0			0			0												
12/23/19 15:00	0			0			0												
12/23/19 16:00	0			0			0												
12/23/19 17:00	0			0			0												
12/23/19 18:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/23/19 19:00	0			0			0												
12/23/19 20:00	0			0			0												
12/23/19 21:00	0			0			0												
12/23/19 22:00	0			0			0												
12/23/19 23:00	0			0			0												
12/24/19 0:00	0			0			0												
12/24/19 1:00	0			0			0												
12/24/19 2:00	0			0			0												
12/24/19 3:00	0			0			0												
12/24/19 4:00	0			0			0												
12/24/19 5:00	0			0			0												
12/24/19 6:00	0			0			0												
12/24/19 7:00	0			0			0												
12/24/19 8:00	0			0			0												
12/24/19 9:00	0			0			0												
12/24/19 10:00	0			0			0												
12/24/19 11:00	0			0			0												
12/24/19 12:00	0			0			0												
12/24/19 13:00	0			0			0												
12/24/19 14:00	0			0			0												
12/24/19 15:00	0			0			0												
12/24/19 16:00	0			0			0												
12/24/19 17:00	0			0			0												
12/24/19 18:00	0			0			0												
12/24/19 19:00	0			0			0												
12/24/19 20:00	0			0			0												
12/24/19 21:00	0			0			0												
12/24/19 22:00	0			0			0												
12/24/19 23:00	0			0			0												
12/25/19 0:00	0			0			0												
12/25/19 1:00	0			0			0												
12/25/19 2:00	0			0			0												
12/25/19 3:00	0			0			0												
12/25/19 4:00	0			0			0												
12/25/19 5:00	0			0			0												
12/25/19 6:00	0			0			0												
12/25/19 7:00	0			0			0												
12/25/19 8:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/25/19 9:00	0			0			0												
12/25/19 10:00	0			0			0												
12/25/19 11:00	0			0			0												
12/25/19 12:00	0			0			0												
12/25/19 13:00	0			0			0												
12/25/19 14:00	0			0			0												
12/25/19 15:00	0			0			0												
12/25/19 16:00	0			0			0												
12/25/19 17:00	0			0			0												
12/25/19 18:00	0			0			0												
12/25/19 19:00	0			0			0												
12/25/19 20:00	0			0			0												
12/25/19 21:00	0			0			0												
12/25/19 22:00	0			0			0												
12/26/19 0:00	0			0			0												
12/26/19 1:00	0			0			0												
12/26/19 2:00	0			0			0												
12/26/19 3:00	0			0			0												
12/26/19 4:00	0			0			0												
12/26/19 5:00	0			0			0												
12/26/19 6:00	0			0			0												
12/26/19 7:00	0			0			0												
12/26/19 8:00	0			0			0												
12/26/19 9:00	0			0			0												
12/26/19 10:00	0			0			0												
12/26/19 11:00	0			0			0												
12/26/19 12:00	0			0			0												
12/26/19 13:00	0			0			0												
12/26/19 14:00	0			0			0												
12/26/19 15:00	0			0			0												
12/26/19 16:00	0			0			0												
12/26/19 17:00	0			0			0												
12/26/19 18:00	0			0			0												
12/26/19 19:00	0			0			0												
12/26/19 20:00	0			0			0												
12/26/19 21:00	0			0			0												
12/26/19 22:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/26/19 23:00	0			0			0												
12/27/19 0:00	0			0			0												
12/27/19 1:00	0			0			0												
12/27/19 2:00	0			0			0												
12/27/19 3:00	0			0			0												
12/27/19 4:00	0			0			0												
12/27/19 5:00	0			0			0												
12/27/19 6:00	0			0			0												
12/27/19 7:00	0			0			0												
12/27/19 8:00	0			0			0												
12/27/19 9:00	0			0			0												
12/27/19 10:00	0			0			0												
12/27/19 11:00	0			0			0												
12/27/19 12:00	0			0			0												
12/27/19 13:00	0			0			0												
12/27/19 14:00	0			0			0												
12/27/19 15:00	0			0			0												
12/27/19 16:00	0			0			0												
12/27/19 17:00	0			0			0												
12/27/19 18:00	0			0			0												
12/27/19 19:00	0			0			0												
12/27/19 20:00	0			0			0												
12/27/19 21:00	0			0			0												
12/27/19 22:00	0			0			0												
12/27/19 23:00	0			0			0												
12/28/19 0:00	0			0			0												
12/28/19 1:00	0			0			0												
12/28/19 2:00	0			0			0												
12/28/19 3:00	0			0			0												
12/28/19 4:00	0			0			0												
12/28/19 5:00	0			0			0												
12/28/19 6:00	0			0			0												
12/28/19 7:00	0			0			0												
12/28/19 8:00	0			0			0												
12/28/19 9:00	0			0			0												
12/28/19 10:00	0			0			0												
12/28/19 11:00	0			0			0												
12/28/19 12:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/28/19 13:00	0			0			0												
12/28/19 14:00	0			0			0												
12/28/19 15:00	0			0			0												
12/28/19 16:00	0			0			0												
12/28/19 17:00	0			0			0												
12/28/19 18:00	0			0			0												
12/28/19 19:00	0			0			0												
12/28/19 20:00	0			0			0												
12/28/19 21:00	0			0			0												
12/28/19 22:00	0			0			0												
12/28/19 23:00	0			0			0												
12/29/19 0:00	0			0			0												
12/29/19 1:00	0			0			0												
12/29/19 2:00	0			0			0												
12/29/19 3:00	0			0			0												
12/29/19 4:00	0			0			0												
12/29/19 5:00	0			0			0												
12/29/19 6:00	0			0			0												
12/29/19 7:00	0			0			0												
12/29/19 8:00	0			0			0												
12/29/19 9:00	0			0			0												
12/29/19 10:00	0			0			0												
12/29/19 11:00	0			0			0												
12/29/19 12:00	0			0			0												
12/29/19 13:00	0			0			0												
12/29/19 14:00	0			0			0												
12/29/19 15:00	0			0			0												
12/29/19 16:00	0			0			0												
12/29/19 17:00	0			0			0												
12/29/19 18:00	0			0			0												
12/29/19 19:00	0			0			0												
12/29/19 20:00	0			0			0												
12/29/19 21:00	0			0			0												
12/29/19 22:00	0			0			0												
12/29/19 23:00	0			0			0												
12/30/19 0:00	0			0			0												
12/30/19 1:00	0			0			0												
12/30/19 2:00	0			0			0												

Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	
12/30/19 3:00	0			0			0												
12/30/19 4:00	0			0			0												
12/30/19 5:00	0			0			0												
12/30/19 6:00	0			0			0												
12/30/19 7:00	0			0			0												
12/30/19 8:00	0			0			0												
12/30/19 9:00	0			0			0												
12/30/19 10:00	0			0			0												
12/30/19 11:00	0			0			0												
12/30/19 12:00	0			0			0												
12/30/19 13:00	0			0			0												
12/30/19 14:00	0			0			0												
12/30/19 15:00	0			0			0												
12/30/19 16:00	0			0			0												
12/30/19 17:00	0			0			0												
12/30/19 18:00	0			0			0												
12/30/19 19:00	0			0			0												
12/30/19 20:00	0			0			0												
12/30/19 21:00	0			0			0												
12/30/19 22:00	0			0			0												
12/30/19 23:00	0			0			0												
12/31/19 0:00	0			0			0												
12/31/19 1:00	0			0			0												
12/31/19 2:00	0			0			0												
12/31/19 3:00	0			0			0												
12/31/19 4:00	0			0			0												
12/31/19 5:00	0			0			0												
12/31/19 6:00	0			0			0												
12/31/19 7:00	0			0			0												
12/31/19 8:00	0			0			0												
12/31/19 9:00	0			0			0												
12/31/19 10:00	0			0			0												
12/31/19 11:00	0			0			0												
12/31/19 12:00	0			0			0												
12/31/19 13:00	0			0			0												
12/31/19 14:00	0			0			0												
12/31/19 15:00	0			0			0												
12/31/19 16:00	0			0			0												

Date/Time	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/31/19 17:00	0			0			0											
12/31/19 18:00	0			0			0											
12/31/19 19:00	0			0			0											
12/31/19 20:00	0			0			0											
12/31/19 21:00	0			0			0											
12/31/19 22:00	0			0			0											
12/31/19 23:00	0			0			0											

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/21/19 07:34	200.0	0.0	0.6	R-A /Span * 100	0.3
	High	10/21/19 07:44	200.0	181.4	183.2	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/21/19 07:34	10.0	0.0	0.6	>1x Alert R-A /Span * 100	6.0
	High	10/21/19 07:40	10.0	9.2	9.9	>1x Alert R-A /Span * 100	7.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/21/19 07:34	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/21/19 07:44	200.0	179.0	184.1	>1x Alert R-A /Span * 100	2.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/21/19 07:34	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/21/19 07:40	10.0	9.2	9.3	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/21/19 07:34	21.0	18.2	18.2	R-A	0.0
	Zero	10/21/19 07:40	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/22/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/19 04:25	200.0	179.0	181.7	R-A /Span * 100	1.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/22/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/19 04:19	10.0	9.2	9.0	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/22/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/19 05:25	200.0	181.4	181.1	R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/22/19 05:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/22/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/22/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/19 05:25	200.0	179.0	181.1	R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/22/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/22/19 05:20	10.0	9.2	9.3	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/22/19 05:15	21.0	18.2	18.2	R-A	0.0
	Zero	10/22/19 05:20	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/23/19 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/19 04:25	200.0	179.0		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/23/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/23/19 04:20	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/23/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/19 05:25	200.0	181.4		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/23/19 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/23/19 05:19	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/23/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/19 05:25	200.0	179.0		R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/23/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/23/19 05:19	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/23/19 05:14	21.0	18.2		R-A	0.0
	Zero	10/23/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/24/19 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 04:25	200.0	179.0		R-A /Span * 100	1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/24/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 04:20	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/24/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 05:24	200.0	181.4		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/24/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 05:20	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/24/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 05:24	200.0	179.0		R-A /Span * 100	1.2

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/24/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 05:20	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/24/19 05:14	21.0	18.2		R-A	0.0
	Zero	10/24/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/24/19 15:23	200.0	0.0		R-A /Span * 100	0.2
	High	10/24/19 15:33	200.0	181.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/24/19 15:23	10.0	0.0		R-A /Span * 100	3.0
	High	10/24/19 15:28	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/24/19 15:23	200.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 15:33	200.0	179.0		R-A /Span * 100	3.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/24/19 15:23	10.0	0.0		R-A /Span * 100	0.0
	High	10/24/19 15:28	10.0	9.3		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/24/19 15:23	21.0	18.1		R-A	0.0
	Zero	10/24/19 15:28	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Warning
	Zero	10/25/19 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 04:24	200.0	179.0		R-A /Span * 100	6.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 04:19	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 05:15	200.0	0.0		R-A /Span * 100	0.2
	High	10/25/19 05:25	200.0	181.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 05:15	10.0	0.0		R-A /Span * 100	3.0
	High	10/25/19 05:20	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 05:25	200.0	179.0		R-A /Span * 100	2.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 05:20	10.0	9.6	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/25/19 05:15	21.0	18.1		R-A	0.0
	Zero	10/25/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 09:18	200.0	0.3		R-A /Span * 100	0.2
	High	10/25/19 09:29	200.0	181.7		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 09:18	10.0	0.3		R-A /Span * 100	3.0
	High	10/25/19 09:23	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 09:18	200.0	0.0		R-A /Span * 100	0.1
	High	10/25/19 09:29	200.0	179.0		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 09:18	10.0	0.0		R-A /Span * 100	1.0
	High	10/25/19 09:23	10.0	9.3		R-A /Span * 100	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 09:18	200.0	0.0		R-A /Span * 100	0.1
	High	10/25/19 09:29	200.0	179.0		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Warning
	Zero	10/25/19 09:18	10.0	0.0		R-A /Span * 100	1.0
	High	10/25/19 09:23	10.0	9.3	>2x	R-A /Span * 100	6.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/25/19 09:18	21.0	18.1		R-A	0.0
	Zero	10/25/19 09:23	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 10:19	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 10:30	200.0	179.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 10:19	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 10:24	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 15:26	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 15:37	200.0	181.4		R-A /Span * 100	0.6

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 15:26	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 15:32	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/25/19 15:26	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 15:37	200.0	179.0		R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/25/19 15:26	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/19 15:32	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/25/19 15:26	21.0	18.2		R-A	0.0
	Zero	10/25/19 15:32	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/26/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	10/26/19 04:25	200.0	179.0		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/26/19 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	10/26/19 04:19	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/26/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	10/26/19 05:25	200.0	181.7		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/26/19 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	10/26/19 05:19	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/26/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/26/19 05:25	200.0	179.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/26/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/26/19 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/26/19 05:14	21.0	18.1		R-A	0.0
	Zero	10/26/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/27/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/27/19 04:24	200.0	179.0		R-A /Span * 100	1.8

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/27/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/27/19 04:19	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/27/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	10/27/19 05:24	200.0	181.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/27/19 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	10/27/19 05:19	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/27/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/27/19 05:24	200.0	179.0		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/27/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/27/19 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	10/27/19 05:14	21.0	18.1		R-A	0.0
	Zero	10/27/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/28/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/28/19 04:25	200.0	179.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/28/19 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/28/19 04:19	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/28/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	10/28/19 05:24	200.0	181.7		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/28/19 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	10/28/19 05:19	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	10/28/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/28/19 05:24	200.0	179.0		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	10/28/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/28/19 05:19	10.0	9.3		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/28/19 05:14	21.0	18.1		R-A	0.0
	Zero	10/28/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/19 04:15	200.0	-0.1		R-A /Span * 100	0.1
	High	10/29/19 04:25	200.0	179.0		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/29/19 04:20	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/19 05:15	200.0	0.3		R-A /Span * 100	0.2
	High	10/29/19 05:25	200.0	181.7		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/19 05:15	10.0	0.0		R-A /Span * 100	4.0
	High	10/29/19 05:20	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/19 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/29/19 05:25	200.0	179.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/19 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/29/19 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/19 05:15	21.0	18.1		R-A	0.0
	Zero	10/29/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/19 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 04:24	200.0	179.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 04:20	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	10/30/19 05:25	200.0	181.7		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/19 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	10/30/19 05:19	10.0	9.2		R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 05:25	200.0	179.0		R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/19 05:14	21.0	18.1		R-A	0.1
	Zero	10/30/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/19 09:02	200.0	0.0		R-A /Span * 100	0.1
	High	10/30/19 09:12	200.0	181.4		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/19 09:02	10.0	0.0		R-A /Span * 100	1.0
	High	10/30/19 09:06	10.0	9.2		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/19 09:02	200.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 09:12	200.0	179.0		R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/19 09:02	10.0	0.0		R-A /Span * 100	0.0
	High	10/30/19 09:06	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/19 09:02	21.0	18.2		R-A	0.1
	Zero	10/30/19 09:06	21.0	0.0		R-A	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/31/19 04:25	200.0	179.0		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/31/19 04:19	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	10/31/19 05:25	200.0	181.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/19 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	10/31/19 05:20	10.0	9.2		R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/31/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/31/19 05:25	200.0	179.0	178.3	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/31/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/31/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/31/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	10/31/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/01/19 04:24	200.0	179.0	178.4	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/19 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/01/19 04:19	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/19 05:15	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/01/19 05:24	200.0	181.7	181.1	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/19 05:15	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/01/19 05:20	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/01/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/01/19 05:24	200.0	179.0	178.3	R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/01/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/01/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	11/01/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/02/19 04:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/02/19 04:25	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/02/19 04:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/02/19 04:19	10.0	9.3	9.1	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/02/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/02/19 05:25	200.0	181.7	181.3	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/02/19 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/02/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/02/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/02/19 05:25	200.0	179.0	178.0	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/02/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/02/19 05:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/02/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/02/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/03/19 04:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/03/19 04:25	200.0	179.0	178.1	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/03/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/19 04:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/03/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/03/19 05:24	200.0	181.7	182.1	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/03/19 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/03/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/03/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/19 05:24	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/03/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/03/19 05:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/03/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/03/19 05:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/19 04:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/04/19 04:25	200.0	179.0	178.0	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/04/19 04:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/04/19 05:24	200.0	181.7	181.9	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/04/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/04/19 05:24	200.0	179.0	177.8	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/04/19 05:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/04/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/05/19 04:25	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/19 04:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/05/19 04:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/05/19 05:25	200.0	181.7	181.8	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/05/19 05:20	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/05/19 05:25	200.0	179.0	177.6	R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/05/19 05:20	10.0	9.3		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/05/19 05:14	21.0	18.1		R-A	0.0
	Zero	11/05/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/19 17:19	200.0	0.0		R-A /Span * 100	0.1
	High	11/05/19 17:29	200.0	181.4		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/19 17:19	10.0	0.0		R-A /Span * 100	2.0
	High	11/05/19 17:24	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/19 17:19	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/19 17:29	200.0	179.0		R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/19 17:19	10.0	0.0		R-A /Span * 100	0.0
	High	11/05/19 17:24	10.0	9.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/05/19 17:19	21.0	18.2		R-A	0.0
	Zero	11/05/19 17:24	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/06/19 04:24	200.0	179.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/06/19 04:20	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/19 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/06/19 04:24	200.0	179.0		R-A /Span * 100	2.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/06/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/06/19 04:19	10.0	9.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	11/06/19 05:25	200.0	181.7		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/06/19 05:19	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/19 05:25	200.0	179.0	177.7	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/19 05:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/06/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/06/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/06/19 05:24	200.0	181.4	182.6	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/06/19 05:20	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/19 05:24	200.0	179.0	181.1	R-A /Span * 100	1.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/06/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/06/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/06/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	11/06/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/07/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/07/19 04:25	200.0	179.0	177.4	R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/07/19 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/19 04:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/07/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/07/19 05:25	200.0	181.7	181.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/07/19 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/07/19 05:20	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/07/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/19 05:25	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/07/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/07/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/07/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/07/19 14:17	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/07/19 14:27	200.0	181.4	183.1	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/07/19 14:17	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/07/19 14:22	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/07/19 14:17	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/19 14:27	200.0	179.0	180.8	R-A /Span * 100	0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/07/19 14:17	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/19 14:22	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/07/19 14:17	21.0	18.2	18.2	R-A	0.0
	Zero	11/07/19 14:22	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/08/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/08/19 04:25	200.0	179.0	176.5	R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/08/19 04:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/08/19 04:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/08/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/08/19 05:24	200.0	181.7	181.3	R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/08/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/08/19 05:20	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/08/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/19 05:24	200.0	179.0	177.6	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/08/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/08/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/08/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/08/19 14:32	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/08/19 14:42	200.0	181.4	182.9	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/08/19 14:32	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/08/19 14:37	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/08/19 14:32	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/19 14:42	200.0	179.0	180.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/08/19 14:32	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/19 14:37	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/08/19 14:32	21.0	18.2	18.2	R-A	0.0
	Zero	11/08/19 14:37	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/09/19 04:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/09/19 04:25	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/09/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/09/19 04:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/09/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/09/19 05:25	200.0	181.7	181.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/09/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/09/19 05:20	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/09/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/09/19 05:25	200.0	179.0	177.9	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/09/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/09/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/09/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/09/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/10/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/19 04:25	200.0	179.0	178.0	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/10/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/19 04:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/10/19 05:15	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/10/19 05:24	200.0	181.7	181.8	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/10/19 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/10/19 05:20	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/10/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/19 05:24	200.0	179.0	177.8	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/10/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/19 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/10/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	11/10/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/11/19 04:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/11/19 04:25	200.0	179.0	177.6	R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/11/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/19 04:20	10.0	9.3	9.0	R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/11/19 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/11/19 05:25	200.0	181.7	181.9	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/11/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/11/19 05:19	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/11/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/19 05:25	200.0	179.0	177.6	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/11/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/19 05:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/11/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/11/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/12/19 02:37	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/12/19 02:47	200.0	181.4	182.9	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/12/19 02:37	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/12/19 02:42	10.0	9.2	9.4	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/12/19 02:37	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/19 02:47	200.0	179.0	180.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/12/19 02:37	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/19 02:42	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/12/19 02:37	21.0	18.2	18.2	R-A	0.0
	Zero	11/12/19 02:42	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/12/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/19 04:25	200.0	179.0	185.1	R-A /Span * 100	3.1

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/12/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/12/19 04:20	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/13/19 02:51	200.0	0.0		R-A /Span * 100	0.1
	High	11/13/19 03:00	200.0	181.4		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/13/19 02:51	10.0	0.0		R-A /Span * 100	2.0
	High	11/13/19 02:55	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/13/19 02:51	200.0	0.0		R-A /Span * 100	0.0
	High	11/13/19 03:00	200.0	179.0		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/13/19 02:51	10.0	0.0		R-A /Span * 100	0.0
	High	11/13/19 02:55	10.0	9.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/13/19 02:51	21.0	18.2		R-A	0.0
	Zero	11/13/19 02:55	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/13/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/13/19 04:25	200.0	179.0		R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/13/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/13/19 04:20	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/13/19 08:19	200.0	0.0		R-A /Span * 100	0.2
	High	11/13/19 08:29	200.0	181.7		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/13/19 08:19	10.0	0.0		R-A /Span * 100	4.0
	High	11/13/19 08:24	10.0	9.2		R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/13/19 08:19	200.0	0.0		R-A /Span * 100	0.0
	High	11/13/19 08:29	200.0	179.0		R-A /Span * 100	1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/13/19 08:19	10.0	0.0		R-A /Span * 100	0.0
	High	11/13/19 08:24	10.0	9.3		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/13/19 08:19	21.0	18.1		R-A	0.0
	Zero	11/13/19 08:24	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 03:04	200.0	0.0		R-A /Span * 100	0.1
	High	11/14/19 03:14	200.0	181.4		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 03:04	10.0	0.0		R-A /Span * 100	2.0
	High	11/14/19 03:09	10.0	9.2		R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 03:04	200.0	0.0		R-A /Span * 100	0.0
	High	11/14/19 03:14	200.0	179.0		R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 03:04	10.0	0.0		R-A /Span * 100	0.0
	High	11/14/19 03:09	10.0	9.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/14/19 03:04	21.0	18.2		R-A	0.0
	Zero	11/14/19 03:09	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/14/19 04:24	200.0	179.0		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/14/19 04:19	10.0	9.2		R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/14/19 04:25	200.0	179.0		R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/14/19 04:20	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 05:15	200.0	0.0		R-A /Span * 100	0.2
	High	11/14/19 05:25	200.0	181.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 05:15	10.0	0.0		R-A /Span * 100	4.0
	High	11/14/19 05:20	10.0	9.2		R-A /Span * 100	4.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/14/19 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/14/19 05:25	200.0	179.0	176.8	R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/14/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/14/19 05:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/14/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	11/14/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/20/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/19 04:25	200.0	179.0	188.3	>1x Alert R-A /Span * 100	4.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/20/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/19 04:20	10.0	9.2	9.6	>1x Alert R-A /Span * 100	4.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/20/19 05:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/20/19 05:25	200.0	181.4	184.6	R-A /Span * 100	1.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/20/19 05:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/20/19 05:20	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/20/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/19 05:25	200.0	179.0	181.4	R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/20/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/20/19 05:15	21.0	18.2	18.2	R-A	0.0
	Zero	11/20/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/20/19 06:20	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/20/19 06:30	200.0	181.4	185.3	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/20/19 06:20	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/20/19 06:25	10.0	9.2	9.5	R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/20/19 06:20	200.0	0.0		R-A /Span * 100	0.0
	High	11/20/19 06:30	200.0	179.0	181.4	R-A /Span * 100	1.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/20/19 06:20	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/19 06:25	10.0	9.2	9.3	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/20/19 06:20	21.0	18.2	18.2	R-A	0.0
	Zero	11/20/19 06:25	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/21/19 09:18	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/21/19 09:28	200.0	181.7	182.6	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/21/19 09:18	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/21/19 09:23	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/21/19 09:18	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/19 09:28	200.0	179.0	178.0	R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/21/19 09:18	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/19 09:23	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/21/19 09:18	21.0	18.1	18.1	R-A	0.0
	Zero	11/21/19 09:23	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/21/19 10:20	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/21/19 10:30	200.0	181.4	183.5	R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/21/19 10:20	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/21/19 10:25	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/21/19 10:20	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/19 10:30	200.0	179.0	180.5	R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/21/19 10:20	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/19 10:25	10.0	9.2	9.2	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/21/19 10:20	21.0	18.2		R-A	0.0
	Zero	11/21/19 10:25	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/22/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/22/19 04:25	200.0	179.0		R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/22/19 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/22/19 04:20	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/22/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/22/19 04:25	200.0	179.0		R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/22/19 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/22/19 04:20	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	11/22/19 05:24	200.0	181.7		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	10.0	0.0		R-A /Span * 100	4.0
	High	11/22/19 05:19	10.0	9.2		R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/22/19 05:24	200.0	179.0		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/22/19 05:19	10.0	9.3		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/22/19 05:14	21.0	18.1		R-A	0.0
	Zero	11/22/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/22/19 05:25	200.0	181.4		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/22/19 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/22/19 05:20	10.0	9.2		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/22/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/22/19 05:25	200.0	179.0	180.3	R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/22/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/22/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/22/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	11/22/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Warning	
	Zero	11/26/19 04:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/26/19 04:25	200.0	179.0	189.4	>2x R-A /Span * 100	5.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/19 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/26/19 04:20	10.0	9.2	9.7	>1x Alert R-A /Span * 100	5.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/19 05:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/26/19 05:25	200.0	181.4	182.4	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/19 05:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/26/19 05:20	10.0	9.2	9.4	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/26/19 05:25	200.0	179.0	181.6	R-A /Span * 100	1.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/26/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/26/19 05:15	21.0	18.2	18.2	R-A	0.0
	Zero	11/26/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/19 09:37	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/26/19 09:47	200.0	181.7	182.4	R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/19 09:37	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/26/19 09:42	10.0	9.2	9.6	R-A /Span * 100	4.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/19 09:37	200.0	0.0		R-A /Span * 100	0.0
	High	11/26/19 09:47	200.0	179.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/19 09:37	10.0	0.0		R-A /Span * 100	0.0
	High	11/26/19 09:42	10.0	9.3		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/26/19 09:37	21.0	18.1		R-A	0.0
	Zero	11/26/19 09:42	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/19 04:14	200.0	-0.1		R-A /Span * 100	0.1
	High	11/27/19 04:25	200.0	179.0		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/19 04:19	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/27/19 04:24	200.0	179.0		R-A /Span * 100	1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/19 04:19	10.0	9.2		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/19 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/27/19 05:24	200.0	181.4		R-A /Span * 100	1.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/19 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/27/19 05:20	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/27/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/27/19 05:24	200.0	179.0		R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/27/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/27/19 05:20	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/27/19 05:14	21.0	18.2		R-A	0.0
	Zero	11/27/19 05:20	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/27/19 05:14	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/27/19 05:25	200.0	181.7	183.9	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/27/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/27/19 05:19	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/27/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/27/19 05:25	200.0	179.0	177.8	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/27/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/27/19 05:19	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/27/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	11/27/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/28/19 04:25	200.0	179.0	179.6	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/19 04:19	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/28/19 04:25	200.0	179.0	176.9	R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/28/19 04:20	10.0	9.2	9.1	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/28/19 05:24	200.0	181.7	183.8	R-A /Span * 100	1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/28/19 05:20	10.0	9.2	9.7	R-A /Span * 100	5.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/28/19 05:24	200.0	179.0	177.3	R-A /Span * 100	0.9

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/28/19 05:20	10.0	9.3		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/28/19 05:14	21.0	18.1		R-A	0.0
	Zero	11/28/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/28/19 05:24	200.0	181.4		R-A /Span * 100	1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	10.0	0.0		R-A /Span * 100	2.0
	High	11/28/19 05:20	10.0	9.2		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/28/19 05:24	200.0	179.0		R-A /Span * 100	0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/28/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/28/19 05:20	10.0	9.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/28/19 05:14	21.0	18.2		R-A	0.0
	Zero	11/28/19 05:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/19 04:25	200.0	179.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/29/19 04:20	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/19 04:25	200.0	179.0		R-A /Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/29/19 04:20	10.0	9.2		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/19 05:24	200.0	181.4		R-A /Span * 100	1.9

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/29/19 05:20	10.0	9.2	9.6	R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/19 05:24	200.0	179.0	180.5	R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/29/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	11/29/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 05:15	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/29/19 05:25	200.0	181.7	183.6	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/29/19 05:20	10.0	9.2	9.7	R-A /Span * 100	5.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/29/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/19 05:25	200.0	179.0	177.7	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/29/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/19 05:20	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/29/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	11/29/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/30/19 04:25	200.0	179.0	179.3	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/19 04:20	10.0	9.3	9.0	>1x Alert R-A /Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/30/19 04:25	200.0	179.0	176.8	R-A /Span * 100	1.1

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/30/19 04:19	10.0	9.2	9.1	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 05:15	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/30/19 05:25	200.0	181.7	182.1	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/30/19 05:19	10.0	9.2	9.7	R-A /Span * 100	5.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/19 05:25	200.0	179.0	177.8	R-A /Span * 100	0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/19 05:19	10.0	9.3	9.1	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/30/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	11/30/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/30/19 05:24	200.0	181.4	182.5	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/30/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	11/30/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/19 05:24	200.0	179.0	180.5	R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	11/30/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/19 05:19	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	11/30/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	11/30/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/01/19 04:24	200.0	179.0	175.5	R-A /Span * 100	1.8

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/01/19 04:19	10.0	9.2	9.0	R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 04:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/01/19 04:24	200.0	179.0	175.8	R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 04:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/01/19 04:20	10.0	9.3	9.0	>1x Alert R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	12/01/19 05:25	200.0	181.7	183.1	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	10.0	0.0	0.5	R-A /Span * 100	5.0
	High	12/01/19 05:20	10.0	9.2	9.7	R-A /Span * 100	5.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/19 05:25	200.0	179.0	176.4	R-A /Span * 100	1.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/19 05:20	10.0	9.3	9.0	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/01/19 05:15	21.0	18.1	18.1	R-A	0.0
	Zero	12/01/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/01/19 05:24	200.0	181.4	183.3	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	12/01/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/19 05:24	200.0	179.0	179.3	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/01/19 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/19 05:19	10.0	9.2	9.1	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/01/19 05:15	21.0	18.2		R-A	0.0
	Zero	12/01/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/02/19 04:25	200.0	179.0		R-A /Span * 100	2.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/02/19 04:19	10.0	9.0	>1x Alert	R-A /Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	12/02/19 04:25	200.0	179.0		R-A /Span * 100	1.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	12/02/19 04:20	10.0	9.2		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	12/02/19 05:24	200.0	181.7		R-A /Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	10.0	0.0		R-A /Span * 100	5.0
	High	12/02/19 05:19	10.0	9.2		R-A /Span * 100	5.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/02/19 05:24	200.0	179.0		R-A /Span * 100	1.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/02/19 05:19	10.0	9.3	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/02/19 05:14	21.0	18.1		R-A	0.0
	Zero	12/02/19 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	12/02/19 05:25	200.0	181.4		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	10.0	0.0		R-A /Span * 100	2.0
	High	12/02/19 05:20	10.0	9.2		R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/02/19 05:25	200.0	179.0	179.6	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/02/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/02/19 05:20	10.0	9.2	9.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/02/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	12/02/19 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/03/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 04:25	200.0	179.0	179.5	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/03/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 04:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/03/19 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/03/19 04:25	200.0	179.0	175.4	R-A /Span * 100	1.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/03/19 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/03/19 04:20	10.0	9.2	9.1	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/03/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:25	200.0	181.7	181.8	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/03/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	Zero	12/03/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:25	200.0	179.0	179.2	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass
	Zero	12/03/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass
	High	12/03/19 05:14	21.0	18.1	18.1	R-A	0.0
	Zero	12/03/19 05:20	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 14:31

Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/19 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/03/19 05:25	200.0	181.4	182.5	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/19 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	12/03/19 05:19	10.0	9.2	9.5	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:25	200.0	179.0	179.5	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/19 05:19	10.0	9.2	9.1	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/03/19 05:14	21.0	18.2	18.2	R-A	0.0
	Zero	12/03/19 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/19 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/04/19 04:24	200.0	179.0	175.6	R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/19 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/04/19 04:19	10.0	9.2	9.0	R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/19 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/19 04:25	200.0	179.0	182.2	R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/19 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/19 04:19	10.0	9.3	9.4	R-A /Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/19 05:25	200.0	181.7	182.6	R-A /Span * 100	0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/19 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/19 05:19	10.0	9.2	9.3	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/19 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/04/19 05:25	200.0	179.0	179.4	R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:31 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75 CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
Zero	12/04/19 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
High	12/04/19 05:19	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75 CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
High	12/04/19 05:14	21.0	18.1	18.1	R-A		0.0
Zero	12/04/19 05:19	21.0	0.0	0.0	R-A		0.0
Part 60 CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
Zero	12/04/19 05:14	200.0	0.0	0.1	R-A /Span * 100		0.1
High	12/04/19 05:25	200.0	181.4	183.3	R-A /Span * 100		1.0
Part 60 CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
Zero	12/04/19 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
High	12/04/19 05:19	10.0	9.2	9.5	R-A /Span * 100		3.0
Part 75 CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
Zero	12/04/19 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
High	12/04/19 05:25	200.0	179.0	179.6	R-A /Span * 100		0.3
Part 75 CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
Zero	12/04/19 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
High	12/04/19 05:19	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75 CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
High	12/04/19 05:14	21.0	18.2	18.2	R-A		0.0
Zero	12/04/19 05:19	21.0	0.0	0.0	R-A		0.0

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/01/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/02/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/03/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/03/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/04/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/05/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/06/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/07/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/07/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/08/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/09/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/10/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/11/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/12/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
10/12/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/12/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,575.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/13/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/13/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/14/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/15/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/16/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/17/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/17/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/18/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/19/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/19/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/20/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/21/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/22/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
10/23/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/23/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
10/24/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
10/24/2019 13:00	1,549.0	30.1	1,549.0	104,500.0	161.9	0.00	0.0	0.0
10/24/2019 14:00	2,985.0	48.4	2,985.0	104,500.0	311.9	0.37	0.2	0.6
10/24/2019 15:00	3,087.5	32.1	3,087.5	104,500.0	322.6	0.39	0.2	0.7
10/24/2019 16:00	3,952.3	38.2	3,953.4	104,500.0	413.1	0.50	0.3	0.8
10/24/2019 17:00	4,239.8	566.8	4,806.6	104,500.0	502.3	0.60	0.3	1.0
10/24/2019 18:00	4,198.5	71.4	4,211.4	104,500.0	440.1	0.54	0.3	0.9
10/24/2019 19:00	4,262.8	1,297.3	5,560.1	104,500.0	581.0	0.70	0.3	1.2
10/24/2019 20:00	4,279.1	317.0	4,596.1	104,500.0	480.3	0.58	0.3	1.0
10/24/2019 21:00	4,285.3	383.0	4,668.3	104,500.0	487.8	0.58	0.3	1.0
10/24/2019 22:00	4,298.1	883.2	5,181.3	104,500.0	541.4	0.65	0.3	1.1
10/24/2019 23:00	3,570.8	24.8	3,573.3	104,500.0	373.4	0.45	0.2	0.8
Average/Sum#:	3,700.7	335.7	4,015.6	104,500.0	419.6	0.54	0.3	0.9
Minimum:	1,549.0	24.8	1,549.0	104,500.0	161.9	0.37	0.2	0.6
Maximum:	4,298.1	1,297.3	5,560.1	104,500.0	581.0	0.70	0.3	1.2
%SI	54.17	54.17	54.17	0.00	54.17	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	3,335.0	44.0	3,335.0	104,500.0	348.5	0.42	0.2	0.7
10/25/2019 01:00	3,323.8	10.7	3,323.8	104,500.0	347.3	0.42	0.2	0.7
10/25/2019 02:00	3,320.7	12.9	3,320.7	104,500.0	347.0	0.42	0.2	0.7
10/25/2019 03:00	3,311.9	6.6	3,311.9	104,500.0	346.1	0.42	0.2	0.7
10/25/2019 04:00	3,314.1	8.0	3,314.1	104,500.0	346.3	0.42	0.2	0.7
10/25/2019 05:00	3,315.4	0.1	3,315.4	104,500.0	346.5	0.42	0.2	0.7
10/25/2019 06:00	4,150.8	340.1	4,399.1	104,500.0	459.7	0.56	0.3	0.9
10/25/2019 07:00	4,154.5	0.8	4,154.5	104,500.0	434.1	0.52	0.3	0.9
10/25/2019 08:00	3,686.5	10.2	3,687.0	104,500.0	385.3	0.46	0.2	0.8
10/25/2019 09:00	3,623.4	0.1	3,623.4	104,500.0	378.6	0.45	0.2	0.8
10/25/2019 10:00	3,587.8	1.6	3,587.8	104,500.0	374.9	0.45	0.2	0.7
10/25/2019 11:00	3,858.9	5.6	3,858.9	104,500.0	403.3	0.48	0.2	0.8
10/25/2019 12:00	3,859.3	15.3	3,859.3	104,500.0	403.3	0.49	0.2	0.8
10/25/2019 13:00	3,891.4	39.6	3,891.4	104,500.0	406.7	0.49	0.2	0.8
10/25/2019 14:00	3,341.1	59.3	3,341.1	104,500.0	349.1	0.43	0.2	0.7
10/25/2019 15:00	3,087.0	48.7	3,087.0	104,500.0	322.6	0.39	0.2	0.7
10/25/2019 16:00	3,847.4	42.8	3,847.4	104,500.0	402.1	0.49	0.2	0.8
10/25/2019 17:00	4,123.9	39.6	4,123.9	104,500.0	430.9	0.52	0.3	0.9
10/25/2019 18:00	3,187.7	50.0	3,187.7	104,500.0	333.1	0.41	0.2	0.7
10/25/2019 19:00	4,230.1	877.3	5,037.2	104,500.0	526.4	0.64	0.3	1.1
10/25/2019 20:00	4,251.4	1,123.9	5,375.3	104,500.0	561.7	0.67	0.3	1.1
10/25/2019 21:00	4,260.9	972.8	5,233.7	104,500.0	546.9	0.65	0.3	1.1
10/25/2019 22:00	4,299.8	942.6	5,242.4	104,500.0	547.8	0.66	0.3	1.1
10/25/2019 23:00	3,417.5	14.8	3,417.5	104,500.0	357.1	0.43	0.2	0.7
Average/Sum#:	3,699.2	194.5	3,869.8	104,500.0	404.4	0.49	0.2	0.8
Minimum:	3,087.0	0.1	3,087.0	104,500.0	322.6	0.39	0.2	0.7
Maximum:	4,299.8	1,123.9	5,375.3	104,500.0	561.7	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	3,207.7	17.6	3,207.7	104,500.0	335.2	0.40	0.2	0.7
10/26/2019 01:00	3,189.1	5.0	3,189.1	104,500.0	333.3	0.40	0.2	0.7
10/26/2019 02:00	3,186.0	4.8	3,186.0	104,500.0	332.9	0.40	0.2	0.7
10/26/2019 03:00	3,139.2	1.9	3,139.2	104,500.0	328.0	0.39	0.2	0.7
10/26/2019 04:00	3,312.8	10.4	3,312.8	104,500.0	346.2	0.42	0.2	0.7
10/26/2019 05:00	3,214.5	0.3	3,214.5	104,500.0	335.9	0.40	0.2	0.7
10/26/2019 06:00	3,363.0	0.9	3,363.0	104,500.0	351.4	0.42	0.2	0.7
10/26/2019 07:00	3,240.0	0.1	3,240.0	104,500.0	338.6	0.41	0.2	0.7
10/26/2019 08:00	3,192.9	0.0	3,192.9	104,500.0	333.7	0.40	0.2	0.7
10/26/2019 09:00	3,198.4	0.2	3,198.4	104,500.0	334.2	0.40	0.2	0.7
10/26/2019 10:00	3,155.8	1.7	3,155.8	104,500.0	329.8	0.40	0.2	0.7
10/26/2019 11:00	3,156.3	5.6	3,156.3	104,500.0	329.8	0.40	0.2	0.7
10/26/2019 12:00	3,382.3	11.0	3,382.3	104,500.0	353.5	0.43	0.2	0.7
10/26/2019 13:00	3,376.8	35.9	3,376.8	104,500.0	352.9	0.43	0.2	0.7
10/26/2019 14:00	3,289.2	52.3	3,289.2	104,500.0	343.7	0.42	0.2	0.7
10/26/2019 15:00	3,033.3	51.8	3,033.3	104,500.0	317.0	0.39	0.2	0.6
10/26/2019 16:00	3,030.3	47.2	3,030.3	104,500.0	316.7	0.39	0.2	0.6
10/26/2019 17:00	3,370.1	43.0	3,370.1	104,500.0	352.2	0.43	0.2	0.7
10/26/2019 18:00	3,296.9	43.8	3,296.9	104,500.0	344.5	0.42	0.2	0.7
10/26/2019 19:00	3,288.9	14.4	3,288.9	104,500.0	343.7	0.41	0.2	0.7
10/26/2019 20:00	3,167.5	10.0	3,167.5	104,500.0	331.0	0.40	0.2	0.7
10/26/2019 21:00	3,167.4	8.8	3,167.4	104,500.0	331.0	0.40	0.2	0.7
10/26/2019 22:00	3,161.5	6.2	3,161.5	104,500.0	330.4	0.40	0.2	0.7
10/26/2019 23:00	3,151.5	8.2	3,151.5	104,500.0	329.3	0.40	0.2	0.7
Average/Sum#:	3,219.6	15.9	3,219.6	104,500.0	336.5	0.41	0.2	0.7
Minimum:	3,030.3	0.0	3,030.3	104,500.0	316.7	0.39	0.2	0.6
Maximum:	3,382.3	52.3	3,382.3	104,500.0	353.5	0.43	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	3,554.8	4.8	3,554.8	104,500.0	371.5	0.45	0.2	0.7
10/27/2019 01:00	3,268.2	3.3	3,268.2	104,500.0	341.5	0.41	0.2	0.7
10/27/2019 02:00	3,439.9	2.9	3,439.9	104,500.0	359.5	0.43	0.2	0.7
10/27/2019 03:00	3,676.1	1.9	3,676.1	104,500.0	384.2	0.46	0.2	0.8
10/27/2019 04:00	3,682.0	0.7	3,682.0	104,500.0	384.8	0.46	0.2	0.8
10/27/2019 05:00	3,497.4	1.2	3,497.4	104,500.0	365.5	0.44	0.2	0.7
10/27/2019 06:00	3,676.6	1.0	3,676.6	104,500.0	384.2	0.46	0.2	0.8
10/27/2019 07:00	3,679.9	0.0	3,679.9	104,500.0	384.5	0.46	0.2	0.8
10/27/2019 08:00	3,678.9	0.0	3,678.9	104,500.0	384.4	0.46	0.2	0.8
10/27/2019 09:00	3,118.0	0.3	3,118.0	104,500.0	325.8	0.39	0.2	0.7
10/27/2019 10:00	2,967.4	0.4	2,967.4	104,500.0	310.1	0.37	0.2	0.6
10/27/2019 11:00	2,972.2	0.2	2,972.2	104,500.0	310.6	0.37	0.2	0.6
10/27/2019 12:00	3,005.5	1.2	3,005.5	104,500.0	314.1	0.38	0.2	0.6
10/27/2019 13:00	3,035.5	16.1	3,035.5	104,500.0	317.2	0.38	0.2	0.6
10/27/2019 14:00	3,013.5	17.6	3,013.5	104,500.0	314.9	0.38	0.2	0.6
10/27/2019 15:00	3,602.1	8.4	3,602.1	104,500.0	376.4	0.45	0.2	0.8
10/27/2019 16:00	3,277.9	9.5	3,277.9	104,500.0	342.5	0.41	0.2	0.7
10/27/2019 17:00	3,267.8	21.1	3,267.8	104,500.0	341.5	0.41	0.2	0.7
10/27/2019 18:00	3,417.8	8.2	3,417.8	104,500.0	357.2	0.43	0.2	0.7
10/27/2019 19:00	3,119.8	7.4	3,119.8	104,500.0	326.0	0.39	0.2	0.7
10/27/2019 20:00	3,279.6	3.2	3,279.6	104,500.0	342.7	0.41	0.2	0.7
10/27/2019 21:00	3,495.3	2.3	3,495.3	104,500.0	365.3	0.44	0.2	0.7
10/27/2019 22:00	3,352.2	1.4	3,352.2	104,500.0	350.3	0.42	0.2	0.7
10/27/2019 23:00	3,191.5	8.2	3,191.5	104,500.0	333.5	0.40	0.2	0.7
Average/Sum#:	3,344.6	5.1	3,344.6	104,500.0	349.5	0.42	0.2	0.7
Minimum:	2,967.4	0.0	2,967.4	104,500.0	310.1	0.37	0.2	0.6
Maximum:	3,682.0	21.1	3,682.0	104,500.0	384.8	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	3,191.1	2.0	3,191.1	104,500.0	333.5	0.40	0.2	0.7
10/28/2019 01:00	3,184.2	0.5	3,184.2	104,500.0	332.7	0.40	0.2	0.7
10/28/2019 02:00	3,189.7	0.2	3,189.7	104,500.0	333.3	0.40	0.2	0.7
10/28/2019 03:00	3,237.6	0.4	3,237.6	104,500.0	338.3	0.41	0.2	0.7
10/28/2019 04:00	4,350.1	253.9	4,571.0	104,500.0	477.7	0.58	0.3	1.0
10/28/2019 05:00	4,353.8	452.9	4,806.7	104,500.0	502.3	0.60	0.3	1.0
10/28/2019 06:00	4,365.6	1,079.8	5,445.4	104,500.0	569.0	0.68	0.3	1.1
10/28/2019 07:00	4,374.8	1,080.2	5,455.0	104,500.0	570.0	0.68	0.3	1.1
10/28/2019 08:00	3,951.8	87.1	3,963.1	104,500.0	414.1	0.51	0.3	0.8
10/28/2019 09:00	3,887.9	0.3	3,887.9	104,500.0	406.3	0.49	0.2	0.8
10/28/2019 10:00	3,869.7	1.4	3,869.7	104,500.0	404.4	0.49	0.2	0.8
10/28/2019 11:00	4,176.4	1.8	4,176.4	104,500.0	436.4	0.53	0.3	0.9
10/28/2019 12:00	3,584.7	2.1	3,584.7	104,500.0	374.6	0.45	0.2	0.8
10/28/2019 13:00	3,566.7	21.7	3,566.7	104,500.0	372.7	0.45	0.2	0.8
10/28/2019 14:00	3,589.7	33.8	3,589.7	104,500.0	375.1	0.45	0.2	0.8
10/28/2019 15:00	3,746.8	31.9	3,746.8	104,500.0	391.5	0.47	0.2	0.8
10/28/2019 16:00	3,696.8	21.3	3,696.8	104,500.0	386.3	0.47	0.2	0.8
10/28/2019 17:00	3,117.7	53.1	3,117.7	104,500.0	325.8	0.40	0.2	0.7
10/28/2019 18:00	4,160.1	422.6	4,498.2	104,500.0	470.1	0.58	0.3	1.0
10/28/2019 19:00	4,179.7	174.7	4,331.7	104,500.0	452.7	0.54	0.3	0.9
10/28/2019 20:00	3,571.4	10.3	3,571.4	104,500.0	373.2	0.45	0.2	0.7
10/28/2019 21:00	4,228.7	379.1	4,558.5	104,500.0	476.4	0.58	0.3	1.0
10/28/2019 22:00	4,239.0	159.0	4,358.3	104,500.0	455.4	0.55	0.3	0.9
10/28/2019 23:00	4,090.2	6.7	4,090.2	104,500.0	427.4	0.51	0.3	0.9
Average/Sum#:	3,829.3	178.2	3,987.0	104,500.0	416.6	0.50	0.2	0.9
Minimum:	3,117.7	0.2	3,117.7	104,500.0	325.8	0.40	0.2	0.7
Maximum:	4,374.8	1,080.2	5,455.0	104,500.0	570.0	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	3,457.5	8.2	3,457.5	104,500.0	361.3	0.43	0.2	0.7
10/29/2019 01:00	3,306.0	22.0	3,306.0	104,500.0	345.5	0.42	0.2	0.7
10/29/2019 02:00	3,179.5	1.7	3,179.5	104,500.0	332.3	0.40	0.2	0.7
10/29/2019 03:00	3,788.8	0.0	3,788.8	104,500.0	395.9	0.48	0.2	0.8
10/29/2019 04:00	4,322.0	1,352.0	5,430.6	104,500.0	567.5	0.71	0.4	1.2
10/29/2019 05:00	4,374.9	2,002.0	6,376.9	104,500.0	666.4	0.80	0.4	1.3
10/29/2019 06:00	4,414.2	2,006.8	6,421.0	104,500.0	671.0	0.81	0.4	1.3
10/29/2019 07:00	4,399.9	2,010.7	6,410.6	104,500.0	669.9	0.80	0.4	1.3
10/29/2019 08:00	4,338.0	1,895.6	6,233.6	104,500.0	651.4	0.78	0.4	1.3
10/29/2019 09:00	4,295.1	1,894.0	6,189.1	104,500.0	646.8	0.78	0.4	1.3
10/29/2019 10:00	4,254.5	1,984.0	6,238.5	104,500.0	651.9	0.78	0.4	1.3
10/29/2019 11:00	4,194.1	1,928.5	6,122.6	104,500.0	639.8	0.77	0.4	1.3
10/29/2019 12:00	4,162.5	1,919.1	6,081.6	104,500.0	635.5	0.76	0.4	1.3
10/29/2019 13:00	4,155.0	1,916.8	6,071.8	104,500.0	634.5	0.76	0.4	1.3
10/29/2019 14:00	4,156.7	1,316.0	5,235.8	104,500.0	547.1	0.69	0.3	1.1
10/29/2019 15:00	4,160.3	1,862.1	6,022.4	104,500.0	629.3	0.76	0.4	1.3
10/29/2019 16:00	4,175.1	1,326.6	5,501.7	104,500.0	574.9	0.69	0.3	1.1
10/29/2019 17:00	4,203.8	1,281.6	5,485.4	104,500.0	573.2	0.69	0.3	1.1
10/29/2019 18:00	4,228.4	1,065.3	5,293.7	104,500.0	553.2	0.66	0.3	1.1
10/29/2019 19:00	4,252.2	863.1	5,115.3	104,500.0	534.5	0.64	0.3	1.1
10/29/2019 20:00	4,282.9	1,053.6	5,336.5	104,500.0	557.7	0.67	0.3	1.1
10/29/2019 21:00	4,304.6	1,143.2	5,447.8	104,500.0	569.3	0.68	0.3	1.1
10/29/2019 22:00	4,317.4	1,102.4	5,419.8	104,500.0	566.4	0.68	0.3	1.1
10/29/2019 23:00	4,090.4	44.0	4,091.7	104,500.0	427.6	0.52	0.3	0.9
Average/Sum#:	4,117.2	1,250.0	5,344.1	104,500.0	558.5	0.67	0.3	1.1
Minimum:	3,179.5	0.0	3,179.5	104,500.0	332.3	0.40	0.2	0.7
Maximum:	4,414.2	2,010.7	6,421.0	104,500.0	671.0	0.81	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
10/30/2019 00:00	3,325.6	39.3	3,325.6	104,500.0	347.5	0.42	0.2	0.7
10/30/2019 01:00	3,339.8	28.9	3,339.8	104,500.0	349.0	0.42	0.2	0.7
10/30/2019 02:00	3,458.0	19.8	3,458.0	104,500.0	361.4	0.44	0.2	0.7
10/30/2019 03:00	3,933.0	10.4	3,933.2	104,500.0	411.0	0.50	0.2	0.8
10/30/2019 04:00	4,426.7	893.9	5,320.6	104,500.0	556.0	0.67	0.3	1.1
10/30/2019 05:00	4,428.8	668.6	5,097.4	104,500.0	532.7	0.64	0.3	1.1
10/30/2019 06:00	4,442.9	580.3	5,023.2	104,500.0	524.9	0.63	0.3	1.1
10/30/2019 07:00	4,013.7	511.5	4,310.4	104,500.0	450.4	0.57	0.3	0.9
10/30/2019 08:00	2,979.6	0.8	2,979.6	104,500.0	311.4	0.38	0.2	0.6
10/30/2019 09:00	2,993.0	2.7	2,993.0	104,500.0	312.8	0.38	0.2	0.6
10/30/2019 10:00	2,991.2	2.8	2,991.2	104,500.0	312.6	0.38	0.2	0.6
10/30/2019 11:00	3,204.6	9.4	3,204.6	104,500.0	334.9	0.40	0.2	0.7
10/30/2019 12:00	4,220.7	480.2	4,691.3	104,500.0	490.2	0.59	0.3	1.0
10/30/2019 13:00	4,200.1	595.1	4,795.2	104,500.0	501.1	0.60	0.3	1.0
10/30/2019 14:00	4,184.5	1,511.0	5,695.5	104,500.0	595.2	0.71	0.4	1.2
10/30/2019 15:00	4,171.7	1,601.0	5,772.7	104,500.0	603.2	0.72	0.4	1.2
10/30/2019 16:00	4,180.8	556.0	4,736.8	104,500.0	495.0	0.59	0.3	1.0
10/30/2019 17:00	4,211.9	1,097.1	5,309.0	104,500.0	554.8	0.67	0.3	1.1
10/30/2019 18:00	4,242.6	879.9	5,122.5	104,500.0	535.3	0.64	0.3	1.1
10/30/2019 19:00	4,292.0	477.9	4,769.9	104,500.0	498.5	0.60	0.3	1.0
10/30/2019 20:00	4,302.5	784.9	5,087.4	104,500.0	531.6	0.64	0.3	1.1
10/30/2019 21:00	4,327.1	424.1	4,730.0	104,500.0	494.3	0.60	0.3	1.0
10/30/2019 22:00	4,217.7	41.6	4,217.7	104,500.0	440.7	0.54	0.3	0.9
10/30/2019 23:00	4,013.4	26.0	4,013.4	104,500.0	419.4	0.51	0.3	0.8
Average/Sum#:	3,920.9	468.5	4,371.6	104,500.0	456.8	0.55	0.3	0.9
Minimum:	2,979.6	0.8	2,979.6	104,500.0	311.4	0.38	0.2	0.6
Maximum:	4,442.9	1,601.0	5,772.7	104,500.0	603.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	3,447.4	19.9	3,447.4	104,500.0	360.3	0.43	0.2	0.7
10/31/2019 01:00	3,383.8	8.2	3,383.8	104,500.0	353.6	0.43	0.2	0.7
10/31/2019 02:00	3,409.6	9.4	3,409.6	104,500.0	356.3	0.43	0.2	0.7
10/31/2019 03:00	3,717.7	5.5	3,717.8	104,500.0	388.5	0.47	0.2	0.8
10/31/2019 04:00	4,438.1	669.0	5,107.1	104,500.0	533.7	0.64	0.3	1.1
10/31/2019 05:00	4,437.2	1,001.5	5,438.7	104,500.0	568.3	0.68	0.3	1.1
10/31/2019 06:00	4,454.0	1,580.0	6,034.0	104,500.0	630.6	0.76	0.4	1.3
10/31/2019 07:00	4,440.9	1,708.2	6,149.1	104,500.0	642.6	0.77	0.4	1.3
10/31/2019 08:00	4,414.4	1,693.0	6,107.4	104,500.0	638.2	0.77	0.4	1.3
10/31/2019 09:00	4,338.0	1,764.7	6,102.7	104,500.0	637.7	0.77	0.4	1.3
10/31/2019 10:00	4,293.2	1,475.2	5,768.4	104,500.0	602.8	0.72	0.4	1.2
10/31/2019 11:00	4,239.2	1,156.8	5,396.0	104,500.0	563.9	0.68	0.3	1.1
10/31/2019 12:00	4,208.9	845.9	5,054.8	104,500.0	528.2	0.64	0.3	1.1
10/31/2019 13:00	4,179.0	1,913.2	6,092.2	104,500.0	636.6	0.76	0.4	1.3
10/31/2019 14:00	4,163.5	1,620.6	5,784.1	104,500.0	604.4	0.73	0.4	1.2
10/31/2019 15:00	4,159.7	1,629.9	5,789.6	104,500.0	605.0	0.73	0.4	1.2
10/31/2019 16:00	4,175.1	1,966.8	6,141.9	104,500.0	641.8	0.77	0.4	1.3
10/31/2019 17:00	4,200.2	1,925.4	6,125.6	104,500.0	640.1	0.77	0.4	1.3
10/31/2019 18:00	4,229.8	1,759.6	5,989.4	104,500.0	625.9	0.75	0.4	1.3
10/31/2019 19:00	4,253.6	392.0	4,645.6	104,500.0	485.5	0.58	0.3	1.0
10/31/2019 20:00	4,284.0	335.1	4,619.1	104,500.0	482.7	0.58	0.3	1.0
10/31/2019 21:00	4,291.4	280.8	4,552.5	104,500.0	475.7	0.58	0.3	1.0
10/31/2019 22:00	3,690.1	33.7	3,690.1	104,500.0	385.6	0.47	0.2	0.8
10/31/2019 23:00	3,259.7	48.3	3,259.7	104,500.0	340.6	0.42	0.2	0.7
Average/Sum#:	4,087.9	993.4	5,075.3	104,500.0	530.4	0.64	0.3	1.1
Minimum:	3,259.7	5.5	3,259.7	104,500.0	340.6	0.42	0.2	0.7
Maximum:	4,454.0	1,966.8	6,149.1	104,500.0	642.6	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	3,020.1	48.4	3,020.1	104,500.0	315.6	0.39	0.2	0.7
11/01/2019 01:00	3,029.1	48.5	3,029.1	106,000.0	321.1	0.39	0.2	0.7
11/01/2019 02:00	3,154.6	48.5	3,154.6	106,000.0	334.4	0.41	0.2	0.7
11/01/2019 03:00	4,013.5	50.1	4,016.0	106,000.0	425.7	0.52	0.3	0.9
11/01/2019 04:00	4,405.7	593.0	4,998.7	106,000.0	529.9	0.64	0.3	1.1
11/01/2019 05:00	4,408.8	1,098.6	5,507.4	106,000.0	583.8	0.70	0.4	1.2
11/01/2019 06:00	4,415.6	1,695.4	6,111.0	106,000.0	647.8	0.78	0.4	1.3
11/01/2019 07:00	4,409.0	565.1	4,974.1	106,000.0	527.3	0.63	0.3	1.1
11/01/2019 08:00	4,341.2	628.0	4,969.2	106,000.0	526.7	0.63	0.3	1.1
11/01/2019 09:00	4,295.6	903.9	5,199.5	106,000.0	551.1	0.66	0.3	1.1
11/01/2019 10:00	4,258.4	1,020.2	5,278.6	106,000.0	559.5	0.67	0.3	1.1
11/01/2019 11:00	4,218.3	345.5	4,563.8	106,000.0	483.8	0.58	0.3	1.0
11/01/2019 12:00	4,170.9	113.7	4,210.7	106,000.0	446.3	0.55	0.3	0.9
11/01/2019 13:00	4,152.7	46.4	4,152.7	106,000.0	440.2	0.53	0.3	0.9
11/01/2019 14:00	4,144.5	381.0	4,498.8	106,000.0	476.9	0.58	0.3	1.0
11/01/2019 15:00	4,140.5	779.1	4,919.6	106,000.0	521.5	0.63	0.3	1.0
11/01/2019 16:00	4,145.5	267.4	4,412.9	106,000.0	467.8	0.56	0.3	0.9
11/01/2019 17:00	4,163.8	484.1	4,647.9	106,000.0	492.7	0.59	0.3	1.0
11/01/2019 18:00	4,204.9	64.9	4,210.1	106,000.0	446.3	0.54	0.3	0.9
11/01/2019 19:00	4,040.6	52.4	4,040.6	106,000.0	428.3	0.52	0.3	0.9
11/01/2019 20:00	4,081.0	63.9	4,084.2	106,000.0	432.9	0.53	0.3	0.9
11/01/2019 21:00	4,305.0	1,013.0	5,318.0	106,000.0	563.7	0.68	0.3	1.1
11/01/2019 22:00	4,326.6	962.1	5,288.7	106,000.0	560.6	0.67	0.3	1.1
11/01/2019 23:00	4,321.6	634.8	4,956.4	106,000.0	525.4	0.63	0.3	1.1
Average/Sum#:	4,090.3	496.2	4,565.1	105,937.5	483.7	0.58	0.3	1.0
Minimum:	3,020.1	46.4	3,020.1	104,500.0	315.6	0.39	0.2	0.7
Maximum:	4,415.6	1,695.4	6,111.0	106,000.0	647.8	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	4,092.0	41.9	4,094.1	106,000.0	434.0	0.53	0.3	0.9
11/02/2019 01:00	3,618.1	17.7	3,618.1	106,000.0	383.5	0.46	0.2	0.8
11/02/2019 02:00	3,689.7	21.1	3,689.7	106,000.0	391.1	0.47	0.2	0.8
11/02/2019 03:00	3,541.9	27.2	3,541.9	106,000.0	375.4	0.45	0.2	0.8
11/02/2019 04:00	4,104.2	23.1	4,105.4	106,000.0	435.2	0.53	0.3	0.9
11/02/2019 05:00	4,398.2	496.6	4,894.8	106,000.0	518.8	0.62	0.3	1.0
11/02/2019 06:00	4,405.9	997.3	5,403.2	106,000.0	572.7	0.69	0.3	1.1
11/02/2019 07:00	3,835.4	15.9	3,836.2	106,000.0	406.6	0.49	0.2	0.8
11/02/2019 08:00	3,728.2	2.1	3,728.2	106,000.0	395.2	0.47	0.2	0.8
11/02/2019 09:00	3,059.9	2.7	3,059.9	106,000.0	324.3	0.39	0.2	0.7
11/02/2019 10:00	3,047.0	9.5	3,047.0	106,000.0	323.0	0.39	0.2	0.6
11/02/2019 11:00	3,012.8	12.0	3,012.8	106,000.0	319.4	0.39	0.2	0.6
11/02/2019 12:00	3,160.5	23.1	3,160.5	106,000.0	335.0	0.41	0.2	0.7
11/02/2019 13:00	3,346.9	37.9	3,346.9	106,000.0	354.8	0.42	0.2	0.7
11/02/2019 14:00	3,806.4	75.3	3,812.4	106,000.0	404.1	0.50	0.2	0.8
11/02/2019 15:00	4,086.3	1,866.0	5,952.3	106,000.0	630.9	0.76	0.4	1.3
11/02/2019 16:00	4,103.7	614.1	4,717.8	106,000.0	500.1	0.60	0.3	1.0
11/02/2019 17:00	4,123.0	1,789.1	5,912.1	106,000.0	626.7	0.75	0.4	1.3
11/02/2019 18:00	4,128.4	85.9	4,135.3	106,000.0	438.3	0.54	0.3	0.9
11/02/2019 19:00	3,897.9	57.5	3,899.1	106,000.0	413.3	0.51	0.3	0.8
11/02/2019 20:00	4,226.5	246.6	4,473.1	106,000.0	474.1	0.57	0.3	0.9
11/02/2019 21:00	4,258.7	842.2	5,100.9	106,000.0	540.7	0.65	0.3	1.1
11/02/2019 22:00	4,294.7	732.8	5,027.5	106,000.0	532.9	0.64	0.3	1.1
11/02/2019 23:00	3,313.8	58.1	3,316.7	106,000.0	351.6	0.43	0.2	0.7
Average/Sum#:	3,803.3	337.3	4,120.2	106,000.0	436.7	0.53	0.3	0.9
Minimum:	3,012.8	2.1	3,012.8	106,000.0	319.4	0.39	0.2	0.6
Maximum:	4,405.9	1,866.0	5,952.3	106,000.0	630.9	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	3,137.5	47.8	3,137.5	106,000.0	332.6	0.41	0.2	0.7
11/03/2019 01:00	3,163.9	11.1	3,163.9	106,000.0	335.4	0.40	0.2	0.7
11/03/2019 02:00	3,160.9	33.9	3,160.9	106,000.0	335.1	0.41	0.2	0.7
11/03/2019 03:00	3,158.3	28.0	3,158.3	106,000.0	334.8	0.41	0.2	0.7
11/03/2019 04:00	3,153.7	11.5	3,153.7	106,000.0	334.3	0.40	0.2	0.7
11/03/2019 05:00	3,341.7	15.1	3,341.7	106,000.0	354.2	0.43	0.2	0.7
11/03/2019 06:00	3,233.2	3.5	3,233.2	106,000.0	342.7	0.41	0.2	0.7
11/03/2019 07:00	3,429.9	0.6	3,429.9	106,000.0	363.6	0.44	0.2	0.7
11/03/2019 08:00	3,835.4	0.1	3,835.4	106,000.0	406.6	0.49	0.2	0.8
11/03/2019 09:00	4,258.7	188.0	4,431.7	106,000.0	469.8	0.57	0.3	0.9
11/03/2019 10:00	4,212.1	342.9	4,555.0	106,000.0	482.8	0.58	0.3	1.0
11/03/2019 11:00	4,157.4	1,025.3	5,182.7	106,000.0	549.4	0.66	0.3	1.1
11/03/2019 12:00	4,124.1	620.2	4,744.3	106,000.0	502.9	0.60	0.3	1.0
11/03/2019 13:00	4,088.0	1,057.8	5,145.8	106,000.0	545.5	0.66	0.3	1.1
11/03/2019 14:00	4,069.6	984.1	5,053.7	106,000.0	535.7	0.64	0.3	1.1
11/03/2019 15:00	4,064.4	1,448.1	5,512.5	106,000.0	584.3	0.70	0.4	1.2
11/03/2019 16:00	4,076.6	1,376.7	5,453.3	106,000.0	578.0	0.69	0.3	1.2
11/03/2019 17:00	3,461.5	165.4	3,486.3	106,000.0	369.5	0.46	0.2	0.8
11/03/2019 18:00	3,335.4	58.3	3,335.4	106,000.0	353.6	0.43	0.2	0.7
11/03/2019 19:00	3,000.6	51.8	3,000.6	106,000.0	318.1	0.39	0.2	0.6
11/03/2019 20:00	3,022.1	26.1	3,022.1	106,000.0	320.3	0.39	0.2	0.6
11/03/2019 21:00	3,103.9	28.3	3,103.9	106,000.0	329.0	0.40	0.2	0.7
11/03/2019 22:00	3,728.0	36.3	3,728.0	106,000.0	395.2	0.48	0.2	0.8
11/03/2019 23:00	3,135.2	50.9	3,135.2	106,000.0	332.3	0.40	0.2	0.7
Average/Sum#:	3,560.5	317.2	3,854.4	106,000.0	408.6	0.49	0.2	0.8
Minimum:	3,000.6	0.1	3,000.6	106,000.0	318.1	0.39	0.2	0.6
Maximum:	4,258.7	1,448.1	5,512.5	106,000.0	584.3	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	3,130.5	21.6	3,130.5	106,000.0	331.8	0.40	0.2	0.7
11/04/2019 01:00	3,140.5	14.7	3,140.5	106,000.0	332.9	0.40	0.2	0.7
11/04/2019 02:00	3,161.0	9.5	3,161.0	106,000.0	335.1	0.40	0.2	0.7
11/04/2019 03:00	3,163.0	7.1	3,163.0	106,000.0	335.3	0.40	0.2	0.7
11/04/2019 04:00	3,209.2	17.1	3,209.2	106,000.0	340.2	0.41	0.2	0.7
11/04/2019 05:00	3,577.3	12.4	3,577.3	106,000.0	379.2	0.46	0.2	0.8
11/04/2019 06:00	3,768.2	7.1	3,768.2	106,000.0	399.4	0.48	0.2	0.8
11/04/2019 07:00	4,097.4	2.7	4,097.4	106,000.0	434.3	0.52	0.3	0.9
11/04/2019 08:00	4,307.9	1,352.6	5,592.9	106,000.0	592.8	0.72	0.4	1.2
11/04/2019 09:00	4,254.5	1,849.2	6,103.7	106,000.0	647.0	0.78	0.4	1.3
11/04/2019 10:00	4,199.2	1,892.6	6,091.8	106,000.0	645.7	0.78	0.4	1.3
11/04/2019 11:00	4,152.7	1,548.6	5,701.3	106,000.0	604.3	0.72	0.4	1.2
11/04/2019 12:00	4,108.7	1,441.0	5,549.7	106,000.0	588.3	0.71	0.4	1.2
11/04/2019 13:00	4,076.6	1,523.9	5,600.5	106,000.0	593.7	0.71	0.4	1.2
11/04/2019 14:00	4,054.4	1,409.7	5,464.1	106,000.0	579.2	0.69	0.3	1.2
11/04/2019 15:00	4,054.4	1,431.9	5,486.3	106,000.0	581.5	0.70	0.3	1.2
11/04/2019 16:00	4,068.3	1,390.5	5,458.8	106,000.0	578.6	0.69	0.3	1.2
11/04/2019 17:00	4,098.7	418.1	4,504.3	106,000.0	477.5	0.57	0.3	1.0
11/04/2019 18:00	4,106.5	60.2	4,106.5	106,000.0	435.3	0.53	0.3	0.9
11/04/2019 19:00	3,591.4	52.8	3,591.4	106,000.0	380.7	0.47	0.2	0.8
11/04/2019 20:00	3,300.2	50.8	3,300.2	106,000.0	349.8	0.43	0.2	0.7
11/04/2019 21:00	3,812.2	30.9	3,812.2	106,000.0	404.1	0.49	0.2	0.8
11/04/2019 22:00	3,548.8	42.2	3,548.8	106,000.0	376.2	0.46	0.2	0.8
11/04/2019 23:00	3,025.5	24.1	3,025.5	106,000.0	320.7	0.39	0.2	0.6
Average/Sum#:	3,750.3	608.8	4,341.0	106,000.0	460.2	0.55	0.3	0.9
Minimum:	3,025.5	2.7	3,025.5	106,000.0	320.7	0.39	0.2	0.6
Maximum:	4,307.9	1,892.6	6,103.7	106,000.0	647.0	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	3,249.4	46.1	3,249.4	106,000.0	344.4	0.42	0.2	0.7
11/05/2019 01:00	3,197.5	31.8	3,197.5	106,000.0	338.9	0.41	0.2	0.7
11/05/2019 02:00	3,185.4	27.2	3,185.4	106,000.0	337.7	0.41	0.2	0.7
11/05/2019 03:00	3,171.3	14.3	3,171.3	106,000.0	336.2	0.41	0.2	0.7
11/05/2019 04:00	3,254.9	15.3	3,254.9	106,000.0	345.0	0.41	0.2	0.7
11/05/2019 05:00	3,742.3	11.8	3,742.3	106,000.0	396.7	0.48	0.2	0.8
11/05/2019 06:00	4,351.7	920.7	5,244.8	106,000.0	555.9	0.67	0.3	1.1
11/05/2019 07:00	4,336.1	790.4	5,126.5	106,000.0	543.4	0.65	0.3	1.1
11/05/2019 08:00	4,302.1	912.0	5,214.1	106,000.0	552.7	0.66	0.3	1.1
11/05/2019 09:00	4,244.1	1,251.6	5,495.7	106,000.0	582.5	0.70	0.3	1.2
11/05/2019 10:00	4,188.5	662.4	4,850.9	106,000.0	514.2	0.62	0.3	1.0
11/05/2019 11:00	4,143.8	658.6	4,802.4	106,000.0	509.1	0.61	0.3	1.0
11/05/2019 12:00	4,087.4	615.1	4,702.5	106,000.0	498.5	0.60	0.3	1.0
11/05/2019 13:00	4,054.5	540.9	4,487.2	106,000.0	475.6	0.58	0.3	1.0
11/05/2019 14:00	3,469.1	50.6	3,469.1	106,000.0	367.7	0.45	0.2	0.7
11/05/2019 15:00	4,144.2	181.0	4,180.4	106,000.0	443.1	0.55	0.3	0.9
11/05/2019 16:00	4,246.3	584.6	4,450.9	106,000.0	471.8	0.62	0.3	1.0
11/05/2019 17:00	4,258.3	55.9	4,258.3	106,000.0	451.4	0.55	0.3	0.9
11/05/2019 18:00	4,252.4	53.7	4,252.4	106,000.0	450.8	0.55	0.3	0.9
11/05/2019 19:00	4,050.4	51.7	4,050.4	106,000.0	429.3	0.52	0.3	0.9
11/05/2019 20:00	3,929.2	43.0	3,929.2	106,000.0	416.5	0.50	0.3	0.8
11/05/2019 21:00	3,099.4	18.2	3,099.4	106,000.0	328.5	0.40	0.2	0.7
11/05/2019 22:00	3,029.0	40.5	3,029.0	106,000.0	321.1	0.39	0.2	0.6
11/05/2019 23:00	2,991.7	19.5	2,991.7	106,000.0	317.1	0.38	0.2	0.6
Average/Sum#:	3,790.8	316.5	4,059.8	106,000.0	430.3	0.52	0.3	0.9
Minimum:	2,991.7	11.8	2,991.7	106,000.0	317.1	0.38	0.2	0.6
Maximum:	4,351.7	1,251.6	5,495.7	106,000.0	582.5	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	3,009.1	4.5	3,009.1	106,000.0	319.0	0.38	0.2	0.6
11/06/2019 01:00	2,978.1	32.8	2,978.1	106,000.0	315.7	0.38	0.2	0.6
11/06/2019 02:00	2,945.6	40.5	2,945.6	106,000.0	312.2	0.38	0.2	0.6
11/06/2019 03:00	2,910.4	39.5	2,910.4	106,000.0	308.5	0.38	0.2	0.6
11/06/2019 04:00	2,868.6	21.6	2,868.6	106,000.0	304.1	0.37	0.2	0.6
11/06/2019 05:00	2,889.8	6.6	2,889.8	106,000.0	306.3	0.37	0.2	0.6
11/06/2019 06:00	3,609.9	11.5	3,609.9	106,000.0	382.6	0.46	0.2	0.8
11/06/2019 07:00	3,704.8	3.3	3,704.8	106,000.0	392.7	0.47	0.2	0.8
11/06/2019 08:00	3,330.7	4.3	3,330.7	106,000.0	353.1	0.42	0.2	0.7
11/06/2019 09:00	3,436.9	3.2	3,436.9	106,000.0	364.3	0.44	0.2	0.7
11/06/2019 10:00	3,441.3	4.7	3,441.3	106,000.0	364.8	0.44	0.2	0.7
11/06/2019 11:00	3,590.0	12.9	3,590.0	106,000.0	380.5	0.46	0.2	0.8
11/06/2019 12:00	3,763.3	35.5	3,763.3	106,000.0	398.9	0.48	0.2	0.8
11/06/2019 13:00	3,787.1	39.1	3,787.1	106,000.0	401.4	0.49	0.2	0.8
11/06/2019 14:00	3,984.2	53.7	3,985.3	106,000.0	422.4	0.52	0.3	0.9
11/06/2019 15:00	4,248.0	552.1	4,800.1	106,000.0	508.8	0.61	0.3	1.0
11/06/2019 16:00	4,249.0	654.7	4,903.7	106,000.0	519.8	0.63	0.3	1.0
11/06/2019 17:00	4,263.3	1,521.8	5,785.1	106,000.0	613.2	0.74	0.4	1.2
11/06/2019 18:00	4,272.4	1,574.2	5,846.6	106,000.0	619.7	0.74	0.4	1.2
11/06/2019 19:00	4,283.4	1,416.0	5,699.4	106,000.0	604.1	0.72	0.4	1.2
11/06/2019 20:00	4,301.2	1,472.9	5,774.1	106,000.0	612.1	0.73	0.4	1.2
11/06/2019 21:00	4,301.7	864.3	5,096.9	106,000.0	540.3	0.66	0.3	1.1
11/06/2019 22:00	3,507.4	33.1	3,507.4	106,000.0	371.8	0.45	0.2	0.8
11/06/2019 23:00	3,184.2	39.7	3,184.2	106,000.0	337.5	0.41	0.2	0.7
Average/Sum#:	3,619.2	351.8	3,952.0	106,000.0	418.9	0.51	0.3	0.8
Minimum:	2,868.6	3.2	2,868.6	106,000.0	304.1	0.37	0.2	0.6
Maximum:	4,301.7	1,574.2	5,846.6	106,000.0	619.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	4,321.2	1,278.9	5,574.5	106,000.0	590.9	0.71	0.4	1.2
11/07/2019 01:00	4,330.0	791.9	5,121.9	106,000.0	542.9	0.65	0.3	1.1
11/07/2019 02:00	4,343.3	758.9	5,102.2	106,000.0	540.8	0.65	0.3	1.1
11/07/2019 03:00	4,369.6	715.1	5,084.7	106,000.0	539.0	0.65	0.3	1.1
11/07/2019 04:00	4,378.0	664.1	5,042.1	106,000.0	534.5	0.64	0.3	1.1
11/07/2019 05:00	4,366.5	1,518.6	5,885.1	106,000.0	623.8	0.75	0.4	1.2
11/07/2019 06:00	4,360.5	1,730.6	6,091.1	106,000.0	645.7	0.77	0.4	1.3
11/07/2019 07:00	4,361.4	1,722.0	6,083.4	106,000.0	644.8	0.77	0.4	1.3
11/07/2019 08:00	4,312.4	934.3	5,246.7	106,000.0	556.2	0.67	0.3	1.1
11/07/2019 09:00	4,262.2	1,248.3	5,510.5	106,000.0	584.1	0.70	0.4	1.2
11/07/2019 10:00	4,187.9	1,111.0	5,210.0	106,000.0	552.3	0.67	0.3	1.1
11/07/2019 11:00	3,234.4	33.8	3,234.4	106,000.0	342.8	0.42	0.2	0.7
11/07/2019 12:00	3,033.7	32.6	3,033.7	106,000.0	321.6	0.39	0.2	0.7
11/07/2019 13:00	3,003.8	28.4	3,003.8	106,000.0	318.4	0.38	0.2	0.6
11/07/2019 14:00	2,999.6	38.7	2,999.6	106,000.0	318.0	0.39	0.2	0.6
11/07/2019 15:00	3,088.0	49.5	3,088.0	106,000.0	327.3	0.40	0.2	0.7
11/07/2019 16:00	4,023.7	50.6	4,023.7	106,000.0	426.5	0.52	0.3	0.9
11/07/2019 17:00	4,226.0	73.6	4,233.4	106,000.0	448.7	0.55	0.3	0.9
11/07/2019 18:00	4,298.5	192.9	4,491.4	106,000.0	476.1	0.57	0.3	1.0
11/07/2019 19:00	4,240.9	175.1	4,393.2	106,000.0	465.7	0.56	0.3	0.9
11/07/2019 20:00	3,788.5	54.0	3,788.5	106,000.0	401.6	0.49	0.2	0.8
11/07/2019 21:00	4,289.9	1,284.0	5,291.4	106,000.0	560.9	0.71	0.4	1.2
11/07/2019 22:00	4,346.2	1,805.6	6,151.8	106,000.0	652.1	0.78	0.4	1.3
11/07/2019 23:00	4,354.6	824.4	5,179.0	106,000.0	549.0	0.66	0.3	1.1
Average/Sum#:	4,021.7	713.2	4,702.7	106,000.0	498.5	0.60	0.3	1.0
Minimum:	2,999.6	28.4	2,999.6	106,000.0	318.0	0.38	0.2	0.6
Maximum:	4,378.0	1,805.6	6,151.8	106,000.0	652.1	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	4,379.9	764.8	5,144.7	106,000.0	545.3	0.66	0.3	1.1
11/08/2019 01:00	4,388.2	288.4	4,676.6	106,000.0	495.7	0.60	0.3	1.0
11/08/2019 02:00	4,379.1	232.4	4,611.5	106,000.0	488.8	0.59	0.3	1.0
11/08/2019 03:00	4,351.2	284.3	4,635.5	106,000.0	491.4	0.59	0.3	1.0
11/08/2019 04:00	4,386.5	347.9	4,734.4	106,000.0	501.8	0.60	0.3	1.0
11/08/2019 05:00	4,396.2	1,184.6	5,580.8	106,000.0	591.6	0.71	0.4	1.2
11/08/2019 06:00	4,384.9	967.2	5,352.1	106,000.0	567.3	0.68	0.3	1.1
11/08/2019 07:00	4,381.7	1,698.0	6,079.7	106,000.0	644.4	0.77	0.4	1.3
11/08/2019 08:00	4,362.6	865.7	5,228.3	106,000.0	554.2	0.67	0.3	1.1
11/08/2019 09:00	4,291.2	1,017.0	5,237.0	106,000.0	555.1	0.67	0.3	1.1
11/08/2019 10:00	3,277.4	11.3	3,277.4	106,000.0	347.4	0.42	0.2	0.7
11/08/2019 11:00	2,978.3	30.0	2,978.3	106,000.0	315.7	0.38	0.2	0.6
11/08/2019 12:00	3,003.7	30.5	3,003.7	106,000.0	318.4	0.39	0.2	0.6
11/08/2019 13:00	3,083.5	40.4	3,083.5	106,000.0	326.9	0.40	0.2	0.7
11/08/2019 14:00	3,133.8	48.0	3,133.8	106,000.0	332.2	0.40	0.2	0.7
11/08/2019 15:00	4,179.0	133.7	4,256.5	106,000.0	451.2	0.55	0.3	0.9
11/08/2019 16:00	4,274.4	225.2	4,499.6	106,000.0	477.0	0.57	0.3	1.0
11/08/2019 17:00	4,289.8	1,181.2	5,471.0	106,000.0	579.9	0.70	0.3	1.2
11/08/2019 18:00	4,302.8	1,350.2	5,653.0	106,000.0	599.2	0.72	0.4	1.2
11/08/2019 19:00	4,298.7	1,193.1	5,432.1	106,000.0	575.8	0.70	0.3	1.2
11/08/2019 20:00	2,964.8	29.4	2,964.8	106,000.0	314.3	0.38	0.2	0.6
11/08/2019 21:00	2,962.3	44.4	2,962.3	106,000.0	314.0	0.38	0.2	0.6
11/08/2019 22:00	2,920.5	40.2	2,920.5	106,000.0	309.6	0.38	0.2	0.6
11/08/2019 23:00	2,876.3	42.8	2,876.3	106,000.0	304.9	0.37	0.2	0.6
Average/Sum#:	3,843.6	502.1	4,324.7	106,000.0	458.4	0.55	0.3	0.9
Minimum:	2,876.3	11.3	2,876.3	106,000.0	304.9	0.37	0.2	0.6
Maximum:	4,396.2	1,698.0	6,079.7	106,000.0	644.4	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	3,303.0	29.8	3,303.0	106,000.0	350.1	0.42	0.2	0.7
11/09/2019 01:00	3,025.6	17.8	3,025.6	106,000.0	320.7	0.39	0.2	0.6
11/09/2019 02:00	2,968.6	8.0	2,968.6	106,000.0	314.7	0.38	0.2	0.6
11/09/2019 03:00	2,998.3	4.4	2,998.3	106,000.0	317.8	0.38	0.2	0.6
11/09/2019 04:00	2,991.7	6.7	2,991.7	106,000.0	317.1	0.38	0.2	0.6
11/09/2019 05:00	3,295.1	16.7	3,295.1	106,000.0	349.3	0.42	0.2	0.7
11/09/2019 06:00	3,429.3	13.4	3,429.3	106,000.0	363.5	0.44	0.2	0.7
11/09/2019 07:00	3,705.8	4.0	3,705.8	106,000.0	392.8	0.47	0.2	0.8
11/09/2019 08:00	3,307.5	6.7	3,307.5	106,000.0	350.6	0.42	0.2	0.7
11/09/2019 09:00	3,243.6	5.5	3,243.6	106,000.0	343.8	0.41	0.2	0.7
11/09/2019 10:00	3,213.2	2.5	3,213.2	106,000.0	340.6	0.41	0.2	0.7
11/09/2019 11:00	3,208.4	5.5	3,208.4	106,000.0	340.1	0.41	0.2	0.7
11/09/2019 12:00	3,224.8	25.6	3,224.8	106,000.0	341.8	0.41	0.2	0.7
11/09/2019 13:00	3,238.5	34.2	3,238.5	106,000.0	343.3	0.42	0.2	0.7
11/09/2019 14:00	3,286.8	48.4	3,286.8	106,000.0	348.4	0.43	0.2	0.7
11/09/2019 15:00	4,179.1	89.2	4,189.8	106,000.0	444.1	0.54	0.3	0.9
11/09/2019 16:00	4,264.6	796.2	5,060.8	106,000.0	536.4	0.64	0.3	1.1
11/09/2019 17:00	4,273.8	734.4	5,008.2	106,000.0	530.9	0.64	0.3	1.1
11/09/2019 18:00	4,281.9	628.0	4,909.9	106,000.0	520.4	0.62	0.3	1.0
11/09/2019 19:00	4,259.7	399.0	4,618.8	106,000.0	489.6	0.59	0.3	1.0
11/09/2019 20:00	3,878.9	49.7	3,878.9	106,000.0	411.2	0.50	0.2	0.8
11/09/2019 21:00	3,945.2	34.4	3,946.9	106,000.0	418.4	0.51	0.3	0.8
11/09/2019 22:00	4,319.9	194.0	4,513.9	106,000.0	478.5	0.57	0.3	1.0
11/09/2019 23:00	3,880.5	67.3	3,892.6	106,000.0	412.6	0.50	0.3	0.8
Average/Sum#:	3,571.8	134.2	3,685.8	106,000.0	390.7	0.47	0.2	0.8
Minimum:	2,968.6	2.5	2,968.6	106,000.0	314.7	0.38	0.2	0.6
Maximum:	4,319.9	796.2	5,060.8	106,000.0	536.4	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	3,557.6	22.8	3,557.6	106,000.0	377.1	0.45	0.2	0.8
11/10/2019 01:00	3,111.2	33.6	3,111.2	106,000.0	329.8	0.40	0.2	0.7
11/10/2019 02:00	3,099.3	39.4	3,099.3	106,000.0	328.5	0.40	0.2	0.7
11/10/2019 03:00	3,099.8	36.5	3,099.8	106,000.0	328.6	0.40	0.2	0.7
11/10/2019 04:00	3,109.7	20.4	3,109.7	106,000.0	329.6	0.40	0.2	0.7
11/10/2019 05:00	3,170.4	40.0	3,170.4	106,000.0	336.1	0.41	0.2	0.7
11/10/2019 06:00	3,325.6	34.3	3,325.6	106,000.0	352.5	0.43	0.2	0.7
11/10/2019 07:00	3,587.2	12.5	3,587.2	106,000.0	380.2	0.46	0.2	0.8
11/10/2019 08:00	3,256.0	0.9	3,256.0	106,000.0	345.1	0.41	0.2	0.7
11/10/2019 09:00	3,468.8	1.9	3,468.8	106,000.0	367.7	0.44	0.2	0.7
11/10/2019 10:00	3,331.8	9.5	3,331.8	106,000.0	353.2	0.42	0.2	0.7
11/10/2019 11:00	3,385.8	10.4	3,385.8	106,000.0	358.9	0.43	0.2	0.7
11/10/2019 12:00	3,351.1	30.9	3,351.1	106,000.0	355.2	0.43	0.2	0.7
11/10/2019 13:00	3,445.2	43.4	3,445.2	106,000.0	365.2	0.44	0.2	0.7
11/10/2019 14:00	3,382.7	42.8	3,382.7	106,000.0	358.6	0.43	0.2	0.7
11/10/2019 15:00	4,092.1	49.3	4,092.1	106,000.0	433.8	0.53	0.3	0.9
11/10/2019 16:00	3,987.8	64.6	3,992.3	106,000.0	423.2	0.52	0.3	0.9
11/10/2019 17:00	4,276.2	472.1	4,748.3	106,000.0	503.3	0.60	0.3	1.0
11/10/2019 18:00	4,282.0	380.0	4,662.0	106,000.0	494.2	0.59	0.3	1.0
11/10/2019 19:00	4,075.4	209.8	4,216.0	106,000.0	446.9	0.54	0.3	0.9
11/10/2019 20:00	3,571.3	31.8	3,571.3	106,000.0	378.6	0.46	0.2	0.8
11/10/2019 21:00	3,595.5	34.2	3,595.5	106,000.0	381.1	0.46	0.2	0.8
11/10/2019 22:00	4,258.9	150.5	4,364.3	106,000.0	462.6	0.56	0.3	0.9
11/10/2019 23:00	3,567.9	42.6	3,567.9	106,000.0	378.2	0.46	0.2	0.8
Average/Sum#:	3,557.9	75.6	3,603.8	106,000.0	382.0	0.46	0.2	0.8
Minimum:	3,099.3	0.9	3,099.3	106,000.0	328.5	0.40	0.2	0.7
Maximum:	4,282.0	472.1	4,748.3	106,000.0	503.3	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	3,441.9	35.4	3,441.9	106,000.0	364.8	0.44	0.2	0.7
11/11/2019 01:00	3,427.3	19.7	3,427.3	106,000.0	363.3	0.44	0.2	0.7
11/11/2019 02:00	3,290.4	10.5	3,290.4	106,000.0	348.8	0.42	0.2	0.7
11/11/2019 03:00	3,289.3	21.8	3,289.3	106,000.0	348.7	0.42	0.2	0.7
11/11/2019 04:00	3,559.0	10.0	3,559.0	106,000.0	377.3	0.45	0.2	0.8
11/11/2019 05:00	4,038.8	18.6	4,038.8	106,000.0	428.1	0.52	0.3	0.9
11/11/2019 06:00	4,250.0	30.3	4,252.4	106,000.0	450.8	0.54	0.3	0.9
11/11/2019 07:00	4,346.1	182.5	4,515.8	106,000.0	478.7	0.58	0.3	1.0
11/11/2019 08:00	3,366.4	2.9	3,366.4	106,000.0	356.8	0.43	0.2	0.7
11/11/2019 09:00	3,326.5	2.7	3,326.5	106,000.0	352.6	0.42	0.2	0.7
11/11/2019 10:00	3,214.8	5.6	3,214.8	106,000.0	340.8	0.41	0.2	0.7
11/11/2019 11:00	3,121.1	19.6	3,121.1	106,000.0	330.8	0.40	0.2	0.7
11/11/2019 12:00	3,471.2	21.7	3,471.2	106,000.0	367.9	0.44	0.2	0.7
11/11/2019 13:00	3,817.0	49.1	3,817.0	106,000.0	404.6	0.49	0.2	0.8
11/11/2019 14:00	4,208.4	54.1	4,208.4	106,000.0	446.1	0.54	0.3	0.9
11/11/2019 15:00	4,228.3	71.0	4,234.0	106,000.0	448.8	0.54	0.3	0.9
11/11/2019 16:00	4,265.2	1,051.1	5,316.3	106,000.0	563.5	0.68	0.3	1.1
11/11/2019 17:00	4,267.2	1,062.3	5,329.5	106,000.0	564.9	0.68	0.3	1.1
11/11/2019 18:00	4,281.3	1,081.1	5,362.4	106,000.0	568.4	0.68	0.3	1.1
11/11/2019 19:00	4,284.6	1,000.9	5,255.5	106,000.0	557.1	0.67	0.3	1.1
11/11/2019 20:00	3,241.9	41.6	3,241.9	106,000.0	343.6	0.42	0.2	0.7
11/11/2019 21:00	3,425.7	30.0	3,425.7	106,000.0	363.1	0.44	0.2	0.7
11/11/2019 22:00	3,586.0	48.3	3,586.0	106,000.0	380.1	0.46	0.2	0.8
11/11/2019 23:00	3,245.3	26.2	3,245.3	106,000.0	344.0	0.42	0.2	0.7
Average/Sum#:	3,708.1	204.0	3,889.0	106,000.0	412.2	0.50	0.2	0.8
Minimum:	3,121.1	2.7	3,121.1	106,000.0	330.8	0.40	0.2	0.7
Maximum:	4,346.1	1,081.1	5,362.4	106,000.0	568.4	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	2,586.9	36.9	2,586.9	106,000.0	274.2	0.38	0.2	0.6
11/12/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/12/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,586.9	36.9	2,586.9	106,000.0	274.2	0.38	0.2	0.6
Minimum:	2,586.9	36.9	2,586.9	106,000.0	274.2	0.38	0.2	0.6
Maximum:	2,586.9	36.9	2,586.9	106,000.0	274.2	0.38	0.2	0.6
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
11/13/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/13/2019 06:00	1,455.8	4.7	1,455.8	106,000.0	154.3	0.00	0.0	0.0
11/13/2019 07:00	3,334.6	1.3	3,334.6	106,000.0	353.5	0.42	0.2	0.7
11/13/2019 08:00	3,493.2	0.1	3,493.2	106,000.0	370.3	0.44	0.2	0.7
11/13/2019 09:00	3,556.4	0.2	3,556.4	106,000.0	377.0	0.45	0.2	0.8
11/13/2019 10:00	3,498.3	1.3	3,498.3	106,000.0	370.8	0.44	0.2	0.7
11/13/2019 11:00	3,505.2	19.6	3,505.2	106,000.0	371.6	0.45	0.2	0.7
11/13/2019 12:00	3,464.9	30.7	3,464.9	106,000.0	367.3	0.44	0.2	0.7
11/13/2019 13:00	3,493.8	19.8	3,493.8	106,000.0	370.3	0.45	0.2	0.7
11/13/2019 14:00	3,651.0	33.6	3,651.0	106,000.0	387.0	0.47	0.2	0.8
11/13/2019 15:00	4,086.6	37.6	4,086.6	106,000.0	433.2	0.52	0.3	0.9
11/13/2019 16:00	4,080.2	45.7	4,080.2	106,000.0	432.5	0.52	0.3	0.9
11/13/2019 17:00	4,058.0	55.7	4,058.0	106,000.0	430.1	0.52	0.3	0.9
11/13/2019 18:00	4,073.9	46.5	4,073.9	106,000.0	431.8	0.53	0.3	0.9
11/13/2019 19:00	4,051.8	42.9	4,051.8	106,000.0	429.5	0.52	0.3	0.9
11/13/2019 20:00	4,038.3	26.2	4,038.3	106,000.0	428.1	0.52	0.3	0.9
11/13/2019 21:00	2,916.2	29.6	2,916.2	106,000.0	309.1	0.38	0.2	0.6
11/13/2019 22:00	3,008.1	36.6	3,008.1	106,000.0	318.9	0.39	0.2	0.6
11/13/2019 23:00	2,909.5	29.2	2,909.5	106,000.0	308.4	0.38	0.2	0.6
Average/Sum#:	3,482.0	25.6	3,482.0	106,000.0	369.1	0.46	0.2	0.8
Minimum:	1,455.8	0.1	1,455.8	106,000.0	154.3	0.38	0.2	0.6
Maximum:	4,086.6	55.7	4,086.6	106,000.0	433.2	0.53	0.3	0.9
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	2,863.1	29.5	2,863.1	106,000.0	303.5	0.37	0.2	0.6
11/14/2019 01:00	2,854.9	30.0	2,854.9	106,000.0	302.6	0.37	0.2	0.6
11/14/2019 02:00	2,853.9	37.5	2,853.9	106,000.0	302.5	0.37	0.2	0.6
11/14/2019 03:00	2,854.3	32.1	2,854.3	106,000.0	302.6	0.37	0.2	0.6
11/14/2019 04:00	2,855.4	24.4	2,855.4	106,000.0	302.7	0.37	0.2	0.6
11/14/2019 05:00	2,913.5	26.9	2,913.5	106,000.0	308.8	0.38	0.2	0.6
11/14/2019 06:00	4,076.8	29.7	4,076.8	106,000.0	432.1	0.52	0.3	0.9
11/14/2019 07:00	3,246.7	18.0	3,246.7	106,000.0	344.2	0.42	0.2	0.7
11/14/2019 08:00	3,475.9	14.3	3,475.9	106,000.0	368.4	0.44	0.2	0.7
11/14/2019 09:00	3,553.7	5.1	3,553.7	106,000.0	376.7	0.45	0.2	0.8
11/14/2019 10:00	3,518.9	17.3	3,518.9	106,000.0	373.0	0.45	0.2	0.7
11/14/2019 11:00	3,606.1	22.4	3,606.1	106,000.0	382.2	0.46	0.2	0.8
11/14/2019 12:00	3,572.7	22.2	3,572.7	106,000.0	378.7	0.46	0.2	0.8
11/14/2019 13:00	3,548.8	22.5	3,548.8	106,000.0	376.2	0.45	0.2	0.8
11/14/2019 14:00	3,530.8	23.2	3,530.8	106,000.0	374.3	0.45	0.2	0.8
11/14/2019 15:00	4,111.6	41.6	4,111.6	106,000.0	435.8	0.53	0.3	0.9
11/14/2019 16:00	4,094.2	47.3	4,094.2	106,000.0	434.0	0.53	0.3	0.9
11/14/2019 17:00	4,040.2	51.4	4,040.2	106,000.0	428.3	0.52	0.3	0.9
11/14/2019 18:00	4,018.7	45.9	4,018.7	106,000.0	426.0	0.52	0.3	0.9
11/14/2019 19:00	3,997.8	46.0	3,997.8	106,000.0	423.8	0.51	0.3	0.9
11/14/2019 20:00	3,928.4	43.0	3,928.4	106,000.0	416.4	0.50	0.3	0.8
11/14/2019 21:00	2,976.2	38.4	2,976.2	106,000.0	315.5	0.38	0.2	0.6
11/14/2019 22:00	2,984.2	38.2	2,984.2	106,000.0	316.3	0.39	0.2	0.6
11/14/2019 23:00	2,776.0	40.3	2,776.0	106,000.0	294.3	0.38	0.2	0.6
Average/Sum#:	3,427.2	31.1	3,427.2	106,000.0	363.3	0.44	0.2	0.7
Minimum:	2,776.0	5.1	2,776.0	106,000.0	294.3	0.37	0.2	0.6
Maximum:	4,111.6	51.4	4,111.6	106,000.0	435.8	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/15/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/16/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/17/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/18/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/19/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/20/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/21/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/21/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/21/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/21/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/21/2019 05:00	1,586.4	3.1	1,586.4	106,000.0	168.2	0.00	0.0	0.0
11/21/2019 06:00	4,111.9	5.7	4,111.9	106,000.0	435.9	0.52	0.3	0.9
11/21/2019 07:00	4,230.8	6.4	4,230.8	106,000.0	448.5	0.54	0.3	0.9
11/21/2019 08:00	4,289.7	0.2	4,289.7	106,000.0	454.7	0.55	0.3	0.9
11/21/2019 09:00	3,597.3	0.4	3,597.3	106,000.0	381.3	0.46	0.2	0.8
11/21/2019 10:00	3,554.3	7.5	3,554.3	106,000.0	376.8	0.45	0.2	0.8
11/21/2019 11:00	3,535.1	17.2	3,535.1	106,000.0	374.7	0.45	0.2	0.8
11/21/2019 12:00	3,540.5	32.8	3,540.5	106,000.0	375.3	0.45	0.2	0.8
11/21/2019 13:00	3,533.5	28.0	3,533.5	106,000.0	374.6	0.45	0.2	0.8
11/21/2019 14:00	3,480.1	33.0	3,480.1	106,000.0	368.9	0.45	0.2	0.7
11/21/2019 15:00	4,008.5	52.7	4,008.5	106,000.0	424.9	0.52	0.3	0.9
11/21/2019 16:00	4,081.7	47.8	4,081.7	106,000.0	432.7	0.53	0.3	0.9
11/21/2019 17:00	4,046.6	49.6	4,046.6	106,000.0	428.9	0.52	0.3	0.9
11/21/2019 18:00	4,017.2	46.1	4,017.2	106,000.0	425.8	0.52	0.3	0.9
11/21/2019 19:00	3,958.2	33.8	3,958.2	106,000.0	419.6	0.51	0.3	0.8
11/21/2019 20:00	3,935.7	35.8	3,935.7	106,000.0	417.2	0.50	0.3	0.8
11/21/2019 21:00	4,114.6	48.5	4,114.6	106,000.0	436.1	0.53	0.3	0.9
11/21/2019 22:00	3,010.7	25.0	3,010.7	106,000.0	319.1	0.39	0.2	0.6
11/21/2019 23:00	2,884.0	18.4	2,884.0	106,000.0	305.7	0.37	0.2	0.6
Average/Sum#:	3,658.8	25.9	3,658.8	106,000.0	387.8	0.48	0.3	0.8
Minimum:	1,586.4	0.2	1,586.4	106,000.0	168.2	0.37	0.2	0.6
Maximum:	4,289.7	52.7	4,289.7	106,000.0	454.7	0.55	0.3	0.9
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	2,901.3	22.3	2,901.3	106,000.0	307.5	0.37	0.2	0.6
11/22/2019 01:00	2,922.5	25.5	2,922.5	106,000.0	309.8	0.38	0.2	0.6
11/22/2019 02:00	2,922.5	11.1	2,922.5	106,000.0	309.8	0.37	0.2	0.6
11/22/2019 03:00	2,928.9	17.4	2,928.9	106,000.0	310.5	0.37	0.2	0.6
11/22/2019 04:00	2,939.4	20.1	2,939.4	106,000.0	311.6	0.38	0.2	0.6
11/22/2019 05:00	3,080.0	21.7	3,080.0	106,000.0	326.5	0.40	0.2	0.7
11/22/2019 06:00	3,654.7	12.7	3,654.7	106,000.0	387.4	0.47	0.2	0.8
11/22/2019 07:00	3,395.1	9.5	3,395.1	106,000.0	359.9	0.43	0.2	0.7
11/22/2019 08:00	3,612.9	3.9	3,612.9	106,000.0	383.0	0.46	0.2	0.8
11/22/2019 09:00	3,626.3	0.9	3,626.3	106,000.0	384.4	0.46	0.2	0.8
11/22/2019 10:00	3,627.7	18.1	3,627.7	106,000.0	384.5	0.46	0.2	0.8
11/22/2019 11:00	3,636.8	20.4	3,636.8	106,000.0	385.5	0.46	0.2	0.8
11/22/2019 12:00	3,675.4	25.3	3,675.4	106,000.0	389.6	0.47	0.2	0.8
11/22/2019 13:00	3,862.9	30.0	3,862.9	106,000.0	409.5	0.50	0.2	0.8
11/22/2019 14:00	3,888.5	38.2	3,888.5	106,000.0	412.2	0.50	0.2	0.8
11/22/2019 15:00	4,279.5	89.7	4,293.0	106,000.0	455.1	0.55	0.3	0.9
11/22/2019 16:00	4,314.7	1,374.8	5,689.5	106,000.0	603.1	0.73	0.4	1.2
11/22/2019 17:00	4,330.3	1,375.2	5,705.5	106,000.0	604.8	0.73	0.4	1.2
11/22/2019 18:00	4,342.0	1,351.9	5,693.9	106,000.0	603.6	0.72	0.4	1.2
11/22/2019 19:00	4,357.4	1,320.9	5,678.3	106,000.0	601.9	0.72	0.4	1.2
11/22/2019 20:00	4,328.8	1,277.8	5,606.6	106,000.0	594.3	0.71	0.4	1.2
11/22/2019 21:00	4,207.6	55.5	4,211.5	106,000.0	446.4	0.54	0.3	0.9
11/22/2019 22:00	4,145.7	30.7	4,145.7	106,000.0	439.4	0.53	0.3	0.9
11/22/2019 23:00	4,116.4	31.6	4,116.4	106,000.0	436.3	0.55	0.3	0.9
Average/Sum#:	3,712.4	299.4	3,992.3	106,000.0	423.2	0.51	0.3	0.9
Minimum:	2,901.3	0.9	2,901.3	106,000.0	307.5	0.37	0.2	0.6
Maximum:	4,357.4	1,375.2	5,705.5	106,000.0	604.8	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/23/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/24/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/25/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
11/26/2019 06:00	3,147.0	6.0	3,147.0	106,000.0	333.6	0.52	0.3	0.9
11/26/2019 07:00	3,871.4	2.9	3,871.4	106,000.0	410.4	0.49	0.2	0.8
11/26/2019 08:00	3,914.1	0.3	3,914.1	106,000.0	414.9	0.50	0.2	0.8
11/26/2019 09:00	3,989.8	0.3	3,989.8	106,000.0	422.9	0.51	0.3	0.8
11/26/2019 10:00	4,016.5	7.3	4,016.5	106,000.0	425.7	0.51	0.3	0.9
11/26/2019 11:00	4,001.6	21.2	4,001.6	106,000.0	424.2	0.51	0.3	0.9
11/26/2019 12:00	3,974.7	28.9	3,974.7	106,000.0	421.3	0.51	0.3	0.8
11/26/2019 13:00	4,043.3	33.2	4,043.3	106,000.0	428.6	0.52	0.3	0.9
11/26/2019 14:00	4,111.9	48.8	4,111.9	106,000.0	435.9	0.53	0.3	0.9
11/26/2019 15:00	4,212.3	135.1	4,270.4	106,000.0	452.7	0.55	0.3	0.9
11/26/2019 16:00	4,319.9	271.5	4,558.8	106,000.0	483.2	0.58	0.3	1.0
11/26/2019 17:00	4,311.8	1,617.7	5,929.5	106,000.0	628.5	0.75	0.4	1.3
11/26/2019 18:00	4,315.2	1,406.0	5,721.2	106,000.0	606.4	0.73	0.4	1.2
11/26/2019 19:00	4,259.3	93.1	4,271.4	106,000.0	452.8	0.55	0.3	0.9
11/26/2019 20:00	4,289.9	46.6	4,289.9	106,000.0	454.7	0.55	0.3	0.9
11/26/2019 21:00	4,207.8	35.0	4,207.8	106,000.0	446.0	0.54	0.3	0.9
11/26/2019 22:00	3,555.6	20.4	3,555.6	106,000.0	376.9	0.45	0.2	0.8
11/26/2019 23:00	3,237.0	32.7	3,237.0	106,000.0	343.1	0.42	0.2	0.7
Average/Sum#:	3,987.7	211.5	4,172.9	106,000.0	442.3	0.54	0.3	0.9
Minimum:	3,147.0	0.3	3,147.0	106,000.0	333.6	0.42	0.2	0.7
Maximum:	4,319.9	1,617.7	5,929.5	106,000.0	628.5	0.75	0.4	1.3
%SI	25.00	25.00	25.00	0.00	25.00	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	3,014.0	26.1	3,014.0	106,000.0	319.5	0.39	0.2	0.6
11/27/2019 01:00	2,875.0	29.1	2,875.0	106,000.0	304.8	0.37	0.2	0.6
11/27/2019 02:00	2,872.9	34.0	2,872.9	106,000.0	304.5	0.37	0.2	0.6
11/27/2019 03:00	2,872.6	41.0	2,872.6	106,000.0	304.5	0.37	0.2	0.6
11/27/2019 04:00	2,941.5	48.7	2,941.5	106,000.0	311.8	0.38	0.2	0.6
11/27/2019 05:00	3,143.3	39.5	3,143.3	106,000.0	333.2	0.40	0.2	0.7
11/27/2019 06:00	4,060.6	39.2	4,060.6	106,000.0	430.4	0.52	0.3	0.9
11/27/2019 07:00	3,519.7	34.1	3,519.7	106,000.0	373.1	0.45	0.2	0.8
11/27/2019 08:00	3,557.2	19.8	3,557.2	106,000.0	377.1	0.46	0.2	0.8
11/27/2019 09:00	3,694.0	22.8	3,694.0	106,000.0	391.6	0.47	0.2	0.8
11/27/2019 10:00	3,917.1	41.1	3,917.1	106,000.0	415.2	0.50	0.3	0.8
11/27/2019 11:00	3,870.0	41.9	3,870.0	106,000.0	410.2	0.50	0.2	0.8
11/27/2019 12:00	3,785.6	34.2	3,785.6	106,000.0	401.3	0.49	0.2	0.8
11/27/2019 13:00	3,719.7	27.0	3,719.7	106,000.0	394.3	0.48	0.2	0.8
11/27/2019 14:00	3,559.9	41.0	3,559.9	106,000.0	377.3	0.46	0.2	0.8
11/27/2019 15:00	3,526.9	50.1	3,526.9	106,000.0	373.9	0.45	0.2	0.8
11/27/2019 16:00	3,798.7	74.9	3,803.9	106,000.0	403.2	0.49	0.2	0.8
11/27/2019 17:00	4,269.5	1,131.1	5,400.6	106,000.0	572.5	0.69	0.3	1.1
11/27/2019 18:00	4,273.0	80.7	4,287.5	106,000.0	454.5	0.55	0.3	0.9
11/27/2019 19:00	4,058.2	38.2	4,058.2	106,000.0	430.2	0.52	0.3	0.9
11/27/2019 20:00	3,984.1	35.0	3,984.1	106,000.0	422.3	0.51	0.3	0.9
11/27/2019 21:00	3,766.0	27.5	3,766.0	106,000.0	399.2	0.48	0.2	0.8
11/27/2019 22:00	3,384.6	26.6	3,384.6	106,000.0	358.8	0.43	0.2	0.7
11/27/2019 23:00	2,972.4	32.0	2,972.4	106,000.0	315.1	0.38	0.2	0.6
Average/Sum#:	3,559.9	84.0	3,607.8	106,000.0	382.4	0.46	0.2	0.8
Minimum:	2,872.6	19.8	2,872.6	106,000.0	304.5	0.37	0.2	0.6
Maximum:	4,273.0	1,131.1	5,400.6	106,000.0	572.5	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	2,882.0	39.8	2,882.0	106,000.0	305.5	0.37	0.2	0.6
11/28/2019 01:00	2,878.5	34.3	2,878.5	106,000.0	305.1	0.37	0.2	0.6
11/28/2019 02:00	2,879.8	37.0	2,879.8	106,000.0	305.3	0.37	0.2	0.6
11/28/2019 03:00	2,880.4	18.9	2,880.4	106,000.0	305.3	0.37	0.2	0.6
11/28/2019 04:00	2,943.8	22.1	2,943.8	106,000.0	312.0	0.38	0.2	0.6
11/28/2019 05:00	3,067.9	21.8	3,067.9	106,000.0	325.2	0.39	0.2	0.7
11/28/2019 06:00	3,113.5	16.8	3,113.5	106,000.0	330.0	0.40	0.2	0.7
11/28/2019 07:00	3,232.5	23.2	3,232.5	106,000.0	342.6	0.41	0.2	0.7
11/28/2019 08:00	3,575.5	14.9	3,575.5	106,000.0	379.0	0.46	0.2	0.8
11/28/2019 09:00	3,639.4	10.7	3,639.4	106,000.0	385.8	0.46	0.2	0.8
11/28/2019 10:00	3,740.8	7.8	3,740.8	106,000.0	396.5	0.48	0.2	0.8
11/28/2019 11:00	3,661.4	13.0	3,661.4	106,000.0	388.1	0.47	0.2	0.8
11/28/2019 12:00	3,544.0	9.4	3,544.0	106,000.0	375.7	0.45	0.2	0.8
11/28/2019 13:00	3,378.2	21.0	3,378.2	106,000.0	358.1	0.43	0.2	0.7
11/28/2019 14:00	3,204.0	38.2	3,204.0	106,000.0	339.6	0.41	0.2	0.7
11/28/2019 15:00	3,165.6	35.0	3,165.6	106,000.0	335.6	0.41	0.2	0.7
11/28/2019 16:00	2,962.2	29.5	2,962.2	106,000.0	314.0	0.38	0.2	0.6
11/28/2019 17:00	3,935.2	29.6	3,935.2	106,000.0	417.1	0.50	0.3	0.8
11/28/2019 18:00	3,857.3	37.0	3,857.3	106,000.0	408.9	0.50	0.2	0.8
11/28/2019 19:00	2,904.4	18.4	2,904.4	106,000.0	307.9	0.37	0.2	0.6
11/28/2019 20:00	3,656.3	19.9	3,656.3	106,000.0	387.6	0.47	0.2	0.8
11/28/2019 21:00	3,522.0	34.5	3,522.0	106,000.0	373.3	0.45	0.2	0.8
11/28/2019 22:00	3,200.5	46.6	3,200.5	106,000.0	339.3	0.41	0.2	0.7
11/28/2019 23:00	2,889.1	33.3	2,889.1	106,000.0	306.2	0.37	0.2	0.6
Average/Sum#:	3,279.8	25.5	3,279.8	106,000.0	347.7	0.42	0.2	0.7
Minimum:	2,878.5	7.8	2,878.5	106,000.0	305.1	0.37	0.2	0.6
Maximum:	3,935.2	46.6	3,935.2	106,000.0	417.1	0.50	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	2,972.3	18.8	2,972.3	106,000.0	315.1	0.38	0.2	0.6
11/29/2019 01:00	2,912.6	17.0	2,912.6	106,000.0	308.7	0.37	0.2	0.6
11/29/2019 02:00	2,886.1	15.2	2,886.1	106,000.0	305.9	0.37	0.2	0.6
11/29/2019 03:00	2,901.0	18.0	2,901.0	106,000.0	307.5	0.37	0.2	0.6
11/29/2019 04:00	2,923.3	19.0	2,923.3	106,000.0	309.9	0.37	0.2	0.6
11/29/2019 05:00	3,039.6	21.7	3,039.6	106,000.0	322.2	0.39	0.2	0.6
11/29/2019 06:00	3,124.3	20.1	3,124.3	106,000.0	331.2	0.40	0.2	0.7
11/29/2019 07:00	3,154.9	15.9	3,154.9	106,000.0	334.4	0.40	0.2	0.7
11/29/2019 08:00	3,278.5	7.9	3,278.5	106,000.0	347.5	0.42	0.2	0.7
11/29/2019 09:00	3,626.4	12.5	3,626.4	106,000.0	384.4	0.46	0.2	0.8
11/29/2019 10:00	3,655.0	16.7	3,655.0	106,000.0	387.4	0.47	0.2	0.8
11/29/2019 11:00	3,502.3	31.2	3,502.3	106,000.0	371.2	0.45	0.2	0.7
11/29/2019 12:00	3,456.3	33.1	3,456.3	106,000.0	366.4	0.44	0.2	0.7
11/29/2019 13:00	3,423.2	41.0	3,423.2	106,000.0	362.9	0.44	0.2	0.7
11/29/2019 14:00	3,345.3	43.4	3,345.3	106,000.0	354.6	0.43	0.2	0.7
11/29/2019 15:00	3,262.9	45.8	3,262.9	106,000.0	345.9	0.42	0.2	0.7
11/29/2019 16:00	3,056.3	57.0	3,056.3	106,000.0	324.0	0.40	0.2	0.7
11/29/2019 17:00	4,313.6	992.3	5,305.9	106,000.0	562.4	0.68	0.3	1.1
11/29/2019 18:00	4,315.3	1,100.0	5,415.3	106,000.0	574.0	0.69	0.3	1.1
11/29/2019 19:00	4,333.4	986.2	5,299.9	106,000.0	561.8	0.68	0.3	1.1
11/29/2019 20:00	4,092.5	44.7	4,092.5	106,000.0	433.8	0.53	0.3	0.9
11/29/2019 21:00	3,807.6	43.0	3,807.6	106,000.0	403.6	0.49	0.2	0.8
11/29/2019 22:00	3,432.4	41.1	3,432.4	106,000.0	363.8	0.44	0.2	0.7
11/29/2019 23:00	3,101.8	33.5	3,101.8	106,000.0	328.8	0.40	0.2	0.7
Average/Sum#:	3,413.2	153.1	3,540.7	106,000.0	375.3	0.45	0.2	0.7
Minimum:	2,886.1	7.9	2,886.1	106,000.0	305.9	0.37	0.2	0.6
Maximum:	4,333.4	1,100.0	5,415.3	106,000.0	574.0	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	2,902.6	20.3	2,902.6	106,000.0	307.7	0.37	0.2	0.6
11/30/2019 01:00	2,901.5	26.8	2,901.5	106,000.0	307.6	0.37	0.2	0.6
11/30/2019 02:00	2,887.5	26.5	2,887.5	106,000.0	306.1	0.37	0.2	0.6
11/30/2019 03:00	2,893.1	37.2	2,893.1	106,000.0	306.7	0.37	0.2	0.6
11/30/2019 04:00	2,910.3	27.5	2,910.3	106,000.0	308.5	0.37	0.2	0.6
11/30/2019 05:00	2,974.3	20.7	2,974.3	106,000.0	315.3	0.38	0.2	0.6
11/30/2019 06:00	3,034.7	21.2	3,034.7	106,000.0	321.7	0.39	0.2	0.6
11/30/2019 07:00	3,251.2	20.8	3,251.2	106,000.0	344.6	0.42	0.2	0.7
11/30/2019 08:00	3,600.3	12.0	3,600.3	106,000.0	381.6	0.46	0.2	0.8
11/30/2019 09:00	3,717.5	7.3	3,717.5	106,000.0	394.1	0.48	0.2	0.8
11/30/2019 10:00	3,822.7	16.4	3,822.7	106,000.0	405.2	0.49	0.2	0.8
11/30/2019 11:00	3,730.4	43.8	3,730.4	106,000.0	395.4	0.48	0.2	0.8
11/30/2019 12:00	3,665.3	40.9	3,665.3	106,000.0	388.5	0.47	0.2	0.8
11/30/2019 13:00	3,743.7	42.7	3,743.7	106,000.0	396.8	0.48	0.2	0.8
11/30/2019 14:00	3,716.7	46.8	3,716.7	106,000.0	394.0	0.48	0.2	0.8
11/30/2019 15:00	3,643.8	56.5	3,643.8	106,000.0	386.2	0.47	0.2	0.8
11/30/2019 16:00	3,115.8	54.5	3,115.8	106,000.0	330.3	0.40	0.2	0.7
11/30/2019 17:00	4,319.7	1,487.3	5,807.0	106,000.0	615.5	0.74	0.4	1.2
11/30/2019 18:00	4,311.7	79.3	4,319.6	106,000.0	457.9	0.56	0.3	0.9
11/30/2019 19:00	3,682.8	49.9	3,682.8	106,000.0	390.4	0.47	0.2	0.8
11/30/2019 20:00	4,245.6	44.8	4,245.6	106,000.0	450.0	0.55	0.3	0.9
11/30/2019 21:00	4,032.1	36.3	4,032.1	106,000.0	427.4	0.52	0.3	0.9
11/30/2019 22:00	3,628.0	28.6	3,628.0	106,000.0	384.6	0.46	0.2	0.8
11/30/2019 23:00	3,441.4	37.7	3,441.4	106,000.0	364.8	0.44	0.2	0.7
Average/Sum#:	3,507.2	95.2	3,569.5	106,000.0	378.4	0.46	0.2	0.8
Minimum:	2,887.5	7.3	2,887.5	106,000.0	306.1	0.37	0.2	0.6
Maximum:	4,319.7	1,487.3	5,807.0	106,000.0	615.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	3,215.0	34.8	3,215.0	106,000.0	340.8	0.41	0.2	0.7
12/01/2019 01:00	2,890.3	36.9	2,890.3	106,000.0	306.4	0.37	0.2	0.6
12/01/2019 02:00	2,881.4	45.8	2,881.4	106,000.0	305.4	0.37	0.2	0.6
12/01/2019 03:00	2,880.9	49.5	2,880.9	106,000.0	305.4	0.37	0.2	0.6
12/01/2019 04:00	2,888.5	50.1	2,888.5	106,000.0	306.2	0.37	0.2	0.6
12/01/2019 05:00	2,955.4	51.5	2,955.4	106,000.0	313.3	0.38	0.2	0.6
12/01/2019 06:00	2,957.8	53.3	2,957.8	106,000.0	313.5	0.38	0.2	0.6
12/01/2019 07:00	3,040.6	54.3	3,040.6	106,000.0	322.3	0.39	0.2	0.7
12/01/2019 08:00	3,042.3	46.3	3,042.3	106,000.0	322.5	0.39	0.2	0.7
12/01/2019 09:00	3,035.3	31.0	3,035.3	106,000.0	321.7	0.39	0.2	0.6
12/01/2019 10:00	3,265.8	20.1	3,265.8	106,000.0	346.2	0.42	0.2	0.7
12/01/2019 11:00	3,228.1	23.4	3,228.1	106,000.0	342.2	0.41	0.2	0.7
12/01/2019 12:00	3,190.5	44.9	3,190.5	106,000.0	338.2	0.41	0.2	0.7
12/01/2019 13:00	3,215.6	52.4	3,215.6	106,000.0	340.9	0.42	0.2	0.7
12/01/2019 14:00	3,373.2	45.5	3,373.2	106,000.0	357.6	0.43	0.2	0.7
12/01/2019 15:00	3,823.4	21.3	3,823.4	106,000.0	405.3	0.49	0.2	0.8
12/01/2019 16:00	3,213.5	37.1	3,213.5	106,000.0	340.6	0.41	0.2	0.7
12/01/2019 17:00	4,257.0	1,110.8	5,223.4	106,000.0	553.7	0.68	0.3	1.1
12/01/2019 18:00	4,277.1	1,478.5	5,755.6	106,000.0	610.1	0.73	0.4	1.2
12/01/2019 19:00	4,314.7	218.9	4,516.1	106,000.0	478.7	0.58	0.3	1.0
12/01/2019 20:00	4,344.8	207.4	4,552.2	106,000.0	482.5	0.58	0.3	1.0
12/01/2019 21:00	4,246.5	83.0	4,261.4	106,000.0	451.7	0.55	0.3	0.9
12/01/2019 22:00	3,497.0	45.6	3,497.0	106,000.0	370.7	0.45	0.2	0.8
12/01/2019 23:00	3,279.6	48.8	3,279.6	106,000.0	347.6	0.42	0.2	0.7
Average/Sum#:	3,388.1	162.1	3,507.6	106,000.0	371.8	0.45	0.2	0.8
Minimum:	2,880.9	20.1	2,880.9	106,000.0	305.4	0.37	0.2	0.6
Maximum:	4,344.8	1,478.5	5,755.6	106,000.0	610.1	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	3,102.7	37.8	3,102.7	106,000.0	328.9	0.40	0.2	0.7
12/02/2019 01:00	2,891.5	43.3	2,891.5	106,000.0	306.5	0.37	0.2	0.6
12/02/2019 02:00	2,888.1	27.9	2,888.1	106,000.0	306.1	0.37	0.2	0.6
12/02/2019 03:00	2,893.7	44.8	2,893.7	106,000.0	306.7	0.37	0.2	0.6
12/02/2019 04:00	2,916.9	56.7	2,916.9	106,000.0	309.2	0.38	0.2	0.6
12/02/2019 05:00	3,113.3	53.1	3,113.3	106,000.0	330.0	0.40	0.2	0.7
12/02/2019 06:00	4,310.2	166.1	4,439.8	106,000.0	470.6	0.57	0.3	1.0
12/02/2019 07:00	4,035.1	44.0	4,036.4	106,000.0	427.9	0.52	0.3	0.9
12/02/2019 08:00	3,831.8	45.5	3,831.8	106,000.0	406.2	0.49	0.2	0.8
12/02/2019 09:00	4,117.4	43.2	4,117.4	106,000.0	436.4	0.53	0.3	0.9
12/02/2019 10:00	4,003.4	49.3	4,003.4	106,000.0	424.4	0.51	0.3	0.9
12/02/2019 11:00	3,970.2	41.1	3,970.2	106,000.0	420.8	0.51	0.3	0.9
12/02/2019 12:00	4,124.9	47.6	4,124.9	106,000.0	437.2	0.53	0.3	0.9
12/02/2019 13:00	4,013.5	48.6	4,013.5	106,000.0	425.4	0.52	0.3	0.9
12/02/2019 14:00	3,985.2	47.2	3,985.2	106,000.0	422.4	0.51	0.3	0.9
12/02/2019 15:00	4,254.2	71.2	4,261.3	106,000.0	451.7	0.55	0.3	0.9
12/02/2019 16:00	4,308.2	1,100.6	5,408.8	106,000.0	573.3	0.69	0.3	1.1
12/02/2019 17:00	4,318.7	1,074.8	5,393.5	106,000.0	571.7	0.69	0.3	1.1
12/02/2019 18:00	4,326.4	1,055.3	5,381.7	106,000.0	570.5	0.69	0.3	1.1
12/02/2019 19:00	4,326.6	994.6	5,321.2	106,000.0	564.0	0.68	0.3	1.1
12/02/2019 20:00	4,329.0	1,027.1	5,356.1	106,000.0	567.7	0.68	0.3	1.1
12/02/2019 21:00	4,179.5	75.6	4,187.1	106,000.0	443.8	0.54	0.3	0.9
12/02/2019 22:00	3,357.8	52.3	3,357.8	106,000.0	355.9	0.43	0.2	0.7
12/02/2019 23:00	2,914.8	50.3	2,914.8	106,000.0	309.0	0.38	0.2	0.6
Average/Sum#:	3,771.4	262.4	3,996.3	106,000.0	423.6	0.51	0.3	0.9
Minimum:	2,888.1	27.9	2,888.1	106,000.0	306.1	0.37	0.2	0.6
Maximum:	4,329.0	1,100.6	5,408.8	106,000.0	573.3	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	2,945.9	51.8	2,945.9	106,000.0	312.3	0.38	0.2	0.6
12/03/2019 01:00	2,866.6	50.8	2,866.6	106,000.0	303.9	0.37	0.2	0.6
12/03/2019 02:00	2,866.6	53.1	2,866.6	106,000.0	303.9	0.37	0.2	0.6
12/03/2019 03:00	2,865.1	51.3	2,865.1	106,000.0	303.7	0.37	0.2	0.6
12/03/2019 04:00	2,865.7	51.7	2,865.7	106,000.0	303.8	0.37	0.2	0.6
12/03/2019 05:00	3,001.0	52.2	3,001.0	106,000.0	318.1	0.39	0.2	0.6
12/03/2019 06:00	3,168.4	50.9	3,168.4	106,000.0	335.9	0.41	0.2	0.7
12/03/2019 07:00	4,017.2	49.0	4,017.2	106,000.0	425.8	0.52	0.3	0.9
12/03/2019 08:00	3,845.1	45.0	3,845.1	106,000.0	407.6	0.49	0.2	0.8
12/03/2019 09:00	4,158.6	42.3	4,158.6	106,000.0	440.8	0.53	0.3	0.9
12/03/2019 10:00	3,950.4	22.7	3,950.4	106,000.0	418.7	0.51	0.3	0.8
12/03/2019 11:00	3,765.3	32.3	3,765.3	106,000.0	399.1	0.48	0.2	0.8
12/03/2019 12:00	3,676.8	55.5	3,676.8	106,000.0	389.7	0.47	0.2	0.8
12/03/2019 13:00	3,682.6	38.9	3,682.6	106,000.0	390.4	0.47	0.2	0.8
12/03/2019 14:00	3,809.7	33.7	3,809.7	106,000.0	403.8	0.49	0.2	0.8
12/03/2019 15:00	3,792.2	57.2	3,792.2	106,000.0	402.0	0.49	0.2	0.8
12/03/2019 16:00	3,998.3	57.7	4,002.3	106,000.0	424.2	0.52	0.3	0.9
12/03/2019 17:00	4,262.3	396.5	4,658.8	106,000.0	493.8	0.59	0.3	1.0
12/03/2019 18:00	4,262.7	274.3	4,523.3	106,000.0	479.5	0.58	0.3	1.0
12/03/2019 19:00	3,514.4	56.6	3,514.4	106,000.0	372.5	0.45	0.2	0.8
12/03/2019 20:00	4,263.1	369.2	4,584.3	106,000.0	485.9	0.59	0.3	1.0
12/03/2019 21:00	4,303.0	76.5	4,314.5	106,000.0	457.3	0.56	0.3	0.9
12/03/2019 22:00	4,260.5	48.4	4,260.5	106,000.0	451.6	0.55	0.3	0.9
12/03/2019 23:00	3,833.7	27.5	3,833.7	106,000.0	406.4	0.49	0.2	0.8
Average/Sum#:	3,665.6	85.2	3,707.0	106,000.0	392.9	0.48	0.2	0.8
Minimum:	2,865.1	22.7	2,865.1	106,000.0	303.7	0.37	0.2	0.6
Maximum:	4,303.0	396.5	4,658.8	106,000.0	493.8	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	3,137.2	34.9	3,137.2	106,000.0	332.5	0.40	0.2	0.7
12/04/2019 01:00	2,895.2	48.9	2,895.2	106,000.0	306.9	0.37	0.2	0.6
12/04/2019 02:00	2,891.4	44.1	2,891.4	106,000.0	306.5	0.37	0.2	0.6
12/04/2019 03:00	2,886.3	41.2	2,886.3	106,000.0	305.9	0.37	0.2	0.6
12/04/2019 04:00	2,924.6	35.5	2,924.6	106,000.0	310.0	0.37	0.2	0.6
12/04/2019 05:00	3,947.9	51.9	3,947.9	106,000.0	418.5	0.51	0.3	0.8
12/04/2019 06:00	4,008.3	50.9	4,010.8	106,000.0	425.1	0.52	0.3	0.9
12/04/2019 07:00	4,317.9	684.0	5,001.9	106,000.0	530.2	0.64	0.3	1.1
12/04/2019 08:00	4,315.6	980.2	5,295.8	106,000.0	561.4	0.67	0.3	1.1
12/04/2019 09:00	4,305.6	958.9	5,264.5	106,000.0	558.0	0.67	0.3	1.1
12/04/2019 10:00	4,097.3	66.0	4,105.9	106,000.0	435.2	0.53	0.3	0.9
12/04/2019 11:00	4,047.0	36.4	4,047.0	106,000.0	429.0	0.52	0.3	0.9
12/04/2019 12:00	4,008.9	39.9	4,008.9	106,000.0	424.9	0.52	0.3	0.9
12/04/2019 13:00	3,984.8	39.1	3,984.8	106,000.0	422.4	0.51	0.3	0.9
12/04/2019 14:00	4,063.2	52.1	4,063.2	106,000.0	430.7	0.52	0.3	0.9
12/04/2019 15:00	4,079.8	54.7	4,083.6	106,000.0	432.9	0.53	0.3	0.9
12/04/2019 16:00	4,289.5	1,076.1	5,365.6	106,000.0	568.8	0.68	0.3	1.1
12/04/2019 17:00	4,297.1	1,135.3	5,432.4	106,000.0	575.8	0.69	0.3	1.2
12/04/2019 18:00	4,303.9	1,127.7	5,431.6	106,000.0	575.7	0.69	0.3	1.2
12/04/2019 19:00	4,309.9	1,125.7	5,435.6	104,600.0	568.6	0.68	0.3	1.1
12/04/2019 20:00	4,312.2	1,074.1	5,386.3	104,600.0	563.4	0.68	0.3	1.1
12/04/2019 21:00	4,310.4	477.2	4,787.6	104,600.0	500.8	0.60	0.3	1.0
12/04/2019 22:00	4,190.2	53.5	4,192.9	104,600.0	438.6	0.53	0.3	0.9
12/04/2019 23:00	3,231.6	47.3	3,231.6	104,600.0	338.0	0.42	0.2	0.7
Average/Sum#:	3,881.5	389.0	4,242.2	105,708.3	448.3	0.54	0.3	0.9
Minimum:	2,886.3	34.9	2,886.3	104,600.0	305.9	0.37	0.2	0.6
Maximum:	4,317.9	1,135.3	5,435.6	106,000.0	575.8	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	1,556.9	46.9	1,556.9	104,600.0	162.9	0.00	0.0	0.0
12/05/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
12/05/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
12/05/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
12/05/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.00	0.0	0.0
12/05/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/05/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	1,556.9	46.9	1,556.9	104,833.3	162.9	0.00	0.0	0.0
Minimum:	1,556.9	46.9	1,556.9	104,600.0	162.9	0.00	0.0	0.0
Maximum:	1,556.9	46.9	1,556.9	106,000.0	162.9	0.00	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/06/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/06/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/07/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/07/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/09/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/10/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/11/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/12/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/12/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/13/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/13/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/14/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/14/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/15/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/16/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/16/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/17/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/17/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/18/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/19/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/20/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/21/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/22/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/23/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/24/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/25/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/26/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/27/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/28/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/29/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT1 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT1 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT1 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT1 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT1 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT1 VOC_Norm, LbPerHr 1 Hour(s)
12/30/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/30/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
12/31/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/01/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/02/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/03/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/04/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/05/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/06/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/07/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/08/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/09/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/10/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 10:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 11:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 12:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 13:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 14:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 15:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 16:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 17:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 18:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 19:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 20:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 21:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 22:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/11/2019 23:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 01:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 02:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 03:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 04:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 05:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 06:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 07:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 08:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 09:00	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
10/12/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/12/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,583.3	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,700.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/13/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
10/14/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/14/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/15/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/16/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
10/17/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/17/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/18/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/19/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/20/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/21/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/21/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/21/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/21/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/21/2019 05:00	1,479.7	0.0	1,479.7	104,500.0	154.6	0.0	0.0	0.0
10/21/2019 06:00	4,013.6	0.0	4,013.6	104,500.0	419.4	0.5	0.3	0.8
10/21/2019 07:00	4,041.1	0.0	4,041.1	104,500.0	422.3	0.5	0.3	0.8
10/21/2019 08:00	3,898.0	8.6	3,898.4	104,500.0	407.4	0.5	0.2	0.8
10/21/2019 09:00	4,028.2	1,211.7	5,239.9	104,500.0	547.6	0.7	0.3	1.1
10/21/2019 10:00	3,990.7	323.9	4,314.6	104,500.0	450.9	0.5	0.3	0.9
10/21/2019 11:00	3,972.8	845.0	4,817.8	104,500.0	503.5	0.6	0.3	1.0
10/21/2019 12:00	3,955.6	1,314.5	5,270.1	104,500.0	550.7	0.7	0.3	1.1
10/21/2019 13:00	3,945.9	1,316.7	5,262.6	104,500.0	549.9	0.7	0.3	1.1
10/21/2019 14:00	3,946.4	1,269.3	5,215.7	104,500.0	545.0	0.7	0.3	1.1
10/21/2019 15:00	3,958.9	817.5	4,776.4	104,500.0	499.1	0.6	0.3	1.0
10/21/2019 16:00	3,965.5	979.2	4,944.7	104,500.0	516.7	0.6	0.3	1.0
10/21/2019 17:00	3,980.5	1,726.8	5,707.3	104,500.0	596.4	0.7	0.4	1.2
10/21/2019 18:00	4,003.0	1,022.7	5,025.7	104,500.0	525.2	0.6	0.3	1.1
10/21/2019 19:00	3,963.6	43.9	3,970.2	104,500.0	414.9	0.5	0.3	0.8
10/21/2019 20:00	3,819.8	0.0	3,819.8	104,500.0	399.2	0.5	0.2	0.8
10/21/2019 21:00	3,631.6	0.0	3,631.6	104,500.0	379.5	0.5	0.2	0.8
10/21/2019 22:00	3,018.4	0.0	3,018.4	104,500.0	315.4	0.4	0.2	0.6
10/21/2019 23:00	2,918.4	0.0	2,918.4	104,500.0	305.0	0.4	0.2	0.6
Average/Sum#:	3,712.2	572.6	4,282.4	104,500.0	447.5	0.6	0.3	0.9
Minimum:	1,479.7	0.0	1,479.7	104,500.0	154.6	0.4	0.2	0.6
Maximum:	4,041.1	1,726.8	5,707.3	104,500.0	596.4	0.7	0.4	1.2
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	2,912.8	0.0	2,912.8	104,500.0	304.4	0.4	0.2	0.6
10/22/2019 01:00	2,864.4	0.0	2,864.4	104,500.0	299.3	0.4	0.2	0.6
10/22/2019 02:00	2,860.4	0.0	2,860.4	104,500.0	298.9	0.4	0.2	0.6
10/22/2019 03:00	2,866.9	0.0	2,866.9	104,500.0	299.6	0.4	0.2	0.6
10/22/2019 04:00	2,984.0	0.0	2,984.0	104,500.0	311.8	0.4	0.2	0.6
10/22/2019 05:00	3,264.3	0.0	3,264.3	104,500.0	341.1	0.4	0.2	0.7
10/22/2019 06:00	3,343.7	0.0	3,343.7	104,500.0	349.4	0.4	0.2	0.7
10/22/2019 07:00	3,518.8	92.8	3,544.8	104,500.0	370.4	0.5	0.2	0.8
10/22/2019 08:00	3,980.5	1,091.2	5,017.1	104,500.0	524.3	0.6	0.3	1.1
10/22/2019 09:00	2,993.4	0.0	2,993.4	104,500.0	312.8	0.4	0.2	0.6
10/22/2019 10:00	3,885.6	1,161.8	5,024.2	104,500.0	525.0	0.6	0.3	1.1
10/22/2019 11:00	3,858.2	1,346.6	5,204.8	104,500.0	543.9	0.7	0.3	1.1
10/22/2019 12:00	3,452.9	727.1	3,801.9	104,500.0	397.3	0.5	0.3	0.9
10/22/2019 13:00	3,972.9	1,042.5	4,890.3	104,500.0	511.0	0.6	0.3	1.0
10/22/2019 14:00	3,988.8	1,249.4	5,238.2	104,500.0	547.4	0.7	0.3	1.1
10/22/2019 15:00	3,985.4	702.5	4,687.9	104,500.0	489.9	0.6	0.3	1.0
10/22/2019 16:00	3,980.1	547.3	4,527.4	104,500.0	473.1	0.6	0.3	0.9
10/22/2019 17:00	3,982.8	921.6	4,904.4	104,500.0	512.5	0.6	0.3	1.0
10/22/2019 18:00	3,999.5	726.3	4,725.8	104,500.0	493.8	0.6	0.3	1.0
10/22/2019 19:00	4,008.7	575.0	4,583.7	104,500.0	479.0	0.6	0.3	1.0
10/22/2019 20:00	3,732.6	9.7	3,733.6	104,500.0	390.2	0.5	0.2	0.8
10/22/2019 21:00	3,683.8	0.0	3,683.8	104,500.0	385.0	0.5	0.2	0.8
10/22/2019 22:00	3,682.1	0.0	3,682.1	104,500.0	384.8	0.5	0.2	0.8
10/22/2019 23:00	3,002.9	0.0	3,002.9	104,500.0	313.8	0.4	0.2	0.6
Average/Sum#:	3,533.6	424.7	3,931.0	104,500.0	410.8	0.5	0.2	0.8
Minimum:	2,860.4	0.0	2,860.4	104,500.0	298.9	0.4	0.2	0.6
Maximum:	4,008.7	1,346.6	5,238.2	104,500.0	547.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	2,911.7	0.0	2,911.7	104,500.0	304.3	0.4	0.2	0.6
10/23/2019 01:00	2,855.5	0.0	2,855.5	104,500.0	298.4	0.4	0.2	0.6
10/23/2019 02:00	2,855.5	0.0	2,855.5	104,500.0	298.4	0.4	0.2	0.6
10/23/2019 03:00	2,863.6	0.0	2,863.6	104,500.0	299.2	0.4	0.2	0.6
10/23/2019 04:00	3,009.7	0.0	3,009.7	104,500.0	314.5	0.4	0.2	0.6
10/23/2019 05:00	3,040.0	0.0	3,040.0	104,500.0	317.7	0.4	0.2	0.6
10/23/2019 06:00	3,381.5	0.0	3,381.5	104,500.0	353.4	0.4	0.2	0.7
10/23/2019 07:00	4,035.2	522.2	4,520.8	104,500.0	472.4	0.6	0.3	1.0
10/23/2019 08:00	3,980.3	1,325.8	5,306.1	104,500.0	554.5	0.7	0.3	1.1
10/23/2019 09:00	3,928.8	1,118.7	5,047.5	104,500.0	527.5	0.6	0.3	1.1
10/23/2019 10:00	3,873.3	1,252.1	5,125.4	104,500.0	535.6	0.6	0.3	1.1
10/23/2019 11:00	3,815.8	1,068.9	4,884.7	104,500.0	510.5	0.6	0.3	1.0
10/23/2019 12:00	3,947.0	636.4	4,583.4	104,500.0	479.0	0.6	0.3	1.0
10/23/2019 13:00	3,948.9	252.1	4,201.0	104,500.0	439.0	0.5	0.3	0.9
10/23/2019 14:00	3,901.4	208.5	4,078.6	104,500.0	426.2	0.5	0.3	0.9
10/23/2019 15:00	3,947.7	564.2	4,511.9	104,500.0	471.5	0.6	0.3	0.9
10/23/2019 16:00	3,968.4	430.1	4,398.5	104,500.0	459.6	0.6	0.3	0.9
10/23/2019 17:00	3,997.2	1,275.1	5,272.3	104,500.0	551.0	0.7	0.3	1.1
10/23/2019 18:00	4,012.8	579.4	4,592.2	104,500.0	479.9	0.6	0.3	1.0
10/23/2019 19:00	3,872.4	7.1	3,873.0	104,500.0	404.7	0.5	0.2	0.8
10/23/2019 20:00	3,713.6	0.0	3,713.6	104,500.0	388.1	0.5	0.2	0.8
10/23/2019 21:00	4,057.9	244.8	4,283.1	104,500.0	447.6	0.5	0.3	0.9
10/23/2019 22:00	3,431.9	0.0	3,431.9	104,500.0	358.6	0.4	0.2	0.7
10/23/2019 23:00	3,170.4	0.0	3,170.4	104,500.0	331.3	0.4	0.2	0.7
Average/Sum#:	3,605.0	395.2	3,996.3	104,500.0	417.6	0.5	0.3	0.8
Minimum:	2,855.5	0.0	2,855.5	104,500.0	298.4	0.4	0.2	0.6
Maximum:	4,057.9	1,325.8	5,306.1	104,500.0	554.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	3,023.3	0.0	3,023.3	104,500.0	315.9	0.4	0.2	0.6
10/24/2019 01:00	3,020.1	0.0	3,020.1	104,500.0	315.6	0.4	0.2	0.6
10/24/2019 02:00	3,032.3	0.0	3,032.3	104,500.0	316.9	0.4	0.2	0.6
10/24/2019 03:00	3,032.1	0.0	3,032.1	104,500.0	316.9	0.4	0.2	0.6
10/24/2019 04:00	3,461.5	0.0	3,461.5	104,500.0	361.7	0.4	0.2	0.7
10/24/2019 05:00	4,075.3	628.3	4,684.8	104,500.0	489.6	0.6	0.3	1.0
10/24/2019 06:00	4,060.4	779.9	4,840.3	104,500.0	505.8	0.6	0.3	1.0
10/24/2019 07:00	4,040.9	0.0	4,040.9	104,500.0	422.3	0.5	0.3	0.8
10/24/2019 08:00	3,589.2	0.0	3,589.2	104,500.0	375.1	0.5	0.2	0.8
10/24/2019 09:00	3,170.8	0.0	3,170.8	104,500.0	331.3	0.4	0.2	0.7
10/24/2019 10:00	3,089.3	0.0	3,089.3	104,500.0	322.8	0.4	0.2	0.6
10/24/2019 11:00	3,099.7	0.0	3,099.7	104,500.0	323.9	0.4	0.2	0.6
10/24/2019 12:00	3,106.7	0.0	3,106.7	104,500.0	324.7	0.4	0.2	0.7
10/24/2019 13:00	3,107.1	0.0	3,107.1	104,500.0	324.7	0.4	0.2	0.7
10/24/2019 14:00	2,815.4	0.0	2,815.4	104,500.0	294.2	0.4	0.2	0.6
10/24/2019 15:00	2,973.2	0.0	2,973.2	104,500.0	310.7	0.4	0.2	0.6
10/24/2019 16:00	3,858.4	9.0	3,859.0	104,500.0	403.3	0.5	0.2	0.8
10/24/2019 17:00	3,991.6	555.9	4,547.5	104,500.0	475.2	0.6	0.3	1.0
10/24/2019 18:00	3,650.4	12.4	3,652.0	104,500.0	381.6	0.5	0.2	0.8
10/24/2019 19:00	1,333.3	0.0	1,333.3	104,500.0	139.3	0.0	0.0	0.0
10/24/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/24/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/24/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/24/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,276.6	99.3	3,373.9	104,500.0	352.6	0.5	0.2	0.7
Minimum:	1,333.3	0.0	1,333.3	104,500.0	139.3	0.4	0.2	0.6
Maximum:	4,075.3	779.9	4,840.3	104,500.0	505.8	0.6	0.3	1.0
%SI	16.67	16.67	16.67	0.00	16.67	20.83	20.83	20.83

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 13:00	1,412.6	0.0	1,412.6	104,500.0	147.6	0.0	0.0	0.0
10/25/2019 14:00	3,111.5	0.0	3,111.5	104,500.0	325.2	0.4	0.2	0.6
10/25/2019 15:00	2,997.0	0.0	2,997.0	104,500.0	313.2	0.4	0.2	0.6
10/25/2019 16:00	3,801.6	0.0	3,801.6	104,500.0	397.3	0.5	0.2	0.8
10/25/2019 17:00	3,977.6	0.0	3,977.6	104,500.0	415.7	0.5	0.2	0.8
10/25/2019 18:00	2,887.6	0.0	2,887.6	104,500.0	301.8	0.4	0.2	0.6
10/25/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/25/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,031.3	0.0	3,031.3	104,500.0	316.8	0.4	0.2	0.7
Minimum:	1,412.6	0.0	1,412.6	104,500.0	147.6	0.4	0.2	0.6
Maximum:	3,977.6	0.0	3,977.6	104,500.0	415.7	0.5	0.2	0.8
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/26/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/27/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/28/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 03:00	1,006.9	0.0	1,006.9	104,500.0	105.2	0.0	0.0	0.0
10/29/2019 04:00	1,073.7	0.0	1,073.7	104,500.0	112.2	0.0	0.0	0.0
10/29/2019 05:00	624.9	0.0	624.9	104,500.0	65.3	0.0	0.0	0.0
10/29/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 09:00	684.2	0.0	684.2	104,500.0	71.5	0.0	0.0	0.0
10/29/2019 10:00	153.3	0.0	153.3	104,500.0	16.0	0.0	0.0	0.0
10/29/2019 11:00	700.5	0.0	700.5	104,500.0	73.2	0.0	0.0	0.0
10/29/2019 12:00	387.8	0.0	387.8	104,500.0	40.5	0.0	0.0	0.0
10/29/2019 13:00	566.8	0.0	566.8	104,500.0	59.2	0.0	0.0	0.0
10/29/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/29/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	649.8	0.0	649.8	104,500.0	67.9	0.0	0.0	0.0
Minimum:	153.3	0.0	153.3	104,500.0	16.0	0.0	0.0	0.0
Maximum:	1,073.7	0.0	1,073.7	104,500.0	112.2	0.0	0.0	0.0
%SI	66.67	66.67	66.67	0.00	66.67	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 07:00	2,408.9	0.0	2,408.9	104,500.0	251.7	0.0	0.0	0.0
10/30/2019 08:00	2,928.1	0.0	2,928.1	104,500.0	306.0	0.4	0.2	0.6
10/30/2019 09:00	2,843.8	0.0	2,843.8	104,500.0	297.2	0.4	0.2	0.6
10/30/2019 10:00	2,833.3	0.0	2,833.3	104,500.0	296.1	0.4	0.2	0.6
10/30/2019 11:00	2,678.8	0.0	2,678.8	104,500.0	279.9	0.4	0.2	0.6
10/30/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/30/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,738.6	0.0	2,738.6	104,500.0	286.2	0.4	0.2	0.6
Minimum:	2,408.9	0.0	2,408.9	104,500.0	251.7	0.4	0.2	0.6
Maximum:	2,928.1	0.0	2,928.1	104,500.0	306.0	0.4	0.2	0.6
%SI	79.17	79.17	79.17	0.00	79.17	83.33	83.33	83.33

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
10/31/2019 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
11/01/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/01/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,937.5	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/02/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/03/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/04/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/05/2019 13:00	1,539.9	0.0	1,539.9	106,000.0	163.2	0.0	0.0	0.0
11/05/2019 14:00	3,254.8	0.0	3,254.8	106,000.0	345.0	0.4	0.2	0.7
11/05/2019 15:00	3,911.7	118.7	3,935.4	106,000.0	417.2	0.5	0.3	0.9
11/05/2019 16:00	4,014.4	551.1	4,207.3	106,000.0	446.0	0.6	0.3	1.0
11/05/2019 17:00	4,023.1	0.0	4,023.1	106,000.0	426.4	0.5	0.3	0.9
11/05/2019 18:00	4,022.1	0.0	4,022.1	106,000.0	426.3	0.5	0.3	0.9
11/05/2019 19:00	3,837.7	0.0	3,837.7	106,000.0	406.8	0.5	0.2	0.8
11/05/2019 20:00	3,724.6	0.0	3,724.6	106,000.0	394.8	0.5	0.2	0.8
11/05/2019 21:00	2,965.5	0.0	2,965.5	106,000.0	314.3	0.4	0.2	0.6
11/05/2019 22:00	2,979.7	0.0	2,979.7	106,000.0	315.8	0.4	0.2	0.6
11/05/2019 23:00	3,027.1	0.0	3,027.1	106,000.0	320.9	0.4	0.2	0.6
Average/Sum#:	3,391.0	60.9	3,410.7	106,000.0	361.5	0.5	0.2	0.8
Minimum:	1,539.9	0.0	1,539.9	106,000.0	163.2	0.4	0.2	0.6
Maximum:	4,023.1	551.1	4,207.3	106,000.0	446.0	0.6	0.3	1.0
%SI	54.17	54.17	54.17	0.00	54.17	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	3,117.0	0.0	3,117.0	106,000.0	330.4	0.4	0.2	0.7
11/06/2019 01:00	3,150.9	0.0	3,150.9	106,000.0	334.0	0.4	0.2	0.7
11/06/2019 02:00	3,186.1	0.0	3,186.1	106,000.0	337.7	0.4	0.2	0.7
11/06/2019 03:00	3,222.8	0.0	3,222.8	106,000.0	341.6	0.4	0.2	0.7
11/06/2019 04:00	3,256.7	0.0	3,256.7	106,000.0	345.2	0.4	0.2	0.7
11/06/2019 05:00	3,278.0	0.0	3,278.0	106,000.0	347.5	0.4	0.2	0.7
11/06/2019 06:00	3,523.7	0.0	3,523.7	106,000.0	373.5	0.4	0.2	0.7
11/06/2019 07:00	3,537.4	0.0	3,537.4	106,000.0	375.0	0.4	0.2	0.7
11/06/2019 08:00	3,230.9	0.0	3,230.9	106,000.0	342.5	0.4	0.2	0.7
11/06/2019 09:00	3,425.0	0.0	3,425.0	106,000.0	363.1	0.4	0.2	0.7
11/06/2019 10:00	3,464.2	0.0	3,464.2	106,000.0	367.2	0.4	0.2	0.7
11/06/2019 11:00	3,405.7	0.0	3,405.7	106,000.0	361.0	0.4	0.2	0.7
11/06/2019 12:00	3,632.4	0.0	3,632.4	106,000.0	385.0	0.5	0.2	0.8
11/06/2019 13:00	3,722.5	0.0	3,722.5	106,000.0	394.6	0.5	0.2	0.8
11/06/2019 14:00	3,937.8	0.6	3,937.8	106,000.0	417.4	0.5	0.3	0.8
11/06/2019 15:00	4,003.3	540.3	4,543.6	106,000.0	481.6	0.6	0.3	1.0
11/06/2019 16:00	4,003.4	648.1	4,651.5	106,000.0	493.1	0.6	0.3	1.0
11/06/2019 17:00	4,021.5	1,507.1	5,528.6	106,000.0	586.0	0.7	0.4	1.2
11/06/2019 18:00	4,041.0	1,560.4	5,601.4	106,000.0	593.7	0.7	0.4	1.2
11/06/2019 19:00	4,053.2	1,404.4	5,457.6	106,000.0	578.5	0.7	0.3	1.2
11/06/2019 20:00	4,059.3	1,461.2	5,520.5	106,000.0	585.2	0.7	0.4	1.2
11/06/2019 21:00	4,067.4	854.8	4,853.8	106,000.0	514.5	0.6	0.3	1.0
11/06/2019 22:00	3,387.6	0.0	3,387.6	106,000.0	359.1	0.4	0.2	0.7
11/06/2019 23:00	2,799.3	0.0	2,799.3	106,000.0	296.7	0.4	0.2	0.6
Average/Sum#:	3,563.6	332.4	3,893.1	106,000.0	412.7	0.5	0.2	0.8
Minimum:	2,799.3	0.0	2,799.3	106,000.0	296.7	0.4	0.2	0.6
Maximum:	4,067.4	1,560.4	5,601.4	106,000.0	593.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	1,147.5	0.0	1,147.5	106,000.0	121.6	0.0	0.0	0.0
11/07/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 10:00	1,558.8	0.0	1,558.8	106,000.0	165.2	0.0	0.0	0.0
11/07/2019 11:00	3,062.4	0.0	3,062.4	106,000.0	324.6	0.4	0.2	0.6
11/07/2019 12:00	2,861.8	0.0	2,861.8	106,000.0	303.4	0.4	0.2	0.6
11/07/2019 13:00	2,826.3	0.0	2,826.3	106,000.0	299.6	0.4	0.2	0.6
11/07/2019 14:00	2,849.3	0.0	2,849.3	106,000.0	302.0	0.4	0.2	0.6
11/07/2019 15:00	3,002.3	0.0	3,002.3	106,000.0	318.2	0.4	0.2	0.6
11/07/2019 16:00	3,877.6	0.0	3,877.6	106,000.0	411.0	0.5	0.2	0.8
11/07/2019 17:00	4,038.2	2.1	4,038.5	106,000.0	428.1	0.5	0.3	0.9
11/07/2019 18:00	4,053.3	110.8	4,164.1	106,000.0	441.4	0.5	0.3	0.9
11/07/2019 19:00	3,871.6	7.8	3,875.7	106,000.0	410.8	0.5	0.2	0.8
11/07/2019 20:00	3,377.8	0.0	3,377.8	106,000.0	358.0	0.4	0.2	0.7
11/07/2019 21:00	2,400.8	0.0	2,400.8	106,000.0	254.5	0.4	0.2	0.7
11/07/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/07/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,994.4	9.3	3,003.3	106,000.0	318.3	0.4	0.2	0.7
Minimum:	1,147.5	0.0	1,147.5	106,000.0	121.6	0.4	0.2	0.6
Maximum:	4,053.3	110.8	4,164.1	106,000.0	441.4	0.5	0.3	0.9
%SI	45.83	45.83	45.83	0.00	45.83	54.17	54.17	54.17

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/08/2019 09:00	1,604.9	0.0	1,604.9	106,000.0	170.1	0.0	0.0	0.0
11/08/2019 10:00	3,076.1	0.0	3,076.1	106,000.0	326.1	0.4	0.2	0.6
11/08/2019 11:00	2,849.5	0.0	2,849.5	106,000.0	302.0	0.4	0.2	0.6
11/08/2019 12:00	2,929.1	0.0	2,929.1	106,000.0	310.5	0.4	0.2	0.6
11/08/2019 13:00	3,058.1	0.0	3,058.1	106,000.0	324.2	0.4	0.2	0.6
11/08/2019 14:00	3,170.9	0.0	3,170.9	106,000.0	336.1	0.4	0.2	0.7
11/08/2019 15:00	3,973.0	90.8	4,025.7	106,000.0	426.7	0.5	0.3	0.9
11/08/2019 16:00	4,038.7	124.9	4,163.6	106,000.0	441.3	0.5	0.3	0.9
11/08/2019 17:00	4,061.2	1,168.5	5,229.7	106,000.0	554.3	0.7	0.3	1.1
11/08/2019 18:00	4,074.9	1,338.1	5,413.0	106,000.0	573.8	0.7	0.3	1.1
11/08/2019 19:00	4,072.6	1,182.5	5,196.0	106,000.0	550.8	0.7	0.3	1.1
11/08/2019 20:00	2,912.2	0.0	2,912.2	106,000.0	308.7	0.4	0.2	0.6
11/08/2019 21:00	2,957.9	0.0	2,957.9	106,000.0	313.5	0.4	0.2	0.6
11/08/2019 22:00	2,970.5	0.0	2,970.5	106,000.0	314.9	0.4	0.2	0.6
11/08/2019 23:00	2,709.7	0.0	2,709.7	106,000.0	287.2	0.3	0.2	0.6
Average/Sum#:	3,230.6	260.3	3,484.5	106,000.0	369.3	0.5	0.2	0.8
Minimum:	1,604.9	0.0	1,604.9	106,000.0	170.1	0.3	0.2	0.6
Maximum:	4,074.9	1,338.1	5,413.0	106,000.0	573.8	0.7	0.3	1.1
%SI	37.50	37.50	37.50	0.00	37.50	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	1,178.0	0.0	1,178.0	106,000.0	124.9	0.0	0.0	0.0
11/09/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/09/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	1,178.0	0.0	1,178.0	106,000.0	124.9	0.0	0.0	0.0
Minimum:	1,178.0	0.0	1,178.0	106,000.0	124.9	0.0	0.0	0.0
Maximum:	1,178.0	0.0	1,178.0	106,000.0	124.9	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/10/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/11/2019 23:00	2,184.0	0.0	2,184.0	106,000.0	231.5	0.0	0.0	0.0
Average/Sum#:	2,184.0	0.0	2,184.0	106,000.0	231.5	0.0	0.0	0.0
Minimum:	2,184.0	0.0	2,184.0	106,000.0	231.5	0.0	0.0	0.0
Maximum:	2,184.0	0.0	2,184.0	106,000.0	231.5	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	3,047.2	0.0	3,047.2	106,000.0	323.0	0.4	0.2	0.7
11/12/2019 01:00	3,057.3	0.0	3,057.3	106,000.0	324.1	0.4	0.2	0.6
11/12/2019 02:00	2,964.4	0.0	2,964.4	106,000.0	314.2	0.4	0.2	0.6
11/12/2019 03:00	2,954.0	0.0	2,954.0	106,000.0	313.1	0.4	0.2	0.6
11/12/2019 04:00	3,247.4	0.0	3,247.4	106,000.0	344.2	0.4	0.2	0.7
11/12/2019 05:00	3,742.9	1.2	3,742.9	106,000.0	396.7	0.5	0.2	0.8
11/12/2019 06:00	4,103.2	613.5	4,716.7	106,000.0	500.0	0.6	0.3	1.0
11/12/2019 07:00	4,084.7	382.5	4,436.6	106,000.0	470.3	0.6	0.3	0.9
11/12/2019 08:00	3,181.2	0.0	3,181.2	106,000.0	337.2	0.4	0.2	0.7
11/12/2019 09:00	3,549.8	0.0	3,549.8	106,000.0	376.3	0.5	0.2	0.8
11/12/2019 10:00	3,692.4	0.0	3,692.4	106,000.0	391.4	0.5	0.2	0.8
11/12/2019 11:00	3,407.8	0.0	3,407.8	106,000.0	361.2	0.4	0.2	0.7
11/12/2019 12:00	3,912.2	0.0	3,912.2	106,000.0	414.7	0.5	0.2	0.8
11/12/2019 13:00	3,646.7	0.0	3,646.7	106,000.0	386.6	0.5	0.2	0.8
11/12/2019 14:00	3,645.7	0.0	3,645.7	106,000.0	386.4	0.5	0.2	0.8
11/12/2019 15:00	3,675.5	0.0	3,675.5	106,000.0	389.6	0.5	0.2	0.8
11/12/2019 16:00	4,026.7	320.7	4,347.4	106,000.0	460.8	0.6	0.3	0.9
11/12/2019 17:00	4,031.4	441.0	4,472.4	106,000.0	474.1	0.6	0.3	0.9
11/12/2019 18:00	4,042.1	990.4	5,032.5	106,000.0	533.4	0.6	0.3	1.1
11/12/2019 19:00	4,056.2	999.7	5,055.9	106,000.0	535.9	0.6	0.3	1.1
11/12/2019 20:00	3,355.6	8.3	3,356.0	106,000.0	355.7	0.4	0.2	0.7
11/12/2019 21:00	3,948.0	0.0	3,948.0	106,000.0	418.5	0.5	0.3	0.8
11/12/2019 22:00	3,925.2	0.4	3,925.2	106,000.0	416.1	0.5	0.2	0.8
11/12/2019 23:00	3,447.0	0.0	3,447.0	106,000.0	365.4	0.4	0.2	0.7
Average/Sum#:	3,614.4	156.6	3,769.3	106,000.0	399.5	0.5	0.2	0.8
Minimum:	2,954.0	0.0	2,954.0	106,000.0	313.1	0.4	0.2	0.6
Maximum:	4,103.2	999.7	5,055.9	106,000.0	535.9	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	4,091.0	473.8	4,531.6	106,000.0	480.3	0.6	0.3	1.0
11/13/2019 01:00	4,094.1	275.9	4,370.0	106,000.0	463.2	0.6	0.3	0.9
11/13/2019 02:00	4,094.6	9.5	4,104.1	106,000.0	435.0	0.5	0.3	0.9
11/13/2019 03:00	4,092.5	44.9	4,137.4	106,000.0	438.6	0.5	0.3	0.9
11/13/2019 04:00	4,127.0	370.1	4,497.1	106,000.0	476.7	0.6	0.3	1.0
11/13/2019 05:00	4,126.7	1,050.7	5,177.4	106,000.0	548.8	0.7	0.3	1.1
11/13/2019 06:00	4,090.6	1,030.8	5,121.4	106,000.0	542.9	0.7	0.3	1.1
11/13/2019 07:00	3,342.6	3.4	3,342.7	106,000.0	354.3	0.4	0.2	0.7
11/13/2019 08:00	3,398.5	0.0	3,398.5	106,000.0	360.2	0.4	0.2	0.7
11/13/2019 09:00	3,522.1	0.0	3,522.1	106,000.0	373.3	0.4	0.2	0.7
11/13/2019 10:00	3,531.0	0.0	3,531.0	106,000.0	374.3	0.5	0.2	0.7
11/13/2019 11:00	3,606.1	0.0	3,606.1	106,000.0	382.2	0.5	0.2	0.8
11/13/2019 12:00	3,636.5	0.0	3,636.5	106,000.0	385.5	0.5	0.2	0.8
11/13/2019 13:00	3,738.1	0.0	3,738.1	106,000.0	396.2	0.5	0.2	0.8
11/13/2019 14:00	3,929.0	0.0	3,929.0	106,000.0	416.5	0.5	0.2	0.8
11/13/2019 15:00	4,006.0	0.0	4,006.0	106,000.0	424.6	0.5	0.3	0.8
11/13/2019 16:00	4,018.1	0.0	4,018.1	106,000.0	425.9	0.5	0.3	0.9
11/13/2019 17:00	4,029.0	0.0	4,029.0	106,000.0	427.1	0.5	0.3	0.9
11/13/2019 18:00	4,045.3	0.0	4,045.3	106,000.0	428.8	0.5	0.3	0.9
11/13/2019 19:00	4,046.1	0.0	4,046.1	106,000.0	428.9	0.5	0.3	0.9
11/13/2019 20:00	4,014.3	0.0	4,014.3	106,000.0	425.5	0.5	0.3	0.9
11/13/2019 21:00	2,830.2	0.0	2,830.2	106,000.0	300.0	0.4	0.2	0.6
11/13/2019 22:00	2,922.4	0.0	2,922.4	106,000.0	309.8	0.4	0.2	0.6
11/13/2019 23:00	2,794.7	0.0	2,794.7	106,000.0	296.2	0.4	0.2	0.6
Average/Sum#:	3,755.3	135.8	3,889.5	106,000.0	412.3	0.5	0.3	0.8
Minimum:	2,794.7	0.0	2,794.7	106,000.0	296.2	0.4	0.2	0.6
Maximum:	4,127.0	1,050.7	5,177.4	106,000.0	548.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	2,710.4	0.0	2,710.4	106,000.0	287.3	0.3	0.2	0.6
11/14/2019 01:00	2,710.4	0.0	2,710.4	106,000.0	287.3	0.3	0.2	0.6
11/14/2019 02:00	2,711.1	0.0	2,711.1	106,000.0	287.4	0.3	0.2	0.6
11/14/2019 03:00	2,711.5	0.0	2,711.5	106,000.0	287.4	0.3	0.2	0.6
11/14/2019 04:00	2,712.9	0.0	2,712.9	106,000.0	287.6	0.3	0.2	0.6
11/14/2019 05:00	2,770.1	0.0	2,770.1	106,000.0	293.6	0.4	0.2	0.6
11/14/2019 06:00	3,952.4	0.0	3,952.4	106,000.0	419.0	0.5	0.3	0.8
11/14/2019 07:00	3,233.7	0.0	3,233.7	106,000.0	342.8	0.4	0.2	0.7
11/14/2019 08:00	3,529.1	0.0	3,529.1	106,000.0	374.1	0.4	0.2	0.7
11/14/2019 09:00	3,677.4	0.0	3,677.4	106,000.0	389.8	0.5	0.2	0.8
11/14/2019 10:00	3,729.1	0.0	3,729.1	106,000.0	395.3	0.5	0.2	0.8
11/14/2019 11:00	3,895.3	0.0	3,895.3	106,000.0	412.9	0.5	0.2	0.8
11/14/2019 12:00	3,920.1	0.0	3,920.1	106,000.0	415.5	0.5	0.2	0.8
11/14/2019 13:00	3,958.2	0.0	3,958.2	106,000.0	419.6	0.5	0.3	0.8
11/14/2019 14:00	3,992.1	0.0	3,992.1	106,000.0	423.2	0.5	0.3	0.8
11/14/2019 15:00	4,052.9	0.0	4,052.9	106,000.0	429.6	0.5	0.3	0.9
11/14/2019 16:00	4,047.7	0.0	4,047.7	106,000.0	429.1	0.5	0.3	0.9
11/14/2019 17:00	4,064.1	0.0	4,064.1	106,000.0	430.8	0.5	0.3	0.9
11/14/2019 18:00	4,075.1	0.0	4,075.1	106,000.0	432.0	0.5	0.3	0.9
11/14/2019 19:00	4,081.9	0.0	4,081.9	106,000.0	432.7	0.5	0.3	0.9
11/14/2019 20:00	4,033.4	0.0	4,033.4	106,000.0	427.5	0.5	0.3	0.9
11/14/2019 21:00	2,913.0	0.0	2,913.0	106,000.0	308.8	0.4	0.2	0.6
11/14/2019 22:00	2,923.5	0.0	2,923.5	106,000.0	309.9	0.4	0.2	0.6
11/14/2019 23:00	2,837.0	0.0	2,837.0	106,000.0	300.7	0.4	0.2	0.6
Average/Sum#:	3,468.4	0.0	3,468.4	106,000.0	367.7	0.4	0.2	0.7
Minimum:	2,710.4	0.0	2,710.4	106,000.0	287.3	0.3	0.2	0.6
Maximum:	4,081.9	0.0	4,081.9	106,000.0	432.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	2,238.9	0.0	2,238.9	106,000.0	237.3	0.4	0.2	0.6
11/15/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/15/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,238.9	0.0	2,238.9	106,000.0	237.3	0.4	0.2	0.6
Minimum:	2,238.9	0.0	2,238.9	106,000.0	237.3	0.4	0.2	0.6
Maximum:	2,238.9	0.0	2,238.9	106,000.0	237.3	0.4	0.2	0.6
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
11/16/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/16/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/17/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/18/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/19/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 03:00	1,509.7	0.0	1,509.7	106,000.0	160.0	0.0	0.0	0.0
11/20/2019 04:00	3,850.5	0.0	3,850.5	106,000.0	408.2	0.5	0.2	0.8
11/20/2019 05:00	3,891.9	0.0	3,891.9	106,000.0	412.5	0.5	0.2	0.8
11/20/2019 06:00	3,353.2	0.0	3,353.2	106,000.0	355.4	0.4	0.2	0.7
11/20/2019 07:00	2,045.9	0.0	2,045.9	106,000.0	216.9	0.4	0.2	0.6
11/20/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/20/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,930.2	0.0	2,930.2	106,000.0	310.6	0.5	0.2	0.7
Minimum:	1,509.7	0.0	1,509.7	106,000.0	160.0	0.4	0.2	0.6
Maximum:	3,891.9	0.0	3,891.9	106,000.0	412.5	0.5	0.2	0.8
%SI	79.17	79.17	79.17	0.00	79.17	83.33	83.33	83.33

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/21/2019 06:00	1,430.8	0.0	1,430.8	106,000.0	151.7	0.0	0.0	0.0
11/21/2019 07:00	3,886.8	0.0	3,886.8	106,000.0	412.0	0.5	0.3	0.9
11/21/2019 08:00	4,061.1	0.0	4,061.1	106,000.0	430.5	0.5	0.3	0.9
11/21/2019 09:00	3,429.0	0.0	3,429.0	106,000.0	363.5	0.4	0.2	0.7
11/21/2019 10:00	3,436.8	0.0	3,436.8	106,000.0	364.3	0.4	0.2	0.7
11/21/2019 11:00	3,484.0	0.0	3,484.0	106,000.0	369.3	0.4	0.2	0.7
11/21/2019 12:00	3,544.0	0.0	3,544.0	106,000.0	375.7	0.5	0.2	0.8
11/21/2019 13:00	3,591.9	0.0	3,591.9	106,000.0	380.7	0.5	0.2	0.8
11/21/2019 14:00	3,594.2	0.0	3,594.2	106,000.0	381.0	0.5	0.2	0.8
11/21/2019 15:00	3,923.2	0.0	3,923.2	106,000.0	415.9	0.5	0.2	0.8
11/21/2019 16:00	3,993.8	0.0	3,993.8	106,000.0	423.3	0.5	0.3	0.8
11/21/2019 17:00	4,017.5	0.0	4,017.5	106,000.0	425.9	0.5	0.3	0.9
11/21/2019 18:00	4,052.7	0.0	4,052.7	106,000.0	429.6	0.5	0.3	0.9
11/21/2019 19:00	4,065.8	0.0	4,065.8	106,000.0	431.0	0.5	0.3	0.9
11/21/2019 20:00	4,077.1	0.0	4,077.1	106,000.0	432.2	0.5	0.3	0.9
11/21/2019 21:00	3,906.8	0.0	3,906.8	106,000.0	414.1	0.5	0.2	0.8
11/21/2019 22:00	2,855.1	0.0	2,855.1	106,000.0	302.6	0.4	0.2	0.6
11/21/2019 23:00	2,780.2	0.0	2,780.2	106,000.0	294.7	0.4	0.2	0.6
Average/Sum#:	3,562.8	0.0	3,562.8	106,000.0	377.7	0.5	0.2	0.8
Minimum:	1,430.8	0.0	1,430.8	106,000.0	151.7	0.4	0.2	0.6
Maximum:	4,077.1	0.0	4,077.1	106,000.0	432.2	0.5	0.3	0.9
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	2,797.4	0.0	2,797.4	106,000.0	296.5	0.4	0.2	0.6
11/22/2019 01:00	2,780.8	0.0	2,780.8	106,000.0	294.8	0.4	0.2	0.6
11/22/2019 02:00	2,781.1	0.0	2,781.1	106,000.0	294.8	0.4	0.2	0.6
11/22/2019 03:00	2,782.4	0.0	2,782.4	106,000.0	294.9	0.4	0.2	0.6
11/22/2019 04:00	2,794.8	0.0	2,794.8	106,000.0	296.2	0.4	0.2	0.6
11/22/2019 05:00	2,930.8	0.0	2,930.8	106,000.0	310.7	0.4	0.2	0.6
11/22/2019 06:00	3,489.6	0.0	3,489.6	106,000.0	369.9	0.4	0.2	0.7
11/22/2019 07:00	3,269.7	0.0	3,269.7	106,000.0	346.6	0.4	0.2	0.7
11/22/2019 08:00	3,527.8	0.0	3,527.8	106,000.0	373.9	0.4	0.2	0.7
11/22/2019 09:00	3,571.7	0.0	3,571.7	106,000.0	378.6	0.5	0.2	0.8
11/22/2019 10:00	3,624.7	0.0	3,624.7	106,000.0	384.2	0.5	0.2	0.8
11/22/2019 11:00	3,703.8	0.0	3,703.8	106,000.0	392.6	0.5	0.2	0.8
11/22/2019 12:00	3,816.3	0.0	3,816.3	106,000.0	404.5	0.5	0.2	0.8
11/22/2019 13:00	3,734.0	0.0	3,734.0	106,000.0	395.8	0.5	0.2	0.8
11/22/2019 14:00	3,757.2	0.0	3,757.2	106,000.0	398.3	0.5	0.2	0.8
11/22/2019 15:00	4,071.4	49.0	4,078.8	106,000.0	432.4	0.5	0.3	0.9
11/22/2019 16:00	4,078.7	1,360.3	5,439.0	106,000.0	576.5	0.7	0.3	1.2
11/22/2019 17:00	4,093.2	1,362.9	5,456.1	106,000.0	578.3	0.7	0.3	1.2
11/22/2019 18:00	4,109.1	1,339.9	5,449.0	106,000.0	577.6	0.7	0.3	1.2
11/22/2019 19:00	4,124.6	1,309.7	5,434.3	106,000.0	576.0	0.7	0.3	1.2
11/22/2019 20:00	4,069.2	1,268.9	5,338.1	106,000.0	565.8	0.7	0.3	1.1
11/22/2019 21:00	3,965.7	10.0	3,966.4	106,000.0	420.4	0.5	0.3	0.8
11/22/2019 22:00	3,987.6	0.0	3,987.6	106,000.0	422.7	0.5	0.3	0.8
11/22/2019 23:00	3,970.5	0.0	3,970.5	106,000.0	420.9	0.5	0.3	0.8
Average/Sum#:	3,576.3	279.2	3,853.4	106,000.0	408.5	0.5	0.2	0.8
Minimum:	2,780.8	0.0	2,780.8	106,000.0	294.8	0.4	0.2	0.6
Maximum:	4,124.6	1,362.9	5,456.1	106,000.0	578.3	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	2,262.6	0.0	2,262.6	106,000.0	239.8	0.4	0.2	0.6
11/23/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/23/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,262.6	0.0	2,262.6	106,000.0	239.8	0.4	0.2	0.6
Minimum:	2,262.6	0.0	2,262.6	106,000.0	239.8	0.4	0.2	0.6
Maximum:	2,262.6	0.0	2,262.6	106,000.0	239.8	0.4	0.2	0.6
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/24/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 03:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 08:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 09:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 10:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 11:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 12:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 13:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 14:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 15:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 16:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 17:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 18:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 19:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 20:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 21:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 22:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/25/2019 23:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/26/2019 01:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/26/2019 02:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
11/26/2019 03:00	1,375.0	0.0	1,375.0	106,000.0	145.8	0.0	0.0	0.0
11/26/2019 04:00	3,040.0	0.0	3,040.0	106,000.0	322.2	0.4	0.2	0.7
11/26/2019 05:00	3,914.3	0.0	3,914.3	106,000.0	414.9	0.5	0.2	0.8
11/26/2019 06:00	3,734.6	0.0	3,734.6	106,000.0	395.9	0.5	0.2	0.8
11/26/2019 07:00	3,674.9	0.0	3,674.9	106,000.0	389.5	0.5	0.2	0.8
11/26/2019 08:00	3,765.6	0.0	3,765.6	106,000.0	399.2	0.5	0.2	0.8
11/26/2019 09:00	3,892.2	0.0	3,892.2	106,000.0	412.6	0.5	0.2	0.8
11/26/2019 10:00	3,970.9	0.0	3,970.9	106,000.0	420.9	0.5	0.3	0.8
11/26/2019 11:00	4,013.4	0.0	4,013.4	106,000.0	425.4	0.5	0.3	0.9
11/26/2019 12:00	4,055.3	0.0	4,055.3	106,000.0	429.9	0.5	0.3	0.9
11/26/2019 13:00	3,969.9	0.0	3,969.9	106,000.0	420.8	0.5	0.3	0.8
11/26/2019 14:00	3,905.8	0.0	3,905.8	106,000.0	414.0	0.5	0.2	0.8
11/26/2019 15:00	3,909.1	0.0	3,909.1	106,000.0	414.4	0.5	0.2	0.8
11/26/2019 16:00	4,089.2	251.1	4,302.6	106,000.0	456.1	0.6	0.3	0.9
11/26/2019 17:00	4,088.6	1,603.7	5,692.3	106,000.0	603.4	0.7	0.4	1.2
11/26/2019 18:00	4,085.8	1,394.0	5,479.8	106,000.0	580.9	0.7	0.3	1.2
11/26/2019 19:00	3,826.0	47.3	3,831.7	106,000.0	406.2	0.5	0.2	0.8
11/26/2019 20:00	3,873.2	0.0	3,873.2	106,000.0	410.6	0.5	0.2	0.8
11/26/2019 21:00	3,854.0	0.0	3,854.0	106,000.0	408.5	0.5	0.2	0.8
11/26/2019 22:00	3,262.2	0.0	3,262.2	106,000.0	345.8	0.4	0.2	0.7
11/26/2019 23:00	2,973.0	0.0	2,973.0	106,000.0	315.1	0.4	0.2	0.6
Average/Sum#:	3,679.7	157.0	3,832.8	106,000.0	406.3	0.5	0.2	0.8
Minimum:	1,375.0	0.0	1,375.0	106,000.0	145.8	0.4	0.2	0.6
Maximum:	4,089.2	1,603.7	5,692.3	106,000.0	603.4	0.7	0.4	1.2
%SI	12.50	12.50	12.50	0.00	12.50	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	2,804.4	0.0	2,804.4	106,000.0	297.3	0.4	0.2	0.6
11/27/2019 01:00	2,708.3	0.0	2,708.3	106,000.0	287.1	0.3	0.2	0.6
11/27/2019 02:00	2,710.0	0.0	2,710.0	106,000.0	287.3	0.3	0.2	0.6
11/27/2019 03:00	2,702.4	0.0	2,702.4	106,000.0	286.5	0.3	0.2	0.6
11/27/2019 04:00	2,806.9	0.0	2,806.9	106,000.0	297.5	0.4	0.2	0.6
11/27/2019 05:00	3,064.8	0.0	3,064.8	106,000.0	324.9	0.4	0.2	0.6
11/27/2019 06:00	4,000.5	0.0	4,000.5	106,000.0	424.1	0.5	0.3	0.8
11/27/2019 07:00	3,542.3	0.0	3,542.3	106,000.0	375.5	0.4	0.2	0.8
11/27/2019 08:00	3,630.1	0.0	3,630.1	106,000.0	384.8	0.5	0.2	0.8
11/27/2019 09:00	3,845.7	0.0	3,845.7	106,000.0	407.6	0.5	0.2	0.8
11/27/2019 10:00	4,026.2	0.0	4,026.2	106,000.0	426.8	0.5	0.3	0.9
11/27/2019 11:00	3,988.3	0.0	3,988.3	106,000.0	422.8	0.5	0.3	0.8
11/27/2019 12:00	3,960.5	0.0	3,960.5	106,000.0	419.8	0.5	0.3	0.8
11/27/2019 13:00	3,937.7	0.0	3,937.7	106,000.0	417.4	0.5	0.3	0.8
11/27/2019 14:00	3,816.8	0.0	3,816.8	106,000.0	404.6	0.5	0.2	0.8
11/27/2019 15:00	3,818.5	0.0	3,818.5	106,000.0	404.8	0.5	0.2	0.8
11/27/2019 16:00	4,016.5	83.6	4,041.6	106,000.0	428.4	0.5	0.3	0.9
11/27/2019 17:00	4,043.1	1,121.1	5,164.2	106,000.0	547.4	0.7	0.3	1.1
11/27/2019 18:00	4,048.7	31.6	4,054.4	106,000.0	429.8	0.5	0.3	0.9
11/27/2019 19:00	3,908.0	0.0	3,908.0	106,000.0	414.2	0.5	0.2	0.8
11/27/2019 20:00	3,901.2	0.0	3,901.2	106,000.0	413.5	0.5	0.2	0.8
11/27/2019 21:00	3,742.8	0.0	3,742.8	106,000.0	396.7	0.5	0.2	0.8
11/27/2019 22:00	3,423.4	0.0	3,423.4	106,000.0	362.9	0.4	0.2	0.7
11/27/2019 23:00	3,126.3	0.0	3,126.3	106,000.0	331.4	0.4	0.2	0.7
Average/Sum#:	3,565.6	51.5	3,613.6	106,000.0	383.0	0.5	0.2	0.8
Minimum:	2,702.4	0.0	2,702.4	106,000.0	286.5	0.3	0.2	0.6
Maximum:	4,048.7	1,121.1	5,164.2	106,000.0	547.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	3,082.1	0.0	3,082.1	106,000.0	326.7	0.4	0.2	0.7
11/28/2019 01:00	2,816.3	0.0	2,816.3	106,000.0	298.5	0.4	0.2	0.6
11/28/2019 02:00	2,732.6	0.0	2,732.6	106,000.0	289.7	0.3	0.2	0.6
11/28/2019 03:00	2,713.8	0.0	2,713.8	106,000.0	287.7	0.3	0.2	0.6
11/28/2019 04:00	2,789.3	0.0	2,789.3	106,000.0	295.7	0.4	0.2	0.6
11/28/2019 05:00	2,982.4	0.0	2,982.4	106,000.0	316.1	0.4	0.2	0.6
11/28/2019 06:00	3,106.1	0.0	3,106.1	106,000.0	329.2	0.4	0.2	0.7
11/28/2019 07:00	3,093.4	0.0	3,093.4	106,000.0	327.9	0.4	0.2	0.7
11/28/2019 08:00	3,352.2	0.0	3,352.2	106,000.0	355.3	0.4	0.2	0.7
11/28/2019 09:00	3,466.2	0.0	3,466.2	106,000.0	367.4	0.4	0.2	0.7
11/28/2019 10:00	3,615.7	0.0	3,615.7	106,000.0	383.3	0.5	0.2	0.8
11/28/2019 11:00	3,588.2	0.0	3,588.2	106,000.0	380.3	0.5	0.2	0.8
11/28/2019 12:00	3,552.2	0.0	3,552.2	106,000.0	376.5	0.5	0.2	0.8
11/28/2019 13:00	3,480.8	0.0	3,480.8	106,000.0	369.0	0.4	0.2	0.7
11/28/2019 14:00	3,408.9	0.0	3,408.9	106,000.0	361.3	0.4	0.2	0.7
11/28/2019 15:00	3,446.4	0.0	3,446.4	106,000.0	365.3	0.4	0.2	0.7
11/28/2019 16:00	3,014.5	0.0	3,014.5	106,000.0	319.5	0.4	0.2	0.6
11/28/2019 17:00	3,795.1	0.0	3,795.1	106,000.0	402.3	0.5	0.2	0.8
11/28/2019 18:00	3,770.7	0.0	3,770.7	106,000.0	399.7	0.5	0.2	0.8
11/28/2019 19:00	2,754.2	0.0	2,754.2	106,000.0	291.9	0.4	0.2	0.6
11/28/2019 20:00	3,525.4	0.0	3,525.4	106,000.0	373.7	0.4	0.2	0.7
11/28/2019 21:00	3,451.0	0.0	3,451.0	106,000.0	365.8	0.4	0.2	0.7
11/28/2019 22:00	3,231.8	0.0	3,231.8	106,000.0	342.6	0.4	0.2	0.7
11/28/2019 23:00	2,904.7	0.0	2,904.7	106,000.0	307.9	0.4	0.2	0.6
Average/Sum#:	3,236.4	0.0	3,236.4	106,000.0	343.1	0.4	0.2	0.7
Minimum:	2,713.8	0.0	2,713.8	106,000.0	287.7	0.3	0.2	0.6
Maximum:	3,795.1	0.0	3,795.1	106,000.0	402.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	3,035.2	0.0	3,035.2	106,000.0	321.7	0.4	0.2	0.6
11/29/2019 01:00	3,038.4	0.0	3,038.4	106,000.0	322.1	0.4	0.2	0.6
11/29/2019 02:00	2,970.8	0.0	2,970.8	106,000.0	314.9	0.4	0.2	0.6
11/29/2019 03:00	3,007.9	0.0	3,007.9	106,000.0	318.8	0.4	0.2	0.6
11/29/2019 04:00	3,071.7	0.0	3,071.7	106,000.0	325.6	0.4	0.2	0.7
11/29/2019 05:00	3,211.7	0.0	3,211.7	106,000.0	340.4	0.4	0.2	0.7
11/29/2019 06:00	3,335.1	0.0	3,335.1	106,000.0	353.5	0.4	0.2	0.7
11/29/2019 07:00	3,431.4	0.0	3,431.4	106,000.0	363.7	0.4	0.2	0.7
11/29/2019 08:00	3,552.2	0.0	3,552.2	106,000.0	376.5	0.5	0.2	0.8
11/29/2019 09:00	3,481.4	0.0	3,481.4	106,000.0	369.0	0.4	0.2	0.7
11/29/2019 10:00	3,560.0	0.0	3,560.0	106,000.0	377.4	0.5	0.2	0.8
11/29/2019 11:00	3,471.2	0.0	3,471.2	106,000.0	367.9	0.4	0.2	0.7
11/29/2019 12:00	3,463.2	0.0	3,463.2	106,000.0	367.1	0.4	0.2	0.7
11/29/2019 13:00	3,475.6	0.0	3,475.6	106,000.0	368.4	0.4	0.2	0.7
11/29/2019 14:00	3,456.4	0.0	3,456.4	106,000.0	366.4	0.4	0.2	0.7
11/29/2019 15:00	3,438.0	0.0	3,438.0	106,000.0	364.4	0.4	0.2	0.7
11/29/2019 16:00	2,920.5	0.0	2,920.5	106,000.0	309.6	0.4	0.2	0.6
11/29/2019 17:00	4,076.1	974.2	5,050.3	106,000.0	535.3	0.6	0.3	1.1
11/29/2019 18:00	4,096.6	1,090.8	5,187.4	106,000.0	549.9	0.7	0.3	1.1
11/29/2019 19:00	4,114.3	978.8	5,073.5	106,000.0	537.8	0.6	0.3	1.1
11/29/2019 20:00	3,920.2	0.0	3,920.2	106,000.0	415.5	0.5	0.2	0.8
11/29/2019 21:00	3,689.3	0.0	3,689.3	106,000.0	391.1	0.5	0.2	0.8
11/29/2019 22:00	3,354.8	0.0	3,354.8	106,000.0	355.6	0.4	0.2	0.7
11/29/2019 23:00	3,102.9	0.0	3,102.9	106,000.0	328.9	0.4	0.2	0.7
Average/Sum#:	3,428.1	126.8	3,554.1	106,000.0	376.7	0.4	0.2	0.7
Minimum:	2,920.5	0.0	2,920.5	106,000.0	309.6	0.4	0.2	0.6
Maximum:	4,114.3	1,090.8	5,187.4	106,000.0	549.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	2,977.3	0.0	2,977.3	106,000.0	315.6	0.4	0.2	0.6
11/30/2019 01:00	2,802.0	0.0	2,802.0	106,000.0	297.0	0.4	0.2	0.6
11/30/2019 02:00	2,732.2	0.0	2,732.2	106,000.0	289.6	0.4	0.2	0.6
11/30/2019 03:00	2,740.2	0.0	2,740.2	106,000.0	290.5	0.4	0.2	0.6
11/30/2019 04:00	2,824.3	0.0	2,824.3	106,000.0	299.4	0.4	0.2	0.6
11/30/2019 05:00	2,951.9	0.0	2,951.9	106,000.0	312.9	0.4	0.2	0.6
11/30/2019 06:00	3,072.7	0.0	3,072.7	106,000.0	325.7	0.4	0.2	0.7
11/30/2019 07:00	3,092.2	0.0	3,092.2	106,000.0	327.8	0.4	0.2	0.7
11/30/2019 08:00	3,467.3	0.0	3,467.3	106,000.0	367.5	0.4	0.2	0.7
11/30/2019 09:00	3,619.0	0.0	3,619.0	106,000.0	383.6	0.5	0.2	0.8
11/30/2019 10:00	3,786.5	0.0	3,786.5	106,000.0	401.4	0.5	0.2	0.8
11/30/2019 11:00	3,747.6	0.0	3,747.6	106,000.0	397.2	0.5	0.2	0.8
11/30/2019 12:00	3,742.7	0.0	3,742.7	106,000.0	396.7	0.5	0.2	0.8
11/30/2019 13:00	3,893.1	0.0	3,893.1	106,000.0	412.7	0.5	0.2	0.8
11/30/2019 14:00	3,922.1	0.0	3,922.1	106,000.0	415.7	0.5	0.2	0.8
11/30/2019 15:00	3,895.9	0.0	3,895.9	106,000.0	413.0	0.5	0.2	0.8
11/30/2019 16:00	3,058.4	0.0	3,058.4	106,000.0	324.2	0.4	0.2	0.6
11/30/2019 17:00	4,100.9	1,465.5	5,566.4	106,000.0	590.0	0.7	0.4	1.2
11/30/2019 18:00	3,975.2	32.7	3,978.5	106,000.0	421.7	0.5	0.3	0.9
11/30/2019 19:00	2,977.9	0.0	2,977.9	106,000.0	315.7	0.4	0.2	0.6
11/30/2019 20:00	3,632.3	0.0	3,632.3	106,000.0	385.0	0.5	0.2	0.8
11/30/2019 21:00	3,504.1	0.0	3,504.1	106,000.0	371.4	0.4	0.2	0.7
11/30/2019 22:00	3,118.8	0.0	3,118.8	106,000.0	330.6	0.4	0.2	0.7
11/30/2019 23:00	2,947.2	0.0	2,947.2	106,000.0	312.4	0.4	0.2	0.6
Average/Sum#:	3,357.6	62.4	3,418.8	106,000.0	362.4	0.5	0.2	0.7
Minimum:	2,732.2	0.0	2,732.2	106,000.0	289.6	0.4	0.2	0.6
Maximum:	4,100.9	1,465.5	5,566.4	106,000.0	590.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	2,746.9	0.0	2,746.9	106,000.0	291.2	0.3	0.2	0.6					
12/01/2019 01:00	2,707.4	0.0	2,707.4	106,000.0	287.0	0.3	0.2	0.6					
12/01/2019 02:00	2,706.7	0.0	2,706.7	106,000.0	286.9	0.3	0.2	0.6					
12/01/2019 03:00	2,707.4	0.0	2,707.4	106,000.0	287.0	0.3	0.2	0.6					
12/01/2019 04:00	2,711.0	0.0	2,711.0	106,000.0	287.4	0.3	0.2	0.6					
12/01/2019 05:00	2,794.6	0.0	2,794.6	106,000.0	296.2	0.4	0.2	0.6					
12/01/2019 06:00	2,857.7	0.0	2,857.7	106,000.0	302.9	0.4	0.2	0.6					
12/01/2019 07:00	2,996.0	0.0	2,996.0	106,000.0	317.6	0.4	0.2	0.6					
12/01/2019 08:00	3,062.6	0.0	3,062.6	106,000.0	324.6	0.4	0.2	0.6					
12/01/2019 09:00	3,090.9	0.0	3,090.9	106,000.0	327.6	0.4	0.2	0.7					
12/01/2019 10:00	3,112.5	0.0	3,112.5	106,000.0	329.9	0.4	0.2	0.7					
12/01/2019 11:00	3,145.2	0.0	3,145.2	106,000.0	333.4	0.4	0.2	0.7					
12/01/2019 12:00	3,180.0	0.0	3,180.0	106,000.0	337.1	0.4	0.2	0.7					
12/01/2019 13:00	3,108.2	0.0	3,108.2	106,000.0	329.5	0.4	0.2	0.7					
12/01/2019 14:00	3,316.7	0.0	3,316.7	106,000.0	351.6	0.4	0.2	0.7					
12/01/2019 15:00	3,814.1	0.0	3,814.1	106,000.0	404.3	0.5	0.2	0.8					
12/01/2019 16:00	3,131.2	0.0	3,131.2	106,000.0	331.9	0.4	0.2	0.7					
12/01/2019 17:00	4,034.4	1,086.9	4,980.0	106,000.0	527.9	0.7	0.3	1.1					
12/01/2019 18:00	4,048.0	1,467.9	5,515.9	106,000.0	584.7	0.7	0.4	1.2					
12/01/2019 19:00	3,980.2	53.4	4,001.6	106,000.0	424.2	0.5	0.3	0.9					
12/01/2019 20:00	4,053.2	21.5	4,073.2	106,000.0	431.8	0.5	0.3	0.9					
12/01/2019 21:00	3,891.0	0.0	3,891.0	106,000.0	412.4	0.5	0.2	0.8					
12/01/2019 22:00	3,268.4	0.0	3,268.4	106,000.0	346.5	0.4	0.2	0.7					
12/01/2019 23:00	3,108.6	0.0	3,108.6	106,000.0	329.5	0.4	0.2	0.7					
Average/Sum#:	3,232.2	109.6	3,334.5	106,000.0	353.5	0.4	0.2	0.7					
Minimum:	2,706.7	0.0	2,706.7	106,000.0	286.9	0.3	0.2	0.6					
Maximum:	4,053.2	1,467.9	5,515.9	106,000.0	584.7	0.7	0.4	1.2					
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00					

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	2,988.2	0.0	2,988.2	106,000.0	316.7	0.4	0.2	0.6
12/02/2019 01:00	2,725.3	0.0	2,725.3	106,000.0	288.9	0.3	0.2	0.6
12/02/2019 02:00	2,714.1	0.0	2,714.1	106,000.0	287.7	0.3	0.2	0.6
12/02/2019 03:00	2,715.8	0.0	2,715.8	106,000.0	287.9	0.3	0.2	0.6
12/02/2019 04:00	2,754.8	0.0	2,754.8	106,000.0	292.0	0.4	0.2	0.6
12/02/2019 05:00	3,003.0	0.0	3,003.0	106,000.0	318.3	0.4	0.2	0.6
12/02/2019 06:00	4,059.3	10.7	4,067.6	106,000.0	431.2	0.5	0.3	0.9
12/02/2019 07:00	3,796.6	0.3	3,796.6	106,000.0	402.4	0.5	0.2	0.8
12/02/2019 08:00	3,700.2	0.0	3,700.2	106,000.0	392.2	0.5	0.2	0.8
12/02/2019 09:00	4,026.5	0.0	4,026.5	106,000.0	426.8	0.5	0.3	0.9
12/02/2019 10:00	3,958.5	0.0	3,958.5	106,000.0	419.6	0.5	0.3	0.8
12/02/2019 11:00	3,966.2	0.0	3,966.2	106,000.0	420.4	0.5	0.3	0.8
12/02/2019 12:00	3,979.1	0.0	3,979.1	106,000.0	421.8	0.5	0.3	0.8
12/02/2019 13:00	3,900.7	0.0	3,900.7	106,000.0	413.5	0.5	0.2	0.8
12/02/2019 14:00	3,911.9	0.0	3,911.9	106,000.0	414.7	0.5	0.2	0.8
12/02/2019 15:00	4,041.6	21.6	4,044.2	106,000.0	428.7	0.5	0.3	0.9
12/02/2019 16:00	4,076.9	1,087.5	5,164.4	106,000.0	547.4	0.7	0.3	1.1
12/02/2019 17:00	4,088.1	1,066.0	5,154.1	106,000.0	546.3	0.7	0.3	1.1
12/02/2019 18:00	4,092.8	1,047.0	5,139.8	106,000.0	544.8	0.7	0.3	1.1
12/02/2019 19:00	4,098.7	985.6	5,084.3	106,000.0	538.9	0.6	0.3	1.1
12/02/2019 20:00	4,100.7	1,019.4	5,120.1	106,000.0	542.7	0.7	0.3	1.1
12/02/2019 21:00	3,973.0	27.5	3,975.8	106,000.0	421.4	0.5	0.3	0.8
12/02/2019 22:00	3,203.5	0.0	3,203.5	106,000.0	339.6	0.4	0.2	0.7
12/02/2019 23:00	2,782.0	0.0	2,782.0	106,000.0	294.9	0.4	0.2	0.6
Average/Sum#:	3,610.7	219.4	3,828.2	106,000.0	405.8	0.5	0.3	0.8
Minimum:	2,714.1	0.0	2,714.1	106,000.0	287.7	0.3	0.2	0.6
Maximum:	4,100.7	1,087.5	5,164.4	106,000.0	547.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	2,834.4	0.0	2,834.4	106,000.0	300.4	0.4	0.2	0.6
12/03/2019 01:00	2,726.1	0.0	2,726.1	106,000.0	289.0	0.3	0.2	0.6
12/03/2019 02:00	2,733.5	0.0	2,733.5	106,000.0	289.8	0.3	0.2	0.6
12/03/2019 03:00	2,731.3	0.0	2,731.3	106,000.0	289.5	0.3	0.2	0.6
12/03/2019 04:00	2,733.9	0.0	2,733.9	106,000.0	289.8	0.4	0.2	0.6
12/03/2019 05:00	2,899.6	0.0	2,899.6	106,000.0	307.4	0.4	0.2	0.6
12/03/2019 06:00	3,106.5	0.0	3,106.5	106,000.0	329.3	0.4	0.2	0.7
12/03/2019 07:00	3,869.1	0.0	3,869.1	106,000.0	410.1	0.5	0.2	0.8
12/03/2019 08:00	3,671.3	0.0	3,671.3	106,000.0	389.2	0.5	0.2	0.8
12/03/2019 09:00	4,008.6	0.0	4,008.6	106,000.0	424.9	0.5	0.3	0.9
12/03/2019 10:00	3,848.5	0.0	3,848.5	106,000.0	407.9	0.5	0.2	0.8
12/03/2019 11:00	3,702.2	0.0	3,702.2	106,000.0	392.4	0.5	0.2	0.8
12/03/2019 12:00	3,662.2	0.0	3,662.2	106,000.0	388.2	0.5	0.2	0.8
12/03/2019 13:00	3,529.5	0.0	3,529.5	106,000.0	374.1	0.5	0.2	0.7
12/03/2019 14:00	3,642.2	0.0	3,642.2	106,000.0	386.1	0.5	0.2	0.8
12/03/2019 15:00	3,690.1	0.0	3,690.1	106,000.0	391.2	0.5	0.2	0.8
12/03/2019 16:00	3,895.4	7.4	3,895.8	106,000.0	413.0	0.5	0.2	0.8
12/03/2019 17:00	4,033.8	389.1	4,422.9	106,000.0	468.8	0.6	0.3	0.9
12/03/2019 18:00	4,045.3	261.3	4,293.5	106,000.0	455.1	0.5	0.3	0.9
12/03/2019 19:00	3,332.4	0.0	3,332.4	106,000.0	353.2	0.4	0.2	0.7
12/03/2019 20:00	4,039.7	354.5	4,348.1	106,000.0	460.9	0.6	0.3	0.9
12/03/2019 21:00	4,046.1	12.8	4,048.0	106,000.0	429.1	0.5	0.3	0.9
12/03/2019 22:00	3,556.0	0.0	3,556.0	106,000.0	376.9	0.5	0.2	0.8
12/03/2019 23:00	3,162.7	0.0	3,162.7	106,000.0	335.2	0.4	0.2	0.7
Average/Sum#:	3,479.2	42.7	3,518.7	106,000.0	373.0	0.5	0.2	0.8
Minimum:	2,726.1	0.0	2,726.1	106,000.0	289.0	0.3	0.2	0.6
Maximum:	4,046.1	389.1	4,422.9	106,000.0	468.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	2,884.1	0.0	2,884.1	106,000.0	305.7	0.4	0.2	0.6
12/04/2019 01:00	2,737.9	0.0	2,737.9	106,000.0	290.2	0.3	0.2	0.6
12/04/2019 02:00	2,717.8	0.0	2,717.8	106,000.0	288.1	0.3	0.2	0.6
12/04/2019 03:00	2,714.2	0.0	2,714.2	106,000.0	287.7	0.3	0.2	0.6
12/04/2019 04:00	2,748.9	0.0	2,748.9	106,000.0	291.4	0.4	0.2	0.6
12/04/2019 05:00	3,813.2	0.0	3,813.2	106,000.0	404.2	0.5	0.2	0.8
12/04/2019 06:00	3,900.7	8.2	3,901.3	106,000.0	413.5	0.5	0.2	0.8
12/04/2019 07:00	4,068.2	674.2	4,742.4	106,000.0	502.7	0.6	0.3	1.0
12/04/2019 08:00	4,069.3	970.8	5,040.1	106,000.0	534.3	0.6	0.3	1.1
12/04/2019 09:00	4,062.2	951.7	5,013.9	106,000.0	531.5	0.6	0.3	1.1
12/04/2019 10:00	3,913.1	33.2	3,917.4	106,000.0	415.2	0.5	0.3	0.8
12/04/2019 11:00	3,915.2	0.0	3,915.2	106,000.0	415.0	0.5	0.2	0.8
12/04/2019 12:00	3,947.6	0.0	3,947.6	106,000.0	418.4	0.5	0.3	0.8
12/04/2019 13:00	3,980.8	0.0	3,980.8	106,000.0	422.0	0.5	0.3	0.8
12/04/2019 14:00	3,903.2	0.0	3,903.2	106,000.0	413.7	0.5	0.2	0.8
12/04/2019 15:00	3,935.2	14.8	3,936.4	106,000.0	417.3	0.5	0.3	0.8
12/04/2019 16:00	4,058.5	1,063.8	5,122.3	106,000.0	543.0	0.7	0.3	1.1
12/04/2019 17:00	4,058.8	1,125.9	5,184.7	106,000.0	549.6	0.7	0.3	1.1
12/04/2019 18:00	4,064.7	1,117.9	5,182.6	106,000.0	549.4	0.7	0.3	1.1
12/04/2019 19:00	4,057.6	1,116.0	5,173.6	104,600.0	541.2	0.7	0.3	1.1
12/04/2019 20:00	4,068.6	1,065.9	5,134.5	104,600.0	537.1	0.6	0.3	1.1
12/04/2019 21:00	4,069.4	469.9	4,539.3	104,600.0	474.8	0.6	0.3	0.9
12/04/2019 22:00	3,871.2	0.6	3,871.2	104,600.0	404.9	0.5	0.2	0.8
12/04/2019 23:00	2,947.5	0.0	2,947.5	104,600.0	308.3	0.4	0.2	0.6
Average/Sum#:	3,687.8	358.9	4,044.6	105,708.3	427.5	0.5	0.3	0.9
Minimum:	2,714.2	0.0	2,714.2	104,600.0	287.7	0.3	0.2	0.6
Maximum:	4,069.4	1,125.9	5,184.7	106,000.0	549.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	1,568.7	0.0	1,568.7	104,600.0	164.1	0.0	0.0	0.0
12/05/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 04:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
12/05/2019 05:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
12/05/2019 06:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
12/05/2019 07:00	0.0	0.0	0.0	106,000.0	0.0	0.0	0.0	0.0
12/05/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/05/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	1,568.7	0.0	1,568.7	104,833.3	164.1	0.0	0.0	0.0
Minimum:	1,568.7	0.0	1,568.7	104,600.0	164.1	0.0	0.0	0.0
Maximum:	1,568.7	0.0	1,568.7	106,000.0	164.1	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/06/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/07/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/08/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/09/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/10/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/11/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/12/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/13/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/14/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/15/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
12/16/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/16/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
12/17/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/17/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/18/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/19/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/20/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/21/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/22/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/23/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh 1 Hour(s)	Unit CT2 GasFlow, _DB, 100scfh 1 Hour(s)	Unit CT2 GasFlowTotal, 100scfh 1 Hour(s)	Unit CT2 GCVGas, BtuPer100scf 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> 4.73 Unit CT2 PM10_Norm, LbPerHr 1 Hour(s)	> 1 Unit CT2 SO2_Norm, LbPerHr 1 Hour(s)	> 1.8 Unit CT2 VOC_Norm, LbPerHr 1 Hour(s)
12/24/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/24/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/25/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/26/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/27/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/28/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/29/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/30/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
12/31/2019 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

CEMs Log

Date/Time	Operator	Description
12/05/19	Administrator (VRL)	Operations tested CT1 and CT2 shutdown bits. Set to true @ 23:50 and 23:51 12/4/19. Edited to false and re-calculated.
12/05/19 8:39	Administrator (ME)	UPDATED MONTHLY GCV VALUE TO 104600 FOR CT1_GCV_GAS, CT2_GCV_GAS, AND GCV_GAS.
12/03/19	Administrator (RG)	REPLACED VAC PUMP ON CEMS1 INLET NOX. RAN MANUAL CAL.
12/03/19 6:13	Administrator (RG)	RAN MANUAL CAL ON CT1 BOTH INLET AND STACK.
11/27/19	Administrator (DWN)	(LATE ENTRY) ALL DAILY CAL GAS BOTTLES CHANGED ON 10-17-19 AFTER VENDOR CHANGE EDITOR UPDATED BUT LOG WAS NOT INCLUDED NEW VENDOR MAGNEGAS ID # K12019 INDUSTRIAL WELDING SUPPLY (LA) UNIT 1 HIGH RANGE CO 181.7 / NOX 179 BOTTLE # EB0100869 UNIT 1 LOW RANGE CO 9.235 / NOX 9.29 BOTTLE # EB0098004 UNIT 1 O2 18.05 BOTTLE # EB0038185 UNIT 2 HIGH RANGE CO 181.4 / NOX 179 BOTTLE # EB0100934 UNIT 2 LOW RANGE CO 9.215 / NOX 9.191 BOTTLE # EB0051567 UNIT 2 O2 18.24 BOTTLE # EB0010634
11/27/19	Operator (RG)	PERFORMED MANUAL CAL ON CT2 INLET ANALYZER.
11/14/19 7:11	Administrator (TJ)	CHANGED E1A-923 REPORT TO LIST GASFLOW_CT RATHER THAN GASFLOW TOTAL. THIS AFTER NOTICING THE OVER-REPORTING ON THE 923.
11/03/19 2:02	Operator (JB)	ADJUSTED CEMS DAYLIGHT SAVINGS BIAS TO -60
11/02/19	Operator (DE)	UPDATED MONTHLY GCV VALUE TO 106,000 FOR CT1, CT2, AND GCV GAS.
10/25/19	Operator (VRL)	Calibrated Unit 1 Stack and Inlet Nox, performed cal error check. Performed second calibration on Inlet Nox.
10/23/19 7:16	Operator (VRL)	REBOOTED SERVER FOR AV UPDATE
10/16/19	Operator (TJ)	CHANGED NH3 SLIP CORRECTION FACTOR ON CT1 TO 0.251 FROM 0.27. CHANGED NH3 SLIP CORRECTION FACTOR ON CT2 TO 0.203 FROM 0.271
10/12/19 9:03	Administrator (BH)	UPDATED NEW GCV VALUE FOR CT1/CT2/GCV NEW VALUE IS 104,500

Cylinder Gas Audit

01/07/2020

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 11/26/2019
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	10:39	L	200	50.300	50.700	25.2 %
11/26/2019	10:44	M	200	112.800	115.600	56.4 %
11/26/2019	10:57	L	200	50.300	50.600	25.2 %
11/26/2019	11:02	M	200	112.800	115.600	56.4 %
11/26/2019	11:14	L	200	50.300	50.700	25.2 %
11/26/2019	11:19	M	200	112.800	115.400	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	50.667	Std	0.7
M	112.800	115.533	Std	2.4

Cylinder Gas Audit

01/07/2020

Page 2

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT1
 Parameter/Scale: CO / Low

Test Date: 11/26/2019
 Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	12:41	L	10	2.400	2.600	24.0 %
11/26/2019	12:46	M	10	5.700	6.000	57.0 %
11/26/2019	12:53	L	10	2.400	2.600	24.0 %
11/26/2019	12:58	M	10	5.700	6.000	57.0 %
11/26/2019	13:05	L	10	2.400	2.500	24.0 %
11/26/2019	13:10	M	10	5.700	6.000	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.567	Std	6.9
M	5.700		6.000	Std	5.3

Cylinder Gas Audit

01/07/2020

Page 3

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / High

Test Date: 11/26/2019
 Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	10:36	L	200	49.400	50.600	24.7 %
11/26/2019	10:41	M	200	112.700	117.400	56.4 %
11/26/2019	10:54	L	200	49.400	50.400	24.7 %
11/26/2019	10:59	M	200	112.700	117.400	56.4 %
11/26/2019	11:11	L	200	49.400	50.800	24.7 %
11/26/2019	11:16	M	200	112.700	117.600	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.600	Std	2.4
M	112.700	117.467	Std	4.2

Cylinder Gas Audit

01/07/2020

Page 4

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / Low

Test Date: 11/26/2019
 Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	14:39	L	10	2.400	2.400	24.0 %
11/26/2019	14:45	M	10	5.700	5.800	57.0 %
11/26/2019	14:52	L	10	2.400	2.400	24.0 %
11/26/2019	14:57	M	10	5.700	5.800	57.0 %
11/26/2019	15:04	L	10	2.400	2.400	24.0 %
11/26/2019	15:09	M	10	5.700	5.800	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.400	Std	0.0
M	5.700		5.800	Std	1.8

Linearity Report

01/07/2020

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest: QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	11/26/2019	Scale: High
Performance Spec:	5 %	Test No.:	96	Highest Error: 3.2
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1039	L	200.0	47.6	48.3		23.8 %
11/26/2019	1044	M	200.0	105.0	108.5		52.5 %
11/26/2019	1050	H	200.0	179.0	179.2		89.5 %
11/26/2019	1057	L	200.0	47.6	48.8		23.8 %
11/26/2019	1102	M	200.0	105.0	108.3		52.5 %
11/26/2019	1107	H	200.0	179.0	178.8		89.5 %
11/26/2019	1114	L	200.0	47.6	48.8		23.8 %
11/26/2019	1119	M	200.0	105.0	108.3		52.5 %
11/26/2019	1124	H	200.0	179.0	179.2		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.633	No	2.2
M	105.000	108.367	No	3.2
H	179.000	179.067	No	0.0

Linearity Report

01/07/2020

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest: QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	11/26/2019	Scale: High
Performance Spec:	5 %	Test No.:	96	Highest Error: 3.7
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1036	L	200.0	48.2	49.8		24.1 %
11/26/2019	1041	M	200.0	106.0	109.2		53.0 %
11/26/2019	1047	H	200.0	179.0	181.4		89.5 %
11/26/2019	1054	L	200.0	48.2	50.0		24.1 %
11/26/2019	1059	M	200.0	106.0	109.7		53.0 %
11/26/2019	1104	H	200.0	179.0	181.5		89.5 %
11/26/2019	1111	L	200.0	48.2	50.1		24.1 %
11/26/2019	1116	M	200.0	106.0	109.8		53.0 %
11/26/2019	1121	H	200.0	179.0	181.4		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.967	No	3.7
M	106.000	109.567	No	3.4
H	179.000	181.433	No	1.4

Linearity Report

01/07/2020

Page 3

ORIS Code: 56298	Facility Name: ROSEVILLE ENERGY	
EDR Site ID: CT002	Component ID: A22	ReasonForTest: QA
	Component Type: O2D	Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument	Test End Date/Time: 11/26/2019	Scale: High
Performance Spec: 5 %	Test No.: 97	Highest Error: 0.0
	Status (Pass/Fail): Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1240	L	21.0	5.6	5.6		26.7 %
11/26/2019	1245	M	21.0	11.2	11.2		53.3 %
11/26/2019	1250	H	21.0	18.2	18.2		86.7 %
11/26/2019	1258	L	21.0	5.6	5.6		26.7 %
11/26/2019	1303	M	21.0	11.2	11.2		53.3 %
11/26/2019	1308	H	21.0	18.2	18.2		86.7 %
11/26/2019	1315	L	21.0	5.6	5.6		26.7 %
11/26/2019	1320	M	21.0	11.2	11.2		53.3 %
11/26/2019	1325	H	21.0	18.2	18.2		86.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.600	No	0.0
M	11.200	11.200	No	0.0
H	18.200	18.200	No	0.0

Linearity Report

01/07/2020

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest: QA
		Component Type:	O2D	Grace Period: 0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	11/26/2019	Scale: High
Performance Spec:	5 %	Test No.:	97	Highest Error: 3.6
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1440	L	21.0	5.6	5.4		26.7 %
11/26/2019	1446	M	21.0	11.1	11.0		52.9 %
11/26/2019	1451	H	21.0	18.0	18.1		85.7 %
11/26/2019	1458	L	21.0	5.6	5.4		26.7 %
11/26/2019	1503	M	21.0	11.1	11.0		52.9 %
11/26/2019	1508	H	21.0	18.0	18.1		85.7 %
11/26/2019	1515	L	21.0	5.6	5.4		26.7 %
11/26/2019	1520	M	21.0	11.1	11.0		52.9 %
11/26/2019	1525	H	21.0	18.0	18.1		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.400	No	3.6
M	11.100	11.000	No	0.9
H	18.000	18.100	No	0.6

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

12/18/19 Taylor Sullivan

EDR check

12/6/19 Taylor Sullivan

Remote check, all available Windows updates were installed. Installed RP v7102 plus patch.

11/26/19 Taylor Sullivan

EDR check.

10/28-29/19 William Vanhorn

Entered the 2019 RATA. EDR's

10/25/19 William Vanhorn

EDR prep. Started some recalculations.

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:39 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
 EDS Data from: CT1_CO_Ppmvdc_3H
 Emission Limitation: 4
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
 Date of Latest CMS Certification or Audit: 04/09/2006 14:00
 Process Unit(s) Description:
 Operating time for EDS: 740.00 Hour(s)
 Operating time for CMS: 740.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:39 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
 EDS Data from: CT1_NOx_Ppmvdc_1H
 Emission Limitation: 2.0
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
 Date of Latest CMS Certification or Audit: 04/09/2006 14:00
 Process Unit(s) Description:
 Operating time for EDS: 740.00 Hour(s)
 Operating time for CMS: 740.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:40 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 506.00 Hour(s)
Operating time for CMS: 506.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.99
4. Total Availability as a percentage of operating time	99.01

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:40 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
 EDS Data from: CT2_NOx_Ppmvdc_1H
 Emission Limitation: 2.0
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
 Date of Latest CMS Certification or Audit: 04/10/2006 07:00
 Process Unit(s) Description:
 Operating time for EDS: 506.00 Hour(s)
 Operating time for CMS: 506.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.99
4. Total Availability as a percentage of operating time	99.01

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:41 **Location:** Roseville, CA



Tag Name: CT1_CO_Ppm_1H

Total Operating Time: 740.00 Hour(s)

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	740.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT1

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:42 **Location:** Roseville, CA



Tag Name: CT1_NOx_Ppm_1H

Total Operating Time: 740.00 Hour(s)

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	740.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data

CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59
Generated: 01/07/2020 14:43

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA



Tag Name: CT1_NOx_SCR_Ppm_1H

Total Operating Time: 740.00 Hour(s)

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	740.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT1

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:42 **Location:** Roseville, CA



Tag Name: CT1_O2Dry_Pct_1H

Total Operating Time: 740.00 Hour(s)

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	740.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Invalid Data

CT2

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:43 **Location:** Roseville, CA



Tag Name: CT2_CO_Ppm_1H

Total Operating Time: 506.00 Hour(s)

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	506.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:44 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H

Total Operating Time: 506.00 Hour(s)

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/29/2019 11:00	10/29/2019 11:59	1		
2	10/29/2019 12:00	10/29/2019 12:59	1		
3	10/29/2019 13:00	10/29/2019 13:59	1		
4	10/30/2019 07:00	10/30/2019 07:59	1		
5	10/30/2019 08:00	10/30/2019 08:59	1	3 - quality assurance calibration	

Total Operating Time:	506.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.01 %
Percent Monitor Downtime:	0.99 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	20.00

NOx SCR Invalid Data

CT2

From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 14:44 **Location:** Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 506.00 Hour(s)
Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	506.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:45 Location: Roseville, CA



Tag Name: CT2_O2Dry_Pct_1H

Total Operating Time: 506.00 Hour(s)

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/29/2019 11:00	10/29/2019 11:59	1		
2	10/29/2019 12:00	10/29/2019 12:59	1		
3	10/29/2019 13:00	10/29/2019 13:59	1		
4	10/30/2019 07:00	10/30/2019 07:59	1		
5	10/30/2019 08:00	10/30/2019 08:59	1	3 - Quality assurance calibration	

Total Operating Time:	506.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.01 %
Percent Monitor Downtime:	0.99 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	20.00

AQ-36

AQ-36: The project owner shall notify the PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6



Roseville Electric
Roseville Energy Park
5120 Phillip Road
Roseville, California 95747

October 30th, 2019

Tony Johnson
Operations and Maintenance Supervisor
Roseville Energy Park
5120 Phillip Road
Roseville, Ca. 95747

To Whom It May Concern:

This memo is to provide additional information to the Non Compliance Event Notification PART II, #2019-003.

On October 29th Roseville Energy Park was dispatched by its Scheduling Coordinator to start Combustion Turbine #2 and synchronize to the grid by 05:00 to supplement local generation needs. The Control Room Operator (CRO) initiated the start and the unit came up to synchronous speed at 04:53. Under normal conditions, the expectation is that the unit automatically synchronizes to the grid at this time. The turbine's generator circuit breaker failed to close after 7 minutes and the CRO gave the unit a stop command at 05:00. This 7 minute span produced a total of 90.2 lbs. of CO, exceeding our permit (REPR-20-02 Section 51) limit of 89.5 lbs.

The CRO attempted a 2nd start and achieved synchronous speed at 05:19 and attempted to synchronize until 05:33 before giving the turbine a stop command. This start attempt netted 185.3 lbs. of CO. The CRO then made the unit unavailable for dispatch. Additional staff arrived at the plant for the normal 06:00 start time and after hours of troubleshooting noticed the turbine controller was in "Load Control" rather than in "Frequency Control". This difference was not noticed by the CRO and resulted in the inability to properly synchronize which resulted in a subsequent excess emissions notice.

A Part I was filed on the 29th and the Operations staff "Startup Checklist" has been edited to include this critical distinction.

Let me know if you have any questions.

Tony Johnson.

A handwritten signature in black ink that reads "Tony Johnson".



Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name ROSEVILLE ENERGY PARK Address 5120 PHILLIP ROAD, ROSEVILLE, CA
2. Title V Source Status Major Yes [X] No [] Synthetic Minor Yes [] No []
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l) Yes [] No []
4. Emission Exceedances NOx [] SOx [] PM [] VOC [] CO [X] Opacity [] None [] check all that apply
5. CEMS / COMS / CMS Breakdown Yes [] No [X]
6. Detection of Non-Compliance Event Date 10/29/19 Time 05:00 [X] AM [] PM
7. Start of Non-Compliance Event Date 10/29/19 Time 05:00 [X] AM [] PM [] Not known
8. Violation Permit No. REPR-20-02 Condition No. Rule Section 51
9. Unit / Equipment Involved Combustion Turbine 2
10. Description / Cause of Non-Compliance Event Turbine failed to synchronize [] additional information attached
11. Immediate Corrective Actions Operator Commanded unit to stop [] additional information attached
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction Yes [] No [X]
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404
Yes [] No [] Not Able to Determine at this Time [X] If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I
13. Submitted By TONY JOHNSON Telephone (916) 746 - 1656
Signature Date 10/29/19 Time 09:00 [X] AM [] PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event Date Time [] AM [] PM
15. Duration of Non-Compliance Event Hours Minutes
16. Excess Emissions Estimates NOx SOx PM
VOC CO Opacity %, for minutes Other
17. Variance in Effect Yes [] Variance # No []
18. Corrective and Preventative Actions Taken (a) Minimize Emissions (b) Correct Event (c) Prevent Future Events [] additional information attached
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404
Yes [] No [] If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I
20. Submitted By Telephone () -
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.
Signature Date Time [] AM [] PM

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Non-Compliance
Event Number

Company Name	ROSEVILLE ENERGY PARK	Address	5120 PHILLIP ROAD, ROSEVILLE, CA
Detection of Non-Compliance Event	Date	Time	<input type="checkbox"/> AM <input type="checkbox"/> PM

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

- | <u>Yes</u> | <u>No</u> | |
|--------------------------|--------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | 1. Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions. |
| <input type="checkbox"/> | <input type="checkbox"/> | 2. The amount and duration of emissions as a result of the event have been minimized. |
| <input type="checkbox"/> | <input type="checkbox"/> | 3. The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance. |
| <input type="checkbox"/> | <input type="checkbox"/> | 4. The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated). |
| <input type="checkbox"/> | <input type="checkbox"/> | 5. The event is not the result of improper equipment design. |
| <input type="checkbox"/> | <input type="checkbox"/> | 6. The event is not the result of improper preventative maintenance of equipment. |
| <input type="checkbox"/> | <input type="checkbox"/> | 7. The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator. |
| <input type="checkbox"/> | <input type="checkbox"/> | 8. The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices. |
| <input type="checkbox"/> | <input type="checkbox"/> | 9. The event has not resulted in a nuisance. |
| <input type="checkbox"/> | <input type="checkbox"/> | 10. The event is not the result of the disregard of air pollution rules or regulations. |
| <input type="checkbox"/> | <input type="checkbox"/> | 11. This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event. |
| <input type="checkbox"/> | <input type="checkbox"/> | 12. Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form. |

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature _____

You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

01/07/2020

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 11/26/2019
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	10:39	L	200	50.300	50.700	25.2 %
11/26/2019	10:44	M	200	112.800	115.600	56.4 %
11/26/2019	10:57	L	200	50.300	50.600	25.2 %
11/26/2019	11:02	M	200	112.800	115.600	56.4 %
11/26/2019	11:14	L	200	50.300	50.700	25.2 %
11/26/2019	11:19	M	200	112.800	115.400	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	50.667	Std	0.7
M	112.800	115.533	Std	2.4

Cylinder Gas Audit

01/07/2020

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 11/26/2019
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	12:41	L	10	2.400	2.600	24.0 %
11/26/2019	12:46	M	10	5.700	6.000	57.0 %
11/26/2019	12:53	L	10	2.400	2.600	24.0 %
11/26/2019	12:58	M	10	5.700	6.000	57.0 %
11/26/2019	13:05	L	10	2.400	2.500	24.0 %
11/26/2019	13:10	M	10	5.700	6.000	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.567	Std	6.9
M	5.700		6.000	Std	5.3

Cylinder Gas Audit

01/07/2020

Page 3

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / High

Test Date: 11/26/2019
 Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	10:36	L	200	49.400	50.600	24.7 %
11/26/2019	10:41	M	200	112.700	117.400	56.4 %
11/26/2019	10:54	L	200	49.400	50.400	24.7 %
11/26/2019	10:59	M	200	112.700	117.400	56.4 %
11/26/2019	11:11	L	200	49.400	50.800	24.7 %
11/26/2019	11:16	M	200	112.700	117.600	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.600	Std	2.4
M	112.700	117.467	Std	4.2

Cylinder Gas Audit

01/07/2020

Page 4

Facility: ROSEVILLE ENERGY
 Unit/Stack: CT2
 Parameter/Scale: CO / Low

Test Date: 11/26/2019
 Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
 Performance Spec: 15 Pct
 Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/26/2019	14:39	L	10	2.400	2.400	24.0 %
11/26/2019	14:45	M	10	5.700	5.800	57.0 %
11/26/2019	14:52	L	10	2.400	2.400	24.0 %
11/26/2019	14:57	M	10	5.700	5.800	57.0 %
11/26/2019	15:04	L	10	2.400	2.400	24.0 %
11/26/2019	15:09	M	10	5.700	5.800	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.400		2.400	Std	0.0
M	5.700		5.800	Std	1.8

Linearity Report

01/07/2020

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest: QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	11/26/2019	Scale: High
Performance Spec:	5 %	Test No.:	96	Highest Error: 3.2
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1039	L	200.0	47.6	48.3		23.8 %
11/26/2019	1044	M	200.0	105.0	108.5		52.5 %
11/26/2019	1050	H	200.0	179.0	179.2		89.5 %
11/26/2019	1057	L	200.0	47.6	48.8		23.8 %
11/26/2019	1102	M	200.0	105.0	108.3		52.5 %
11/26/2019	1107	H	200.0	179.0	178.8		89.5 %
11/26/2019	1114	L	200.0	47.6	48.8		23.8 %
11/26/2019	1119	M	200.0	105.0	108.3		52.5 %
11/26/2019	1124	H	200.0	179.0	179.2		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.633	No	2.2
M	105.000	108.367	No	3.2
H	179.000	179.067	No	0.0

Linearity Report

01/07/2020

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest: QA
		Component Type:	NOXA	Grace Period: 0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	11/26/2019	Scale: High
Performance Spec:	5 %	Test No.:	96	Highest Error: 3.7
		Status (Pass/Fail):	Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1036	L	200.0	48.2	49.8		24.1 %
11/26/2019	1041	M	200.0	106.0	109.2		53.0 %
11/26/2019	1047	H	200.0	179.0	181.4		89.5 %
11/26/2019	1054	L	200.0	48.2	50.0		24.1 %
11/26/2019	1059	M	200.0	106.0	109.7		53.0 %
11/26/2019	1104	H	200.0	179.0	181.5		89.5 %
11/26/2019	1111	L	200.0	48.2	50.1		24.1 %
11/26/2019	1116	M	200.0	106.0	109.8		53.0 %
11/26/2019	1121	H	200.0	179.0	181.4		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.967	No	3.7
M	106.000	109.567	No	3.4
H	179.000	181.433	No	1.4

Linearity Report

01/07/2020

Page 3

ORIS Code: 56298	Facility Name: ROSEVILLE ENERGY	
EDR Site ID: CT002	Component ID: A22	ReasonForTest: QA
	Component Type: O2D	Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument	Test End Date/Time: 11/26/2019	Scale: High
Performance Spec: 5 %	Test No.: 97	Highest Error: 0.0
	Status (Pass/Fail): Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1240	L	21.0	5.6	5.6		26.7 %
11/26/2019	1245	M	21.0	11.2	11.2		53.3 %
11/26/2019	1250	H	21.0	18.2	18.2		86.7 %
11/26/2019	1258	L	21.0	5.6	5.6		26.7 %
11/26/2019	1303	M	21.0	11.2	11.2		53.3 %
11/26/2019	1308	H	21.0	18.2	18.2		86.7 %
11/26/2019	1315	L	21.0	5.6	5.6		26.7 %
11/26/2019	1320	M	21.0	11.2	11.2		53.3 %
11/26/2019	1325	H	21.0	18.2	18.2		86.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.600	No	0.0
M	11.200	11.200	No	0.0
H	18.200	18.200	No	0.0

Linearity Report

01/07/2020

Page 4

ORIS Code: 56298	Facility Name: ROSEVILLE ENERGY	
EDR Site ID: CT001	Component ID: A16	ReasonForTest: QA
	Component Type: O2D	Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument	Test End Date/Time: 11/26/2019	Scale: High
Performance Spec: 5 %	Test No.: 97	Highest Error: 3.6
	Status (Pass/Fail): Passed	

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/26/2019	1440	L	21.0	5.6	5.4		26.7 %
11/26/2019	1446	M	21.0	11.1	11.0		52.9 %
11/26/2019	1451	H	21.0	18.0	18.1		85.7 %
11/26/2019	1458	L	21.0	5.6	5.4		26.7 %
11/26/2019	1503	M	21.0	11.1	11.0		52.9 %
11/26/2019	1508	H	21.0	18.0	18.1		85.7 %
11/26/2019	1515	L	21.0	5.6	5.4		26.7 %
11/26/2019	1520	M	21.0	11.1	11.0		52.9 %
11/26/2019	1525	H	21.0	18.0	18.1		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.400	No	3.6
M	11.100	11.000	No	0.9
H	18.000	18.100	No	0.6

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

12/18/19 Taylor Sullivan

EDR check

12/6/19 Taylor Sullivan

Remote check, all available Windows updates were installed. Installed RP v7102 plus patch.

11/26/19 Taylor Sullivan

EDR check.

10/28-29/19 William Vanhorn

Entered the 2019 RATA. EDR's

10/25/19 William Vanhorn

EDR prep. Started some recalculations.

AQ-41

AQ-41The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59
Generated: 01/07/2020 14:51

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Tag Name: ALL_CO_Lb_1D

Total Operating Time: 40.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	40.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59
Generated: 01/07/2020 14:51

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Tag Name: ALL_NOx_Lb_1D

Total Operating Time: 40.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	40.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59
Generated: 01/07/2020 14:52

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Tag Name: ALL_PM10_Lb_1D

Total Operating Time: 40.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	40.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59
Generated: 01/07/2020 14:52

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Tag Name: ALL_SO2_Lb_1D

Total Operating Time: 40.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	40.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59
Generated: 01/07/2020 14:53

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Tag Name: ALL_VOC_Lb_1D

Total Operating Time: 40.00 Day(s)

No Exclusions Allowed

Non-Operating Time: 52.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	40.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:00 Location: Roseville, CA



Tag Name: CT1_CO_3Hr_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:00 Location: Roseville, CA



Tag Name: CT1_CO_Ppmvdc_3H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:01 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:01 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:02 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:02 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:02 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:03 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:03 Location: Roseville, CA

Tag Name: CT1_SO2_Norm_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:04 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H

Total Operating Time: 740.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,468.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	740.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:06 Location: Roseville, CA



Tag Name: CT2_CO_3Hr_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:06 Location: Roseville, CA



Tag Name: CT2_CO_Ppmvdc_3H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:07 Location: Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H

Total Operating Time: 506.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	10/29/19 03:00	10/29/19 03:59	1	90.2	89.5		
2	10/29/19 04:00	10/29/19 04:59	1	185.3	89.5		

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.40 %
Time in compliance as a percentage of operating time:	99.60 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:12 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:12 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:12 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:13 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:13 Location: Roseville, CA



Tag Name: CT2_PM10_Norm_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:14 Location: Roseville, CA



Tag Name: CT2_SO2_Norm_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 15:14 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H

Total Operating Time: 506.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,702.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	506.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

- a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
- b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
- c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants;
and
- d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59
Generated: 01/07/2020 15:18

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOX, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Oct 19	0.3916	0.3916	0.1162	0.1162
Nov 19	1.0151	1.4067	0.3043	0.4205
Dec 19	0.2419	1.6486	0.0767	0.4972

Sum/Avg	1.6486		0.4972	
---------	--------	--	--------	--

Roseville Energy Park Quarterly Emissions Summary for PCAPCD



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:15 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOx, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOx, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2019	0.0847	1.5929	0.2498	4.0636	178.28	2,985.67	0.2409	2.0614	0.1418	4.5586	96.55	3,068.60
Nov 2019	0.2966	1.4561	0.6173	4.3275	461.92	3,210.13	0.2540	2.0999	0.3977	4.5797	293.17	3,130.51
Dec 2019	0.0403	1.2839	0.1245	3.7999	96.12	2,795.31	0.0448	1.9116	0.1174	4.0114	96.12	2,739.33
Sum/Avg	1.2839		3.7999		2,795.31		1.9116		4.0114		2,739.33	
Limit Value												

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a-(bxc/1,000,000)) \times 1,000,000/b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 13:00	0	26.4	35.7	17.7	0.0	692,843.1	0.28	0.28
10/24/2019 14:00	2	5.3	15.6	14.5	14.6	667,380.4	0.75	1.00
10/24/2019 15:00	2	1.9	15.0	14.4	27.5	679,655.9	0.00	1.00
10/24/2019 16:00	1	1.8	12.2	14.6	26.3	897,951.1	0.00	1.00
10/24/2019 17:00	2	2.0	14.4	13.8	33.4	968,819.5	0.00	1.00
10/24/2019 18:00	2	1.9	10.5	14.5	28.3	941,693.2	0.00	1.00
10/24/2019 19:00	3	2.3	18.3	12.8	44.4	982,266.1	0.00	1.00
10/24/2019 20:00	1	2.0	13.3	14.1	30.5	967,256.7	0.00	1.00
10/24/2019 21:00	2	2.0	13.4	14.1	32.8	982,360.6	0.00	1.00
10/24/2019 22:00	2	2.2	15.7	13.3	38.1	975,534.7	0.00	1.00
10/24/2019 23:00	2	1.9	13.3	14.3	27.0	774,762.2	0.00	1.00
Average/Sum#:	2	4.5	16.1	14.4	27.5	866,411.2	1.03 #	10.28 #
Minimum:	1	1.8	10.5	12.8	0.0	667,380.4	0.00	0.00
Maximum:	3	26.4	35.7	17.7	44.4	982,360.6	0.75	1.00
%SI	58.33	54.17	54.17	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	2	1.9	13.8	14.4	27.0	734,222.2	0.00	1.00
10/25/2019 01:00	2	1.9	13.8	14.4	27.5	731,694.0	0.00	1.00
10/25/2019 02:00	2	1.9	14.1	14.4	28.8	731,061.9	0.00	1.00
10/25/2019 03:00	2	1.9	14.2	14.4	29.7	729,165.8	0.00	1.00
10/25/2019 04:00	2	1.9	14.7	14.4	29.3	729,587.2	0.00	1.00
10/25/2019 05:00	2	1.9	14.3	14.3	29.9	718,947.8	0.00	1.00
10/25/2019 06:00	2	1.9	14.3	14.1	35.5	925,771.2	0.00	1.00
10/25/2019 07:00	2	1.9	12.4	14.6	31.1	943,598.6	0.00	1.00
10/25/2019 08:00	2	1.9	13.5	14.5	31.9	824,436.3	0.00	1.00
10/25/2019 09:00	1	1.8	13.1	14.4	29.5	797,637.0	0.00	1.00
10/25/2019 10:00	2	1.9	12.7	14.4	26.3	789,841.8	0.00	1.00
10/25/2019 11:00	2	1.9	12.4	14.5	29.0	862,951.3	0.00	1.00
10/25/2019 12:00	2	1.8	12.1	14.5	28.4	862,951.3	0.00	1.00
10/25/2019 13:00	2	1.8	11.6	14.5	27.2	870,226.4	0.00	1.00
10/25/2019 14:00	2	1.9	12.8	14.4	26.7	735,486.2	0.00	1.00
10/25/2019 15:00	2	1.9	13.2	14.4	25.3	679,655.9	0.00	1.00
10/25/2019 16:00	1	1.8	11.0	14.5	25.4	860,383.7	0.00	1.00
10/25/2019 17:00	2	1.8	9.7	14.6	26.0	936,642.8	0.00	1.00
10/25/2019 18:00	2	1.9	12.2	14.4	24.3	701,777.3	0.00	1.00
10/25/2019 19:00	2	2.1	14.1	13.4	37.7	961,153.3	0.00	1.00
10/25/2019 20:00	3	2.3	15.8	13.0	39.8	973,678.1	0.00	1.00
10/25/2019 21:00	2	2.2	15.0	13.2	37.8	972,647.0	0.00	1.00
10/25/2019 22:00	2	2.2	15.0	13.2	37.2	974,247.6	0.00	1.00
10/25/2019 23:00	2	2.0	12.4	14.3	25.2	740,941.6	0.00	1.00
Average/Sum#:	2	1.9	13.3	14.2	29.9	824,529.4	0.00 #	24.00 #
Minimum:	1	1.8	9.7	13.0	24.3	679,655.9	0.00	1.00
Maximum:	3	2.3	15.8	14.6	39.8	974,247.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	2	1.9	13.0	14.3	26.2	695,501.6	0.00	1.00
10/26/2019 01:00	2	1.9	13.2	14.3	27.6	691,559.3	0.00	1.00
10/26/2019 02:00	2	1.9	13.2	14.4	27.7	701,356.0	0.00	1.00
10/26/2019 03:00	3	1.9	13.6	14.4	28.4	691,032.6	0.00	1.00
10/26/2019 04:00	2	1.9	13.4	14.3	27.8	718,325.3	0.00	1.00
10/26/2019 05:00	2	1.9	13.3	14.3	28.7	696,954.0	0.00	1.00
10/26/2019 06:00	2	1.9	12.9	14.3	28.7	729,114.7	0.00	1.00
10/26/2019 07:00	3	1.9	13.1	14.3	28.3	702,556.2	0.00	1.00
10/26/2019 08:00	2	1.9	12.9	14.4	27.4	703,041.4	0.00	1.00
10/26/2019 09:00	2	1.9	12.7	14.4	27.1	704,094.8	0.00	1.00
10/26/2019 10:00	2	1.9	13.0	14.5	27.0	705,681.5	0.00	1.00
10/26/2019 11:00	2	1.9	13.0	14.5	27.1	705,681.5	0.00	1.00
10/26/2019 12:00	2	1.8	12.4	14.6	26.7	768,399.2	0.00	1.00
10/26/2019 13:00	2	1.8	12.4	14.6	26.9	767,095.0	0.00	1.00
10/26/2019 14:00	2	1.8	12.3	14.5	26.2	735,423.7	0.00	1.00
10/26/2019 15:00	2	1.8	13.8	14.5	28.4	678,293.0	0.00	1.00
10/26/2019 16:00	2	1.8	13.6	14.5	27.2	677,651.1	0.00	1.00
10/26/2019 17:00	2	1.8	12.1	14.5	25.2	753,611.4	0.00	1.00
10/26/2019 18:00	2	1.9	12.5	14.5	26.6	737,135.5	0.00	1.00
10/26/2019 19:00	2	1.9	12.3	14.5	25.9	735,423.7	0.00	1.00
10/26/2019 20:00	2	1.9	12.8	14.4	26.0	697,353.0	0.00	1.00
10/26/2019 21:00	2	1.9	12.8	14.4	25.4	697,353.0	0.00	1.00
10/26/2019 22:00	2	1.9	13.0	14.4	26.3	696,088.9	0.00	1.00
10/26/2019 23:00	2	1.9	13.4	14.4	28.0	693,771.5	0.00	1.00
Average/Sum#:	2	1.9	12.9	14.4	27.1	711,770.7	0.00 #	24.00 #
Minimum:	2	1.8	12.1	14.3	25.2	677,651.1	0.00	1.00
Maximum:	3	1.9	13.8	14.6	28.7	768,399.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag: > 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	2	1.8	13.0	14.5	29.6	794,908.1	0.00	1.00
10/27/2019 01:00	2	1.9	13.4	14.4	29.1	719,474.5	0.00	1.00
10/27/2019 02:00	2	1.9	13.0	14.4	28.9	757,397.0	0.00	1.00
10/27/2019 03:00	2	1.9	13.2	14.5	31.8	822,082.6	0.00	1.00
10/27/2019 04:00	2	1.8	13.9	14.5	32.4	823,366.4	0.00	1.00
10/27/2019 05:00	2	1.9	13.5	14.4	30.9	770,037.9	0.00	1.00
10/27/2019 06:00	2	1.9	13.2	14.5	31.9	822,082.6	0.00	1.00
10/27/2019 07:00	2	1.8	13.3	14.5	32.8	822,724.5	0.00	1.00
10/27/2019 08:00	2	1.8	13.4	14.5	33.0	822,510.5	0.00	1.00
10/27/2019 09:00	3	1.9	14.2	14.5	30.0	697,122.6	0.00	1.00
10/27/2019 10:00	3	1.8	14.3	14.5	29.3	663,528.9	0.00	1.00
10/27/2019 11:00	3	1.8	14.4	14.5	29.6	664,598.8	0.00	1.00
10/27/2019 12:00	3	1.8	14.7	14.5	30.5	672,087.8	0.00	1.00
10/27/2019 13:00	3	1.8	14.6	14.5	30.4	678,721.0	0.00	1.00
10/27/2019 14:00	3	1.8	14.7	14.5	30.3	673,799.6	0.00	1.00
10/27/2019 15:00	2	1.8	13.2	14.6	30.9	818,176.7	0.00	1.00
10/27/2019 16:00	2	1.9	13.3	14.5	29.0	732,856.0	0.00	1.00
10/27/2019 17:00	2	1.9	13.1	14.5	28.7	730,716.3	0.00	1.00
10/27/2019 18:00	2	1.9	12.6	14.5	27.8	764,310.0	0.00	1.00
10/27/2019 19:00	3	1.9	14.3	14.4	31.2	686,819.0	0.00	1.00
10/27/2019 20:00	2	1.9	13.3	14.4	29.7	722,002.7	0.00	1.00
10/27/2019 21:00	2	1.9	13.1	14.4	30.3	769,616.5	0.00	1.00
10/27/2019 22:00	3	1.9	13.6	14.4	31.3	738,014.4	0.00	1.00
10/27/2019 23:00	3	1.9	14.0	14.4	30.2	702,620.0	0.00	1.00
Average/Sum#:	2	1.9	13.6	14.5	30.4	744,565.6	0.00 #	24.00 #
Minimum:	2	1.8	12.6	14.4	27.8	663,528.9	0.00	1.00
Maximum:	3	1.9	14.7	14.6	33.0	823,366.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	3	1.9	14.0	14.4	30.3	702,620.0	0.00	1.00
10/28/2019 01:00	3	1.9	14.1	14.3	30.9	690,314.4	0.00	1.00
10/28/2019 02:00	3	1.9	14.1	14.3	30.7	691,559.3	0.00	1.00
10/28/2019 03:00	3	1.9	13.9	14.3	30.2	701,933.7	0.00	1.00
10/28/2019 04:00	2	1.9	13.4	14.2	37.9	976,379.1	0.00	1.00
10/28/2019 05:00	3	2.0	14.0	13.9	42.0	982,659.8	0.00	1.00
10/28/2019 06:00	3	2.2	16.8	13.1	47.3	998,977.5	0.00	1.00
10/28/2019 07:00	3	2.3	16.9	13.1	47.6	1,000,733.2	0.00	1.00
10/28/2019 08:00	2	2.0	13.9	14.3	35.6	859,210.1	0.00	1.00
10/28/2019 09:00	2	1.8	13.5	14.5	35.7	869,370.5	0.00	1.00
10/28/2019 10:00	2	1.8	13.2	14.6	34.5	879,040.0	0.00	1.00
10/28/2019 11:00	2	1.8	11.2	14.7	31.2	963,898.1	0.00	1.00
10/28/2019 12:00	2	1.8	12.9	14.5	30.8	801,541.2	0.00	1.00
10/28/2019 13:00	2	1.8	12.7	14.6	29.9	810,134.1	0.00	1.00
10/28/2019 14:00	2	1.8	12.9	14.6	30.8	815,350.9	0.00	1.00
10/28/2019 15:00	2	1.8	13.2	14.6	33.1	850,999.4	0.00	1.00
10/28/2019 16:00	2	1.8	13.2	14.6	32.5	839,696.3	0.00	1.00
10/28/2019 17:00	2	1.8	14.0	14.5	29.0	697,122.6	0.00	1.00
10/28/2019 18:00	2	1.9	13.3	14.1	35.5	946,715.3	0.00	1.00
10/28/2019 19:00	2	1.9	12.2	14.4	33.3	953,751.4	0.00	1.00
10/28/2019 20:00	2	1.9	13.0	14.5	31.1	798,545.6	0.00	1.00
10/28/2019 21:00	2	1.9	12.9	14.1	35.5	959,402.6	0.00	1.00
10/28/2019 22:00	2	1.9	12.0	14.3	33.1	944,902.8	0.00	1.00
10/28/2019 23:00	2	1.8	11.4	14.6	31.0	929,034.9	0.00	1.00
Average/Sum#:	2	1.9	13.4	14.3	34.1	860,995.5	0.00 #	24.00 #
Minimum:	2	1.8	11.2	13.1	29.0	690,314.4	0.00	1.00
Maximum:	3	2.3	16.9	14.7	47.6	1,000,733.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	2	1.9	13.0	14.4	29.7	761,189.3	0.00	1.00
10/29/2019 01:00	3	1.9	13.3	14.3	29.7	716,872.9	0.00	1.00
10/29/2019 02:00	3	1.9	13.9	14.3	30.3	689,484.4	0.00	1.00
10/29/2019 03:00	2	1.9	12.8	14.4	32.2	834,084.8	0.00	1.00
10/29/2019 04:00	4	2.3	17.6	12.8	52.8	959,442.4	0.00	1.00
10/29/2019 05:00	5	2.6	19.3	11.8	63.3	1,002,840.0	0.00	1.00
10/29/2019 06:00	5	2.6	19.1	11.8	61.4	1,009,762.4	0.00	1.00
10/29/2019 07:00	5	2.6	19.0	11.8	60.7	1,008,107.0	0.00	1.00
10/29/2019 08:00	5	2.6	18.8	12.0	58.2	1,002,295.6	0.00	1.00
10/29/2019 09:00	5	2.6	19.3	12.0	59.0	995,217.6	0.00	1.00
10/29/2019 10:00	5	2.6	20.0	11.9	61.3	991,919.7	0.00	1.00
10/29/2019 11:00	5	2.6	20.3	12.0	60.0	984,446.9	0.00	1.00
10/29/2019 12:00	5	2.6	20.6	12.0	59.1	977,830.6	0.00	1.00
10/29/2019 13:00	5	2.6	20.7	12.0	59.2	976,291.9	0.00	1.00
10/29/2019 14:00	3	2.3	17.8	12.9	48.5	936,515.1	0.00	1.00
10/29/2019 15:00	4	2.6	20.5	12.1	59.0	979,294.1	0.00	1.00
10/29/2019 16:00	3	2.3	18.7	12.8	47.9	971,953.2	0.00	1.00
10/29/2019 17:00	3	2.3	18.4	12.9	47.9	981,192.6	0.00	1.00
10/29/2019 18:00	3	2.3	16.8	13.2	44.8	983,851.4	0.00	1.00
10/29/2019 19:00	3	2.2	15.4	13.4	42.3	975,943.1	0.00	1.00
10/29/2019 20:00	3	2.2	16.3	13.2	45.7	991,854.5	0.00	1.00
10/29/2019 21:00	3	2.3	16.9	13.0	46.8	986,852.3	0.00	1.00
10/29/2019 22:00	3	2.3	16.7	13.0	46.1	981,825.3	0.00	1.00
10/29/2019 23:00	2	1.9	12.2	14.5	31.6	914,946.7	0.00	1.00
Average/Sum#:	4	2.3	17.4	12.9	49.1	942,250.6	0.00 #	24.00 #
Minimum:	2	1.9	12.2	11.8	29.7	689,484.4	0.00	1.00
Maximum:	5	2.6	20.7	14.5	63.3	1,009,762.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	2	1.9	13.5	14.3	30.0	721,022.7	0.00	1.00
10/30/2019 01:00	3	1.9	13.3	14.3	30.5	724,135.0	0.00	1.00
10/30/2019 02:00	3	1.9	13.4	14.3	31.9	749,863.6	0.00	1.00
10/30/2019 03:00	3	1.9	13.7	14.4	37.5	865,897.6	0.00	1.00
10/30/2019 04:00	3	1.9	15.9	13.3	49.2	1,001,842.0	0.00	1.00
10/30/2019 05:00	3	2.1	14.6	13.6	44.0	999,304.6	0.00	1.00
10/30/2019 06:00	3	2.1	13.9	13.7	42.1	998,348.4	0.00	1.00
10/30/2019 07:00	3	2.1	14.8	13.7	39.6	856,651.0	0.00	1.00
10/30/2019 08:00	3	1.9	14.4	14.5	30.4	666,310.6	0.00	1.00
10/30/2019 09:00	3	1.9	13.5	14.5	27.8	669,306.2	0.00	1.00
10/30/2019 10:00	3	1.9	13.8	14.5	29.3	668,878.2	0.00	1.00
10/30/2019 11:00	3	1.8	13.4	14.5	29.7	716,594.1	0.00	1.00
10/30/2019 12:00	2	2.0	13.7	14.0	38.3	972,886.7	0.00	1.00
10/30/2019 13:00	2	2.0	14.4	13.9	38.8	980,312.2	0.00	1.00
10/30/2019 14:00	4	2.4	19.4	12.6	53.3	982,025.8	0.00	1.00
10/30/2019 15:00	4	2.4	20.3	12.5	53.9	983,377.1	0.00	1.00
10/30/2019 16:00	2	2.1	14.5	13.9	36.4	968,378.7	0.00	1.00
10/30/2019 17:00	3	2.2	16.6	13.1	45.1	974,047.0	0.00	1.00
10/30/2019 18:00	3	2.2	15.3	13.4	41.4	977,403.8	0.00	1.00
10/30/2019 19:00	2	2.0	13.5	14.0	37.6	989,359.5	0.00	1.00
10/30/2019 20:00	3	2.1	14.9	13.5	40.3	983,764.9	0.00	1.00
10/30/2019 21:00	2	2.0	13.2	14.0	36.7	981,023.9	0.00	1.00
10/30/2019 22:00	2	1.9	11.4	14.6	32.0	957,945.0	0.00	1.00
10/30/2019 23:00	2	1.9	12.1	14.5	33.2	897,400.9	0.00	1.00
Average/Sum#:	3	2.0	14.5	13.9	37.9	886,920.0	0.00 #	24.00 #
Minimum:	2	1.8	11.4	12.5	27.8	666,310.6	0.00	1.00
Maximum:	4	2.4	20.3	14.6	53.9	1,001,842.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	3	1.9	13.3	14.3	30.9	747,581.2	0.00	1.00
10/31/2019 01:00	3	1.9	13.2	14.3	30.4	733,679.5	0.00	1.00
10/31/2019 02:00	3	1.9	13.1	14.3	30.4	739,281.7	0.00	1.00
10/31/2019 03:00	2	1.9	12.2	14.4	30.1	818,494.4	0.00	1.00
10/31/2019 04:00	2	1.9	14.6	13.7	43.5	1,015,085.8	0.00	1.00
10/31/2019 05:00	3	2.2	15.7	13.2	47.9	1,010,706.3	0.00	1.00
10/31/2019 06:00	4	2.4	18.8	12.4	54.4	1,015,951.8	0.00	1.00
10/31/2019 07:00	4	2.5	18.8	12.2	56.6	1,011,485.2	0.00	1.00
10/31/2019 08:00	4	2.5	18.9	12.3	56.4	1,016,240.3	0.00	1.00
10/31/2019 09:00	4	2.5	19.3	12.2	57.9	1,003,772.3	0.00	1.00
10/31/2019 10:00	3	2.4	18.8	12.6	51.5	994,565.1	0.00	1.00
10/31/2019 11:00	3	2.3	17.1	13.1	46.8	990,023.6	0.00	1.00
10/31/2019 12:00	3	2.1	15.2	13.5	40.9	977,472.9	0.00	1.00
10/31/2019 13:00	5	2.5	20.9	12.1	61.3	990,654.0	0.00	1.00
10/31/2019 14:00	4	2.4	20.3	12.4	54.2	973,741.3	0.00	1.00
10/31/2019 15:00	4	2.5	20.3	12.4	54.8	974,707.9	0.00	1.00
10/31/2019 16:00	5	2.6	21.4	12.0	61.6	987,524.2	0.00	1.00
10/31/2019 17:00	5	2.6	20.9	12.0	60.3	984,908.5	0.00	1.00
10/31/2019 18:00	4	2.5	20.0	12.2	56.6	985,198.5	0.00	1.00
10/31/2019 19:00	2	2.0	13.4	14.1	33.9	977,728.7	0.00	1.00
10/31/2019 20:00	2	2.0	12.9	14.2	35.4	986,598.7	0.00	1.00
10/31/2019 21:00	2	1.9	12.5	14.2	34.7	972,291.3	0.00	1.00
10/31/2019 22:00	2	1.9	13.0	14.5	31.9	825,078.2	0.00	1.00
10/31/2019 23:00	2	1.9	13.2	14.4	28.8	717,578.4	0.00	1.00
Average/Sum#:	3	2.2	16.6	13.2	45.5	935,431.2	0.00 #	24.00 #
Minimum:	2	1.9	12.2	12.0	28.8	717,578.4	0.00	1.00
Maximum:	5	2.6	21.4	14.5	61.6	1,016,240.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	2	1.9	13.5	14.4	27.0	664,908.2	0.00	1.00
11/01/2019 01:00	2	1.9	13.6	14.4	27.8	676,495.6	0.00	1.00
11/01/2019 02:00	3	1.9	14.0	14.3	30.7	693,841.7	0.00	1.00
11/01/2019 03:00	2	1.9	12.7	14.5	33.6	910,881.2	0.00	1.00
11/01/2019 04:00	2	1.9	14.5	13.7	42.0	1,007,858.3	0.00	1.00
11/01/2019 05:00	3	2.3	16.2	13.0	48.4	1,011,987.3	0.00	1.00
11/01/2019 06:00	4	2.5	18.7	12.3	56.0	1,031,526.9	0.00	1.00
11/01/2019 07:00	2	2.1	13.8	13.7	38.2	1,002,913.2	0.00	1.00
11/01/2019 08:00	3	2.1	13.6	13.7	40.1	1,001,772.0	0.00	1.00
11/01/2019 09:00	3	2.2	15.0	13.4	43.6	1,006,253.0	0.00	1.00
11/01/2019 10:00	3	2.2	16.0	13.2	43.3	995,055.8	0.00	1.00
11/01/2019 11:00	2	2.0	12.9	14.1	34.9	974,305.2	0.00	1.00
11/01/2019 12:00	2	1.9	11.7	14.6	32.6	970,117.6	0.00	1.00
11/01/2019 13:00	2	1.8	11.5	14.7	32.8	972,291.3	0.00	1.00
11/01/2019 14:00	2	1.9	13.4	14.2	36.9	974,744.0	0.00	1.00
11/01/2019 15:00	3	2.1	15.2	13.6	41.2	978,294.3	0.00	1.00
11/01/2019 16:00	2	1.9	12.8	14.3	35.0	970,631.4	0.00	1.00
11/01/2019 17:00	2	2.0	13.9	14.0	36.2	977,848.4	0.00	1.00
11/01/2019 18:00	2	1.9	11.5	14.6	32.9	970,117.6	0.00	1.00
11/01/2019 19:00	2	1.8	11.3	14.6	30.5	930,991.2	0.00	1.00
11/01/2019 20:00	2	1.8	11.4	14.6	31.0	940,990.2	0.00	1.00
11/01/2019 21:00	3	2.2	15.6	13.2	44.6	1,002,525.4	0.00	1.00
11/01/2019 22:00	3	2.2	15.5	13.2	43.0	997,012.1	0.00	1.00
11/01/2019 23:00	2	2.1	13.8	13.7	38.3	999,299.4	0.00	1.00
Average/Sum#:	2	2.0	13.8	13.9	37.5	944,277.6	0.00 #	24.00 #
Minimum:	2	1.8	11.3	12.3	27.0	664,908.2	0.00	1.00
Maximum:	4	2.5	18.7	14.7	56.0	1,031,526.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	2	1.9	11.5	14.5	31.5	928,640.9	0.00	1.00
11/02/2019 01:00	2	1.9	12.6	14.4	29.8	807,960.4	0.00	1.00
11/02/2019 02:00	2	1.9	12.3	14.4	30.0	823,972.1	0.00	1.00
11/02/2019 03:00	2	1.9	12.4	14.4	29.2	790,895.3	0.00	1.00
11/02/2019 04:00	2	1.8	12.3	14.5	33.7	931,208.6	0.00	1.00
11/02/2019 05:00	3	2.0	13.4	13.8	41.2	1,000,644.2	0.00	1.00
11/02/2019 06:00	3	2.2	15.7	13.2	44.9	1,018,531.6	0.00	1.00
11/02/2019 07:00	2	1.9	12.6	14.4	30.5	856,627.6	0.00	1.00
11/02/2019 08:00	2	1.9	12.6	14.4	31.3	832,610.0	0.00	1.00
11/02/2019 09:00	3	1.9	13.6	14.4	28.5	683,237.4	0.00	1.00
11/02/2019 10:00	2	1.9	13.8	14.4	28.3	680,498.6	0.00	1.00
11/02/2019 11:00	2	1.9	13.8	14.5	28.3	683,428.4	0.00	1.00
11/02/2019 12:00	2	1.8	13.3	14.5	27.8	716,808.1	0.00	1.00
11/02/2019 13:00	2	1.8	12.2	14.5	26.7	759,174.6	0.00	1.00
11/02/2019 14:00	2	1.8	12.0	14.6	29.9	878,387.9	0.00	1.00
11/02/2019 15:00	4	2.5	20.5	12.1	57.6	981,783.9	0.00	1.00
11/02/2019 16:00	2	2.1	14.8	13.8	35.7	964,576.2	0.00	1.00
11/02/2019 17:00	4	2.5	20.7	12.1	55.7	975,248.0	0.00	1.00
11/02/2019 18:00	1	1.9	11.7	14.6	28.4	952,728.1	0.00	1.00
11/02/2019 19:00	2	1.8	11.9	14.6	29.8	898,385.9	0.00	1.00
11/02/2019 20:00	2	1.9	12.0	14.3	33.8	983,703.2	0.00	1.00
11/02/2019 21:00	3	2.1	14.7	13.4	40.3	987,263.7	0.00	1.00
11/02/2019 22:00	2	2.1	14.2	13.6	38.2	999,679.8	0.00	1.00
11/02/2019 23:00	2	2.0	13.1	14.3	28.5	729,529.7	0.00	1.00
Average/Sum#:	2	2.0	13.7	14.1	34.2	869,396.8	0.00 #	24.00 #
Minimum:	1	1.8	11.5	12.1	26.7	680,498.6	0.00	1.00
Maximum:	4	2.5	20.7	14.6	57.6	1,018,531.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag: > 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	2	1.9	13.7	14.3	29.1	690,106.9	0.00	1.00
11/03/2019 01:00	2	1.9	13.5	14.3	28.4	695,916.6	0.00	1.00
11/03/2019 02:00	2	1.9	13.5	14.3	28.8	695,294.1	0.00	1.00
11/03/2019 03:00	3	1.9	13.7	14.3	29.4	694,671.6	0.00	1.00
11/03/2019 04:00	2	1.9	14.3	14.3	29.8	693,634.2	0.00	1.00
11/03/2019 05:00	2	1.9	13.1	14.3	29.6	734,924.4	0.00	1.00
11/03/2019 06:00	2	1.9	13.2	14.3	28.6	711,063.2	0.00	1.00
11/03/2019 07:00	2	1.9	12.7	14.3	29.3	754,428.3	0.00	1.00
11/03/2019 08:00	2	1.8	12.0	14.5	30.9	870,012.4	0.00	1.00
11/03/2019 09:00	2	1.9	11.8	14.4	34.0	989,777.8	0.00	1.00
11/03/2019 10:00	2	1.9	12.5	14.2	34.4	986,803.1	0.00	1.00
11/03/2019 11:00	3	2.2	15.9	13.2	42.5	977,093.2	0.00	1.00
11/03/2019 12:00	2	2.1	13.9	13.8	35.7	969,976.8	0.00	1.00
11/03/2019 13:00	3	2.2	16.5	13.2	42.9	970,157.1	0.00	1.00
11/03/2019 14:00	3	2.2	16.2	13.3	40.9	965,264.0	0.00	1.00
11/03/2019 15:00	3	2.4	19.5	12.7	48.4	975,798.4	0.00	1.00
11/03/2019 16:00	3	2.4	19.1	12.8	47.0	977,194.2	0.00	1.00
11/03/2019 17:00	1	2.0	13.1	14.3	25.6	766,670.2	0.00	1.00
11/03/2019 18:00	2	1.9	12.3	14.5	25.8	756,607.0	0.00	1.00
11/03/2019 19:00	2	1.9	13.7	14.4	27.6	670,175.2	0.00	1.00
11/03/2019 20:00	2	1.9	13.7	14.4	27.5	674,810.2	0.00	1.00
11/03/2019 21:00	2	1.8	13.3	14.4	27.1	693,139.4	0.00	1.00
11/03/2019 22:00	2	1.9	12.5	14.5	29.9	845,619.6	0.00	1.00
11/03/2019 23:00	2	1.9	13.7	14.4	29.0	700,091.9	0.00	1.00
Average/Sum#:	2	2.0	14.1	14.1	32.6	810,801.2	0.00 #	24.00 #
Minimum:	1	1.8	11.8	12.7	25.6	670,175.2	0.00	1.00
Maximum:	3	2.4	19.5	14.5	48.4	989,777.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	2	1.9	13.7	14.4	28.8	699,038.5	0.00	1.00
11/04/2019 01:00	2	1.9	13.6	14.3	28.6	690,729.4	0.00	1.00
11/04/2019 02:00	2	1.9	13.5	14.3	28.5	695,294.1	0.00	1.00
11/04/2019 03:00	2	1.9	13.4	14.3	28.5	695,709.1	0.00	1.00
11/04/2019 04:00	2	1.8	13.5	14.3	28.0	705,876.0	0.00	1.00
11/04/2019 05:00	2	1.9	11.7	14.4	26.6	798,901.1	0.00	1.00
11/04/2019 06:00	2	1.9	12.1	14.4	30.0	841,458.6	0.00	1.00
11/04/2019 07:00	2	1.9	11.4	14.5	30.8	929,282.8	0.00	1.00
11/04/2019 08:00	3	2.3	17.3	12.8	48.8	1,002,215.8	0.00	1.00
11/04/2019 09:00	4	2.5	19.7	12.0	54.8	995,525.4	0.00	1.00
11/04/2019 10:00	4	2.6	20.3	12.0	55.5	993,525.1	0.00	1.00
11/04/2019 11:00	3	2.4	19.4	12.5	48.5	985,170.4	0.00	1.00
11/04/2019 12:00	3	2.4	19.4	12.7	47.2	982,478.5	0.00	1.00
11/04/2019 13:00	3	2.4	19.8	12.5	48.3	967,889.6	0.00	1.00
11/04/2019 14:00	3	2.4	19.2	12.7	46.1	967,281.2	0.00	1.00
11/04/2019 15:00	3	2.4	19.3	12.7	46.3	971,122.3	0.00	1.00
11/04/2019 16:00	3	2.4	19.2	12.7	45.3	966,279.2	0.00	1.00
11/04/2019 17:00	2	2.0	13.5	14.0	31.2	947,681.4	0.00	1.00
11/04/2019 18:00	2	1.8	11.2	14.6	29.0	946,207.0	0.00	1.00
11/04/2019 19:00	2	1.9	12.2	14.5	27.4	814,593.5	0.00	1.00
11/04/2019 20:00	2	1.9	12.2	14.4	25.4	736,961.0	0.00	1.00
11/04/2019 21:00	2	1.8	11.7	14.5	29.1	864,663.1	0.00	1.00
11/04/2019 22:00	2	1.9	12.1	14.4	27.3	792,580.7	0.00	1.00
11/04/2019 23:00	2	1.9	13.4	14.4	27.2	675,652.9	0.00	1.00
Average/Sum#:	2	2.1	15.1	13.7	36.1	861,088.2	0.00 #	24.00 #
Minimum:	2	1.8	11.2	12.0	25.4	675,652.9	0.00	1.00
Maximum:	4	2.6	20.3	14.6	55.5	1,002,215.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	2	1.9	12.7	14.4	26.8	725,584.2	0.00	1.00
11/05/2019 01:00	2	1.9	13.1	14.3	27.8	703,178.7	0.00	1.00
11/05/2019 02:00	2	1.9	13.3	14.3	28.3	700,688.8	0.00	1.00
11/05/2019 03:00	2	1.9	13.2	14.3	28.3	697,576.5	0.00	1.00
11/05/2019 04:00	2	1.9	13.3	14.3	28.0	715,835.5	0.00	1.00
11/05/2019 05:00	2	1.9	12.0	14.4	28.8	835,770.2	0.00	1.00
11/05/2019 06:00	3	2.1	14.8	13.3	41.5	1,001,661.9	0.00	1.00
11/05/2019 07:00	2	2.2	14.2	13.5	39.2	1,005,601.6	0.00	1.00
11/05/2019 08:00	3	2.2	14.8	13.3	40.6	995,895.9	0.00	1.00
11/05/2019 09:00	3	2.3	17.0	12.9	45.2	997,112.1	0.00	1.00
11/05/2019 10:00	2	2.1	13.8	13.7	34.8	977,997.2	0.00	1.00
11/05/2019 11:00	2	2.1	13.6	13.7	35.9	968,297.2	0.00	1.00
11/05/2019 12:00	2	2.1	13.5	13.8	34.2	961,490.2	0.00	1.00
11/05/2019 13:00	2	2.0	12.8	13.9	32.3	930,426.1	0.00	1.00
11/05/2019 14:00	2	1.8	11.8	14.6	26.5	799,265.6	0.00	1.00
11/05/2019 15:00	2	1.8	10.0	14.5	27.8	948,112.4	0.00	1.00
11/05/2019 16:00	2	2.1	11.9	13.8	30.0	909,992.1	0.00	1.00
11/05/2019 17:00	2	1.8	9.2	14.5	27.3	965,872.1	0.00	1.00
11/05/2019 18:00	2	1.8	9.3	14.5	27.0	964,588.3	0.00	1.00
11/05/2019 19:00	2	1.9	9.4	14.5	25.5	918,584.2	0.00	1.00
11/05/2019 20:00	2	1.9	10.2	14.4	26.4	877,485.0	0.00	1.00
11/05/2019 21:00	2	1.9	13.2	14.3	27.0	681,599.9	0.00	1.00
11/05/2019 22:00	2	1.9	13.1	14.4	26.2	676,495.6	0.00	1.00
11/05/2019 23:00	2	1.9	13.0	14.4	25.8	668,068.4	0.00	1.00
Average/Sum#:	2	2.0	12.6	14.1	30.9	859,465.8	0.00 #	24.00 #
Minimum:	2	1.8	9.2	12.9	25.5	668,068.4	0.00	1.00
Maximum:	3	2.3	17.0	14.6	45.2	1,005,601.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	2	1.9	13.1	14.4	26.1	672,071.4	0.00	1.00
11/06/2019 01:00	2	1.9	12.8	14.5	25.1	675,511.4	0.00	1.00
11/06/2019 02:00	2	1.9	12.4	14.5	24.0	668,022.3	0.00	1.00
11/06/2019 03:00	2	1.9	12.6	14.5	24.9	660,105.3	0.00	1.00
11/06/2019 04:00	3	1.9	15.1	14.5	29.9	650,690.6	0.00	1.00
11/06/2019 05:00	3	1.8	14.8	14.5	30.1	655,398.0	0.00	1.00
11/06/2019 06:00	2	1.9	11.4	14.4	25.8	806,064.3	0.00	1.00
11/06/2019 07:00	2	1.9	12.0	14.4	28.8	827,343.0	0.00	1.00
11/06/2019 08:00	2	1.9	12.2	14.3	26.7	732,642.0	0.00	1.00
11/06/2019 09:00	2	1.9	11.4	14.4	24.3	767,509.7	0.00	1.00
11/06/2019 10:00	2	1.9	11.4	14.5	24.8	780,571.9	0.00	1.00
11/06/2019 11:00	2	1.8	11.1	14.5	24.5	814,165.6	0.00	1.00
11/06/2019 12:00	2	1.9	11.2	14.5	26.5	853,536.5	0.00	1.00
11/06/2019 13:00	2	1.9	11.2	14.5	26.3	858,885.9	0.00	1.00
11/06/2019 14:00	2	1.8	9.7	14.5	24.8	903,820.1	0.00	1.00
11/06/2019 15:00	2	2.0	11.9	13.8	30.6	981,356.5	0.00	1.00
11/06/2019 16:00	2	2.1	12.6	13.7	31.7	988,648.3	0.00	1.00
11/06/2019 17:00	3	2.4	16.8	12.5	42.5	999,679.8	0.00	1.00
11/06/2019 18:00	3	2.5	17.2	12.4	44.0	998,390.9	0.00	1.00
11/06/2019 19:00	3	2.4	16.7	12.6	41.9	996,710.0	0.00	1.00
11/06/2019 20:00	3	2.4	16.9	12.5	43.1	997,886.5	0.00	1.00
11/06/2019 21:00	2	2.2	13.6	13.3	34.9	973,552.6	0.00	1.00
11/06/2019 22:00	2	1.9	11.7	14.3	25.3	771,442.4	0.00	1.00
11/06/2019 23:00	2	1.9	12.2	14.4	24.6	711,047.3	0.00	1.00
Average/Sum#:	2	2.0	13.0	14.0	29.6	822,710.5	0.00 #	24.00 #
Minimum:	2	1.8	9.7	12.4	24.0	650,690.6	0.00	1.00
Maximum:	3	2.5	17.2	14.5	44.0	999,679.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	3	2.3	16.1	12.8	43.4	999,003.5	0.00	1.00
11/07/2019 01:00	2	2.2	13.5	13.4	35.1	991,280.7	0.00	1.00
11/07/2019 02:00	2	2.2	13.3	13.5	35.8	1,000,790.1	0.00	1.00
11/07/2019 03:00	2	2.1	13.1	13.5	36.1	997,459.1	0.00	1.00
11/07/2019 04:00	2	2.0	13.5	13.6	37.7	1,002,681.3	0.00	1.00
11/07/2019 05:00	3	2.4	17.6	12.6	54.1	1,029,213.2	0.00	1.00
11/07/2019 06:00	4	2.5	18.8	12.2	52.5	1,016,364.7	0.00	1.00
11/07/2019 07:00	4	2.5	18.8	12.2	52.4	1,014,948.1	0.00	1.00
11/07/2019 08:00	2	2.2	14.8	13.3	38.1	1,002,202.4	0.00	1.00
11/07/2019 09:00	3	2.3	16.6	12.9	43.8	999,851.0	0.00	1.00
11/07/2019 10:00	2	2.3	16.6	13.0	39.9	957,383.7	0.00	1.00
11/07/2019 11:00	2	1.9	13.1	14.5	26.9	733,497.9	0.00	1.00
11/07/2019 12:00	2	1.9	13.5	14.5	26.8	688,135.8	0.00	1.00
11/07/2019 13:00	2	1.8	13.5	14.5	26.9	681,288.6	0.00	1.00
11/07/2019 14:00	2	1.8	13.4	14.5	26.7	680,432.7	0.00	1.00
11/07/2019 15:00	2	1.9	13.5	14.5	27.4	700,332.2	0.00	1.00
11/07/2019 16:00	1	1.8	9.3	14.6	21.9	927,078.6	0.00	1.00
11/07/2019 17:00	1	1.8	9.2	14.6	25.2	975,334.5	0.00	1.00
11/07/2019 18:00	2	1.9	9.8	14.3	28.2	987,853.0	0.00	1.00
11/07/2019 19:00	2	1.9	9.9	14.3	28.4	966,274.1	0.00	1.00
11/07/2019 20:00	2	1.9	11.2	14.4	27.4	846,093.6	0.00	1.00
11/07/2019 21:00	3	2.2	15.2	12.8	45.1	948,284.1	0.00	1.00
11/07/2019 22:00	4	2.5	17.8	12.0	50.8	1,003,372.6	0.00	1.00
11/07/2019 23:00	2	2.2	13.9	13.4	35.2	1,002,418.6	0.00	1.00
Average/Sum#:	2	2.1	14.0	13.6	36.1	922,982.3	0.00 #	24.00 #
Minimum:	1	1.8	9.2	12.0	21.9	680,432.7	0.00	1.00
Maximum:	4	2.5	18.8	14.6	54.1	1,029,213.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	2	2.2	13.6	13.5	36.3	1,009,117.7	0.00	1.00
11/08/2019 01:00	2	2.0	11.6	14.1	31.6	998,270.1	0.00	1.00
11/08/2019 02:00	2	1.9	11.4	14.2	32.5	999,066.6	0.00	1.00
11/08/2019 03:00	2	2.0	11.8	14.1	33.4	989,610.5	0.00	1.00
11/08/2019 04:00	2	1.9	12.7	14.1	35.9	1,010,554.6	0.00	1.00
11/08/2019 05:00	3	2.2	16.1	12.9	44.3	1,012,689.3	0.00	1.00
11/08/2019 06:00	3	2.2	15.0	13.2	41.1	1,008,927.9	0.00	1.00
11/08/2019 07:00	4	2.5	18.2	12.2	52.3	1,014,318.5	0.00	1.00
11/08/2019 08:00	2	2.2	14.5	13.3	38.5	998,598.7	0.00	1.00
11/08/2019 09:00	2	2.2	15.6	13.2	39.9	987,230.5	0.00	1.00
11/08/2019 10:00	2	1.9	13.1	14.4	27.3	731,904.7	0.00	1.00
11/08/2019 11:00	2	1.8	13.2	14.5	25.8	675,511.4	0.00	1.00
11/08/2019 12:00	2	1.8	13.5	14.5	27.2	681,288.6	0.00	1.00
11/08/2019 13:00	2	1.9	13.2	14.4	26.1	688,715.1	0.00	1.00
11/08/2019 14:00	2	1.9	13.0	14.3	25.7	689,276.9	0.00	1.00
11/08/2019 15:00	1	1.9	9.9	14.4	25.8	950,591.2	0.00	1.00
11/08/2019 16:00	2	1.9	10.2	14.3	28.9	989,720.4	0.00	1.00
11/08/2019 17:00	2	2.2	15.3	12.9	38.5	992,661.5	0.00	1.00
11/08/2019 18:00	3	2.4	16.5	12.7	40.9	1,000,681.8	0.00	1.00
11/08/2019 19:00	2	2.3	15.9	12.9	38.9	985,643.2	0.00	1.00
11/08/2019 20:00	2	1.9	13.2	14.5	26.3	672,515.8	0.00	1.00
11/08/2019 21:00	2	1.9	12.0	14.4	22.0	661,537.3	0.00	1.00
11/08/2019 22:00	3	1.9	13.5	14.4	28.3	652,267.4	0.00	1.00
11/08/2019 23:00	2	1.7	13.8	14.5	26.7	652,402.3	0.00	1.00
Average/Sum#:	2	2.0	13.6	13.8	33.1	877,212.6	0.00 #	24.00 #
Minimum:	1	1.7	9.9	12.2	22.0	652,267.4	0.00	1.00
Maximum:	4	2.5	18.2	14.5	52.3	1,014,318.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	2	1.8	12.3	14.3	26.6	726,417.4	0.00	1.00
11/09/2019 01:00	2	1.8	12.7	14.4	25.7	675,652.9	0.00	1.00
11/09/2019 02:00	2	1.8	12.5	14.4	25.4	663,012.1	0.00	1.00
11/09/2019 03:00	2	1.8	12.7	14.4	26.1	669,543.2	0.00	1.00
11/09/2019 04:00	2	1.8	13.2	14.4	26.5	668,068.4	0.00	1.00
11/09/2019 05:00	2	1.9	12.9	14.3	29.4	724,757.5	0.00	1.00
11/09/2019 06:00	2	1.9	12.7	14.3	28.4	754,220.9	0.00	1.00
11/09/2019 07:00	2	1.9	11.9	14.4	27.8	827,553.7	0.00	1.00
11/09/2019 08:00	2	1.9	12.6	14.3	27.9	727,454.8	0.00	1.00
11/09/2019 09:00	2	1.9	12.7	14.3	27.8	713,345.6	0.00	1.00
11/09/2019 10:00	2	1.9	12.7	14.4	26.8	717,578.4	0.00	1.00
11/09/2019 11:00	2	1.9	12.8	14.4	27.3	716,525.0	0.00	1.00
11/09/2019 12:00	2	1.9	12.6	14.4	26.3	720,106.5	0.00	1.00
11/09/2019 13:00	2	1.9	12.2	14.3	24.9	712,308.2	0.00	1.00
11/09/2019 14:00	2	1.9	11.9	14.3	24.6	722,890.1	0.00	1.00
11/09/2019 15:00	1	1.8	9.3	14.5	24.7	950,252.1	0.00	1.00
11/09/2019 16:00	2	2.1	13.2	13.5	34.7	992,647.6	0.00	1.00
11/09/2019 17:00	2	2.1	12.9	13.5	33.6	982,469.5	0.00	1.00
11/09/2019 18:00	2	2.1	12.4	13.7	33.8	989,789.5	0.00	1.00
11/09/2019 19:00	2	2.0	11.8	14.0	30.2	971,695.9	0.00	1.00
11/09/2019 20:00	2	1.9	11.7	14.4	28.4	866,318.9	0.00	1.00
11/09/2019 21:00	2	1.9	11.5	14.4	28.1	881,487.9	0.00	1.00
11/09/2019 22:00	2	1.9	10.9	14.3	30.3	992,832.7	0.00	1.00
11/09/2019 23:00	2	1.9	11.6	14.4	28.4	869,268.5	0.00	1.00
Average/Sum#:	2	1.9	12.2	14.3	28.1	801,508.2	0.00 #	24.00 #
Minimum:	1	1.8	9.3	13.5	24.6	663,012.1	0.00	1.00
Maximum:	2	2.1	13.2	14.5	34.7	992,832.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	2	1.9	12.0	14.3	26.4	782,439.3	0.00	1.00
11/10/2019 01:00	2	1.9	13.4	14.3	27.0	684,297.2	0.00	1.00
11/10/2019 02:00	2	1.9	13.4	14.3	26.5	681,599.9	0.00	1.00
11/10/2019 03:00	2	1.9	13.4	14.3	26.7	681,807.4	0.00	1.00
11/10/2019 04:00	2	1.9	13.9	14.3	27.3	683,882.2	0.00	1.00
11/10/2019 05:00	2	1.9	13.3	14.3	27.0	697,369.0	0.00	1.00
11/10/2019 06:00	2	1.9	12.2	14.3	26.4	731,397.1	0.00	1.00
11/10/2019 07:00	2	1.9	11.4	14.3	25.8	788,871.4	0.00	1.00
11/10/2019 08:00	2	1.9	12.7	14.3	28.2	716,043.0	0.00	1.00
11/10/2019 09:00	2	1.9	11.7	14.4	25.6	774,672.8	0.00	1.00
11/10/2019 10:00	2	1.9	12.0	14.4	26.3	744,124.1	0.00	1.00
11/10/2019 11:00	2	1.9	11.7	14.5	25.3	767,947.5	0.00	1.00
11/10/2019 12:00	2	1.9	11.4	14.5	24.4	760,030.5	0.00	1.00
11/10/2019 13:00	2	1.9	10.6	14.4	22.5	769,405.8	0.00	1.00
11/10/2019 14:00	2	1.9	11.0	14.3	23.6	744,053.9	0.00	1.00
11/10/2019 15:00	1	1.8	9.2	14.6	24.3	942,946.5	0.00	1.00
11/10/2019 16:00	2	1.9	9.9	14.5	25.7	905,531.9	0.00	1.00
11/10/2019 17:00	2	2.0	12.1	13.9	31.4	984,616.1	0.00	1.00
11/10/2019 18:00	2	2.0	11.8	14.0	30.6	980,825.4	0.00	1.00
11/10/2019 19:00	2	1.9	11.4	14.2	28.5	913,426.5	0.00	1.00
11/10/2019 20:00	2	1.9	11.3	14.4	24.6	797,637.0	0.00	1.00
11/10/2019 21:00	2	1.9	11.2	14.4	24.9	802,904.1	0.00	1.00
11/10/2019 22:00	2	1.9	10.7	14.3	30.2	959,842.0	0.00	1.00
11/10/2019 23:00	2	1.9	11.5	14.3	25.8	784,721.7	0.00	1.00
Average/Sum#:	2	1.9	11.8	14.3	26.5	795,016.3	0.00 #	24.00 #
Minimum:	1	1.8	9.2	13.9	22.5	681,599.9	0.00	1.00
Maximum:	2	2.0	13.9	14.6	31.4	984,616.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	2	1.9	11.5	14.3	25.4	756,918.2	0.00	1.00
11/11/2019 01:00	2	1.9	11.7	14.3	25.6	753,805.9	0.00	1.00
11/11/2019 02:00	2	1.9	12.5	14.3	27.8	723,720.0	0.00	1.00
11/11/2019 03:00	2	1.9	12.5	14.3	27.5	723,512.5	0.00	1.00
11/11/2019 04:00	2	1.9	12.3	14.4	28.3	794,898.2	0.00	1.00
11/11/2019 05:00	2	1.8	11.4	14.5	30.9	916,016.5	0.00	1.00
11/11/2019 06:00	2	1.9	10.6	14.5	30.0	964,588.3	0.00	1.00
11/11/2019 07:00	2	1.9	11.4	14.3	32.7	993,247.7	0.00	1.00
11/11/2019 08:00	2	1.9	12.1	14.3	26.6	740,319.1	0.00	1.00
11/11/2019 09:00	2	1.9	11.9	14.4	25.7	742,860.1	0.00	1.00
11/11/2019 10:00	2	1.9	12.7	14.4	26.7	717,999.7	0.00	1.00
11/11/2019 11:00	2	1.9	13.1	14.4	26.7	696,931.7	0.00	1.00
11/11/2019 12:00	2	1.9	11.1	14.4	23.1	775,094.2	0.00	1.00
11/11/2019 13:00	2	1.9	11.2	14.5	26.5	865,733.0	0.00	1.00
11/11/2019 14:00	1	1.8	9.0	14.6	24.4	969,682.9	0.00	1.00
11/11/2019 15:00	2	1.8	9.1	14.6	25.5	975,551.8	0.00	1.00
11/11/2019 16:00	2	2.2	14.5	13.1	38.4	989,321.3	0.00	1.00
11/11/2019 17:00	2	2.4	14.8	13.1	36.2	991,779.3	0.00	1.00
11/11/2019 18:00	2	2.2	14.9	13.1	38.7	997,924.1	0.00	1.00
11/11/2019 19:00	2	2.2	14.7	13.1	36.4	978,085.0	0.00	1.00
11/11/2019 20:00	2	2.0	12.8	14.3	24.7	712,930.6	0.00	1.00
11/11/2019 21:00	2	1.9	11.7	14.3	24.2	753,390.9	0.00	1.00
11/11/2019 22:00	2	1.9	11.2	14.4	24.1	800,797.2	0.00	1.00
11/11/2019 23:00	3	1.8	11.9	14.3	27.9	713,760.6	0.00	1.00
Average/Sum#:	2	1.9	12.1	14.2	28.5	835,369.5	0.00 #	24.00 #
Minimum:	1	1.8	9.0	13.1	23.1	696,931.7	0.00	1.00
Maximum:	3	2.4	14.9	14.6	38.7	997,924.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	1	3.9	19.6	14.8	13.7	615,567.5	0.15	0.42
11/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.9	19.6	14.8	13.7	615,567.5	0.15 #	0.42 #
Minimum:	1	3.9	19.6	14.8	13.7	615,567.5	0.00	0.00
Maximum:	1	3.9	19.6	14.8	13.7	615,567.5	0.15	0.42
%SI	95.83	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2019 06:00	0	23.3	29.5	17.8	0.0	681,619.9	0.27	0.27
11/13/2019 07:00	3	4.6	14.8	14.3	21.1	733,472.0	0.67	1.00
11/13/2019 08:00	2	1.9	12.8	14.4	30.1	780,150.5	0.00	1.00
11/13/2019 09:00	2	1.9	12.4	14.5	28.0	806,676.6	0.00	1.00
11/13/2019 10:00	4	2.0	12.5	14.5	35.8	793,410.3	0.00	1.00
11/13/2019 11:00	0	1.5	12.4	14.5	19.4	795,122.0	0.00	1.00
11/13/2019 12:00	2	1.9	12.5	14.5	27.9	785,921.2	0.00	1.00
11/13/2019 13:00	2	1.8	12.2	14.5	26.9	792,340.4	0.00	1.00
11/13/2019 14:00	2	1.9	11.3	14.4	25.3	815,334.2	0.00	1.00
11/13/2019 15:00	2	1.8	9.7	14.6	25.8	941,642.3	0.00	1.00
11/13/2019 16:00	2	1.8	9.7	14.6	26.1	940,120.7	0.00	1.00
11/13/2019 17:00	2	1.8	9.8	14.5	26.5	920,296.0	0.00	1.00
11/13/2019 18:00	2	1.8	9.9	14.5	27.0	923,933.5	0.00	1.00
11/13/2019 19:00	2	1.9	10.0	14.5	27.6	919,012.1	0.00	1.00
11/13/2019 20:00	2	1.9	10.2	14.5	28.2	916,016.5	0.00	1.00
11/13/2019 21:00	2	1.9	13.2	14.5	25.7	661,389.2	0.00	1.00
11/13/2019 22:00	2	1.9	13.2	14.4	25.6	671,860.7	0.00	1.00
11/13/2019 23:00	2	1.9	13.1	14.4	25.2	649,739.2	0.00	1.00
Average/Sum#:	2	3.2	12.7	14.7	25.1	807,114.3	0.94 #	17.27 #
Minimum:	0	1.5	9.7	14.3	0.0	649,739.2	0.00	0.00
Maximum:	4	23.3	29.5	17.8	35.8	941,642.3	0.67	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	2	1.9	13.4	14.5	25.9	649,406.7	0.00	1.00
11/14/2019 01:00	2	1.8	13.0	14.5	24.5	647,481.0	0.00	1.00
11/14/2019 02:00	2	1.8	13.0	14.5	24.9	647,267.0	0.00	1.00
11/14/2019 03:00	2	1.8	13.1	14.5	25.1	647,481.0	0.00	1.00
11/14/2019 04:00	2	1.8	13.5	14.5	25.2	647,694.9	0.00	1.00
11/14/2019 05:00	2	1.8	13.1	14.5	25.5	660,747.3	0.00	1.00
11/14/2019 06:00	1	1.8	10.1	14.5	25.0	924,575.4	0.00	1.00
11/14/2019 07:00	2	1.9	13.1	14.3	27.2	714,175.6	0.00	1.00
11/14/2019 08:00	2	1.9	11.8	14.3	24.9	764,387.8	0.00	1.00
11/14/2019 09:00	2	1.9	11.5	14.4	24.6	793,634.1	0.00	1.00
11/14/2019 10:00	2	1.9	11.5	14.4	24.7	785,838.9	0.00	1.00
11/14/2019 11:00	2	1.9	11.5	14.4	25.7	805,221.5	0.00	1.00
11/14/2019 12:00	2	1.9	11.7	14.4	26.0	797,847.7	0.00	1.00
11/14/2019 13:00	2	1.9	11.7	14.4	25.8	792,580.7	0.00	1.00
11/14/2019 14:00	2	1.9	11.6	14.4	25.4	788,577.8	0.00	1.00
11/14/2019 15:00	2	1.8	9.6	14.5	25.9	932,492.4	0.00	1.00
11/14/2019 16:00	2	1.8	9.6	14.5	26.2	928,640.9	0.00	1.00
11/14/2019 17:00	2	1.9	9.7	14.5	26.4	916,444.5	0.00	1.00
11/14/2019 18:00	2	1.9	9.8	14.5	27.0	911,523.1	0.00	1.00
11/14/2019 19:00	2	1.9	10.4	14.5	27.6	906,815.7	0.00	1.00
11/14/2019 20:00	2	1.9	11.4	14.5	28.6	890,981.7	0.00	1.00
11/14/2019 21:00	2	1.9	12.2	14.4	22.8	664,697.5	0.00	1.00
11/14/2019 22:00	2	1.9	12.2	14.4	23.9	666,383.0	0.00	1.00
11/14/2019 23:00	2	3.1	15.2	14.6	19.0	639,716.8	0.17	1.00
Average/Sum#:	2	1.9	11.8	14.5	25.3	771,858.9	0.17 #	24.00 #
Minimum:	1	1.8	9.6	14.3	19.0	639,716.8	0.00	1.00
Maximum:	2	3.1	15.2	14.6	28.6	932,492.4	0.17	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 05:00	0	22.8	29.0	17.6	0.0	697,991.5	0.28	0.28
11/21/2019 06:00	2	4.2	13.3	14.5	25.8	932,706.4	0.62	1.00
11/21/2019 07:00	2	1.9	12.2	14.5	34.2	959,666.9	0.00	1.00
11/21/2019 08:00	2	1.8	11.8	14.5	33.6	972,933.2	0.00	1.00
11/21/2019 09:00	2	1.9	12.8	14.4	31.8	803,325.4	0.00	1.00
11/21/2019 10:00	2	1.9	12.3	14.5	28.5	806,248.6	0.00	1.00
11/21/2019 11:00	2	1.9	12.1	14.5	28.1	801,755.2	0.00	1.00
11/21/2019 12:00	2	1.9	12.0	14.5	27.9	803,039.0	0.00	1.00
11/21/2019 13:00	2	1.9	12.0	14.5	27.8	801,541.2	0.00	1.00
11/21/2019 14:00	2	1.9	12.2	14.5	27.9	789,344.8	0.00	1.00
11/21/2019 15:00	2	1.8	10.1	14.5	26.8	909,169.4	0.00	1.00
11/21/2019 16:00	2	1.8	10.2	14.5	28.5	925,859.3	0.00	1.00
11/21/2019 17:00	2	1.8	11.1	14.6	29.8	932,295.4	0.00	1.00
11/21/2019 18:00	2	1.8	11.1	14.6	30.1	925,557.0	0.00	1.00
11/21/2019 19:00	2	1.9	11.3	14.5	30.4	897,828.9	0.00	1.00
11/21/2019 20:00	2	1.8	11.9	14.5	31.8	892,693.5	0.00	1.00
11/21/2019 21:00	2	1.8	11.2	14.6	30.7	947,946.0	0.00	1.00
11/21/2019 22:00	2	1.9	13.2	14.4	27.5	672,282.0	0.00	1.00
11/21/2019 23:00	3	1.9	13.7	14.5	28.6	654,114.1	0.00	1.00
Average/Sum#:	2	3.1	12.8	14.7	27.9	848,752.5	0.90 #	18.28 #
Minimum:	2	1.8	10.1	14.4	0.0	654,114.1	0.00	0.00
Maximum:	3	22.8	29.0	17.6	34.2	972,933.2	0.62	1.00
%SI	25.00	20.83	20.83	20.83	20.83	20.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Const. Value/Limit Tag: > 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	2	1.9	13.5	14.5	27.4	657,965.6	0.00	1.00
11/22/2019 01:00	3	1.9	13.3	14.4	27.4	652,688.7	0.00	1.00
11/22/2019 02:00	3	1.9	13.4	14.4	27.7	652,688.7	0.00	1.00
11/22/2019 03:00	3	1.9	13.4	14.4	27.7	654,163.5	0.00	1.00
11/22/2019 04:00	2	1.8	14.1	14.4	28.6	656,481.0	0.00	1.00
11/22/2019 05:00	3	1.9	13.0	14.3	27.6	677,450.1	0.00	1.00
11/22/2019 06:00	2	1.9	12.1	14.4	28.9	816,176.9	0.00	1.00
11/22/2019 07:00	3	1.9	12.6	14.3	30.0	746,751.3	0.00	1.00
11/22/2019 08:00	2	1.9	12.0	14.4	28.9	806,907.0	0.00	1.00
11/22/2019 09:00	2	1.9	11.9	14.4	29.2	809,856.5	0.00	1.00
11/22/2019 10:00	2	1.9	12.0	14.4	29.0	810,067.2	0.00	1.00
11/22/2019 11:00	2	1.9	12.0	14.5	29.2	824,864.2	0.00	1.00
11/22/2019 12:00	2	1.8	12.3	14.5	30.1	833,637.1	0.00	1.00
11/22/2019 13:00	2	1.8	12.0	14.6	30.7	890,125.8	0.00	1.00
11/22/2019 14:00	2	1.8	11.8	14.6	29.8	895,994.8	0.00	1.00
11/22/2019 15:00	2	1.8	10.1	14.5	30.1	973,789.1	0.00	1.00
11/22/2019 16:00	3	2.3	16.6	12.7	43.9	1,007,194.9	0.00	1.00
11/22/2019 17:00	3	2.4	16.9	12.7	44.7	1,010,034.0	0.00	1.00
11/22/2019 18:00	3	2.4	16.8	12.7	45.2	1,008,029.9	0.00	1.00
11/22/2019 19:00	3	2.4	16.6	12.7	45.4	1,005,190.9	0.00	1.00
11/22/2019 20:00	3	2.3	16.9	12.8	45.7	1,004,751.7	0.00	1.00
11/22/2019 21:00	2	1.9	10.5	14.5	31.2	955,173.5	0.00	1.00
11/22/2019 22:00	2	1.8	10.5	14.5	32.0	940,195.4	0.00	1.00
11/22/2019 23:00	2	2.0	11.2	14.5	30.8	933,562.3	0.07	1.00
Average/Sum#:	2	2.0	13.1	14.1	32.6	842,655.8	0.07 #	24.00 #
Minimum:	2	1.8	10.1	12.7	27.4	652,688.7	0.00	1.00
Maximum:	3	2.4	16.9	14.6	45.7	1,010,034.0	0.07	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 06:00	4	11.3	19.5	15.4	14.7	830,618.1	0.90	0.95
11/26/2019 07:00	3	1.8	14.5	14.4	42.3	864,633.5	0.00	1.00
11/26/2019 08:00	3	1.9	14.1	14.4	40.3	874,114.1	0.00	1.00
11/26/2019 09:00	3	1.9	13.4	14.5	41.0	904,890.0	0.00	1.00
11/26/2019 10:00	3	1.8	12.9	14.5	39.3	910,881.2	0.00	1.00
11/26/2019 11:00	2	1.8	12.7	14.5	38.4	907,671.6	0.00	1.00
11/26/2019 12:00	3	1.9	12.7	14.5	37.7	901,466.4	0.00	1.00
11/26/2019 13:00	2	1.8	12.0	14.5	34.8	917,086.4	0.00	1.00
11/26/2019 14:00	2	1.8	11.7	14.6	35.1	947,511.3	0.00	1.00
11/26/2019 15:00	2	1.9	11.8	14.2	36.2	925,281.2	0.00	1.00
11/26/2019 16:00	3	1.9	12.2	14.2	38.8	987,620.7	0.00	1.00
11/26/2019 17:00	4	2.4	18.1	12.3	54.4	1,000,794.4	0.00	1.00
11/26/2019 18:00	4	2.4	17.5	12.6	51.0	1,000,504.8	0.00	1.00
11/26/2019 19:00	2	2.0	11.2	14.4	33.6	953,962.1	0.00	1.00
11/26/2019 20:00	2	1.8	11.0	14.5	35.1	972,933.2	0.00	1.00
11/26/2019 21:00	2	1.8	10.7	14.5	32.9	954,317.6	0.00	1.00
11/26/2019 22:00	3	1.9	12.5	14.4	31.5	794,055.5	0.00	1.00
11/26/2019 23:00	3	1.9	12.9	14.3	30.1	711,893.2	0.00	1.00
Average/Sum#:	3	2.4	13.4	14.3	37.1	908,902.0	0.90 #	17.95 #
Minimum:	2	1.8	10.7	12.3	14.7	711,893.2	0.00	0.00
Maximum:	4	11.3	19.5	15.4	54.4	1,000,794.4	0.90	1.00
%SI	25.00	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	3	1.9	13.4	14.3	29.5	662,925.9	0.00	1.00
11/27/2019 01:00	3	1.9	13.5	14.4	29.1	642,154.7	0.00	1.00
11/27/2019 02:00	3	1.9	13.4	14.4	28.7	641,522.7	0.00	1.00
11/27/2019 03:00	3	1.9	13.3	14.4	28.6	641,522.7	0.00	1.00
11/27/2019 04:00	2	1.9	13.2	14.4	26.5	656,902.3	0.00	1.00
11/27/2019 05:00	3	1.9	13.5	14.3	31.1	691,351.8	0.00	1.00
11/27/2019 06:00	2	1.9	11.4	14.5	31.2	920,937.9	0.00	1.00
11/27/2019 07:00	2	1.9	12.4	14.3	30.3	774,139.8	0.00	1.00
11/27/2019 08:00	2	1.9	11.8	14.4	29.3	794,476.8	0.00	1.00
11/27/2019 09:00	2	1.9	12.2	14.4	32.5	825,025.5	0.00	1.00
11/27/2019 10:00	2	1.9	12.0	14.5	33.6	888,414.1	0.00	1.00
11/27/2019 11:00	2	1.9	12.4	14.5	34.1	877,715.4	0.00	1.00
11/27/2019 12:00	2	1.9	12.7	14.5	34.4	858,671.9	0.00	1.00
11/27/2019 13:00	3	1.9	12.9	14.5	34.7	843,693.8	0.00	1.00
11/27/2019 14:00	2	1.9	12.5	14.4	31.5	794,898.2	0.00	1.00
11/27/2019 15:00	2	1.9	12.4	14.4	31.0	787,735.0	0.00	1.00
11/27/2019 16:00	2	1.8	12.2	14.5	32.5	862,737.4	0.00	1.00
11/27/2019 17:00	3	2.2	16.1	13.0	46.0	992,399.3	0.00	1.00
11/27/2019 18:00	2	1.9	11.2	14.4	34.3	957,543.7	0.00	1.00
11/27/2019 19:00	2	1.8	11.2	14.5	32.0	920,510.0	0.00	1.00
11/27/2019 20:00	2	1.9	11.5	14.5	32.3	903,606.1	0.00	1.00
11/27/2019 21:00	3	1.9	12.6	14.4	33.9	841,037.3	0.00	1.00
11/27/2019 22:00	3	1.9	12.7	14.3	30.0	744,468.9	0.00	1.00
11/27/2019 23:00	2	1.9	12.7	14.4	26.4	663,854.8	0.00	1.00
Average/Sum#:	2	1.9	12.6	14.4	31.8	799,510.3	0.00 #	24.00 #
Minimum:	2	1.8	11.2	13.0	26.4	641,522.7	0.00	1.00
Maximum:	3	2.2	16.1	14.5	46.0	992,399.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	3	1.9	13.6	14.4	29.5	643,629.5	0.00	1.00
11/28/2019 01:00	3	1.9	13.7	14.4	29.5	642,786.7	0.00	1.00
11/28/2019 02:00	3	1.9	13.7	14.4	29.6	643,208.1	0.00	1.00
11/28/2019 03:00	3	1.9	13.8	14.4	30.3	643,208.1	0.00	1.00
11/28/2019 04:00	2	1.9	13.2	14.4	26.8	657,323.7	0.00	1.00
11/28/2019 05:00	3	1.9	13.6	14.3	31.6	674,752.7	0.00	1.00
11/28/2019 06:00	3	1.9	13.6	14.3	31.1	684,712.2	0.00	1.00
11/28/2019 07:00	3	1.9	13.0	14.3	30.4	710,855.7	0.00	1.00
11/28/2019 08:00	2	1.9	11.9	14.4	29.2	798,479.8	0.00	1.00
11/28/2019 09:00	2	1.9	12.0	14.4	31.5	812,806.0	0.00	1.00
11/28/2019 10:00	3	1.9	12.5	14.4	33.6	835,348.9	0.00	1.00
11/28/2019 11:00	3	1.9	12.4	14.4	32.8	817,651.7	0.00	1.00
11/28/2019 12:00	3	1.9	12.3	14.4	31.5	791,527.3	0.00	1.00
11/28/2019 13:00	3	1.9	12.2	14.4	30.1	754,447.5	0.00	1.00
11/28/2019 14:00	3	1.9	12.9	14.3	30.9	704,631.1	0.00	1.00
11/28/2019 15:00	3	1.9	13.2	14.3	31.1	696,331.6	0.00	1.00
11/28/2019 16:00	3	1.9	13.1	14.4	29.2	661,537.3	0.00	1.00
11/28/2019 17:00	2	1.8	11.8	14.5	33.2	892,479.5	0.00	1.00
11/28/2019 18:00	3	1.9	12.6	14.4	35.1	861,473.3	0.00	1.00
11/28/2019 19:00	3	1.9	13.6	14.4	29.6	648,685.8	0.00	1.00
11/28/2019 20:00	2	1.9	12.2	14.4	31.5	816,598.3	0.00	1.00
11/28/2019 21:00	3	1.9	12.4	14.3	31.1	774,554.7	0.00	1.00
11/28/2019 22:00	3	1.9	13.3	14.3	31.4	704,008.6	0.00	1.00
11/28/2019 23:00	3	1.9	14.1	14.4	31.4	645,104.2	0.00	1.00
Average/Sum#:	3	1.9	12.9	14.4	30.9	729,839.3	0.00 #	24.00 #
Minimum:	2	1.8	11.8	14.3	26.8	642,786.7	0.00	1.00
Maximum:	3	1.9	14.1	14.5	35.1	892,479.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	3	1.9	12.9	14.4	27.0	663,854.8	0.00	1.00
11/29/2019 01:00	3	1.9	13.6	14.4	30.1	650,371.2	0.00	1.00
11/29/2019 02:00	3	1.9	14.1	14.4	31.3	644,472.2	0.00	1.00
11/29/2019 03:00	3	1.9	13.8	14.4	30.3	647,843.1	0.00	1.00
11/29/2019 04:00	3	1.8	14.1	14.4	30.2	652,899.4	0.00	1.00
11/29/2019 05:00	3	1.9	13.6	14.3	30.5	668,528.1	0.00	1.00
11/29/2019 06:00	3	1.9	13.9	14.3	32.1	687,202.1	0.00	1.00
11/29/2019 07:00	3	1.9	13.7	14.3	31.5	693,841.7	0.00	1.00
11/29/2019 08:00	3	1.9	13.0	14.3	30.5	721,022.7	0.00	1.00
11/29/2019 09:00	2	1.9	12.0	14.4	30.4	809,856.5	0.00	1.00
11/29/2019 10:00	2	1.9	12.3	14.4	32.1	816,176.9	0.00	1.00
11/29/2019 11:00	3	1.9	12.5	14.4	31.6	782,046.7	0.00	1.00
11/29/2019 12:00	3	1.9	12.5	14.4	31.4	771,934.0	0.00	1.00
11/29/2019 13:00	3	1.9	12.6	14.4	31.4	764,560.2	0.00	1.00
11/29/2019 14:00	3	1.9	13.0	14.4	32.5	747,073.7	0.00	1.00
11/29/2019 15:00	3	1.9	13.1	14.4	32.1	728,744.5	0.00	1.00
11/29/2019 16:00	3	1.8	13.2	14.5	29.9	693,271.1	0.00	1.00
11/29/2019 17:00	3	2.2	15.4	13.3	46.3	1,013,374.0	0.00	1.00
11/29/2019 18:00	3	2.3	16.0	13.1	48.0	1,007,755.9	0.00	1.00
11/29/2019 19:00	3	2.2	15.5	13.2	46.0	999,146.3	0.00	1.00
11/29/2019 20:00	2	1.9	11.5	14.5	34.6	928,213.0	0.00	1.00
11/29/2019 21:00	3	1.9	12.8	14.4	35.5	850,307.2	0.00	1.00
11/29/2019 22:00	3	1.9	12.6	14.3	30.7	754,843.3	0.00	1.00
11/29/2019 23:00	3	1.9	13.8	14.3	31.8	682,222.3	0.00	1.00
Average/Sum#:	3	1.9	13.4	14.2	33.2	765,815.0	0.00 #	24.00 #
Minimum:	2	1.8	11.5	13.1	27.0	644,472.2	0.00	1.00
Maximum:	3	2.3	16.0	14.5	48.0	1,013,374.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	3	1.9	14.2	14.5	31.7	658,393.6	0.00	1.00
11/30/2019 01:00	3	1.9	14.2	14.5	31.3	658,179.6	0.00	1.00
11/30/2019 02:00	3	1.9	14.4	14.5	32.2	654,970.0	0.00	1.00
11/30/2019 03:00	3	1.8	14.4	14.5	32.1	656,253.8	0.00	1.00
11/30/2019 04:00	3	1.9	15.2	14.5	33.0	660,105.3	0.00	1.00
11/30/2019 05:00	3	1.8	13.6	14.4	29.0	664,276.2	0.00	1.00
11/30/2019 06:00	3	1.9	13.5	14.4	30.0	677,759.7	0.00	1.00
11/30/2019 07:00	3	1.9	13.6	14.3	33.2	715,005.5	0.00	1.00
11/30/2019 08:00	2	1.9	12.4	14.4	31.7	803,957.5	0.00	1.00
11/30/2019 09:00	3	1.9	12.8	14.5	35.6	843,265.9	0.00	1.00
11/30/2019 10:00	3	1.8	13.2	14.5	38.1	867,016.8	0.00	1.00
11/30/2019 11:00	3	1.9	13.3	14.5	37.2	846,047.5	0.00	1.00
11/30/2019 12:00	3	1.9	12.9	14.5	35.0	831,283.4	0.00	1.00
11/30/2019 13:00	3	1.8	12.9	14.5	35.9	849,043.1	0.00	1.00
11/30/2019 14:00	3	1.9	12.9	14.5	35.6	843,051.9	0.00	1.00
11/30/2019 15:00	3	1.9	12.9	14.5	34.4	826,362.0	0.00	1.00
11/30/2019 16:00	3	1.9	12.7	14.4	28.5	695,878.3	0.00	1.00
11/30/2019 17:00	4	2.3	17.1	12.5	53.0	1,003,429.4	0.00	1.00
11/30/2019 18:00	2	1.9	10.9	14.4	34.4	964,706.8	0.00	1.00
11/30/2019 19:00	3	1.9	12.3	14.4	32.8	822,497.4	0.00	1.00
11/30/2019 20:00	2	1.8	10.3	14.5	33.1	962,876.5	0.00	1.00
11/30/2019 21:00	2	1.9	11.4	14.5	33.5	914,518.7	0.00	1.00
11/30/2019 22:00	3	1.9	12.2	14.4	32.0	810,277.9	0.00	1.00
11/30/2019 23:00	3	1.9	12.0	14.3	29.6	756,918.2	0.00	1.00
Average/Sum#:	3	1.9	13.1	14.4	33.9	791,086.5	0.00 #	24.00 #
Minimum:	2	1.8	10.3	12.5	28.5	654,970.0	0.00	1.00
Maximum:	4	2.3	17.1	14.5	53.0	1,003,429.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	3	1.9	12.7	14.3	30.4	707,121.0	0.00	1.00
12/01/2019 01:00	3	1.9	12.9	14.5	28.3	655,611.9	0.00	1.00
12/01/2019 02:00	3	1.9	12.8	14.5	27.9	653,472.2	0.00	1.00
12/01/2019 03:00	3	1.9	12.5	14.5	27.4	653,472.2	0.00	1.00
12/01/2019 04:00	2	1.8	13.0	14.5	27.7	655,184.0	0.00	1.00
12/01/2019 05:00	2	1.9	12.1	14.4	26.1	660,062.6	0.00	1.00
12/01/2019 06:00	3	1.9	12.1	14.4	26.1	660,483.9	0.00	1.00
12/01/2019 07:00	3	1.9	12.7	14.3	29.1	668,735.6	0.00	1.00
12/01/2019 08:00	3	1.9	12.8	14.3	29.2	669,150.6	0.00	1.00
12/01/2019 09:00	3	1.9	12.5	14.3	27.8	667,490.6	0.00	1.00
12/01/2019 10:00	3	1.9	12.4	14.3	30.0	718,325.3	0.00	1.00
12/01/2019 11:00	3	1.9	12.5	14.3	29.8	710,025.8	0.00	1.00
12/01/2019 12:00	3	1.9	12.7	14.3	30.3	701,726.3	0.00	1.00
12/01/2019 13:00	3	1.9	12.5	14.3	29.6	707,328.4	0.00	1.00
12/01/2019 14:00	3	1.9	12.0	14.3	29.7	741,979.0	0.00	1.00
12/01/2019 15:00	2	1.9	11.9	14.4	32.2	853,888.8	0.00	1.00
12/01/2019 16:00	3	1.9	12.2	14.3	28.1	706,706.0	0.00	1.00
12/01/2019 17:00	3	2.2	14.9	13.1	43.0	972,115.7	0.00	1.00
12/01/2019 18:00	4	2.4	17.0	12.5	48.3	994,626.0	0.00	1.00
12/01/2019 19:00	2	2.0	11.0	14.2	33.8	978,423.1	0.00	1.00
12/01/2019 20:00	2	1.9	11.1	14.3	35.1	1,001,132.2	0.00	1.00
12/01/2019 21:00	2	1.9	10.2	14.4	33.1	951,644.6	0.00	1.00
12/01/2019 22:00	3	1.9	12.0	14.3	30.1	769,160.0	0.00	1.00
12/01/2019 23:00	3	1.9	12.3	14.3	29.7	721,230.2	0.00	1.00
Average/Sum#:	3	1.9	12.5	14.2	31.0	757,462.3	0.00 #	24.00 #
Minimum:	2	1.8	10.2	12.5	26.1	653,472.2	0.00	1.00
Maximum:	4	2.4	17.0	14.5	48.3	1,001,132.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	3	1.9	13.0	14.3	30.1	682,429.8	0.00	1.00
12/02/2019 01:00	3	1.9	13.0	14.5	29.2	655,825.9	0.00	1.00
12/02/2019 02:00	3	1.9	12.8	14.5	27.9	654,970.0	0.00	1.00
12/02/2019 03:00	2	1.9	12.1	14.5	25.9	656,253.8	0.00	1.00
12/02/2019 04:00	2	1.8	12.6	14.5	26.4	661,603.2	0.00	1.00
12/02/2019 05:00	3	1.9	12.7	14.3	29.8	684,712.2	0.00	1.00
12/02/2019 06:00	2	1.9	10.9	14.3	33.3	976,441.1	0.00	1.00
12/02/2019 07:00	2	1.9	10.9	14.5	32.2	915,588.6	0.00	1.00
12/02/2019 08:00	2	1.9	11.9	14.4	33.3	855,784.9	0.00	1.00
12/02/2019 09:00	2	1.9	10.0	14.5	31.1	933,776.3	0.00	1.00
12/02/2019 10:00	2	1.9	10.9	14.5	31.4	908,099.5	0.00	1.00
12/02/2019 11:00	2	1.8	11.3	14.5	32.3	900,396.5	0.00	1.00
12/02/2019 12:00	2	1.8	10.9	14.5	30.3	935,488.0	0.00	1.00
12/02/2019 13:00	2	1.9	10.8	14.5	30.2	910,239.3	0.00	1.00
12/02/2019 14:00	2	1.9	10.9	14.5	30.4	903,820.1	0.00	1.00
12/02/2019 15:00	2	1.8	9.6	14.6	30.3	981,855.5	0.00	1.00
12/02/2019 16:00	3	2.2	14.8	13.1	43.7	1,006,526.9	0.00	1.00
12/02/2019 17:00	3	2.3	14.8	13.1	42.8	1,003,717.8	0.00	1.00
12/02/2019 18:00	3	2.3	14.7	13.1	42.9	1,001,611.0	0.00	1.00
12/02/2019 19:00	3	2.2	14.3	13.2	42.3	1,003,058.9	0.00	1.00
12/02/2019 20:00	3	2.2	14.6	13.1	42.3	996,695.2	0.00	1.00
12/02/2019 21:00	2	1.9	10.2	14.4	31.3	935,000.8	0.00	1.00
12/02/2019 22:00	3	1.9	12.3	14.3	29.3	738,451.7	0.00	1.00
12/02/2019 23:00	3	1.9	12.8	14.5	27.4	661,175.2	0.00	1.00
Average/Sum#:	2	2.0	12.2	14.2	32.8	856,813.4	0.00 #	24.00 #
Minimum:	2	1.8	9.6	13.1	25.9	654,970.0	0.00	1.00
Maximum:	3	2.3	14.8	14.6	43.7	1,006,526.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	2	1.9	12.0	14.4	24.7	657,955.7	0.00	1.00
12/03/2019 01:00	3	1.9	13.7	14.5	30.5	650,262.6	0.00	1.00
12/03/2019 02:00	3	1.8	13.9	14.5	30.4	650,262.6	0.00	1.00
12/03/2019 03:00	3	1.9	14.0	14.5	30.9	649,834.7	0.00	1.00
12/03/2019 04:00	3	1.9	14.6	14.5	30.2	650,048.6	0.00	1.00
12/03/2019 05:00	3	1.9	12.6	14.4	26.1	670,175.2	0.00	1.00
12/03/2019 06:00	3	1.9	13.2	14.3	30.3	696,954.0	0.00	1.00
12/03/2019 07:00	2	1.8	10.9	14.5	29.2	911,095.2	0.00	1.00
12/03/2019 08:00	2	1.9	12.2	14.4	33.3	858,734.4	0.00	1.00
12/03/2019 09:00	2	1.8	10.8	14.5	30.8	943,191.0	0.00	1.00
12/03/2019 10:00	2	1.9	11.8	14.4	32.9	882,120.0	0.00	1.00
12/03/2019 11:00	2	1.9	12.3	14.4	32.8	840,826.6	0.00	1.00
12/03/2019 12:00	2	1.9	12.2	14.4	31.3	821,022.6	0.00	1.00
12/03/2019 13:00	2	1.9	11.9	14.4	31.0	822,497.4	0.00	1.00
12/03/2019 14:00	2	1.9	12.0	14.5	34.3	864,021.2	0.00	1.00
12/03/2019 15:00	2	1.8	12.1	14.5	32.1	860,169.7	0.00	1.00
12/03/2019 16:00	2	1.9	10.9	14.5	31.0	907,671.6	0.00	1.00
12/03/2019 17:00	2	2.0	11.7	14.0	35.0	980,031.5	0.00	1.00
12/03/2019 18:00	2	2.0	11.1	14.2	33.0	980,058.2	0.00	1.00
12/03/2019 19:00	2	1.9	11.3	14.3	28.5	772,894.8	0.00	1.00
12/03/2019 20:00	2	2.0	11.6	14.0	35.3	964,352.6	0.00	1.00
12/03/2019 21:00	2	1.9	9.9	14.5	32.7	978,496.5	0.00	1.00
12/03/2019 22:00	2	1.8	9.4	14.5	30.4	966,300.1	0.00	1.00
12/03/2019 23:00	3	1.9	11.8	14.4	34.2	856,206.3	0.00	1.00
Average/Sum#:	2	1.9	12.0	14.4	31.3	826,466.0	0.00 #	24.00 #
Minimum:	2	1.8	9.4	14.0	24.7	649,834.7	0.00	1.00
Maximum:	3	2.0	14.6	14.5	35.3	980,058.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	3	1.9	12.4	14.3	28.2	689,899.4	0.00	1.00
12/04/2019 01:00	2	1.9	12.3	14.5	26.3	656,681.8	0.00	1.00
12/04/2019 02:00	3	1.9	12.3	14.5	26.5	655,825.9	0.00	1.00
12/04/2019 03:00	3	1.9	12.5	14.5	27.6	654,542.1	0.00	1.00
12/04/2019 04:00	3	1.8	12.9	14.5	27.9	663,314.9	0.00	1.00
12/04/2019 05:00	2	1.9	10.9	14.5	30.3	895,475.2	0.00	1.00
12/04/2019 06:00	2	1.9	10.8	14.5	31.3	909,597.4	0.00	1.00
12/04/2019 07:00	3	2.1	12.5	13.6	38.6	994,614.8	0.00	1.00
12/04/2019 08:00	3	2.2	13.9	13.1	42.0	985,634.4	0.00	1.00
12/04/2019 09:00	3	2.2	13.8	13.2	41.4	992,388.1	0.00	1.00
12/04/2019 10:00	2	1.9	9.8	14.4	29.8	916,882.3	0.00	1.00
12/04/2019 11:00	2	1.9	9.7	14.5	29.8	917,942.3	0.00	1.00
12/04/2019 12:00	2	1.9	9.8	14.5	30.0	909,169.4	0.00	1.00
12/04/2019 13:00	2	1.9	9.9	14.5	30.0	903,820.1	0.00	1.00
12/04/2019 14:00	2	1.8	9.7	14.5	29.5	921,579.8	0.00	1.00
12/04/2019 15:00	2	1.9	9.7	14.5	30.0	926,287.2	0.00	1.00
12/04/2019 16:00	3	2.2	14.3	13.1	43.5	998,626.4	0.00	1.00
12/04/2019 17:00	3	2.3	14.7	12.9	43.9	985,643.2	0.00	1.00
12/04/2019 18:00	3	2.3	14.6	13.0	44.0	997,946.4	0.00	1.00
12/04/2019 19:00	3	2.3	14.6	13.0	43.8	985,638.9	0.00	1.00
12/04/2019 20:00	3	2.3	14.3	13.0	42.7	976,624.9	0.00	1.00
12/04/2019 21:00	3	2.1	11.4	13.8	35.2	965,926.4	0.00	1.00
12/04/2019 22:00	2	1.9	9.5	14.5	29.8	938,483.6	0.00	1.00
12/04/2019 23:00	3	1.9	12.0	14.3	27.1	701,311.3	0.03	1.00
Average/Sum#:	3	2.0	12.0	14.0	33.7	880,994.0	0.03 #	24.00 #
Minimum:	2	1.8	9.5	12.9	26.3	654,542.1	0.00	1.00
Maximum:	3	2.3	14.7	14.5	44.0	998,626.4	0.03	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	0	11.5	36.8	16.0	0.0	455,263.7	0.12	0.12
12/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	11.5	36.8	16.0	0.0	455,263.7	0.12 #	0.12 #
Minimum:	0	11.5	36.8	16.0	0.0	455,263.7	0.00	0.00
Maximum:	0	11.5	36.8	16.0	0.0	455,263.7	0.12	0.12
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/21/2019 05:00	0	23.7	28.7	17.8	0.0	682,945.2	0.28	0.28
10/21/2019 06:00	1	6.1	18.0	14.5	30.2	897,400.9	0.57	1.00
10/21/2019 07:00	2	1.9	17.9	14.5	39.5	903,606.1	0.00	1.00
10/21/2019 08:00	1	1.8	16.6	14.6	32.8	885,561.1	0.00	1.00
10/21/2019 09:00	2	2.2	20.8	12.9	45.9	937,371.0	0.00	1.00
10/21/2019 10:00	1	2.0	16.9	14.0	35.6	894,889.1	0.00	1.00
10/21/2019 11:00	2	2.1	18.3	13.4	40.3	919,340.2	0.00	1.00
10/21/2019 12:00	2	2.3	20.4	12.8	45.1	931,039.5	0.00	1.00
10/21/2019 13:00	2	2.4	20.6	12.7	45.0	918,349.4	0.00	1.00
10/21/2019 14:00	2	2.4	20.4	12.7	44.9	910,166.2	0.00	1.00
10/21/2019 15:00	2	2.2	18.0	13.3	38.0	899,315.4	0.00	1.00
10/21/2019 16:00	2	2.2	18.6	13.2	41.3	918,937.1	0.00	1.00
10/21/2019 17:00	3	2.5	21.6	12.2	51.8	938,764.0	0.00	1.00
10/21/2019 18:00	2	2.2	19.5	13.1	41.8	922,079.1	0.00	1.00
10/21/2019 19:00	1	1.9	15.0	14.5	30.9	887,772.2	0.00	1.00
10/21/2019 20:00	1	1.8	14.3	14.5	28.7	854,178.5	0.00	1.00
10/21/2019 21:00	1	1.9	14.0	14.5	26.4	812,025.9	0.00	1.00
10/21/2019 22:00	1	1.9	15.5	14.3	24.6	654,418.9	0.00	1.00
10/21/2019 23:00	2	1.9	15.9	14.4	26.6	642,576.1	0.00	1.00
Average/Sum#:	2	3.4	18.5	13.9	35.2	863,722.9	0.85 #	18.28 #
Minimum:	1	1.8	14.0	12.2	0.0	642,576.1	0.00	0.00
Maximum:	3	23.7	28.7	17.8	51.8	938,764.0	0.57	1.00
%SI	25.00	20.83	20.83	20.83	20.83	20.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2019 00:00	2	1.9	15.8	14.4	26.1	641,312.0	0.00	1.00
10/22/2019 01:00	2	1.9	15.8	14.4	25.9	630,567.3	0.00	1.00
10/22/2019 02:00	2	1.9	15.6	14.4	25.9	629,724.5	0.00	1.00
10/22/2019 03:00	2	1.9	15.5	14.4	26.2	631,199.3	0.00	1.00
10/22/2019 04:00	1	1.8	16.2	14.4	26.7	656,902.3	0.00	1.00
10/22/2019 05:00	1	1.9	14.5	14.4	24.5	718,631.8	0.00	1.00
10/22/2019 06:00	1	1.9	14.3	14.4	26.2	736,118.3	0.00	1.00
10/22/2019 07:00	1	1.9	15.6	14.3	30.2	768,537.6	0.00	1.00
10/22/2019 08:00	2	2.1	20.3	13.1	46.6	920,499.0	0.00	1.00
10/22/2019 09:00	1	1.9	15.7	14.5	25.4	669,306.2	0.00	1.00
10/22/2019 10:00	2	2.1	20.2	13.1	47.5	921,728.0	0.00	1.00
10/22/2019 11:00	3	2.2	21.3	12.8	48.9	919,543.1	0.00	1.00
10/22/2019 12:00	2	2.1	17.8	13.4	33.3	725,429.7	0.00	1.00
10/22/2019 13:00	2	2.0	18.2	13.2	42.6	908,799.8	0.00	1.00
10/22/2019 14:00	2	2.2	19.6	12.8	43.8	925,460.4	0.00	1.00
10/22/2019 15:00	2	2.0	17.0	13.6	37.8	919,015.1	0.00	1.00
10/22/2019 16:00	2	2.0	16.3	13.8	36.0	912,499.5	0.00	1.00
10/22/2019 17:00	2	2.0	17.8	13.3	40.6	923,460.5	0.00	1.00
10/22/2019 18:00	2	2.1	17.0	13.5	37.4	913,813.2	0.00	1.00
10/22/2019 19:00	2	2.1	16.5	13.7	36.1	911,047.6	0.00	1.00
10/22/2019 20:00	1	1.9	13.8	14.4	26.7	822,076.0	0.00	1.00
10/22/2019 21:00	1	1.9	13.6	14.4	26.9	811,120.6	0.00	1.00
10/22/2019 22:00	1	1.9	13.8	14.5	27.2	823,366.4	0.00	1.00
10/22/2019 23:00	1	1.9	15.5	14.3	25.1	651,099.0	0.00	1.00
Average/Sum#:	2	2.0	16.6	13.9	33.1	795,469.1	0.00 #	24.00 #
Minimum:	1	1.8	13.6	12.8	24.5	629,724.5	0.00	1.00
Maximum:	3	2.2	21.3	14.5	48.9	925,460.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2019 00:00	2	1.9	15.8	14.4	26.1	641,101.3	0.00	1.00
10/23/2019 01:00	2	1.9	15.7	14.4	25.7	628,671.1	0.00	1.00
10/23/2019 02:00	2	1.9	15.6	14.4	25.6	628,671.1	0.00	1.00
10/23/2019 03:00	2	1.9	15.7	14.4	25.8	630,356.6	0.00	1.00
10/23/2019 04:00	1	1.9	16.4	14.3	26.1	652,551.5	0.00	1.00
10/23/2019 05:00	1	1.9	16.1	14.3	26.3	659,191.1	0.00	1.00
10/23/2019 06:00	1	1.9	13.8	14.4	24.0	744,545.5	0.00	1.00
10/23/2019 07:00	2	1.9	17.5	13.8	40.6	911,149.4	0.00	1.00
10/23/2019 08:00	2	2.3	21.2	12.8	48.7	937,464.0	0.00	1.00
10/23/2019 09:00	2	2.3	20.7	13.1	45.1	926,117.1	0.00	1.00
10/23/2019 10:00	2	2.3	21.2	12.9	46.2	916,829.6	0.00	1.00
10/23/2019 11:00	2	2.3	20.3	13.2	43.2	907,910.6	0.00	1.00
10/23/2019 12:00	1	2.1	17.0	13.6	35.2	898,567.5	0.00	1.00
10/23/2019 13:00	1	2.0	15.3	14.2	33.6	897,279.6	0.00	1.00
10/23/2019 14:00	1	1.9	15.1	14.2	32.9	871,117.4	0.00	1.00
10/23/2019 15:00	2	2.1	16.4	13.8	36.1	909,413.5	0.00	1.00
10/23/2019 16:00	2	2.0	16.1	14.0	37.1	912,155.7	0.00	1.00
10/23/2019 17:00	2	2.3	20.1	12.8	44.9	931,546.7	0.00	1.00
10/23/2019 18:00	2	2.1	17.3	13.7	37.8	912,759.4	0.00	1.00
10/23/2019 19:00	1	1.9	14.4	14.5	29.7	865,947.0	0.00	1.00
10/23/2019 20:00	1	1.9	14.2	14.5	28.4	830,427.5	0.00	1.00
10/23/2019 21:00	2	1.9	16.5	14.1	38.3	901,403.5	0.00	1.00
10/23/2019 22:00	1	1.9	13.8	14.4	23.7	755,500.9	0.00	1.00
10/23/2019 23:00	1	1.9	14.4	14.3	23.6	687,409.5	0.00	1.00
Average/Sum#:	2	2.0	16.7	13.9	33.5	814,920.3	0.00 #	24.00 #
Minimum:	1	1.9	13.8	12.8	23.6	628,671.1	0.00	1.00
Maximum:	2	2.3	21.2	14.5	48.7	937,464.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2019 00:00	2	1.9	16.2	14.3	27.1	655,456.3	0.00	1.00
10/24/2019 01:00	1	1.9	16.4	14.3	26.9	654,833.8	0.00	1.00
10/24/2019 02:00	2	1.9	16.5	14.3	27.1	657,531.2	0.00	1.00
10/24/2019 03:00	2	1.9	16.5	14.3	27.5	657,531.2	0.00	1.00
10/24/2019 04:00	1	2.0	14.1	14.4	23.6	762,032.0	0.00	1.00
10/24/2019 05:00	2	2.0	18.8	13.7	46.5	931,208.6	0.00	1.00
10/24/2019 06:00	2	2.1	19.8	13.5	44.3	936,020.1	0.00	1.00
10/24/2019 07:00	1	1.9	16.9	14.6	38.6	917,949.1	0.00	1.00
10/24/2019 08:00	1	1.8	15.2	14.5	28.5	802,611.1	0.00	1.00
10/24/2019 09:00	1	1.9	14.6	14.5	24.7	708,891.1	0.00	1.00
10/24/2019 10:00	1	1.9	14.5	14.3	22.5	669,773.0	0.00	1.00
10/24/2019 11:00	1	1.9	14.3	14.3	22.7	672,055.4	0.00	1.00
10/24/2019 12:00	1	1.9	14.1	14.4	22.8	684,080.1	0.00	1.00
10/24/2019 13:00	1	1.9	14.0	14.4	22.6	684,080.1	0.00	1.00
10/24/2019 14:00	1	1.9	14.5	14.5	22.8	629,507.3	0.00	1.00
10/24/2019 15:00	1	1.9	15.1	14.3	24.6	644,666.9	0.00	1.00
10/24/2019 16:00	1	1.9	13.8	14.6	29.4	876,649.0	0.00	1.00
10/24/2019 17:00	2	2.0	16.7	13.8	36.6	916,550.0	0.00	1.00
10/24/2019 18:00	1	2.5	15.3	14.5	24.7	816,519.3	0.17	1.00
10/24/2019 19:00	0	19.7	36.1	16.6	0.0	443,629.8	0.07	0.07
10/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.8	16.7	14.4	27.2	736,078.8	0.24 #	19.07 #
Minimum:	1	1.8	13.8	13.5	0.0	443,629.8	0.00	0.00
Maximum:	2	19.7	36.1	16.6	46.5	936,020.1	0.17	1.00
%SI	20.83	16.67	16.67	16.67	16.67	16.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 13:00	0	27.2	32.3	17.7	0.0	631,647.0	0.28	0.28
10/25/2019 14:00	1	5.4	16.3	14.4	20.0	685,133.6	0.57	1.00
10/25/2019 15:00	1	1.9	15.9	14.3	25.0	649,854.1	0.00	1.00
10/25/2019 16:00	1	1.9	14.5	14.6	28.9	863,606.8	0.00	1.00
10/25/2019 17:00	1	1.8	15.9	14.6	34.1	903,602.7	0.00	1.00
10/25/2019 18:00	1	3.3	18.4	14.6	20.0	656,019.5	0.17	1.00
10/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	6.9	18.9	15.0	21.3	731,644.0	1.02 #	5.28 #
Minimum:	1	1.8	14.5	14.3	0.0	631,647.0	0.00	0.00
Maximum:	1	27.2	32.3	17.7	34.1	903,602.7	0.57	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 03:00	0	18.4	21.9	18.7	0.0	654,833.8	0.27	0.27
10/29/2019 04:00	0	24.0	23.3	18.3	0.0	590,959.3	0.43	0.43
10/29/2019 05:00	0	12.2	14.3	19.3	0.0	558,896.3	0.15	0.15
10/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 09:00	0	13.7	15.8	19.2	0.0	575,963.8	0.15	0.15
10/29/2019 10:00	0	0.0	0.0	21.0	0.0	0.0	0.02	0.02
10/29/2019 11:00	0	0.0	15.3	0.0	0.0	47,962.6	0.13	0.13
10/29/2019 12:00	0	0.0	6.8	0.0	0.0	26,536.7	0.07	0.07
10/29/2019 13:00	0	0.0	15.6	0.0	0.0	38,789.4	0.15	0.15
10/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	13.7	14.1	19.3	0.0	476,130.6	1.37 #	1.37 #
Minimum:	0	0.0	0.0	18.3	0.0	0.0	0.00	0.00
Maximum:	0	24.0	23.3	21.0	0.0	654,833.8	0.43	0.43
%SI	100.00	79.17	66.67	79.17	66.67	79.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 07:00	0	0.0	25.4	0.0	0.0	164,920.6	0.63	0.63
10/30/2019 08:00	0	0.0	19.0	0.0	29.8	200,499.5	0.85	1.00
10/30/2019 09:00	2	1.9	17.3	14.5	26.0	635,926.4	0.00	1.00
10/30/2019 10:00	1	1.9	17.4	14.6	28.2	643,629.5	0.00	1.00
10/30/2019 11:00	2	3.4	21.1	14.8	24.2	628,363.7	0.15	0.92
10/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.4	20.0	14.6	21.6	635,973.2	1.63 #	4.55 #
Minimum:	1	1.9	17.3	14.5	0.0	628,363.7	0.00	0.00
Maximum:	2	3.4	25.4	14.8	29.8	643,629.5	0.85	1.00
%SI	87.50	87.50	79.17	87.50	79.17	87.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2019 13:00	0	27.1	32.4	17.6	0.0	677,242.6	0.27	0.27
11/05/2019 14:00	1	5.4	16.2	14.5	18.9	738,205.3	0.60	1.00
11/05/2019 15:00	1	1.8	17.0	14.5	37.2	892,693.5	0.00	1.00
11/05/2019 16:00	1	2.1	18.3	13.8	38.0	860,230.0	0.00	1.00
11/05/2019 17:00	1	1.8	16.2	14.5	34.7	912,379.0	0.00	1.00
11/05/2019 18:00	1	1.8	15.9	14.5	34.3	912,165.0	0.00	1.00
11/05/2019 19:00	1	1.9	14.6	14.5	29.3	870,440.4	0.00	1.00
11/05/2019 20:00	1	1.8	14.7	14.4	28.3	831,767.3	0.00	1.00
11/05/2019 21:00	2	1.9	16.3	14.3	27.0	652,136.5	0.00	1.00
11/05/2019 22:00	1	1.9	16.7	14.3	27.5	655,248.8	0.00	1.00
11/05/2019 23:00	1	1.9	16.3	14.4	26.4	676,074.3	0.00	1.00
Average/Sum#:	1	4.5	17.7	14.7	27.4	788,962.1	0.87 #	10.27 #
Minimum:	1	1.8	14.6	13.8	0.0	652,136.5	0.00	0.00
Maximum:	2	27.1	32.4	17.6	38.0	912,379.0	0.60	1.00
%SI	58.33	54.17	54.17	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2019 00:00	1	1.9	15.4	14.4	25.2	696,088.9	0.00	1.00
11/06/2019 01:00	1	1.9	15.2	14.4	25.5	703,673.5	0.00	1.00
11/06/2019 02:00	1	1.9	15.1	14.4	25.7	711,468.6	0.00	1.00
11/06/2019 03:00	1	1.9	14.8	14.4	25.8	719,685.2	0.00	1.00
11/06/2019 04:00	1	1.8	15.1	14.4	26.1	727,269.7	0.00	1.00
11/06/2019 05:00	1	1.9	14.7	14.4	25.9	732,115.3	0.00	1.00
11/06/2019 06:00	1	1.9	14.3	14.4	27.9	786,892.3	0.00	1.00
11/06/2019 07:00	1	1.9	14.3	14.4	27.8	790,052.5	0.00	1.00
11/06/2019 08:00	1	1.9	14.7	14.4	25.7	721,581.3	0.00	1.00
11/06/2019 09:00	1	1.9	14.1	14.5	26.7	776,934.4	0.00	1.00
11/06/2019 10:00	1	1.8	14.3	14.5	27.8	785,707.2	0.00	1.00
11/06/2019 11:00	1	1.9	13.5	14.4	23.9	760,557.2	0.00	1.00
11/06/2019 12:00	1	1.9	13.7	14.5	27.5	823,794.4	0.00	1.00
11/06/2019 13:00	1	1.8	13.8	14.5	27.8	844,335.7	0.00	1.00
11/06/2019 14:00	1	1.8	14.3	14.6	31.9	907,298.0	0.00	1.00
11/06/2019 15:00	1	2.0	16.7	13.8	36.7	928,894.1	0.00	1.00
11/06/2019 16:00	2	2.1	17.1	13.7	38.2	937,865.5	0.00	1.00
11/06/2019 17:00	2	2.4	20.6	12.5	47.2	955,336.5	0.00	1.00
11/06/2019 18:00	3	2.5	21.1	12.4	49.6	956,502.7	0.00	1.00
11/06/2019 19:00	2	2.4	20.7	12.6	47.7	954,472.3	0.00	1.00
11/06/2019 20:00	2	2.4	21.0	12.5	48.5	954,032.3	0.00	1.00
11/06/2019 21:00	2	2.2	18.7	13.3	41.8	927,064.3	0.00	1.00
11/06/2019 22:00	1	1.9	14.1	14.4	24.6	756,554.3	0.00	1.00
11/06/2019 23:00	1	3.0	17.9	14.5	21.6	634,856.6	0.13	1.00
Average/Sum#:	1	2.0	16.1	14.0	31.5	812,209.7	0.13 #	24.00 #
Minimum:	1	1.8	13.5	12.4	21.6	634,856.6	0.00	1.00
Maximum:	3	3.0	21.1	14.6	49.6	956,502.7	0.13	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2019 00:00	0	15.7	30.6	17.2	0.0	450,059.5	0.02	0.02
11/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 10:00	0	22.1	28.6	17.5	0.0	665,379.1	0.28	0.28
11/07/2019 11:00	1	5.2	17.0	14.4	22.6	683,869.5	0.53	1.00
11/07/2019 12:00	2	1.9	16.8	14.5	28.1	649,192.7	0.00	1.00
11/07/2019 13:00	1	1.8	16.5	14.6	26.9	651,237.4	0.00	1.00
11/07/2019 14:00	1	1.8	16.2	14.5	26.8	646,197.1	0.00	1.00
11/07/2019 15:00	1	1.9	15.5	14.5	24.7	680,860.7	0.00	1.00
11/07/2019 16:00	1	1.8	14.3	14.6	30.0	893,386.4	0.00	1.00
11/07/2019 17:00	1	1.8	15.4	14.5	33.8	916,016.5	0.00	1.00
11/07/2019 18:00	1	1.9	15.7	14.3	35.9	915,854.4	0.00	1.00
11/07/2019 19:00	1	1.9	14.5	14.3	30.5	852,362.9	0.00	1.00
11/07/2019 20:00	1	1.9	13.2	14.4	23.1	754,236.8	0.00	1.00
11/07/2019 21:00	1	7.6	25.5	15.1	10.5	600,894.0	0.15	0.25
11/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	5.2	18.4	15.0	22.5	719,965.2	0.98 #	10.55 #
Minimum:	1	1.8	13.2	14.3	0.0	450,059.5	0.00	0.00
Maximum:	2	22.1	30.6	17.5	35.9	916,016.5	0.53	1.00
%SI	54.17	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2019 09:00	0	23.2	28.4	17.5	0.0	685,115.0	0.28	0.28
11/08/2019 10:00	1	5.5	17.5	14.4	22.5	687,029.7	0.55	1.00
11/08/2019 11:00	2	1.9	17.0	14.5	28.5	646,197.1	0.00	1.00
11/08/2019 12:00	1	1.8	16.7	14.5	27.0	664,384.8	0.00	1.00
11/08/2019 13:00	1	1.9	15.3	14.4	23.9	683,026.7	0.00	1.00
11/08/2019 14:00	1	1.9	14.2	14.4	23.3	708,097.7	0.00	1.00
11/08/2019 15:00	1	1.9	15.3	14.4	33.7	898,974.4	0.00	1.00
11/08/2019 16:00	1	1.9	16.0	14.3	36.5	915,646.9	0.00	1.00
11/08/2019 17:00	2	2.2	19.8	12.9	43.2	948,839.9	0.00	1.00
11/08/2019 18:00	2	2.4	20.6	12.7	47.1	958,263.1	0.00	1.00
11/08/2019 19:00	2	2.3	20.2	12.9	45.1	942,848.7	0.00	1.00
11/08/2019 20:00	1	1.9	14.6	14.4	23.4	650,371.2	0.00	1.00
11/08/2019 21:00	2	1.9	15.9	14.3	26.7	650,476.6	0.00	1.00
11/08/2019 22:00	2	2.0	17.0	14.3	29.3	653,381.4	0.00	1.00
11/08/2019 23:00	2	1.9	20.3	14.5	30.7	614,529.2	0.08	1.00
Average/Sum#:	2	3.6	17.9	14.3	29.4	753,812.2	0.91 #	14.28 #
Minimum:	1	1.8	14.2	12.7	0.0	614,529.2	0.00	0.00
Maximum:	2	23.2	28.4	17.5	47.1	958,263.1	0.55	1.00
%SI	41.67	37.50	37.50	37.50	37.50	37.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2019 00:00	0	13.1	36.9	16.6	0.0	397,770.0	0.08	0.08
11/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	13.1	36.9	16.6	0.0	397,770.0	0.08 #	0.08 #
Minimum:	0	13.1	36.9	16.6	0.0	397,770.0	0.00	0.00
Maximum:	0	13.1	36.9	16.6	0.0	397,770.0	0.08	0.08
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2019 23:00	0	18.6	25.0	16.0	0.0	646,983.2	0.52	0.52
Average/Sum#:	0	18.6	25.0	16.0	0.0	646,983.2	0.52 #	0.52 #
Minimum:	0	18.6	25.0	16.0	0.0	646,983.2	0.00	0.00
Maximum:	0	18.6	25.0	16.0	0.0	646,983.2	0.52	0.52
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2019 00:00	1	3.4	16.5	14.4	25.4	680,498.6	0.38	1.00
11/12/2019 01:00	1	1.9	17.0	14.3	26.9	672,470.4	0.00	1.00
11/12/2019 02:00	1	1.9	17.2	14.3	28.6	651,929.0	0.00	1.00
11/12/2019 03:00	1	1.9	16.6	14.4	26.5	659,641.2	0.00	1.00
11/12/2019 04:00	1	1.9	15.1	14.3	24.5	714,175.6	0.00	1.00
11/12/2019 05:00	1	1.9	15.2	14.4	30.6	835,770.2	0.00	1.00
11/12/2019 06:00	2	2.0	18.7	13.7	42.6	950,989.2	0.00	1.00
11/12/2019 07:00	2	2.0	17.8	13.9	39.5	920,057.6	0.00	1.00
11/12/2019 08:00	1	1.9	15.5	14.3	24.8	699,651.4	0.00	1.00
11/12/2019 09:00	1	1.9	14.1	14.5	28.1	805,178.7	0.00	1.00
11/12/2019 10:00	1	1.8	14.7	14.6	30.8	850,782.1	0.00	1.00
11/12/2019 11:00	1	1.9	14.0	14.5	25.9	772,868.9	0.00	1.00
11/12/2019 12:00	1	1.8	14.3	14.6	31.2	901,429.0	0.00	1.00
11/12/2019 13:00	1	1.9	13.7	14.5	26.7	827,217.9	0.00	1.00
11/12/2019 14:00	1	1.9	13.7	14.5	27.1	826,790.0	0.00	1.00
11/12/2019 15:00	1	1.9	13.7	14.5	27.5	833,637.1	0.00	1.00
11/12/2019 16:00	2	1.9	15.9	14.1	37.0	927,986.4	0.00	1.00
11/12/2019 17:00	2	2.0	16.3	13.9	38.2	927,491.6	0.00	1.00
11/12/2019 18:00	2	2.2	18.7	13.2	42.2	948,637.6	0.00	1.00
11/12/2019 19:00	2	2.2	19.0	13.1	42.9	940,864.8	0.00	1.00
11/12/2019 20:00	1	1.9	14.2	14.3	22.7	738,036.7	0.00	1.00
11/12/2019 21:00	1	1.8	14.2	14.5	32.4	895,475.2	0.00	1.00
11/12/2019 22:00	1	1.9	14.3	14.5	32.0	890,339.8	0.00	1.00
11/12/2019 23:00	1	1.9	13.5	14.3	24.0	758,163.1	0.00	1.00
Average/Sum#:	1	2.0	15.6	14.2	30.8	817,920.1	0.38 #	24.00 #
Minimum:	1	1.8	13.5	13.1	22.7	651,929.0	0.00	1.00
Maximum:	2	3.4	19.0	14.6	42.9	950,989.2	0.38	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2019 00:00	2	2.0	16.9	13.8	40.6	926,386.7	0.00	1.00
11/13/2019 01:00	2	2.0	16.5	14.1	38.5	932,819.7	0.00	1.00
11/13/2019 02:00	2	1.9	16.0	14.3	37.7	902,575.2	0.00	1.00
11/13/2019 03:00	2	1.9	15.9	14.3	37.5	910,044.7	0.00	1.00
11/13/2019 04:00	2	2.0	17.5	14.0	40.3	946,093.6	0.00	1.00
11/13/2019 05:00	2	2.2	20.4	13.1	46.8	963,513.0	0.00	1.00
11/13/2019 06:00	2	2.3	20.7	13.1	46.7	953,154.5	0.00	1.00
11/13/2019 07:00	1	1.9	16.0	14.3	26.2	735,131.9	0.00	1.00
11/13/2019 08:00	1	1.9	13.9	14.4	25.2	758,871.8	0.00	1.00
11/13/2019 09:00	1	1.9	14.1	14.5	27.8	798,759.6	0.00	1.00
11/13/2019 10:00	1	1.8	14.2	14.5	28.3	800,899.3	0.00	1.00
11/13/2019 11:00	1	1.8	14.6	14.6	30.2	830,784.1	0.00	1.00
11/13/2019 12:00	1	1.8	14.6	14.6	30.6	837,957.3	0.00	1.00
11/13/2019 13:00	1	1.8	14.6	14.6	30.5	861,215.8	0.00	1.00
11/13/2019 14:00	1	1.9	14.2	14.6	32.0	905,341.7	0.00	1.00
11/13/2019 15:00	1	1.8	15.2	14.5	34.3	908,527.5	0.00	1.00
11/13/2019 16:00	1	1.8	15.2	14.5	34.7	911,309.1	0.00	1.00
11/13/2019 17:00	1	1.8	15.3	14.5	35.0	913,876.8	0.00	1.00
11/13/2019 18:00	1	1.8	15.4	14.5	35.3	917,514.3	0.00	1.00
11/13/2019 19:00	1	1.8	15.2	14.5	34.7	917,728.3	0.00	1.00
11/13/2019 20:00	1	1.8	15.2	14.5	34.2	910,453.2	0.00	1.00
11/13/2019 21:00	1	1.8	15.5	14.5	23.2	641,917.7	0.00	1.00
11/13/2019 22:00	1	1.9	15.7	14.4	25.8	652,688.7	0.00	1.00
11/13/2019 23:00	2	1.9	17.2	14.4	28.9	624,036.2	0.00	1.00
Average/Sum#:	1	1.9	15.8	14.3	33.5	852,566.7	0.00 #	24.00 #
Minimum:	1	1.8	13.9	13.1	23.2	624,036.2	0.00	1.00
Maximum:	2	2.3	20.7	14.6	46.8	963,513.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2019 00:00	2	1.9	17.6	14.5	29.6	614,743.2	0.00	1.00
11/14/2019 01:00	2	1.8	17.5	14.6	29.0	624,501.0	0.00	1.00
11/14/2019 02:00	2	1.8	17.6	14.5	29.1	614,957.1	0.00	1.00
11/14/2019 03:00	2	1.8	17.8	14.5	30.2	614,957.1	0.00	1.00
11/14/2019 04:00	2	1.8	18.5	14.5	30.2	615,385.1	0.00	1.00
11/14/2019 05:00	2	1.8	17.9	14.5	29.3	628,223.4	0.00	1.00
11/14/2019 06:00	1	1.9	14.2	14.5	29.0	896,545.0	0.00	1.00
11/14/2019 07:00	1	1.9	14.3	14.3	22.9	711,270.7	0.00	1.00
11/14/2019 08:00	1	1.9	13.4	14.4	25.6	788,156.4	0.00	1.00
11/14/2019 09:00	1	1.9	13.8	14.4	27.9	821,233.3	0.00	1.00
11/14/2019 10:00	1	1.9	13.9	14.4	28.3	832,820.7	0.00	1.00
11/14/2019 11:00	1	1.9	13.9	14.5	30.2	883,492.7	0.00	1.00
11/14/2019 12:00	1	1.8	14.0	14.5	30.6	889,056.0	0.00	1.00
11/14/2019 13:00	1	1.8	14.1	14.5	31.3	897,828.9	0.00	1.00
11/14/2019 14:00	1	1.8	14.3	14.6	32.1	919,905.4	0.00	1.00
11/14/2019 15:00	1	1.8	15.3	14.5	35.2	919,226.1	0.00	1.00
11/14/2019 16:00	1	1.8	14.9	14.5	33.7	918,156.3	0.00	1.00
11/14/2019 17:00	1	1.8	15.2	14.5	34.9	921,793.8	0.00	1.00
11/14/2019 18:00	1	1.9	15.3	14.5	35.2	924,361.5	0.00	1.00
11/14/2019 19:00	1	1.9	15.4	14.5	35.5	925,859.3	0.00	1.00
11/14/2019 20:00	1	1.8	15.3	14.5	34.2	914,732.7	0.00	1.00
11/14/2019 21:00	1	1.9	14.4	14.4	21.9	650,581.9	0.00	1.00
11/14/2019 22:00	1	1.9	14.7	14.4	23.7	652,899.4	0.00	1.00
11/14/2019 23:00	1	1.9	14.7	14.4	23.9	633,516.8	0.00	1.00
Average/Sum#:	1	1.9	15.3	14.5	29.7	783,925.2	0.00 #	24.00 #
Minimum:	1	1.8	13.4	14.3	21.9	614,743.2	0.00	1.00
Maximum:	2	1.9	18.5	14.6	35.5	925,859.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2019 00:00	1	6.8	25.2	15.1	10.7	560,283.5	0.17	0.28
11/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	6.8	25.2	15.1	10.7	560,283.5	0.17 #	0.28 #
Minimum:	1	6.8	25.2	15.1	10.7	560,283.5	0.00	0.00
Maximum:	1	6.8	25.2	15.1	10.7	560,283.5	0.17	0.28
%SI	95.83	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 03:00	0	25.0	30.8	17.7	0.0	684,712.2	0.27	0.27
11/20/2019 04:00	1	6.2	17.4	14.5	24.4	873,436.0	0.63	1.00
11/20/2019 05:00	1	1.9	16.8	14.5	35.3	882,636.8	0.00	1.00
11/20/2019 06:00	2	1.7	15.7	14.4	28.1	748,759.1	0.00	1.00
11/20/2019 07:00	2	4.5	34.4	15.3	4.7	530,407.4	0.15	0.17
11/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	7.9	23.0	15.3	18.5	743,990.3	1.05 #	3.44 #
Minimum:	1	1.7	15.7	14.4	0.0	530,407.4	0.00	0.00
Maximum:	2	25.0	34.4	17.7	35.3	882,636.8	0.63	1.00
%SI	83.33	79.17	79.17	79.17	79.17	79.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2019 06:00	0	25.1	30.6	17.9	0.0	692,472.3	0.25	0.25
11/21/2019 07:00	1	6.4	18.3	14.5	27.1	881,566.9	0.57	1.00
11/21/2019 08:00	1	1.8	17.9	14.5	38.0	921,151.9	0.00	1.00
11/21/2019 09:00	1	1.9	15.2	14.4	25.8	765,824.3	0.00	1.00
11/21/2019 10:00	1	1.9	14.7	14.5	27.0	779,502.0	0.00	1.00
11/21/2019 11:00	1	1.8	14.6	14.5	27.3	790,200.7	0.00	1.00
11/21/2019 12:00	1	1.8	14.6	14.5	28.3	803,894.9	0.00	1.00
11/21/2019 13:00	1	1.8	14.8	14.5	29.1	814,593.5	0.00	1.00
11/21/2019 14:00	1	1.8	14.7	14.5	29.1	815,235.5	0.00	1.00
11/21/2019 15:00	1	1.8	14.9	14.6	32.4	904,037.5	0.00	1.00
11/21/2019 16:00	1	1.8	14.7	14.6	32.5	920,122.8	0.00	1.00
11/21/2019 17:00	1	1.8	14.9	14.6	33.3	925,774.4	0.00	1.00
11/21/2019 18:00	1	1.8	15.3	14.5	34.7	919,226.1	0.00	1.00
11/21/2019 19:00	1	1.9	15.1	14.5	34.6	922,221.7	0.00	1.00
11/21/2019 20:00	1	1.8	15.5	14.5	35.8	924,789.4	0.00	1.00
11/21/2019 21:00	1	1.9	14.6	14.5	30.7	886,060.4	0.00	1.00
11/21/2019 22:00	2	1.9	17.3	14.4	28.1	637,519.7	0.00	1.00
11/21/2019 23:00	2	1.8	17.2	14.5	28.3	630,577.1	0.00	1.00
Average/Sum#:	1	3.4	16.4	14.7	29.0	829,709.5	0.82 #	17.25 #
Minimum:	1	1.8	14.6	14.4	0.0	630,577.1	0.00	0.00
Maximum:	2	25.1	30.6	17.9	38.0	925,774.4	0.57	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2019 00:00	2	1.9	16.2	14.4	26.9	624,668.2	0.00	1.00
11/22/2019 01:00	2	1.9	17.7	14.5	29.7	630,791.1	0.00	1.00
11/22/2019 02:00	2	1.9	17.8	14.5	29.8	630,791.1	0.00	1.00
11/22/2019 03:00	2	1.9	18.1	14.4	30.6	621,297.3	0.00	1.00
11/22/2019 04:00	2	1.8	18.7	14.4	31.2	624,036.2	0.00	1.00
11/22/2019 05:00	1	1.9	15.6	14.4	24.8	654,584.9	0.00	1.00
11/22/2019 06:00	1	1.9	14.0	14.4	25.0	779,307.8	0.00	1.00
11/22/2019 07:00	1	1.9	14.6	14.3	25.8	719,155.3	0.00	1.00
11/22/2019 08:00	1	1.9	14.0	14.4	27.0	787,735.0	0.00	1.00
11/22/2019 09:00	1	1.9	14.1	14.4	27.8	797,637.0	0.00	1.00
11/22/2019 10:00	1	1.9	14.3	14.5	29.0	822,082.6	0.00	1.00
11/22/2019 11:00	1	1.8	14.6	14.5	30.7	840,056.3	0.00	1.00
11/22/2019 12:00	1	1.8	14.8	14.6	32.2	879,257.4	0.00	1.00
11/22/2019 13:00	1	1.8	14.7	14.6	30.8	860,346.3	0.00	1.00
11/22/2019 14:00	1	1.9	14.1	14.5	29.0	852,252.7	0.00	1.00
11/22/2019 15:00	1	1.8	15.5	14.5	36.7	925,217.3	0.00	1.00
11/22/2019 16:00	2	2.3	20.2	12.7	45.7	962,772.1	0.00	1.00
11/22/2019 17:00	2	2.4	20.5	12.7	48.2	965,778.2	0.00	1.00
11/22/2019 18:00	2	2.4	20.6	12.7	48.4	964,609.2	0.00	1.00
11/22/2019 19:00	2	2.3	20.7	12.8	48.8	973,812.9	0.00	1.00
11/22/2019 20:00	2	2.3	20.9	12.8	48.8	956,568.3	0.00	1.00
11/22/2019 21:00	1	1.9	15.0	14.5	34.7	899,540.6	0.00	1.00
11/22/2019 22:00	1	1.8	14.9	14.5	34.8	904,462.0	0.00	1.00
11/22/2019 23:00	1	1.8	16.0	14.5	36.5	900,610.5	0.00	1.00
Average/Sum#:	1	2.0	16.6	14.1	33.9	815,723.8	0.00 #	24.00 #
Minimum:	1	1.8	14.0	12.7	24.8	621,297.3	0.00	1.00
Maximum:	2	2.4	20.9	14.6	48.8	973,812.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOX, Ppm	NOX, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2019 00:00	0	7.5	28.0	15.1	8.5	566,186.2	0.15	0.25
11/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	7.5	28.0	15.1	8.5	566,186.2	0.15 #	0.25 #
Minimum:	0	7.5	28.0	15.1	8.5	566,186.2	0.00	0.00
Maximum:	0	7.5	28.0	15.1	8.5	566,186.2	0.15	0.25
%SI	95.83	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2019 03:00	0	23.8	30.2	18.2	0.0	739,489.2	0.25	0.25
11/26/2019 04:00	1	8.5	19.3	14.3	19.4	668,528.1	0.68	1.00
11/26/2019 05:00	1	1.9	17.2	14.5	35.9	887,772.2	0.00	1.00
11/26/2019 06:00	1	1.9	16.6	14.4	31.3	834,084.8	0.00	1.00
11/26/2019 07:00	1	1.9	16.0	14.4	31.1	820,601.2	0.00	1.00
11/26/2019 08:00	1	1.9	16.1	14.4	32.9	841,037.3	0.00	1.00
11/26/2019 09:00	1	1.9	16.1	14.5	34.8	882,850.8	0.00	1.00
11/26/2019 10:00	1	1.8	16.4	14.5	37.9	900,610.5	0.00	1.00
11/26/2019 11:00	1	1.8	16.6	14.6	38.0	924,687.5	0.00	1.00
11/26/2019 12:00	1	1.8	16.8	14.6	40.1	934,469.1	0.00	1.00
11/26/2019 13:00	1	1.9	16.6	14.5	37.1	900,396.5	0.00	1.00
11/26/2019 14:00	1	1.8	15.7	14.5	36.3	885,846.4	0.00	1.00
11/26/2019 15:00	1	1.8	15.3	14.5	32.9	886,702.3	0.00	1.00
11/26/2019 16:00	2	1.9	17.5	14.2	42.1	932,230.5	0.00	1.00
11/26/2019 17:00	3	2.4	22.4	12.4	51.6	972,130.2	0.00	1.00
11/26/2019 18:00	3	2.4	21.7	12.6	51.0	958,432.1	0.00	1.00
11/26/2019 19:00	1	1.9	15.4	14.4	32.5	855,784.9	0.00	1.00
11/26/2019 20:00	1	1.8	14.9	14.5	32.4	878,571.3	0.00	1.00
11/26/2019 21:00	1	1.9	15.0	14.5	32.2	874,077.9	0.00	1.00
11/26/2019 22:00	1	1.9	14.5	14.3	24.1	717,495.4	0.00	1.00
11/26/2019 23:00	2	1.9	16.8	14.3	28.2	653,796.4	0.00	1.00
Average/Sum#:	1	3.3	17.5	14.4	33.4	854,742.6	0.93 #	20.25 #
Minimum:	1	1.8	14.5	12.4	0.0	653,796.4	0.00	0.00
Maximum:	3	23.8	30.2	18.2	51.6	972,130.2	0.68	1.00
%SI	16.67	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2019 00:00	1	1.9	15.5	14.4	24.5	626,353.6	0.00	1.00
11/27/2019 01:00	2	1.8	19.4	14.5	33.8	614,315.2	0.00	1.00
11/27/2019 02:00	2	1.9	19.0	14.5	32.0	614,743.2	0.00	1.00
11/27/2019 03:00	2	1.9	19.4	14.5	32.6	613,031.4	0.00	1.00
11/27/2019 04:00	2	1.9	15.8	14.4	24.0	626,775.0	0.00	1.00
11/27/2019 05:00	1	1.8	16.2	14.3	26.0	674,130.3	0.00	1.00
11/27/2019 06:00	1	1.9	15.5	14.5	33.9	907,457.6	0.00	1.00
11/27/2019 07:00	1	1.9	14.4	14.4	26.1	791,105.9	0.00	1.00
11/27/2019 08:00	1	1.9	14.4	14.4	29.0	810,699.2	0.00	1.00
11/27/2019 09:00	1	1.9	14.8	14.5	32.1	872,152.2	0.00	1.00
11/27/2019 10:00	1	1.8	16.3	14.5	37.8	913,234.9	0.00	1.00
11/27/2019 11:00	1	1.8	15.6	14.6	34.6	919,035.9	0.00	1.00
11/27/2019 12:00	1	1.8	15.5	14.6	34.8	912,514.9	0.00	1.00
11/27/2019 13:00	1	1.8	15.7	14.6	35.7	907,298.0	0.00	1.00
11/27/2019 14:00	1	1.8	15.3	14.5	32.5	865,733.0	0.00	1.00
11/27/2019 15:00	1	1.8	14.9	14.5	32.3	866,160.9	0.00	1.00
11/27/2019 16:00	2	1.8	16.4	14.5	39.5	916,658.4	0.00	1.00
11/27/2019 17:00	2	2.3	20.2	13.0	45.9	948,889.8	0.00	1.00
11/27/2019 18:00	2	1.9	16.2	14.4	39.3	905,505.5	0.00	1.00
11/27/2019 19:00	1	1.9	14.8	14.5	32.8	886,274.3	0.00	1.00
11/27/2019 20:00	1	1.9	14.7	14.5	32.9	884,776.5	0.00	1.00
11/27/2019 21:00	1	1.9	14.4	14.4	30.5	835,770.2	0.00	1.00
11/27/2019 22:00	1	1.9	13.7	14.4	25.1	764,560.2	0.00	1.00
11/27/2019 23:00	1	1.9	14.6	14.3	24.9	687,617.0	0.00	1.00
Average/Sum#:	1	1.9	15.9	14.4	32.2	806,866.4	0.00 #	24.00 #
Minimum:	1	1.8	13.7	13.0	24.0	613,031.4	0.00	1.00
Maximum:	2	2.3	20.2	14.6	45.9	948,889.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2019 00:00	1	1.9	15.4	14.3	26.5	677,865.1	0.00	1.00
11/28/2019 01:00	2	1.9	15.5	14.4	26.8	628,881.8	0.00	1.00
11/28/2019 02:00	2	1.8	19.0	14.5	34.1	619,878.5	0.00	1.00
11/28/2019 03:00	3	1.8	21.0	14.5	37.9	615,599.1	0.00	1.00
11/28/2019 04:00	1	1.9	16.8	14.4	26.1	622,982.8	0.00	1.00
11/28/2019 05:00	1	1.9	16.5	14.3	28.3	655,871.3	0.00	1.00
11/28/2019 06:00	1	1.9	15.3	14.3	25.3	683,052.3	0.00	1.00
11/28/2019 07:00	1	1.9	15.5	14.3	26.6	680,354.9	0.00	1.00
11/28/2019 08:00	1	1.9	13.5	14.3	24.2	737,206.8	0.00	1.00
11/28/2019 09:00	1	1.9	13.5	14.4	26.2	774,040.8	0.00	1.00
11/28/2019 10:00	1	1.9	13.8	14.4	27.8	807,539.0	0.00	1.00
11/28/2019 11:00	1	1.9	13.7	14.4	28.0	801,218.6	0.00	1.00
11/28/2019 12:00	1	1.9	13.7	14.4	27.4	793,212.7	0.00	1.00
11/28/2019 13:00	1	1.9	13.5	14.4	26.7	777,411.7	0.00	1.00
11/28/2019 14:00	1	1.9	13.5	14.4	25.7	761,189.3	0.00	1.00
11/28/2019 15:00	1	1.9	13.5	14.4	26.4	769,616.5	0.00	1.00
11/28/2019 16:00	2	1.9	15.7	14.3	27.8	662,925.9	0.00	1.00
11/28/2019 17:00	1	1.9	14.0	14.5	30.3	860,811.6	0.00	1.00
11/28/2019 18:00	1	1.9	14.5	14.5	31.1	855,248.3	0.00	1.00
11/28/2019 19:00	2	1.9	18.0	14.4	31.1	614,976.9	0.00	1.00
11/28/2019 20:00	1	1.9	13.5	14.4	25.3	787,313.7	0.00	1.00
11/28/2019 21:00	1	1.9	13.6	14.4	26.2	770,669.9	0.00	1.00
11/28/2019 22:00	1	1.9	14.1	14.3	25.1	710,855.7	0.00	1.00
11/28/2019 23:00	2	1.9	15.8	14.3	27.9	638,857.2	0.00	1.00
Average/Sum#:	1	1.9	15.1	14.4	27.9	721,149.2	0.00 #	24.00 #
Minimum:	1	1.8	13.5	14.3	24.2	614,976.9	0.00	1.00
Maximum:	3	1.9	21.0	14.5	37.9	860,811.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2019 00:00	2	1.9	16.5	14.3	28.2	667,490.6	0.00	1.00
11/29/2019 01:00	2	1.9	16.6	14.3	28.5	668,320.6	0.00	1.00
11/29/2019 02:00	2	1.9	16.8	14.3	29.4	653,381.4	0.00	1.00
11/29/2019 03:00	2	1.9	16.8	14.3	28.8	661,473.5	0.00	1.00
11/29/2019 04:00	1	1.8	16.6	14.3	27.9	675,582.7	0.00	1.00
11/29/2019 05:00	1	1.9	14.5	14.3	24.8	706,291.0	0.00	1.00
11/29/2019 06:00	1	1.9	14.2	14.3	26.2	733,472.0	0.00	1.00
11/29/2019 07:00	1	1.9	13.7	14.4	26.0	766,245.6	0.00	1.00
11/29/2019 08:00	1	1.9	13.8	14.4	27.7	793,212.7	0.00	1.00
11/29/2019 09:00	1	1.9	13.7	14.4	26.7	777,411.7	0.00	1.00
11/29/2019 10:00	1	1.9	13.8	14.5	28.0	807,532.4	0.00	1.00
11/29/2019 11:00	1	1.9	13.8	14.4	27.1	775,094.2	0.00	1.00
11/29/2019 12:00	1	1.9	13.7	14.4	27.2	773,408.8	0.00	1.00
11/29/2019 13:00	1	1.9	13.7	14.5	27.4	788,274.9	0.00	1.00
11/29/2019 14:00	1	1.9	13.8	14.4	27.3	771,934.0	0.00	1.00
11/29/2019 15:00	1	1.9	13.9	14.5	27.3	779,716.0	0.00	1.00
11/29/2019 16:00	2	1.8	17.6	14.5	31.9	662,459.0	0.00	1.00
11/29/2019 17:00	2	2.1	19.4	13.3	45.9	964,543.3	0.00	1.00
11/29/2019 18:00	2	2.3	20.3	13.1	48.4	965,444.2	0.00	1.00
11/29/2019 19:00	2	2.2	19.8	13.2	47.1	956,462.9	0.00	1.00
11/29/2019 20:00	1	1.9	14.9	14.5	34.6	889,056.0	0.00	1.00
11/29/2019 21:00	1	1.9	14.3	14.4	29.9	823,972.1	0.00	1.00
11/29/2019 22:00	1	1.9	13.8	14.4	25.3	749,180.5	0.00	1.00
11/29/2019 23:00	2	1.9	15.7	14.3	27.9	682,429.8	0.00	1.00
Average/Sum#:	1	1.9	15.5	14.2	30.4	770,516.2	0.00 #	24.00 #
Minimum:	1	1.8	13.7	13.1	24.8	653,381.4	0.00	1.00
Maximum:	2	2.3	20.3	14.5	48.4	965,444.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2019 00:00	2	1.9	16.5	14.3	29.4	654,833.8	0.00	1.00
11/30/2019 01:00	2	1.9	16.4	14.5	28.2	635,498.5	0.00	1.00
11/30/2019 02:00	3	1.8	20.0	14.5	37.6	619,664.5	0.00	1.00
11/30/2019 03:00	2	1.8	19.9	14.5	35.4	621,590.3	0.00	1.00
11/30/2019 04:00	1	1.9	16.7	14.5	27.2	640,633.8	0.00	1.00
11/30/2019 05:00	2	1.9	16.7	14.3	29.6	649,231.7	0.00	1.00
11/30/2019 06:00	2	1.9	16.8	14.3	28.8	675,790.2	0.00	1.00
11/30/2019 07:00	2	1.9	16.5	14.3	28.7	680,147.4	0.00	1.00
11/30/2019 08:00	1	1.9	14.0	14.4	26.7	774,251.5	0.00	1.00
11/30/2019 09:00	1	1.9	14.5	14.5	30.3	820,798.7	0.00	1.00
11/30/2019 10:00	1	1.8	15.0	14.5	33.4	858,885.9	0.00	1.00
11/30/2019 11:00	1	1.9	15.0	14.5	33.0	849,899.0	0.00	1.00
11/30/2019 12:00	1	1.8	14.8	14.5	32.8	848,829.1	0.00	1.00
11/30/2019 13:00	1	1.8	15.0	14.6	34.5	897,081.7	0.00	1.00
11/30/2019 14:00	1	1.8	15.0	14.6	35.0	903,602.7	0.00	1.00
11/30/2019 15:00	1	1.8	14.9	14.6	34.0	897,733.8	0.00	1.00
11/30/2019 16:00	1	1.9	14.8	14.4	25.5	683,026.7	0.00	1.00
11/30/2019 17:00	3	2.2	20.4	12.6	53.1	973,446.2	0.00	1.00
11/30/2019 18:00	2	1.8	15.0	14.4	35.7	888,440.4	0.00	1.00
11/30/2019 19:00	2	1.8	15.3	14.3	26.2	655,041.3	0.00	1.00
11/30/2019 20:00	1	1.8	13.4	14.4	27.9	811,120.6	0.00	1.00
11/30/2019 21:00	1	1.8	13.3	14.4	26.8	782,468.0	0.00	1.00
11/30/2019 22:00	2	1.8	14.8	14.3	26.6	685,957.1	0.00	1.00
11/30/2019 23:00	2	1.8	15.6	14.3	27.8	648,194.2	0.00	1.00
Average/Sum#:	2	1.9	15.8	14.4	31.4	756,507.0	0.00 #	24.00 #
Minimum:	1	1.8	13.3	12.6	25.5	619,664.5	0.00	1.00
Maximum:	3	2.2	20.4	14.6	53.1	973,446.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019 00:00	2	1.8	17.4	14.5	31.7	623,088.1	0.00	1.00
12/01/2019 01:00	2	1.7	18.8	14.5	34.5	614,101.2	0.00	1.00
12/01/2019 02:00	2	1.7	18.1	14.5	32.0	613,887.3	0.00	1.00
12/01/2019 03:00	2	1.7	17.8	14.5	31.4	614,101.2	0.00	1.00
12/01/2019 04:00	2	1.7	18.1	14.5	31.3	614,957.1	0.00	1.00
12/01/2019 05:00	2	1.8	14.7	14.4	23.6	624,036.2	0.00	1.00
12/01/2019 06:00	2	1.8	14.6	14.4	25.0	638,151.8	0.00	1.00
12/01/2019 07:00	2	1.8	15.4	14.3	27.1	658,983.6	0.00	1.00
12/01/2019 08:00	2	1.8	15.6	14.3	27.2	673,507.8	0.00	1.00
12/01/2019 09:00	1	1.8	15.2	14.3	26.4	679,732.5	0.00	1.00
12/01/2019 10:00	1	1.8	14.6	14.3	25.3	684,504.7	0.00	1.00
12/01/2019 11:00	1	1.8	13.8	14.3	23.9	691,766.8	0.00	1.00
12/01/2019 12:00	1	1.8	13.6	14.3	24.2	699,443.9	0.00	1.00
12/01/2019 13:00	1	1.8	14.4	14.3	25.4	683,674.7	0.00	1.00
12/01/2019 14:00	1	1.8	13.2	14.3	24.7	729,529.7	0.00	1.00
12/01/2019 15:00	1	1.7	13.5	14.5	29.8	865,091.1	0.00	1.00
12/01/2019 16:00	1	1.8	14.2	14.3	24.6	688,654.5	0.00	1.00
12/01/2019 17:00	2	2.1	18.2	13.1	44.1	926,819.4	0.00	1.00
12/01/2019 18:00	3	2.4	19.9	12.5	48.5	953,217.2	0.00	1.00
12/01/2019 19:00	2	2.0	14.5	14.3	34.0	880,166.4	0.00	1.00
12/01/2019 20:00	2	1.9	15.1	14.3	36.3	895,935.5	0.00	1.00
12/01/2019 21:00	1	1.9	13.9	14.5	31.3	882,422.8	0.00	1.00
12/01/2019 22:00	1	1.9	13.6	14.3	23.6	718,947.8	0.00	1.00
12/01/2019 23:00	1	1.9	14.9	14.3	26.0	683,674.7	0.00	1.00
Average/Sum#:	2	1.8	15.5	14.2	29.7	722,433.2	0.00 #	24.00 #
Minimum:	1	1.7	13.2	12.5	23.6	613,887.3	0.00	1.00
Maximum:	3	2.4	19.9	14.5	48.5	953,217.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2019 00:00	2	1.9	15.5	14.3	27.0	657,116.2	0.00	1.00
12/02/2019 01:00	3	1.9	19.1	14.5	35.7	618,166.7	0.00	1.00
12/02/2019 02:00	2	1.8	18.4	14.5	31.6	615,599.1	0.00	1.00
12/02/2019 03:00	2	1.8	17.3	14.5	29.7	616,027.0	0.00	1.00
12/02/2019 04:00	1	1.8	16.4	14.5	27.1	624,799.9	0.00	1.00
12/02/2019 05:00	1	1.9	15.0	14.3	25.5	660,436.0	0.00	1.00
12/02/2019 06:00	1	1.9	14.9	14.4	34.1	908,455.1	0.00	1.00
12/02/2019 07:00	1	1.9	13.7	14.4	29.1	847,779.0	0.00	1.00
12/02/2019 08:00	1	1.9	13.5	14.4	28.2	826,289.6	0.00	1.00
12/02/2019 09:00	1	1.8	14.0	14.5	33.1	913,234.9	0.00	1.00
12/02/2019 10:00	1	1.9	13.8	14.5	31.3	897,828.9	0.00	1.00
12/02/2019 11:00	1	1.9	13.7	14.5	31.6	899,540.6	0.00	1.00
12/02/2019 12:00	1	1.8	13.8	14.5	32.0	902,536.3	0.00	1.00
12/02/2019 13:00	1	1.9	13.5	14.5	30.3	884,776.5	0.00	1.00
12/02/2019 14:00	1	1.8	13.4	14.5	30.6	887,344.2	0.00	1.00
12/02/2019 15:00	1	1.8	14.1	14.5	34.1	917,300.4	0.00	1.00
12/02/2019 16:00	2	2.2	18.3	13.1	42.6	961,055.0	0.00	1.00
12/02/2019 17:00	2	2.3	18.4	13.1	43.8	959,123.8	0.00	1.00
12/02/2019 18:00	2	2.3	18.3	13.1	43.8	956,490.3	0.00	1.00
12/02/2019 19:00	2	2.2	18.1	13.2	43.5	958,419.2	0.00	1.00
12/02/2019 20:00	2	2.3	18.4	13.1	43.4	952,803.4	0.00	1.00
12/02/2019 21:00	1	1.9	14.0	14.4	33.1	887,808.4	0.00	1.00
12/02/2019 22:00	1	1.9	13.5	14.3	22.6	704,631.1	0.00	1.00
12/02/2019 23:00	2	1.9	15.4	14.5	26.8	631,005.1	0.00	1.00
Average/Sum#:	1	1.9	15.6	14.2	32.9	820,356.9	0.00 #	24.00 #
Minimum:	1	1.8	13.4	13.1	22.6	615,599.1	0.00	1.00
Maximum:	3	2.3	19.1	14.5	43.8	961,055.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2019 00:00	1	1.9	13.6	14.4	22.3	632,884.7	0.00	1.00
12/03/2019 01:00	2	1.9	17.2	14.5	31.3	618,380.7	0.00	1.00
12/03/2019 02:00	2	1.9	17.1	14.5	30.0	620,092.5	0.00	1.00
12/03/2019 03:00	2	1.9	17.2	14.5	29.9	619,450.6	0.00	1.00
12/03/2019 04:00	2	1.8	17.5	14.5	30.1	620,092.5	0.00	1.00
12/03/2019 05:00	2	1.9	14.7	14.4	24.2	647,632.4	0.00	1.00
12/03/2019 06:00	1	1.9	14.5	14.3	24.2	683,259.8	0.00	1.00
12/03/2019 07:00	1	1.8	13.5	14.5	29.2	877,501.5	0.00	1.00
12/03/2019 08:00	1	1.9	13.4	14.4	27.3	819,969.2	0.00	1.00
12/03/2019 09:00	1	1.8	14.0	14.5	32.9	909,169.4	0.00	1.00
12/03/2019 10:00	1	1.9	13.7	14.5	29.9	872,794.1	0.00	1.00
12/03/2019 11:00	1	1.9	13.4	14.4	28.3	826,711.0	0.00	1.00
12/03/2019 12:00	1	1.9	13.3	14.5	27.5	830,641.5	0.00	1.00
12/03/2019 13:00	1	1.9	12.9	14.4	26.0	788,156.4	0.00	1.00
12/03/2019 14:00	1	1.9	13.2	14.5	27.9	826,148.1	0.00	1.00
12/03/2019 15:00	1	1.9	13.2	14.5	28.2	837,060.7	0.00	1.00
12/03/2019 16:00	1	1.9	13.7	14.5	31.5	883,706.7	0.00	1.00
12/03/2019 17:00	2	2.0	15.9	14.0	37.5	930,414.7	0.00	1.00
12/03/2019 18:00	2	2.0	15.6	14.1	36.9	916,507.4	0.00	1.00
12/03/2019 19:00	1	1.9	13.0	14.3	22.4	732,849.5	0.00	1.00
12/03/2019 20:00	2	2.0	15.4	14.0	37.9	914,735.8	0.00	1.00
12/03/2019 21:00	1	1.9	14.5	14.5	35.1	918,156.3	0.00	1.00
12/03/2019 22:00	1	1.9	13.0	14.4	25.0	794,055.5	0.00	1.00
12/03/2019 23:00	1	1.9	13.5	14.3	22.9	695,501.6	0.00	1.00
Average/Sum#:	1	1.9	14.5	14.4	29.1	783,994.7	0.00 #	24.00 #
Minimum:	1	1.8	12.9	14.0	22.3	618,380.7	0.00	1.00
Maximum:	2	2.0	17.5	14.5	37.9	930,414.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2019 00:00	2	1.9	14.9	14.3	25.8	634,292.5	0.00	1.00
12/04/2019 01:00	2	1.9	16.6	14.5	28.9	620,948.4	0.00	1.00
12/04/2019 02:00	2	1.8	17.1	14.5	30.1	616,454.9	0.00	1.00
12/04/2019 03:00	2	1.9	17.4	14.5	30.1	615,599.1	0.00	1.00
12/04/2019 04:00	2	1.8	17.6	14.5	29.9	623,516.0	0.00	1.00
12/04/2019 05:00	1	1.8	13.4	14.5	25.1	864,877.1	0.00	1.00
12/04/2019 06:00	1	1.9	13.8	14.5	30.9	884,776.5	0.00	1.00
12/04/2019 07:00	2	2.1	16.8	13.6	39.4	943,026.9	0.00	1.00
12/04/2019 08:00	2	2.2	18.0	13.2	42.1	950,238.2	0.00	1.00
12/04/2019 09:00	2	2.2	18.0	13.2	41.9	945,258.5	0.00	1.00
12/04/2019 10:00	1	2.0	14.0	14.4	32.6	874,746.2	0.00	1.00
12/04/2019 11:00	1	1.8	13.5	14.5	30.1	887,986.1	0.00	1.00
12/04/2019 12:00	1	1.8	13.6	14.5	31.3	895,261.2	0.00	1.00
12/04/2019 13:00	1	1.8	13.8	14.5	31.9	902,964.2	0.00	1.00
12/04/2019 14:00	1	1.8	13.6	14.5	30.2	885,204.5	0.00	1.00
12/04/2019 15:00	1	1.9	13.7	14.5	31.7	892,907.5	0.00	1.00
12/04/2019 16:00	2	2.2	18.2	13.1	42.1	953,330.1	0.00	1.00
12/04/2019 17:00	2	2.3	18.6	13.0	43.7	952,703.3	0.00	1.00
12/04/2019 18:00	2	2.3	18.7	13.0	44.1	952,356.7	0.00	1.00
12/04/2019 19:00	2	2.3	18.7	13.0	43.9	938,142.4	0.00	1.00
12/04/2019 20:00	2	2.3	18.5	13.0	43.4	931,035.2	0.00	1.00
12/04/2019 21:00	2	2.1	16.2	13.8	38.7	915,778.4	0.00	1.00
12/04/2019 22:00	1	1.9	13.5	14.5	30.1	866,374.9	0.00	1.00
12/04/2019 23:00	1	1.9	15.0	14.4	23.8	649,528.5	0.03	1.00
Average/Sum#:	2	2.0	16.0	14.0	34.2	841,554.5	0.03 #	24.00 #
Minimum:	1	1.8	13.4	13.0	23.8	615,599.1	0.00	1.00
Maximum:	2	2.3	18.7	14.5	44.1	953,330.1	0.03	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2019 00:00	0	13.2	37.0	16.0	0.0	458,617.4	0.12	0.12
12/05/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	13.2	37.0	16.0	0.0	458,617.4	0.12 #	0.12 #
Minimum:	0	13.2	37.0	16.0	0.0	458,617.4	0.00	0.00
Maximum:	0	13.2	37.0	16.0	0.0	458,617.4	0.12	0.12
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 15:34 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:34 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2019 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2019 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NOx	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.00	0.00	0.00
10/02/2019	0.00	0.00	0.00	0.00	0.00
10/03/2019	0.00	0.00	0.00	0.00	0.00
10/04/2019	0.00	0.00	0.00	0.00	0.00
10/05/2019	0.00	0.00	0.00	0.00	0.00
10/06/2019	0.00	0.00	0.00	0.00	0.00
10/07/2019	0.00	0.00	0.00	0.00	0.00
10/08/2019	0.00	0.00	0.00	0.00	0.00
10/09/2019	0.00	0.00	0.00	0.00	0.00
10/10/2019	0.00	0.00	0.00	0.00	0.00
10/11/2019	0.00	0.00	0.00	0.00	0.00
10/12/2019	0.00	0.00	0.00	0.00	0.00
10/13/2019	0.00	0.00	0.00	0.00	0.00
10/14/2019	0.00	0.00	0.00	0.00	0.00
10/15/2019	0.00	0.00	0.00	0.00	0.00
10/16/2019	0.00	0.00	0.00	0.00	0.00
10/17/2019	0.00	0.00	0.00	0.00	0.00
10/18/2019	0.00	0.00	0.00	0.00	0.00
10/19/2019	0.00	0.00	0.00	0.00	0.00
10/20/2019	0.00	0.00	0.00	0.00	0.00
10/21/2019	46.26	65.45	5.04	10.08	16.78
10/22/2019	18.36	60.33	5.92	11.84	19.73
10/23/2019	17.21	63.08	6.02	12.05	20.07
10/24/2019	54.98	85.19	6.82	13.72	22.83
10/25/2019	62.93	85.06	6.91	13.82	22.98
10/26/2019	19.60	50.83	4.86	9.69	16.16
10/27/2019	17.37	52.71	5.05	10.06	16.77
10/28/2019	22.77	62.36	5.98	11.99	20.01
10/29/2019	338.32	102.83	8.10	16.22	27.04
10/30/2019	45.65	75.70	7.38	14.74	24.57
10/31/2019	18.36	79.67	7.63	15.28	25.48
Monthly Avg/Sum*:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
Daily Min:	17.21	50.83	4.86	9.69	16.16
Daily Max:	338.32	102.83	8.10	16.22	27.04
Oct 2019 - Oct 2019	661.81	783.21	69.71	139.49	232.42
QTD:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
YTD 2019:	5,142.90 *	13,106.22 *	1,216.27 *	2,433.64 *	4,055.91 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.00	13.94	23.22
11/02/2019	22.69	65.84	6.26	12.58	20.98
11/03/2019	21.34	61.80	5.88	11.73	19.64
11/04/2019	18.26	69.40	6.64	13.25	22.10
11/05/2019	52.08	100.71	8.53	17.03	28.37
11/06/2019	42.42	126.86	11.97	23.94	39.94
11/07/2019	83.67	109.38	9.41	18.78	31.34
11/08/2019	62.35	113.46	9.84	19.71	32.81
11/09/2019	36.76	59.05	5.65	11.25	18.79
11/10/2019	23.22	57.70	5.53	10.99	18.37
11/11/2019	48.40	72.13	6.02	12.04	20.05
11/12/2019	40.18	63.34	5.81	11.64	19.40
11/13/2019	72.57	112.30	9.86	19.70	32.85
11/14/2019	58.46	111.34	10.52	21.00	35.12
11/15/2019	19.85	1.69	0.04	0.08	0.13
11/16/2019	0.00	0.00	0.00	0.00	0.00
11/17/2019	0.00	0.00	0.00	0.00	0.00
11/18/2019	0.00	0.00	0.00	0.00	0.00
11/19/2019	0.00	0.00	0.00	0.00	0.00
11/20/2019	41.86	21.26	0.75	1.51	2.52
11/21/2019	97.32	110.63	8.34	16.73	27.87
11/22/2019	41.89	125.41	11.96	23.91	39.92
11/23/2019	13.86	1.69	0.04	0.07	0.12
11/24/2019	0.00	0.00	0.00	0.00	0.00
11/25/2019	0.00	0.00	0.00	0.00	0.00
11/26/2019	128.07	128.26	9.81	19.66	32.75
11/27/2019	38.45	115.86	11.04	22.08	36.74
11/28/2019	36.18	104.67	9.95	19.92	33.17
11/29/2019	38.55	113.72	10.82	21.67	36.10
11/30/2019	37.78	110.86	10.67	21.38	35.55
Monthly Avg/Sum*:	1,101.16 *	2,030.35 *	182.34 *	364.59 *	607.85 *
Daily Min:	13.86	1.69	0.04	0.07	0.12
Daily Max:	128.07	128.26	11.97	23.94	39.94
Oct 2019 - Nov 2019	1,762.97	2,813.56	252.05	504.08	840.27
QTD:	1,762.97 *	2,813.56 *	252.05 *	504.08 *	840.27 *
YTD 2019:	6,244.06 *	15,136.57 *	1,398.61 *	2,798.23 *	4,663.76 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:11 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2019	38.31	107.26	10.49	20.91	34.80
12/02/2019	35.09	125.41	11.96	23.89	39.79
12/03/2019	35.34	116.36	11.06	22.04	36.78
12/04/2019	31.69	132.56	12.65	25.26	42.06
12/05/2019	29.57	2.15	0.02	0.04	0.08
12/06/2019	0.00	0.00	0.00	0.00	0.00
12/07/2019	0.00	0.00	0.00	0.00	0.00
12/08/2019	0.00	0.00	0.00	0.00	0.00
12/09/2019	0.00	0.00	0.00	0.00	0.00
12/10/2019	0.00	0.00	0.00	0.00	0.00
12/11/2019	0.00	0.00	0.00	0.00	0.00
12/12/2019	0.00	0.00	0.00	0.00	0.00
12/13/2019	0.00	0.00	0.00	0.00	0.00
12/14/2019	0.00	0.00	0.00	0.00	0.00
12/15/2019	0.00	0.00	0.00	0.00	0.00
12/16/2019	0.00	0.00	0.00	0.00	0.00
12/17/2019	0.00	0.00	0.00	0.00	0.00
12/18/2019	0.00	0.00	0.00	0.00	0.00
12/19/2019	0.00	0.00	0.00	0.00	0.00
12/20/2019	0.00	0.00	0.00	0.00	0.00
12/21/2019	0.00	0.00	0.00	0.00	0.00
12/22/2019	0.00	0.00	0.00	0.00	0.00
12/23/2019	0.00	0.00	0.00	0.00	0.00
12/24/2019	0.00	0.00	0.00	0.00	0.00
12/25/2019	0.00	0.00	0.00	0.00	0.00
12/26/2019	0.00	0.00	0.00	0.00	0.00
12/27/2019	0.00	0.00	0.00	0.00	0.00
12/28/2019	0.00	0.00	0.00	0.00	0.00
12/29/2019	0.00	0.00	0.00	0.00	0.00
12/30/2019	0.00	0.00	0.00	0.00	0.00
12/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	170.00 *	483.74 *	46.18 *	92.14 *	153.51 *
Daily Min:	29.57	2.15	0.02	0.04	0.08
Daily Max:	38.31	132.56	12.65	25.26	42.06
Oct 2019 - Dec 2019	1,932.97	3,297.30	298.23	596.22	993.78
QTD:	1,932.97 *	3,297.30 *	298.23 *	596.22 *	993.78 *
YTD 2019:	6,414.06 *	15,620.31 *	1,444.79 *	2,890.37 *	4,817.27 *

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2019	0.0	0.0	0.0	0.0
10/02/2019	0.0	0.0	0.0	0.0
10/03/2019	0.0	0.0	0.0	0.0
10/04/2019	0.0	0.0	0.0	0.0
10/05/2019	0.0	0.0	0.0	0.0
10/06/2019	0.0	0.0	0.0	0.0
10/07/2019	0.0	0.0	0.0	0.0
10/08/2019	0.0	0.0	0.0	0.0
10/09/2019	0.0	0.0	0.0	0.0
10/10/2019	0.0	0.0	0.0	0.0
10/11/2019	0.0	0.0	0.0	0.0
10/12/2019	0.0	0.0	0.0	0.0
10/13/2019	0.0	0.0	0.0	0.0
10/14/2019	0.0	0.0	0.0	0.0
10/15/2019	0.0	0.0	0.0	0.0
10/16/2019	0.0	0.0	0.0	0.0
10/17/2019	0.0	0.0	0.0	0.0
10/18/2019	0.0	0.0	0.0	0.0
10/19/2019	0.0	0.0	0.0	0.0
10/20/2019	0.0	0.0	0.0	0.0
10/21/2019	0.0	0.0	32.0	14.5
10/22/2019	0.0	0.0	0.0	0.0
10/23/2019	0.0	0.0	0.0	0.0
10/24/2019	24.2	13.8	8.5	1.7
10/25/2019	0.0	0.0	29.9	14.3
10/26/2019	0.0	0.0	0.0	0.0
10/27/2019	0.0	0.0	0.0	0.0
10/28/2019	0.0	0.0	0.0	0.0
10/29/2019	0.0	0.0	294.3	17.8
10/30/2019	0.0	0.0	6.9	1.2
10/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	24.2 *	13.8 *	371.6 *	49.5 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	24.2	13.8	294.3	17.8
Oct 2019 - Oct 2019	24.2	13.8	371.6	49.5
QTD:	24.2 *	13.8 *	371.6 *	49.5 *
YTD 2019:	510.0 *	177.6 *	1,020.0 *	319.5 *

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOx_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOx_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2019	0.0	0.0	0.0	0.0
11/02/2019	0.0	0.0	0.0	0.0
11/03/2019	0.0	0.0	0.0	0.0
11/04/2019	0.0	0.0	0.0	0.0
11/05/2019	0.0	0.0	20.9	12.7
11/06/2019	0.0	0.0	2.2	1.1
11/07/2019	0.0	0.0	41.7	13.2
11/08/2019	0.0	0.0	26.6	12.7
11/09/2019	0.0	0.0	8.1	0.7
11/10/2019	0.0	0.0	0.0	0.0
11/11/2019	0.0	0.0	24.7	10.0
11/12/2019	10.2	1.0	0.2	2.2
11/13/2019	35.2	11.5	0.0	0.0
11/14/2019	9.6	1.1	0.0	0.0
11/15/2019	0.0	0.0	9.2	1.2
11/16/2019	0.0	0.0	0.0	0.0
11/17/2019	0.0	0.0	0.0	0.0
11/18/2019	0.0	0.0	0.0	0.0
11/19/2019	0.0	0.0	0.0	0.0
11/20/2019	0.0	0.0	36.7	14.9
11/21/2019	38.5	12.4	29.2	13.8
11/22/2019	0.0	0.1	0.0	0.0
11/23/2019	0.0	0.0	9.3	1.3
11/24/2019	0.0	0.0	0.0	0.0
11/25/2019	0.0	0.0	0.0	0.0
11/26/2019	53.5	12.9	31.0	15.0
11/27/2019	0.0	0.0	0.0	0.0
11/28/2019	0.0	0.0	0.0	0.0
11/29/2019	0.0	0.0	0.0	0.0
11/30/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	147.0 *	39.0 *	239.8 *	98.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	53.5	12.9	41.7	15.0
Oct 2019 - Nov 2019	171.2	52.8	611.4	148.3
QTD:	171.2 *	52.8 *	611.4 *	148.3 *
YTD 2019:	657.0 *	216.6 *	1,259.8 *	418.3 *

Monthly Summary By Day Report



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 09:13 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2019	0.0	0.0	0.0	0.0
12/02/2019	0.0	0.0	0.0	0.0
12/03/2019	0.0	0.0	0.0	0.0
12/04/2019	0.0	0.1	0.0	0.1
12/05/2019	9.4	1.0	8.9	1.0
12/06/2019	0.0	0.0	0.0	0.0
12/07/2019	0.0	0.0	0.0	0.0
12/08/2019	0.0	0.0	0.0	0.0
12/09/2019	0.0	0.0	0.0	0.0
12/10/2019	0.0	0.0	0.0	0.0
12/11/2019	0.0	0.0	0.0	0.0
12/12/2019	0.0	0.0	0.0	0.0
12/13/2019	0.0	0.0	0.0	0.0
12/14/2019	0.0	0.0	0.0	0.0
12/15/2019	0.0	0.0	0.0	0.0
12/16/2019	0.0	0.0	0.0	0.0
12/17/2019	0.0	0.0	0.0	0.0
12/18/2019	0.0	0.0	0.0	0.0
12/19/2019	0.0	0.0	0.0	0.0
12/20/2019	0.0	0.0	0.0	0.0
12/21/2019	0.0	0.0	0.0	0.0
12/22/2019	0.0	0.0	0.0	0.0
12/23/2019	0.0	0.0	0.0	0.0
12/24/2019	0.0	0.0	0.0	0.0
12/25/2019	0.0	0.0	0.0	0.0
12/26/2019	0.0	0.0	0.0	0.0
12/27/2019	0.0	0.0	0.0	0.0
12/28/2019	0.0	0.0	0.0	0.0
12/29/2019	0.0	0.0	0.0	0.0
12/30/2019	0.0	0.0	0.0	0.0
12/31/2019	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	9.4 *	1.1 *	8.9 *	1.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	9.4	1.0	8.9	1.0
Oct 2019 - Dec 2019	180.6	53.9	620.3	149.4
QTD:	180.6 *	53.9 *	620.3 *	149.4 *
YTD 2019:	666.4 *	217.7 *	1,268.7 *	419.4 *

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/01/2019 00:00	10/24/2019 12:00	565
11/12/2019 01:00	11/13/2019 05:00	29
11/15/2019 00:00	11/21/2019 04:00	149
11/23/2019 00:00	11/26/2019 05:00	78
12/05/2019 01:00	12/31/2019 23:00	647

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,468.00 Hour(s)
Offline Percentage:	66.49 %
Total Online:	740.00 Hour(s)
Online Percentage:	33.51 %

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/24/2019 13:43	10/24/2019 14:44	Cold Startup	62
2	11/12/2019 00:16	11/12/2019 00:24	Shutdown	9
3	11/13/2019 06:44	11/13/2019 07:39	Cold Startup	56
4	11/14/2019 23:49	11/14/2019 23:58	Shutdown	10
5	11/21/2019 05:43	11/21/2019 06:36	Cold Startup	54
6	11/22/2019 23:56	11/22/2019 23:59	Shutdown	4
7	11/26/2019 06:03	11/26/2019 06:56	Cold Startup	54
8	12/04/2019 23:58	12/05/2019 00:06	Shutdown	9

Startup / Shutdown Events

CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:08 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	226	0.51
Warm Startup	0		0.00
Shutdown	4	32	0.07
Total Process Events:	8	258	0.58

Total Report Time: 2,207.98 Hour(s)
Total Operating Time: 736.30 Hour(s)
Total Startup Time: 226 Minute(s)
Total Shutdown Time: 32 Minute(s)
Total Startup/Shutdown Time: 258 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 0.58 %

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/01/2019 00:00	10/21/2019 04:00	485
10/24/2019 20:00	10/25/2019 12:00	17
10/25/2019 19:00	10/29/2019 02:00	80
10/29/2019 06:00	10/29/2019 08:00	3
10/29/2019 14:00	10/30/2019 06:00	17
10/30/2019 12:00	11/05/2019 12:00	145
11/07/2019 01:00	11/07/2019 09:00	9
11/07/2019 22:00	11/08/2019 08:00	11
11/09/2019 01:00	11/11/2019 22:00	70
11/15/2019 01:00	11/20/2019 02:00	122
11/20/2019 08:00	11/21/2019 05:00	22
11/23/2019 01:00	11/26/2019 02:00	74
12/05/2019 01:00	12/31/2019 23:00	647

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,702.00 Hour(s)
Offline Percentage:	77.08 %
Total Online:	506.00 Hour(s)
Online Percentage:	22.92 %

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/21/2019 05:43	10/21/2019 06:33	Cold Startup	51
2	10/24/2019 18:50	10/24/2019 19:03	Shutdown	14
3	10/25/2019 13:43	10/25/2019 14:33	Cold Startup	51
4	10/25/2019 18:50	10/25/2019 18:59	Shutdown	10
5	10/29/2019 03:44	10/29/2019 04:02	Cold Startup	19
6	10/29/2019 04:02	10/29/2019 04:02	Shutdown	1
7	10/29/2019 04:12	10/29/2019 04:34	Cold Startup	23
8	10/29/2019 04:34	10/29/2019 04:34	Shutdown	1
9	10/29/2019 05:44	10/29/2019 05:52	Cold Startup	9
10	10/29/2019 05:51	10/29/2019 05:52	Shutdown	2
11	10/29/2019 09:04	10/29/2019 09:12	Cold Startup	9
12	10/29/2019 09:12	10/29/2019 09:12	Shutdown	1
13	10/29/2019 10:59	10/29/2019 11:06	Cold Startup	8
14	10/29/2019 11:06	10/29/2019 11:06	Shutdown	1
15	10/29/2019 11:17	10/29/2019 11:17	Cold Startup	1
16	10/29/2019 11:17	10/29/2019 11:17	Shutdown	1
17	10/29/2019 12:56	10/29/2019 13:03	Cold Startup	8
18	10/29/2019 13:02	10/29/2019 13:03	Shutdown	2
19	10/29/2019 13:13	10/29/2019 13:17	Cold Startup	5
20	10/29/2019 13:17	10/29/2019 13:17	Shutdown	1
21	10/30/2019 07:22	10/30/2019 08:50	Cold Startup	89
22	10/30/2019 11:46	10/30/2019 11:54	Shutdown	9

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 **To:** 12/31/2019 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	11/05/2019 13:44	11/05/2019 14:35	cold Startup	52
24	11/06/2019 23:52	11/07/2019 00:01	Shutdown	10
25	11/07/2019 10:43	11/07/2019 11:31	cold Startup	49
26	11/07/2019 21:06	11/07/2019 21:14	Shutdown	9
27	11/08/2019 09:43	11/08/2019 10:32	cold Startup	50
28	11/08/2019 23:55	11/09/2019 00:04	Shutdown	10
29	11/11/2019 23:29	11/12/2019 00:22	cold Startup	54
30	11/15/2019 00:07	11/15/2019 00:16	Shutdown	10
31	11/20/2019 03:44	11/20/2019 04:37	cold Startup	54
32	11/20/2019 07:01	11/20/2019 07:09	Shutdown	9
33	11/21/2019 06:45	11/21/2019 07:33	cold Startup	49
34	11/23/2019 00:06	11/23/2019 00:14	Shutdown	9
35	11/26/2019 03:45	11/26/2019 04:40	cold Startup	56
36	12/04/2019 23:58	12/05/2019 00:06	Shutdown	9

Startup / Shutdown Events

CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/07/2020 09:10 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	18	637	2.19
Warm Startup	0		0.00
Shutdown	18	109	0.37
Total Process Events:	36	746	2.56

Total Report Time: 2,207.98 Hour(s)
Total Operating Time: 485.83 Hour(s)
Total Startup Time: 637 Minute(s)
Total Shutdown Time: 109 Minute(s)
Total Startup/Shutdown Time: 746 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 2.56 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 13:38	0			0			0			0			0			0		
10/24/19 13:39	0			0			0			0			0			0		
10/24/19 13:40	0			0			0			0			0			0		
10/24/19 13:41	0			0			0			0			0			0		
10/24/19 13:42	0			0			0			0			0			0		
10/24/19 13:43	0			0.3			0			0			0			0		1
10/24/19 13:44	8240.7			0.3			0			0			0			0		1
10/24/19 13:45	29189.1			1			0.1			0			0			0		1
10/24/19 13:46	43128.9			558.1			18.29			62.72			3.38			1		1
10/24/19 13:47	57607.9			416.9			20.32			60.94			4.89			1		1
10/24/19 13:48	87490.1			222.4			25.96			47.4			9.1			1		1
10/24/19 13:49	131004.2			112.9			37.55			35.41			19.38			1		1
10/24/19 13:50	137935.6			37.1			59.42			12.26			32.33			1		1
10/24/19 13:51	153569.8			908.2			56.79			331.18			34.08			1		1
10/24/19 13:52	174441.2			1600			52.38			664.72			35.82			1		1
10/24/19 13:53	198778.2			393.6			65.83			185.9			51.17			1		1
10/24/19 13:54	222961.2			25.9			70.8			13.71			61.71			1		1
10/24/19 13:55	243524.5			2.5			72.92			1.43			69.28			1		1
10/24/19 13:56	269324.8			1.8			67.85			1.13			70.69			1		1
10/24/19 13:57	289272			1.7			52.72			1.17			59.02			1		1
10/24/19 13:58	293276.8			1.9			27.09			1.29			30.62			1		1
10/24/19 13:59	293584.9			2			19.61			1.38			22.23			1		1
10/24/19 14:00	292583.7			1.9			16.52			1.31			18.75			1		1
10/24/19 14:01	291890.5			1.7			13.89			1.18			15.67			1		1
10/24/19 14:02	291043.3			1.7			12.26			1.14			13.82			1		1
10/24/19 14:03	290658.3			1.6			10.51			1.08			11.88			1		1
10/24/19 14:04	295279.3			1.5			9.5			1.03			10.87			1		1
10/24/19 14:05	302672.8			1.4			8.76			0.98			10.26			1		1
10/24/19 14:06	303597			1.3			8.48			0.92			9.98			1		1
10/24/19 14:07	305060.3			1.2			8.3			0.86			9.8			1		1
10/24/19 14:08	315149.3			1.2			7.84			0.89			9.53			1		1
10/24/19 14:09	315842.5			1.1			7.28			0.83			8.97			1		1
10/24/19 14:10	315688.5			1.1			7.1			0.82			8.66			1		1
10/24/19 14:11	315534.4			1.1			7.01			0.83			8.6			1		1
10/24/19 14:12	314610.3			1			6.91			0.76			8.49			1		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 14:13	318846.1			1			6.82			0.77			8.53			1		
10/24/19 14:14	325854.6			1			6.56			0.8			8.39			1		
10/24/19 14:15	326547.7			0.9			6.37			0.73			8.17			1		
10/24/19 14:16	326470.7			0.9			6.46			0.73			8.29			1		
10/24/19 14:17	326547.7			0.9			6.56			0.73			8.42			1		
10/24/19 14:18	326239.7			0.9			6.56			0.73			8.41			1		
10/24/19 14:19	326316.7			0.9			6.65			0.73			8.53			1		
10/24/19 14:20	325238.4			0.9			6.74			0.73			8.61			1		
10/24/19 14:21	321310.6			0.8			6.84			0.65			8.63			1		
10/24/19 14:22	305214.3			0.8			7.12			0.61			8.54			1		
10/24/19 14:23	299669.2			0.9			7.84			0.66			9.23			1		
10/24/19 14:24	298976			0.9			7.96			0.67			9.35			1		
10/24/19 14:25	299284.1			0.9			7.96			0.67			9.37			1		
10/24/19 14:26	299130			0.8			8.15			0.6			9.59			1		
10/24/19 14:27	290889.3			0.8			6.27			0.59			7.19			1		
10/24/19 14:28	284497			0.8			3			0.57			3.36			1		
10/24/19 14:29	284728.1			0.9			2.47			0.58			2.77			1		
10/24/19 14:30	286345.4			0.7			2.34			0.51			2.64			1		
10/24/19 14:31	292044.6			0.7			2.34			0.52			2.68			1		
10/24/19 14:32	291274.4			0.7			2.49			0.51			2.85			1		
10/24/19 14:33	290504.3			0.7			2.86			0.51			3.26			1		
10/24/19 14:34	290196.2			0.7			3.04			0.51			3.46			1		
10/24/19 14:35	290119.2			0.7			3.23			0.51			3.67			1		
10/24/19 14:36	290581.3			0.7			3.13			0.51			3.57			1		
10/24/19 14:37	290966.3			0.7			2.95			0.51			3.35			1		
10/24/19 14:38	289195			0.7			2.67			0.51			3.03			1		
10/24/19 14:39	288039.8			0.7			2.4			0.5			2.7			1		
10/24/19 14:40	288886.9			0.7			2.3			0.51			2.6			1		
10/24/19 14:41	288501.8			0.7			2.12			0.51			2.4			1		
10/24/19 14:42	288578.8			0.7			2.03			0.51			2.29			1		
10/24/19 14:43	288270.8			0.7			1.94			0.51			2.18			1		
10/24/19 14:44	288501.8			0.7			1.84			0.5			2.08			1		
10/24/19 14:45	288732.9			0.7			1.75			0.51			1.98			0		
10/24/19 14:46	288963.9			0.7			1.66			0.51			1.88			0		
10/24/19 14:47	288886.9			0.7			1.66			0.51			1.88			0		
10/24/19 14:48	288578.8			0.7			1.66			0.51			1.88			0		
10/24/19 14:49	288655.9			0.7			1.57			0.51			1.77			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 0:11	294509.1			1			1.27			0.71			1.48			0		
11/12/19 0:12	294355			1			1.27			0.71			1.48			0		
11/12/19 0:13	294355			1			1.36			0.7			1.58			0		
11/12/19 0:14	294047			1			1.36			0.71			1.58			0		
11/12/19 0:15	293892.9			1			1.45			0.7			1.69			0		
11/12/19 0:16	289811.1			1			1.45			0.69			1.66			1		
11/12/19 0:17	270018			1			1.54			0.65			1.65			1		
11/12/19 0:18	246143			1			4.06			0.6			3.97			1		
11/12/19 0:19	227274.1			1			7.61			0.52			6.85			1		
11/12/19 0:20	201396.8			0.8			12.32			0.4			9.89			1		
11/12/19 0:21	177213.8			3			14.64			1.27			10.38			1		
11/12/19 0:22	155572.3			96.6			16.93			36.77			10.61			1		
11/12/19 0:23	137242.5			857.6			18.44			288.71			10.22			1		
11/12/19 0:24	59148.3			1776.7			19.22			264.88			4.71			1		
11/12/19 0:25	0			0			21.03			17.26			0.26			0		
11/12/19 0:26	0			0			0.3			0			0			0		
11/12/19 0:27	0			0			0.1			0			0			0		
11/12/19 0:28	0			0			0.1			0			0			0		
11/12/19 0:29	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/13/19 6:39	0			0			0			0			0			0		
11/13/19 6:40	0			0			0			0			0			0		
11/13/19 6:41	0			0			0			0			0			0		
11/13/19 6:42	0			0			0			0			0			0		
11/13/19 6:43	0			0			0			0			0			0		
11/13/19 6:44	0			0.5			0			0			0			0		1
11/13/19 6:45	0			0.5			0			0			0			0		1
11/13/19 6:46	0			45.2			31.47			0.05			0.06			0		1
11/13/19 6:47	27263.7			623.7			16.66			40.35			1.77			0		1
11/13/19 6:48	52139.8			468.3			21.74			58.8			4.49			0		1
11/13/19 6:49	99042.5			295.9			27.44			69.81			10.65			0		1
11/13/19 6:50	135471.1			157.2			39.5			50.69			20.96			0		1
11/13/19 6:51	140477.1			99.7			57.82			33.5			31.97			0		1
11/13/19 6:52	158113.8			1683.7			49.41			631.67			30.51			0		1
11/13/19 6:53	178292			1836.1			53.45			780.09			37.37			0		1
11/13/19 6:54	202552			747.3			58.85			359.84			46.63			0		1
11/13/19 6:55	226966.1			63.7			60.84			34.39			54.03			0		1
11/13/19 6:56	246220.1			6			58.65			3.53			56.67			0		1
11/13/19 6:57	274639			2.4			51.52			1.59			55.48			0		1
11/13/19 6:58	293122.8			2.2			36.54			1.52			41.83			0		1
11/13/19 6:59	294971.2			2.1			22.54			1.48			25.97			0		1
11/13/19 7:00	294278			2.3			15.53			1.58			17.85			0		1
11/13/19 7:01	297512.7			2.2			12.75			1.53			14.84			0		1
11/13/19 7:02	310297.3			2			10.83			1.49			13.12			0		1
11/13/19 7:03	313069.9			1.9			8.45			1.44			10.34			0		1
11/13/19 7:04	313840.1			1.8			7.98			1.36			9.78			0		1
11/13/19 7:05	327548.9			1.7			7.29			1.35			9.32			0		1
11/13/19 7:06	332323.9			1.6			6.77			1.3			8.78			0		1
11/13/19 7:07	332940.1			1.6			6.25			1.25			8.13			0		1
11/13/19 7:08	335096.5			1.5			6.25			1.19			8.18			0		1
11/13/19 7:09	342104.9			1.4			5.99			1.14			8			0		1
11/13/19 7:10	347727.1			1.4			5.46			1.16			7.41			0		1
11/13/19 7:11	361204.9			1.3			5.36			1.15			7.57			0		1
11/13/19 7:12	369137.6			1.3			4.63			1.11			6.67			0		1
11/13/19 7:13	371833.1			1.2			4.79			1.06			6.96			0		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/13/19 7:14	375067.8			1.2			4.9			1.05			7.18			1		
11/13/19 7:15	378148.4			1.1			5.08			0.98			7.51			1		
11/13/19 7:16	378533.5			1.1			5.17			0.98			7.65			1		
11/13/19 7:17	364208.5			1.1			5.54			0.94			7.88			1		
11/13/19 7:18	345108.6			1.1			6.17			0.88			8.31			1		
11/13/19 7:19	326316.7			1.1			6.16			0.89			7.85			1		
11/13/19 7:20	325777.6			1.1			6.16			0.88			7.84			1		
11/13/19 7:21	333710.2			1.1			6.08			0.91			7.92			1		
11/13/19 7:22	334788.4			1.2			6.08			0.92			7.95			1		
11/13/19 7:23	335019.5			1.2			6.08			0.92			7.95			1		
11/13/19 7:24	334865.4			1.2			6.08			0.92			7.96			1		
11/13/19 7:25	334249.3			1.2			5.01			0.92			6.53			1		
11/13/19 7:26	333325.1			1.2			3.31			0.92			4.3			1		
11/13/19 7:27	328781.2			1.2			2.77			0.91			3.56			1		
11/13/19 7:28	327240.9			1.1			2.73			0.89			3.49			1		
11/13/19 7:29	327471.9			1.1			2.77			0.83			3.55			1		
11/13/19 7:30	327703			1.1			2.77			0.83			3.55			1		
11/13/19 7:31	327625.9			1.1			2.77			0.84			3.55			1		
11/13/19 7:32	327086.8			1.1			2.68			0.83			3.43			1		
11/13/19 7:33	327086.8			1.1			2.59			0.83			3.31			1		
11/13/19 7:34	327471.9			1.1			2.41			0.83			3.09			1		
11/13/19 7:35	327471.9			1.1			2.23			0.83			2.86			1		
11/13/19 7:36	327317.9			1.1			2.06			0.83			2.63			1		
11/13/19 7:37	325854.6			1.1			1.97			0.83			2.51			1		
11/13/19 7:38	325315.5			1.2			1.79			0.9			2.27			1		
11/13/19 7:39	325084.4			1.2			1.7			0.9			2.16			1		
11/13/19 7:40	324930.4			1.2			1.61			0.9			2.04			0		
11/13/19 7:41	325084.4			1.2			1.61			0.9			2.04			0		
11/13/19 7:42	324391.3			1.2			1.61			0.89			2.04			0		
11/13/19 7:43	324391.3			1.2			1.52			0.9			1.93			0		
11/13/19 7:44	324622.3			1.2			1.61			0.9			2.04			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 23:44	296357.5			0.9			1.72			0.65			2.03			0		
11/14/19 23:45	297050.6			0.9			1.72			0.65			2.02			0		
11/14/19 23:46	296742.5			0.9			1.72			0.65			2.02			0		
11/14/19 23:47	296742.5			0.9			1.63			0.65			1.92			0		
11/14/19 23:48	296357.5			0.9			1.72			0.64			2.02			0		
11/14/19 23:49	296665.5			0.9			1.72			0.65			2.03			1		
11/14/19 23:50	285113.1			0.9			1.72			0.62			1.95			1		
11/14/19 23:51	262316.4			0.9			2			0.57			2.07			1		
11/14/19 23:52	238518.5			0.9			5.99			0.54			5.67			1		
11/14/19 23:53	218494.3			0.9			9.34			0.47			8.08			1		
11/14/19 23:54	192077.8			0.7			15.49			0.34			11.84			1		
11/14/19 23:55	168433.9			4			18.05			1.64			12.16			1		
11/14/19 23:56	149257			237.5			19.58			86.01			11.67			1		
11/14/19 23:57	131081.2			1313.7			20.03			419.04			10.51			1		
11/14/19 23:58	6623.4			1870.1			21.1			45.63			0.85			1		
11/14/19 23:59	0			0			23.01			18.21			0.2			0		
11/15/19 0:00	0			0			0.2			0			0			0		
11/15/19 0:01	0			0			0.1			0			0			0		
11/15/19 0:02	0			0			0.1			0			0			0		
11/15/19 0:03	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 5:38	0			0			0			0			0			0		
11/21/19 5:39	0			0			0			0			0			0		
11/21/19 5:40	0			0			0			0			0			0		
11/21/19 5:41	0			0			0			0			0			0		
11/21/19 5:42	0			0			0			0			0			0		
11/21/19 5:43	0			0.5			0			0			0			0		1
11/21/19 5:44	0			0.5			0			0			0			0		1
11/21/19 5:45	4389.9			39.3			29.5			0.45			0.55			0		1
11/21/19 5:46	31037.4			609.8			16.66			44.91			2.02			0		1
11/21/19 5:47	55374.5			490.4			21.63			64.43			4.68			0		1
11/21/19 5:48	105742.9			293.2			25.96			73.58			10.72			0		1
11/21/19 5:49	134855			149.5			37.37			47.98			19.74			0		1
11/21/19 5:50	137396.5			174.1			52.31			56.92			28.16			0		1
11/21/19 5:51	156265.4			1883.4			38.06			698.17			23.22			0		1
11/21/19 5:52	177598.8			1860.1			39.74			784.02			27.57			0		1
11/21/19 5:53	200780.6			876.4			49.02			418.44			38.52			0		1
11/21/19 5:54	225656.8			109.7			58.2			58.83			51.37			0		1
11/21/19 5:55	245603.9			7.4			61.6			4.34			59.18			0		1
11/21/19 5:56	273098.6			2.7			58.89			1.74			62.9			0		1
11/21/19 5:57	297358.7			2.4			46.43			1.71			54.05			0		1
11/21/19 5:58	316612.7			2.3			27.39			1.72			33.9			0		1
11/21/19 5:59	335096.5			2.5			15.65			1.98			20.53			0		1
11/21/19 6:00	352348.1			2.6			13.6			2.14			18.71			0		1
11/21/19 6:01	370369.8			2.4			10.76			2.14			15.56			0		1
11/21/19 6:02	392165.3			2.2			9.12			2.08			13.98			0		1
11/21/19 6:03	410957.2			2			8.35			1.95			13.4			0		1
11/21/19 6:04	417965.7			1.8			7.44			1.8			12.15			0		1
11/21/19 6:05	419737.1			1.6			7.08			1.63			11.6			0		1
11/21/19 6:06	419660			1.5			6.72			1.54			11.02			0		1
11/21/19 6:07	419814.1			1.6			6.36			1.56			10.43			0		1
11/21/19 6:08	419352			1.5			6.27			1.47			10.27			0		1
11/21/19 6:09	418735.8			1.5			6.27			1.47			10.25			0		1
11/21/19 6:10	417580.6			1.4			6.08			1.37			9.93			0		1
11/21/19 6:11	417195.5			1.3			5.99			1.28			9.76			0		1
11/21/19 6:12	416348.3			1.3			5.9			1.27			9.59			0		1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 6:13	416040.3			1.2			5.9			1.19			9.6			1		
11/21/19 6:14	415578.2			1.2			5.81			1.18			9.42			1		
11/21/19 6:15	415347.1			1.2			5.81			1.18			9.42			1		
11/21/19 6:16	415347.1			1.1			5.81			1.09			9.44			1		
11/21/19 6:17	414808			1.1			5.9			1.09			9.56			1		
11/21/19 6:18	414500			1.1			5.9			1.09			9.56			1		
11/21/19 6:19	414037.9			1.1			5.99			1.09			9.69			1		
11/21/19 6:20	413806.8			1.1			6.08			1.09			9.84			1		
11/21/19 6:21	413883.8			1.1			6.18			1.09			9.99			1		
11/21/19 6:22	413729.8			1.1			5.99			1.09			9.69			1		
11/21/19 6:23	413267.7			1.1			4.06			1.08			6.55			1		
11/21/19 6:24	413036.7			1.1			2.67			1.08			4.31			1		
11/21/19 6:25	413113.7			1.1			2.58			1.08			4.16			1		
11/21/19 6:26	412882.6			1.1			2.58			1.09			4.17			1		
11/21/19 6:27	412574.6			1.2			2.67			1.17			4.31			1		
11/21/19 6:28	412497.6			1.2			2.86			1.17			4.6			1		
11/21/19 6:29	412728.6			1.2			2.86			1.18			4.62			1		
11/21/19 6:30	412651.6			1.1			2.86			1.09			4.61			1		
11/21/19 6:31	412343.5			1.1			2.58			1.08			4.16			1		
11/21/19 6:32	412266.5			1.1			2.4			1.08			3.86			1		
11/21/19 6:33	412035.4			1.1			2.12			1.08			3.42			1		
11/21/19 6:34	411958.4			1.1			1.94			1.08			3.11			1		
11/21/19 6:35	411727.4			1.1			1.84			1.08			2.96			1		
11/21/19 6:36	411804.4			1.1			1.75			1.08			2.82			1		
11/21/19 6:37	411804.4			1.1			1.75			1.09			2.83			0		
11/21/19 6:38	411111.3			1.1			1.66			1.08			2.67			0		
11/21/19 6:39	411727.4			1.1			1.66			1.08			2.68			0		
11/21/19 6:40	411419.3			1.1			1.66			1.08			2.67			0		
11/21/19 6:41	411650.4			1.1			1.66			1.08			2.67			0		

CT1 SUSD EVENT 6

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/19 23:51	399250.8			1			1.75			0.97			2.75			0		
11/22/19 23:52	380689.9			1			1.82			0.91			2.72			0		
11/22/19 23:53	362052.1			1.1			1.88			0.93			2.68			0		
11/22/19 23:54	338485.2			1.1			2.03			0.86			2.7			0		
11/22/19 23:55	313917.1			1.1			2.11			0.86			2.6			0		
11/22/19 23:56	301286.5			1.1			2.03			0.82			2.4			1		
11/22/19 23:57	280800.3			1.1			1.76			0.77			1.95			1		
11/22/19 23:58	258773.7			1.1			2.72			0.68			2.78			1		
11/22/19 23:59	22180.6			1			7.02			0.06			0.69			1		
11/23/19 0:00	0			0			11.11			0.12			0.11			0		
11/23/19 0:01	0			0			0.1			0			0			0		
11/23/19 0:02	0			0			0.1			0			0			0		
11/23/19 0:03	0			0			0.1			0			0			0		
11/23/19 0:04	0			0			0			0			0			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 5:58	0			0			0			0			0			0		
11/26/19 5:59	0			0			0			0			0			0		
11/26/19 6:00	0			0			0			0			0			0		
11/26/19 6:01	0			0			0			0			0			0		
11/26/19 6:02	0			0			0			0			0			0		
11/26/19 6:03	0			0.4			0			0			0			0		
11/26/19 6:04	0			1.4			0.1			0			0			0		
11/26/19 6:05	8240.7			790.6			19.67			16.99			0.7			1		
11/26/19 6:06	38431			593.8			18.05			54.76			2.74			1		
11/26/19 6:07	73550.3			419.9			23.6			73.69			6.82			1		
11/26/19 6:08	125690.1			249.9			27.14			74.72			13.36			1		
11/26/19 6:09	138474.7			116.3			46.49			38.47			25.3			1		
11/26/19 6:10	143403.7			838.2			47.58			285.19			26.64			1		
11/26/19 6:11	148024.7			2008.5			43.01			709			24.99			1		
11/26/19 6:12	164275.1			1945.2			45.36			758.06			29.09			1		
11/26/19 6:13	184299.2			1778.4			55.97			777.88			40.29			1		
11/26/19 6:14	208944.3			665.8			71.25			330.11			58.14			1		
11/26/19 6:15	232126.1			66.3			73.03			36.61			66.32			1		
11/26/19 6:16	252458.4			6.4			66.67			3.82			65.85			1		
11/26/19 6:17	279799			3			58.89			2			64.44			1		
11/26/19 6:18	304136.1			2.6			40.24			1.89			47.85			1		
11/26/19 6:19	323236			2.5			23.69			1.89			29.9			1		
11/26/19 6:20	340718.7			2.6			13.08			2.08			17.43			1		
11/26/19 6:21	358817.4			2.6			10.52			2.19			14.77			1		
11/26/19 6:22	376531.1			2.4			8.81			2.13			12.99			1		
11/26/19 6:23	398711.7			2.1			7.24			2.03			11.3			1		
11/26/19 6:24	414654			1.9			6.35			1.88			10.33			1		
11/26/19 6:25	418889.9			1.7			6.08			1.66			9.99			1		
11/26/19 6:26	419583			1.5			5.9			1.45			9.69			1		
11/26/19 6:27	419429			1.4			5.81			1.36			9.51			1		
11/26/19 6:28	419352			1.3			5.63			1.27			9.23			1		
11/26/19 6:29	417195.5			1.2			5.54			1.17			9.02			1		
11/26/19 6:30	400714.1			1.2			5.54			1.12			8.68			1		
11/26/19 6:31	381999.2			1.2			5.99			1.05			8.93			1		
11/26/19 6:32	373450.4			1.2			6.26			1.03			9.15			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 6:33	371756.1			1.2			5.72			1.03			8.32			1		
11/26/19 6:34	370754.9			1.2			5.63			1.02			8.16			1		
11/26/19 6:35	370292.8			1.2			5.54			1.03			8.06			1		
11/26/19 6:36	370292.8			1.1			5.54			0.94			8.01			1		
11/26/19 6:37	370292.8			1.1			5.45			0.94			7.89			1		
11/26/19 6:38	370061.8			1.1			5.45			0.94			7.89			1		
11/26/19 6:39	369137.6			1.1			5.54			0.94			7.99			1		
11/26/19 6:40	371756.1			1.1			5.63			0.96			8.2			1		
11/26/19 6:41	373065.4			1.1			5.54			0.97			8.09			1		
11/26/19 6:42	373604.5			1.1			5.63			0.97			8.24			1		
11/26/19 6:43	375760.9			1.1			4.99			0.97			7.34			1		
11/26/19 6:44	376454.1			1.1			3.27			0.98			4.81			1		
11/26/19 6:45	376762.1			1.1			2.72			0.97			4.01			1		
11/26/19 6:46	379919.8			1.1			2.72			0.98			4.05			1		
11/26/19 6:47	377070.2			1.1			2.72			0.98			4.02			1		
11/26/19 6:48	368829.5			1.1			2.77			0.94			4.01			1		
11/26/19 6:49	363746.4			1.2			2.86			1			4.07			1		
11/26/19 6:50	361281.9			1.2			2.77			1			3.91			1		
11/26/19 6:51	360896.8			1.2			2.59			1			3.65			1		
11/26/19 6:52	364901.7			1.3			2.32			1.09			3.32			1		
11/26/19 6:53	372295.2			1.3			2.09			1.12			3.03			1		
11/26/19 6:54	375221.8			1.3			1.91			1.13			2.79			1		
11/26/19 6:55	386543.2			1.2			1.72			1.08			2.61			1		
11/26/19 6:56	395323			1.2			1.82			1.11			2.8			1		
11/26/19 6:57	403332.7			1.2			1.84			1.15			2.9			0		
11/26/19 6:58	410726.2			1.2			1.84			1.17			2.96			0		
11/26/19 6:59	412574.6			1.2			1.84			1.18			2.98			0		
11/26/19 7:00	412959.7			1.1			1.75			1.08			2.82			0		
11/26/19 7:01	412035.4			1.1			1.75			1.08			2.82			0		

CT1 SUSD EVENT 8

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 23:53	362899.3			0.6			2			0.55			2.83			0		
12/04/19 23:54	341796.9			0.7			2.06			0.58			2.75			0		
12/04/19 23:55	328704.2			0.7			2.11			0.55			2.72			0		
12/04/19 23:56	319000.2			0.8			2.11			0.6			2.63			0		
12/04/19 23:57	299207.1			0.8			2.03			0.56			2.37			0		
12/04/19 23:58	280107.1			0.8			1.88			0.54			2.06			1		
12/04/19 23:59	260314			0.7			2.18			0.45			2.23			1		
12/05/19 0:00	236439			0.7			5.81			0.37			5.41			1		
12/05/19 0:01	215182.6			0.5			9.24			0.25			7.83			1		
12/05/19 0:02	189305.3			0.3			14.91			0.15			11.18			1		
12/05/19 0:03	165969.4			3.4			17.1			1.35			11.24			1		
12/05/19 0:04	145483.2			227.2			18.24			79.58			10.51			1		
12/05/19 0:05	127307.4			1232.5			18.94			380.17			9.62			1		
12/05/19 0:06	10166.1			1893.4			19.49			65.27			1.11			1		
12/05/19 0:07	0			0			17.04			34.65			0.31			0		
12/05/19 0:08	0			0			0.2			0			0			0		
12/05/19 0:09	0			0			0.1			0			0			0		
12/05/19 0:10	0			0			0.1			0			0			0		
12/05/19 0:11	0			0			0.1			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 5:38	0			0			0			0			0			0		
10/21/19 5:39	0			0			0			0			0			0		
10/21/19 5:40	0			0			0			0			0			0		
10/21/19 5:41	0			0			0			0			0			0		
10/21/19 5:42	4852			0			0			0			0			0		
10/21/19 5:43	3003.6			0.6			0			0			0			0		1
10/21/19 5:44	20101.2			0.6			0			0			0			0		1
10/21/19 5:45	35350.3			2			0.3			0			0			0		1
10/21/19 5:46	46209.6			573.7			17.25			62.02			3.07			1		1
10/21/19 5:47	55759.6			498.1			18.32			65			3.93			1		1
10/21/19 5:48	77324			351.6			23.9			63.6			7.11			1		1
10/21/19 5:49	121069.1			224.2			25.75			63.49			12			1		1
10/21/19 5:50	135471.1			109.6			44.25			34.74			23.08			1		1
10/21/19 5:51	143557.8			373.2			49.97			125.3			27.61			1		1
10/21/19 5:52	161502.5			1866.8			38.35			705.37			23.85			1		1
10/21/19 5:53	180756.5			1337			42.78			565.35			29.77			1		1
10/21/19 5:54	202321			349			52.67			165.13			41.02			1		1
10/21/19 5:55	224116.5			28.7			55.74			15.07			48.09			1		1
10/21/19 5:56	242908.4			3.6			63.08			2.06			58.98			1		1
10/21/19 5:57	268477.7			2.6			65.41			1.66			67.61			1		1
10/21/19 5:58	290119.2			2.4			47.29			1.65			52.83			1		1
10/21/19 5:59	307370.8			2.4			26.81			1.75			31.72			1		1
10/21/19 6:00	324237.3			2.7			20.3			2.04			25.34			1		1
10/21/19 6:01	341642.8			2.7			16.4			2.15			21.57			1		1
10/21/19 6:02	355659.8			2.5			13.12			2.05			17.97			1		1
10/21/19 6:03	372141.2			2.2			11.8			1.95			16.91			1		1
10/21/19 6:04	392165.3			2			11.16			1.83			16.86			1		1
10/21/19 6:05	410957.2			1.9			10.23			1.86			16.19			1		1
10/21/19 6:06	409570.9			1.8			11.15			1.68			17.59			1		1
10/21/19 6:07	407799.6			1.8			10.88			1.67			17.08			1		1
10/21/19 6:08	408723.8			1.7			10.51			1.59			16.54			1		1
10/21/19 6:09	408184.7			1.6			10.42			1.5			16.37			1		1
10/21/19 6:10	409185.9			1.6			10.42			1.5			16.41			1		1
10/21/19 6:11	408877.8			1.5			10.51			1.41			16.54			1		1
10/21/19 6:12	407029.4			1.5			10.79			1.4			16.9			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 6:13	405874.2			1.5			10.88			1.4			17			1		
10/21/19 6:14	405412.1			1.5			10.97			1.4			17.12			1		
10/21/19 6:15	404873			1.5			11.06			1.4			17.24			1		
10/21/19 6:16	405181			1.5			11.25			1.4			17.54			1		
10/21/19 6:17	405951.2			1.5			11.43			1.4			17.86			1		
10/21/19 6:18	404950			1.4			11.71			1.31			18.25			1		
10/21/19 6:19	403486.7			1.4			12.08			1.31			18.76			1		
10/21/19 6:20	403255.6			1.4			12.35			1.3			19.18			1		
10/21/19 6:21	403948.8			1.4			10.79			1.31			16.77			1		
10/21/19 6:22	404795.9			1.4			5.07			1.31			7.9			1		
10/21/19 6:23	406875.4			1.4			3.78			1.32			5.92			1		
10/21/19 6:24	405181			1.4			3.5			1.31			5.46			1		
10/21/19 6:25	405951.2			1.4			3.32			1.31			5.19			1		
10/21/19 6:26	403640.7			1.4			3.04			1.31			4.73			1		
10/21/19 6:27	404564.9			1.4			2.77			1.31			4.31			1		
10/21/19 6:28	405335.1			1.4			2.43			1.33			3.8			1		
10/21/19 6:29	405566.1			1.4			2.12			1.31			3.31			1		
10/21/19 6:30	405104			1.4			1.94			1.31			3.02			1		
10/21/19 6:31	406490.3			1.4			1.75			1.31			2.74			1		
10/21/19 6:32	404333.8			1.4			1.66			1.31			2.58			1		
10/21/19 6:33	405181			1.4			1.48			1.31			2.3			1		
10/21/19 6:34	403794.8			1.4			1.38			1.31			2.15			0		
10/21/19 6:35	403255.6			1.4			1.38			1.3			2.15			0		
10/21/19 6:36	403024.6			1.4			1.29			1.3			2			0		
10/21/19 6:37	402331.4			1.4			1.29			1.3			2			0		
10/21/19 6:38	405104			1.4			1.2			1.31			1.87			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 18:45	378533.5			0.7			1.75			0.65			2.55			0		
10/24/19 18:46	376146			0.7			1.75			0.65			2.54			0		
10/24/19 18:47	376069			0.7			1.75			0.65			2.54			0		
10/24/19 18:48	373450.4			0.7			1.66			0.64			2.39			0		
10/24/19 18:49	374913.8			0.8			1.66			0.73			2.4			0		
10/24/19 18:50	373373.4			0.8			1.66			0.72			2.39			1		
10/24/19 18:51	359895.6			0.8			1.75			0.7			2.43			1		
10/24/19 18:52	339563.4			0.8			1.82			0.65			2.37			1		
10/24/19 18:53	317690.9			0.8			2.23			0.6			2.73			1		
10/24/19 18:54	296203.4			0.9			2.55			0.61			2.91			1		
10/24/19 18:55	275640.2			0.9			2.73			0.57			2.9			1		
10/24/19 18:56	255153.9			0.9			3.09			0.54			3.03			1		
10/24/19 18:57	233512.4			0.9			4.89			0.5			4.39			1		
10/24/19 18:58	217262.1			0.8			8.8			0.39			7.36			1		
10/24/19 18:59	192539.9			0.6			21.01			0.28			15.57			1		
10/24/19 19:00	170898.4			0.6			24.39			0.23			16.05			1		
10/24/19 19:01	150797.3			7.4			26.55			2.62			15.41			1		
10/24/19 19:02	133776.8			631.6			28.47			197.65			14.66			1		
10/24/19 19:03	77863.1			1659.2			28.83			302.33			8.64			1		
10/24/19 19:04	0			0			31.22			0			0			0		
10/24/19 19:05	0			0			11.8			0			0			0		
10/24/19 19:06	0			0			0.2			0			0			0		
10/24/19 19:07	0			0			0.1			0			0			0		
10/24/19 19:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 13:38	0			0			0			0			0			0		
10/25/19 13:39	0			0			0			0			0			0		
10/25/19 13:40	0			0			0			0			0			0		
10/25/19 13:41	0			0			0			0			0			0		
10/25/19 13:42	0			0			0			0			0			0		
10/25/19 13:43	10089.1			0			0			0			0			0		1
10/25/19 13:44	21872.5			0			0			0			0			0		1
10/25/19 13:45	34811.2			135.7			82.6			11.06			11.08			0		1
10/25/19 13:46	45054.3			458			23.23			48.29			4.03			0		1
10/25/19 13:47	55759.6			348.7			25.67			45.5			5.51			0		1
10/25/19 13:48	78248.2			202.6			34			37.09			10.24			0		1
10/25/19 13:49	117988.5			112.4			42.58			31.01			19.34			0		1
10/25/19 13:50	129925.9			37.2			60.63			11.32			30.33			0		1
10/25/19 13:51	135779.2			18.2			65.62			5.79			34.3			0		1
10/25/19 13:52	149025.9			1637.2			59			570.6			33.84			0		1
10/25/19 13:53	170128.3			994			60.31			395.61			39.5			0		1
10/25/19 13:54	191615.7			192.3			62.02			86.16			45.74			0		1
10/25/19 13:55	213026.2			11.9			63.14			5.94			51.78			0		1
10/25/19 13:56	234667.7			2.2			67.74			1.18			61.19			0		1
10/25/19 13:57	258080.5			1.8			61.85			1.11			61.45			0		1
10/25/19 13:58	275178.1			1.8			40.29			1.13			42.68			0		1
10/25/19 13:59	280184.1			1.8			20.6			1.19			22.23			0		1
10/25/19 14:00	288270.8			1.8			16.34			1.22			18.13			0		1
10/25/19 14:01	290427.2			1.7			16.16			1.17			18.06			0		1
10/25/19 14:02	302441.7			1.5			15.34			1.09			17.86			0		1
10/25/19 14:03	310605.4			1.4			13.86			1.04			16.57			0		1
10/25/19 14:04	316766.7			1.5			12.16			1.08			14.83			0		1
10/25/19 14:05	324468.3			1.4			11.34			1.05			14.17			0		1
10/25/19 14:06	338177.1			1.3			9.86			1.02			12.84			0		1
10/25/19 14:07	346032.8			1.1			9.4			0.9			12.53			0		1
10/25/19 14:08	347727.1			1			9.31	X		0.82			12.47	X		0		1
10/25/19 14:09	349575.5			0.9			9.22			0.75			12.41			0		1
10/25/19 14:10	351346.9			0.9			9.31			0.76			12.6			0		1
10/25/19 14:11	350037.6			0.9			9.31			0.75			12.55			0		1
10/25/19 14:12	353041.2			0.8			9.31			0.69			12.65			0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 14:13	351577.9			0.8			9.5			0.68			12.85			1		
10/25/19 14:14	350268.7			0.8			9.59			0.68			12.93			1		
10/25/19 14:15	351423.9			0.8			9.68			0.68			13.09			1		
10/25/19 14:16	350268.7			0.8			9.59			0.68			12.93			1		
10/25/19 14:17	349883.6			0.8			9.77			0.68			13.16			1		
10/25/19 14:18	349421.5			0.8			9.86			0.68			13.27			1		
10/25/19 14:19	343029.1			0.8			9.86			0.67			13.03			1		
10/25/19 14:20	324699.3			0.8			6.9			0.62			8.62			1		
10/25/19 14:21	316458.6			0.8			4.29			0.6			5.23			1		
10/25/19 14:22	319154.2			0.9			3.75			0.67			4.61			1		
10/25/19 14:23	319000.2			0.9			3.18			0.68			3.9			1		
10/25/19 14:24	308063.9			0.9			3.09			0.65			3.66			1		
10/25/19 14:25	302133.7			0.9			2.86			0.63			3.33			1		
10/25/19 14:26	301517.5			0.9			2.68			0.63			3.11			1		
10/25/19 14:27	299361.1			0.9			2.59			0.63			2.99			1		
10/25/19 14:28	297050.6			0.9			2.41			0.62			2.76			1		
10/25/19 14:29	296357.5			0.9			2.23			0.62			2.55			1		
10/25/19 14:30	298513.9			0.9			2.06			0.62			2.36			1		
10/25/19 14:31	297512.7			0.9			1.97			0.62			2.25			1		
10/25/19 14:32	296742.5			0.9			1.79			0.62			2.04			1		
10/25/19 14:33	295125.2			0.9			1.7			0.62			1.93			1		
10/25/19 14:34	295510.3			0.8			1.52			0.56			1.73			0		
10/25/19 14:35	294894.2			0.8			1.43			0.56			1.62			0		
10/25/19 14:36	292891.8			0.8			1.34			0.55			1.51			0		
10/25/19 14:37	294355			0.8			1.34			0.55			1.52			0		
10/25/19 14:38	295510.3			0.8			1.34			0.56			1.53			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/25/19 18:45	288270.8			0.8			1.63			0.55			1.81			0		
10/25/19 18:46	287269.6			0.8			1.63			0.55			1.81			0		
10/25/19 18:47	288578.8			0.8			1.63			0.55			1.82			0		
10/25/19 18:48	287115.5			0.8			1.63			0.55			1.81			0		
10/25/19 18:49	287192.6			0.8			1.72			0.55			1.91			0		
10/25/19 18:50	286037.3			0.8			1.72			0.55			1.9			1		
10/25/19 18:51	267630.5			0.8			1.72			0.51			1.78			1		
10/25/19 18:52	248299.5			0.7			1.82			0.42			1.74			1		
10/25/19 18:53	229969.7			0.7			4.68			0.4			4.15			1		
10/25/19 18:54	209406.4			0.7			8.46			0.34			6.82			1		
10/25/19 18:55	186763.7			0.5			17.08			0.23			12.28			1		
10/25/19 18:56	163273.9			2.2			20.01			0.84			12.58			1		
10/25/19 18:57	144559			122.3			22.55			41.37			12.55			1		
10/25/19 18:58	128385.6			860.8			25.26			258.58			12.49			1		
10/25/19 18:59	49675.3			1821.5			27.59			211.62			5.28			1		
10/25/19 19:00	0			0			36.58			0			0			0		
10/25/19 19:01	0			0			11.8			0			0			0		
10/25/19 19:02	0			0			0.1			0			0			0		
10/25/19 19:03	0			0			0.1			0			0			0		
10/25/19 19:04	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 3:39	0			0			0			0			0			0		
10/29/19 3:40	0			0			0			0			0			0		
10/29/19 3:41	0			0			0			0			0			0		
10/29/19 3:42	0			0			0			0			0			0		
10/29/19 3:43	0			0			0			0			0			0		
10/29/19 3:44	6238.3			0.1			0			0			0			1		
10/29/19 3:45	26262.4			0			0			0			0			1		
10/29/19 3:46	38431			73.8			29.5			6.64			4.37			1		
10/29/19 3:47	48597.1			573.8			15.86			65.25			2.97			1		
10/29/19 3:48	59533.3			494.9			19.67			68.91			4.51			1		
10/29/19 3:49	90185.7			335.7			25.15			70.78			8.73			1		
10/29/19 3:50	145637.2			202.7			25.48			69.07			14.29			1		
10/29/19 3:51	139861			432.9			45.37			141.68			24.44			1		
10/29/19 3:52	136703.3			1664.8			40.43			532.54			21.29			1		
10/29/19 3:53	134855			1987.7			43.7			626.93			22.68			1		
10/29/19 3:54	134007.8			2052.2			51.39			643.14			26.5			1		
10/29/19 3:55	133160.6			2053.6			61.09			639.88			31.33			1		
10/29/19 3:56	131312.2			2053.6			68.33			630.69			34.53			1		
10/29/19 3:57	130234			2122			71.39			646.49			35.79			1		
10/29/19 3:58	128308.6			2121.8			65.29			636.93			32.26			1		
10/29/19 3:59	127769.5			2121.2			61.36			633.9			30.18			1		
10/29/19 4:00	127384.4			2196.6			62.66			654.46			30.73			1		
10/29/19 4:01	136164.2			2198.9			62.05			700.41			32.53			1		
10/29/19 4:02	11321.3			2126			64.51			56.15			2.8			1		
10/29/19 4:03	0			0			78.01			0			0			0		
10/29/19 4:04	0			0			1.1			0			0			0		
10/29/19 4:05	0			0			0.9			0			0			0		
10/29/19 4:06	0			0			0.7			0			0			0		
10/29/19 4:07	0			0			0.6			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 3:57	130234			2122			71.39			646.49			35.79			1		
10/29/19 3:58	128308.6			2121.8			65.29			636.93			32.26			1		
10/29/19 3:59	127769.5			2121.2			61.36			633.9			30.18			1		
10/29/19 4:00	127384.4			2196.6			62.66			654.46			30.73			1		
10/29/19 4:01	136164.2			2198.9			62.05			700.41			32.53			1		
10/29/19 4:02	11321.3			2126			64.51			56.15			2.8			1		
10/29/19 4:03	0			0			78.01			0			0			0		
10/29/19 4:04	0			0			1.1			0			0			0		
10/29/19 4:05	0			0			0.9			0			0			0		
10/29/19 4:06	0			0			0.7			0			0			0		
10/29/19 4:07	0			0			0.6			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 4:07	0			0			0.6			0			0			0		
10/29/19 4:08	0			0			0.5			0			0			0		
10/29/19 4:09	0			0			0.4			0			0			0		
10/29/19 4:10	0			0			0.3			0			0			0		
10/29/19 4:11	0			0			0.3			0			0			0		
10/29/19 4:12	14479			10.8			0.3			0			0			1		
10/29/19 4:13	29728.2			9.9			0.3			0			0			1		
10/29/19 4:14	41049.5			64.9			41.3			6.23			6.53			1		
10/29/19 4:15	51908.8			427.4			26.88			51.86			5.37			1		
10/29/19 4:16	66926.9			379.6			31.47			59.39			8.1			1		
10/29/19 4:17	108361.5			254.6			37.17			64.51			15.5			1		
10/29/19 4:18	141786.4			133.5			53.84			44.28			29.39			1		
10/29/19 4:19	134315.9			409.8			66.04			128.78			34.16			1		
10/29/19 4:20	131620.3			1869.9			54.58			575.54			27.64			1		
10/29/19 4:21	131543.3			2051.9			55.76			631.54			28.25			1		
10/29/19 4:22	130927.2			2051.9			55.38			628.33			27.91			1		
10/29/19 4:23	129925.9			2120.3			56.84			644.52			28.43			1		
10/29/19 4:24	136857.4			2120.3			56.64			678.7			29.84			1		
10/29/19 4:25	133699.7			2051.9			58.24			641.65			29.97			1		
10/29/19 4:26	133622.7			2051.9			56.34			641.19			28.97			1		
10/29/19 4:27	132467.5			2051.9			55.19			635.68			28.14			1		
10/29/19 4:28	132005.4			2051.9			54.24			633.84			27.58			1		
10/29/19 4:29	129694.9			2051.9			53.86			622.36			26.89			1		
10/29/19 4:30	129848.9			2120.3			55.26			644.05			27.63			1		
10/29/19 4:31	128924.7			2120.3			55.46			639.3			27.52			1		
10/29/19 4:32	126614.3			2120.3			56.25			627.91			27.41			1		
10/29/19 4:33	126537.2			2120.3			56.84			627.44			27.68			1		
10/29/19 4:34	93805.5			2193.4			59.41			481.16			21.45			1		
10/29/19 4:35	0			0			61.19			0			0			0		
10/29/19 4:36	0			0			88.5			0			0			0		
10/29/19 4:37	0			0			0.5			0			0			0		
10/29/19 4:38	0			0			0.4			0			0			0		
10/29/19 4:39	0			0			0.4			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 4:29	129694.9			2051.9			53.86			622.36			26.89			1		
10/29/19 4:30	129848.9			2120.3			55.26			644.05			27.63			1		
10/29/19 4:31	128924.7			2120.3			55.46			639.3			27.52			1		
10/29/19 4:32	126614.3			2120.3			56.25			627.91			27.41			1		
10/29/19 4:33	126537.2			2120.3			56.84			627.44			27.68			1		
10/29/19 4:34	93805.5			2193.4			59.41			481.16			21.45			1		
10/29/19 4:35	0			0			61.19			0			0			0		
10/29/19 4:36	0			0			88.5			0			0			0		
10/29/19 4:37	0			0			0.5			0			0			0		
10/29/19 4:38	0			0			0.4			0			0			0		
10/29/19 4:39	0			0			0.4			0			0			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 5:39	0			0			0			0			0			0		
10/29/19 5:40	0			0			0			0			0			0		
10/29/19 5:41	0			0			0			0			0			0		
10/29/19 5:42	0			0			0			0			0			0		
10/29/19 5:43	0			0			0			0			0			0		
10/29/19 5:44	11706.4			0.7			0			3.25			7.71			1		
10/29/19 5:45	25338.3			0.7			0			48.1			4.49			1		
10/29/19 5:46	37737.8			36.9			53.1			57.28			7.04			1		
10/29/19 5:47	48058			428.1			24.26			59.84			12.69			1		
10/29/19 5:48	61304.7			399.2			29.83			51.29			25.47			1		
10/29/19 5:49	97964.3			261.1			33.63			249.97			31.09			1		
10/29/19 5:50	144867			151.3			45.66			0			0			1		
10/29/19 5:51	135471.1			788.6			59.59			0			0			1		
10/29/19 5:52	0			1900.7			53.99			0			0			1		
10/29/19 5:53	0			0			62.93			0			0			0		
10/29/19 5:54	0			0			0.5			0			0			0		
10/29/19 5:55	0			0			0.4			0			0			0		
10/29/19 5:56	0			0			0.3			0			0			0		
10/29/19 5:57	0			0			0.2			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 5:46	37737.8			36.9			53.1			3.25			7.71			1		
10/29/19 5:47	48058			428.1			24.26			48.1			4.49			1		
10/29/19 5:48	61304.7			399.2			29.83			57.28			7.04			1		
10/29/19 5:49	97964.3			261.1			33.63			59.84			12.69			1		
10/29/19 5:50	144867			151.3			45.66			51.29			25.47			1		
10/29/19 5:51	135471.1			788.6			59.59			249.97			31.09			1		
10/29/19 5:52	0			1900.7			53.99			0			0			1		
10/29/19 5:53	0			0			62.93			0			0			0		
10/29/19 5:54	0			0			0.5			0			0			0		
10/29/19 5:55	0			0			0.4			0			0			0		
10/29/19 5:56	0			0			0.3			0			0			0		
10/29/19 5:57	0			0			0.2			0			0			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 8:59	0			0			0			0			0			0		
10/29/19 9:00	0			0			0			0			0			0		
10/29/19 9:01	0			0			0			0			0			0		
10/29/19 9:02	0			0			0			0			0			0		
10/29/19 9:03	0			0			0			0			0			0		
10/29/19 9:04	12014.5			0.2			0			5.72			6.63			1		
10/29/19 9:05	28649.9			0.4			0			63.27			5.39			1		
10/29/19 9:06	40818.5			59.8			42.14			59.92			7.38			1		
10/29/19 9:07	50830.5			532.3			27.53			63.82			14.89			1		
10/29/19 9:08	62922.1			406.8			30.43			49.35			29.53			1		
10/29/19 9:09	101584.1			268.5			38.06			256.15			32.22			1		
10/29/19 9:10	146638.4			143.9			52.33			161.31			8.39			1		
10/29/19 9:11	135548.1			808.1			61.77			0			0			0		
10/29/19 9:12	36813.6			1871.7			59.18			0			0			0		
10/29/19 9:13	0			0			64.9			0			0			0		
10/29/19 9:14	0			0			1			0			0			0		
10/29/19 9:15	0			0			0.7			0			0			0		
10/29/19 9:16	0			0			0.5			0			0			0		
10/29/19 9:17	0			0			0.5			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 9:07	50830.5			532.3			27.53			63.27			5.39			1		
10/29/19 9:08	62922.1			406.8			30.43			59.92			7.38			1		
10/29/19 9:09	101584.1			268.5			38.06			63.82			14.89			1		
10/29/19 9:10	146638.4			143.9			52.33			49.35			29.53			1		
10/29/19 9:11	135548.1			808.1			61.77			256.15			32.22			1		
10/29/19 9:12	36813.6			1871.7			59.18			161.31			8.39			1		
10/29/19 9:13	0			0			64.9			0			0			0		
10/29/19 9:14	0			0			1			0			0			0		
10/29/19 9:15	0			0			0.7			0			0			0		
10/29/19 9:16	0			0			0.5			0			0			0		
10/29/19 9:17	0			0			0.5			0			0			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 10:54	0			0			0			0			0			0		
10/29/19 10:55	0			0			0			0			0			0		
10/29/19 10:56	0			0			0			0			0			0		
10/29/19 10:57	0			0			0			0			0			0		
10/29/19 10:58	4543.9			0			0			0			0			0		
10/29/19 10:59	15326.2			0.4			0			0			0			0		
10/29/19 11:00	30729.4			1.2	X		0.2	X		0	X		0	X		1		
10/29/19 11:01	41896.7			522.7	X		43.07	X		51.25	X		6.95	X		1		
10/29/19 11:02	52524.9			445.6	X		28.57	X		54.76	X		5.78	X		1		
10/29/19 11:03	68621.2			315.8	X		38.19	X		50.69	X		10.09	X		1		
10/29/19 11:04	115138.9			203.4	X		43.55	X		54.78	X		19.3	X		1		
10/29/19 11:05	142094.5			109.7	X		63.01	X		36.48	X		34.47	X		1		
10/29/19 11:06	109362.7			1053.2	X		64.03	X		269.46	X		26.96	X		1		
10/29/19 11:07	0			0	X		63.98	X		0	X		0	X		0		
10/29/19 11:08	0			0	X		224.2	X		0	X		0	X		0		
10/29/19 11:09	0			0	X		0.8	X		0	X		0	X		0		
10/29/19 11:10	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 11:11	0			0	X		0.5	X		0	X		0	X		0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:01	41896.7			522.7	X		43.07	X		51.25	X		6.95	X		1		
10/29/19 11:02	52524.9			445.6	X		28.57	X		54.76	X		5.78	X		1		
10/29/19 11:03	68621.2			315.8	X		38.19	X		50.69	X		10.09	X		1		
10/29/19 11:04	115138.9			203.4	X		43.55	X		54.78	X		19.3	X		1		
10/29/19 11:05	142094.5			109.7	X		63.01	X		36.48	X		34.47	X		1		
10/29/19 11:06	109362.7			1053.2	X		64.03	X		269.46	X		26.96	X		1		
10/29/19 11:07	0			0	X		63.98	X		0	X		0	X		0		
10/29/19 11:08	0			0	X		224.2	X		0	X		0	X		0		
10/29/19 11:09	0			0	X		0.8	X		0	X		0	X		0		
10/29/19 11:10	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 11:11	0			0	X		0.5	X		0	X		0	X		0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:12	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 11:13	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 11:14	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:15	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:16	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:17	0			4	X		0.2	X		0	X		0	X		0		1
10/29/19 11:18	0			0	X		0.1	X		0	X		0	X		0		
10/29/19 11:19	0			0	X		59	X		0	X		0	X		0		
10/29/19 11:20	0			0	X		22.13	X		0	X		0	X		0		
10/29/19 11:21	0			0	X		29.5	X		0	X		0	X		0		
10/29/19 11:22	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 11:12	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 11:13	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 11:14	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:15	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:16	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 11:17	0			4	X		0.2	X		0	X		0	X		0		1
10/29/19 11:18	0			0	X		0.1	X		0	X		0	X		0		
10/29/19 11:19	0			0	X		59	X		0	X		0	X		0		
10/29/19 11:20	0			0	X		22.13	X		0	X		0	X		0		
10/29/19 11:21	0			0	X		29.5	X		0	X		0	X		0		
10/29/19 11:22	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 17

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 12:51	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:52	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:53	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:54	0			0	X		0	X		0	X		0	X		0		
10/29/19 12:55	1232.3			0	X		0	X		0	X		0	X		0		
10/29/19 12:56	22565.7			0.3	X		0	X		0	X		0	X		0		1
10/29/19 12:57	33656			1.4	X		1	X		0	X		0	X		0		1
10/29/19 12:58	44746.3			496.1	X		38.12	X		51.97	X		6.57	X		0		1
10/29/19 12:59	54142.2			429.4	X		31.47	X		54.4	X		6.56	X		0		1
10/29/19 13:00	74936.5			273.6	X		41.3	X		47.95	X		11.91	X		0		1
10/29/19 13:01	130311			164.6	X		48.6	X		50.19	X		24.39	X		0		1
10/29/19 13:02	135625.1			129.8	X		67.09	X		41.17	X		35.02	X		0		1
10/29/19 13:03	0			1206	X		65.59	X		0	X		0	X		0		1
10/29/19 13:04	0			0	X		99.12	X		0	X		0	X		0		0
10/29/19 13:05	0			0	X		0.9	X		0	X		0	X		0		0
10/29/19 13:06	0			0	X		0.7	X		0	X		0	X		0		0
10/29/19 13:07	0			0	X		0.5	X		0	X		0	X		0		0
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		0

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 12:57	33656			1.4	X		1	X		0	X		0	X		1		
10/29/19 12:58	44746.3			496.1	X		38.12	X		51.97	X		6.57	X		1		
10/29/19 12:59	54142.2			429.4	X		31.47	X		54.4	X		6.56	X		1		
10/29/19 13:00	74936.5			273.6	X		41.3	X		47.95	X		11.91	X		1		
10/29/19 13:01	130311			164.6	X		48.6	X		50.19	X		24.39	X		1		
10/29/19 13:02	135625.1			129.8	X		67.09	X		41.17	X		35.02	X		1		
10/29/19 13:03	0			1206	X		65.59	X		0	X		0	X		1		
10/29/19 13:04	0			0	X		99.12	X		0	X		0	X		0		
10/29/19 13:05	0			0	X		0.9	X		0	X		0	X		0		
10/29/19 13:06	0			0	X		0.7	X		0	X		0	X		0		
10/29/19 13:07	0			0	X		0.5	X		0	X		0	X		0		
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 13:08	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 13:09	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:10	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:11	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:12	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:13	15711.3			2.1	X		0.2	X		0	X		0	X		0		1
10/29/19 13:14	29959.2			2.7	X		0.3	X		0	X		0	X		0		1
10/29/19 13:15	41511.6			15.9	X		47.79	X		1.55	X		7.64	X		0		1
10/29/19 13:16	51754.7			377.9	X		29.81	X		45.77	X		5.94	X		0		1
10/29/19 13:17	30267.3			277.3	X		39.44	X		19.61	X		4.59	X		0		1
10/29/19 13:18	0			0	X		39.61	X		0	X		0	X		0		0
10/29/19 13:19	0			0	X		12.54	X		0	X		0	X		0		0
10/29/19 13:20	0			0	X		0.4	X		0	X		0	X		0		0
10/29/19 13:21	0			0	X		0.3	X		0	X		0	X		0		0
10/29/19 13:22	0			0	X		0.2	X		0	X		0	X		0		0

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 13:12	0			0	X		0.2	X		0	X		0	X		0		
10/29/19 13:13	15711.3			2.1	X		0.2	X		0	X		0	X		1		
10/29/19 13:14	29959.2			2.7	X		0.3	X		0	X		0	X		1		
10/29/19 13:15	41511.6			15.9	X		47.79	X		1.55	X		7.64	X		1		
10/29/19 13:16	51754.7			377.9	X		29.81	X		45.77	X		5.94	X		1		
10/29/19 13:17	30267.3			277.3	X		39.44	X		19.61	X		4.59	X		1		
10/29/19 13:18	0			0	X		39.61	X		0	X		0	X		0		
10/29/19 13:19	0			0	X		12.54	X		0	X		0	X		0		
10/29/19 13:20	0			0	X		0.4	X		0	X		0	X		0		
10/29/19 13:21	0			0	X		0.3	X		0	X		0	X		0		
10/29/19 13:22	0			0	X		0.2	X		0	X		0	X		0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 7:17	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:18	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:19	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:20	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:21	0			0	X		0	X		0	X		0	X		0		
10/30/19 7:22	16250.4			0.1	X		0	X		0	X		0	X		0		1
10/30/19 7:23	31422.5			0.8	X		0	X		0	X		0	X		0		1
10/30/19 7:24	42897.9			5.9	X		25.81	X		0.59	X		4.26	X		0		1
10/30/19 7:25	53526.1			592.4	X		20.82	X		74.13	X		4.29	X		0		1
10/30/19 7:26	66618.8			451.7	X		26.55	X		70.37	X		6.81	X		0		1
10/30/19 7:27	104741.7			305.2	X		29.81	X		74.82	X		12.03	X		0		1
10/30/19 7:28	138089.6			159.6	X		45.4	X		51.54	X		24.14	X		0		1
10/30/19 7:29	139861			128	X		62.15	X		41.9	X		33.47	X		0		1
10/30/19 7:30	152260.6			1695	X		55.38	X		603.66	X		32.46	X		0		1
10/30/19 7:31	169589.2			1865.3	X		57.03	X		739.88	X		37.23	X		0		1
10/30/19 7:32	189536.3			1012.6	X		63.15	X		449.01	X		46.08	X		0		1
10/30/19 7:33	213103.2			172.1	X		60.4	X		85.78	X		49.56	X		0		1
10/30/19 7:34	231587			13.6	X		53.98	X		7.34	X		48.12	X		0		1
10/30/19 7:35	251996.3			2.7	X		47.87	X		1.57	X		46.43	X		0		1
10/30/19 7:36	277719.6			2.1	X		43.74	X		1.39	X		46.76	X		0		1
10/30/19 7:37	298051.8			2	X		39.64	X		1.41	X		45.49	X		0		1
10/30/19 7:38	302364.7			2.1	X		26.03	X		1.47	X		30.3	X		0		1
10/30/19 7:39	300978.4			2.2	X		20.82	X		1.53	X		24.13	X		0		1
10/30/19 7:40	299515.1			2.2	X		20.39	X		1.52	X		23.51	X		0		1
10/30/19 7:41	298590.9			2	X		19.73	X		1.41	X		22.67	X		0		1
10/30/19 7:42	298051.8			1.8	X		18.76	X		1.29	X		21.52	X		0		1
10/30/19 7:43	298513.9			1.8	X		18.06	X		1.25	X		20.75	X		0		1
10/30/19 7:44	297512.7			1.6	X		17.43	X		1.12	X		19.97	X		0		1
10/30/19 7:45	298051.8			1.5	X		16.81	X		1.06	X		19.29	X		0		1
10/30/19 7:46	297050.6			1.5	X		16.45	X		1.06	X		18.81	X		0		1
10/30/19 7:47	297358.7			1.4	X		16.09	X		0.99	X		18.42	X		0		1
10/30/19 7:48	309758.3			1.4	X		15.82	X		1.04	X		18.87	X		0		1
10/30/19 7:49	315765.5			1.3	X		15.73	X		0.99	X		19.13	X		0		1
10/30/19 7:50	316766.7			1.3	X		15.55	X		0.99	X		18.97	X		0		1
10/30/19 7:51	320848.5			1.3	X		15.02	X		0.94	X		18.55	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 7:52	319385.3			1.3	X		14.16	X		0.95	X		17.41	X		1		
10/30/19 7:53	320540.5			1.2	X		14.16	X		0.88	X		17.48	X		1		
10/30/19 7:54	317536.8			1.3	X		14.16	X		0.94	X		17.31	X		1		
10/30/19 7:55	314764.3			1.3	X		14.52	X		0.94	X		17.6	X		1		
10/30/19 7:56	313840.1			1.2	X		14.8	X		0.87	X		17.88	X		1		
10/30/19 7:57	313686.1			1.2	X		15.02	X		0.85	X		18.14	X		1		
10/30/19 7:58	313301			1.2	X		15.43	X		0.86	X		18.61	X		1		
10/30/19 7:59	312453.8			1.2	X		15.52	X		0.86	X		18.67	X		1		
10/30/19 8:00	312376.8			1.2	X		15.43	X		0.86	X		18.55	X		1		
10/30/19 8:01	313301			1.1	X		15.43	X		0.8	X		18.61	X		1		
10/30/19 8:02	312607.8			1.1	X		15.52	X		0.8	X		18.68	X		1		
10/30/19 8:03	313455			1	X		15.2	X		0.72	X		18.34	X		1		
10/30/19 8:04	311144.5			1	X		10.62	X		0.73	X		12.72	X		1		
10/30/19 8:05	311837.7			1	X		8.35	X		0.73	X		10.03	X		1		
10/30/19 8:06	313146.9			1	X		7.35	X		0.73	X		8.86	X		1		
10/30/19 8:07	309989.3			1	X		6.9	X		0.72	X		8.23	X		1		
10/30/19 8:08	297127.6			0.9	X		6.44	X		0.63	X		7.37	X		1		
10/30/19 8:09	291967.6			0.9	X		6.44	X		0.62	X		7.24	X		1		
10/30/19 8:10	289503			0.9	X		6.26	X		0.61	X		6.98	X		1		
10/30/19 8:11	283418.8			0.9	X		5.72	X		0.6	X		6.24	X		1		
10/30/19 8:12	282186.5			0.8	X		6.18	X		0.55	X		6.71	X		1		
10/30/19 8:13	277950.7			0.8	X		6.73	X		0.54	X		7.2	X		1		
10/30/19 8:14	277642.6			0.8	X		6.91	X		0.54	X		7.39	X		1		
10/30/19 8:15	279336.9			0.8	X		6.73	X		0.54	X		7.24	X		1		
10/30/19 8:16	277334.5			0.8	X		6.55	X		0.54	X		6.99	X		1		
10/30/19 8:17	287192.6			0.8	X		6.27	X		0.56	X		6.93	X		1		
10/30/19 8:18	291582.5			0.8	X		5.35	X		0.57	X		6	X		1		
10/30/19 8:19	291582.5			0.8	X		4.36	X		0.56	X		4.89	X		1		
10/30/19 8:20	291890.5			0.8	X		4.18	X		0.56	X		4.69	X		1		
10/30/19 8:21	291659.5			0.9	X		4.18	X		0.62	X		4.69	X		1		
10/30/19 8:22	291736.5			0.9	X		4.18	X		0.62	X		4.69	X		1		
10/30/19 8:23	291274.4			0.9	X		4.08	X		0.62	X		4.58	X		1		
10/30/19 8:24	292352.6			0.9	X		4.08	X		0.62	X		4.6	X		1		
10/30/19 8:25	293199.8			0.9	X		4.08	X		0.62	X		4.61	X		1		
10/30/19 8:26	292044.6			0.9	X		4.08	X		0.62	X		4.59	X		1		
10/30/19 8:27	293276.8			0.9	X		3.99	X		0.62	X		4.51	X		1		
10/30/19 8:28	292583.7			0.9	X		3.99	X		0.62	X		4.5	X		1		
10/30/19 8:29	292121.6			0.9	X		3.9	X		0.62	X		4.39	X		1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 8:30	292352.6			0.9	X		3.9	X		0.62	X		4.39	X		1		
10/30/19 8:31	291043.3			0.9	X		3.81	X		0.62	X		4.27	X		1		
10/30/19 8:32	292429.7			0.8	X		3.81	X		0.56	X		4.29	X		1		
10/30/19 8:33	291197.4			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:34	290812.3			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:35	291197.4			0.8	X		3.81	X		0.56	X		4.27	X		1		
10/30/19 8:36	292121.6			0.8	X		3.81	X		0.56	X		4.29	X		1		
10/30/19 8:37	291659.5			0.8	X		3.72	X		0.56	X		4.18	X		1		
10/30/19 8:38	290735.3			0.8	X		3.72	X		0.56	X		4.17	X		1		
10/30/19 8:39	290504.3			0.8	X		3.72	X		0.56	X		4.16	X		1		
10/30/19 8:40	290966.3			0.8	X		3.72	X		0.56	X		4.17	X		1		
10/30/19 8:41	291582.5			0.8	X		3.63	X		0.56	X		4.08	X		1		
10/30/19 8:42	291813.5			0.8	X		3.45	X		0.56	X		3.87	X		1		
10/30/19 8:43	291274.4			0.8	X		3.18	X		0.56	X		3.56	X		1		
10/30/19 8:44	291582.5			0.8	X		2.9	X		0.56	X		3.26	X		1		
10/30/19 8:45	290735.3			0.8	X		2.54	X		0.56	X		2.84	X		1		
10/30/19 8:46	290581.3			0.8	X		2.3	X		0.56	X		2.58	X		1		
10/30/19 8:47	291120.4			0.8	X		2	X		0.56	X		2.24	X		1		
10/30/19 8:48	292044.6			0.8	X		1.82	X		0.56	X		2.04	X		1		
10/30/19 8:49	291197.4			0.8	X		1.66	X		0.57	X		1.86	X		1		
10/30/19 8:50	291120.4			0.8	X		1.57	X		0.56	X		1.76	X		1		
10/30/19 8:51	291043.3			0.8	X		1.48	X		0.56	X		1.65	X		0		
10/30/19 8:52	291043.3			0.8	X		1.38	X		0.56	X		1.55	X		0		
10/30/19 8:53	290427.2			0.9	X		1.29	X		0.63	X		1.44	X		0		
10/30/19 8:54	291351.4			0.8	X		1.29	X		0.57	X		1.45	X		0		
10/30/19 8:55	292275.6			0.8	X		1.2	X		0.57	X		1.35	X		0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 11:41	283341.8			0.8			1.78			0.56			1.94			0		
10/30/19 11:42	282879.7			0.8			1.69			0.56			1.84			0		
10/30/19 11:43	282417.6			0.8			1.69			0.56			1.83			0		
10/30/19 11:44	282956.7			0.8			1.69			0.56			1.84			0		
10/30/19 11:45	281801.4			0.8			1.69			0.56			1.83			0		
10/30/19 11:46	276564.3			0.7			1.69			0.48			1.79			1		
10/30/19 11:47	254922.9			0.8			1.69			0.5			1.65			1		
10/30/19 11:48	235745.9			0.8			3.52			0.42			3.2			1		
10/30/19 11:49	218571.3			0.7			7.67			0.35			6.45			1		
10/30/19 11:50	194773.4			0.6			16.77			0.28			12.57			1		
10/30/19 11:51	172284.7			0.5			20.76			0.18			13.77			1		
10/30/19 11:52	150566.2			5			23.22			1.76			13.45			1		
10/30/19 11:53	133083.6			456.8			25.96			142.24			13.3			1		
10/30/19 11:54	76707.9			1488.3			26.63			267.19			7.87			1		
10/30/19 11:55	0			0			28.96			0			0			0		
10/30/19 11:56	0			0			0.3			0			0			0		
10/30/19 11:57	0			0			0.1			0			0			0		
10/30/19 11:58	0			0			0.1			0			0			0		
10/30/19 11:59	0			0			0.1			0			0			0		

CT2 SUSD EVENT 23

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/19 13:39	0			0			0			0			0			0		
11/05/19 13:40	0			0			0			0			0			0		
11/05/19 13:41	0			0			0			0			0			0		
11/05/19 13:42	0			0			0			0			0			0		
11/05/19 13:43	0			0			0			0			0			0		
11/05/19 13:44	16404.4			0.2			0			0			0			0		1
11/05/19 13:45	31345.5			0.8			0			0			0			0		1
11/05/19 13:46	42974.9			5.2			19.01			0.53			3.19			0		1
11/05/19 13:47	52293.8			444.7			17.7			55.14			3.61			0		1
11/05/19 13:48	69622.4			287.9			23.9			47.56			6.5			0		1
11/05/19 13:49	111442.1			169.5			26.01			44.81			11.32			0		1
11/05/19 13:50	130619.1			69.7			44.48			21.6			22.69			0		1
11/05/19 13:51	139090.8			164.6			57.71			54.33			31.34			0		1
11/05/19 13:52	158113.8			1536.1			42.02			576.31			25.94			0		1
11/05/19 13:53	180448.4			830.9			52.3			355.82			36.86			0		1
11/05/19 13:54	201088.7			125.3			62.23			59.8			48.88			0		1
11/05/19 13:55	222730.2			7.1			66.62			3.77			57.95			0		1
11/05/19 13:56	243909.6			1.9			72.22			1.07			68.78			0		1
11/05/19 13:57	267938.6			1.8			63.62			1.13			66.56			0		1
11/05/19 13:58	288116.8			1.7			41.57			1.18			46.77			0		1
11/05/19 13:59	307755.8			1.9			22.62			1.37			27.18			0		1
11/05/19 14:00	322542.9			1.9			20.43			1.48			25.73			0		1
11/05/19 14:01	327471.9			1.9			15.82			1.46			20.23			0		1
11/05/19 14:02	327703			1.8			14.25			1.41			18.24			0		1
11/05/19 14:03	329089.3			1.6			12.98			1.28			16.68			0		1
11/05/19 14:04	338023.1			1.5			11.89			1.24			15.7			0		1
11/05/19 14:05	345724.7			1.4			10.42			1.13			14.07			0		1
11/05/19 14:06	347881.2			1.3			9.86			1.07			13.4			0		1
11/05/19 14:07	348035.2			1.2			9.65			1.01			13.11			0		1
11/05/19 14:08	346109.8			1.1			9.46			0.92			12.78			0		1
11/05/19 14:09	346417.8			1.1			9.37			0.92			12.67			0		1
11/05/19 14:10	344492.4			1.1			9.55	X		0.92			12.85	X		0		1
11/05/19 14:11	344954.5			1			9.55	X		0.84			12.87	X		0		1
11/05/19 14:12	345647.7			1			9.55	X		0.84			12.89	X		0		1
11/05/19 14:13	343414.2			0.9			9.65	X		0.76			12.94	X		0		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/19 14:14	344569.5			1			9.55	X		0.84			12.85	X		1		
11/05/19 14:15	341950.9			1			9.37			0.84			12.51			1		
11/05/19 14:16	342721.1			1			9.46			0.84			12.66			1		
11/05/19 14:17	341026.7			1			9.55			0.83			12.72			1		
11/05/19 14:18	343876.3			0.9			9.55			0.76			12.83			1		
11/05/19 14:19	342567			0.9			9.65			0.76			12.9			1		
11/05/19 14:20	343183.2			0.9			9.74			0.76			13.05			1		
11/05/19 14:21	338947.3			0.9			9.93			0.75			13.14			1		
11/05/19 14:22	326162.7			0.9			10.02			0.72			12.76			1		
11/05/19 14:23	321464.7			0.9			6.36			0.7			7.98			1		
11/05/19 14:24	320694.5			1			3.6			0.77			4.5			1		
11/05/19 14:25	319847.3			1			3.13			0.77			3.91			1		
11/05/19 14:26	320232.4			1			3.04			0.77			3.8			1		
11/05/19 14:27	319385.3			0.9			2.86			0.7			3.56			1		
11/05/19 14:28	314148.2			0.9			2.77			0.69			3.39			1		
11/05/19 14:29	306908.7			0.9			2.58			0.67			3.09			1		
11/05/19 14:30	307447.8			0.9			2.4			0.67			2.88			1		
11/05/19 14:31	306523.6			0.9			2.21			0.67			2.65			1		
11/05/19 14:32	305676.4			1			2.03			0.74			2.42			1		
11/05/19 14:33	305830.4			1			1.84			0.74			2.2			1		
11/05/19 14:34	305599.4			0.9			1.66			0.67			1.98			1		
11/05/19 14:35	305907.4			0.9			1.57			0.67			1.87			1		
11/05/19 14:36	306985.7			0.9			1.38			0.67			1.66			0		
11/05/19 14:37	305984.5			1			1.29			0.74			1.54			0		
11/05/19 14:38	305291.3			0.9			1.29			0.67			1.54			0		
11/05/19 14:39	306061.5			0.9			1.2			0.67			1.43			0		
11/05/19 14:40	306138.5			0.9			1.2			0.67			1.43			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/19 23:47	286422.4			0.9			1.82			0.62			2.03			0		
11/06/19 23:48	286191.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:49	286576.4			0.9			1.82			0.62			2.03			0		
11/06/19 23:50	286037.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:51	285960.3			0.9			1.82			0.62			2.03			0		
11/06/19 23:52	283649.8			1			1.82			0.67			2.01			1		
11/06/19 23:53	263933.8			1			1.82			0.63			1.87			1		
11/06/19 23:54	242215.2			1			3.23			0.58			3.05			1		
11/06/19 23:55	224655.6			0.9			6.95			0.46			6.09			1		
11/06/19 23:56	204477.4			0.8			14.4			0.39			11.5			1		
11/06/19 23:57	180063.3			0.7			19.23			0.28			13.52			1		
11/06/19 23:58	158961			5.4			21.63			2.04			13.43			1		
11/06/19 23:59	141786.4			383.4			23.46			128.98			12.99			1		
11/07/19 0:00	114753.8			1407.1			25.04			383			11.22			1		
11/07/19 0:01	0			0			28.58			0			0			1		
11/07/19 0:02	0			0			39.33			0			0			0		
11/07/19 0:03	0			0			0.2			0			0			0		
11/07/19 0:04	0			0			0.2			0			0			0		
11/07/19 0:05	0			0			0.1			0			0			0		
11/07/19 0:06	0			0			0.1			0			0			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 10:38	0			0			0			0			0			0		
11/07/19 10:39	0			0			0			0			0			0		
11/07/19 10:40	0			0			0			0			0			0		
11/07/19 10:41	0			0			0			0			0			0		
11/07/19 10:42	0			0			0			0			0			0		
11/07/19 10:43	6623.4			0.2			0			0			0			0		1
11/07/19 10:44	24722.1			0.2			0			0			0			0		1
11/07/19 10:45	37506.8			40.3			26.55			3.59			3.89			18.09		1
11/07/19 10:46	47980.9			564.5			15.84			64.32			2.97			26.87		1
11/07/19 10:47	58994.2			472.6			22.05			66.12			5.08			18.09		1
11/07/19 10:48	87490.1			286.3			25.85			59.41			8.83			18.09		1
11/07/19 10:49	129001.8			169.6			35.91			51.89			18.09			18.09		1
11/07/19 10:50	137781.6			62			49.95			20.25			26.87			26.87		1
11/07/19 10:51	153877.9			888.8			48.27			324.48			29			29		1
11/07/19 10:52	171437.5			1505.7			48.89			612.4			32.72			32.72		1
11/07/19 10:53	194003.2			494.1			48.53			227.41			36.76			36.76		1
11/07/19 10:54	215259.6			49.5			49.38			25.29			41.51			41.51		1
11/07/19 10:55	234898.7			3.8			51.71			2.13			47.44			47.44		1
11/07/19 10:56	258388.6			1.8			54.05			1.1			54.54			54.54		1
11/07/19 10:57	282263.5			1.6			41.97			1.08			46.26			46.26		1
11/07/19 10:58	297204.6			1.7			23.6			1.18			27.39			27.39		1
11/07/19 10:59	312530.8			1.8			15.01			1.35			18.32			18.32		1
11/07/19 11:00	318923.2			1.8			14.66			1.38			18.26			18.26		1
11/07/19 11:01	325238.4			1.7			12.75			1.34			16.2			16.2		1
11/07/19 11:02	330783.6			1.7			11.36			1.31			14.67			14.67		1
11/07/19 11:03	329936.4			1.5			10.91			1.19			14.05			14.05		1
11/07/19 11:04	328473.1			1.3			11.08			1.05			14.22			14.22		1
11/07/19 11:05	329243.3			1.3			11			1.05			14.14			14.14		1
11/07/19 11:06	331630.8			1.3			10.73			0.98			13.89			13.89		1
11/07/19 11:07	332246.9			1.3			10.44			1			13.54			13.54		1
11/07/19 11:08	333325.1			1.2			10.35			0.93			13.47			13.47		1
11/07/19 11:09	333864.3			1.2			10.35			0.93			13.49			13.49		1
11/07/19 11:10	338254.2			1.1			10.26			0.87			13.55			13.55		1
11/07/19 11:11	340256.6			1.1			9.89			0.88			13.15			13.15		1
11/07/19 11:12	337561			1			10.05			0.81			13.25			13.25		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 11:13	340025.5			1			10.23			0.82			13.59			1		
11/07/19 11:14	339794.5			1			10.42			0.82			13.82			1		
11/07/19 11:15	338870.3			1			10.51			0.82			13.91			1		
11/07/19 11:16	338639.2			1			10.51			0.81			13.9			1		
11/07/19 11:17	336867.9			0.9			10.6			0.74			13.95			1		
11/07/19 11:18	327703			0.9			8.94			0.72			11.44			1		
11/07/19 11:19	319308.2			1			4.54			0.76			5.66			1		
11/07/19 11:20	314995.3			1			3.63			0.75			4.47			1		
11/07/19 11:21	311144.5			1			3.45			0.74			4.19			1		
11/07/19 11:22	308140.9			1			3.27			0.73			3.93			1		
11/07/19 11:23	304675.2			1			3			0.72			3.56			1		
11/07/19 11:24	298899			1			2.63			0.71			3.07			1		
11/07/19 11:25	298282.9			1			2.54			0.71			2.96			1		
11/07/19 11:26	297512.7			1			2.36			0.7			2.74			1		
11/07/19 11:27	296357.5			1			2.18			0.7			2.52			1		
11/07/19 11:28	297435.7			1			2			0.7			2.32			1		
11/07/19 11:29	297050.6			1			1.82			0.7			2.11			1		
11/07/19 11:30	295972.4			1.1			1.63			0.76			1.89			1		
11/07/19 11:31	290812.3			1			1.54			0.69			1.75			1		
11/07/19 11:32	291274.4			1			1.45			0.69			1.65			0		
11/07/19 11:33	290581.3			0.9			1.38			0.64			1.57			0		
11/07/19 11:34	289657.1			0.9			1.29			0.63			1.46			0		
11/07/19 11:35	290735.3			0.9			1.29			0.64			1.47			0		
11/07/19 11:36	291582.5			0.9			1.2			0.64			1.36			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:01	342952.1			1.2			1.72			0.96			2.31			0		
11/07/19 21:02	341796.9			1.2			1.72			0.96			2.3			0		
11/07/19 21:03	332400.9			1.3			1.72			1			2.24			0		
11/07/19 21:04	312530.8			1.3			1.7			0.93			2.07			0		
11/07/19 21:05	292506.7			1.2			1.76			0.86			2.01			0		
11/07/19 21:06	271250.3			1.3			1.85			0.85			1.96			1		
11/07/19 21:07	249685.8			1.4			1.91			0.81			1.86			1		
11/07/19 21:08	232203.2			1.3			4.4			0.72			3.99			1		
11/07/19 21:09	211639.9			1.2			8.46			0.59			6.99			1		
11/07/19 21:10	187379.9			0.9			17.81			0.42			13.03			1		
11/07/19 21:11	164506.1			2.4			20.77			0.92			13.34			1		
11/07/19 21:12	146176.3			212.5			23.2			73.74			13.25			1		
11/07/19 21:13	129309.8			1131.2			25.77			347.17			13.02			1		
11/07/19 21:14	45054.3			1846.4			27.59			197.56			4.86			1		
11/07/19 21:15	0			0			31.47			0			0			0		
11/07/19 21:16	0			0			11.8			0			0			0		
11/07/19 21:17	0			0			0.2			0			0			0		
11/07/19 21:18	0			0			0.1			0			0			0		
11/07/19 21:19	0			0			0.1			0			0			0		

CT2 SUSD EVENT 27

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 9:38	0			0			0			0			0			0		
11/08/19 9:39	0			0			0			0			0			0		
11/08/19 9:40	0			0			0			0			0			0		
11/08/19 9:41	0			0			0			0			0			0		
11/08/19 9:42	0			0			0			0			0			0		
11/08/19 9:43	9704			0.2			0			0			0			0		1
11/08/19 9:44	27186.6			0.5			0			0			0			0		1
11/08/19 9:45	39509.2			54.6			27.29			5.12			4.21			1		
11/08/19 9:46	50137.4			567			20.18			67.4			3.95			1		
11/08/19 9:47	61689.8			462.4			26.08			67.69			6.28			1		
11/08/19 9:48	94267.5			291.1			27.81			65.09			10.24			1		
11/08/19 9:49	132467.5			163.5			39.83			51.38			20.6			1		
11/08/19 9:50	140323.1			64.1			55.66			21.34			30.49			1		
11/08/19 9:51	157728.7			1142.3			51.13			427.52			31.5			1		
11/08/19 9:52	177290.8			1463			52.93			615.36			36.64			1		
11/08/19 9:53	199240.3			446.2			50.51			210.97			39.3			1		
11/08/19 9:54	220111.7			47.1			52.07			24.58			44.76			1		
11/08/19 9:55	241830.2			3.3			53.33			1.89			50.35			1		
11/08/19 9:56	264857.9			2			55.17			1.24			57.07			1		
11/08/19 9:57	286807.5			1.9			40.27			1.27			45.1			1		
11/08/19 9:58	305984.5			1.8			21.95			1.32			26.23			1		
11/08/19 9:59	319231.2			2			15.18			1.51			18.93			1		
11/08/19 10:00	320232.4			2			14.28			1.49			17.85			1		
11/08/19 10:01	319693.3			1.9			13.45			1.45			16.79			1		
11/08/19 10:02	319077.2			1.7			12.49			1.31			15.57			1		
11/08/19 10:03	317767.9			1.6			11.8			1.24			14.64			1		
11/08/19 10:04	316458.6			1.6			11.54			1.19			14.25			1		
11/08/19 10:05	317228.8			1.5			11.1			1.13			13.75			1		
11/08/19 10:06	316766.7			1.4			10.92			1.06			13.51			1		
11/08/19 10:07	323775.2			1.3			10.48			1.01			13.25			1		
11/08/19 10:08	328011			1.3			9.65			0.97			12.37			1		
11/08/19 10:09	332863			1.2			9.8			0.93			12.74			1		
11/08/19 10:10	334095.3			1.2			9.71			0.94			12.67			1		
11/08/19 10:11	331938.8			1.1			9.8			0.86			12.71			1		
11/08/19 10:12	334403.3			1.1			9.89			0.86			12.92			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 10:13	332477.9			1			9.98			0.79			12.96			1		
11/08/19 10:14	333248.1			1			10.08			0.79			13.11			1		
11/08/19 10:15	332786			1			10.17			0.79			13.21			1		
11/08/19 10:16	332786			1			10.17			0.79			13.21			1		
11/08/19 10:17	331938.8			1			10.26			0.79			13.3			1		
11/08/19 10:18	321695.7			1			10.44			0.76			13.11			1		
11/08/19 10:19	318769.1			1			10.8			0.76			13.45			1		
11/08/19 10:20	314841.3			1			5.45			0.75			6.7			1		
11/08/19 10:21	312299.8			1			3.9			0.74			4.76			1		
11/08/19 10:22	310913.5			1			3.45			0.74			4.19			1		
11/08/19 10:23	308063.9			1			3.18			0.73			3.82			1		
11/08/19 10:24	299284.1			1			3			0.71			3.5			1		
11/08/19 10:25	299361.1			1			2.86			0.7			3.34			1		
11/08/19 10:26	298667.9			1.1			2.77			0.76			3.23			1		
11/08/19 10:27	299361.1			1.1			2.54			0.77			2.97			1		
11/08/19 10:28	297435.7			1.1			2.27			0.77			2.64			1		
11/08/19 10:29	297435.7			1.1			2.09			0.77			2.42			1		
11/08/19 10:30	297204.6			1			1.91			0.7			2.21			1		
11/08/19 10:31	296819.6			1			1.72			0.7			2			1		
11/08/19 10:32	297127.6			1			1.54			0.7			1.79			1		
11/08/19 10:33	296896.6			1			1.45			0.7			1.68			0		
11/08/19 10:34	296896.6			1			1.36			0.7			1.58			0		
11/08/19 10:35	297974.8			1			1.27			0.71			1.48			0		
11/08/19 10:36	298822			1			1.27			0.71			1.48			0		
11/08/19 10:37	297204.6			1			1.27			0.7			1.47			0		

CT2 SUSD EVENT 28

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/08/19 23:50	275101.1			0.8			1.48			0.54			1.58			0		
11/08/19 23:51	274484.9			0.8			1.48			0.54			1.58			0		
11/08/19 23:52	274484.9			0.8			1.48			0.54			1.58			0		
11/08/19 23:53	275640.2			0.8			1.48			0.54			1.59			0		
11/08/19 23:54	274639			0.8			1.48			0.54			1.58			0		
11/08/19 23:55	275255.1			0.9			1.48			0.6			1.59			1		
11/08/19 23:56	262624.5			0.9			1.48			0.57			1.51			1		
11/08/19 23:57	242600.3			0.9			2.25			0.54			2.13			1		
11/08/19 23:58	225733.8			0.9			5.61			0.46			4.95			1		
11/08/19 23:59	203322.2			0.8			9.3			0.39			7.38			1		
11/09/19 0:00	178908.1			0.7			14.75			0.28			10.3			1		
11/09/19 0:01	157035.6			4.2			16.72			1.56			10.25			1		
11/09/19 0:02	139861			356.8			18.68			118.45			10.21			1		
11/09/19 0:03	113213.5			1360.3			20.25			365.41			8.95			1		
11/09/19 0:04	0			1958.4			22.86			0			0			1		
11/09/19 0:05	0			0			25.57			0			0			0		
11/09/19 0:06	0			0			0.2			0			0			0		
11/09/19 0:07	0			0			0.1			0			0			0		
11/09/19 0:08	0			0			0.1			0			0			0		
11/09/19 0:09	0			0			0.1			0			0			0		

CT2 SUSD EVENT 29

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 23:24	0			0			0			0			0			0		
11/11/19 23:25	0			0			0			0			0			0		
11/11/19 23:26	0			0			0			0			0			0		
11/11/19 23:27	0			0			0			0			0			0		
11/11/19 23:28	2156.4			0			0			0			0			0		
11/11/19 23:29	13400.8			0.3			0			0			0			0		1
11/11/19 23:30	28958			0.6			0			0			0			0		1
11/11/19 23:31	41203.5			59.7			19.91			5.84			3.21			1		1
11/11/19 23:32	52524.9			506.8			16.46			63.19			3.38			1		1
11/11/19 23:33	67312			374.9			20.95			59.84			5.5			1		1
11/11/19 23:34	106051			244.1			25.29			61.43			10.47			1		1
11/11/19 23:35	134161.8			119.4			37.52			38.01			19.66			1		1
11/11/19 23:36	141170.3			81.1			51.63			27.17			28.45			1		1
11/11/19 23:37	160270.2			1464.1			42.91			556.82			26.86			1		1
11/11/19 23:38	179139.2			1228.7			53.76			522.29			37.61			1		1
11/11/19 23:39	203091.1			244.3			62.23			117.73			49.36			1		1
11/11/19 23:40	224039.5			16.3			61.83			8.69			54.1			1		1
11/11/19 23:41	242985.4			2.3			64.12			1.35			60.85			1		1
11/11/19 23:42	267784.5			1.8			57.4			1.14			60.01			1		1
11/11/19 23:43	286345.4			1.8			38.9			1.19			43.5			1		1
11/11/19 23:44	286884.5			1.9			21.17			1.3			23.72			1		1
11/11/19 23:45	286653.4			2			15.67			1.38			17.54			1		1
11/11/19 23:46	286268.4			1.9			13.91			1.32			15.55			1		1
11/11/19 23:47	290119.2			1.8			12.6			1.23			14.28			1		1
11/11/19 23:48	291274.4			1.7			11.62			1.17			13.22			1		1
11/11/19 23:49	291890.5			1.6			11.26			1.11			12.84			1		1
11/11/19 23:50	290889.3			1.5			10.19			1.05			11.57			1		1
11/11/19 23:51	289734.1			1.4			9.39			0.98			10.62			1		1
11/11/19 23:52	289349			1.3			9.21			0.92			10.4			1		1
11/11/19 23:53	288886.9			1.3			9.03			0.86			10.18			1		1
11/11/19 23:54	289118			1.3			8.94			0.86			10.09			1		1
11/11/19 23:55	289349			1.2			8.99			0.81			10.15			1		1
11/11/19 23:56	288193.8			1.2			8.99			0.81			10.11			1		1
11/11/19 23:57	288270.8			1.2			9.08			0.81			10.22			1		1
11/11/19 23:58	287885.7			1.2			8.35			0.81			9.39			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 23:59	287346.6			1.1			8.99			0.74			10.08			1		
11/12/19 0:00	287500.6			1.1			8.99			0.74			10.09			1		
11/12/19 0:01	287962.7			1.1			8.99			0.74			10.1			1		
11/12/19 0:02	286191.3			1			9.08			0.68			10.15			1		
11/12/19 0:03	287346.6			1			9.17		X	0.68			10.29		X	1		
11/12/19 0:04	287346.6			1			9.17		X	0.68			10.29		X	1		
11/12/19 0:05	286730.5			1			9.08			0.68			10.16			1		
11/12/19 0:06	286499.4			0.9			9.26			0.62			10.36			1		
11/12/19 0:07	286730.5			0.9			9.35			0.62			10.47			1		
11/12/19 0:08	286807.5			1			9.44			0.68			10.57			1		
11/12/19 0:09	286961.5			1			9.71			0.68			10.88			1		
11/12/19 0:10	286422.4			1			9.89			0.68			11.07			1		
11/12/19 0:11	285575.2			0.9			6.9			0.62			7.69			1		
11/12/19 0:12	285498.2			0.9			4.18			0.61			4.65			1		
11/12/19 0:13	285883.3			1			3.63			0.68			4.05			1		
11/12/19 0:14	285344.2			1			3.36			0.68			3.74			1		
11/12/19 0:15	285806.3			1			3.09			0.68			3.44			1		
11/12/19 0:16	285190.2			1			2.81			0.68			3.13			1		
11/12/19 0:17	285498.2			1			2.54			0.68			2.83			1		
11/12/19 0:18	285806.3			0.9			2.36			0.62			2.63			1		
11/12/19 0:19	285267.2			0.9			2.09			0.61			2.33			1		
11/12/19 0:20	285113.1			0.9			2			0.61			2.22			1		
11/12/19 0:21	289965.1			0.9			1.82			0.62			2.06			1		
11/12/19 0:22	290812.3			0.9			1.63			0.63			1.86			1		
11/12/19 0:23	292814.7			1			1.54			0.69			1.76			0		
11/12/19 0:24	291736.5			1			1.54			0.69			1.76			0		
11/12/19 0:25	293122.8			1			1.45			0.69			1.66			0		
11/12/19 0:26	292814.7			1			1.36			0.69			1.56			0		
11/12/19 0:27	292352.6			1			1.36			0.69			1.55			0		

CT2 SUSD EVENT 30

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/19 0:02	281724.4			0.9			1.72			0.61			1.9			0		
11/15/19 0:03	282186.5			0.9			1.63			0.61			1.8			0		
11/15/19 0:04	280723.2			0.9			1.63			0.6			1.79			0		
11/15/19 0:05	282648.6			0.8			1.54			0.55			1.7			0		
11/15/19 0:06	282340.6			0.8			1.63			0.55			1.8			0		
11/15/19 0:07	282032.5			0.9			1.72			0.61			1.9			1		
11/15/19 0:08	265705.1			0.9			1.63			0.57			1.7			1		
11/15/19 0:09	245372.9			0.8			2.77			0.48			2.65			1		
11/15/19 0:10	227428.2			0.8			6.85			0.41			6.09			1		
11/15/19 0:11	205170.5			0.8			13.3			0.39			10.66			1		
11/15/19 0:12	181603.7			0.6			17.49			0.28			12.4			1		
11/15/19 0:13	159885.2			4.1			19.51			1.55			12.18			1		
11/15/19 0:14	142479.5			377.2			21.4			127.49			11.91			1		
11/15/19 0:15	126152.2			1396.4			22.96			417.91			11.31			1		
11/15/19 0:16	0			1961.8			25.44			0			0			1		
11/15/19 0:17	0			0			28.32			0			0			0		
11/15/19 0:18	0			0			0.2			0			0			0		
11/15/19 0:19	0			0			0.1			0			0			0		
11/15/19 0:20	0			0			0.1			0			0			0		
11/15/19 0:21	0			0			0.1			0			0			0		

CT2 SUSD EVENT 31

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 3:39	0			0			0			0			0			0		
11/20/19 3:40	0			0			0			0			0			0		
11/20/19 3:41	0			0			0			0			0			0		
11/20/19 3:42	0			0			0			0			0			0		
11/20/19 3:43	2772.6			0			0			0			0			0		
11/20/19 3:44	12861.7			0.1			0			0			0			0		1
11/20/19 3:45	29343.1			0.1			0			0			0			0		1
11/20/19 3:46	41819.7			46.4			21.07			4.6			3.44			1		
11/20/19 3:47	51985.8			520.1			16.77			64.15			3.4			1		
11/20/19 3:48	67620			381.4			21.54			61.22			5.69			1		
11/20/19 3:49	107129.2			254			25.57			64.58			10.7			1		
11/20/19 3:50	133314.6			123.2			39.41			38.96			20.52			1		
11/20/19 3:51	139398.9			144.4			50.52			47.76			27.51			1		
11/20/19 3:52	155341.2			1642.3			37.37			605.49			22.67			1		
11/20/19 3:53	176058.5			1369.8			42.45			572.15			29.18			1		
11/20/19 3:54	197391.9			357			53.96			167.19			41.59			1		
11/20/19 3:55	219341.5			30			61.05			15.62			52.29			1		
11/20/19 3:56	239057.6			2.7			65.13			1.54			60.8			1		
11/20/19 3:57	264087.8			1.9			64.18			1.17			66.17			1		
11/20/19 3:58	285344.2			1.8			46.45			1.2			51.76			1		
11/20/19 3:59	295356.3			1.8			26.03			1.28			30.02			1		
11/20/19 4:00	296665.5			2.1			19.96			1.47			23.12			1		
11/20/19 4:01	296203.4			2.1			19.35			1.46			22.38			1		
11/20/19 4:02	308526			1.9			17.44			1.4			21.01			1		
11/20/19 4:03	325469.5			1.8			14.84			1.41			18.86			1		
11/20/19 4:04	343260.2			1.8			11.27			1.43			15.11			1		
11/20/19 4:05	362437.2			1.6			10.08			1.41			14.26			1		
11/20/19 4:06	384078.7			1.4			9.59			1.26			14.38			1		
11/20/19 4:07	395400			1.2			9.31			1.12			14.38			1		
11/20/19 4:08	398018.5			1.1			9.55	X		1.06			14.85	X		1		
11/20/19 4:09	398711.7			1			9.46			0.97			14.73			1		
11/20/19 4:10	400329			0.9			9.65			0.89			15.08			1		
11/20/19 4:11	398018.5			1			9.74			0.97			15.14			1		
11/20/19 4:12	398403.6			1			9.74			0.97			15.15			1		
11/20/19 4:13	397171.4			0.9			9.74			0.88			15.11			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 4:14	396401.2			0.9			9.65			0.88			14.93			1		
11/20/19 4:15	396324.2			0.9			9.65			0.88			14.93			1		
11/20/19 4:16	394937.9			0.8			9.74			0.79			15.02			1		
11/20/19 4:17	392781.5			0.8			9.93			0.79			15.22			1		
11/20/19 4:18	393474.6			0.9			9.93			0.87			15.25			1		
11/20/19 4:19	394398.8			0.9			10.11			0.88			15.58			1		
11/20/19 4:20	394167.8			0.8			10.21			0.79			15.71			1		
11/20/19 4:21	392473.4			0.8			10.4			0.78			15.93			1		
11/20/19 4:22	393474.6			0.8			10.4			0.79			15.97			1		
11/20/19 4:23	393474.6			0.8			7.96			0.79			12.23			1		
11/20/19 4:24	392935.5			0.8			5.15			0.79			7.9			1		
11/20/19 4:25	393012.5			0.8			4.78			0.79			7.33			1		
11/20/19 4:26	391472.2			0.8			4.59			0.78			7.02			1		
11/20/19 4:27	390316.9			0.8			4.31			0.78			6.57			1		
11/20/19 4:28	390933.1			0.8			4.03			0.78			6.15			1		
11/20/19 4:29	392550.4			0.8			3.84			0.79			5.89			1		
11/20/19 4:30	391395.2			0.8			3.65			0.78			5.58			1		
11/20/19 4:31	390625			0.8			3.28			0.78			5			1		
11/20/19 4:32	389546.8			0.8			2.81			0.78			4.27			1		
11/20/19 4:33	391626.2			0.8			2.43			0.78			3.72			1		
11/20/19 4:34	392396.4			0.8			2.06			0.78			3.16			1		
11/20/19 4:35	391780.3			0.8			1.78			0.78			2.72			1		
11/20/19 4:36	390856.1			0.8			1.59			0.78			2.43			1		
11/20/19 4:37	390239.9			0.8			1.5			0.78			2.28			1		
11/20/19 4:38	388853.7			0.8			1.4			0.78			2.13			0		
11/20/19 4:39	390471			0.8			1.31			0.78			2			0		
11/20/19 4:40	388930.7			0.8			1.22			0.78			1.85			0		
11/20/19 4:41	389238.7			0.8			1.31			0.78			1.99			0		
11/20/19 4:42	389700.8			0.8			1.31			0.78			2			0		

CT2 SUSD EVENT 32

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 6:56	339640.4			0.9			0.82			0.73			1.08			0		
11/20/19 6:57	338716.3			0.9			0.82			0.73			1.08			0		
11/20/19 6:58	335019.5			0.9			0.82			0.72			1.07			0		
11/20/19 6:59	319693.3			0.9			0.82			0.69			1.02			0		
11/20/19 7:00	297743.8			0.9			0.8			0.63			0.94			0		
11/20/19 7:01	275948.2			1			0.72			0.64			0.77			1		
11/20/19 7:02	257233.3			1			0.72			0.6			0.72			1		
11/20/19 7:03	236670.1			0.9			0.92			0.52			0.85			1		
11/20/19 7:04	219341.5			0.9			2.19			0.45			1.87			1		
11/20/19 7:05	196852.8			0.7			4.98			0.33			3.83			1		
11/20/19 7:06	173131.9			0.6			8.02			0.23			5.42			1		
11/20/19 7:07	151413.4			6.5			10.42			2.35			6.16			1		
11/20/19 7:08	135471.1			456.7			12.81			146.82			6.78			1		
11/20/19 7:09	102046.2			1524			15.73			369.12			6.27			1		
11/20/19 7:10	0			0			20.75			0			0			0		
11/20/19 7:11	0			0			53.1			0			0			0		
11/20/19 7:12	0			0			0.2			0			0			0		
11/20/19 7:13	0			0			0.2			0			0			0		
11/20/19 7:14	0			0			0.1			0			0			0		

CT2 SUSD EVENT 33

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 6:40	0			0			0			0			0			0		
11/21/19 6:41	0			0			0			0			0			0		
11/21/19 6:42	0			0			0			0			0			0		
11/21/19 6:43	0			0			0			0			0			0		
11/21/19 6:44	0			0			0			0			0			0		
11/21/19 6:45	16250.4			0.2			0			0			0			0		1
11/21/19 6:46	30421.3			1.1			0			0			0			0		1
11/21/19 6:47	41896.7			577.6			21.24			57.41			3.47			11.18		1
11/21/19 6:48	52987			554.3			18.01			69.73			3.73			22.99		1
11/21/19 6:49	66464.8			413			23.6			65.08			6.12			31.57		1
11/21/19 6:50	106128			273.9			26.97			68.98			11.18			32.26		1
11/21/19 6:51	136318.3			138.3			43.19			44.73			22.99			39.82		1
11/21/19 6:52	142864.6			114.7			56.6			38.87			31.57			45.17		1
11/21/19 6:53	158806.9			1603.2			52.03			603.98			32.26			48.93		1
11/21/19 6:54	180833.5			1335.5			56.38			573.09			39.82			54.74		1
11/21/19 6:55	200472.6			362.2			57.7			172.29			45.17			60.68		1
11/21/19 6:56	221343.9			34.5			56.61			18.13			48.93			61.52		1
11/21/19 6:57	242754.3			3.1			57.75			1.76			54.74			62.46		1
11/21/19 6:58	266629.3			1.8			58.29			1.16			60.68			63.40		1
11/21/19 6:59	282032.5			1.9			41.39			1.25			45.6			64.34		1
11/21/19 7:00	281493.4			2			25.08			1.33			27.56			65.28		1
11/21/19 7:01	280338.1			2.2			21.43			1.44			23.46			66.22		1
11/21/19 7:02	279491			2.2			19.64			1.46			21.44			67.16		1
11/21/19 7:03	277257.5			2			19.02			1.33			20.59			68.10		1
11/21/19 7:04	283264.8			1.8			18.14			1.24			20.07			69.04		1
11/21/19 7:05	300285.3			1.7			15.38			1.21			18.03			70.00		1
11/21/19 7:06	318846.1			1.6			10.92			1.2			13.6			71.00		1
11/21/19 7:07	337330			1.5			10.04			1.2			13.23			72.00		1
11/21/19 7:08	354735.6			1.4			8.31			1.2			11.52			73.00		1
11/21/19 7:09	376146			1.4			7.72			1.22			11.33			74.00		1
11/21/19 7:10	395400			1.2			8.11			1.12			12.53			75.00		1
11/21/19 7:11	412035.4			1.2			8.39			1.17			13.5			76.00		1
11/21/19 7:12	412651.6			1.2			9.03			1.17			14.56			77.00		1
11/21/19 7:13	411573.3			1.1			9.96			1.08			16			78.00		1
11/21/19 7:14	406721.3			1.1			9.96			1.07			15.81			79.00		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/21/19 7:15	410187.1			1.1			10.14			1.08			16.24			1		
11/21/19 7:16	411034.3			1.1			10.33			1.08			16.57			1		
11/21/19 7:17	411881.4			1.1			10.6			1.08			17.05			1		
11/21/19 7:18	411342.3			1.1			10.97			1.08			17.62			1		
11/21/19 7:19	408492.7			1.1			11.34			1.07			18.09			1		
11/21/19 7:20	407414.5			1			11.43			0.98			18.19			1		
11/21/19 7:21	406182.3			1			10.4			0.99			16.49			1		
11/21/19 7:22	407183.4			1			4.87			1			7.74			1		
11/21/19 7:23	405951.2			0.9			3.28			0.9			5.2			1		
11/21/19 7:24	406567.3			0.9			3			0.9			4.76			1		
11/21/19 7:25	404718.9			0.9			3			0.9			4.74			1		
11/21/19 7:26	404718.9			0.9			2.9			0.9			4.59			1		
11/21/19 7:27	404564.9			0.9			2.81			0.9			4.44			1		
11/21/19 7:28	405566.1			0.9			2.53			0.9			4			1		
11/21/19 7:29	405412.1			1			2.34			0.99			3.71			1		
11/21/19 7:30	405951.2			1			2.06			0.99			3.27			1		
11/21/19 7:31	403486.7			1			1.84			0.97			2.91			1		
11/21/19 7:32	403178.6			1			1.66			0.97			2.61			1		
11/21/19 7:33	404487.9			0.9			1.57			0.88			2.48			1		
11/21/19 7:34	404025.8			0.9			1.48			0.88			2.33			0		
11/21/19 7:35	400252			0.9			1.38			0.88			2.16			0		
11/21/19 7:36	402408.5			0.9			1.29			0.88			2.03			0		
11/21/19 7:37	404564.9			0.9			1.2			0.88			1.89			0		
11/21/19 7:38	403332.7			0.8			1.2			0.79			1.89			0		

CT2 SUSD EVENT 34

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/19 0:01	277180.5			1			1.54			0.66			1.67			0		
11/23/19 0:02	278335.7			0.9			1.75			0.61			1.9			0		
11/23/19 0:03	277719.6			0.9			1.94			0.61			2.1			0		
11/23/19 0:04	278104.7			0.8			2.03			0.55			2.2			0		
11/23/19 0:05	277565.6			0.8			2.03			0.55			2.2			0		
11/23/19 0:06	276102.3			0.8			2.03			0.54			2.19			1		
11/23/19 0:07	257079.3			0.8			2.21			0.51			2.22			1		
11/23/19 0:08	238210.4			0.8			4.79			0.47			4.46			1		
11/23/19 0:09	219418.5			0.8			8.03			0.4			6.88			1		
11/23/19 0:10	195081.5			0.7			16.66			0.34			12.7			1		
11/23/19 0:11	172438.8			1.7			20.01			0.71			13.48			1		
11/23/19 0:12	153030.7			11.9			21.8			4.33			13.03			1		
11/23/19 0:13	136857.4			706.5			24.34			229.48			13.01			1		
11/23/19 0:14	78864.4			1722.6			26.3			322.37			8.1			1		
11/23/19 0:15	0			0			29.05			0			0			0		
11/23/19 0:16	0			0			23.6			0			0			0		
11/23/19 0:17	0			0			0.2			0			0			0		
11/23/19 0:18	0			0			0.2			0			0			0		
11/23/19 0:19	0			0			0.1			0			0			0		

CT2 SUSD EVENT 35

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 3:40	0			0			0			0			0			0		
11/26/19 3:41	0			0			0			0			0			0		
11/26/19 3:42	0			0			0			0			0			0		
11/26/19 3:43	0			0			0			0			0			0		
11/26/19 3:44	3080.6			0			0			0			0			0		
11/26/19 3:45	15018.1			0.1			0			0			0			0		1
11/26/19 3:46	23566.9			0.1			0			0			0			0		1
11/26/19 3:47	37814.8			70.8			59			6.36			8.72			1		1
11/26/19 3:48	49444.3			601.8			15.86			70.59			3.06			1		1
11/26/19 3:49	59302.3			516.3			19.67			72.69			4.56			1		1
11/26/19 3:50	88106.3			359			24.53			75.05			8.44			1		1
11/26/19 3:51	131620.3			221.7			26.41			69.22			13.57			1		1
11/26/19 3:52	140169.1			94.4			47.2			31.4			25.84			1		1
11/26/19 3:53	155726.3			840.4			46.46			310.58			28.26			1		1
11/26/19 3:54	173285.9			1812.2			46.13			745.18			31.22			1		1
11/26/19 3:55	194080.3			829.1			56.36			381.76			42.71			1		1
11/26/19 3:56	215336.7			107.3			63.02			54.82			53.01			1		1
11/26/19 3:57	237132.2			6.6			64.06			3.73			59.33			1		1
11/26/19 3:58	258311.6			2.2			67.09			1.34			67.67			1		1
11/26/19 3:59	283649.8			1.9			58			1.28			64.25			1		1
11/26/19 4:00	299207.1			1.7			38.85			1.22			45.4			1		1
11/26/19 4:01	300362.3			1.9			22.3			1.36			26.16			1		1
11/26/19 4:02	301209.5			2.1			19.26			1.49			22.66			1		1
11/26/19 4:03	299361.1			2			17.96			1.42			20.99			1		1
11/26/19 4:04	298822			1.9			16.14			1.35			18.83			1		1
11/26/19 4:05	297897.8			1.8			15.06			1.31			17.52			1		1
11/26/19 4:06	297820.8			1.7			13.74			1.18			15.98			1		1
11/26/19 4:07	298205.8			1.6			12.68			1.12			14.77			1		1
11/26/19 4:08	297512.7			1.4			11.98			0.99			13.92			1		1
11/26/19 4:09	298051.8			1.3			11.62			0.93			13.53			1		1
11/26/19 4:10	297820.8			1.3			11.27			0.93			13.11			1		1
11/26/19 4:11	296357.5			1.3			11.26			0.88			13.03			1		1
11/26/19 4:12	296357.5			1.3			11.08			0.88			12.83			1		1
11/26/19 4:13	296357.5			1.3			11			0.88			12.72			1		1
11/26/19 4:14	296511.5			1.3			10.91			0.88			12.63			1		1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 4:15	295279.3			1.2			10.91			0.81			12.58			1		
11/26/19 4:16	296511.5			1.2			10.82			0.82			12.52			1		
11/26/19 4:17	295048.2			1.1			10.82			0.75			12.46			1		
11/26/19 4:18	295356.3			1.1			10.82			0.75			12.48			1		
11/26/19 4:19	295048.2			1			10.73			0.69			12.36			1		
11/26/19 4:20	295048.2			1			10.73			0.69			12.36			1		
11/26/19 4:21	293892.9			1			10.73			0.69			12.31			1		
11/26/19 4:22	295279.3			1			10.91			0.69			12.58			1		
11/26/19 4:23	295510.3			1			11.08			0.69			12.79			1		
11/26/19 4:24	295972.4			1			11.26			0.69			13.02			1		
11/26/19 4:25	295741.3			0.9			11.44			0.63			13.22			1		
11/26/19 4:26	293815.9			0.9			11.62			0.62			13.33			1		
11/26/19 4:27	293892.9			0.9			11.89			0.62			13.64			1		
11/26/19 4:28	295202.2			1			11.8			0.69			13.6			1		
11/26/19 4:29	293892.9			1			7.78			0.69			8.92			1		
11/26/19 4:30	294509.1			0.9			4.56			0.62			5.24			1		
11/26/19 4:31	294817.2			0.9			3.58			0.63			4.12			1		
11/26/19 4:32	293970			0.9			3.13			0.62			3.59			1		
11/26/19 4:33	294047			0.9			3.04			0.62			3.49			1		
11/26/19 4:34	292968.8			0.9			2.77			0.62			3.17			1		
11/26/19 4:35	293045.8			0.9			2.59			0.62			2.97			1		
11/26/19 4:36	294278			0.9			2.32			0.62			2.67			1		
11/26/19 4:37	291890.5			0.9			2.15			0.62			2.45			1		
11/26/19 4:38	293507.9			0.9			1.88			0.62			2.15			1		
11/26/19 4:39	294278			0.9			1.7			0.62			1.95			1		
11/26/19 4:40	292814.7			0.9			1.61			0.62			1.84			1		
11/26/19 4:41	291967.6			0.9			1.52			0.62			1.73			0		
11/26/19 4:42	293584.9			0.9			1.43			0.62			1.64			0		
11/26/19 4:43	294432.1			0.9			1.34			0.62			1.54			0		
11/26/19 4:44	292814.7			0.9			1.25			0.62			1.43			0		
11/26/19 4:45	293507.9			0.9			1.25			0.62			1.43			0		

CT2 SUSD EVENT 36

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 23:53	344184.4			0.8			2			0.66			2.65			0		
12/04/19 23:54	325161.4			0.9			1.91			0.69			2.39			0		
12/04/19 23:55	311221.5			0.9			1.88			0.65			2.25			0		
12/04/19 23:56	303519.9			1			1.85			0.69			2.16			0		
12/04/19 23:57	286191.3			1			1.79			0.66			1.97			0		
12/04/19 23:58	267399.5			1			1.79			0.62			1.84			1		
12/04/19 23:59	248222.5			0.9			2.21			0.54			2.12			1		
12/05/19 0:00	231433			0.9			4.96			0.51			4.43			1		
12/05/19 0:01	208790.3			0.8			8.95			0.38			7.2			1		
12/05/19 0:02	186224.6			0.5			16.86			0.23			12.1			1		
12/05/19 0:03	163273.9			3			19.12			1.13			12.03			1		
12/05/19 0:04	144636			195.5			21.19			66.21			11.81			1		
12/05/19 0:05	127461.4			1044.1			23.6			311.56			11.59			1		
12/05/19 0:06	36274.5			1848.8			25.34			156.85			3.54			1		
12/05/19 0:07	0			0			28.32			0			0			0		
12/05/19 0:08	0			0			11.8			0			0			0		
12/05/19 0:09	0			0			0.2			0			0			0		
12/05/19 0:10	0			0			0.1			0			0			0		
12/05/19 0:11	0			0			0.1			0			0			0		

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NO _x)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SO _x)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/19 13:00	0			0			0	X		0.19			0.09714			0.32		
10/24/19 14:00	0.7			1.6			2			0.37			0.18714			0.62		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 15:00	0.9			1.7			2			0.39			0.19356			0.65		
10/24/19 16:00	0.8			1.7			1			0.5			0.24786			0.83		
10/24/19 17:00	1.1			1.7			2			0.6			0.30138			1		
10/24/19 18:00	0.9			1.7			2			0.53			0.26406			0.88		
10/24/19 19:00	0.5			1.6			3			0.7			0.3486			1.16		
10/24/19 20:00	1.3			1.8			1			0.58			0.28818			0.96		
10/24/19 21:00	1.3			1.7			2			0.59			0.29268			0.98		
10/24/19 22:00	0.7			1.7			2			0.65			0.32484			1.08		
10/24/19 23:00	1.1			1.7			2			0.45			0.22404			0.75		
10/25/19 0:00	1.1			1.7			2			0.42			0.2091			0.7		
10/25/19 1:00	1.1			1.7			2			0.42			0.20838			0.69		
10/25/19 2:00	1.1			1.7			2			0.42			0.2082			0.69		
10/25/19 3:00	1.3			1.7			2			0.42			0.20766			0.69		
10/25/19 4:00	1.4			1.7			2			0.42			0.20778			0.69		
10/25/19 5:00	1.3			1.7			2			0.42			0.2079			0.69		
10/25/19 6:00	1.3			1.7			2			0.55			0.27582			0.92		
10/25/19 7:00	1.2			1.7			2			0.52			0.26046			0.87		
10/25/19 8:00	1.2			1.7			2			0.46			0.23118			0.77		
10/25/19 9:00	1			1.7			1			0.45			0.22716			0.76		
10/25/19 10:00	0.9			1.7			2			0.45			0.22494			0.75		
10/25/19 11:00	0.8			1.7			2			0.48			0.24198			0.81		
10/25/19 12:00	0.8			1.7			2			0.48			0.24198			0.81		
10/25/19 13:00	0.8			1.7			2			0.49			0.24402			0.81		
10/25/19 14:00	0.9			1.7			2			0.42			0.20946			0.7		
10/25/19 15:00	0.9			1.7			2			0.39			0.19356			0.65		
10/25/19 16:00	0.8			1.7			1			0.48			0.24126			0.8		
10/25/19 17:00	0.8			1.7			2			0.52			0.25854			0.86		
10/25/19 18:00	0.8			1.7			2			0.4			0.19986			0.67		
10/25/19 19:00	0.8			1.7			2			0.63			0.31584			1.05		
10/25/19 20:00	0.6			1.7			3			0.67			0.33702			1.12		
10/25/19 21:00	0.7			1.7			2			0.66			0.32814			1.09		
10/25/19 22:00	0.8			1.7			2			0.66			0.32868			1.1		
10/25/19 23:00	1.3			1.8			2			0.43			0.21426			0.71		
10/26/19 0:00	1.2			1.7			2			0.4			0.20112			0.67		
10/26/19 1:00	1.2			1.7			2			0.4			0.19998			0.67		
10/26/19 2:00	1.2			1.7			2			0.4			0.19974			0.67		
10/26/19 3:00	1.1			1.7			3			0.39			0.1968			0.66		
10/26/19 4:00	1.2			1.7			2			0.42			0.20772			0.69		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/19 5:00	1.3			1.7			2			0.4			0.20154			0.67		
10/26/19 6:00	1.4			1.7			2			0.42			0.21084			0.7		
10/26/19 7:00	1.4			1.7			3			0.41			0.20316			0.68		
10/26/19 8:00	1.5			1.7			2			0.4			0.20022			0.67		
10/26/19 9:00	1			1.7			2			0.4			0.20052			0.67		
10/26/19 10:00	1			1.7			2			0.4			0.19788			0.66		
10/26/19 11:00	0.9			1.7			2			0.4			0.19788			0.66		
10/26/19 12:00	0.9			1.7			2			0.42			0.2121			0.71		
10/26/19 13:00	0.9			1.7			2			0.42			0.21174			0.71		
10/26/19 14:00	0.9			1.7			2			0.41			0.20622			0.69		
10/26/19 15:00	0.9			1.7			2			0.38			0.1902			0.63		
10/26/19 16:00	0.9			1.7			2			0.38			0.19002			0.63		
10/26/19 17:00	0.9			1.7			2			0.42			0.21132			0.7		
10/26/19 18:00	0.9			1.7			2			0.41			0.2067			0.69		
10/26/19 19:00	1			1.7			2			0.41			0.20622			0.69		
10/26/19 20:00	1.2			1.7			2			0.4			0.1986			0.66		
10/26/19 21:00	1.1			1.7			2			0.4			0.1986			0.66		
10/26/19 22:00	1			1.7			2			0.4			0.19824			0.66		
10/26/19 23:00	1			1.7			2			0.4			0.19758			0.66		
10/27/19 0:00	0.9			1.7			2			0.45			0.2229			0.74		
10/27/19 1:00	1			1.7			2			0.41			0.2049			0.68		
10/27/19 2:00	0.9			1.7			2			0.43			0.2157			0.72		
10/27/19 3:00	0.9			1.7			2			0.46			0.23052			0.77		
10/27/19 4:00	0.9			1.7			2			0.46			0.23088			0.77		
10/27/19 5:00	1			1.7			2			0.44			0.2193			0.73		
10/27/19 6:00	0.9			1.7			2			0.46			0.23052			0.77		
10/27/19 7:00	0.9			1.7			2			0.46			0.2307			0.77		
10/27/19 8:00	0.9			1.7			2			0.46			0.23064			0.77		
10/27/19 9:00	0.9			1.7			3			0.39			0.19548			0.65		
10/27/19 10:00	0.8			1.7			3			0.37			0.18606			0.62		
10/27/19 11:00	0.8			1.7			3			0.37			0.18636			0.62		
10/27/19 12:00	0.9			1.7			3			0.38			0.18846			0.63		
10/27/19 13:00	0.9			1.7			3			0.38			0.19032			0.63		
10/27/19 14:00	0.9			1.7			3			0.38			0.18894			0.63		
10/27/19 15:00	0.8			1.7			2			0.45			0.22584			0.75		
10/27/19 16:00	0.9			1.7			2			0.41			0.2055			0.69		
10/27/19 17:00	0.9			1.7			2			0.41			0.2049			0.68		
10/27/19 18:00	0.9			1.7			2			0.43			0.21432			0.71		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/19 19:00	0.9			1.7			3			0.39			0.1956			0.65		
10/27/19 20:00	1			1.7			2			0.41			0.20562			0.69		
10/27/19 21:00	0.9			1.7			2			0.44			0.21918			0.73		
10/27/19 22:00	1			1.7			3			0.42			0.21018			0.7		
10/27/19 23:00	1			1.7			3			0.4			0.2001			0.67		
10/28/19 0:00	1			1.7			3			0.4			0.2001			0.67		
10/28/19 1:00	1			1.7			3			0.4			0.19962			0.67		
10/28/19 2:00	1			1.7			3			0.4			0.19998			0.67		
10/28/19 3:00	1			1.7			3			0.41			0.20298			0.68		
10/28/19 4:00	1.3			1.6			2			0.57			0.28662			0.96		
10/28/19 5:00	1.2			1.7			3			0.6			0.30138			1		
10/28/19 6:00	0.7			1.7			3			0.68			0.3414			1.14		
10/28/19 7:00	0.7			1.7			3			0.68			0.342			1.14		
10/28/19 8:00	1			1.8			2			0.5			0.24846			0.83		
10/28/19 9:00	0.9			1.7			2			0.49			0.24378			0.81		
10/28/19 10:00	0.9			1.7			2			0.49			0.24264			0.81		
10/28/19 11:00	0.9			1.7			2			0.52			0.26184			0.87		
10/28/19 12:00	0.9			1.7			2			0.45			0.22476			0.75		
10/28/19 13:00	0.9			1.7			2			0.45			0.22362			0.75		
10/28/19 14:00	0.9			1.7			2			0.45			0.22506			0.75		
10/28/19 15:00	0.9			1.7			2			0.47			0.2349			0.78		
10/28/19 16:00	0.9			1.7			2			0.46			0.23178			0.77		
10/28/19 17:00	0.9			1.7			2			0.39			0.19548			0.65		
10/28/19 18:00	1.1			1.7			2			0.56			0.28206			0.94		
10/28/19 19:00	1.3			1.7			2			0.54			0.27162			0.91		
10/28/19 20:00	1			1.7			2			0.45			0.22392			0.75		
10/28/19 21:00	1.3			1.7			2			0.57			0.28584			0.95		
10/28/19 22:00	1.4			1.7			2			0.55			0.27324			0.91		
10/28/19 23:00	1			1.7			2			0.51			0.25644			0.85		
10/29/19 0:00	1			1.7			2			0.43			0.21678			0.72		
10/29/19 1:00	1.1			1.7			3			0.41			0.2073			0.69		
10/29/19 2:00	1.1			1.7			3			0.4			0.19938			0.66		
10/29/19 3:00	1			1.7			2			0.48			0.23754			0.79		
10/29/19 4:00	0.8			1.7			4			0.68			0.3405			1.14		
10/29/19 5:00	0.7			1.7			5			0.8			0.39984			1.33		
10/29/19 6:00	0.3			1.7			5			0.81			0.4026			1.34		
10/29/19 7:00	0.3			1.7			5			0.8			0.40194			1.34		
10/29/19 8:00	0.3			1.7			5			0.78			0.39084			1.3		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 9:00	0.3			1.7			5			0.78			0.38808			1.29		
10/29/19 10:00	0.3			1.7			5			0.78			0.39114			1.3		
10/29/19 11:00	0.3			1.7			5			0.77			0.38388			1.28		
10/29/19 12:00	0.3			1.7			5			0.76			0.3813			1.27		
10/29/19 13:00	0.3			1.7			5			0.76			0.3807			1.27		
10/29/19 14:00	0.7			1.7			3			0.66			0.32826			1.09		
10/29/19 15:00	0.3			1.7			4			0.76			0.37758			1.26		
10/29/19 16:00	0.4			1.7			3			0.69			0.34494			1.15		
10/29/19 17:00	0.4			1.7			3			0.69			0.34392			1.15		
10/29/19 18:00	0.5			1.7			3			0.66			0.33192			1.11		
10/29/19 19:00	0.7			1.7			3			0.64			0.3207			1.07		
10/29/19 20:00	0.6			1.7			3			0.67			0.33462			1.12		
10/29/19 21:00	0.5			1.7			3			0.68			0.34158			1.14		
10/29/19 22:00	0.6			1.7			3			0.68			0.33984			1.13		
10/29/19 23:00	0.9			1.8			2			0.51			0.25656			0.86		
10/30/19 0:00	1			1.7			2			0.42			0.2085			0.7		
10/30/19 1:00	1			1.7			3			0.42			0.2094			0.7		
10/30/19 2:00	1			1.7			3			0.43			0.21684			0.72		
10/30/19 3:00	0.9			1.7			3			0.49			0.2466			0.82		
10/30/19 4:00	0.9			1.5			3			0.67			0.3336			1.11		
10/30/19 5:00	1.1			1.7			3			0.64			0.31962			1.07		
10/30/19 6:00	1.1			1.7			3			0.63			0.31494			1.05		
10/30/19 7:00	1			1.7			3			0.54			0.27024			0.9		
10/30/19 8:00	0.9			1.7			3			0.37			0.18684			0.62		
10/30/19 9:00	0.9			1.7			3			0.38			0.18768			0.63		
10/30/19 10:00	0.9			1.7			3			0.38			0.18756			0.63		
10/30/19 11:00	0.9			1.7			3			0.4			0.20094			0.67		
10/30/19 12:00	1.1			1.7			2			0.59			0.29412			0.98		
10/30/19 13:00	1			1.7			2			0.6			0.30066			1		
10/30/19 14:00	0.4			1.7			4			0.71			0.35712			1.19		
10/30/19 15:00	0.3			1.7			4			0.72			0.36192			1.21		
10/30/19 16:00	1			1.7			2			0.59			0.297			0.99		
10/30/19 17:00	0.6			1.7			3			0.67			0.33288			1.11		
10/30/19 18:00	0.7			1.7			3			0.64			0.32118			1.07		
10/30/19 19:00	1.2			1.7			2			0.6			0.2991			1		
10/30/19 20:00	1			1.7			3			0.64			0.31896			1.06		
10/30/19 21:00	1.6			1.7			2			0.59			0.29658			0.99		
10/30/19 22:00	1.2			1.7			2			0.53			0.26442			0.88		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 23:00	1.2			1.7			2			0.5			0.25164			0.84		
10/31/19 0:00	1.2			1.7			3			0.43			0.21618			0.72		
10/31/19 1:00	1.3			1.7			3			0.42			0.21216			0.71		
10/31/19 2:00	1.1			1.7			3			0.43			0.21378			0.71		
10/31/19 3:00	1			1.7			2			0.47			0.2331			0.78		
10/31/19 4:00	1.2			1.5			2			0.64			0.32022			1.07		
10/31/19 5:00	0.9			1.7			3			0.68			0.34098			1.14		
10/31/19 6:00	0.4			1.7			4			0.76			0.37836			1.26		
10/31/19 7:00	0.3			1.7			4			0.77			0.38556			1.29		
10/31/19 8:00	0.3			1.7			4			0.77			0.38292			1.28		
10/31/19 9:00	0.3			1.7			4			0.77			0.38262			1.28		
10/31/19 10:00	0.4			1.7			3			0.72			0.36168			1.21		
10/31/19 11:00	0.5			1.7			3			0.68			0.33834			1.13		
10/31/19 12:00	0.7			1.7			3			0.63			0.31692			1.06		
10/31/19 13:00	0.3			1.7			5			0.76			0.38196			1.27		
10/31/19 14:00	0.3			1.7			4			0.73			0.36264			1.21		
10/31/19 15:00	0.3			1.7			4			0.73			0.363			1.21		
10/31/19 16:00	0.2			1.7			5			0.77			0.38508			1.28		
10/31/19 17:00	0.2			1.7			5			0.77			0.38406			1.28		
10/31/19 18:00	0.3			1.7			4			0.75			0.37554			1.25		
10/31/19 19:00	1.2			1.8			2			0.58			0.2913			0.97		
10/31/19 20:00	1.4			1.7			2			0.58			0.28962			0.97		
10/31/19 21:00	1.5			1.7			2			0.57			0.28542			0.95		
10/31/19 22:00	1.1			1.7			2			0.46			0.23136			0.77		
10/31/19 23:00	1.1			1.7			2			0.41			0.20436			0.68		
11/01/19 0:00	1.1			1.7			2			0.38			0.18936			0.63		
11/01/19 1:00	1			1.7			2			0.39			0.19266			0.64		
11/01/19 2:00	1			1.7			3			0.4			0.20064			0.67		
11/01/19 3:00	1			1.7			2			0.51			0.25542			0.85		
11/01/19 4:00	1.2			1.6			2			0.64			0.31794			1.06		
11/01/19 5:00	0.7			1.7			3			0.7			0.35028			1.17		
11/01/19 6:00	0.3			1.7			4			0.78			0.38868			1.3		
11/01/19 7:00	1.2			1.7			2			0.63			0.31638			1.05		
11/01/19 8:00	1.1			1.7			3			0.63			0.31602			1.05		
11/01/19 9:00	0.8			1.7			3			0.66			0.33066			1.1		
11/01/19 10:00	0.6			1.7			3			0.67			0.3357			1.12		
11/01/19 11:00	1.2			1.7			2			0.58			0.29028			0.97		
11/01/19 12:00	1.1			1.7			2			0.54			0.26778			0.89		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/19 13:00	1			1.7			2			0.53			0.26412			0.88		
11/01/19 14:00	1.1			1.7			2			0.57			0.28614			0.95		
11/01/19 15:00	0.8			1.7			3			0.63			0.3129			1.04		
11/01/19 16:00	1.2			1.7			2			0.56			0.28068			0.94		
11/01/19 17:00	1.1			1.7			2			0.59			0.29562			0.99		
11/01/19 18:00	1.1			1.7			2			0.54			0.26778			0.89		
11/01/19 19:00	1			1.7			2			0.51			0.25698			0.86		
11/01/19 20:00	1.1			1.7			2			0.52			0.25974			0.87		
11/01/19 21:00	0.8			1.7			3			0.68			0.33822			1.13		
11/01/19 22:00	0.8			1.7			3			0.67			0.33636			1.12		
11/01/19 23:00	1.1			1.7			2			0.63			0.31524			1.05		
11/02/19 0:00	1.1			1.7			2			0.52			0.2604			0.87		
11/02/19 1:00	1.1			1.7			2			0.46			0.2301			0.77		
11/02/19 2:00	1.2			1.7			2			0.47			0.23466			0.78		
11/02/19 3:00	1.1			1.7			2			0.45			0.22524			0.75		
11/02/19 4:00	1			1.7			2			0.52			0.26112			0.87		
11/02/19 5:00	1.5			1.7			3			0.62			0.31128			1.04		
11/02/19 6:00	0.8			1.7			3			0.69			0.34362			1.15		
11/02/19 7:00	1.2			1.8			2			0.49			0.24396			0.81		
11/02/19 8:00	1			1.7			2			0.47			0.23712			0.79		
11/02/19 9:00	1			1.7			3			0.39			0.19458			0.65		
11/02/19 10:00	1			1.7			2			0.39			0.1938			0.65		
11/02/19 11:00	0.9			1.7			2			0.38			0.19164			0.64		
11/02/19 12:00	1			1.7			2			0.4			0.201			0.67		
11/02/19 13:00	0.9			1.7			2			0.43			0.21288			0.71		
11/02/19 14:00	1			1.7			2			0.48			0.24246			0.81		
11/02/19 15:00	0.4			1.7			4			0.76			0.37854			1.26		
11/02/19 16:00	0.9			1.7			2			0.6			0.30006			1		
11/02/19 17:00	0.3			1.6			4			0.75			0.37602			1.25		
11/02/19 18:00	1			1.8			1			0.53			0.26298			0.88		
11/02/19 19:00	1			1.7			2			0.5			0.24798			0.83		
11/02/19 20:00	1.6			1.7			2			0.57			0.28446			0.95		
11/02/19 21:00	0.9			1.7			3			0.65			0.32442			1.08		
11/02/19 22:00	1			1.7			2			0.64			0.31974			1.07		
11/02/19 23:00	1.3			1.8			2			0.42			0.21096			0.7		
11/03/19 0:00	1.2			1.7			2			0.4			0.19956			0.67		
11/03/19 1:00	1.1			1.7			2			0.4			0.20124			0.67		
11/03/19 2:00	1.2			1.7			2			0.4			0.20106			0.67		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/19 3:00	1.3			1.7			3			0.4			0.20088			0.67		
11/03/19 4:00	1.3			1.7			2			0.4			0.20058			0.67		
11/03/19 5:00	1.4			1.7			2			0.43			0.21252			0.71		
11/03/19 6:00	1.4			1.7			2			0.41			0.20562			0.69		
11/03/19 7:00	1.3			1.7			2			0.44			0.21816			0.73		
11/03/19 8:00	1.1			1.7			2			0.49			0.24396			0.81		
11/03/19 9:00	1.4			1.7			2			0.56			0.28188			0.94		
11/03/19 10:00	1.1			1.7			2			0.58			0.28968			0.97		
11/03/19 11:00	0.6			1.7			3			0.66			0.32964			1.1		
11/03/19 12:00	1			1.7			2			0.6			0.30174			1.01		
11/03/19 13:00	0.6			1.7			3			0.65			0.3273			1.09		
11/03/19 14:00	0.6			1.7			3			0.64			0.32142			1.07		
11/03/19 15:00	0.4			1.7			3			0.7			0.35058			1.17		
11/03/19 16:00	0.4			1.7			3			0.69			0.3468			1.16		
11/03/19 17:00	1			1.8			1			0.44			0.2217			0.74		
11/03/19 18:00	1			1.7			2			0.42			0.21216			0.71		
11/03/19 19:00	1.1			1.7			2			0.38			0.19086			0.64		
11/03/19 20:00	1.1			1.7			2			0.38			0.19218			0.64		
11/03/19 21:00	1.1			1.7			2			0.39			0.1974			0.66		
11/03/19 22:00	1			1.7			2			0.47			0.23712			0.79		
11/03/19 23:00	1.1			1.7			2			0.4			0.19938			0.66		
11/04/19 0:00	1.2			1.7			2			0.4			0.19908			0.66		
11/04/19 1:00	1.2			1.7			2			0.4			0.19974			0.67		
11/04/19 2:00	1.1			1.7			2			0.4			0.20106			0.67		
11/04/19 3:00	1.1			1.7			2			0.4			0.20118			0.67		
11/04/19 4:00	1.1			1.7			2			0.41			0.20412			0.68		
11/04/19 5:00	1.2			1.7			2			0.46			0.22752			0.76		
11/04/19 6:00	1.1			1.7			2			0.48			0.23964			0.8		
11/04/19 7:00	1.1			1.7			2			0.52			0.26058			0.87		
11/04/19 8:00	0.6			1.6			3			0.71			0.35568			1.19		
11/04/19 9:00	0.3			1.7			4			0.78			0.3882			1.29		
11/04/19 10:00	0.3			1.7			4			0.77			0.38742			1.29		
11/04/19 11:00	0.4			1.7			3			0.73			0.36258			1.21		
11/04/19 12:00	0.4			1.7			3			0.71			0.35298			1.18		
11/04/19 13:00	0.4			1.7			3			0.71			0.35622			1.19		
11/04/19 14:00	0.4			1.7			3			0.7			0.34752			1.16		
11/04/19 15:00	0.4			1.7			3			0.7			0.3489			1.16		
11/04/19 16:00	0.4			1.7			3			0.69			0.34716			1.16		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/19 17:00	1.1			1.8			2			0.57			0.2865			0.96		
11/04/19 18:00	1			1.7			2			0.52			0.26118			0.87		
11/04/19 19:00	1			1.7			2			0.46			0.22842			0.76		
11/04/19 20:00	1.2			1.7			2			0.42			0.20988			0.7		
11/04/19 21:00	1.1			1.7			2			0.48			0.24246			0.81		
11/04/19 22:00	1.1			1.7			2			0.45			0.22572			0.75		
11/04/19 23:00	1.1			1.7			2			0.38			0.19242			0.64		
11/05/19 0:00	1.3			1.7			2			0.41			0.20664			0.69		
11/05/19 1:00	1.4			1.7			2			0.41			0.20334			0.68		
11/05/19 2:00	1.2			1.7			2			0.41			0.20262			0.68		
11/05/19 3:00	1.2			1.7			2			0.4			0.20172			0.67		
11/05/19 4:00	1.2			1.7			2			0.41			0.207			0.69		
11/05/19 5:00	1.3			1.7			2			0.48			0.23802			0.79		
11/05/19 6:00	0.9			1.7			3			0.67			0.33354			1.11		
11/05/19 7:00	1			1.7			2			0.65			0.32604			1.09		
11/05/19 8:00	0.8			1.7			3			0.66			0.33162			1.11		
11/05/19 9:00	0.5			1.7			3			0.7			0.3495			1.17		
11/05/19 10:00	1			1.7			2			0.62			0.30852			1.03		
11/05/19 11:00	1			1.7			2			0.61			0.30546			1.02		
11/05/19 12:00	1			1.7			2			0.6			0.2991			1		
11/05/19 13:00	0.9			1.7			2			0.57			0.28536			0.95		
11/05/19 14:00	1			1.7			2			0.44			0.22062			0.74		
11/05/19 15:00	1			1.7			2			0.53			0.26586			0.89		
11/05/19 16:00	0.7			1.7			2			0.57			0.28308			0.94		
11/05/19 17:00	0.9			1.7			2			0.54			0.27084			0.9		
11/05/19 18:00	0.9			1.7			2			0.54			0.27048			0.9		
11/05/19 19:00	1			1.7			2			0.52			0.25758			0.86		
11/05/19 20:00	1			1.7			2			0.5			0.2499			0.83		
11/05/19 21:00	1.1			1.7			2			0.39			0.1971			0.66		
11/05/19 22:00	1.1			1.7			2			0.39			0.19266			0.64		
11/05/19 23:00	1.1			1.7			2			0.38			0.19026			0.63		
11/06/19 0:00	1.1			1.7			2			0.38			0.1914			0.64		
11/06/19 1:00	1			1.7			2			0.38			0.18942			0.63		
11/06/19 2:00	1			1.7			2			0.37			0.18732			0.62		
11/06/19 3:00	1			1.7			2			0.37			0.1851			0.62		
11/06/19 4:00	1.1			1.7			3			0.36			0.18246			0.61		
11/06/19 5:00	1.7			1.7			3			0.37			0.18378			0.61		
11/06/19 6:00	1.6			1.7			2			0.46			0.22956			0.77		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/19 7:00	1.2			1.7			2			0.47			0.23562			0.79		
11/06/19 8:00	1.2			1.7			2			0.42			0.21186			0.71		
11/06/19 9:00	1			1.7			2			0.44			0.21858			0.73		
11/06/19 10:00	1			1.7			2			0.44			0.21888			0.73		
11/06/19 11:00	1			1.7			2			0.46			0.2283			0.76		
11/06/19 12:00	0.9			1.7			2			0.48			0.23934			0.8		
11/06/19 13:00	0.9			1.7			2			0.48			0.24084			0.8		
11/06/19 14:00	0.9			1.7			2			0.51			0.25344			0.84		
11/06/19 15:00	1.2			1.7			2			0.61			0.30528			1.02		
11/06/19 16:00	1.1			1.7			2			0.62			0.31188			1.04		
11/06/19 17:00	0.3			1.7			3			0.74			0.36792			1.23		
11/06/19 18:00	0.3			1.7			3			0.74			0.37182			1.24		
11/06/19 19:00	0.4			1.7			3			0.72			0.36246			1.21		
11/06/19 20:00	0.4			1.7			3			0.73			0.36726			1.22		
11/06/19 21:00	0.8			1.7			2			0.65			0.32418			1.08		
11/06/19 22:00	1.1			1.7			2			0.45			0.22308			0.74		
11/06/19 23:00	1.1			1.7			2			0.41			0.2025			0.68		
11/07/19 0:00	0.6			1.7			3			0.71			0.35454			1.18		
11/07/19 1:00	0.9			1.7			2			0.65			0.32574			1.09		
11/07/19 2:00	0.9			1.7			2			0.65			0.32448			1.08		
11/07/19 3:00	1			1.7			2			0.65			0.3234			1.08		
11/07/19 4:00	1.1			1.6			2			0.64			0.3207			1.07		
11/07/19 5:00	0.7			1.7			3			0.75			0.37428			1.25		
11/07/19 6:00	0.4			1.7			4			0.77			0.38742			1.29		
11/07/19 7:00	0.4			1.7			4			0.77			0.38688			1.29		
11/07/19 8:00	0.8			1.7			2			0.67			0.33372			1.11		
11/07/19 9:00	0.6			1.7			3			0.7			0.35046			1.17		
11/07/19 10:00	0.6			1.7			2			0.66			0.33138			1.1		
11/07/19 11:00	1			1.8			2			0.41			0.20568			0.69		
11/07/19 12:00	1			1.7			2			0.39			0.19296			0.64		
11/07/19 13:00	0.9			1.7			2			0.38			0.19104			0.64		
11/07/19 14:00	0.9			1.7			2			0.38			0.1908			0.64		
11/07/19 15:00	1			1.7			2			0.39			0.19638			0.65		
11/07/19 16:00	0.9			1.7			1			0.51			0.2559			0.85		
11/07/19 17:00	1			1.7			1			0.54			0.26922			0.9		
11/07/19 18:00	1.6			1.7			2			0.57			0.28566			0.95		
11/07/19 19:00	1.8			1.7			2			0.56			0.27942			0.93		
11/07/19 20:00	1.4			1.7			2			0.48			0.24096			0.8		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:00	0.8			1.7			3			0.67			0.33654			1.12		
11/07/19 22:00	0.4			1.7			4			0.78			0.39126			1.3		
11/07/19 23:00	0.9			1.7			2			0.66			0.3294			1.1		
11/08/19 0:00	1			1.7			2			0.65			0.32718			1.09		
11/08/19 1:00	1.5			1.7			2			0.59			0.29742			0.99		
11/08/19 2:00	1.7			1.7			2			0.59			0.29328			0.98		
11/08/19 3:00	1.6			1.7			2			0.59			0.29484			0.98		
11/08/19 4:00	1.7			1.7			2			0.6			0.30108			1		
11/08/19 5:00	1.1			1.7			3			0.71			0.35496			1.18		
11/08/19 6:00	1			1.7			3			0.68			0.34038			1.13		
11/08/19 7:00	0.5			1.7			4			0.77			0.38664			1.29		
11/08/19 8:00	1.1			1.7			2			0.67			0.33252			1.11		
11/08/19 9:00	0.8			1.7			2			0.67			0.33306			1.11		
11/08/19 10:00	1.1			1.8			2			0.42			0.20844			0.69		
11/08/19 11:00	1			1.7			2			0.38			0.18942			0.63		
11/08/19 12:00	1			1.7			2			0.38			0.19104			0.64		
11/08/19 13:00	1			1.7			2			0.39			0.19614			0.65		
11/08/19 14:00	1			1.7			2			0.4			0.19932			0.66		
11/08/19 15:00	1.3			1.7			1			0.54			0.27072			0.9		
11/08/19 16:00	1.4			1.7			2			0.57			0.2862			0.95		
11/08/19 17:00	0.5			1.7			2			0.7			0.34794			1.16		
11/08/19 18:00	0.4			1.7			3			0.72			0.35952			1.2		
11/08/19 19:00	0.6			1.7			2			0.69			0.34548			1.15		
11/08/19 20:00	1			1.8			2			0.38			0.18858			0.63		
11/08/19 21:00	1			1.7			2			0.38			0.1884			0.63		
11/08/19 22:00	1			1.8			3			0.37			0.18576			0.62		
11/08/19 23:00	1			1.6			2			0.37			0.18294			0.61		
11/09/19 0:00	1.2			1.7			2			0.42			0.21006			0.7		
11/09/19 1:00	1.1			1.7			2			0.38			0.19242			0.64		
11/09/19 2:00	1.1			1.6			2			0.38			0.18882			0.63		
11/09/19 3:00	1.2			1.7			2			0.38			0.19068			0.64		
11/09/19 4:00	1.1			1.6			2			0.38			0.19026			0.63		
11/09/19 5:00	1.2			1.7			2			0.42			0.20958			0.7		
11/09/19 6:00	1.2			1.7			2			0.44			0.2181			0.73		
11/09/19 7:00	1.1			1.7			2			0.47			0.23568			0.79		
11/09/19 8:00	1.2			1.7			2			0.42			0.21036			0.7		
11/09/19 9:00	1.2			1.7			2			0.41			0.20628			0.69		
11/09/19 10:00	1.1			1.7			2			0.41			0.20436			0.68		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/19 11:00	1.1			1.7			2			0.41			0.20406			0.68		
11/09/19 12:00	1			1.7			2			0.41			0.20508			0.68		
11/09/19 13:00	1			1.7			2			0.41			0.20598			0.69		
11/09/19 14:00	1			1.7			2			0.42			0.20904			0.7		
11/09/19 15:00	0.9			1.7			1			0.53			0.26646			0.89		
11/09/19 16:00	0.8			1.7			2			0.64			0.32184			1.07		
11/09/19 17:00	0.9			1.7			2			0.64			0.31854			1.06		
11/09/19 18:00	1.1			1.7			2			0.62			0.31224			1.04		
11/09/19 19:00	1.3			1.7			2			0.59			0.29376			0.98		
11/09/19 20:00	1.1			1.7			2			0.49			0.24672			0.82		
11/09/19 21:00	1.1			1.7			2			0.5			0.25104			0.84		
11/09/19 22:00	1.8			1.7			2			0.57			0.2871			0.96		
11/09/19 23:00	1.2			1.7			2			0.5			0.24756			0.83		
11/10/19 0:00	1.1			1.7			2			0.45			0.22626			0.75		
11/10/19 1:00	1.1			1.7			2			0.4			0.19788			0.66		
11/10/19 2:00	1.1			1.7			2			0.39			0.1971			0.66		
11/10/19 3:00	1.1			1.7			2			0.39			0.19716			0.66		
11/10/19 4:00	1.1			1.7			2			0.4			0.19776			0.66		
11/10/19 5:00	1.2			1.7			2			0.4			0.20166			0.67		
11/10/19 6:00	1.1			1.7			2			0.42			0.2115			0.71		
11/10/19 7:00	1.1			1.7			2			0.46			0.22812			0.76		
11/10/19 8:00	1.2			1.7			2			0.41			0.20706			0.69		
11/10/19 9:00	1			1.7			2			0.44			0.22062			0.74		
11/10/19 10:00	1.1			1.7			2			0.42			0.21192			0.71		
11/10/19 11:00	1			1.7			2			0.43			0.21534			0.72		
11/10/19 12:00	1			1.7			2			0.43			0.21312			0.71		
11/10/19 13:00	1			1.7			2			0.44			0.21912			0.73		
11/10/19 14:00	1			1.7			2			0.43			0.21516			0.72		
11/10/19 15:00	0.9			1.7			1			0.52			0.26028			0.87		
11/10/19 16:00	1			1.7			2			0.51			0.25392			0.85		
11/10/19 17:00	1.3			1.7			2			0.6			0.30198			1.01		
11/10/19 18:00	1.4			1.7			2			0.59			0.29652			0.99		
11/10/19 19:00	1.4			1.7			2			0.54			0.26814			0.89		
11/10/19 20:00	1.1			1.7			2			0.45			0.22716			0.76		
11/10/19 21:00	1.1			1.7			2			0.46			0.22866			0.76		
11/10/19 22:00	1.6			1.7			2			0.56			0.27756			0.93		
11/10/19 23:00	1.1			1.7			2			0.45			0.22692			0.76		
11/11/19 0:00	1.2			1.7			2			0.44			0.21888			0.73		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 1:00	1.3			1.7			2			0.44			0.21798			0.73		
11/11/19 2:00	1.3			1.7			2			0.42			0.20928			0.7		
11/11/19 3:00	1.5			1.7			2			0.42			0.20922			0.7		
11/11/19 4:00	1.7			1.7			2			0.45			0.22638			0.75		
11/11/19 5:00	1.3			1.7			2			0.51			0.25686			0.86		
11/11/19 6:00	1.3			1.7			2			0.54			0.27048			0.9		
11/11/19 7:00	2.1			1.7			2			0.57			0.28722			0.96		
11/11/19 8:00	1.3			1.7			2			0.43			0.21408			0.71		
11/11/19 9:00	1.1			1.7			2			0.42			0.21156			0.71		
11/11/19 10:00	1.1			1.7			2			0.41			0.20448			0.68		
11/11/19 11:00	1			1.7			2			0.4			0.19848			0.66		
11/11/19 12:00	1			1.7			2			0.44			0.22074			0.74		
11/11/19 13:00	1			1.7			2			0.49			0.24276			0.81		
11/11/19 14:00	0.9			1.7			1			0.54			0.26766			0.89		
11/11/19 15:00	1			1.7			2			0.54			0.26928			0.9		
11/11/19 16:00	0.7			1.7			2			0.68			0.3381			1.13		
11/11/19 17:00	0.6			1.8			2			0.68			0.33894			1.13		
11/11/19 18:00	0.7			1.6			2			0.68			0.34104			1.14		
11/11/19 19:00	0.8			1.7			2			0.67			0.33426			1.11		
11/11/19 20:00	1.3			1.8			2			0.41			0.20616			0.69		
11/11/19 21:00	1.2			1.7			2			0.44			0.21786			0.73		
11/11/19 22:00	1.1			1.7			2			0.46			0.22806			0.76		
11/11/19 23:00	1.1			1.6			3			0.41			0.2064			0.69		
11/12/19 0:00	1			1.2			1			0.33			0.16452			0.55		
11/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/19 6:00	0			0			0	X		0.19			0.09258			0.31		
11/13/19 7:00	1.3			1.6			3			0.42			0.2121			0.71		
11/13/19 8:00	1.3			1.7			2			0.44			0.22218			0.74		
11/13/19 9:00	1			1.7			2			0.45			0.2262			0.75		
11/13/19 10:00	1			1.8			4			0.44			0.22248			0.74		
11/13/19 11:00	1			1.4			0			0.45			0.22296			0.74		
11/13/19 12:00	1			1.7			2			0.44			0.22038			0.73		
11/13/19 13:00	1			1.7			2			0.44			0.22218			0.74		
11/13/19 14:00	1			1.7			2			0.46			0.2322			0.77		
11/13/19 15:00	0.9			1.7			2			0.52			0.25992			0.87		
11/13/19 16:00	0.9			1.7			2			0.52			0.2595			0.87		
11/13/19 17:00	0.9			1.7			2			0.52			0.25806			0.86		
11/13/19 18:00	0.9			1.7			2			0.52			0.25908			0.86		
11/13/19 19:00	0.9			1.7			2			0.52			0.2577			0.86		
11/13/19 20:00	1.1			1.7			2			0.51			0.25686			0.86		
11/13/19 21:00	1			1.7			2			0.37			0.18546			0.62		
11/13/19 22:00	1.1			1.7			2			0.38			0.19134			0.64		
11/13/19 23:00	1			1.7			2			0.37			0.18504			0.62		
11/14/19 0:00	1			1.7			2			0.36			0.1821			0.61		
11/14/19 1:00	1.1			1.7			2			0.36			0.18156			0.61		
11/14/19 2:00	1			1.7			2			0.36			0.1815			0.61		
11/14/19 3:00	0.9			1.7			2			0.36			0.18156			0.61		
11/14/19 4:00	0.9			1.6			2			0.36			0.18162			0.61		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 5:00	1.1			1.7			2			0.37			0.18528			0.62		
11/14/19 6:00	1			1.7			1			0.52			0.25926			0.86		
11/14/19 7:00	1.1			1.7			2			0.41			0.20652			0.69		
11/14/19 8:00	1			1.7			2			0.44			0.22104			0.74		
11/14/19 9:00	1			1.7			2			0.45			0.22602			0.75		
11/14/19 10:00	1			1.7			2			0.45			0.2238			0.75		
11/14/19 11:00	1			1.7			2			0.46			0.22932			0.76		
11/14/19 12:00	1			1.7			2			0.45			0.22722			0.76		
11/14/19 13:00	0.9			1.7			2			0.45			0.22572			0.75		
11/14/19 14:00	0.9			1.7			2			0.45			0.22458			0.75		
11/14/19 15:00	0.9			1.7			2			0.52			0.26148			0.87		
11/14/19 16:00	0.9			1.7			2			0.52			0.2604			0.87		
11/14/19 17:00	0.9			1.7			2			0.51			0.25698			0.86		
11/14/19 18:00	0.9			1.7			2			0.51			0.2556			0.85		
11/14/19 19:00	0.9			1.7			2			0.51			0.25428			0.85		
11/14/19 20:00	0.9			1.7			2			0.5			0.24984			0.83		
11/14/19 21:00	1			1.7			2			0.38			0.1893			0.63		
11/14/19 22:00	1			1.7			2			0.38			0.18978			0.63		
11/14/19 23:00	0.9			1.7			2			0.35			0.17658			0.59		
11/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 5:00	0			0			0	X		0.2			0.10092			0.34		
11/21/19 6:00	1.1			1.6			2			0.52			0.26154			0.87		
11/21/19 7:00	1			1.7			2			0.54			0.2691			0.9		
11/21/19 8:00	1			1.7			2			0.55			0.27282			0.91		
11/21/19 9:00	1.1			1.7			2			0.46			0.22878			0.76		
11/21/19 10:00	1			1.7			2			0.45			0.22608			0.75		
11/21/19 11:00	1			1.7			2			0.45			0.22482			0.75		
11/21/19 12:00	1			1.7			2			0.45			0.22518			0.75		
11/21/19 13:00	1			1.7			2			0.45			0.22476			0.75		
11/21/19 14:00	1			1.7			2			0.44			0.22134			0.74		
11/21/19 15:00	0.9			1.7			2			0.51			0.25494			0.85		
11/21/19 16:00	0.9			1.7			2			0.52			0.25962			0.87		
11/21/19 17:00	0.9			1.7			2			0.51			0.25734			0.86		
11/21/19 18:00	0.9			1.7			2			0.51			0.25548			0.85		
11/21/19 19:00	1.8			1.7			2			0.5			0.25176			0.84		
11/21/19 20:00	1			1.7			2			0.5			0.25032			0.83		
11/21/19 21:00	1			1.7			2			0.52			0.26166			0.87		
11/21/19 22:00	1.1			1.7			2			0.38			0.19146			0.64		
11/21/19 23:00	1			1.7			3			0.37			0.18342			0.61		
11/22/19 0:00	1			1.7			2			0.37			0.1845			0.62		
11/22/19 1:00	1.1			1.7			3			0.37			0.18588			0.62		
11/22/19 2:00	1.1			1.7			3			0.37			0.18588			0.62		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/19 3:00	1			1.7			3			0.37			0.1863			0.62		
11/22/19 4:00	1.2			1.7			2			0.37			0.18696			0.62		
11/22/19 5:00	1.3			1.7			3			0.39			0.1959			0.65		
11/22/19 6:00	1.4			1.7			2			0.46			0.23244			0.77		
11/22/19 7:00	1.3			1.7			3			0.43			0.21594			0.72		
11/22/19 8:00	1.2			1.7			2			0.46			0.2298			0.77		
11/22/19 9:00	1			1.7			2			0.46			0.23064			0.77		
11/22/19 10:00	1			1.7			2			0.46			0.2307			0.77		
11/22/19 11:00	1			1.7			2			0.46			0.2313			0.77		
11/22/19 12:00	1			1.7			2			0.47			0.23376			0.78		
11/22/19 13:00	0.9			1.7			2			0.49			0.2457			0.82		
11/22/19 14:00	0.9			1.7			2			0.49			0.24732			0.82		
11/22/19 15:00	1			1.7			2			0.55			0.27306			0.91		
11/22/19 16:00	0.5			1.7			3			0.72			0.36186			1.21		
11/22/19 17:00	0.4			1.7			3			0.73			0.36288			1.21		
11/22/19 18:00	0.4			1.7			3			0.72			0.36216			1.21		
11/22/19 19:00	0.5			1.7			3			0.72			0.36114			1.2		
11/22/19 20:00	0.7			1.7			3			0.71			0.35658			1.19		
11/22/19 21:00	2.2			1.8			2			0.54			0.26784			0.89		
11/22/19 22:00	1.4			1.7			2			0.53			0.26364			0.88		
11/22/19 23:00	1.3			1.7			2			0.52			0.26178			0.87		
11/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 6:00	1.2			1.8			4			0.4			0.20016			0.67		
11/26/19 7:00	1.1			1.7			3			0.49			0.24624			0.82		
11/26/19 8:00	1.1			1.7			3			0.5			0.24894			0.83		
11/26/19 9:00	1.4			1.7			3			0.51			0.25374			0.85		
11/26/19 10:00	1			1.7			3			0.51			0.25542			0.85		
11/26/19 11:00	1			1.7			2			0.51			0.25452			0.85		
11/26/19 12:00	1			1.7			3			0.51			0.25278			0.84		
11/26/19 13:00	0.9			1.7			2			0.51			0.25716			0.86		
11/26/19 14:00	0.9			1.7			2			0.52			0.26154			0.87		
11/26/19 15:00	1.7			1.7			2			0.54			0.27162			0.91		
11/26/19 16:00	1.7			1.7			3			0.58			0.28992			0.97		
11/26/19 17:00	0.3			1.6			4			0.75			0.3771			1.26		
11/26/19 18:00	0.4			1.7			4			0.73			0.36384			1.21		
11/26/19 19:00	1			1.8			2			0.54			0.27168			0.91		
11/26/19 20:00	0.9			1.7			2			0.55			0.27282			0.91		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 21:00	0.9			1.7			2			0.54			0.2676			0.89		
11/26/19 22:00	1			1.7			3			0.45			0.22614			0.75		
11/26/19 23:00	1.1			1.7			3			0.41			0.20586			0.69		
11/27/19 0:00	1.1			1.7			3			0.38			0.1917			0.64		
11/27/19 1:00	0.9			1.7			3			0.37			0.18288			0.61		
11/27/19 2:00	1			1.7			3			0.37			0.1827			0.61		
11/27/19 3:00	0.9			1.7			3			0.37			0.1827			0.61		
11/27/19 4:00	1			1.7			2			0.37			0.18708			0.62		
11/27/19 5:00	1.1			1.7			3			0.4			0.19992			0.67		
11/27/19 6:00	1			1.7			2			0.52			0.25824			0.86		
11/27/19 7:00	1			1.7			2			0.45			0.22386			0.75		
11/27/19 8:00	1			1.7			2			0.45			0.22626			0.75		
11/27/19 9:00	1			1.7			2			0.47			0.23496			0.78		
11/27/19 10:00	1			1.7			2			0.5			0.24912			0.83		
11/27/19 11:00	1			1.7			2			0.49			0.24612			0.82		
11/27/19 12:00	1			1.7			2			0.48			0.24078			0.8		
11/27/19 13:00	1			1.7			3			0.47			0.23658			0.79		
11/27/19 14:00	1			1.7			2			0.45			0.22638			0.75		
11/27/19 15:00	1			1.7			2			0.45			0.22434			0.75		
11/27/19 16:00	1			1.7			2			0.48			0.24192			0.81		
11/27/19 17:00	0.6			1.7			3			0.69			0.3435			1.15		
11/27/19 18:00	1.1			1.7			2			0.55			0.2727			0.91		
11/27/19 19:00	1			1.7			2			0.52			0.25812			0.86		
11/27/19 20:00	1			1.7			2			0.51			0.25338			0.84		
11/27/19 21:00	1			1.7			3			0.48			0.23952			0.8		
11/27/19 22:00	1.1			1.7			3			0.43			0.21528			0.72		
11/27/19 23:00	1			1.7			2			0.38			0.18906			0.63		
11/28/19 0:00	1			1.7			3			0.37			0.1833			0.61		
11/28/19 1:00	0.9			1.7			3			0.37			0.18306			0.61		
11/28/19 2:00	1			1.7			3			0.37			0.18318			0.61		
11/28/19 3:00	1			1.7			3			0.37			0.18318			0.61		
11/28/19 4:00	1.2			1.7			2			0.37			0.1872			0.62		
11/28/19 5:00	1.2			1.7			3			0.39			0.19512			0.65		
11/28/19 6:00	1.1			1.7			3			0.4			0.198			0.66		
11/28/19 7:00	1.1			1.7			3			0.41			0.20556			0.69		
11/28/19 8:00	1			1.7			2			0.45			0.2274			0.76		
11/28/19 9:00	1			1.7			2			0.46			0.23148			0.77		
11/28/19 10:00	1			1.7			3			0.48			0.2379			0.79		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/19 11:00	1			1.7			3			0.47			0.23286			0.78		
11/28/19 12:00	1			1.7			3			0.45			0.22542			0.75		
11/28/19 13:00	1			1.7			3			0.43			0.21486			0.72		
11/28/19 14:00	1.1			1.7			3			0.41			0.20376			0.68		
11/28/19 15:00	1.1			1.7			3			0.4			0.20136			0.67		
11/28/19 16:00	0.9			1.7			3			0.38			0.1884			0.63		
11/28/19 17:00	1			1.7			2			0.5			0.25026			0.83		
11/28/19 18:00	1			1.7			3			0.49			0.24534			0.82		
11/28/19 19:00	0.9			1.7			3			0.37			0.18474			0.62		
11/28/19 20:00	1			1.7			2			0.47			0.23256			0.78		
11/28/19 21:00	1			1.7			3			0.45			0.22398			0.75		
11/28/19 22:00	1.1			1.7			3			0.41			0.20358			0.68		
11/28/19 23:00	1			1.7			3			0.37			0.18372			0.61		
11/29/19 0:00	1.1			1.7			3			0.38			0.18906			0.63		
11/29/19 1:00	1			1.7			3			0.37			0.18522			0.62		
11/29/19 2:00	1			1.7			3			0.37			0.18354			0.61		
11/29/19 3:00	1			1.7			3			0.37			0.1845			0.62		
11/29/19 4:00	1			1.6			3			0.37			0.18594			0.62		
11/29/19 5:00	1.1			1.7			3			0.39			0.19332			0.64		
11/29/19 6:00	1.1			1.7			3			0.4			0.19872			0.66		
11/29/19 7:00	1.2			1.7			3			0.4			0.20064			0.67		
11/29/19 8:00	1.2			1.7			3			0.42			0.2085			0.7		
11/29/19 9:00	1.1			1.7			2			0.46			0.23064			0.77		
11/29/19 10:00	1			1.7			2			0.46			0.23244			0.77		
11/29/19 11:00	1.1			1.7			3			0.45			0.22272			0.74		
11/29/19 12:00	1			1.7			3			0.44			0.21984			0.73		
11/29/19 13:00	1.1			1.7			3			0.44			0.21774			0.73		
11/29/19 14:00	1.1			1.7			3			0.43			0.21276			0.71		
11/29/19 15:00	1.1			1.7			3			0.42			0.20754			0.69		
11/29/19 16:00	0.9			1.7			3			0.39			0.1944			0.65		
11/29/19 17:00	0.8			1.7			3			0.67			0.33744			1.12		
11/29/19 18:00	0.7			1.7			3			0.69			0.3444			1.15		
11/29/19 19:00	0.7			1.7			3			0.67			0.33708			1.12		
11/29/19 20:00	1			1.8			2			0.52			0.26028			0.87		
11/29/19 21:00	1			1.7			3			0.48			0.24216			0.81		
11/29/19 22:00	1.1			1.7			3			0.44			0.21828			0.73		
11/29/19 23:00	1.1			1.7			3			0.39			0.19728			0.66		
11/30/19 0:00	1			1.7			3			0.37			0.18462			0.62		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/19 1:00	1			1.7			3			0.37			0.18456			0.62		
11/30/19 2:00	0.9			1.7			3			0.37			0.18366			0.61		
11/30/19 3:00	1			1.7			3			0.37			0.18402			0.61		
11/30/19 4:00	0.9			1.7			3			0.37			0.1851			0.62		
11/30/19 5:00	1			1.7			3			0.38			0.18918			0.63		
11/30/19 6:00	1			1.7			3			0.39			0.19302			0.64		
11/30/19 7:00	1.1			1.7			3			0.41			0.20676			0.69		
11/30/19 8:00	1			1.7			2			0.46			0.22896			0.76		
11/30/19 9:00	1			1.7			3			0.47			0.23646			0.79		
11/30/19 10:00	1			1.7			3			0.49			0.24312			0.81		
11/30/19 11:00	1			1.7			3			0.47			0.23724			0.79		
11/30/19 12:00	1			1.7			3			0.47			0.2331			0.78		
11/30/19 13:00	1			1.7			3			0.48			0.23808			0.79		
11/30/19 14:00	1			1.7			3			0.47			0.2364			0.79		
11/30/19 15:00	1			1.7			3			0.46			0.23172			0.77		
11/30/19 16:00	1			1.7			3			0.4			0.19818			0.66		
11/30/19 17:00	0.6			1.7			4			0.74			0.3693			1.23		
11/30/19 18:00	1.1			1.8			2			0.55			0.27474			0.92		
11/30/19 19:00	1			1.7			3			0.47			0.23424			0.78		
11/30/19 20:00	1			1.7			2			0.54			0.27			0.9		
11/30/19 21:00	1			1.7			2			0.51			0.25644			0.85		
11/30/19 22:00	1			1.7			3			0.46			0.23076			0.77		
11/30/19 23:00	1.1			1.7			3			0.44			0.21888			0.73		
12/01/19 0:00	1.1			1.7			3			0.41			0.20448			0.68		
12/01/19 1:00	0.9			1.7			3			0.37			0.18384			0.61		
12/01/19 2:00	0.9			1.7			3			0.37			0.18324			0.61		
12/01/19 3:00	0.9			1.7			3			0.37			0.18324			0.61		
12/01/19 4:00	0.9			1.7			2			0.37			0.18372			0.61		
12/01/19 5:00	1			1.7			2			0.38			0.18798			0.63		
12/01/19 6:00	1			1.7			3			0.38			0.1881			0.63		
12/01/19 7:00	1			1.7			3			0.39			0.19338			0.64		
12/01/19 8:00	1.1			1.7			3			0.39			0.1935			0.65		
12/01/19 9:00	1			1.7			3			0.39			0.19302			0.64		
12/01/19 10:00	1.1			1.7			3			0.42			0.20772			0.69		
12/01/19 11:00	1.1			1.7			3			0.41			0.20532			0.68		
12/01/19 12:00	1.1			1.7			3			0.41			0.20292			0.68		
12/01/19 13:00	1.1			1.7			3			0.41			0.20454			0.68		
12/01/19 14:00	1.1			1.7			3			0.43			0.21456			0.72		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/19 15:00	1			1.7			2			0.49			0.24318			0.81		
12/01/19 16:00	1.1			1.7			3			0.41			0.20436			0.68		
12/01/19 17:00	0.7			1.7			3			0.66			0.33222			1.11		
12/01/19 18:00	0.4			1.7			4			0.73			0.36606			1.22		
12/01/19 19:00	1.5			1.8			2			0.57			0.28722			0.96		
12/01/19 20:00	1.5			1.7			2			0.58			0.2895			0.97		
12/01/19 21:00	1.1			1.7			2			0.54			0.27102			0.9		
12/01/19 22:00	1.1			1.7			3			0.44			0.22242			0.74		
12/01/19 23:00	1.1			1.7			3			0.42			0.20856			0.7		
12/02/19 0:00	1.1			1.7			3			0.39			0.19734			0.66		
12/02/19 1:00	1			1.8			3			0.37			0.1839			0.61		
12/02/19 2:00	1			1.7			3			0.37			0.18366			0.61		
12/02/19 3:00	0.9			1.7			2			0.37			0.18402			0.61		
12/02/19 4:00	0.9			1.7			2			0.37			0.18552			0.62		
12/02/19 5:00	1.1			1.7			3			0.4			0.198			0.66		
12/02/19 6:00	1.6			1.7			2			0.56			0.28236			0.94		
12/02/19 7:00	1.1			1.7			2			0.51			0.25674			0.86		
12/02/19 8:00	1			1.7			2			0.49			0.24372			0.81		
12/02/19 9:00	1			1.7			2			0.52			0.26184			0.87		
12/02/19 10:00	1			1.7			2			0.51			0.25464			0.85		
12/02/19 11:00	0.9			1.7			2			0.5			0.25248			0.84		
12/02/19 12:00	0.6			1.7			2			0.52			0.26232			0.87		
12/02/19 13:00	0.6			1.7			2			0.51			0.25524			0.85		
12/02/19 14:00	0.6			1.7			2			0.51			0.25344			0.84		
12/02/19 15:00	0.7			1.7			2			0.54			0.27102			0.9		
12/02/19 16:00	0.4			1.7			3			0.69			0.34398			1.15		
12/02/19 17:00	0.3			1.7			3			0.69			0.34302			1.14		
12/02/19 18:00	0.3			1.7			3			0.68			0.3423			1.14		
12/02/19 19:00	0.4			1.7			3			0.68			0.3384			1.13		
12/02/19 20:00	0.3			1.7			3			0.68			0.34062			1.14		
12/02/19 21:00	0.7			1.8			2			0.53			0.26628			0.89		
12/02/19 22:00	0.6			1.7			3			0.43			0.21354			0.71		
12/02/19 23:00	0.6			1.7			3			0.37			0.1854			0.62		
12/03/19 0:00	0.5			1.7			2			0.37			0.18738			0.62		
12/03/19 1:00	0.6			1.7			3			0.36			0.18234			0.61		
12/03/19 2:00	0.6			1.7			3			0.36			0.18234			0.61		
12/03/19 3:00	0.6			1.7			3			0.36			0.18222			0.61		
12/03/19 4:00	0.6			1.7			3			0.36			0.18228			0.61		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/19 5:00	0.6			1.7			3			0.38			0.19086			0.64		
12/03/19 6:00	0.7			1.7			3			0.4			0.20154			0.67		
12/03/19 7:00	0.6			1.7			2			0.51			0.25548			0.85		
12/03/19 8:00	0.6			1.7			2			0.49			0.24456			0.82		
12/03/19 9:00	0.6			1.7			2			0.53			0.26448			0.88		
12/03/19 10:00	0.6			1.7			2			0.5			0.25122			0.84		
12/03/19 11:00	0.6			1.7			2			0.48			0.23946			0.8		
12/03/19 12:00	0.6			1.7			2			0.47			0.23382			0.78		
12/03/19 13:00	0.6			1.7			2			0.47			0.23424			0.78		
12/03/19 14:00	0.6			1.7			2			0.48			0.24228			0.81		
12/03/19 15:00	0.6			1.7			2			0.48			0.2412			0.8		
12/03/19 16:00	0.6			1.7			2			0.51			0.25452			0.85		
12/03/19 17:00	1			1.7			2			0.59			0.29628			0.99		
12/03/19 18:00	1.2			1.7			2			0.58			0.2877			0.96		
12/03/19 19:00	0.8			1.7			2			0.45			0.2235			0.75		
12/03/19 20:00	1			1.7			2			0.58			0.29154			0.97		
12/03/19 21:00	0.8			1.7			2			0.55			0.27438			0.91		
12/03/19 22:00	0.9			1.7			2			0.54			0.27096			0.9		
12/03/19 23:00	0.6			1.7			3			0.49			0.24384			0.81		
12/04/19 0:00	0.7			1.7			3			0.4			0.1995			0.67		
12/04/19 1:00	0.6			1.7			2			0.37			0.18414			0.61		
12/04/19 2:00	0.6			1.7			3			0.37			0.1839			0.61		
12/04/19 3:00	0.6			1.7			3			0.37			0.18354			0.61		
12/04/19 4:00	0.6			1.7			3			0.37			0.186			0.62		
12/04/19 5:00	0.7			1.7			2			0.5			0.2511			0.84		
12/04/19 6:00	0.6			1.7			2			0.51			0.25506			0.85		
12/04/19 7:00	0.8			1.7			3			0.64			0.31812			1.06		
12/04/19 8:00	0.5			1.7			3			0.67			0.33684			1.12		
12/04/19 9:00	0.5			1.7			3			0.67			0.3348			1.12		
12/04/19 10:00	0.7			1.8			2			0.52			0.26112			0.87		
12/04/19 11:00	0.6			1.7			2			0.51			0.2574			0.86		
12/04/19 12:00	0.6			1.7			2			0.51			0.25494			0.85		
12/04/19 13:00	0.6			1.7			2			0.51			0.25344			0.84		
12/04/19 14:00	0.6			1.7			2			0.52			0.25842			0.86		
12/04/19 15:00	0.6			1.7			2			0.52			0.25974			0.87		
12/04/19 16:00	0.4			1.6			3			0.68			0.34128			1.14		
12/04/19 17:00	0.3			1.7			3			0.69			0.34548			1.15		
12/04/19 18:00	0.3			1.7			3			0.69			0.34542			1.15		

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 19:00	0.3			1.7			3			0.68			0.34116			1.14		
12/04/19 20:00	0.4			1.7			3			0.68			0.33804			1.13		
12/04/19 21:00	0.9			1.7			3			0.6			0.30048			1		
12/04/19 22:00	0.7			1.7			2			0.53			0.26316			0.88		
12/04/19 23:00	0.6			1.7			3			0.41			0.2028			0.68		
12/05/19 0:00	0			0			0	X		0.2			0.09774			0.33		
12/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/01/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/02/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/03/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/04/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/21/19 5:00	0			0	X		0			0	X		0.09276			0.31		
10/21/19 6:00	1.4			1			1.6			0	X		0.25164			0.84		
10/21/19 7:00	1.4			2			1.7			0	X		0.25338			0.84		
10/21/19 8:00	1.3			1			1.7			0	X		0.24444			0.81		
10/21/19 9:00	0.8			2			1.6			0	X		0.32856			1.1		
10/21/19 10:00	1.5			1			1.7			0	X		0.27054			0.9		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/19 11:00	1			2			1.7			0	X		0.3021			1.01		
10/21/19 12:00	0.7			2			1.7			0	X		0.33042			1.1		
10/21/19 13:00	0.7			2			1.7			0	X		0.32994			1.1		
10/21/19 14:00	0.7			2			1.7			0	X		0.327			1.09		
10/21/19 15:00	0.6			2			1.7			0	X		0.29946			1		
10/21/19 16:00	0.5			2			1.7			0	X		0.31002			1.03		
10/21/19 17:00	0.2			3			1.7			0	X		0.35784			1.19		
10/21/19 18:00	0.5			2			1.7			0	X		0.31512			1.05		
10/21/19 19:00	0.8			1			1.8			0	X		0.24894			0.83		
10/21/19 20:00	0.7			1			1.7			0	X		0.23952			0.8		
10/21/19 21:00	0.7			1			1.7			0	X		0.2277			0.76		
10/21/19 22:00	0.9			1			1.7			0	X		0.18924			0.63		
10/21/19 23:00	0.8			2			1.7			0	X		0.183			0.61		
10/22/19 0:00	0.8			2			1.7			0	X		0.18264			0.61		
10/22/19 1:00	1			2			1.7			0	X		0.17958			0.6		
10/22/19 2:00	1.2			2			1.7			0	X		0.17934			0.6		
10/22/19 3:00	1.5			2			1.7			0	X		0.17976			0.6		
10/22/19 4:00	1.2			1			1.6			0	X		0.18708			0.62		
10/22/19 5:00	1.1			1			1.7			0	X		0.20466			0.68		
10/22/19 6:00	1.3			1			1.8			0	X		0.20964			0.7		
10/22/19 7:00	1.7			1			1.7			0	X		0.22224			0.74		
10/22/19 8:00	0.7			2			1.6			0	X		0.31458			1.05		
10/22/19 9:00	0.9			1			1.8			0	X		0.18768			0.63		
10/22/19 10:00	0.5			2			1.6			0	X		0.315			1.05		
10/22/19 11:00	0.3			3			1.6			0	X		0.32634			1.09		
10/22/19 12:00	0.5			2			1.7			0	X		0.23838			0.79		
10/22/19 13:00	0.5			2			1.6			0	X		0.3066			1.02		
10/22/19 14:00	0.4			2			1.6			0	X		0.32844			1.09		
10/22/19 15:00	0.7			2			1.6			0	X		0.29394			0.98		
10/22/19 16:00	0.9			2			1.6			0	X		0.28386			0.95		
10/22/19 17:00	0.6			2			1.6			0	X		0.3075			1.03		
10/22/19 18:00	0.8			2			1.7			0	X		0.29628			0.99		
10/22/19 19:00	1			2			1.7			0	X		0.2874			0.96		
10/22/19 20:00	0.9			1			1.7			0	X		0.23412			0.78		
10/22/19 21:00	0.9			1			1.7			0	X		0.231			0.77		
10/22/19 22:00	0.8			1			1.7			0	X		0.23088			0.77		
10/22/19 23:00	1			1			1.7			0	X		0.18828			0.63		
10/23/19 0:00	1.1			2			1.7			0	X		0.18258			0.61		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/19 1:00	1			2			1.7			0	X		0.17904			0.6		
10/23/19 2:00	1			2			1.7			0	X		0.17904			0.6		
10/23/19 3:00	0.8			2			1.7			0	X		0.17952			0.6		
10/23/19 4:00	0.9			1			1.7			0	X		0.1887			0.63		
10/23/19 5:00	1			1			1.7			0	X		0.19062			0.64		
10/23/19 6:00	0.9			1			1.7			0	X		0.21204			0.71		
10/23/19 7:00	1			2			1.6			0	X		0.28344			0.94		
10/23/19 8:00	0.4			2			1.7			0	X		0.3327			1.11		
10/23/19 9:00	0.4			2			1.7			0	X		0.3165			1.06		
10/23/19 10:00	0.3			2			1.7			0	X		0.32136			1.07		
10/23/19 11:00	0.4			2			1.7			0	X		0.3063			1.02		
10/23/19 12:00	0.7			1			1.7			0	X		0.2874			0.96		
10/23/19 13:00	1.1			1			1.7			0	X		0.2634			0.88		
10/23/19 14:00	1.1			1			1.7			0	X		0.25572			0.85		
10/23/19 15:00	0.8			2			1.7			0	X		0.2829			0.94		
10/23/19 16:00	1			2			1.7			0	X		0.27576			0.92		
10/23/19 17:00	0.3			2			1.7			0	X		0.3306			1.1		
10/23/19 18:00	0.8			2			1.7			0	X		0.28794			0.96		
10/23/19 19:00	0.8			1			1.7			0	X		0.24282			0.81		
10/23/19 20:00	0.7			1			1.7			0	X		0.23286			0.78		
10/23/19 21:00	1.2			2			1.7			0	X		0.26856			0.9		
10/23/19 22:00	0.8			1			1.7			0	X		0.21516			0.72		
10/23/19 23:00	0.8			1			1.7			0	X		0.19878			0.66		
10/24/19 0:00	0.9			2			1.7			0	X		0.18954			0.63		
10/24/19 1:00	0.8			1			1.7			0	X		0.18936			0.63		
10/24/19 2:00	0.8			2			1.7			0	X		0.19014			0.63		
10/24/19 3:00	0.8			2			1.7			0	X		0.19014			0.63		
10/24/19 4:00	0.8			1			1.8			0	X		0.21702			0.72		
10/24/19 5:00	0.9			2			1.7			0	X		0.29376			0.98		
10/24/19 6:00	0.7			2			1.7			0	X		0.30348			1.01		
10/24/19 7:00	0.8			1			1.8			0	X		0.25338			0.84		
10/24/19 8:00	0.7			1			1.7			0	X		0.22506			0.75		
10/24/19 9:00	0.8			1			1.7			0	X		0.19878			0.66		
10/24/19 10:00	0.8			1			1.7			0	X		0.19368			0.65		
10/24/19 11:00	0.8			1			1.7			0	X		0.19434			0.65		
10/24/19 12:00	0.8			1			1.7			0	X		0.19482			0.65		
10/24/19 13:00	0.8			1			1.7			0.19			0.19482			0.65		
10/24/19 14:00	0.7			1			1.7			0.37			0.17652			0.59		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/19 15:00	0.8			1			1.7			0.39			0.18642			0.62		
10/24/19 16:00	0.8			1			1.7			0.5			0.24198			0.81		
10/24/19 17:00	0.9			2			1.7			0.6			0.28512			0.95		
10/24/19 18:00	0.8			1			1.7			0.53			0.22896			0.76		
10/24/19 19:00	0			0	X		0			0.7			0.08358			0.28		
10/24/19 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/24/19 21:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/24/19 22:00	0	X		0	X		0	X		0.65			0	X		0	X	
10/24/19 23:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/25/19 0:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 1:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 2:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 3:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 4:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 5:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/25/19 6:00	0	X		0	X		0	X		0.55			0	X		0	X	
10/25/19 7:00	0	X		0	X		0	X		0.52			0	X		0	X	
10/25/19 8:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/25/19 9:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/25/19 10:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/25/19 11:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/25/19 12:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/25/19 13:00	0			0	X		0			0.49			0.08856			0.3		
10/25/19 14:00	0.8			1			1.5			0.42			0.19512			0.65		
10/25/19 15:00	0.8			1			1.7			0.39			0.18792			0.63		
10/25/19 16:00	0.7			1			1.8			0.48			0.23838			0.79		
10/25/19 17:00	0.7			1			1.7			0.52			0.24942			0.83		
10/25/19 18:00	0.8			1			1.7			0.4			0.18108			0.6		
10/25/19 19:00	0	X		0	X		0	X		0.63			0	X		0	X	
10/25/19 20:00	0	X		0	X		0	X		0.67			0	X		0	X	
10/25/19 21:00	0	X		0	X		0	X		0.66			0	X		0	X	
10/25/19 22:00	0	X		0	X		0	X		0.66			0	X		0	X	
10/25/19 23:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/26/19 0:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 3:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/26/19 4:00	0	X		0	X		0	X		0.42			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/19 5:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 6:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/26/19 7:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/26/19 8:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 9:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 10:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 11:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 12:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/26/19 13:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/26/19 14:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/26/19 15:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/26/19 16:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/26/19 17:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/26/19 18:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/26/19 19:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/26/19 20:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 21:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 22:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/26/19 23:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/27/19 0:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/27/19 1:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/27/19 2:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/27/19 3:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/27/19 4:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/27/19 5:00	0	X		0	X		0	X		0.44			0	X		0	X	
10/27/19 6:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/27/19 7:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/27/19 8:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/27/19 9:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/27/19 10:00	0	X		0	X		0	X		0.37			0	X		0	X	
10/27/19 11:00	0	X		0	X		0	X		0.37			0	X		0	X	
10/27/19 12:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/27/19 13:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/27/19 14:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/27/19 15:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/27/19 16:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/27/19 17:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/27/19 18:00	0	X		0	X		0	X		0.43			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/19 19:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/27/19 20:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/27/19 21:00	0	X		0	X		0	X		0.44			0	X		0	X	
10/27/19 22:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/27/19 23:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/28/19 0:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/28/19 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/28/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/28/19 3:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/28/19 4:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/28/19 5:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/28/19 6:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/28/19 7:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/28/19 8:00	0	X		0	X		0	X		0.5			0	X		0	X	
10/28/19 9:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/28/19 10:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/28/19 11:00	0	X		0	X		0	X		0.52			0	X		0	X	
10/28/19 12:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/28/19 13:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/28/19 14:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/28/19 15:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/28/19 16:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/28/19 17:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/28/19 18:00	0	X		0	X		0	X		0.56			0	X		0	X	
10/28/19 19:00	0	X		0	X		0	X		0.54			0	X		0	X	
10/28/19 20:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/28/19 21:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/28/19 22:00	0	X		0	X		0	X		0.55			0	X		0	X	
10/28/19 23:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/29/19 0:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/29/19 1:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/29/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/29/19 3:00	0			0	X		0			0.48			0.06312			0.21		
10/29/19 4:00	0			0	X		0			0.68			0.06732			0.22		
10/29/19 5:00	0			0	X		0			0.8			0.03918			0.13		
10/29/19 6:00	0	X		0	X		0	X		0.81			0	X		0	X	
10/29/19 7:00	0	X		0	X		0	X		0.8			0	X		0	X	
10/29/19 8:00	0	X		0	X		0	X		0.78			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/19 9:00	0			0	X		0			0.78			0.0429			0.14		
10/29/19 10:00	0			0	X		0			0.78			0.0096			0.03		
10/29/19 11:00	0	X		0	X		0	X		0.77			0.04392			0.15		
10/29/19 12:00	0	X		0	X		0	X		0.76			0.0243			0.08		
10/29/19 13:00	0	X		0	X		0	X		0.76			0.03552			0.12		
10/29/19 14:00	0	X		0	X		0	X		0.66			0	X		0	X	
10/29/19 15:00	0	X		0	X		0	X		0.76			0	X		0	X	
10/29/19 16:00	0	X		0	X		0	X		0.69			0	X		0	X	
10/29/19 17:00	0	X		0	X		0	X		0.69			0	X		0	X	
10/29/19 18:00	0	X		0	X		0	X		0.66			0	X		0	X	
10/29/19 19:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/29/19 20:00	0	X		0	X		0	X		0.67			0	X		0	X	
10/29/19 21:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/29/19 22:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/29/19 23:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/30/19 0:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/30/19 1:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/30/19 2:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/30/19 3:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/30/19 4:00	0	X		0	X		0	X		0.67			0	X		0	X	
10/30/19 5:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/30/19 6:00	0	X		0	X		0	X		0.63			0	X		0	X	
10/30/19 7:00	0	X		0	X		0	X		0.54			0.15102			0.5		
10/30/19 8:00	0	X		0	X		0	X		0.37			0.1836			0.61		
10/30/19 9:00	0.8			2			1.7			0.38			0.17832			0.59		
10/30/19 10:00	0.8			1			1.7			0.38			0.17766			0.59		
10/30/19 11:00	0.8			2			1.7			0.4			0.16794			0.56		
10/30/19 12:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/30/19 13:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/30/19 14:00	0	X		0	X		0	X		0.71			0	X		0	X	
10/30/19 15:00	0	X		0	X		0	X		0.72			0	X		0	X	
10/30/19 16:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/30/19 17:00	0	X		0	X		0	X		0.67			0	X		0	X	
10/30/19 18:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/30/19 19:00	0	X		0	X		0	X		0.6			0	X		0	X	
10/30/19 20:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/30/19 21:00	0	X		0	X		0	X		0.59			0	X		0	X	
10/30/19 22:00	0	X		0	X		0	X		0.53			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/19 23:00	0	X		0	X		0	X		0.5			0	X		0	X	
10/31/19 0:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/31/19 1:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/31/19 2:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/31/19 3:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/31/19 4:00	0	X		0	X		0	X		0.64			0	X		0	X	
10/31/19 5:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/31/19 6:00	0	X		0	X		0	X		0.76			0	X		0	X	
10/31/19 7:00	0	X		0	X		0	X		0.77			0	X		0	X	
10/31/19 8:00	0	X		0	X		0	X		0.77			0	X		0	X	
10/31/19 9:00	0	X		0	X		0	X		0.77			0	X		0	X	
10/31/19 10:00	0	X		0	X		0	X		0.72			0	X		0	X	
10/31/19 11:00	0	X		0	X		0	X		0.68			0	X		0	X	
10/31/19 12:00	0	X		0	X		0	X		0.63			0	X		0	X	
10/31/19 13:00	0	X		0	X		0	X		0.76			0	X		0	X	
10/31/19 14:00	0	X		0	X		0	X		0.73			0	X		0	X	
10/31/19 15:00	0	X		0	X		0	X		0.73			0	X		0	X	
10/31/19 16:00	0	X		0	X		0	X		0.77			0	X		0	X	
10/31/19 17:00	0	X		0	X		0	X		0.77			0	X		0	X	
10/31/19 18:00	0	X		0	X		0	X		0.75			0	X		0	X	
10/31/19 19:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/31/19 20:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/31/19 21:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/31/19 22:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/31/19 23:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/01/19 0:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/01/19 1:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/01/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/01/19 3:00	0	X		0	X		0	X		0.51			0	X		0	X	
11/01/19 4:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/01/19 5:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/01/19 6:00	0	X		0	X		0	X		0.78			0	X		0	X	
11/01/19 7:00	0	X		0	X		0	X		0.63			0	X		0	X	
11/01/19 8:00	0	X		0	X		0	X		0.63			0	X		0	X	
11/01/19 9:00	0	X		0	X		0	X		0.66			0	X		0	X	
11/01/19 10:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/01/19 11:00	0	X		0	X		0	X		0.58			0	X		0	X	
11/01/19 12:00	0	X		0	X		0	X		0.54			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/19 13:00	0	X		0	X		0	X		0.53			0	X		0	X	
11/01/19 14:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/01/19 15:00	0	X		0	X		0	X		0.63			0	X		0	X	
11/01/19 16:00	0	X		0	X		0	X		0.56			0	X		0	X	
11/01/19 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/01/19 18:00	0	X		0	X		0	X		0.54			0	X		0	X	
11/01/19 19:00	0	X		0	X		0	X		0.51			0	X		0	X	
11/01/19 20:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/01/19 21:00	0	X		0	X		0	X		0.68			0	X		0	X	
11/01/19 22:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/01/19 23:00	0	X		0	X		0	X		0.63			0	X		0	X	
11/02/19 0:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/02/19 1:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/02/19 2:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/02/19 3:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/02/19 4:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/02/19 5:00	0	X		0	X		0	X		0.62			0	X		0	X	
11/02/19 6:00	0	X		0	X		0	X		0.69			0	X		0	X	
11/02/19 7:00	0	X		0	X		0	X		0.49			0	X		0	X	
11/02/19 8:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/02/19 9:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/02/19 10:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/02/19 11:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/02/19 12:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/02/19 13:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/02/19 14:00	0	X		0	X		0	X		0.48			0	X		0	X	
11/02/19 15:00	0	X		0	X		0	X		0.76			0	X		0	X	
11/02/19 16:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/02/19 17:00	0	X		0	X		0	X		0.75			0	X		0	X	
11/02/19 18:00	0	X		0	X		0	X		0.53			0	X		0	X	
11/02/19 19:00	0	X		0	X		0	X		0.5			0	X		0	X	
11/02/19 20:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/02/19 21:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/02/19 22:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/02/19 23:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/03/19 0:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/03/19 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/03/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/19 3:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/03/19 4:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/03/19 5:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/03/19 6:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/03/19 7:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/03/19 8:00	0	X		0	X		0	X		0.49			0	X		0	X	
11/03/19 9:00	0	X		0	X		0	X		0.56			0	X		0	X	
11/03/19 10:00	0	X		0	X		0	X		0.58			0	X		0	X	
11/03/19 11:00	0	X		0	X		0	X		0.66			0	X		0	X	
11/03/19 12:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/03/19 13:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/03/19 14:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/03/19 15:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/03/19 16:00	0	X		0	X		0	X		0.69			0	X		0	X	
11/03/19 17:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/03/19 18:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/03/19 19:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/03/19 20:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/03/19 21:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/03/19 22:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/03/19 23:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/04/19 0:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/04/19 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/04/19 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/04/19 3:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/04/19 4:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/04/19 5:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/04/19 6:00	0	X		0	X		0	X		0.48			0	X		0	X	
11/04/19 7:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/04/19 8:00	0	X		0	X		0	X		0.71			0	X		0	X	
11/04/19 9:00	0	X		0	X		0	X		0.78			0	X		0	X	
11/04/19 10:00	0	X		0	X		0	X		0.77			0	X		0	X	
11/04/19 11:00	0	X		0	X		0	X		0.73			0	X		0	X	
11/04/19 12:00	0	X		0	X		0	X		0.71			0	X		0	X	
11/04/19 13:00	0	X		0	X		0	X		0.71			0	X		0	X	
11/04/19 14:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/04/19 15:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/04/19 16:00	0	X		0	X		0	X		0.69			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/19 17:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/04/19 18:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/04/19 19:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/04/19 20:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/04/19 21:00	0	X		0	X		0	X		0.48			0	X		0	X	
11/04/19 22:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/04/19 23:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/05/19 0:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/05/19 1:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/05/19 2:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/05/19 3:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/05/19 4:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/05/19 5:00	0	X		0	X		0	X		0.48			0	X		0	X	
11/05/19 6:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/05/19 7:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/05/19 8:00	0	X		0	X		0	X		0.66			0	X		0	X	
11/05/19 9:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/05/19 10:00	0	X		0	X		0	X		0.62			0	X		0	X	
11/05/19 11:00	0	X		0	X		0	X		0.61			0	X		0	X	
11/05/19 12:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/05/19 13:00	0			0	X		0			0.57			0.09792			0.33		
11/05/19 14:00	0.9			1			1.4			0.44			0.207			0.69		
11/05/19 15:00	1			1			1.7			0.53			0.25032			0.83		
11/05/19 16:00	0.6			1			1.8			0.57			0.2676			0.89		
11/05/19 17:00	0.9			1			1.6			0.54			0.25584			0.85		
11/05/19 18:00	0.9			1			1.7			0.54			0.25578			0.85		
11/05/19 19:00	0.9			1			1.7			0.52			0.24408			0.81		
11/05/19 20:00	1			1			1.7			0.5			0.23688			0.79		
11/05/19 21:00	1.1			2			1.7			0.39			0.18858			0.63		
11/05/19 22:00	1.1			1			1.7			0.39			0.18948			0.63		
11/05/19 23:00	1.1			1			1.7			0.38			0.19254			0.64		
11/06/19 0:00	1			1			1.7			0.38			0.19824			0.66		
11/06/19 1:00	1			1			1.7			0.38			0.2004			0.67		
11/06/19 2:00	1			1			1.7			0.37			0.20262			0.68		
11/06/19 3:00	1			1			1.7			0.37			0.20496			0.68		
11/06/19 4:00	1.2			1			1.7			0.36			0.20712			0.69		
11/06/19 5:00	1.6			1			1.7			0.37			0.2085			0.7		
11/06/19 6:00	1.6			1			1.7			0.46			0.2241			0.75		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/19 7:00	1.1			1			1.7			0.47			0.225			0.75		
11/06/19 8:00	1.2			1			1.7			0.42			0.2055			0.69		
11/06/19 9:00	0.9			1			1.7			0.44			0.21786			0.73		
11/06/19 10:00	0.9			1			1.7			0.44			0.22032			0.73		
11/06/19 11:00	0.9			1			1.7			0.46			0.2166			0.72		
11/06/19 12:00	0.9			1			1.7			0.48			0.231			0.77		
11/06/19 13:00	0.8			1			1.7			0.48			0.23676			0.79		
11/06/19 14:00	0.8			1			1.7			0.51			0.25044			0.83		
11/06/19 15:00	1.1			1			1.7			0.61			0.28896			0.96		
11/06/19 16:00	0.9			2			1.7			0.62			0.29586			0.99		
11/06/19 17:00	0.3			2			1.7			0.74			0.3516			1.17		
11/06/19 18:00	0.3			3			1.7			0.74			0.35622			1.19		
11/06/19 19:00	0.4			2			1.7			0.72			0.3471			1.16		
11/06/19 20:00	0.4			2			1.7			0.73			0.35112			1.17		
11/06/19 21:00	0.7			2			1.7			0.65			0.3087			1.03		
11/06/19 22:00	1			1			1.7			0.45			0.21546			0.72		
11/06/19 23:00	1			1			1.7			0.41			0.17802			0.59		
11/07/19 0:00	0			0	X		0			0.71			0.07296			0.24		
11/07/19 1:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/07/19 2:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/07/19 3:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/07/19 4:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/07/19 5:00	0	X		0	X		0	X		0.75			0	X		0	X	
11/07/19 6:00	0	X		0	X		0	X		0.77			0	X		0	X	
11/07/19 7:00	0	X		0	X		0	X		0.77			0	X		0	X	
11/07/19 8:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/07/19 9:00	0	X		0	X		0	X		0.7			0	X		0	X	
11/07/19 10:00	0			0	X		0			0.66			0.09912			0.33		
11/07/19 11:00	0.9			1			1.6			0.41			0.19476			0.65		
11/07/19 12:00	0.9			2			1.7			0.39			0.18204			0.61		
11/07/19 13:00	0.8			1			1.7			0.38			0.17976			0.6		
11/07/19 14:00	0.9			1			1.7			0.38			0.1812			0.6		
11/07/19 15:00	0.9			1			1.7			0.39			0.19092			0.64		
11/07/19 16:00	0.8			1			1.7			0.51			0.2466			0.82		
11/07/19 17:00	1			1			1.7			0.54			0.25686			0.86		
11/07/19 18:00	1.7			1			1.7			0.57			0.26484			0.88		
11/07/19 19:00	2			1			1.7			0.56			0.24648			0.82		
11/07/19 20:00	1.5			1			1.7			0.48			0.2148			0.72		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/19 21:00	1.2			1			1.7			0.67			0.1527			0.51		
11/07/19 22:00	0	X		0	X		0	X		0.78			0	X		0	X	
11/07/19 23:00	0	X		0	X		0	X		0.66			0	X		0	X	
11/08/19 0:00	0	X		0	X		0	X		0.65			0	X		0	X	
11/08/19 1:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/19 2:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/19 3:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/08/19 4:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/08/19 5:00	0	X		0	X		0	X		0.71			0	X		0	X	
11/08/19 6:00	0	X		0	X		0	X		0.68			0	X		0	X	
11/08/19 7:00	0	X		0	X		0	X		0.77			0	X		0	X	
11/08/19 8:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/08/19 9:00	0			0	X		0			0.67			0.10206			0.34		
11/08/19 10:00	1			1			1.5			0.42			0.19566			0.65		
11/08/19 11:00	0.9			2			1.7			0.38			0.1812			0.6		
11/08/19 12:00	0.9			1			1.7			0.38			0.1863			0.62		
11/08/19 13:00	1			1			1.7			0.39			0.19452			0.65		
11/08/19 14:00	0.9			1			1.7			0.4			0.20166			0.67		
11/08/19 15:00	1.5			1			1.7			0.54			0.25602			0.85		
11/08/19 16:00	1.6			1			1.7			0.57			0.26478			0.88		
11/08/19 17:00	0.5			2			1.7			0.7			0.33258			1.11		
11/08/19 18:00	0.4			2			1.7			0.72			0.34428			1.15		
11/08/19 19:00	0.5			2			1.7			0.69			0.33048			1.1		
11/08/19 20:00	0.9			1			1.7			0.38			0.18522			0.62		
11/08/19 21:00	1			2			1.7			0.38			0.1881			0.63		
11/08/19 22:00	1			2			1.8			0.37			0.18894			0.63		
11/08/19 23:00	0.9			2			1.6			0.37			0.17232			0.57		
11/09/19 0:00	0			0	X		0			0.42			0.07494			0.25		
11/09/19 1:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/09/19 2:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/09/19 3:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/09/19 4:00	0	X		0	X		0	X		0.38			0	X		0	X	
11/09/19 5:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/09/19 6:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/09/19 7:00	0	X		0	X		0	X		0.47			0	X		0	X	
11/09/19 8:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/09/19 9:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/09/19 10:00	0	X		0	X		0	X		0.41			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/19 11:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/09/19 12:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/09/19 13:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/09/19 14:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/09/19 15:00	0	X		0	X		0	X		0.53			0	X		0	X	
11/09/19 16:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/09/19 17:00	0	X		0	X		0	X		0.64			0	X		0	X	
11/09/19 18:00	0	X		0	X		0	X		0.62			0	X		0	X	
11/09/19 19:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/09/19 20:00	0	X		0	X		0	X		0.49			0	X		0	X	
11/09/19 21:00	0	X		0	X		0	X		0.5			0	X		0	X	
11/09/19 22:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/09/19 23:00	0	X		0	X		0	X		0.5			0	X		0	X	
11/10/19 0:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/10/19 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/10/19 2:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/10/19 3:00	0	X		0	X		0	X		0.39			0	X		0	X	
11/10/19 4:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/10/19 5:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/10/19 6:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/10/19 7:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/10/19 8:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/10/19 9:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/10/19 10:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/10/19 11:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/10/19 12:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/10/19 13:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/10/19 14:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/10/19 15:00	0	X		0	X		0	X		0.52			0	X		0	X	
11/10/19 16:00	0	X		0	X		0	X		0.51			0	X		0	X	
11/10/19 17:00	0	X		0	X		0	X		0.6			0	X		0	X	
11/10/19 18:00	0	X		0	X		0	X		0.59			0	X		0	X	
11/10/19 19:00	0	X		0	X		0	X		0.54			0	X		0	X	
11/10/19 20:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/10/19 21:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/10/19 22:00	0	X		0	X		0	X		0.56			0	X		0	X	
11/10/19 23:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/11/19 0:00	0	X		0	X		0	X		0.44			0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/19 1:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/11/19 2:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/11/19 3:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/11/19 4:00	0	X		0	X		0	X		0.45			0	X		0	X	
11/11/19 5:00	0	X		0	X		0	X		0.51			0	X		0	X	
11/11/19 6:00	0	X		0	X		0	X		0.54			0	X		0	X	
11/11/19 7:00	0	X		0	X		0	X		0.57			0	X		0	X	
11/11/19 8:00	0	X		0	X		0	X		0.43			0	X		0	X	
11/11/19 9:00	0	X		0	X		0	X		0.42			0	X		0	X	
11/11/19 10:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/11/19 11:00	0	X		0	X		0	X		0.4			0	X		0	X	
11/11/19 12:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/11/19 13:00	0	X		0	X		0	X		0.49			0	X		0	X	
11/11/19 14:00	0	X		0	X		0	X		0.54			0	X		0	X	
11/11/19 15:00	0	X		0	X		0	X		0.54			0	X		0	X	
11/11/19 16:00	0	X		0	X		0	X		0.68			0	X		0	X	
11/11/19 17:00	0	X		0	X		0	X		0.68			0	X		0	X	
11/11/19 18:00	0	X		0	X		0	X		0.68			0	X		0	X	
11/11/19 19:00	0	X		0	X		0	X		0.67			0	X		0	X	
11/11/19 20:00	0	X		0	X		0	X		0.41			0	X		0	X	
11/11/19 21:00	0	X		0	X		0	X		0.44			0	X		0	X	
11/11/19 22:00	0	X		0	X		0	X		0.46			0	X		0	X	
11/11/19 23:00	0			0	X		0			0.41			0.1389			0.46		
11/12/19 0:00	1			1			1.6			0.33			0.1938			0.65		
11/12/19 1:00	1			1			1.7		X	0			0.19446			0.65		
11/12/19 2:00	1			1			1.7		X	0			0.18852			0.63		
11/12/19 3:00	1.1			1			1.7		X	0			0.18786			0.63		
11/12/19 4:00	1.1			1			1.7		X	0			0.20652			0.69		
11/12/19 5:00	1.1			1			1.7		X	0			0.23802			0.79		
11/12/19 6:00	1.2			2			1.6		X	0			0.3			1		
11/12/19 7:00	1.4			2			1.7		X	0			0.28218			0.94		
11/12/19 8:00	1.3			1			1.7		X	0			0.20232			0.67		
11/12/19 9:00	0.9			1			1.7		X	0			0.22578			0.75		
11/12/19 10:00	0.9			1			1.7		X	0			0.23484			0.78		
11/12/19 11:00	0.9			1			1.7		X	0			0.21672			0.72		
11/12/19 12:00	0.8			1			1.7		X	0			0.24882			0.83		
11/12/19 13:00	0.9			1			1.7		X	0			0.23196			0.77		
11/12/19 14:00	0.9			1			1.7		X	0			0.23184			0.77		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/19 15:00	0.9			1			1.7			0	X		0.23376			0.78		
11/12/19 16:00	1.4			2			1.7			0	X		0.27648			0.92		
11/12/19 17:00	1.2			2			1.7			0	X		0.28446			0.95		
11/12/19 18:00	0.6			2			1.7			0	X		0.32004			1.07		
11/12/19 19:00	0.6			2			1.7			0	X		0.32154			1.07		
11/12/19 20:00	1.3			1			1.7			0	X		0.21342			0.71		
11/12/19 21:00	1.7			1			1.7			0	X		0.2511			0.84		
11/12/19 22:00	1.3			1			1.7			0	X		0.24966			0.83		
11/12/19 23:00	1.1			1			1.7			0	X		0.21924			0.73		
11/13/19 0:00	1.4			2			1.7			0	X		0.28818			0.96		
11/13/19 1:00	1.4			2			1.7			0	X		0.27792			0.93		
11/13/19 2:00	1.5			2			1.7			0	X		0.261			0.87		
11/13/19 3:00	1.5			2			1.7			0	X		0.26316			0.88		
11/13/19 4:00	1.4			2			1.7			0	X		0.28602			0.95		
11/13/19 5:00	0.7			2			1.7			0	X		0.32928			1.1		
11/13/19 6:00	0.7			2			1.7			0.19			0.32574			1.09		
11/13/19 7:00	1.3			1			1.7			0.42			0.21258			0.71		
11/13/19 8:00	1.2			1			1.7			0.44			0.21612			0.72		
11/13/19 9:00	1			1			1.7			0.45			0.22398			0.75		
11/13/19 10:00	0.9			1			1.7			0.44			0.22458			0.75		
11/13/19 11:00	0.9			1			1.7			0.45			0.22932			0.76		
11/13/19 12:00	0.9			1			1.7			0.44			0.2313			0.77		
11/13/19 13:00	0.9			1			1.7			0.44			0.23772			0.79		
11/13/19 14:00	0.9			1			1.7			0.46			0.2499			0.83		
11/13/19 15:00	0.9			1			1.7			0.52			0.25476			0.85		
11/13/19 16:00	0.9			1			1.7			0.52			0.25554			0.85		
11/13/19 17:00	0.9			1			1.7			0.52			0.25626			0.85		
11/13/19 18:00	0.9			1			1.7			0.52			0.25728			0.86		
11/13/19 19:00	1			1			1.7			0.52			0.25734			0.86		
11/13/19 20:00	1.1			1			1.7			0.51			0.2553			0.85		
11/13/19 21:00	1			1			1.7			0.37			0.18			0.6		
11/13/19 22:00	1.1			1			1.7			0.38			0.18588			0.62		
11/13/19 23:00	1			2			1.7			0.37			0.17772			0.59		
11/14/19 0:00	1			2			1.7			0.36			0.17238			0.57		
11/14/19 1:00	1			2			1.7			0.36			0.17238			0.57		
11/14/19 2:00	0.9			2			1.7			0.36			0.17244			0.57		
11/14/19 3:00	0.8			2			1.7			0.36			0.17244			0.57		
11/14/19 4:00	0.8			2			1.7			0.36			0.17256			0.58		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/19 5:00	0.9			2			1.7			0.37			0.17616			0.59		
11/14/19 6:00	0.9			1			1.7			0.52			0.2514			0.84		
11/14/19 7:00	1			1			1.7			0.41			0.20568			0.69		
11/14/19 8:00	0.9			1			1.7			0.44			0.22446			0.75		
11/14/19 9:00	0.9			1			1.7			0.45			0.23388			0.78		
11/14/19 10:00	0.9			1			1.7			0.45			0.23718			0.79		
11/14/19 11:00	0.9			1			1.7			0.46			0.24774			0.83		
11/14/19 12:00	0.9			1			1.7			0.45			0.2493			0.83		
11/14/19 13:00	0.8			1			1.7			0.45			0.25176			0.84		
11/14/19 14:00	0.8			1			1.7			0.45			0.25392			0.85		
11/14/19 15:00	0.8			1			1.7			0.52			0.25776			0.86		
11/14/19 16:00	0.8			1			1.7			0.52			0.25746			0.86		
11/14/19 17:00	0.9			1			1.7			0.51			0.25848			0.86		
11/14/19 18:00	0.9			1			1.7			0.51			0.2592			0.86		
11/14/19 19:00	0.9			1			1.7			0.51			0.25962			0.87		
11/14/19 20:00	0.9			1			1.7			0.5			0.2565			0.86		
11/14/19 21:00	0.9			1			1.7			0.38			0.18528			0.62		
11/14/19 22:00	0.9			1			1.7			0.38			0.18594			0.62		
11/14/19 23:00	0.9			1			1.7			0.35			0.18042			0.6		
11/15/19 0:00	0.9			1			1.7			0	X		0.14238			0.47		
11/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 3:00	0			0	X		0			0	X		0.096			0.32		
11/20/19 4:00	0.8			1			1.4			0	X		0.24492			0.82		
11/20/19 5:00	0.8			1			1.8			0	X		0.2475			0.83		
11/20/19 6:00	0.9			2			1.6			0	X		0.21324			0.71		
11/20/19 7:00	0.9			2			0.8			0	X		0.13014			0.43		
11/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/19 5:00	0	X		0	X		0	X		0.2			0	X		0	X	
11/21/19 6:00	0			0	X		0			0.52			0.09102			0.3		
11/21/19 7:00	0.8			1			1.5			0.54			0.2472			0.82		
11/21/19 8:00	0.9			1			1.7			0.55			0.2583			0.86		
11/21/19 9:00	0.9			1			1.7			0.46			0.2181			0.73		
11/21/19 10:00	0.9			1			1.7			0.45			0.21858			0.73		
11/21/19 11:00	0.8			1			1.7			0.45			0.22158			0.74		
11/21/19 12:00	0.8			1			1.7			0.45			0.22542			0.75		
11/21/19 13:00	0.8			1			1.7			0.45			0.22842			0.76		
11/21/19 14:00	0.8			1			1.7			0.44			0.2286			0.76		
11/21/19 15:00	0.8			1			1.7			0.51			0.24954			0.83		
11/21/19 16:00	0.8			1			1.7			0.52			0.25398			0.85		
11/21/19 17:00	0.8			1			1.7			0.51			0.25554			0.85		
11/21/19 18:00	0.8			1			1.7			0.51			0.25776			0.86		
11/21/19 19:00	1.7			1			1.7			0.5			0.2586			0.86		
11/21/19 20:00	0.9			1			1.7			0.5			0.25932			0.86		
11/21/19 21:00	0.9			1			1.7			0.52			0.24846			0.83		
11/21/19 22:00	1			2			1.7			0.38			0.18156			0.61		
11/21/19 23:00	0.9			2			1.7			0.37			0.17682			0.59		
11/22/19 0:00	0.9			2			1.7			0.37			0.1779			0.59		
11/22/19 1:00	0.9			2			1.7			0.37			0.17688			0.59		
11/22/19 2:00	1			2			1.7			0.37			0.17688			0.59		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/19 3:00	0.9			2			1.7			0.37			0.17694			0.59		
11/22/19 4:00	1			2			1.6			0.37			0.17772			0.59		
11/22/19 5:00	1.2			1			1.7			0.39			0.18642			0.62		
11/22/19 6:00	1.3			1			1.7			0.46			0.22194			0.74		
11/22/19 7:00	1.3			1			1.7			0.43			0.20796			0.69		
11/22/19 8:00	1.1			1			1.7			0.46			0.22434			0.75		
11/22/19 9:00	0.9			1			1.7			0.46			0.22716			0.76		
11/22/19 10:00	0.9			1			1.7			0.46			0.23052			0.77		
11/22/19 11:00	0.9			1			1.7			0.46			0.23556			0.79		
11/22/19 12:00	0.8			1			1.7			0.47			0.2427			0.81		
11/22/19 13:00	0.8			1			1.7			0.49			0.23748			0.79		
11/22/19 14:00	0.8			1			1.7			0.49			0.23898			0.8		
11/22/19 15:00	0.9			1			1.7			0.55			0.25944			0.86		
11/22/19 16:00	0.4			2			1.7			0.72			0.3459			1.15		
11/22/19 17:00	0.4			2			1.7			0.73			0.34698			1.16		
11/22/19 18:00	0.4			2			1.7			0.72			0.34656			1.16		
11/22/19 19:00	0.4			2			1.7			0.72			0.3456			1.15		
11/22/19 20:00	0.5			2			1.7			0.71			0.33948			1.13		
11/22/19 21:00	2.1			1			1.8			0.54			0.25224			0.84		
11/22/19 22:00	1.7			1			1.7			0.53			0.25362			0.85		
11/22/19 23:00	1.1			1			1.7			0.52			0.25254			0.84		
11/23/19 0:00	0.9			0			1.8			0	X		0.14388			0.48		
11/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/19 3:00	0			0	X		0			0	X		0.08748			0.29		
11/26/19 4:00	0.9			1			1.3			0	X		0.19332			0.64		
11/26/19 5:00	0.9			1			1.8			0	X		0.24894			0.83		
11/26/19 6:00	1			1			1.7			0.4			0.23754			0.79		
11/26/19 7:00	1			1			1.7			0.49			0.2337			0.78		
11/26/19 8:00	1			1			1.7			0.5			0.23952			0.8		
11/26/19 9:00	1.1			1			1.7			0.51			0.24756			0.83		
11/26/19 10:00	0.8			1			1.7			0.51			0.25254			0.84		
11/26/19 11:00	0.9			1			1.7			0.51			0.25524			0.85		
11/26/19 12:00	0.8			1			1.7			0.51			0.25794			0.86		
11/26/19 13:00	0.8			1			1.7			0.51			0.25248			0.84		
11/26/19 14:00	0.8			1			1.7			0.52			0.2484			0.83		
11/26/19 15:00	0.8			1			1.7			0.54			0.24864			0.83		
11/26/19 16:00	1.5			2			1.7			0.58			0.27366			0.91		
11/26/19 17:00	0.3			3			1.7			0.75			0.36204			1.21		
11/26/19 18:00	0.4			3			1.7			0.73			0.34854			1.16		
11/26/19 19:00	0.8			1			1.8			0.54			0.24372			0.81		
11/26/19 20:00	0.8			1			1.7			0.55			0.24636			0.82		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/19 21:00	0.8			1			1.7			0.54			0.2451			0.82		
11/26/19 22:00	0.9			1			1.7			0.45			0.20748			0.69		
11/26/19 23:00	1			2			1.7			0.41			0.18906			0.63		
11/27/19 0:00	0.9			1			1.7			0.38			0.17838			0.59		
11/27/19 1:00	0.8			2			1.7			0.37			0.17226			0.57		
11/27/19 2:00	0.8			2			1.7			0.37			0.17238			0.57		
11/27/19 3:00	0.8			2			1.7			0.37			0.1719			0.57		
11/27/19 4:00	0.8			2			1.7			0.37			0.1785			0.6		
11/27/19 5:00	1			1			1.6			0.4			0.19494			0.65		
11/27/19 6:00	0.8			1			1.7			0.52			0.25446			0.85		
11/27/19 7:00	0.9			1			1.7			0.45			0.2253			0.75		
11/27/19 8:00	0.9			1			1.7			0.45			0.23088			0.77		
11/27/19 9:00	0.9			1			1.7			0.47			0.24456			0.82		
11/27/19 10:00	0.9			1			1.7			0.5			0.25608			0.85		
11/27/19 11:00	0.8			1			1.7			0.49			0.25368			0.85		
11/27/19 12:00	0.8			1			1.7			0.48			0.25188			0.84		
11/27/19 13:00	0.8			1			1.7			0.47			0.25044			0.83		
11/27/19 14:00	0.9			1			1.7			0.45			0.24276			0.81		
11/27/19 15:00	0.9			1			1.7			0.45			0.24288			0.81		
11/27/19 16:00	1.1			2			1.7			0.48			0.25704			0.86		
11/27/19 17:00	0.5			2			1.7			0.69			0.32844			1.09		
11/27/19 18:00	1			2			1.7			0.55			0.25788			0.86		
11/27/19 19:00	0.9			1			1.7			0.52			0.24852			0.83		
11/27/19 20:00	0.9			1			1.7			0.51			0.2481			0.83		
11/27/19 21:00	0.9			1			1.7			0.48			0.23802			0.79		
11/27/19 22:00	0.9			1			1.7			0.43			0.21774			0.73		
11/27/19 23:00	1			1			1.7			0.38			0.19884			0.66		
11/28/19 0:00	1			1			1.7			0.37			0.19602			0.65		
11/28/19 1:00	0.9			2			1.8			0.37			0.1791			0.6		
11/28/19 2:00	0.8			2			1.7			0.37			0.17382			0.58		
11/28/19 3:00	0.8			3			1.7			0.37			0.17262			0.58		
11/28/19 4:00	1.1			1			1.8			0.37			0.17742			0.59		
11/28/19 5:00	1.1			1			1.7			0.39			0.18966			0.63		
11/28/19 6:00	1			1			1.7			0.4			0.19752			0.66		
11/28/19 7:00	1			1			1.7			0.41			0.19674			0.66		
11/28/19 8:00	0.9			1			1.7			0.45			0.21318			0.71		
11/28/19 9:00	0.9			1			1.7			0.46			0.22044			0.73		
11/28/19 10:00	0.9			1			1.7			0.48			0.22998			0.77		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/19 11:00	0.9			1			1.7			0.47			0.22818			0.76		
11/28/19 12:00	0.9			1			1.7			0.45			0.2259			0.75		
11/28/19 13:00	0.9			1			1.7			0.43			0.2214			0.74		
11/28/19 14:00	0.9			1			1.7			0.41			0.21678			0.72		
11/28/19 15:00	0.9			1			1.7			0.4			0.21918			0.73		
11/28/19 16:00	1			2			1.7			0.38			0.1917			0.64		
11/28/19 17:00	0.9			1			1.7			0.5			0.24138			0.8		
11/28/19 18:00	0.9			1			1.7			0.49			0.23982			0.8		
11/28/19 19:00	0.8			2			1.7			0.37			0.17514			0.58		
11/28/19 20:00	0.9			1			1.7			0.47			0.22422			0.75		
11/28/19 21:00	0.9			1			1.7			0.45			0.21948			0.73		
11/28/19 22:00	1			1			1.7			0.41			0.20556			0.69		
11/28/19 23:00	1			2			1.7			0.37			0.18474			0.62		
11/29/19 0:00	1.1			2			1.7			0.38			0.19302			0.64		
11/29/19 1:00	1.1			2			1.7			0.37			0.19326			0.64		
11/29/19 2:00	1.1			2			1.7			0.37			0.18894			0.63		
11/29/19 3:00	1.1			2			1.7			0.37			0.19128			0.64		
11/29/19 4:00	1.1			1			1.6			0.37			0.19536			0.65		
11/29/19 5:00	1.1			1			1.7			0.39			0.20424			0.68		
11/29/19 6:00	1			1			1.7			0.4			0.2121			0.71		
11/29/19 7:00	1			1			1.7			0.4			0.21822			0.73		
11/29/19 8:00	1			1			1.7			0.42			0.2259			0.75		
11/29/19 9:00	1			1			1.7			0.46			0.2214			0.74		
11/29/19 10:00	0.9			1			1.7			0.46			0.22644			0.75		
11/29/19 11:00	0.9			1			1.7			0.45			0.22074			0.74		
11/29/19 12:00	0.9			1			1.7			0.44			0.22026			0.73		
11/29/19 13:00	0.9			1			1.7			0.44			0.22104			0.74		
11/29/19 14:00	0.9			1			1.7			0.43			0.21984			0.73		
11/29/19 15:00	0.9			1			1.7			0.42			0.21864			0.73		
11/29/19 16:00	0.8			2			1.7			0.39			0.18576			0.62		
11/29/19 17:00	0.7			2			1.7			0.67			0.32118			1.07		
11/29/19 18:00	0.6			2			1.7			0.69			0.32994			1.1		
11/29/19 19:00	0.6			2			1.7			0.67			0.32268			1.08		
11/29/19 20:00	0.9			1			1.7			0.52			0.2493			0.83		
11/29/19 21:00	0.9			1			1.7			0.48			0.23466			0.78		
11/29/19 22:00	1			1			1.7			0.44			0.21336			0.71		
11/29/19 23:00	1.1			2			1.7			0.39			0.19734			0.66		
11/30/19 0:00	1			2			1.7			0.37			0.18936			0.63		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/19 1:00	0.9			2			1.7			0.37			0.1782			0.59		
11/30/19 2:00	0.8			3			1.7			0.37			0.17376			0.58		
11/30/19 3:00	0.9			2			1.7			0.37			0.1743			0.58		
11/30/19 4:00	0.9			1			1.8			0.37			0.17964			0.6		
11/30/19 5:00	1			2			1.7			0.38			0.18774			0.63		
11/30/19 6:00	1.1			2			1.7			0.39			0.19542			0.65		
11/30/19 7:00	1.1			2			1.7			0.41			0.19668			0.66		
11/30/19 8:00	1			1			1.7			0.46			0.2205			0.74		
11/30/19 9:00	0.9			1			1.7			0.47			0.23016			0.77		
11/30/19 10:00	0.9			1			1.7			0.49			0.24084			0.8		
11/30/19 11:00	0.9			1			1.7			0.47			0.23832			0.79		
11/30/19 12:00	0.9			1			1.7			0.47			0.23802			0.79		
11/30/19 13:00	0.9			1			1.7			0.48			0.24762			0.83		
11/30/19 14:00	0.9			1			1.7			0.47			0.24942			0.83		
11/30/19 15:00	0.8			1			1.7			0.46			0.2478			0.83		
11/30/19 16:00	0.9			1			1.7			0.4			0.19452			0.65		
11/30/19 17:00	0.5			3			1.5			0.74			0.354			1.18		
11/30/19 18:00	0.9			2			1.6			0.55			0.25302			0.84		
11/30/19 19:00	1			2			1.6			0.47			0.18942			0.63		
11/30/19 20:00	1			1			1.6			0.54			0.231			0.77		
11/30/19 21:00	0.9			1			1.6			0.51			0.22284			0.74		
11/30/19 22:00	1			2			1.6			0.46			0.19836			0.66		
11/30/19 23:00	1			2			1.6			0.44			0.18744			0.62		
12/01/19 0:00	0.8			2			1.7			0.41			0.17472			0.58		
12/01/19 1:00	0.8			2			1.6			0.37			0.1722			0.57		
12/01/19 2:00	0.8			2			1.6			0.37			0.17214			0.57		
12/01/19 3:00	0.8			2			1.6			0.37			0.1722			0.57		
12/01/19 4:00	0.8			2			1.5			0.37			0.17244			0.57		
12/01/19 5:00	0.8			2			1.6			0.38			0.17772			0.59		
12/01/19 6:00	0.9			2			1.6			0.38			0.18174			0.61		
12/01/19 7:00	1			2			1.6			0.39			0.19056			0.64		
12/01/19 8:00	1			2			1.6			0.39			0.19476			0.65		
12/01/19 9:00	1.1			1			1.6			0.39			0.19656			0.66		
12/01/19 10:00	1			1			1.6			0.42			0.19794			0.66		
12/01/19 11:00	1			1			1.6			0.41			0.20004			0.67		
12/01/19 12:00	1			1			1.6			0.41			0.20226			0.67		
12/01/19 13:00	1			1			1.6			0.41			0.1977			0.66		
12/01/19 14:00	1			1			1.6			0.43			0.21096			0.7		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/19 15:00	0.9			1			1.6			0.49			0.24258			0.81		
12/01/19 16:00	1			1			1.6			0.41			0.19914			0.66		
12/01/19 17:00	0.7			2			1.6			0.66			0.31674			1.06		
12/01/19 18:00	0.4			3			1.7			0.73			0.35082			1.17		
12/01/19 19:00	1.6			2			1.8			0.57			0.25452			0.85		
12/01/19 20:00	1.8			2			1.7			0.58			0.25908			0.86		
12/01/19 21:00	0.9			1			1.7			0.54			0.24744			0.82		
12/01/19 22:00	1			1			1.7			0.44			0.2079			0.69		
12/01/19 23:00	1.1			1			1.7			0.42			0.1977			0.66		
12/02/19 0:00	1			2			1.7			0.39			0.19002			0.63		
12/02/19 1:00	0.8			3			1.7			0.37			0.17334			0.58		
12/02/19 2:00	0.8			2			1.7			0.37			0.17262			0.58		
12/02/19 3:00	0.8			2			1.7			0.37			0.17274			0.58		
12/02/19 4:00	0.8			1			1.7			0.37			0.1752			0.58		
12/02/19 5:00	1			1			1.7			0.4			0.19098			0.64		
12/02/19 6:00	1.8			1			1.7			0.56			0.25872			0.86		
12/02/19 7:00	1			1			1.7			0.51			0.24144			0.8		
12/02/19 8:00	0.9			1			1.7			0.49			0.23532			0.78		
12/02/19 9:00	0.9			1			1.7			0.52			0.25608			0.85		
12/02/19 10:00	0.9			1			1.7			0.51			0.25176			0.84		
12/02/19 11:00	0.8			1			1.7			0.5			0.25224			0.84		
12/02/19 12:00	0.8			1			1.7			0.52			0.25308			0.84		
12/02/19 13:00	0.8			1			1.7			0.51			0.2481			0.83		
12/02/19 14:00	0.8			1			1.7			0.51			0.24882			0.83		
12/02/19 15:00	1			1			1.7			0.54			0.25722			0.86		
12/02/19 16:00	0.6			2			1.7			0.69			0.32844			1.09		
12/02/19 17:00	0.5			2			1.7			0.69			0.32778			1.09		
12/02/19 18:00	0.5			2			1.7			0.68			0.32688			1.09		
12/02/19 19:00	0.6			2			1.7			0.68			0.32334			1.08		
12/02/19 20:00	0.5			2			1.7			0.68			0.32562			1.09		
12/02/19 21:00	0.9			1			1.7			0.53			0.25284			0.84		
12/02/19 22:00	1			1			1.7			0.43			0.20376			0.68		
12/02/19 23:00	0.8			2			1.7			0.37			0.17694			0.59		
12/03/19 0:00	0.8			1			1.7			0.37			0.18024			0.6		
12/03/19 1:00	0.8			2			1.7			0.36			0.1734			0.58		
12/03/19 2:00	0.8			2			1.7			0.36			0.17388			0.58		
12/03/19 3:00	0.8			2			1.7			0.36			0.1737			0.58		
12/03/19 4:00	0.8			2			1.6			0.36			0.17388			0.58		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/19 5:00	0.9			2			1.7			0.38			0.18444			0.61		
12/03/19 6:00	1			1			1.7			0.4			0.19758			0.66		
12/03/19 7:00	0.9			1			1.7			0.51			0.24606			0.82		
12/03/19 8:00	1			1			1.7			0.49			0.23352			0.78		
12/03/19 9:00	0.9			1			1.7			0.53			0.25494			0.85		
12/03/19 10:00	0.9			1			1.7			0.5			0.24474			0.82		
12/03/19 11:00	0.9			1			1.7			0.48			0.23544			0.78		
12/03/19 12:00	0.9			1			1.7			0.47			0.23292			0.78		
12/03/19 13:00	0.9			1			1.7			0.47			0.22446			0.75		
12/03/19 14:00	0.9			1			1.7			0.48			0.23166			0.77		
12/03/19 15:00	0.9			1			1.7			0.48			0.23472			0.78		
12/03/19 16:00	0.9			1			1.7			0.51			0.2478			0.83		
12/03/19 17:00	1.3			2			1.7			0.59			0.28128			0.94		
12/03/19 18:00	1.4			2			1.7			0.58			0.27306			0.91		
12/03/19 19:00	1.1			1			1.7			0.45			0.21192			0.71		
12/03/19 20:00	1.3			2			1.7			0.58			0.27654			0.92		
12/03/19 21:00	1.1			1			1.7			0.55			0.25746			0.86		
12/03/19 22:00	1.2			1			1.7			0.54			0.22614			0.75		
12/03/19 23:00	1			1			1.7			0.49			0.20112			0.67		
12/04/19 0:00	1			2			1.7			0.4			0.18342			0.61		
12/04/19 1:00	0.8			2			1.7			0.37			0.17412			0.58		
12/04/19 2:00	0.8			2			1.7			0.37			0.17286			0.58		
12/04/19 3:00	0.8			2			1.7			0.37			0.17262			0.58		
12/04/19 4:00	0.8			2			1.7			0.37			0.17484			0.58		
12/04/19 5:00	0.9			1			1.7			0.5			0.24252			0.81		
12/04/19 6:00	1			1			1.7			0.51			0.2481			0.83		
12/04/19 7:00	1.2			2			1.6			0.64			0.30162			1.01		
12/04/19 8:00	0.7			2			1.7			0.67			0.32058			1.07		
12/04/19 9:00	0.7			2			1.7			0.67			0.3189			1.06		
12/04/19 10:00	1			1			1.8			0.52			0.24912			0.83		
12/04/19 11:00	0.8			1			1.7			0.51			0.249			0.83		
12/04/19 12:00	0.8			1			1.7			0.51			0.25104			0.84		
12/04/19 13:00	0.8			1			1.7			0.51			0.2532			0.84		
12/04/19 14:00	0.8			1			1.7			0.52			0.24822			0.83		
12/04/19 15:00	0.9			1			1.7			0.52			0.25038			0.83		
12/04/19 16:00	0.6			2			1.6			0.68			0.3258			1.09		
12/04/19 17:00	0.4			2			1.7			0.69			0.32976			1.1		
12/04/19 18:00	0.5			2			1.7			0.69			0.32964			1.1		

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/19 19:00	0.5			2			1.7			0.68			0.32472			1.08		
12/04/19 20:00	0.6			2			1.7			0.68			0.32226			1.07		
12/04/19 21:00	1.1			2			1.7			0.6			0.28488			0.95		
12/04/19 22:00	0.9			1			1.7			0.53			0.24294			0.81		
12/04/19 23:00	0.8			1			1.7			0.41			0.18498			0.62		
12/05/19 0:00	0			0	X		0			0.2			0.09846			0.33		
12/05/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/19 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/19 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.00	0.00	0.00
10/02/2019	0.00	0.00	0.00	0.00	0.00
10/03/2019	0.00	0.00	0.00	0.00	0.00
10/04/2019	0.00	0.00	0.00	0.00	0.00
10/05/2019	0.00	0.00	0.00	0.00	0.00
10/06/2019	0.00	0.00	0.00	0.00	0.00
10/07/2019	0.00	0.00	0.00	0.00	0.00
10/08/2019	0.00	0.00	0.00	0.00	0.00
10/09/2019	0.00	0.00	0.00	0.00	0.00
10/10/2019	0.00	0.00	0.00	0.00	0.00
10/11/2019	0.00	0.00	0.00	0.00	0.00
10/12/2019	0.00	0.00	0.00	0.00	0.00
10/13/2019	0.00	0.00	0.00	0.00	0.00
10/14/2019	0.00	0.00	0.00	0.00	0.00
10/15/2019	0.00	0.00	0.00	0.00	0.00
10/16/2019	0.00	0.00	0.00	0.00	0.00
10/17/2019	0.00	0.00	0.00	0.00	0.00
10/18/2019	0.00	0.00	0.00	0.00	0.00
10/19/2019	0.00	0.00	0.00	0.00	0.00
10/20/2019	0.00	0.00	0.00	0.00	0.00
10/21/2019	46.26	65.45	5.04	10.08	16.78
10/22/2019	18.36	60.33	5.92	11.84	19.73
10/23/2019	17.21	63.08	6.02	12.05	20.07
10/24/2019	54.98	85.19	6.82	13.72	22.83
10/25/2019	62.93	85.06	6.91	13.82	22.98
10/26/2019	19.60	50.83	4.86	9.69	16.16
10/27/2019	17.37	52.71	5.05	10.06	16.77
10/28/2019	22.77	62.36	5.98	11.99	20.01
10/29/2019	338.32	102.83	8.10	16.22	27.04
10/30/2019	45.65	75.70	7.38	14.74	24.57
10/31/2019	18.36	79.67	7.63	15.28	25.48
Monthly Avg/Sum*:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
Daily Min:	17.21	50.83	4.86	9.69	16.16
Daily Max:	338.32	102.83	8.10	16.22	27.04
Oct 2019 - Oct 2019	661.81	783.21	69.71	139.49	232.42
QTD:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
YTD 2019:	5,142.90 *	13,106.22 *	1,216.27 *	2,433.64 *	4,055.91 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.00	13.94	23.22
11/02/2019	22.69	65.84	6.26	12.58	20.98
11/03/2019	21.34	61.80	5.88	11.73	19.64
11/04/2019	18.26	69.40	6.64	13.25	22.10
11/05/2019	52.08	100.71	8.53	17.03	28.37
11/06/2019	42.42	126.86	11.97	23.94	39.94
11/07/2019	83.67	109.38	9.41	18.78	31.34
11/08/2019	62.35	113.46	9.84	19.71	32.81
11/09/2019	36.76	59.05	5.65	11.25	18.79
11/10/2019	23.22	57.70	5.53	10.99	18.37
11/11/2019	48.40	72.13	6.02	12.04	20.05
11/12/2019	40.18	63.34	5.81	11.64	19.40
11/13/2019	72.57	112.30	9.86	19.70	32.85
11/14/2019	58.46	111.34	10.52	21.00	35.12
11/15/2019	19.85	1.69	0.04	0.08	0.13
11/16/2019	0.00	0.00	0.00	0.00	0.00
11/17/2019	0.00	0.00	0.00	0.00	0.00
11/18/2019	0.00	0.00	0.00	0.00	0.00
11/19/2019	0.00	0.00	0.00	0.00	0.00
11/20/2019	41.86	21.26	0.75	1.51	2.52
11/21/2019	97.32	110.63	8.34	16.73	27.87
11/22/2019	41.89	125.41	11.96	23.91	39.92
11/23/2019	13.86	1.69	0.04	0.07	0.12
11/24/2019	0.00	0.00	0.00	0.00	0.00
11/25/2019	0.00	0.00	0.00	0.00	0.00
11/26/2019	128.07	128.26	9.81	19.66	32.75
11/27/2019	38.45	115.86	11.04	22.08	36.74
11/28/2019	36.18	104.67	9.95	19.92	33.17
11/29/2019	38.55	113.72	10.82	21.67	36.10
11/30/2019	37.78	110.86	10.67	21.38	35.55
Monthly Avg/Sum*:	1,101.16 *	2,030.35 *	182.34 *	364.59 *	607.85 *
Daily Min:	13.86	1.69	0.04	0.07	0.12
Daily Max:	128.07	128.26	11.97	23.94	39.94
Oct 2019 - Nov 2019	1,762.97	2,813.56	252.05	504.08	840.27
QTD:	1,762.97 *	2,813.56 *	252.05 *	504.08 *	840.27 *
YTD 2019:	6,244.06 *	15,136.57 *	1,398.61 *	2,798.23 *	4,663.76 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2019	38.31	107.26	10.49	20.91	34.80
12/02/2019	35.09	125.41	11.96	23.89	39.79
12/03/2019	35.34	116.36	11.06	22.04	36.78
12/04/2019	31.69	132.56	12.65	25.26	42.06
12/05/2019	29.57	2.15	0.02	0.04	0.08
12/06/2019	0.00	0.00	0.00	0.00	0.00
12/07/2019	0.00	0.00	0.00	0.00	0.00
12/08/2019	0.00	0.00	0.00	0.00	0.00
12/09/2019	0.00	0.00	0.00	0.00	0.00
12/10/2019	0.00	0.00	0.00	0.00	0.00
12/11/2019	0.00	0.00	0.00	0.00	0.00
12/12/2019	0.00	0.00	0.00	0.00	0.00
12/13/2019	0.00	0.00	0.00	0.00	0.00
12/14/2019	0.00	0.00	0.00	0.00	0.00
12/15/2019	0.00	0.00	0.00	0.00	0.00
12/16/2019	0.00	0.00	0.00	0.00	0.00
12/17/2019	0.00	0.00	0.00	0.00	0.00
12/18/2019	0.00	0.00	0.00	0.00	0.00
12/19/2019	0.00	0.00	0.00	0.00	0.00
12/20/2019	0.00	0.00	0.00	0.00	0.00
12/21/2019	0.00	0.00	0.00	0.00	0.00
12/22/2019	0.00	0.00	0.00	0.00	0.00
12/23/2019	0.00	0.00	0.00	0.00	0.00
12/24/2019	0.00	0.00	0.00	0.00	0.00
12/25/2019	0.00	0.00	0.00	0.00	0.00
12/26/2019	0.00	0.00	0.00	0.00	0.00
12/27/2019	0.00	0.00	0.00	0.00	0.00
12/28/2019	0.00	0.00	0.00	0.00	0.00
12/29/2019	0.00	0.00	0.00	0.00	0.00
12/30/2019	0.00	0.00	0.00	0.00	0.00
12/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	170.00 *	483.74 *	46.18 *	92.14 *	153.51 *
Daily Min:	29.57	2.15	0.02	0.04	0.08
Daily Max:	38.31	132.56	12.65	25.26	42.06
Oct 2019 - Dec 2019	1,932.97	3,297.30	298.23	596.22	993.78
QTD:	1,932.97 *	3,297.30 *	298.23 *	596.22 *	993.78 *
YTD 2019:	6,414.06 *	15,620.31 *	1,444.79 *	2,890.37 *	4,817.27 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.0	0.00	0.00
10/02/2019	0.00	0.00	0.0	0.00	0.00
10/03/2019	0.00	0.00	0.0	0.00	0.00
10/04/2019	0.00	0.00	0.0	0.00	0.00
10/05/2019	0.00	0.00	0.0	0.00	0.00
10/06/2019	0.00	0.00	0.0	0.00	0.00
10/07/2019	0.00	0.00	0.0	0.00	0.00
10/08/2019	0.00	0.00	0.0	0.00	0.00
10/09/2019	0.00	0.00	0.0	0.00	0.00
10/10/2019	0.00	0.00	0.0	0.00	0.00
10/11/2019	0.00	0.00	0.0	0.00	0.00
10/12/2019	0.00	0.00	0.0	0.00	0.00
10/13/2019	0.00	0.00	0.0	0.00	0.00
10/14/2019	0.00	0.00	0.0	0.00	0.00
10/15/2019	0.00	0.00	0.0	0.00	0.00
10/16/2019	0.00	0.00	0.0	0.00	0.00
10/17/2019	0.00	0.00	0.0	0.00	0.00
10/18/2019	0.00	0.00	0.0	0.00	0.00
10/19/2019	0.00	0.00	0.0	0.00	0.00
10/20/2019	0.00	0.00	0.0	0.00	0.00
10/21/2019	0.00	0.00	0.0	0.00	0.00
10/22/2019	0.00	0.00	0.0	0.00	0.00
10/23/2019	0.00	0.00	0.0	0.00	0.00
10/24/2019	31.75	39.81	2.6	5.41	9.00
10/25/2019	21.05	60.97	5.5	11.66	19.40
10/26/2019	19.60	50.83	4.8	9.69	16.16
10/27/2019	17.37	52.71	4.8	10.06	16.77
10/28/2019	22.77	62.36	5.8	11.99	20.01
10/29/2019	15.49	84.49	7.8	16.08	26.80
10/30/2019	23.09	68.72	6.6	13.15	21.94
10/31/2019	18.36	79.67	7.7	15.28	25.48
Monthly Avg/Sum*:	169.48 *	499.56 *	45.6 *	93.32 *	155.56 *
Daily Min:	15.49	39.81	2.6	5.41	9.00
Daily Max:	31.75	84.49	7.8	16.08	26.80
Oct 2019 - Oct 2019	169.48	499.56	45.6	93.32	155.56
QTD:	169.48 *	499.56 *	45.6 *	93.32 *	155.56 *
YTD 2019:	1,893.08 *	6,115.19 *	592.3 *	1,147.35 *	1,911.76 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.1	13.94	23.22
11/02/2019	22.69	65.84	6.1	12.58	20.98
11/03/2019	21.34	61.80	5.7	11.73	19.64
11/04/2019	18.26	69.40	6.6	13.25	22.10
11/05/2019	22.88	64.88	6.1	12.40	20.67
11/06/2019	20.58	63.42	6.0	12.06	20.12
11/07/2019	22.95	74.68	7.2	14.34	23.92
11/08/2019	25.46	68.64	6.6	13.21	21.98
11/09/2019	23.42	58.39	5.5	11.24	18.77
11/10/2019	23.22	57.70	5.4	10.99	18.37
11/11/2019	24.65	62.20	5.7	11.89	19.81
11/12/2019	17.30	1.60	0.1	0.14	0.23
11/13/2019	48.91	50.61	4.0	7.82	13.06
11/14/2019	40.62	56.12	5.4	10.43	17.46
11/15/2019	0.00	0.00	0.0	0.00	0.00
11/16/2019	0.00	0.00	0.0	0.00	0.00
11/17/2019	0.00	0.00	0.0	0.00	0.00
11/18/2019	0.00	0.00	0.0	0.00	0.00
11/19/2019	0.00	0.00	0.0	0.00	0.00
11/20/2019	0.00	0.00	0.0	0.00	0.00
11/21/2019	53.98	55.97	4.6	8.69	14.50
11/22/2019	22.36	63.98	6.2	12.16	20.31
11/23/2019	0.00	0.00	0.0	0.00	0.00
11/24/2019	0.00	0.00	0.0	0.00	0.00
11/25/2019	0.00	0.00	0.0	0.00	0.00
11/26/2019	80.36	61.71	5.1	9.53	15.91
11/27/2019	20.26	58.06	5.3	11.03	18.36
11/28/2019	18.99	52.68	4.9	10.04	16.70
11/29/2019	19.98	56.81	5.2	10.82	18.02
11/30/2019	19.96	57.25	5.3	10.91	18.16
Monthly Avg/Sum*:	593.12 *	1,234.73 *	114.1 *	229.20 *	382.29 *
Daily Min:	17.30	1.60	0.1	0.14	0.23
Daily Max:	80.36	74.68	7.2	14.34	23.92
Oct 2019 - Nov 2019	762.60	1,734.29	159.7	322.52	537.85
QTD:	762.60 *	1,734.29 *	159.7 *	322.52 *	537.85 *
YTD 2019:	2,486.20 *	7,349.92 *	706.4 *	1,376.55 *	2,294.05 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2019	20.19	56.13	5.4	10.74	17.85
12/02/2019	16.62	64.16	6.3	12.19	20.32
12/03/2019	15.21	59.59	5.7	11.29	18.87
12/04/2019	13.39	68.07	6.6	12.92	21.53
12/05/2019	15.25	1.00	0.0	0.02	0.04
12/06/2019	0.00	0.00	0.0	0.00	0.00
12/07/2019	0.00	0.00	0.0	0.00	0.00
12/08/2019	0.00	0.00	0.0	0.00	0.00
12/09/2019	0.00	0.00	0.0	0.00	0.00
12/10/2019	0.00	0.00	0.0	0.00	0.00
12/11/2019	0.00	0.00	0.0	0.00	0.00
12/12/2019	0.00	0.00	0.0	0.00	0.00
12/13/2019	0.00	0.00	0.0	0.00	0.00
12/14/2019	0.00	0.00	0.0	0.00	0.00
12/15/2019	0.00	0.00	0.0	0.00	0.00
12/16/2019	0.00	0.00	0.0	0.00	0.00
12/17/2019	0.00	0.00	0.0	0.00	0.00
12/18/2019	0.00	0.00	0.0	0.00	0.00
12/19/2019	0.00	0.00	0.0	0.00	0.00
12/20/2019	0.00	0.00	0.0	0.00	0.00
12/21/2019	0.00	0.00	0.0	0.00	0.00
12/22/2019	0.00	0.00	0.0	0.00	0.00
12/23/2019	0.00	0.00	0.0	0.00	0.00
12/24/2019	0.00	0.00	0.0	0.00	0.00
12/25/2019	0.00	0.00	0.0	0.00	0.00
12/26/2019	0.00	0.00	0.0	0.00	0.00
12/27/2019	0.00	0.00	0.0	0.00	0.00
12/28/2019	0.00	0.00	0.0	0.00	0.00
12/29/2019	0.00	0.00	0.0	0.00	0.00
12/30/2019	0.00	0.00	0.0	0.00	0.00
12/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	80.66 *	248.95 *	24.0 *	47.16 *	78.61 *
Daily Min:	13.39	1.00	0.0	0.02	0.04
Daily Max:	20.19	68.07	6.6	12.92	21.53
Oct 2019 - Dec 2019	843.26	1,983.24	183.7	369.68	616.46
QTD:	843.26 *	1,983.24 *	183.7 *	369.68 *	616.46 *
YTD 2019:	2,566.86 *	7,598.87 *	730.4 *	1,423.71 *	2,372.66 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.0	0.00	0.00
10/02/2019	0.00	0.00	0.0	0.00	0.00
10/03/2019	0.00	0.00	0.0	0.00	0.00
10/04/2019	0.00	0.00	0.0	0.00	0.00
10/05/2019	0.00	0.00	0.0	0.00	0.00
10/06/2019	0.00	0.00	0.0	0.00	0.00
10/07/2019	0.00	0.00	0.0	0.00	0.00
10/08/2019	0.00	0.00	0.0	0.00	0.00
10/09/2019	0.00	0.00	0.0	0.00	0.00
10/10/2019	0.00	0.00	0.0	0.00	0.00
10/11/2019	0.00	0.00	0.0	0.00	0.00
10/12/2019	0.00	0.00	0.0	0.00	0.00
10/13/2019	0.00	0.00	0.0	0.00	0.00
10/14/2019	0.00	0.00	0.0	0.00	0.00
10/15/2019	0.00	0.00	0.0	0.00	0.00
10/16/2019	0.00	0.00	0.0	0.00	0.00
10/17/2019	0.00	0.00	0.0	0.00	0.00
10/18/2019	0.00	0.00	0.0	0.00	0.00
10/19/2019	0.00	0.00	0.0	0.00	0.00
10/20/2019	0.00	0.00	0.0	0.00	0.00
10/21/2019	46.26	65.45	4.9	10.08	16.78
10/22/2019	18.36	60.33	5.8	11.84	19.73
10/23/2019	17.21	63.08	6.1	12.05	20.07
10/24/2019	23.23	45.38	4.2	8.31	13.83
10/25/2019	41.88	24.09	1.0	2.16	3.58
10/26/2019	0.00	0.00	0.0	0.00	0.00
10/27/2019	0.00	0.00	0.0	0.00	0.00
10/28/2019	0.00	0.00	0.0	0.00	0.00
10/29/2019	321.22	18.34	0.0	0.14	0.24
10/30/2019	13.71	6.98	0.9	1.59	2.63
10/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	481.87 *	283.65 *	22.9 *	46.17 *	76.86 *
Daily Min:	13.71	6.98	0.0	0.14	0.24
Daily Max:	321.22	65.45	6.1	12.05	20.07
Oct 2019 - Oct 2019	481.87	283.65	22.9	46.17	76.86
QTD:	481.87 *	283.65 *	22.9 *	46.17 *	76.86 *
YTD 2019:	3,225.75 *	6,991.03 *	648.4 *	1,286.29 *	2,144.15 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2019	0.00	0.00	0.0	0.00	0.00
11/02/2019	0.00	0.00	0.0	0.00	0.00
11/03/2019	0.00	0.00	0.0	0.00	0.00
11/04/2019	0.00	0.00	0.0	0.00	0.00
11/05/2019	29.20	35.83	2.4	4.63	7.70
11/06/2019	21.84	63.44	5.9	11.88	19.82
11/07/2019	60.72	34.70	2.2	4.44	7.42
11/08/2019	36.89	44.82	3.3	6.50	10.83
11/09/2019	13.34	0.66	0.0	0.01	0.02
11/10/2019	0.00	0.00	0.0	0.00	0.00
11/11/2019	23.75	9.93	0.1	0.15	0.24
11/12/2019	22.88	61.74	5.5	11.50	19.17
11/13/2019	23.66	61.69	6.1	11.88	19.79
11/14/2019	17.84	55.22	5.7	10.57	17.66
11/15/2019	19.85	1.69	0.0	0.08	0.13
11/16/2019	0.00	0.00	0.0	0.00	0.00
11/17/2019	0.00	0.00	0.0	0.00	0.00
11/18/2019	0.00	0.00	0.0	0.00	0.00
11/19/2019	0.00	0.00	0.0	0.00	0.00
11/20/2019	41.86	21.26	0.6	1.51	2.52
11/21/2019	43.34	54.66	4.0	8.04	13.37
11/22/2019	19.53	61.43	5.7	11.75	19.61
11/23/2019	13.86	1.69	0.0	0.07	0.12
11/24/2019	0.00	0.00	0.0	0.00	0.00
11/25/2019	0.00	0.00	0.0	0.00	0.00
11/26/2019	47.71	66.55	4.8	10.13	16.84
11/27/2019	18.19	57.80	5.6	11.05	18.38
11/28/2019	17.19	51.99	4.8	9.88	16.47
11/29/2019	18.57	56.91	5.1	10.85	18.08
11/30/2019	17.82	53.61	5.1	10.47	17.39
Monthly Avg/Sum*:	508.04 *	795.62 *	66.9 *	135.39 *	225.56 *
Daily Min:	13.34	0.66	0.0	0.01	0.02
Daily Max:	60.72	66.55	6.1	11.88	19.82
Oct 2019 - Nov 2019	989.91	1,079.27	89.8	181.56	302.42
QTD:	989.91 *	1,079.27 *	89.8 *	181.56 *	302.42 *
YTD 2019:	3,733.79 *	7,786.65 *	715.3 *	1,421.68 *	2,369.71 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2019	18.12	51.13	5.3	10.17	16.95
12/02/2019	18.47	61.25	6.0	11.70	19.47
12/03/2019	20.13	56.77	5.3	10.75	17.91
12/04/2019	18.30	64.49	6.0	12.34	20.53
12/05/2019	14.32	1.15	0.0	0.02	0.04
12/06/2019	0.00	0.00	0.0	0.00	0.00
12/07/2019	0.00	0.00	0.0	0.00	0.00
12/08/2019	0.00	0.00	0.0	0.00	0.00
12/09/2019	0.00	0.00	0.0	0.00	0.00
12/10/2019	0.00	0.00	0.0	0.00	0.00
12/11/2019	0.00	0.00	0.0	0.00	0.00
12/12/2019	0.00	0.00	0.0	0.00	0.00
12/13/2019	0.00	0.00	0.0	0.00	0.00
12/14/2019	0.00	0.00	0.0	0.00	0.00
12/15/2019	0.00	0.00	0.0	0.00	0.00
12/16/2019	0.00	0.00	0.0	0.00	0.00
12/17/2019	0.00	0.00	0.0	0.00	0.00
12/18/2019	0.00	0.00	0.0	0.00	0.00
12/19/2019	0.00	0.00	0.0	0.00	0.00
12/20/2019	0.00	0.00	0.0	0.00	0.00
12/21/2019	0.00	0.00	0.0	0.00	0.00
12/22/2019	0.00	0.00	0.0	0.00	0.00
12/23/2019	0.00	0.00	0.0	0.00	0.00
12/24/2019	0.00	0.00	0.0	0.00	0.00
12/25/2019	0.00	0.00	0.0	0.00	0.00
12/26/2019	0.00	0.00	0.0	0.00	0.00
12/27/2019	0.00	0.00	0.0	0.00	0.00
12/28/2019	0.00	0.00	0.0	0.00	0.00
12/29/2019	0.00	0.00	0.0	0.00	0.00
12/30/2019	0.00	0.00	0.0	0.00	0.00
12/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	89.34 *	234.79 *	22.6 *	44.98 *	74.90 *
Daily Min:	14.32	1.15	0.0	0.02	0.04
Daily Max:	20.13	64.49	6.0	12.34	20.53
Oct 2019 - Dec 2019	1,079.25	1,314.06	112.4	226.54	377.32
QTD:	1,079.25 *	1,314.06 *	112.4 *	226.54 *	377.32 *
YTD 2019:	3,823.13 *	8,021.44 *	737.9 *	1,466.66 *	2,444.61 *

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NOx	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM ₁₀	16,300	13,692	17,789	17,569	32.67
SO _x	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.00	0.00	0.00
10/02/2019	0.00	0.00	0.00	0.00	0.00
10/03/2019	0.00	0.00	0.00	0.00	0.00
10/04/2019	0.00	0.00	0.00	0.00	0.00
10/05/2019	0.00	0.00	0.00	0.00	0.00
10/06/2019	0.00	0.00	0.00	0.00	0.00
10/07/2019	0.00	0.00	0.00	0.00	0.00
10/08/2019	0.00	0.00	0.00	0.00	0.00
10/09/2019	0.00	0.00	0.00	0.00	0.00
10/10/2019	0.00	0.00	0.00	0.00	0.00
10/11/2019	0.00	0.00	0.00	0.00	0.00
10/12/2019	0.00	0.00	0.00	0.00	0.00
10/13/2019	0.00	0.00	0.00	0.00	0.00
10/14/2019	0.00	0.00	0.00	0.00	0.00
10/15/2019	0.00	0.00	0.00	0.00	0.00
10/16/2019	0.00	0.00	0.00	0.00	0.00
10/17/2019	0.00	0.00	0.00	0.00	0.00
10/18/2019	0.00	0.00	0.00	0.00	0.00
10/19/2019	0.00	0.00	0.00	0.00	0.00
10/20/2019	0.00	0.00	0.00	0.00	0.00
10/21/2019	46.26	65.45	5.04	10.08	16.78
10/22/2019	18.36	60.33	5.92	11.84	19.73
10/23/2019	17.21	63.08	6.02	12.05	20.07
10/24/2019	54.98	85.19	6.82	13.72	22.83
10/25/2019	62.93	85.06	6.91	13.82	22.98
10/26/2019	19.60	50.83	4.86	9.69	16.16
10/27/2019	17.37	52.71	5.05	10.06	16.77
10/28/2019	22.77	62.36	5.98	11.99	20.01
10/29/2019	338.32	102.83	8.10	16.22	27.04
10/30/2019	45.65	75.70	7.38	14.74	24.57
10/31/2019	18.36	79.67	7.63	15.28	25.48
Monthly Avg/Sum*:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
Daily Min:	17.21	50.83	4.86	9.69	16.16
Daily Max:	338.32	102.83	8.10	16.22	27.04
Oct 2019 - Oct 2019	661.81	783.21	69.71	139.49	232.42
QTD:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
YTD 2019:	5,142.90 *	13,106.22 *	1,216.27 *	2,433.64 *	4,055.91 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.00	13.94	23.22
11/02/2019	22.69	65.84	6.26	12.58	20.98
11/03/2019	21.34	61.80	5.88	11.73	19.64
11/04/2019	18.26	69.40	6.64	13.25	22.10
11/05/2019	52.08	100.71	8.53	17.03	28.37
11/06/2019	42.42	126.86	11.97	23.94	39.94
11/07/2019	83.67	109.38	9.41	18.78	31.34
11/08/2019	62.35	113.46	9.84	19.71	32.81
11/09/2019	36.76	59.05	5.65	11.25	18.79
11/10/2019	23.22	57.70	5.53	10.99	18.37
11/11/2019	48.40	72.13	6.02	12.04	20.05
11/12/2019	40.18	63.34	5.81	11.64	19.40
11/13/2019	72.57	112.30	9.86	19.70	32.85
11/14/2019	58.46	111.34	10.52	21.00	35.12
11/15/2019	19.85	1.69	0.04	0.08	0.13
11/16/2019	0.00	0.00	0.00	0.00	0.00
11/17/2019	0.00	0.00	0.00	0.00	0.00
11/18/2019	0.00	0.00	0.00	0.00	0.00
11/19/2019	0.00	0.00	0.00	0.00	0.00
11/20/2019	41.86	21.26	0.75	1.51	2.52
11/21/2019	97.32	110.63	8.34	16.73	27.87
11/22/2019	41.89	125.41	11.96	23.91	39.92
11/23/2019	13.86	1.69	0.04	0.07	0.12
11/24/2019	0.00	0.00	0.00	0.00	0.00
11/25/2019	0.00	0.00	0.00	0.00	0.00
11/26/2019	128.07	128.26	9.81	19.66	32.75
11/27/2019	38.45	115.86	11.04	22.08	36.74
11/28/2019	36.18	104.67	9.95	19.92	33.17
11/29/2019	38.55	113.72	10.82	21.67	36.10
11/30/2019	37.78	110.86	10.67	21.38	35.55
Monthly Avg/Sum*:	1,101.16 *	2,030.35 *	182.34 *	364.59 *	607.85 *
Daily Min:	13.86	1.69	0.04	0.07	0.12
Daily Max:	128.07	128.26	11.97	23.94	39.94
Oct 2019 - Nov 2019	1,762.97	2,813.56	252.05	504.08	840.27
QTD:	1,762.97 *	2,813.56 *	252.05 *	504.08 *	840.27 *
YTD 2019:	6,244.06 *	15,136.57 *	1,398.61 *	2,798.23 *	4,663.76 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2019	38.31	107.26	10.49	20.91	34.80
12/02/2019	35.09	125.41	11.96	23.89	39.79
12/03/2019	35.34	116.36	11.06	22.04	36.78
12/04/2019	31.69	132.56	12.65	25.26	42.06
12/05/2019	29.57	2.15	0.02	0.04	0.08
12/06/2019	0.00	0.00	0.00	0.00	0.00
12/07/2019	0.00	0.00	0.00	0.00	0.00
12/08/2019	0.00	0.00	0.00	0.00	0.00
12/09/2019	0.00	0.00	0.00	0.00	0.00
12/10/2019	0.00	0.00	0.00	0.00	0.00
12/11/2019	0.00	0.00	0.00	0.00	0.00
12/12/2019	0.00	0.00	0.00	0.00	0.00
12/13/2019	0.00	0.00	0.00	0.00	0.00
12/14/2019	0.00	0.00	0.00	0.00	0.00
12/15/2019	0.00	0.00	0.00	0.00	0.00
12/16/2019	0.00	0.00	0.00	0.00	0.00
12/17/2019	0.00	0.00	0.00	0.00	0.00
12/18/2019	0.00	0.00	0.00	0.00	0.00
12/19/2019	0.00	0.00	0.00	0.00	0.00
12/20/2019	0.00	0.00	0.00	0.00	0.00
12/21/2019	0.00	0.00	0.00	0.00	0.00
12/22/2019	0.00	0.00	0.00	0.00	0.00
12/23/2019	0.00	0.00	0.00	0.00	0.00
12/24/2019	0.00	0.00	0.00	0.00	0.00
12/25/2019	0.00	0.00	0.00	0.00	0.00
12/26/2019	0.00	0.00	0.00	0.00	0.00
12/27/2019	0.00	0.00	0.00	0.00	0.00
12/28/2019	0.00	0.00	0.00	0.00	0.00
12/29/2019	0.00	0.00	0.00	0.00	0.00
12/30/2019	0.00	0.00	0.00	0.00	0.00
12/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	170.00 *	483.74 *	46.18 *	92.14 *	153.51 *
Daily Min:	29.57	2.15	0.02	0.04	0.08
Daily Max:	38.31	132.56	12.65	25.26	42.06
Oct 2019 - Dec 2019	1,932.97	3,297.30	298.23	596.22	993.78
QTD:	1,932.97 *	3,297.30 *	298.23 *	596.22 *	993.78 *
YTD 2019:	6,414.06 *	15,620.31 *	1,444.79 *	2,890.37 *	4,817.27 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.0	0.00	0.00
10/02/2019	0.00	0.00	0.0	0.00	0.00
10/03/2019	0.00	0.00	0.0	0.00	0.00
10/04/2019	0.00	0.00	0.0	0.00	0.00
10/05/2019	0.00	0.00	0.0	0.00	0.00
10/06/2019	0.00	0.00	0.0	0.00	0.00
10/07/2019	0.00	0.00	0.0	0.00	0.00
10/08/2019	0.00	0.00	0.0	0.00	0.00
10/09/2019	0.00	0.00	0.0	0.00	0.00
10/10/2019	0.00	0.00	0.0	0.00	0.00
10/11/2019	0.00	0.00	0.0	0.00	0.00
10/12/2019	0.00	0.00	0.0	0.00	0.00
10/13/2019	0.00	0.00	0.0	0.00	0.00
10/14/2019	0.00	0.00	0.0	0.00	0.00
10/15/2019	0.00	0.00	0.0	0.00	0.00
10/16/2019	0.00	0.00	0.0	0.00	0.00
10/17/2019	0.00	0.00	0.0	0.00	0.00
10/18/2019	0.00	0.00	0.0	0.00	0.00
10/19/2019	0.00	0.00	0.0	0.00	0.00
10/20/2019	0.00	0.00	0.0	0.00	0.00
10/21/2019	0.00	0.00	0.0	0.00	0.00
10/22/2019	0.00	0.00	0.0	0.00	0.00
10/23/2019	0.00	0.00	0.0	0.00	0.00
10/24/2019	31.75	39.81	2.6	5.41	9.00
10/25/2019	21.05	60.97	5.5	11.66	19.40
10/26/2019	19.60	50.83	4.8	9.69	16.16
10/27/2019	17.37	52.71	4.8	10.06	16.77
10/28/2019	22.77	62.36	5.8	11.99	20.01
10/29/2019	15.49	84.49	7.8	16.08	26.80
10/30/2019	23.09	68.72	6.6	13.15	21.94
10/31/2019	18.36	79.67	7.7	15.28	25.48
Monthly Avg/Sum*:	169.48 *	499.56 *	45.6 *	93.32 *	155.56 *
Daily Min:	15.49	39.81	2.6	5.41	9.00
Daily Max:	31.75	84.49	7.8	16.08	26.80
Oct 2019 - Oct 2019	169.48	499.56	45.6	93.32	155.56
QTD:	169.48 *	499.56 *	45.6 *	93.32 *	155.56 *
YTD 2019:	1,893.08 *	6,115.19 *	592.3 *	1,147.35 *	1,911.76 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.1	13.94	23.22
11/02/2019	22.69	65.84	6.1	12.58	20.98
11/03/2019	21.34	61.80	5.7	11.73	19.64
11/04/2019	18.26	69.40	6.6	13.25	22.10
11/05/2019	22.88	64.88	6.1	12.40	20.67
11/06/2019	20.58	63.42	6.0	12.06	20.12
11/07/2019	22.95	74.68	7.2	14.34	23.92
11/08/2019	25.46	68.64	6.6	13.21	21.98
11/09/2019	23.42	58.39	5.5	11.24	18.77
11/10/2019	23.22	57.70	5.4	10.99	18.37
11/11/2019	24.65	62.20	5.7	11.89	19.81
11/12/2019	17.30	1.60	0.1	0.14	0.23
11/13/2019	48.91	50.61	4.0	7.82	13.06
11/14/2019	40.62	56.12	5.4	10.43	17.46
11/15/2019	0.00	0.00	0.0	0.00	0.00
11/16/2019	0.00	0.00	0.0	0.00	0.00
11/17/2019	0.00	0.00	0.0	0.00	0.00
11/18/2019	0.00	0.00	0.0	0.00	0.00
11/19/2019	0.00	0.00	0.0	0.00	0.00
11/20/2019	0.00	0.00	0.0	0.00	0.00
11/21/2019	53.98	55.97	4.6	8.69	14.50
11/22/2019	22.36	63.98	6.2	12.16	20.31
11/23/2019	0.00	0.00	0.0	0.00	0.00
11/24/2019	0.00	0.00	0.0	0.00	0.00
11/25/2019	0.00	0.00	0.0	0.00	0.00
11/26/2019	80.36	61.71	5.1	9.53	15.91
11/27/2019	20.26	58.06	5.3	11.03	18.36
11/28/2019	18.99	52.68	4.9	10.04	16.70
11/29/2019	19.98	56.81	5.2	10.82	18.02
11/30/2019	19.96	57.25	5.3	10.91	18.16
Monthly Avg/Sum*:	593.12 *	1,234.73 *	114.1 *	229.20 *	382.29 *
Daily Min:	17.30	1.60	0.1	0.14	0.23
Daily Max:	80.36	74.68	7.2	14.34	23.92
Oct 2019 - Nov 2019	762.60	1,734.29	159.7	322.52	537.85
QTD:	762.60 *	1,734.29 *	159.7 *	322.52 *	537.85 *
YTD 2019:	2,486.20 *	7,349.92 *	706.4 *	1,376.55 *	2,294.05 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2019	20.19	56.13	5.4	10.74	17.85
12/02/2019	16.62	64.16	6.3	12.19	20.32
12/03/2019	15.21	59.59	5.7	11.29	18.87
12/04/2019	13.39	68.07	6.6	12.92	21.53
12/05/2019	15.25	1.00	0.0	0.02	0.04
12/06/2019	0.00	0.00	0.0	0.00	0.00
12/07/2019	0.00	0.00	0.0	0.00	0.00
12/08/2019	0.00	0.00	0.0	0.00	0.00
12/09/2019	0.00	0.00	0.0	0.00	0.00
12/10/2019	0.00	0.00	0.0	0.00	0.00
12/11/2019	0.00	0.00	0.0	0.00	0.00
12/12/2019	0.00	0.00	0.0	0.00	0.00
12/13/2019	0.00	0.00	0.0	0.00	0.00
12/14/2019	0.00	0.00	0.0	0.00	0.00
12/15/2019	0.00	0.00	0.0	0.00	0.00
12/16/2019	0.00	0.00	0.0	0.00	0.00
12/17/2019	0.00	0.00	0.0	0.00	0.00
12/18/2019	0.00	0.00	0.0	0.00	0.00
12/19/2019	0.00	0.00	0.0	0.00	0.00
12/20/2019	0.00	0.00	0.0	0.00	0.00
12/21/2019	0.00	0.00	0.0	0.00	0.00
12/22/2019	0.00	0.00	0.0	0.00	0.00
12/23/2019	0.00	0.00	0.0	0.00	0.00
12/24/2019	0.00	0.00	0.0	0.00	0.00
12/25/2019	0.00	0.00	0.0	0.00	0.00
12/26/2019	0.00	0.00	0.0	0.00	0.00
12/27/2019	0.00	0.00	0.0	0.00	0.00
12/28/2019	0.00	0.00	0.0	0.00	0.00
12/29/2019	0.00	0.00	0.0	0.00	0.00
12/30/2019	0.00	0.00	0.0	0.00	0.00
12/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	80.66 *	248.95 *	24.0 *	47.16 *	78.61 *
Daily Min:	13.39	1.00	0.0	0.02	0.04
Daily Max:	20.19	68.07	6.6	12.92	21.53
Oct 2019 - Dec 2019	843.26	1,983.24	183.7	369.68	616.46
QTD:	843.26 *	1,983.24 *	183.7 *	369.68 *	616.46 *
YTD 2019:	2,566.86 *	7,598.87 *	730.4 *	1,423.71 *	2,372.66 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.0	0.00	0.00
10/02/2019	0.00	0.00	0.0	0.00	0.00
10/03/2019	0.00	0.00	0.0	0.00	0.00
10/04/2019	0.00	0.00	0.0	0.00	0.00
10/05/2019	0.00	0.00	0.0	0.00	0.00
10/06/2019	0.00	0.00	0.0	0.00	0.00
10/07/2019	0.00	0.00	0.0	0.00	0.00
10/08/2019	0.00	0.00	0.0	0.00	0.00
10/09/2019	0.00	0.00	0.0	0.00	0.00
10/10/2019	0.00	0.00	0.0	0.00	0.00
10/11/2019	0.00	0.00	0.0	0.00	0.00
10/12/2019	0.00	0.00	0.0	0.00	0.00
10/13/2019	0.00	0.00	0.0	0.00	0.00
10/14/2019	0.00	0.00	0.0	0.00	0.00
10/15/2019	0.00	0.00	0.0	0.00	0.00
10/16/2019	0.00	0.00	0.0	0.00	0.00
10/17/2019	0.00	0.00	0.0	0.00	0.00
10/18/2019	0.00	0.00	0.0	0.00	0.00
10/19/2019	0.00	0.00	0.0	0.00	0.00
10/20/2019	0.00	0.00	0.0	0.00	0.00
10/21/2019	46.26	65.45	4.9	10.08	16.78
10/22/2019	18.36	60.33	5.8	11.84	19.73
10/23/2019	17.21	63.08	6.1	12.05	20.07
10/24/2019	23.23	45.38	4.2	8.31	13.83
10/25/2019	41.88	24.09	1.0	2.16	3.58
10/26/2019	0.00	0.00	0.0	0.00	0.00
10/27/2019	0.00	0.00	0.0	0.00	0.00
10/28/2019	0.00	0.00	0.0	0.00	0.00
10/29/2019	321.22	18.34	0.0	0.14	0.24
10/30/2019	13.71	6.98	0.9	1.59	2.63
10/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	481.87 *	283.65 *	22.9 *	46.17 *	76.86 *
Daily Min:	13.71	6.98	0.0	0.14	0.24
Daily Max:	321.22	65.45	6.1	12.05	20.07
Oct 2019 - Oct 2019	481.87	283.65	22.9	46.17	76.86
QTD:	481.87 *	283.65 *	22.9 *	46.17 *	76.86 *
YTD 2019:	3,225.75 *	6,991.03 *	648.4 *	1,286.29 *	2,144.15 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2019	0.00	0.00	0.0	0.00	0.00
11/02/2019	0.00	0.00	0.0	0.00	0.00
11/03/2019	0.00	0.00	0.0	0.00	0.00
11/04/2019	0.00	0.00	0.0	0.00	0.00
11/05/2019	29.20	35.83	2.4	4.63	7.70
11/06/2019	21.84	63.44	5.9	11.88	19.82
11/07/2019	60.72	34.70	2.2	4.44	7.42
11/08/2019	36.89	44.82	3.3	6.50	10.83
11/09/2019	13.34	0.66	0.0	0.01	0.02
11/10/2019	0.00	0.00	0.0	0.00	0.00
11/11/2019	23.75	9.93	0.1	0.15	0.24
11/12/2019	22.88	61.74	5.5	11.50	19.17
11/13/2019	23.66	61.69	6.1	11.88	19.79
11/14/2019	17.84	55.22	5.7	10.57	17.66
11/15/2019	19.85	1.69	0.0	0.08	0.13
11/16/2019	0.00	0.00	0.0	0.00	0.00
11/17/2019	0.00	0.00	0.0	0.00	0.00
11/18/2019	0.00	0.00	0.0	0.00	0.00
11/19/2019	0.00	0.00	0.0	0.00	0.00
11/20/2019	41.86	21.26	0.6	1.51	2.52
11/21/2019	43.34	54.66	4.0	8.04	13.37
11/22/2019	19.53	61.43	5.7	11.75	19.61
11/23/2019	13.86	1.69	0.0	0.07	0.12
11/24/2019	0.00	0.00	0.0	0.00	0.00
11/25/2019	0.00	0.00	0.0	0.00	0.00
11/26/2019	47.71	66.55	4.8	10.13	16.84
11/27/2019	18.19	57.80	5.6	11.05	18.38
11/28/2019	17.19	51.99	4.8	9.88	16.47
11/29/2019	18.57	56.91	5.1	10.85	18.08
11/30/2019	17.82	53.61	5.1	10.47	17.39
Monthly Avg/Sum*:	508.04 *	795.62 *	66.9 *	135.39 *	225.56 *
Daily Min:	13.34	0.66	0.0	0.01	0.02
Daily Max:	60.72	66.55	6.1	11.88	19.82
Oct 2019 - Nov 2019	989.91	1,079.27	89.8	181.56	302.42
QTD:	989.91 *	1,079.27 *	89.8 *	181.56 *	302.42 *
YTD 2019:	3,733.79 *	7,786.65 *	715.3 *	1,421.68 *	2,369.71 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:37 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2019	18.12	51.13	5.3	10.17	16.95
12/02/2019	18.47	61.25	6.0	11.70	19.47
12/03/2019	20.13	56.77	5.3	10.75	17.91
12/04/2019	18.30	64.49	6.0	12.34	20.53
12/05/2019	14.32	1.15	0.0	0.02	0.04
12/06/2019	0.00	0.00	0.0	0.00	0.00
12/07/2019	0.00	0.00	0.0	0.00	0.00
12/08/2019	0.00	0.00	0.0	0.00	0.00
12/09/2019	0.00	0.00	0.0	0.00	0.00
12/10/2019	0.00	0.00	0.0	0.00	0.00
12/11/2019	0.00	0.00	0.0	0.00	0.00
12/12/2019	0.00	0.00	0.0	0.00	0.00
12/13/2019	0.00	0.00	0.0	0.00	0.00
12/14/2019	0.00	0.00	0.0	0.00	0.00
12/15/2019	0.00	0.00	0.0	0.00	0.00
12/16/2019	0.00	0.00	0.0	0.00	0.00
12/17/2019	0.00	0.00	0.0	0.00	0.00
12/18/2019	0.00	0.00	0.0	0.00	0.00
12/19/2019	0.00	0.00	0.0	0.00	0.00
12/20/2019	0.00	0.00	0.0	0.00	0.00
12/21/2019	0.00	0.00	0.0	0.00	0.00
12/22/2019	0.00	0.00	0.0	0.00	0.00
12/23/2019	0.00	0.00	0.0	0.00	0.00
12/24/2019	0.00	0.00	0.0	0.00	0.00
12/25/2019	0.00	0.00	0.0	0.00	0.00
12/26/2019	0.00	0.00	0.0	0.00	0.00
12/27/2019	0.00	0.00	0.0	0.00	0.00
12/28/2019	0.00	0.00	0.0	0.00	0.00
12/29/2019	0.00	0.00	0.0	0.00	0.00
12/30/2019	0.00	0.00	0.0	0.00	0.00
12/31/2019	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	89.34 *	234.79 *	22.6 *	44.98 *	74.90 *
Daily Min:	14.32	1.15	0.0	0.02	0.04
Daily Max:	20.13	64.49	6.0	12.34	20.53
Oct 2019 - Dec 2019	1,079.25	1,314.06	112.4	226.54	377.32
QTD:	1,079.25 *	1,314.06 *	112.4 *	226.54 *	377.32 *
YTD 2019:	3,823.13 *	8,021.44 *	737.9 *	1,466.66 *	2,444.61 *

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2019	0.00	0.00	0.00	0.00	0.00
10/02/2019	0.00	0.00	0.00	0.00	0.00
10/03/2019	0.00	0.00	0.00	0.00	0.00
10/04/2019	0.00	0.00	0.00	0.00	0.00
10/05/2019	0.00	0.00	0.00	0.00	0.00
10/06/2019	0.00	0.00	0.00	0.00	0.00
10/07/2019	0.00	0.00	0.00	0.00	0.00
10/08/2019	0.00	0.00	0.00	0.00	0.00
10/09/2019	0.00	0.00	0.00	0.00	0.00
10/10/2019	0.00	0.00	0.00	0.00	0.00
10/11/2019	0.00	0.00	0.00	0.00	0.00
10/12/2019	0.00	0.00	0.00	0.00	0.00
10/13/2019	0.00	0.00	0.00	0.00	0.00
10/14/2019	0.00	0.00	0.00	0.00	0.00
10/15/2019	0.00	0.00	0.00	0.00	0.00
10/16/2019	0.00	0.00	0.00	0.00	0.00
10/17/2019	0.00	0.00	0.00	0.00	0.00
10/18/2019	0.00	0.00	0.00	0.00	0.00
10/19/2019	0.00	0.00	0.00	0.00	0.00
10/20/2019	0.00	0.00	0.00	0.00	0.00
10/21/2019	46.26	65.45	5.04	10.08	16.78
10/22/2019	18.36	60.33	5.92	11.84	19.73
10/23/2019	17.21	63.08	6.02	12.05	20.07
10/24/2019	54.98	85.19	6.82	13.72	22.83
10/25/2019	62.93	85.06	6.91	13.82	22.98
10/26/2019	19.60	50.83	4.86	9.69	16.16
10/27/2019	17.37	52.71	5.05	10.06	16.77
10/28/2019	22.77	62.36	5.98	11.99	20.01
10/29/2019	338.32	102.83	8.10	16.22	27.04
10/30/2019	45.65	75.70	7.38	14.74	24.57
10/31/2019	18.36	79.67	7.63	15.28	25.48
Monthly Avg/Sum*:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
Daily Min:	17.21	50.83	4.86	9.69	16.16
Daily Max:	338.32	102.83	8.10	16.22	27.04
Oct 2019 - Oct 2019	661.81	783.21	69.71	139.49	232.42
QTD:	661.81 *	783.21 *	69.71 *	139.49 *	232.42 *
YTD 2019:	5,142.90 *	13,106.22 *	1,216.27 *	2,433.64 *	4,055.91 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2019	24.95	72.99	7.00	13.94	23.22
11/02/2019	22.69	65.84	6.26	12.58	20.98
11/03/2019	21.34	61.80	5.88	11.73	19.64
11/04/2019	18.26	69.40	6.64	13.25	22.10
11/05/2019	52.08	100.71	8.53	17.03	28.37
11/06/2019	42.42	126.86	11.97	23.94	39.94
11/07/2019	83.67	109.38	9.41	18.78	31.34
11/08/2019	62.35	113.46	9.84	19.71	32.81
11/09/2019	36.76	59.05	5.65	11.25	18.79
11/10/2019	23.22	57.70	5.53	10.99	18.37
11/11/2019	48.40	72.13	6.02	12.04	20.05
11/12/2019	40.18	63.34	5.81	11.64	19.40
11/13/2019	72.57	112.30	9.86	19.70	32.85
11/14/2019	58.46	111.34	10.52	21.00	35.12
11/15/2019	19.85	1.69	0.04	0.08	0.13
11/16/2019	0.00	0.00	0.00	0.00	0.00
11/17/2019	0.00	0.00	0.00	0.00	0.00
11/18/2019	0.00	0.00	0.00	0.00	0.00
11/19/2019	0.00	0.00	0.00	0.00	0.00
11/20/2019	41.86	21.26	0.75	1.51	2.52
11/21/2019	97.32	110.63	8.34	16.73	27.87
11/22/2019	41.89	125.41	11.96	23.91	39.92
11/23/2019	13.86	1.69	0.04	0.07	0.12
11/24/2019	0.00	0.00	0.00	0.00	0.00
11/25/2019	0.00	0.00	0.00	0.00	0.00
11/26/2019	128.07	128.26	9.81	19.66	32.75
11/27/2019	38.45	115.86	11.04	22.08	36.74
11/28/2019	36.18	104.67	9.95	19.92	33.17
11/29/2019	38.55	113.72	10.82	21.67	36.10
11/30/2019	37.78	110.86	10.67	21.38	35.55
Monthly Avg/Sum*:	1,101.16 *	2,030.35 *	182.34 *	364.59 *	607.85 *
Daily Min:	13.86	1.69	0.04	0.07	0.12
Daily Max:	128.07	128.26	11.97	23.94	39.94
Oct 2019 - Nov 2019	1,762.97	2,813.56	252.05	504.08	840.27
QTD:	1,762.97 *	2,813.56 *	252.05 *	504.08 *	840.27 *
YTD 2019:	6,244.06 *	15,136.57 *	1,398.61 *	2,798.23 *	4,663.76 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 15:36 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2019	38.31	107.26	10.49	20.91	34.80
12/02/2019	35.09	125.41	11.96	23.89	39.79
12/03/2019	35.34	116.36	11.06	22.04	36.78
12/04/2019	31.69	132.56	12.65	25.26	42.06
12/05/2019	29.57	2.15	0.02	0.04	0.08
12/06/2019	0.00	0.00	0.00	0.00	0.00
12/07/2019	0.00	0.00	0.00	0.00	0.00
12/08/2019	0.00	0.00	0.00	0.00	0.00
12/09/2019	0.00	0.00	0.00	0.00	0.00
12/10/2019	0.00	0.00	0.00	0.00	0.00
12/11/2019	0.00	0.00	0.00	0.00	0.00
12/12/2019	0.00	0.00	0.00	0.00	0.00
12/13/2019	0.00	0.00	0.00	0.00	0.00
12/14/2019	0.00	0.00	0.00	0.00	0.00
12/15/2019	0.00	0.00	0.00	0.00	0.00
12/16/2019	0.00	0.00	0.00	0.00	0.00
12/17/2019	0.00	0.00	0.00	0.00	0.00
12/18/2019	0.00	0.00	0.00	0.00	0.00
12/19/2019	0.00	0.00	0.00	0.00	0.00
12/20/2019	0.00	0.00	0.00	0.00	0.00
12/21/2019	0.00	0.00	0.00	0.00	0.00
12/22/2019	0.00	0.00	0.00	0.00	0.00
12/23/2019	0.00	0.00	0.00	0.00	0.00
12/24/2019	0.00	0.00	0.00	0.00	0.00
12/25/2019	0.00	0.00	0.00	0.00	0.00
12/26/2019	0.00	0.00	0.00	0.00	0.00
12/27/2019	0.00	0.00	0.00	0.00	0.00
12/28/2019	0.00	0.00	0.00	0.00	0.00
12/29/2019	0.00	0.00	0.00	0.00	0.00
12/30/2019	0.00	0.00	0.00	0.00	0.00
12/31/2019	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	170.00 *	483.74 *	46.18 *	92.14 *	153.51 *
Daily Min:	29.57	2.15	0.02	0.04	0.08
Daily Max:	38.31	132.56	12.65	25.26	42.06
Oct 2019 - Dec 2019	1,932.97	3,297.30	298.23	596.22	993.78
QTD:	1,932.97 *	3,297.30 *	298.23 *	596.22 *	993.78 *
YTD 2019:	6,414.06 *	15,620.31 *	1,444.79 *	2,890.37 *	4,817.27 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2019 00:00 To: 12/31/2019 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/07/2020 14:32 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2019	0.3310	3.6667	0.3916	8.6208	0.0696	1.5963	0.0349	0.7982	0.1162	2.6610
Nov 2019	0.5504	3.5681	1.0151	8.9063	0.1824	1.6530	0.0911	0.8264	0.3043	2.7560
Dec 2019	0.0850	3.2072	0.2419	7.8108	0.0460	1.4448	0.0230	0.7223	0.0767	2.4089
Sum/Avg	3.2072		7.8108		1.4448		0.7223		2.4089	
Limit Value										

Replace the dates with the ones you need

10/1/2019 0:00
12/31/2019 0:00

1D

TOWER AVG.

519-AIT-9504-1

2548

10/1/19 0:00	3766.3
10/2/19 0:00	2929.8
10/3/19 0:00	2701.9
10/4/19 0:00	2531.2
10/5/19 0:00	2365.7
10/6/19 0:00	2318.4
10/7/19 0:00	2297.8
10/8/19 0:00	2235.6
10/9/19 0:00	2138.3
10/10/19 0:00	1934.6
10/11/19 0:00	1871.5
10/12/19 0:00	1884.5
10/13/19 0:00	1855.2
10/14/19 0:00	1831.6
10/15/19 0:00	1816.0
10/16/19 0:00	1757.6
10/17/19 0:00	1755.3
10/18/19 0:00	1709.4
10/19/19 0:00	1718.4
10/20/19 0:00	1729.5
10/21/19 0:00	1698.0
10/22/19 0:00	3487.2
10/23/19 0:00	3584.7
10/24/19 0:00	3374.9
10/25/19 0:00	3220.4
10/26/19 0:00	3651.8
10/27/19 0:00	3449.3
10/28/19 0:00	3598.1
10/29/19 0:00	3527.4
10/30/19 0:00	3748.8
10/31/19 0:00	3588.7
11/1/19 0:00	3819.3
11/2/19 0:00	3681.8
11/3/19 0:00	3131.6
11/4/19 0:00	3358.2
11/5/19 0:00	3339.1
11/6/19 0:00	3226.5
11/7/19 0:00	3114.4
11/8/19 0:00	2834.8
11/9/19 0:00	2936.0
11/10/19 0:00	2737.9
11/11/19 0:00	2588.7
11/12/19 0:00	3123.7
11/13/19 0:00	3035.5
11/14/19 0:00	3046.1
11/15/19 0:00	3047.4
11/16/19 0:00	2236.6
11/17/19 0:00	1892.0
11/18/19 0:00	2316.4

11/19/19 0:00	2155.4
11/20/19 0:00	1897.3
11/21/19 0:00	1626.6
11/22/19 0:00	3136.0
11/23/19 0:00	3902.2
11/24/19 0:00	2766.4
11/25/19 0:00	2413.3
11/26/19 0:00	2053.9
11/27/19 0:00	3163.3
11/28/19 0:00	4386.3
11/29/19 0:00	4028.5
11/30/19 0:00	4864.0
12/1/19 0:00	3591.3
12/2/19 0:00	3461.0
12/3/19 0:00	3470.8
12/4/19 0:00	3595.3
12/5/19 0:00	3664.6
12/6/19 0:00	2289.3
12/7/19 0:00	2046.3
12/8/19 0:00	1858.3
12/9/19 0:00	2342.8
12/10/19 0:00	2237.8
12/11/19 0:00	2170.2
12/12/19 0:00	2146.0
12/13/19 0:00	2163.8
12/14/19 0:00	2062.0
12/15/19 0:00	1831.1
12/16/19 0:00	1707.2
12/17/19 0:00	1628.4
12/18/19 0:00	1595.5
12/19/19 0:00	1590.5
12/20/19 0:00	1599.8
12/21/19 0:00	1541.7
12/22/19 0:00	1450.9
12/23/19 0:00	1395.4
12/24/19 0:00	1358.1
12/25/19 0:00	1343.1
12/26/19 0:00	1326.3
12/27/19 0:00	1298.6
12/28/19 0:00	1295.8
12/29/19 0:00	1340.6

Resize to show alsize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2548	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00163072	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	5.26
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	484		4Q19
---------------------------	------------	--	-------------

fill only these

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification: The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 1Q19 QAQR.

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2019 0:00
12/31/2019 0:00

1D

TOWER AVG.

519-AIT-9504-1

2548

10/1/19 0:00	3766.3
10/2/19 0:00	2929.8
10/3/19 0:00	2701.9
10/4/19 0:00	2531.2
10/5/19 0:00	2365.7
10/6/19 0:00	2318.4
10/7/19 0:00	2297.8
10/8/19 0:00	2235.6
10/9/19 0:00	2138.3
10/10/19 0:00	1934.6
10/11/19 0:00	1871.5
10/12/19 0:00	1884.5
10/13/19 0:00	1855.2
10/14/19 0:00	1831.6
10/15/19 0:00	1816.0
10/16/19 0:00	1757.6
10/17/19 0:00	1755.3
10/18/19 0:00	1709.4
10/19/19 0:00	1718.4
10/20/19 0:00	1729.5
10/21/19 0:00	1698.0
10/22/19 0:00	3487.2
10/23/19 0:00	3584.7
10/24/19 0:00	3374.9
10/25/19 0:00	3220.4
10/26/19 0:00	3651.8
10/27/19 0:00	3449.3
10/28/19 0:00	3598.1
10/29/19 0:00	3527.4
10/30/19 0:00	3748.8
10/31/19 0:00	3588.7
11/1/19 0:00	3819.3
11/2/19 0:00	3681.8
11/3/19 0:00	3131.6
11/4/19 0:00	3358.2
11/5/19 0:00	3339.1
11/6/19 0:00	3226.5
11/7/19 0:00	3114.4
11/8/19 0:00	2834.8
11/9/19 0:00	2936.0
11/10/19 0:00	2737.9
11/11/19 0:00	2588.7
11/12/19 0:00	3123.7
11/13/19 0:00	3035.5
11/14/19 0:00	3046.1
11/15/19 0:00	3047.4
11/16/19 0:00	2236.6
11/17/19 0:00	1892.0
11/18/19 0:00	2316.4

11/19/19 0:00	2155.4
11/20/19 0:00	1897.3
11/21/19 0:00	1626.6
11/22/19 0:00	3136.0
11/23/19 0:00	3902.2
11/24/19 0:00	2766.4
11/25/19 0:00	2413.3
11/26/19 0:00	2053.9
11/27/19 0:00	3163.3
11/28/19 0:00	4386.3
11/29/19 0:00	4028.5
11/30/19 0:00	4864.0
12/1/19 0:00	3591.3
12/2/19 0:00	3461.0
12/3/19 0:00	3470.8
12/4/19 0:00	3595.3
12/5/19 0:00	3664.6
12/6/19 0:00	2289.3
12/7/19 0:00	2046.3
12/8/19 0:00	1858.3
12/9/19 0:00	2342.8
12/10/19 0:00	2237.8
12/11/19 0:00	2170.2
12/12/19 0:00	2146.0
12/13/19 0:00	2163.8
12/14/19 0:00	2062.0
12/15/19 0:00	1831.1
12/16/19 0:00	1707.2
12/17/19 0:00	1628.4
12/18/19 0:00	1595.5
12/19/19 0:00	1590.5
12/20/19 0:00	1599.8
12/21/19 0:00	1541.7
12/22/19 0:00	1450.9
12/23/19 0:00	1395.4
12/24/19 0:00	1358.1
12/25/19 0:00	1343.1
12/26/19 0:00	1326.3
12/27/19 0:00	1298.6
12/28/19 0:00	1295.8
12/29/19 0:00	1340.6

Resize to show alsize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2548	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00163072	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	5.26
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	484		4Q19
---------------------------	------------	--	-------------

fill only these

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $PM-10 = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow own water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2019 0:00
12/31/2019 0:00

1D

TOWER AVG.

519-AIT-9504-1

2548

10/1/19 0:00	3766.3
10/2/19 0:00	2929.8
10/3/19 0:00	2701.9
10/4/19 0:00	2531.2
10/5/19 0:00	2365.7
10/6/19 0:00	2318.4
10/7/19 0:00	2297.8
10/8/19 0:00	2235.6
10/9/19 0:00	2138.3
10/10/19 0:00	1934.6
10/11/19 0:00	1871.5
10/12/19 0:00	1884.5
10/13/19 0:00	1855.2
10/14/19 0:00	1831.6
10/15/19 0:00	1816.0
10/16/19 0:00	1757.6
10/17/19 0:00	1755.3
10/18/19 0:00	1709.4
10/19/19 0:00	1718.4
10/20/19 0:00	1729.5
10/21/19 0:00	1698.0
10/22/19 0:00	3487.2
10/23/19 0:00	3584.7
10/24/19 0:00	3374.9
10/25/19 0:00	3220.4
10/26/19 0:00	3651.8
10/27/19 0:00	3449.3
10/28/19 0:00	3598.1
10/29/19 0:00	3527.4
10/30/19 0:00	3748.8
10/31/19 0:00	3588.7
11/1/19 0:00	3819.3
11/2/19 0:00	3681.8
11/3/19 0:00	3131.6
11/4/19 0:00	3358.2
11/5/19 0:00	3339.1
11/6/19 0:00	3226.5
11/7/19 0:00	3114.4
11/8/19 0:00	2834.8
11/9/19 0:00	2936.0
11/10/19 0:00	2737.9
11/11/19 0:00	2588.7
11/12/19 0:00	3123.7
11/13/19 0:00	3035.5
11/14/19 0:00	3046.1
11/15/19 0:00	3047.4
11/16/19 0:00	2236.6
11/17/19 0:00	1892.0
11/18/19 0:00	2316.4

11/19/19 0:00	2155.4
11/20/19 0:00	1897.3
11/21/19 0:00	1626.6
11/22/19 0:00	3136.0
11/23/19 0:00	3902.2
11/24/19 0:00	2766.4
11/25/19 0:00	2413.3
11/26/19 0:00	2053.9
11/27/19 0:00	3163.3
11/28/19 0:00	4386.3
11/29/19 0:00	4028.5
11/30/19 0:00	4864.0
12/1/19 0:00	3591.3
12/2/19 0:00	3461.0
12/3/19 0:00	3470.8
12/4/19 0:00	3595.3
12/5/19 0:00	3664.6
12/6/19 0:00	2289.3
12/7/19 0:00	2046.3
12/8/19 0:00	1858.3
12/9/19 0:00	2342.8
12/10/19 0:00	2237.8
12/11/19 0:00	2170.2
12/12/19 0:00	2146.0
12/13/19 0:00	2163.8
12/14/19 0:00	2062.0
12/15/19 0:00	1831.1
12/16/19 0:00	1707.2
12/17/19 0:00	1628.4
12/18/19 0:00	1595.5
12/19/19 0:00	1590.5
12/20/19 0:00	1599.8
12/21/19 0:00	1541.7
12/22/19 0:00	1450.9
12/23/19 0:00	1395.4
12/24/19 0:00	1358.1
12/25/19 0:00	1343.1
12/26/19 0:00	1326.3
12/27/19 0:00	1298.6
12/28/19 0:00	1295.8
12/29/19 0:00	1340.6

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2548	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00163072	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	5.26
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	484		4Q19
---------------------------	------------	--	-------------

fill only these

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-STOP		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	
12/24/19	E.O.	13:37 - 14:07	Bi-Weekly Test	97	805	
1/6/19	KAB	1241 - 1311	Bi-Weekly Test	97	30	
1-20-19	Ry	0825 - 0555	Bi-Weekly Test	98	60	
1-29-19	Ry	1013 - 1043	Bi-Weekly Test	98	90	
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120	
3-11-19	EO.	0724 - 0730	OUTAGE / BLACK PLANT	99	126	
4-29-19	ME	0920 - 0950	TEST / Warm oil for Sines	99	156	
4/29/2019	ME	1202 - 1206	Post Maint Print/TEST	99	160	
7-18-19	Rc	1311 - 1347	TEST-INTELLIGENCE	100	195	
8-22-19	Rc	DIESEL DELIVERY 16.0 GALS				
9-20-19	As	1026 - 1029	TEST RUN	100	198	
9-20-19	B	1416 - 1421	TEST RUN	100	203	
9-20-19	B	1424 - 1434	TEST RUN	100	213	
10-10-19	ME	1100 - 1124	TEST RUN / Troubleshooting	100	237	
10-10-19	ME	1134 - 1144	TEST RUN / Troubleshooting	101	245	
10-10-19	ME	1150 - 1158	TEST RUN / Troubleshooting	101	253	
10-10-19	ME	1206 - 1207	TEST RUN / Troubleshooting	101	254	
10-13-19	KAB	0942 - 0947	WEEKLY TEST RUN	101	259	
10-27-19	Ry		Bi-Weekly Test	102	289	
11-3-19	BP		Bi-Weekly Test - Failed	102	304	
11-10-19	KAB		Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309	
11-24-19	ZHR		Bi-Weekly Test Run - Successful	103	339	
12-8-19	KAB		Bi-Weekly Test Run	103	369	
12-29-19	BP		Bi-Weekly Test 1439 - 1509	104	399	
1/04/20	BH		Bi-Weekly Test 14:16 - 14:49	104	33	
1/6/20	BH		Troubleshoot with CEO / CAT 13:04 - 13:24	104	63	
1/6/20	As	1447 - 1453	TEST RUN	105	69	
1/6/20	As	1512 - 1518	TEST RUN	105	75	
1/7/20	As	1110 - 1112	TEST RUN	105	77	
1/7/20	As	1114 - 1127	TEST RUN	105	90	
1/7/20	As	1153 - 1309	TEST RUN	106	166	
1/7/20	As	1317 - 1330	TEST RUN	106	179	

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	START	Reason	STOP	INITIALS	TOTAL	YTD
11/6/2018	09:49	Inspection/Weekly Test	10:19	ME	146.7	18.7
11-16-18		Cosco Fire caused pump start		DWN	147.0	19.0
11-18-18	1434	Weekly Test	1504	DWN	147.5	19.5
11-25-2018	1430	weekly Test	1500	Ry	148.0	20.0
12-2-18	1608	weekly Test Run	1638	BP	148.5	20.5
12-9-18	14:45	Weekly Test Run	15:50	KAS	149.0	21.0
12-16-18	1200	WEEKLY TEST RUN	1230	B	149.5	21.5
12-24-18	15:39	WEEKLY TEST RUN	16:09	E.O.	150.0	22.0
12-30-18	13:49	WEEKLY TEST RUN		E.O.	150.5	22.5

2019

1-6-19	1348	WEEKLY TEST RUN	1418	VAB	151	0.5
1-13-19	1339	WEEKLY TEST RUN	1409	AB	151.5	1.0
1-20-19	1027	Weekly Test	1057	Ry	152	1.5
1-27-19	1211	WEEKLY TEST	1241	VAB	152.5	2.0
1-29-19	1029	Weekly Test	1059	Ry	153.0	2.5
2-10-19	1522	Weekly Test	1552	ME	153.5	3.0
2-17-19	1500	Weekly Test	1530	Ry	154.0	3.5
2-24-19	1630	weekly test	1700	BP	154.5	4.0
3-10-19	1535	WEEKLY TEST	1605	RC	155.0	4.5
3-17-19	1412	Weekly Test	1442	Ry	155.5	5.0
3-24-19	1235	Weekly Test	1305	KAS	156.0	5.5
3-30-19	1646	WEEKLY TEST RUN	1716	VAB	156.5	6.0
4-7-19	1530	WEEKLY TEST RUN	1600	RC	157.0	6.5
4-14-19	1412	Weekly Test Run	1442	Ry	157.5	7.0
4-21-19	1448	Weekly Test Run	1518	ME	158.0	7.5
4-28-19	1357	Weekly Test Run	1427	ME	158.5	8.0
4-29-19	1043	Post Maint Drive	1045	ME	158.5	8.0
5/5/19	1436	WEEKLY TEST RUN	1500	RC	159.0	8.5
5/6/19	1325	MAINTENANCE PM	1330	RC	159.1	8.6
5/7/19	1131	TEST RUN AFTER REPAIR	1133	B	159.1	8.6
5-12-19	1120	Weekly Test	1150	Ry	159.6	9.1
5-19-19	1108	Weekly Test	1138	BP	160.1	9.6
5/26/19	1324	Weekly Test	1354	ME	160.6	10.1
6-2-19	1220	WEEKLY TEST	1250	RC	161.1	10.6

DATE	START	Reason	STOP	INITIALS	TOTAL	YTD
6-09-2019	1320	weekly Test	1350	Ry	161.6	11.1
6-15-2019	1611	Weekly Test	1641	ME	162.1	11.6
6-22-2019	1630	Weekly Test	1700	ME	162.6	12.1
6-30-2019	1020	WEEKLY TEST	1050	RC	163.1	12.6
7-7-2019	1128	Weekly Test	1158	Ry	163.6	13.1
7-14-2019	1450	Weekly Test	1520	BP	164.1	13.6
7-20-2019	1332	Weekly test	1402	BP	164.6	14.1
7-29-2019	1630	WEEKLY TEST	1700	EO.	165.1	14.6
08-04-2019	1115	weekly Test	1145	Ry	165.6	15.1
8-11-19	1910	WEEKLY TEST	1940	RC	166.1	15.6
8-18-19	1535	WEEKLY TEST	1565	RC	166.6	16.1
8-22-19	DIESEL DELIVERY	60.0 GALLONS		RC		
8-25-19	1620	WEEKLY TEST	1650	RC	167.1	16.6
9-1-19	1602	WEEKLY TEST	1632	EO.	167.6	17.1
9-8-19	1545	Weekly Test	16:15	JAS	168.1	17.6
9-15-19	1625	WEEKLY TEST	1655	RC	168.6	18.1
9-22-19	1515	Weekly Test	1545	DWN	169.1	18.6
10-6-19	1210	Weekly test	1240	BP	169.6	19.1
10-13-19	1043	Weekly Test	1113	ME	170.1	19.6
10-20-19	1425	WEEKLY TEST	1455	RC	170.6	20.1
10-27-19	1330	Weekly Test	1400	Ry	171.1	20.6
11-3-19	1351	weekly Test	1421	BP	171.6	21.1
11-11-19	1307	WEEKLY TEST	1327	VAB	172.1	21.6
11-17-19	1402	WEEKLY TEST	1432	RC	172.6	22.1
11-24-19	1345	Weekly Test	1415	ZAR	173.1	22.6
12/5/19	1331	WEEKLY TEST	1401	SH	173.6	23.1
12-8-19	1416	WEEKLY TEST	1446	VAB	174.1	23.6
12-15-19	1350	Weekly Test	1420	DWN	174.6	24.1
12-17-19	1430	Cosco Deluge Tests	1530	ZAR	175.1	24.6
12-22-19	1350	Weekly Test	1420	ZAR	175.6	25.1
12-29-19	1554	weekly test	1624	BP	176.1	25.6

20 20

1-5-20	1531	Weekly Test	1601	ME	176.6	0.5
--------	------	-------------	------	----	-------	-----

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-STOP		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	
12/24/19	E.O.	13:37 - 14:07	Bi-Weekly Test	97	805	
1/6/19	LAB	1241 - 1311	Bi-Weekly Test	97	30	
1-20-19	Ry	0825 - 0555	Bi-Weekly Test	98	60	
1-29-19	Ry	1013 - 1043	Bi-Weekly Test	98	90	
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120	
3-11-19	EO.	0724 - 0730	OUTAGE / BLACK PLANT	99	126	
4-29-19	ME	0920 - 0950	TEST / Warm oil for Sine	99	156	
4/29/2019	ME	1202 - 1206	Post Maint Print/TEST	99	160	
7-18-19	Rc	1311 - 1347	TEST-INTELLIGENCE	100	195	
8-22-19	Rc	DIESEL DELIVERY 16.0 GALS				
9-20-19	As	1026 - 1029	TEST RUN	100	198	
9-20-19	B	1416 - 1421	TEST RUN	100	203	
9-20-19	B	1424 - 1434	TEST RUN	100	213	
10-10-19	ME	1100 - 1124	TEST RUN / Trouble Shooting	100	237	
10-10-19	ME	1134 - 1144	TEST RUN / Trouble Shooting	101	245	
10-10-19	ME	1150 - 1158	TEST RUN / Trouble Shooting	101	253	
10-10-19	ME	1206 - 1207	TEST RUN / Trouble Shooting	101	254	
10-13-19	LAB	0942 - 0947	WEEKLY TEST RUN	101	259	
10-27-19	Ry	Bi-Weekly Test		102	289	
11-3-19	BP	Bi-Weekly Test - Failed		102	304	
11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN		102	309	
11-24-19	ZUR	Bi-Weekly Test Run - Successful		103	339	
12-8-19	LAB	Bi-Weekly Test Run		103	369	
12-29-19	BP	Bi-Weekly Test 1439 - 1509		104	399	
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49		104	33	
1/6/20	BH	Troubleshooting with CEO / CAT 13:04		104	63	
1/6/20	As	1447 - 1453	TEST RUN	105	69	
1/6/20	As	1512 - 1518	TEST RUN	105	75	
1/7/20	As	1110 - 1112	TEST RUN	105	77	
1/7/20	As	1114 - 1127	TEST RUN	105	90	
1/7/20	As	1153 - 1309	TEST RUN	106	166	
1/7/20	As	1317 - 1330	TEST RUN	106	179	

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-STOP		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	
12/24/19	E.O.	13:37 - 14:07	Bi-Weekly Test	97	805	
1/6/19	KAB	1241 - 1311	Bi-Weekly Test	97	30	
1-20-19	Ry	0825 - 0555	Bi-Weekly Test	98	60	
1-29-19	Ry	1013 - 1043	Bi-Weekly Test	98	90	
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120	
3-11-19	EO.	0724 - 0730	OUTAGE / BLACK PLANT	99	126	
4-29-19	ME	0920 - 0950	TEST / Warm oil for Sines	99	156	
4/29/2019	ME	1202 - 1206	Post Maint Print/TEST	99	160	
7-18-19	Rc	1311 - 1347	TEST-INTELLIGENCE	100	195	
8-22-19	Rc	DIESEL DELIVERY 16.0 GALS				
9-20-19	As	1026 - 1029	TEST RUN	100	198	
9-20-19	B	1416 - 1421	TEST RUN	100	203	
9-20-19	B	1424 - 1434	TEST RUN	100	213	
10-10-19	ME	1100 - 1124	TEST RUN / Trouble Shooting	100	237	
10-10-19	ME	1134 - 1144	TEST RUN / Trouble Shooting	101	245	
10-10-19	ME	1150 - 1158	TEST RUN / Trouble Shooting	101	253	
10-10-19	ME	1206 - 1207	TEST RUN / Trouble Shooting	101	254	
10-13-19	KAB	0942 - 0947	WEEKLY TEST RUN	101	259	
10-27-19	Ry		Bi-Weekly Test	102	289	
11-3-19	BP		Bi-Weekly Test - Failed	102	304	
11-10-19	KAB		Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309	
11-24-19	ZHR		Bi-Weekly Test Run - Successful	103	339	
12-8-19	KAB		Bi-Weekly Test Run	103	369	
12-29-19	BP		Bi-Weekly Test 1439 - 1509	104	399	
1/04/20	BH		Bi-Weekly Test 14:16 - 14:49	104	33	
1/6/20	BH		Troubleshooting with CEO / CAT 13:04 - 13:24	104	63	
1/6/20	As	1447 - 1453	TEST RUN	105	69	
1/6/20	As	1512 - 1518	TEST RUN	105	75	
1/7/20	As	1110 - 1112	TEST RUN	105	77	
1/7/20	As	1114 - 1127	TEST RUN	105	90	
1/7/20	As	1153 - 1309	TEST RUN	106	166	
1/7/20	As	1317 - 1330	TEST RUN	106	179	

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	TECH	TIME START-STOP		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	
12/24/19	E.O.	13:37 - 14:07	Bi-Weekly Test	97	805	
1/6/19	KAB	1241 - 1311	Bi-Weekly Test	97	30	
1-20-19	Ry	0825 - 0555	Bi-Weekly Test	98	60	
1-29-19	Ry	1013 - 1043	Bi-Weekly Test	98	90	
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120	
3-11-19	EO.	0724 - 0730	OUTAGE / BLACK PLANT	99	126	
4-29-19	ME	0920 - 0950	TEST / Warm oil for Sines	99	156	
4/29/2019	ME	1202 - 1206	Post Maint Print/TEST	99	160	
7-18-19	Rc	1311 - 1347	TEST-INTELLIGENCE	100	195	
8-22-19	Rc	DIESEL DELIVERY 16.0 GALS				
9-20-19	As	1026 - 1029	TEST RUN	100	198	
9-20-19	B	1416 - 1421	TEST RUN	100	203	
9-20-19	B	1424 - 1434	TEST RUN	100	213	
10-10-19	ME	1100 - 1124	TEST RUN / Trouble Shooting	100	237	
10-10-19	ME	1134 - 1144	TEST RUN / Trouble Shooting	101	245	
10-10-19	ME	1150 - 1158	TEST RUN / Trouble Shooting	101	253	
10-10-19	ME	1206 - 1207	TEST RUN / Trouble Shooting	101	254	
10-13-19	KAB	0942 - 0947	WEEKLY TEST RUN	101	259	
10-27-19	Ry		Bi-Weekly Test	102	289	
11-3-19	BP		Bi-Weekly Test - Failed	102	304	
11-10-19	KAB		Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309	
11-24-19	ZUR		Bi-Weekly Test Run - Successful	103	339	
12-8-19	KAB		Bi-Weekly Test Run	103	369	
12-29-19	BP		Bi-Weekly Test 1439 - 1509	104	399	
1/04/20	BH		Bi-Weekly Test 14:16 - 14:49	104	33	
1/6/20	BH		Troubleshooting with CEO / CAT 13:04 - 13:24	104	63	
1/6/20	As	1447 - 1453	TEST RUN	105	69	
1/6/20	As	1512 - 1518	TEST RUN	105	75	
1/7/20	As	1110 - 1112	TEST RUN	105	77	
1/7/20	As	1114 - 1127	TEST RUN	105	90	
1/7/20	As	1153 - 1309	TEST RUN	106	166	
1/7/20	As	1317 - 1330	TEST RUN	106	179	

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-STOP		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	
12/24/19	E.O.	13:37 - 14:07	Bi-Weekly Test	97	805	
1/6/19	KAB	1241 - 1311	Bi-Weekly Test	97	30	
1-20-19	Ry	0825 - 0555	Bi-Weekly Test	98	60	
1-29-19	Ry	1013 - 1043	Bi-Weekly Test	98	90	
2-17-19	Ry	1035 - 1105	Bi-Weekly Test	99	120	
3-11-19	EO.	0724 - 0730	OUTAGE / BLACK PLANT	99	126	
4-29-19	ME	0920 - 0950	TEST / Warm oil for Sines	99	156	
4/29/2019	ME	1202 - 1206	Post Maint Print/TEST	99	160	
7-18-19	Rc	1311 - 1347	TEST-INTELLIGENCE	100	195	
8-22-19	Rc	DIESEL DELIVERY 16.0 GALS				
9-20-19	As	1026 - 1029	TEST RUN	100	198	
9-20-19	B	1416 - 1421	TEST RUN	100	203	
9-20-19	B	1424 - 1434	TEST RUN	100	213	
10-10-19	ME	1100 - 1124	TEST RUN / Troubleshooting	100	237	
10-10-19	ME	1134 - 1144	TEST RUN / Troubleshooting	101	245	
10-10-19	ME	1150 - 1158	TEST RUN / Troubleshooting	101	253	
10-10-19	ME	1206 - 1207	TEST RUN / Troubleshooting	101	254	
10-13-19	KAB	0942 - 0947	WEEKLY TEST RUN	101	259	
10-27-19	Ry		Bi-Weekly Test	102	289	
11-3-19	BP		Bi-Weekly Test - Failed	102	304	
11-10-19	KAB		Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309	
11-24-19	ZHR		Bi-Weekly Test Run - Successful	103	339	
12-8-19	KAB		Bi-Weekly Test Run	103	369	
12-29-19	BP		Bi-Weekly Test 1439 - 1509	104	399	
1/04/20	BH		Bi-Weekly Test 14:16 - 14:49	104	33	
1/6/20	BH		Troubleshoot with CEO / CAT 13:04 - 13:24	104	63	
1/6/20	As	1447 - 1453	TEST RUN	105	69	
1/6/20	As	1512 - 1518	TEST RUN	105	75	
1/7/20	As	1110 - 1112	TEST RUN	105	77	
1/7/20	As	1114 - 1127	TEST RUN	105	90	
1/7/20	As	1153 - 1309	TEST RUN	106	166	
1/7/20	As	1317 - 1330	TEST RUN	106	179	

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 4Q19 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.