DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	232806
Document Title:	Quarterly Operating Report
Description:	1st Quarter 2020 Operating Report
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	4/21/2020 12:30:11 PM
Docketed Date:	4/21/2020

ATTACHMENT 1
Complaints
FCD: AQ-5
Title V: #5

During the first quarter of 2020, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD and the CEC.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

2020 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20	Avg
Gr/100SCF	0.251	0.229	0.192										0.224

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 200050
REPORT DATE	: 01/16/2020

On January 10, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-JAN-A	200050-4725	712.5

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 4 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 01/09/2020**
PROJECT NO.	**: 200050**	**RECEIVING DATE**	**: 01/10/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 01/13/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 01/16/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-JAN-A**
AAC ID	**200050-4725**
Canister Dil. Fac.	**3.2**
Analyte	**Result**
Hydrogen Sulfide	**0.727**
COS / SO2	**0.443**
Methyl Mercaptan	**0.167**
Ethyl Mercaptan	< 0.159
Dimethyl Sulfide	< 0.159
Carbon Disulfide	< 0.159
Isopropyl Mercaptan	< 0.159
tert-Butyl Mercaptan	**0.736**
n-Propyl Mercaptan	< 0.159
Methylethylsulfide	< 0.159
sec-Butyl Mercaptan / Thiophene	< 0.159
iso-Butyl Mercaptan	< 0.159
Diethyl Sulfide	< 0.159
n-Butyl Mercaptan	< 0.159
Dimethyl Disulfide	< 0.159
2-Methylthiophene	< 0.159
3-Methylthiophene	< 0.159
Tetrahydrothiophene	**0.883**
Bromothiophene	< 0.159
Thiophenol	< 0.159
Diethyl Disulfide	< 0.159
Total Unidentified Sulfur	< 0.159
Total Reduced Sulfurs	**2.51**
Total Sulfurs	**2.96**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 1/13/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 1/8/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5372	533	101.9	4.3
Duplicate	5036	499	95.5	2.2
Triplicate	5043	500	95.6	2.1

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6095	532	97.2	1.4
Duplicate	6393	558	101.9	3.4
Triplicate	6054	528	96.5	2.0

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6790	540	100.9	1.0
Duplicate	7018	559	104.2	2.3
Triplicate	6777	539	100.7	1.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 200050-4725

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	0.2	0.2	0.2	0.7
MeSH	0.1	0.1	0.1	1.6
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 200050-4725 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	0.0	261.5	261.9	265.7	100.1	101.6	1.4
MeSH	0.0	273.8	274.8	284.6	100.4	103.9	3.5
DMS	<PQL	267.9	272.2	275.5	101.6	102.8	1.2

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	559.7	107.0
MeSH	547.5	554.8	101.3
DMS	535.8	542.6	101.3

Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, * Must be < 5% RPD from Mean result.***

H2S: PQL = 10.0 ppbV, MDL = 0.95 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.40 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.46 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200050

SAM #

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 1/9/20
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon / State: CA / Zip: 94583	Site Contacat:		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003		

Preparation and Analysis

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-JAN-A 4725		1/9/20	1320	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North [signature] (via UPS)	Date: 1/9/20	Time: 1600	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By: Rudy [signature]	Date: 1/10/20	Time: 1004

Comments

UPS 1x LOL.com

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Nat'l Gas Sampling
AAC PROJECT NO.	: 200089
REPORT DATE	: 01/24/2020

On January 16, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) Tedlar Bag for BTU analysis by ASTM D-3588. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.
CPP-GS-JAN-1	200089-4863

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. The sample was transferred from a cylinder into a Tedlar Bag at ATS for transport on 01/15/2020. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data contained in this hardcopy report.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 200089

SAMPLING DATE : 01/09/2020
ANALYSIS DATE : 01/16-17/2020

	Client ID:	CPP-GS-JAN-1	
	AAC ID:	200089-4863	
	Component	Mole %	Weight %
FIXED GASES	H_2	0.00	0.00
	Ar/O_2	0.52	0.96
	N_2	2.32	3.75
	CO	0.00	0.00
	CO_2	0.81	2.04
	CH_4	91.67	84.72
	He	NM	NM
HYDROCARBONS	C_2 (as Ethane)	4.2847	7.4221
	C_3 (as Propane)	0.2973	0.7551
	C_4 (as Butane)	0.0742	0.2483
	C_5 (as Pentane)	0.0137	0.0570
	C_6 (as Hexane)	0.0030	0.0148
	C_{6+} (as Hexane)	0.0059	0.0294
TRS	TRS as H2S	NM	NM
H2O	Moisture content	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications			
Atomic Breakdown - (scf/lb) / %		*HHV Btu/lb*	22137
Carbon (C)	70.8	*LHV Btu/lb*	19953
Hydrogen (H)	23.0	*HHV Btu/dscf*	1013
Oxygen (O)	2.4	*LHV Btu/dscf*	913
Nitrogen (N)	3.7	*F-Factor*	8647
Helium (He)	0.00	*Relative Density*	0.5994
Argon (Ar)	0.00	*C2-C6+ Weight %*	8.5267
Sulfur (S)	0.00	*MW lb/lb-mole*	17.359
Motor Octane Number	129.58	*Methane Number*	91.33

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 01/16/2020
Analyst : ZB
Units : %

Instrument ID : GC-BTU-TCD
Calb Date : 06/26/19
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H2	O2	N2	CO	CH4	CO2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.7	10.7	20.7	10.1	10.0	10.1
	% Rec *	97.4	102.9	102.5	100.8	100.4	101.2

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H2	O2	N2	CH4	CO	CO2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H2	O2	N2	CO	CH4	CO2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	LCS Result	9.5	10.6	20.4	10.0	9.9	10.0
	LCSD Result	9.4	10.5	20.2	10.0	9.9	10.0
	LCS % Rec *	95.6	101.8	101.1	100.0	99.6	100.2
	LCSD % Rec *	94.8	101.1	100.4	99.6	99.2	99.9
	% RPD ***	0.9	0.6	0.8	0.4	0.4	0.2

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H2	O2	N2	CO	CH4	CO2
200041-4697	Sample	0.0	0.2	0.8	0.0	42.3	26.2
	Sample Dup	0.0	0.2	0.8	0.0	42.2	26.1
	Mean	0.0	0.2	0.8	0.0	42.2	26.2
	% RPD ***	0.0	1.6	1.7	0.0	0.3	0.3

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N2	CO	CH4	CO2
200041-4697	Sample Conc	0.0	0.4	0.0	21.1	13.1
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.0	10.6	10.4	31.4	23.0
	MSD Result	9.8	10.4	10.2	31.4	23.0
	MS % Rec **	100.5	100.9	103.9	103.0	99.6
	MSD % Rec **	98.8	98.6	102.3	102.6	99.4
	% RPD ***	1.7	2.3	1.5	0.4	0.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H2	O2	N2	CO	CH4	CO2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.3	10.5	20.2	9.9	9.9	9.9
	% Rec *	93.9	100.9	100.3	99.0	98.7	99.1

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 01/17/2020
Analyst : DL/CH
Units : ppmv

Instrument ID : FID #3
Calb Date : 08/13/19
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	110.8	113.2	114.3	113.8	113.0	109.4
	% Rec *	111.1	113.0	114.4	114.0	113.0	109.2

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	LCS Result	106.7	110.1	108.7	107.5	107.5	103.7
	LCSD Result	107.4	110.6	109.3	107.9	108.5	104.6
	LCS % Rec *	107.0	110.0	108.8	107.7	107.6	103.5
	LCSD % Rec *	107.8	110.4	109.4	108.1	108.6	104.4
	% RPD ***	0.7	0.4	0.5	0.4	0.9	0.9

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200063-4780	Sample	0.2	0.0	0.0	0.0	0.0	0.0
	Sample Dup	0.2	0.0	0.0	0.0	0.0	0.0
	Mean	0.2	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.4	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200063-4780	Sample Conc	0.1	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.8	50.1	50.0	49.9	50.0	50.1
	MS Result	59.0	59.4	59.7	59.6	59.3	59.1
	MSD Result	59.5	61.0	60.3	59.7	60.1	59.2
	MS % Rec **	118.2	118.6	119.6	119.4	118.7	117.9
	MSD % Rec **	119.2	121.8	120.6	119.7	120.3	118.2
	% RPD ***	0.9	2.7	0.8	0.2	1.3	0.3

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	107.3	110.9	107.8	107.6	107.7	102.7
	% Rec *	107.6	110.8	107.9	107.8	107.7	102.5

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200089

Chain of Custody Record

Pacific Gas and Electric Company

SAM # ATS

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Client: PG&E Applied technical Services		Project Manager: Surinder Sidhu		Date:
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Nat'l Gas Sampling		Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number		Laboratory Contact		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	BTU	Preparation and Analysis
CPP-GS-SAM-1		1/9/20	1310	Gas	500cc	cyl	1	None	Line pressure		4863
				Gas	1L	bag	1	None		X	

Special Instruction: Sample transfer to Tedlar bag by ATS on 1/15/2020

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (Cell/lab)	Date: 1/10/20	Time: 1500	1. Received By	Date: 1/10/20	Time: 15:40
2. Relinquished By	Date: 1/15/20	Time: 10:30	2. Received By	Date: 1/16/20	Time: 1338
3. Relinquished By	Date:	Time:	3. Received By	Date:	Time:

Comments: Gas transferred from SS Cyl to 1L Tedlar bag at ATS for transport to AAC (date/time recorded above)

350

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 200193
REPORT DATE	: 02/11/2020

On February 5, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-FEB-A	200193-5377	707.0

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 02/04/2020**
PROJECT NO.	**: 200193**	**RECEIVING DATE**	**: 02/05/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 02/10/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 02/11/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-FEB-A**
AAC ID	**200193-5377**
Canister Dil. Fac.	**2.4**
Analyte	**Result**
Hydrogen Sulfide	**0.870**
COS / SO2	**0.642**
Methyl Mercaptan	**0.227**
Ethyl Mercaptan	**0.121**
Dimethyl Sulfide	< 0.121
Carbon Disulfide	< 0.121
Isopropyl Mercaptan	< 0.121
tert-Butyl Mercaptan	**0.805**
n-Propyl Mercaptan	< 0.121
Methylethylsulfide	< 0.121
sec-Butyl Mercaptan / Thiophene	< 0.121
iso-Butyl Mercaptan	< 0.121
Diethyl Sulfide	< 0.121
n-Butyl Mercaptan	< 0.121
Dimethyl Disulfide	< 0.121
2-Methylthiophene	< 0.121
3-Methylthiophene	< 0.121
Tetrahydrothiophene	**0.926**
Bromothiophene	< 0.121
Thiophenol	< 0.121
Diethyl Disulfide	< 0.121
Total Unidentified Sulfur	**0.180**
Total Reduced Sulfurs	**3.13**
Total Sulfurs	**3.77**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : **PG&E**
PROJECT NO. : **200193**
MATRIX : **AIR**
UNITS : **grains/100 dscf**

SAMPLING DATE : **02/04/2020**
RECEIVING DATE : **02/05/2020**
ANALYSIS DATE : **02/10/2020**
REPORT DATE : **02/11/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-FEB-A**
AAC ID	**200193-5377**
Canister Dil. Fac.	**2.4**
Analyte	**Result**
Hydrogen Sulfide	**0.05300**
COS / SO2	**0.03912**
Methyl Mercaptan	**0.01384**
Ethyl Mercaptan	**0.00739**
Dimethyl Sulfide	< 0.00738
Carbon Disulfide	< 0.00738
Isopropyl Mercaptan	< 0.00738
tert-Butyl Mercaptan	**0.04901**
n-Propyl Mercaptan	< 0.00738
Methylethylsulfide	< 0.00738
sec-Butyl Mercaptan / Thiophene	< 0.00738
iso-Butyl Mercaptan	< 0.00738
Diethyl Sulfide	< 0.00738
n-Butyl Mercaptan	< 0.00738
Dimethyl Disulfide	< 0.00738
2-Methylthiophene	< 0.00738
3-Methylthiophene	< 0.00738
Tetrahydrothiophene	**0.05638**
Bromothiophene	< 0.00738
Thiophenol	< 0.00738
Diethyl Disulfide	< 0.00738
Total Unidentified Sulfur	**0.01094**
Total Reduced Sulfurs	**0.19056**
Total Sulfurs	**0.22969**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 2/10/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 1/8/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5074	503	96.2	0.9
Duplicate	5093	505	96.6	0.5
Triplicate	5193	515	98.5	1.4

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6202	541	98.9	1.0
Duplicate	6353	555	101.3	1.4
Triplicate	6236	544	99.4	0.4

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6762	538	100.4	0.2
Duplicate	6741	536	100.1	0.1
Triplicate	6749	537	100.3	0.0

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 200206-5431

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate Sample ID 200206-5431 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	261.5	241.7	238.3	92.4	91.1	1.4
MeSH	<PQL	273.8	270.2	276.5	98.7	101.0	2.3
DMS	<PQL	267.9	278.2	282.4	103.9	105.4	1.5

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	544.7	104.1
MeSH	547.5	563.4	102.9
DMS	535.8	536.8	100.2

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200193

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu				Date: 2/4/20			
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com			Laboratory: AAC Labs			
City: San Ramon	State: CA	Zip: 94583	Site Contacat				Laboratory Phone: 805-650-1642			
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039				Laboratory Fax			
Contract Number, PO Number			Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003							
PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-FEB-A		2/4/20	1545	Gas	1 liter	cyl	1	None	5377	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via UPS)	Date: 2/4/20	Time: 1600	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 2/5/20	Time: 1135

Comments

UPS 1x 1.0 L can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Nat'l Gas Sampling
AAC PROJECT NO.	: 200233
REPORT DATE	: 02/17/2020

On February 11, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) Tedlar Bag for BTU analysis by ASTM D-3588. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.
CPP-GS-FEB-1	200233-5567

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. Sample was transferred to a Tedlar Bag by ATS on February 10, 2020. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 200233
SAMPLING DATE : 02/04/2020
ANALYSIS DATE : 02/11-12/2020

	Client ID:	CPP-GS-FEB-1	
	AAC ID:	200233-5567	
	Component	Mole %	Weight %
FIXED GASES	H_2	0.00	0.00
	O_2	0.18	0.34
	N_2	1.23	2.00
	CO	0.00	0.00
	CO_2	0.59	1.50
	CH_4	92.84	86.64
	He	NM	NM
	Ar	0.00	0.00
HYDROCARBONS	C_2 (as Ethane)	4.6916	8.2068
	C_3 (as Propane)	0.3786	0.9713
	C_4 (as Butane)	0.0754	0.2549
	C_5 (as Pentane)	0.0118	0.0495
	C_6 (as Hexane)	0.0024	0.0120
	C_{6+} (as Hexane)	0.0041	0.0206
TRS	TRS as H2S	NM	NM
H2O	Moisture content	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications				
Atomic Breakdown - (scf/lb) / %			*HHV Btu/lb*	22815
Carbon (C)	72.9		*LHV Btu/lb*	20566
Hydrogen (H)	23.7		*HHV Btu/dscf*	1033
Oxygen (O)	1.4		*LHV Btu/dscf*	932
Nitrogen (N)	2.0		*F-Factor*	8648
Helium (He)	0.00		*Relative Density*	0.5936
Argon (Ar)	0.00		*C2-C6+ Weight %*	9.5150
Sulfur (S)	0.00		*MW lb/lb-mole*	17.190
Motor Octane Number	129.60		*Methane Number*	91.38

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 02/11/2020
Analyst : CH
Units : %

Instrument ID : TCD #1
Calb Date : 09/27/19
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.5	11.0	22.5	10.0	10.0	9.7
	% Rec *	95.7	105.5	111.8	100.5	99.5	97.6

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	LCS Result	9.6	10.6	21.4	10.0	10.0	9.9
	LCSD Result	10.2	10.6	21.2	10.1	10.0	9.9
	LCS % Rec *	97.3	102.2	106.3	100.3	99.6	98.8
	LCSD % Rec *	102.4	101.6	105.1	101.1	100.1	99.0
	% RPD ***	5.1	0.6	1.1	0.7	0.5	0.2

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
200197-5397	Sample	0.0	12.7	59.5	0.0	0.0	1.7
	Sample Dup	0.0	12.8	60.1	0.0	0.0	1.7
	Mean	0.0	12.7	59.8	0.0	0.0	1.7
	% RPD ***	0.0	0.9	0.9	6.5	0.0	1.7

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
200197-5397	Sample Conc	0.0	29.9	0.0	0.0	0.8
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.1	39.2	10.3	10.2	10.6
	MSD Result	10.1	39.2	10.3	10.3	10.7
	MS % Rec **	102.0	91.8	102.7	102.0	97.6
	MSD % Rec **	102.4	92.2	103.2	102.6	99.0
	% RPD ***	0.3	0.4	0.5	0.5	1.4

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	9.8	10.9	22.5	10.0	9.9	9.6
	% Rec *	98.6	104.4	111.4	99.7	99.0	96.6

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 02/12/2020
Analyst : DL/CH
Units : ppmv

Instrument ID : FID #3
Calb Date : 08/13/19
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	102.1	104.6	102.6	102.2	102.1	98.1
	% Rec *	102.4	104.5	102.7	102.4	102.1	97.9

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	LCS Result	104.2	107.1	105.7	104.2	104.3	100.4
	LCSD Result	105.2	108.0	106.1	105.4	105.8	101.1
	LCS % Rec *	104.5	106.9	105.8	104.4	104.3	100.2
	LCSD % Rec *	105.5	107.8	106.2	105.6	105.9	100.9
	% RPD ***	0.9	0.8	0.4	1.2	1.5	0.7

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200207-5433	Sample	1.4	0.0	0.0	0.0	0.0	0.0
	Sample Dup	1.4	0.0	0.0	0.0	0.0	0.0
	Mean	1.4	0.0	0.0	0.0	0.0	0.0
	% RPD ***	1.3	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200207-5433	Sample Conc	0.7	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.8	50.1	50.0	49.9	50.0	50.1
	MS Result	51.2	51.6	50.3	49.6	49.7	48.5
	MSD Result	58.3	58.7	57.3	56.5	56.5	54.8
	MS % Rec **	101.2	103.1	100.6	99.3	99.4	96.8
	MSD % Rec **	115.5	117.3	114.8	113.3	113.0	109.4
	% RPD ***	13.2	12.9	13.1	13.1	12.9	12.2

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	99.8	102.3	100.3	99.5	99.7	96.0
	% Rec *	100.1	102.2	100.4	99.7	99.8	95.8

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Chain of Custody Record

Pacific Gas and Electric Company

200233

SAM # ATS

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Client: PG&E Applied technical Services	Project Manager: Surinder Sidhu		Date: 2/5/20	Preparation and Analysis
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC	
City: San Ramon / State: CA / Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642	
Project Number/Name: Nat'l Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax	
Contract Number, PO Number	Laboratory Contact			

556 PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	BTU
GPP-GS-FEB-1		2/4/20	1535	Gas	500cc	cyl	1	None	Line pressure	
				Gas	1L	bag	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM) Sample was transfer to Tedlar bag by ATS on 02/10/2020.

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

	Relinquished By	Date	Time	Received By	Date	Time
1.	Steve North (self/lab)	2/5/20	1430	1.	2/5/20	14:32
2.		2/10/20	9:45AM	2.	2/11/20	1345
3.		Date	Time	3.	Date	Time

Comments: Gas transferred from SS Cyl to 1L Tedlar bag at ATS for transport to AAC (date/time recorded above)

GS

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 200398
REPORT DATE	: 03/25/2020

On March 6, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-MAR-A	200398-6353	688.9

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 03/04/2020**
PROJECT NO.	**: 200398**	**RECEIVING DATE**	**: 03/06/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 03/09/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 03/25/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-MAR-A**
AAC ID	**200398-6353**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.949**
COS / SO2	**0.585**
Methyl Mercaptan	< 0.113
Ethyl Mercaptan	< 0.113
Dimethyl Sulfide	< 0.113
Carbon Disulfide	< 0.113
Isopropyl Mercaptan	< 0.113
tert-Butyl Mercaptan	**0.597**
n-Propyl Mercaptan	< 0.113
Methylethylsulfide	< 0.113
sec-Butyl Mercaptan / Thiophene	< 0.113
iso-Butyl Mercaptan	< 0.113
Diethyl Sulfide	< 0.113
n-Butyl Mercaptan	< 0.113
Dimethyl Disulfide	< 0.113
2-Methylthiophene	< 0.113
3-Methylthiophene	< 0.113
Tetrahydrothiophene	**1.03**
Bromothiophene	< 0.113
Thiophenol	< 0.113
Diethyl Disulfide	< 0.113
Total Unidentified Sulfur	< 0.113
Total Reduced Sulfurs	**2.58**
Total Sulfurs	**3.16**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 03/04/2020**
PROJECT NO.	**: 200398**	**RECEIVING DATE**	**: 03/06/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 03/09/2020**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 03/25/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-MAR-A**
AAC ID	**200398-6353**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	**0.05780**
COS / SO2	**0.03565**
Methyl Mercaptan	< 0.00690
Ethyl Mercaptan	< 0.00690
Dimethyl Sulfide	< 0.00690
Carbon Disulfide	< 0.00690
Isopropyl Mercaptan	< 0.00690
tert-Butyl Mercaptan	**0.03635**
n-Propyl Mercaptan	< 0.00690
Methylethylsulfide	< 0.00690
sec-Butyl Mercaptan / Thiophene	< 0.00690
iso-Butyl Mercaptan	< 0.00690
Diethyl Sulfide	< 0.00690
n-Butyl Mercaptan	< 0.00690
Dimethyl Disulfide	< 0.00690
2-Methylthiophene	< 0.00690
3-Methylthiophene	< 0.00690
Tetrahydrothiophene	**0.06294**
Bromothiophene	< 0.00690
Thiophenol	< 0.00690
Diethyl Disulfide	< 0.00690
Total Unidentified Sulfur	< 0.00690
Total Reduced Sulfurs	**0.15708**
Total Sulfurs	**0.19272**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 3/9/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 3/9/2020

Opening Calibration Verification Standard

523.0 ppbV H2S (SS1192)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4635	513	98.0	0.8
Duplicate	4653	515	98.4	0.4
Triplicate	4728	523	100.0	1.2

547.5 ppbV H2S (SS1192)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5808	538	98.3	0.0
Duplicate	5806	538	98.3	0.0
Triplicate	5809	538	98.3	0.0

535.8 ppbV H2S (SS1192)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6655	540	100.8	0.2
Duplicate	6659	540	100.9	0.2
Triplicate	6615	537	100.2	0.4

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 200399-6354

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	277.9	283.8	280.8	2.1
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 200399-6354 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	28.1	261.5	275.4	293.8	95.1	101.5	6.5
MeSH	<PQL	273.8	263.9	276.2	96.4	100.9	4.6
DMS	<PQL	267.9	270.3	273.1	100.9	101.9	1.0

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	523.0	549.3	105.0
MeSH	547.5	547.4	100.0
DMS	535.8	541.7	101.1

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, PhD
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200398

SAM #										Preparation and Analysis
Client: PG&E Environmental Services			Project Manager: Surinder Sidhu				Date: 3/5/20			
Address: 3400 Crow Canyon Road			Telephone Number: 925-866-5245	Email: SKSG@pge.com			Laboratory: AAC Labs			
City: San Ramon	State: CA	Zip: 94583	Site Contacat:				Laboratory Phone: 805-650-1642			
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039				Laboratory Fax:			
Contract Number, PO Number:			Laboratory Contact: Marcus Hueppe - 1534 Eastman Ave. Suite A Ventura CA 93003							

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS-MAR-A		3/4/20	1440	Gas	1 liter	cyl	1	None	6353	X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO)	Date: 3/5/20	Time: 11:00	1. Received By		Date	Time
2. Relinquished By	Date	Time	2. Received By		Date	Time
3. Relinquished By	Date	Time	3. Received By		Date: 3/6/20	Time: 1420

Comments

1.0L 1x Can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Nat'l Gas Sampling
AAC PROJECT NO.	: 200414
REPORT DATE	: 03/20/2020

On March 10, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) Tedlar Bag for BTU analysis by ASTM D-3588. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.
CPP-GS-MAR-1	200414-6393

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. The sample was transferred to a Tedlar Bag by ATS on March 9, 2020. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report
ASTM-D3588 (BTU and F-Factor)

CLIENT : PG&E
PROJECT NO. : 200414

SAMPLING DATE : 03/04/2020
ANALYSIS DATE : 03/10/2020

	Client ID:	CPP-GS-MAR-1	
	AAC ID:	200414-6393	
	Component	Mole %	Weight %
FIXED GASES	H_2	0.00	0.00
	O_2	0.46	0.86
	N_2	2.24	3.65
	CO	0.00	0.00
	CO_2	0.60	1.54
	CH_4	92.74	86.71
	He	NM	NM
	Ar	0.00	0.00
HYDROCARBONS	C_2 (as Ethane)	3.7004	6.4854
	C_3 (as Propane)	0.2120	0.5450
	C_4 (as Butane)	0.0438	0.1483
	C_5 (as Pentane)	0.0087	0.0367
	C_6 (as Hexane)	0.0019	0.0094
	C_{6+} (as Hexane)	0.0036	0.0180
TRS	Total Reduced Sulfur	NM	NM
H2O	Moisture content	NM	NM

All results have been normalized to 100% on a dry basis.

Fuel Gas Specifications				
Atomic Breakdown - (scf/lb) / %			*HHV Btu/lb*	22328
Carbon (C)	71.1		*LHV Btu/lb*	20123
Hydrogen (H)	23.2		*HHV Btu/dscf*	1009
Oxygen (O)	2.0		*LHV Btu/dscf*	910
Nitrogen (N)	3.7		*F-Factor*	8645
Helium (He)	0.00		*Relative Density*	0.5924
Argon (Ar)	0.00		*C2-C6+ Weight %*	7.2429
Sulfur (S)	0.00		*MW lb/lb-mole*	17.157
Motor Octane Number	131.35		*Methane Number*	94.21

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 03/10/2020
Analyst : CH
Units : %

Instrument ID : TCD #1
Calb Date : 09/27/19
Reporting Limit : 0.1%

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	10.2	10.4	20.6	10.0	9.9	9.7
	% Rec *	103.2	100.1	102.1	100.0	98.9	97.3

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	LCS Result	9.8	10.4	20.5	10.0	9.9	9.7
	LCSD Result	10.3	10.5	20.7	10.1	10.0	9.8
	LCS % Rec *	99.0	99.9	101.7	100.2	99.1	97.4
	LCSD % Rec *	104.3	101.3	102.7	101.4	100.3	98.3
	% RPD ***	5.2	1.3	1.0	1.2	1.2	0.9

IV -Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
200338-5970	Sample	0.0	0.6	4.7	21.6	0.0	11.1
	Sample Dup	0.0	0.6	4.7	21.7	0.0	11.1
	Mean	0.0	0.6	4.7	21.7	0.0	11.1
	% RPD ***	0.0	0.6	0.0	0.5	0.0	0.5

V - Matrix Spike & Duplicate- BTU/ASTM D-1945

AAC ID	Analyte	H_2	N_2	CH_4	CO	CO_2
200338-5970	Sample Conc	0.0	2.4	10.8	0.0	5.6
	Spike Conc	9.9	10.1	10.0	10.0	10.0
	MS Result	10.1	12.7	20.9	10.1	15.5
	MSD Result	10.1	12.9	20.9	10.4	15.7
	MS % Rec **	102.3	102.4	100.8	101.4	99.5
	MSD % Rec **	102.0	104.1	101.0	103.6	101.3
	% RPD ***	0.3	1.7	0.3	2.2	1.8

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	H_2	O_2	N_2	CH_4	CO	CO_2
CCV	Spike Conc	9.9	10.4	20.2	10.0	10.0	10.0
	Result	10.0	10.4	20.6	10.0	10.0	9.6
	% Rec *	100.6	100.4	102.2	100.4	99.6	96.6

** Must be 85-115%*
*** Must be 75-125%*
**** Must be < 25%*
ND = Not Detected
<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

Date Analyzed : 03/10/2020
Analyst : DL/CH
Units : ppmv

Instrument ID : FID #3
Calb Date : 08/13/19
Reporting Limit : 0.5 ppmv

I - Opening Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	103.7	106.0	104.7	103.4	102.1	99.2
	% Rec *	104.0	105.8	104.8	103.6	102.2	99.0

II - Method Blank - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
MB	Concentration	ND	ND	ND	ND	ND	ND

III - Laboratory Control Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
Lab Control Standards	Sample Conc	0.0	0.0	0.0	0.0	0.0	0.0
	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	LCS Result	101.6	104.4	102.4	101.4	100.3	97.2
	LCSD Result	103.4	106.3	104.7	103.2	103.3	99.4
	LCS % Rec *	102.0	104.3	102.5	101.6	100.4	97.1
	LCSD % Rec *	103.8	106.2	104.8	103.4	103.4	99.2
	% RPD ***	1.8	1.8	2.2	1.8	2.9	2.2

IV - Sample & Sample Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200358-6153	Sample	1.8	0.0	0.0	0.0	0.0	0.0
	Sample Dup	1.8	0.0	0.0	0.0	0.0	0.0
	Mean	1.8	0.0	0.0	0.0	0.0	0.0
	% RPD ***	0.8	0.0	0.0	0.0	0.0	0.0

V - Matrix Spike & Duplicate - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
200358-6153	Sample Conc	0.9	0.0	0.0	0.0	0.0	0.0
	Spike Conc	49.8	50.1	50.0	49.9	50.0	50.1
	MS Result	47.7	48.1	47.0	46.4	46.0	45.5
	MSD Result	51.5	51.9	50.7	49.9	50.3	49.2
	MS % Rec **	93.9	96.1	94.1	93.0	92.1	90.8
	MSD % Rec **	101.4	103.6	101.4	100.1	100.7	98.1
	% RPD ***	7.6	7.5	7.5	7.3	8.9	7.7

VI - Closing Continuing Calibration Verification - BTU/ASTM D-1945

AAC ID	Analyte	Methane	Ethane	Propane	Butane	Pentane	Hexane
CCV	Spike Conc	99.7	100.1	99.9	99.8	100.0	100.2
	Result	94.2	95.8	93.9	93.8	93.6	89.9
	% Rec *	94.5	95.6	94.0	94.0	93.6	89.7

** Must be 85-115%*

*** Must be 75-125%*

**** Must be < 25%*

ND = Not Detected

<RL = less than Reporting Limit

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

200414

Chain of Custody Record

Pacific Gas and Electric Company

SAM # ATS

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

Client: PG&E Applied technical Services		Project Manager: Surinder Sidhu		Date
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Nat'l Gas Sampling		Sampler: Steve North 925-785-3039		Laboratory Fax
Contract Number, PO Number		Laboratory Contact		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: BTU
CPP-GS-MAR-1	63913	3/4/20	1430	Gas	500cc	cyl	1	None	Line pressure	
				Gas	1L	bag	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) and Evan Cavalli (EMCM@PGE.COM)

* Sample was transfer to Tedlar bag by ATS on 03/09/2020 from Gas cylinder

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

		Date	Time		Date	Time
1. Relinquished By: Steve North	(self/lab)	3/5/20	11:05	1. Received By	03/05/2020	11:05
2. Relinquished By		3/9/2020	10AM	2. Received By	Date	Time
3. Relinquished By		Date	Time	3. Received By	03/10/20	0930

Comments: Gas transferred from SS Cyl to 1L Tedlar bag at ATS for transport to AAC (date/time recorded above)

65

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/01/2020 00:00	1	1
01/01/2020 01:00	1	1
01/01/2020 02:00	2	2
01/01/2020 03:00	2	2
01/01/2020 04:00	2	2
01/01/2020 05:00	2	2
01/01/2020 06:00	2	2
01/01/2020 07:00	2	2
01/01/2020 08:00	2	2
01/01/2020 09:00	2	2
01/01/2020 10:00	2	2
01/01/2020 11:00	2	2
01/01/2020 12:00	2	2
01/01/2020 13:00	2	2
01/01/2020 14:00	2	2
01/01/2020 15:00	2	2
01/01/2020 16:00	2	2
01/01/2020 17:00	2	2
01/01/2020 18:00	2	2
01/01/2020 19:00	2	2
01/01/2020 20:00	2	2
01/01/2020 21:00	2	2
01/01/2020 22:00	2	2
01/01/2020 23:00	2	2
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/02/2020 00:00	2	2
01/02/2020 01:00	2	14
01/02/2020 02:00	2	19
01/02/2020 03:00	2	22
01/02/2020 04:00	2	21
01/02/2020 05:00	2	9
01/02/2020 06:00	2	4
01/02/2020 07:00	12	1
01/02/2020 08:00	20	1
01/02/2020 09:00	20	0
01/02/2020 10:00	19	0
01/02/2020 11:00	8	0
01/02/2020 12:00	0	0
01/02/2020 13:00	0	0
01/02/2020 14:00	0	0
01/02/2020 15:00	0	0
01/02/2020 16:00	0	0
01/02/2020 17:00	1	1
01/02/2020 18:00	1	1
01/02/2020 19:00	1	1
01/02/2020 20:00	1	1
01/02/2020 21:00	1	1
01/02/2020 22:00	1	1
01/02/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	0	0
Maximum:	20	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/03/2020 00:00	1	1
01/03/2020 01:00	1	1
01/03/2020 02:00	1	1
01/03/2020 03:00	1	1
01/03/2020 04:00	1	1
01/03/2020 05:00	1	1
01/03/2020 06:00	1	1
01/03/2020 07:00	1	1
01/03/2020 08:00	1	1
01/03/2020 09:00	1	1
01/03/2020 10:00	1	1
01/03/2020 11:00	0	0
01/03/2020 12:00	0	0
01/03/2020 13:00	0	0
01/03/2020 14:00	0	0
01/03/2020 15:00	0	0
01/03/2020 16:00	0	0
01/03/2020 17:00	1	1
01/03/2020 18:00	1	1
01/03/2020 19:00	1	1
01/03/2020 20:00	1	1
01/03/2020 21:00	1	1
01/03/2020 22:00	1	1
01/03/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/04/2020 00:00	1	1
01/04/2020 01:00	1	1
01/04/2020 02:00	1	1
01/04/2020 03:00	1	1
01/04/2020 04:00	1	1
01/04/2020 05:00	1	1
01/04/2020 06:00	1	1
01/04/2020 07:00	1	1
01/04/2020 08:00	1	1
01/04/2020 09:00	1	1
01/04/2020 10:00	1	1
01/04/2020 11:00	1	1
01/04/2020 12:00	1	1
01/04/2020 13:00	1	1
01/04/2020 14:00	1	1
01/04/2020 15:00	1	1
01/04/2020 16:00	1	1
01/04/2020 17:00	1	1
01/04/2020 18:00	1	1
01/04/2020 19:00	1	1
01/04/2020 20:00	1	1
01/04/2020 21:00	1	1
01/04/2020 22:00	1	1
01/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/05/2020 00:00	1	1
01/05/2020 01:00	1	1
01/05/2020 02:00	1	1
01/05/2020 03:00	1	1
01/05/2020 04:00	1	1
01/05/2020 05:00	1	1
01/05/2020 06:00	1	1
01/05/2020 07:00	1	1
01/05/2020 08:00	1	1
01/05/2020 09:00	1	1
01/05/2020 10:00	1	1
01/05/2020 11:00	1	1
01/05/2020 12:00	1	1
01/05/2020 13:00	1	1
01/05/2020 14:00	1	1
01/05/2020 15:00	1	1
01/05/2020 16:00	1	1
01/05/2020 17:00	1	1
01/05/2020 18:00	1	1
01/05/2020 19:00	1	1
01/05/2020 20:00	1	1
01/05/2020 21:00	1	1
01/05/2020 22:00	1	1
01/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/06/2020 00:00	1	1
01/06/2020 01:00	1	1
01/06/2020 02:00	1	1
01/06/2020 03:00	1	1
01/06/2020 04:00	1	12
01/06/2020 05:00	1	21
01/06/2020 06:00	1	25
01/06/2020 07:00	6	25
01/06/2020 08:00	18	14
01/06/2020 09:00	18	5
01/06/2020 10:00	18	0
01/06/2020 11:00	13	0
01/06/2020 12:00	1	0
01/06/2020 13:00	0	0
01/06/2020 14:00	0	0
01/06/2020 15:00	0	0
01/06/2020 16:00	0	0
01/06/2020 17:00	1	1
01/06/2020 18:00	1	1
01/06/2020 19:00	1	1
01/06/2020 20:00	1	1
01/06/2020 21:00	1	1
01/06/2020 22:00	1	1
01/06/2020 23:00	1	1
Average/Sum#:	4	5
Minimum:	0	0
Maximum:	18	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/07/2020 00:00	1	1
01/07/2020 01:00	1	1
01/07/2020 02:00	1	1
01/07/2020 03:00	1	1
01/07/2020 04:00	1	1
01/07/2020 05:00	1	1
01/07/2020 06:00	1	1
01/07/2020 07:00	1	1
01/07/2020 08:00	1	1
01/07/2020 09:00	1	1
01/07/2020 10:00	1	1
01/07/2020 11:00	0	0
01/07/2020 12:00	0	0
01/07/2020 13:00	0	0
01/07/2020 14:00	0	0
01/07/2020 15:00	0	0
01/07/2020 16:00	0	0
01/07/2020 17:00	1	1
01/07/2020 18:00	1	1
01/07/2020 19:00	1	1
01/07/2020 20:00	1	1
01/07/2020 21:00	1	1
01/07/2020 22:00	1	1
01/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/08/2020 00:00	1	1
01/08/2020 01:00	1	1
01/08/2020 02:00	1	1
01/08/2020 03:00	1	1
01/08/2020 04:00	1	1
01/08/2020 05:00	1	1
01/08/2020 06:00	1	1
01/08/2020 07:00	1	1
01/08/2020 08:00	1	1
01/08/2020 09:00	1	1
01/08/2020 10:00	1	1
01/08/2020 11:00	1	1
01/08/2020 12:00	1	1
01/08/2020 13:00	1	1
01/08/2020 14:00	1	1
01/08/2020 15:00	1	1
01/08/2020 16:00	1	1
01/08/2020 17:00	1	1
01/08/2020 18:00	1	1
01/08/2020 19:00	1	1
01/08/2020 20:00	1	1
01/08/2020 21:00	1	13
01/08/2020 22:00	1	17
01/08/2020 23:00	1	19
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/09/2020 00:00	1	18
01/09/2020 01:00	1	6
01/09/2020 02:00	12	2
01/09/2020 03:00	19	0
01/09/2020 04:00	19	0
01/09/2020 05:00	19	0
01/09/2020 06:00	8	0
01/09/2020 07:00	0	0
01/09/2020 08:00	0	0
01/09/2020 09:00	0	0
01/09/2020 10:00	0	0
01/09/2020 11:00	0	0
01/09/2020 12:00	0	0
01/09/2020 13:00	0	0
01/09/2020 14:00	0	0
01/09/2020 15:00	0	0
01/09/2020 16:00	0	0
01/09/2020 17:00	1	1
01/09/2020 18:00	1	1
01/09/2020 19:00	1	1
01/09/2020 20:00	1	1
01/09/2020 21:00	1	1
01/09/2020 22:00	1	1
01/09/2020 23:00	1	1
Average/Sum#:	4	1
Minimum:	0	0
Maximum:	19	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/10/2020 00:00	1	1
01/10/2020 01:00	1	1
01/10/2020 02:00	1	1
01/10/2020 03:00	1	1
01/10/2020 04:00	1	1
01/10/2020 05:00	1	1
01/10/2020 06:00	1	1
01/10/2020 07:00	1	1
01/10/2020 08:00	1	1
01/10/2020 09:00	1	1
01/10/2020 10:00	1	1
01/10/2020 11:00	1	1
01/10/2020 12:00	0	0
01/10/2020 13:00	0	0
01/10/2020 14:00	0	0
01/10/2020 15:00	0	0
01/10/2020 16:00	0	0
01/10/2020 17:00	1	1
01/10/2020 18:00	1	1
01/10/2020 19:00	1	1
01/10/2020 20:00	1	1
01/10/2020 21:00	1	1
01/10/2020 22:00	1	1
01/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/11/2020 00:00	1	1
01/11/2020 01:00	1	1
01/11/2020 02:00	1	1
01/11/2020 03:00	1	1
01/11/2020 04:00	1	1
01/11/2020 05:00	1	1
01/11/2020 06:00	1	1
01/11/2020 07:00	1	1
01/11/2020 08:00	1	1
01/11/2020 09:00	1	1
01/11/2020 10:00	1	1
01/11/2020 11:00	1	1
01/11/2020 12:00	1	1
01/11/2020 13:00	1	1
01/11/2020 14:00	1	1
01/11/2020 15:00	1	1
01/11/2020 16:00	1	1
01/11/2020 17:00	1	1
01/11/2020 18:00	1	1
01/11/2020 19:00	1	1
01/11/2020 20:00	1	1
01/11/2020 21:00	1	1
01/11/2020 22:00	1	1
01/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/12/2020 00:00	1	1
01/12/2020 01:00	1	1
01/12/2020 02:00	1	1
01/12/2020 03:00	1	1
01/12/2020 04:00	1	1
01/12/2020 05:00	1	1
01/12/2020 06:00	1	1
01/12/2020 07:00	1	1
01/12/2020 08:00	1	1
01/12/2020 09:00	1	1
01/12/2020 10:00	1	1
01/12/2020 11:00	1	1
01/12/2020 12:00	1	1
01/12/2020 13:00	1	1
01/12/2020 14:00	1	1
01/12/2020 15:00	1	1
01/12/2020 16:00	1	1
01/12/2020 17:00	1	1
01/12/2020 18:00	1	1
01/12/2020 19:00	1	1
01/12/2020 20:00	1	1
01/12/2020 21:00	1	1
01/12/2020 22:00	1	1
01/12/2020 23:00	1	12
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	12
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/13/2020 00:00	1	19
01/13/2020 01:00	1	22
01/13/2020 02:00	1	21
01/13/2020 03:00	11	10
01/13/2020 04:00	21	3
01/13/2020 05:00	26	0
01/13/2020 06:00	26	0
01/13/2020 07:00	16	0
01/13/2020 08:00	6	0
01/13/2020 09:00	0	0
01/13/2020 10:00	0	0
01/13/2020 11:00	0	0
01/13/2020 12:00	0	0
01/13/2020 13:00	0	0
01/13/2020 14:00	0	0
01/13/2020 15:00	0	0
01/13/2020 16:00	0	0
01/13/2020 17:00	1	1
01/13/2020 18:00	1	1
01/13/2020 19:00	1	1
01/13/2020 20:00	1	1
01/13/2020 21:00	1	1
01/13/2020 22:00	1	1
01/13/2020 23:00	1	1
Average/Sum#:	5	3
Minimum:	0	0
Maximum:	26	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/14/2020 00:00	1	1
01/14/2020 01:00	1	1
01/14/2020 02:00	1	1
01/14/2020 03:00	1	1
01/14/2020 04:00	1	1
01/14/2020 05:00	1	1
01/14/2020 06:00	1	1
01/14/2020 07:00	1	1
01/14/2020 08:00	1	1
01/14/2020 09:00	1	1
01/14/2020 10:00	1	1
01/14/2020 11:00	1	1
01/14/2020 12:00	1	1
01/14/2020 13:00	1	0
01/14/2020 14:00	1	0
01/14/2020 15:00	1	0
01/14/2020 16:00	1	0
01/14/2020 17:00	1	1
01/14/2020 18:00	1	1
01/14/2020 19:00	1	1
01/14/2020 20:00	1	1
01/14/2020 21:00	1	1
01/14/2020 22:00	1	1
01/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	16.67

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/15/2020 00:00	1	1
01/15/2020 01:00	1	1
01/15/2020 02:00	1	1
01/15/2020 03:00	1	1
01/15/2020 04:00	1	1
01/15/2020 05:00	1	1
01/15/2020 06:00	1	1
01/15/2020 07:00	1	1
01/15/2020 08:00	1	1
01/15/2020 09:00	1	1
01/15/2020 10:00	1	1
01/15/2020 11:00	1	0
01/15/2020 12:00	1	0
01/15/2020 13:00	1	0
01/15/2020 14:00	1	0
01/15/2020 15:00	1	0
01/15/2020 16:00	1	0
01/15/2020 17:00	1	1
01/15/2020 18:00	1	1
01/15/2020 19:00	1	1
01/15/2020 20:00	1	1
01/15/2020 21:00	1	1
01/15/2020 22:00	1	1
01/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/16/2020 00:00	1	1
01/16/2020 01:00	1	1
01/16/2020 02:00	1	1
01/16/2020 03:00	1	1
01/16/2020 04:00	1	1
01/16/2020 05:00	1	1
01/16/2020 06:00	1	1
01/16/2020 07:00	1	1
01/16/2020 08:00	1	1
01/16/2020 09:00	1	1
01/16/2020 10:00	1	1
01/16/2020 11:00	1	1
01/16/2020 12:00	1	0
01/16/2020 13:00	1	0
01/16/2020 14:00	1	0
01/16/2020 15:00	1	0
01/16/2020 16:00	1	0
01/16/2020 17:00	1	1
01/16/2020 18:00	1	1
01/16/2020 19:00	1	1
01/16/2020 20:00	1	1
01/16/2020 21:00	1	1
01/16/2020 22:00	1	1
01/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/17/2020 00:00	1	1
01/17/2020 01:00	1	1
01/17/2020 02:00	1	1
01/17/2020 03:00	1	1
01/17/2020 04:00	1	1
01/17/2020 05:00	1	1
01/17/2020 06:00	1	1
01/17/2020 07:00	1	1
01/17/2020 08:00	1	1
01/17/2020 09:00	1	1
01/17/2020 10:00	1	1
01/17/2020 11:00	1	1
01/17/2020 12:00	1	0
01/17/2020 13:00	1	0
01/17/2020 14:00	1	0
01/17/2020 15:00	1	0
01/17/2020 16:00	1	0
01/17/2020 17:00	1	1
01/17/2020 18:00	1	1
01/17/2020 19:00	1	1
01/17/2020 20:00	1	1
01/17/2020 21:00	1	1
01/17/2020 22:00	1	1
01/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/18/2020 00:00	1	1
01/18/2020 01:00	1	1
01/18/2020 02:00	1	1
01/18/2020 03:00	1	1
01/18/2020 04:00	1	1
01/18/2020 05:00	1	1
01/18/2020 06:00	1	1
01/18/2020 07:00	1	1
01/18/2020 08:00	1	1
01/18/2020 09:00	1	1
01/18/2020 10:00	1	1
01/18/2020 11:00	1	0
01/18/2020 12:00	1	0
01/18/2020 13:00	1	0
01/18/2020 14:00	1	0
01/18/2020 15:00	1	0
01/18/2020 16:00	1	0
01/18/2020 17:00	1	1
01/18/2020 18:00	1	1
01/18/2020 19:00	1	1
01/18/2020 20:00	1	1
01/18/2020 21:00	1	1
01/18/2020 22:00	1	1
01/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/19/2020 00:00	1	1
01/19/2020 01:00	1	1
01/19/2020 02:00	1	1
01/19/2020 03:00	1	0
01/19/2020 04:00	1	0
01/19/2020 05:00	1	0
01/19/2020 06:00	1	0
01/19/2020 07:00	1	0
01/19/2020 08:00	1	0
01/19/2020 09:00	1	0
01/19/2020 10:00	1	0
01/19/2020 11:00	1	0
01/19/2020 12:00	1	0
01/19/2020 13:00	1	0
01/19/2020 14:00	1	0
01/19/2020 15:00	1	0
01/19/2020 16:00	1	0
01/19/2020 17:00	1	0
01/19/2020 18:00	1	1
01/19/2020 19:00	1	1
01/19/2020 20:00	1	1
01/19/2020 21:00	1	1
01/19/2020 22:00	1	1
01/19/2020 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/20/2020 00:00	1	1
01/20/2020 01:00	1	1
01/20/2020 02:00	1	1
01/20/2020 03:00	1	1
01/20/2020 04:00	1	1
01/20/2020 05:00	1	1
01/20/2020 06:00	1	1
01/20/2020 07:00	1	1
01/20/2020 08:00	1	1
01/20/2020 09:00	1	1
01/20/2020 10:00	1	1
01/20/2020 11:00	1	1
01/20/2020 12:00	1	1
01/20/2020 13:00	1	1
01/20/2020 14:00	1	1
01/20/2020 15:00	1	1
01/20/2020 16:00	1	1
01/20/2020 17:00	1	1
01/20/2020 18:00	1	1
01/20/2020 19:00	1	1
01/20/2020 20:00	1	1
01/20/2020 21:00	1	1
01/20/2020 22:00	1	1
01/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/21/2020 00:00	1	1
01/21/2020 01:00	1	1
01/21/2020 02:00	1	1
01/21/2020 03:00	1	1
01/21/2020 04:00	1	1
01/21/2020 05:00	1	1
01/21/2020 06:00	1	1
01/21/2020 07:00	1	1
01/21/2020 08:00	1	1
01/21/2020 09:00	1	1
01/21/2020 10:00	1	1
01/21/2020 11:00	1	1
01/21/2020 12:00	1	1
01/21/2020 13:00	1	0
01/21/2020 14:00	1	0
01/21/2020 15:00	1	0
01/21/2020 16:00	1	0
01/21/2020 17:00	1	1
01/21/2020 18:00	1	1
01/21/2020 19:00	1	1
01/21/2020 20:00	1	1
01/21/2020 21:00	1	1
01/21/2020 22:00	1	1
01/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/22/2020 00:00	1	1
01/22/2020 01:00	1	1
01/22/2020 02:00	1	1
01/22/2020 03:00	1	0
01/22/2020 04:00	1	0
01/22/2020 05:00	1	0
01/22/2020 06:00	1	0
01/22/2020 07:00	1	0
01/22/2020 08:00	1	0
01/22/2020 09:00	1	0
01/22/2020 10:00	1	0
01/22/2020 11:00	1	0
01/22/2020 12:00	1	0
01/22/2020 13:00	1	0
01/22/2020 14:00	1	0
01/22/2020 15:00	1	0
01/22/2020 16:00	1	0
01/22/2020 17:00	1	1
01/22/2020 18:00	1	1
01/22/2020 19:00	1	1
01/22/2020 20:00	1	1
01/22/2020 21:00	1	1
01/22/2020 22:00	1	1
01/22/2020 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/23/2020 00:00	1	1
01/23/2020 01:00	1	1
01/23/2020 02:00	1	1
01/23/2020 03:00	1	1
01/23/2020 04:00	1	1
01/23/2020 05:00	1	1
01/23/2020 06:00	1	1
01/23/2020 07:00	1	1
01/23/2020 08:00	1	1
01/23/2020 09:00	1	1
01/23/2020 10:00	1	1
01/23/2020 11:00	1	0
01/23/2020 12:00	1	0
01/23/2020 13:00	1	0
01/23/2020 14:00	1	0
01/23/2020 15:00	1	0
01/23/2020 16:00	1	0
01/23/2020 17:00	1	0
01/23/2020 18:00	1	1
01/23/2020 19:00	1	1
01/23/2020 20:00	1	1
01/23/2020 21:00	1	1
01/23/2020 22:00	1	1
01/23/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/24/2020 00:00	1	1
01/24/2020 01:00	1	1
01/24/2020 02:00	1	1
01/24/2020 03:00	1	0
01/24/2020 04:00	1	0
01/24/2020 05:00	1	0
01/24/2020 06:00	1	0
01/24/2020 07:00	1	0
01/24/2020 08:00	1	0
01/24/2020 09:00	1	0
01/24/2020 10:00	1	0
01/24/2020 11:00	1	0
01/24/2020 12:00	1	0
01/24/2020 13:00	1	0
01/24/2020 14:00	1	0
01/24/2020 15:00	1	0
01/24/2020 16:00	1	0
01/24/2020 17:00	1	0
01/24/2020 18:00	1	1
01/24/2020 19:00	1	1
01/24/2020 20:00	1	1
01/24/2020 21:00	1	1
01/24/2020 22:00	1	1
01/24/2020 23:00	1	2
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/25/2020 00:00	1	2
01/25/2020 01:00	1	2
01/25/2020 02:00	1	2
01/25/2020 03:00	1	2
01/25/2020 04:00	1	2
01/25/2020 05:00	1	2
01/25/2020 06:00	1	2
01/25/2020 07:00	1	2
01/25/2020 08:00	1	2
01/25/2020 09:00	1	2
01/25/2020 10:00	1	2
01/25/2020 11:00	1	2
01/25/2020 12:00	1	2
01/25/2020 13:00	1	2
01/25/2020 14:00	1	2
01/25/2020 15:00	1	2
01/25/2020 16:00	1	2
01/25/2020 17:00	1	2
01/25/2020 18:00	1	2
01/25/2020 19:00	1	2
01/25/2020 20:00	1	2
01/25/2020 21:00	1	2
01/25/2020 22:00	1	2
01/25/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/26/2020 00:00	1	2
01/26/2020 01:00	1	2
01/26/2020 02:00	1	2
01/26/2020 03:00	1	2
01/26/2020 04:00	1	2
01/26/2020 05:00	1	2
01/26/2020 06:00	1	2
01/26/2020 07:00	1	2
01/26/2020 08:00	1	2
01/26/2020 09:00	1	2
01/26/2020 10:00	1	2
01/26/2020 11:00	1	2
01/26/2020 12:00	1	2
01/26/2020 13:00	1	2
01/26/2020 14:00	1	2
01/26/2020 15:00	1	2
01/26/2020 16:00	1	2
01/26/2020 17:00	1	2
01/26/2020 18:00	1	2
01/26/2020 19:00	1	2
01/26/2020 20:00	1	2
01/26/2020 21:00	1	2
01/26/2020 22:00	1	2
01/26/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/27/2020 00:00	1	2
01/27/2020 01:00	1	2
01/27/2020 02:00	1	2
01/27/2020 03:00	1	2
01/27/2020 04:00	1	2
01/27/2020 05:00	1	2
01/27/2020 06:00	1	2
01/27/2020 07:00	1	2
01/27/2020 08:00	1	2
01/27/2020 09:00	1	2
01/27/2020 10:00	1	2
01/27/2020 11:00	1	2
01/27/2020 12:00	1	2
01/27/2020 13:00	1	2
01/27/2020 14:00	1	2
01/27/2020 15:00	1	2
01/27/2020 16:00	1	2
01/27/2020 17:00	1	2
01/27/2020 18:00	1	13
01/27/2020 19:00	1	17
01/27/2020 20:00	1	19
01/27/2020 21:00	1	18
01/27/2020 22:00	1	7
01/27/2020 23:00	1	3
Average/Sum#:	1	5
Minimum:	1	2
Maximum:	1	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/28/2020 00:00	1	0
01/28/2020 01:00	1	0
01/28/2020 02:00	1	0
01/28/2020 03:00	14	0
01/28/2020 04:00	18	0
01/28/2020 05:00	18	0
01/28/2020 06:00	18	0
01/28/2020 07:00	5	0
01/28/2020 08:00	1	0
01/28/2020 09:00	1	0
01/28/2020 10:00	1	0
01/28/2020 11:00	1	0
01/28/2020 12:00	1	0
01/28/2020 13:00	1	0
01/28/2020 14:00	1	0
01/28/2020 15:00	1	0
01/28/2020 16:00	1	0
01/28/2020 17:00	1	0
01/28/2020 18:00	1	1
01/28/2020 19:00	1	1
01/28/2020 20:00	1	1
01/28/2020 21:00	1	1
01/28/2020 22:00	1	2
01/28/2020 23:00	1	2
Average/Sum#:	4	0
Minimum:	1	0
Maximum:	18	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/29/2020 00:00	1	2
01/29/2020 01:00	1	2
01/29/2020 02:00	1	2
01/29/2020 03:00	1	2
01/29/2020 04:00	1	2
01/29/2020 05:00	1	2
01/29/2020 06:00	1	2
01/29/2020 07:00	1	2
01/29/2020 08:00	1	2
01/29/2020 09:00	1	2
01/29/2020 10:00	1	2
01/29/2020 11:00	1	2
01/29/2020 12:00	1	2
01/29/2020 13:00	1	2
01/29/2020 14:00	1	2
01/29/2020 15:00	1	2
01/29/2020 16:00	1	2
01/29/2020 17:00	1	13
01/29/2020 18:00	1	18
01/29/2020 19:00	1	20
01/29/2020 20:00	1	20
01/29/2020 21:00	1	8
01/29/2020 22:00	1	3
01/29/2020 23:00	1	1
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	20
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/30/2020 00:00	1	1
01/30/2020 01:00	1	0
01/30/2020 02:00	15	0
01/30/2020 03:00	17	0
01/30/2020 04:00	17	0
01/30/2020 05:00	17	0
01/30/2020 06:00	3	0
01/30/2020 07:00	1	1
01/30/2020 08:00	1	1
01/30/2020 09:00	1	1
01/30/2020 10:00	1	1
01/30/2020 11:00	1	0
01/30/2020 12:00	1	0
01/30/2020 13:00	1	0
01/30/2020 14:00	1	0
01/30/2020 15:00	1	0
01/30/2020 16:00	1	0
01/30/2020 17:00	1	0
01/30/2020 18:00	1	0
01/30/2020 19:00	1	0
01/30/2020 20:00	1	1
01/30/2020 21:00	1	1
01/30/2020 22:00	1	1
01/30/2020 23:00	1	1
Average/Sum#:	4	0
Minimum:	1	0
Maximum:	17	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
01/31/2020 00:00	1	1
01/31/2020 01:00	1	1
01/31/2020 02:00	1	0
01/31/2020 03:00	1	0
01/31/2020 04:00	1	0
01/31/2020 05:00	3	0
01/31/2020 06:00	5	0
01/31/2020 07:00	5	0
01/31/2020 08:00	4	0
01/31/2020 09:00	2	0
01/31/2020 10:00	1	0
01/31/2020 11:00	1	0
01/31/2020 12:00	1	0
01/31/2020 13:00	1	0
01/31/2020 14:00	1	0
01/31/2020 15:00	1	0
01/31/2020 16:00	1	0
01/31/2020 17:00	1	0
01/31/2020 18:00	1	0
01/31/2020 19:00	1	1
01/31/2020 20:00	1	1
01/31/2020 21:00	1	1
01/31/2020 22:00	1	1
01/31/2020 23:00	1	2
Average/Sum#:	2	0
Minimum:	1	0
Maximum:	5	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/01/2020 00:00	1	2
02/01/2020 01:00	1	2
02/01/2020 02:00	1	2
02/01/2020 03:00	1	2
02/01/2020 04:00	1	2
02/01/2020 05:00	1	2
02/01/2020 06:00	1	2
02/01/2020 07:00	1	2
02/01/2020 08:00	1	2
02/01/2020 09:00	1	2
02/01/2020 10:00	1	2
02/01/2020 11:00	1	2
02/01/2020 12:00	1	2
02/01/2020 13:00	1	2
02/01/2020 14:00	1	2
02/01/2020 15:00	1	2
02/01/2020 16:00	1	2
02/01/2020 17:00	1	2
02/01/2020 18:00	1	2
02/01/2020 19:00	1	2
02/01/2020 20:00	1	2
02/01/2020 21:00	1	2
02/01/2020 22:00	1	2
02/01/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/02/2020 00:00	1	2
02/02/2020 01:00	1	2
02/02/2020 02:00	1	2
02/02/2020 03:00	1	2
02/02/2020 04:00	1	2
02/02/2020 05:00	1	2
02/02/2020 06:00	1	2
02/02/2020 07:00	1	2
02/02/2020 08:00	1	2
02/02/2020 09:00	1	2
02/02/2020 10:00	1	2
02/02/2020 11:00	1	2
02/02/2020 12:00	1	2
02/02/2020 13:00	1	2
02/02/2020 14:00	1	2
02/02/2020 15:00	1	2
02/02/2020 16:00	1	2
02/02/2020 17:00	1	2
02/02/2020 18:00	1	2
02/02/2020 19:00	1	2
02/02/2020 20:00	1	2
02/02/2020 21:00	1	2
02/02/2020 22:00	1	2
02/02/2020 23:00	1	15
Average/Sum#:	1	3
Minimum:	1	2
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/03/2020 00:00	1	19
02/03/2020 01:00	1	23
02/03/2020 02:00	1	22
02/03/2020 03:00	6	9
02/03/2020 04:00	18	5
02/03/2020 05:00	20	0
02/03/2020 06:00	19	0
02/03/2020 07:00	14	0
02/03/2020 08:00	2	0
02/03/2020 09:00	1	0
02/03/2020 10:00	1	0
02/03/2020 11:00	1	0
02/03/2020 12:00	1	0
02/03/2020 13:00	1	0
02/03/2020 14:00	1	0
02/03/2020 15:00	1	0
02/03/2020 16:00	1	0
02/03/2020 17:00	1	0
02/03/2020 18:00	1	1
02/03/2020 19:00	1	1
02/03/2020 20:00	1	1
02/03/2020 21:00	1	1
02/03/2020 22:00	1	1
02/03/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	0
Maximum:	20	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/04/2020 00:00	1	1
02/04/2020 01:00	1	1
02/04/2020 02:00	1	1
02/04/2020 03:00	1	1
02/04/2020 04:00	1	1
02/04/2020 05:00	1	1
02/04/2020 06:00	1	1
02/04/2020 07:00	1	1
02/04/2020 08:00	1	1
02/04/2020 09:00	1	1
02/04/2020 10:00	1	1
02/04/2020 11:00	1	1
02/04/2020 12:00	1	0
02/04/2020 13:00	1	0
02/04/2020 14:00	1	0
02/04/2020 15:00	1	0
02/04/2020 16:00	1	0
02/04/2020 17:00	1	1
02/04/2020 18:00	1	1
02/04/2020 19:00	1	1
02/04/2020 20:00	1	1
02/04/2020 21:00	1	1
02/04/2020 22:00	1	1
02/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/05/2020 00:00	1	1
02/05/2020 01:00	1	1
02/05/2020 02:00	1	1
02/05/2020 03:00	1	1
02/05/2020 04:00	1	1
02/05/2020 05:00	1	1
02/05/2020 06:00	1	1
02/05/2020 07:00	1	1
02/05/2020 08:00	1	1
02/05/2020 09:00	1	1
02/05/2020 10:00	1	1
02/05/2020 11:00	1	1
02/05/2020 12:00	1	0
02/05/2020 13:00	1	0
02/05/2020 14:00	1	0
02/05/2020 15:00	1	0
02/05/2020 16:00	1	0
02/05/2020 17:00	1	1
02/05/2020 18:00	1	1
02/05/2020 19:00	1	1
02/05/2020 20:00	1	1
02/05/2020 21:00	1	1
02/05/2020 22:00	1	1
02/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/06/2020 00:00	1	1
02/06/2020 01:00	1	1
02/06/2020 02:00	1	1
02/06/2020 03:00	1	1
02/06/2020 04:00	1	1
02/06/2020 05:00	1	1
02/06/2020 06:00	1	1
02/06/2020 07:00	1	1
02/06/2020 08:00	1	1
02/06/2020 09:00	1	1
02/06/2020 10:00	1	1
02/06/2020 11:00	1	0
02/06/2020 12:00	1	0
02/06/2020 13:00	1	0
02/06/2020 14:00	1	0
02/06/2020 15:00	1	0
02/06/2020 16:00	1	0
02/06/2020 17:00	1	0
02/06/2020 18:00	1	1
02/06/2020 19:00	1	1
02/06/2020 20:00	1	1
02/06/2020 21:00	1	1
02/06/2020 22:00	1	1
02/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/07/2020 00:00	1	1
02/07/2020 01:00	1	1
02/07/2020 02:00	1	1
02/07/2020 03:00	1	0
02/07/2020 04:00	1	0
02/07/2020 05:00	1	0
02/07/2020 06:00	1	0
02/07/2020 07:00	1	1
02/07/2020 08:00	1	1
02/07/2020 09:00	1	1
02/07/2020 10:00	1	1
02/07/2020 11:00	1	1
02/07/2020 12:00	1	0
02/07/2020 13:00	1	0
02/07/2020 14:00	1	0
02/07/2020 15:00	1	0
02/07/2020 16:00	1	0
02/07/2020 17:00	1	1
02/07/2020 18:00	1	1
02/07/2020 19:00	1	1
02/07/2020 20:00	1	1
02/07/2020 21:00	1	1
02/07/2020 22:00	1	1
02/07/2020 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/08/2020 00:00	1	2
02/08/2020 01:00	1	2
02/08/2020 02:00	1	2
02/08/2020 03:00	1	2
02/08/2020 04:00	1	2
02/08/2020 05:00	1	2
02/08/2020 06:00	1	2
02/08/2020 07:00	1	2
02/08/2020 08:00	1	2
02/08/2020 09:00	1	2
02/08/2020 10:00	1	2
02/08/2020 11:00	1	2
02/08/2020 12:00	1	2
02/08/2020 13:00	1	2
02/08/2020 14:00	1	2
02/08/2020 15:00	1	2
02/08/2020 16:00	1	2
02/08/2020 17:00	1	2
02/08/2020 18:00	1	2
02/08/2020 19:00	1	2
02/08/2020 20:00	1	2
02/08/2020 21:00	1	2
02/08/2020 22:00	1	2
02/08/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/09/2020 00:00	1	2
02/09/2020 01:00	1	2
02/09/2020 02:00	1	2
02/09/2020 03:00	1	2
02/09/2020 04:00	1	2
02/09/2020 05:00	1	2
02/09/2020 06:00	1	2
02/09/2020 07:00	1	2
02/09/2020 08:00	1	2
02/09/2020 09:00	1	2
02/09/2020 10:00	1	2
02/09/2020 11:00	1	2
02/09/2020 12:00	1	2
02/09/2020 13:00	1	2
02/09/2020 14:00	1	2
02/09/2020 15:00	1	2
02/09/2020 16:00	1	2
02/09/2020 17:00	1	2
02/09/2020 18:00	1	2
02/09/2020 19:00	1	2
02/09/2020 20:00	1	2
02/09/2020 21:00	1	2
02/09/2020 22:00	1	2
02/09/2020 23:00	1	15
Average/Sum#:	1	3
Minimum:	1	2
Maximum:	1	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/10/2020 00:00	1	22
02/10/2020 01:00	1	26
02/10/2020 02:00	1	25
02/10/2020 03:00	17	12
02/10/2020 04:00	24	4
02/10/2020 05:00	26	0
02/10/2020 06:00	26	0
02/10/2020 07:00	11	0
02/10/2020 08:00	3	0
02/10/2020 09:00	1	0
02/10/2020 10:00	1	0
02/10/2020 11:00	1	0
02/10/2020 12:00	1	0
02/10/2020 13:00	1	0
02/10/2020 14:00	1	0
02/10/2020 15:00	1	0
02/10/2020 16:00	1	0
02/10/2020 17:00	1	0
02/10/2020 18:00	1	1
02/10/2020 19:00	1	1
02/10/2020 20:00	1	1
02/10/2020 21:00	1	1
02/10/2020 22:00	1	1
02/10/2020 23:00	1	1
Average/Sum#:	5	4
Minimum:	1	0
Maximum:	26	26
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/11/2020 00:00	1	1
02/11/2020 01:00	1	1
02/11/2020 02:00	1	1
02/11/2020 03:00	1	0
02/11/2020 04:00	1	0
02/11/2020 05:00	1	0
02/11/2020 06:00	1	0
02/11/2020 07:00	1	0
02/11/2020 08:00	1	0
02/11/2020 09:00	1	0
02/11/2020 10:00	1	0
02/11/2020 11:00	1	0
02/11/2020 12:00	1	0
02/11/2020 13:00	1	0
02/11/2020 14:00	1	0
02/11/2020 15:00	1	0
02/11/2020 16:00	1	0
02/11/2020 17:00	1	0
02/11/2020 18:00	1	0
02/11/2020 19:00	1	1
02/11/2020 20:00	1	1
02/11/2020 21:00	1	1
02/11/2020 22:00	1	1
02/11/2020 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/12/2020 00:00	1	1
02/12/2020 01:00	1	1
02/12/2020 02:00	1	1
02/12/2020 03:00	1	0
02/12/2020 04:00	1	0
02/12/2020 05:00	1	0
02/12/2020 06:00	1	0
02/12/2020 07:00	1	0
02/12/2020 08:00	1	0
02/12/2020 09:00	1	0
02/12/2020 10:00	1	0
02/12/2020 11:00	1	0
02/12/2020 12:00	1	0
02/12/2020 13:00	1	0
02/12/2020 14:00	1	0
02/12/2020 15:00	1	0
02/12/2020 16:00	1	0
02/12/2020 17:00	1	0
02/12/2020 18:00	1	0
02/12/2020 19:00	1	1
02/12/2020 20:00	1	1
02/12/2020 21:00	1	1
02/12/2020 22:00	1	1
02/12/2020 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/13/2020 00:00	1	1
02/13/2020 01:00	1	1
02/13/2020 02:00	1	1
02/13/2020 03:00	1	1
02/13/2020 04:00	1	1
02/13/2020 05:00	1	1
02/13/2020 06:00	1	1
02/13/2020 07:00	1	1
02/13/2020 08:00	1	1
02/13/2020 09:00	1	1
02/13/2020 10:00	1	1
02/13/2020 11:00	1	0
02/13/2020 12:00	1	0
02/13/2020 13:00	1	0
02/13/2020 14:00	1	0
02/13/2020 15:00	1	0
02/13/2020 16:00	1	0
02/13/2020 17:00	1	1
02/13/2020 18:00	1	1
02/13/2020 19:00	1	1
02/13/2020 20:00	1	1
02/13/2020 21:00	1	1
02/13/2020 22:00	1	1
02/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/14/2020 00:00	1	1
02/14/2020 01:00	1	1
02/14/2020 02:00	1	1
02/14/2020 03:00	1	1
02/14/2020 04:00	1	1
02/14/2020 05:00	1	1
02/14/2020 06:00	1	1
02/14/2020 07:00	1	1
02/14/2020 08:00	1	1
02/14/2020 09:00	1	1
02/14/2020 10:00	1	1
02/14/2020 11:00	1	1
02/14/2020 12:00	1	1
02/14/2020 13:00	1	1
02/14/2020 14:00	1	1
02/14/2020 15:00	1	1
02/14/2020 16:00	1	1
02/14/2020 17:00	1	1
02/14/2020 18:00	1	1
02/14/2020 19:00	1	1
02/14/2020 20:00	1	1
02/14/2020 21:00	1	1
02/14/2020 22:00	1	1
02/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/15/2020 00:00	1	1
02/15/2020 01:00	1	1
02/15/2020 02:00	1	1
02/15/2020 03:00	1	1
02/15/2020 04:00	1	1
02/15/2020 05:00	1	1
02/15/2020 06:00	1	1
02/15/2020 07:00	1	1
02/15/2020 08:00	1	1
02/15/2020 09:00	1	1
02/15/2020 10:00	1	1
02/15/2020 11:00	1	1
02/15/2020 12:00	1	1
02/15/2020 13:00	1	1
02/15/2020 14:00	1	1
02/15/2020 15:00	1	1
02/15/2020 16:00	1	1
02/15/2020 17:00	1	1
02/15/2020 18:00	1	1
02/15/2020 19:00	1	1
02/15/2020 20:00	1	1
02/15/2020 21:00	1	1
02/15/2020 22:00	1	1
02/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/16/2020 00:00	1	1
02/16/2020 01:00	1	1
02/16/2020 02:00	1	1
02/16/2020 03:00	1	1
02/16/2020 04:00	1	1
02/16/2020 05:00	1	1
02/16/2020 06:00	1	1
02/16/2020 07:00	1	1
02/16/2020 08:00	1	1
02/16/2020 09:00	1	1
02/16/2020 10:00	1	1
02/16/2020 11:00	1	1
02/16/2020 12:00	1	1
02/16/2020 13:00	1	1
02/16/2020 14:00	1	1
02/16/2020 15:00	1	1
02/16/2020 16:00	1	1
02/16/2020 17:00	1	1
02/16/2020 18:00	1	1
02/16/2020 19:00	1	1
02/16/2020 20:00	1	1
02/16/2020 21:00	1	1
02/16/2020 22:00	1	1
02/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/17/2020 00:00	1	1
02/17/2020 01:00	1	1
02/17/2020 02:00	1	1
02/17/2020 03:00	1	1
02/17/2020 04:00	1	1
02/17/2020 05:00	1	1
02/17/2020 06:00	1	1
02/17/2020 07:00	1	1
02/17/2020 08:00	1	1
02/17/2020 09:00	1	15
02/17/2020 10:00	1	20
02/17/2020 11:00	1	25
02/17/2020 12:00	1	29
02/17/2020 13:00	1	15
02/17/2020 14:00	1	10
02/17/2020 15:00	15	4
02/17/2020 16:00	19	0
02/17/2020 17:00	19	0
02/17/2020 18:00	19	0
02/17/2020 19:00	4	1
02/17/2020 20:00	1	1
02/17/2020 21:00	1	1
02/17/2020 22:00	1	1
02/17/2020 23:00	1	1
Average/Sum#:	4	6
Minimum:	1	0
Maximum:	19	29
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/18/2020 00:00	1	1
02/18/2020 01:00	1	1
02/18/2020 02:00	1	1
02/18/2020 03:00	1	1
02/18/2020 04:00	1	1
02/18/2020 05:00	1	1
02/18/2020 06:00	1	1
02/18/2020 07:00	1	1
02/18/2020 08:00	1	1
02/18/2020 09:00	1	1
02/18/2020 10:00	1	1
02/18/2020 11:00	1	1
02/18/2020 12:00	1	1
02/18/2020 13:00	1	1
02/18/2020 14:00	1	1
02/18/2020 15:00	1	0
02/18/2020 16:00	1	0
02/18/2020 17:00	1	1
02/18/2020 18:00	1	1
02/18/2020 19:00	1	1
02/18/2020 20:00	1	1
02/18/2020 21:00	1	1
02/18/2020 22:00	1	1
02/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/19/2020 00:00	1	1
02/19/2020 01:00	1	1
02/19/2020 02:00	1	1
02/19/2020 03:00	1	1
02/19/2020 04:00	1	1
02/19/2020 05:00	1	1
02/19/2020 06:00	1	1
02/19/2020 07:00	1	1
02/19/2020 08:00	1	1
02/19/2020 09:00	1	1
02/19/2020 10:00	1	1
02/19/2020 11:00	1	1
02/19/2020 12:00	1	1
02/19/2020 13:00	1	1
02/19/2020 14:00	1	1
02/19/2020 15:00	1	1
02/19/2020 16:00	1	1
02/19/2020 17:00	1	1
02/19/2020 18:00	1	1
02/19/2020 19:00	1	1
02/19/2020 20:00	1	1
02/19/2020 21:00	1	1
02/19/2020 22:00	1	1
02/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/20/2020 00:00	1	1
02/20/2020 01:00	1	1
02/20/2020 02:00	1	1
02/20/2020 03:00	1	1
02/20/2020 04:00	1	1
02/20/2020 05:00	1	1
02/20/2020 06:00	1	1
02/20/2020 07:00	1	1
02/20/2020 08:00	1	1
02/20/2020 09:00	1	1
02/20/2020 10:00	1	1
02/20/2020 11:00	1	1
02/20/2020 12:00	1	1
02/20/2020 13:00	1	1
02/20/2020 14:00	1	1
02/20/2020 15:00	1	1
02/20/2020 16:00	1	1
02/20/2020 17:00	1	1
02/20/2020 18:00	1	1
02/20/2020 19:00	1	1
02/20/2020 20:00	1	1
02/20/2020 21:00	1	1
02/20/2020 22:00	1	1
02/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/21/2020 00:00	1	1
02/21/2020 01:00	1	1
02/21/2020 02:00	1	1
02/21/2020 03:00	1	0
02/21/2020 04:00	1	0
02/21/2020 05:00	1	0
02/21/2020 06:00	1	0
02/21/2020 07:00	1	0
02/21/2020 08:00	1	0
02/21/2020 09:00	1	0
02/21/2020 10:00	1	0
02/21/2020 11:00	1	0
02/21/2020 12:00	1	0
02/21/2020 13:00	1	0
02/21/2020 14:00	1	0
02/21/2020 15:00	1	0
02/21/2020 16:00	1	0
02/21/2020 17:00	1	1
02/21/2020 18:00	1	1
02/21/2020 19:00	1	1
02/21/2020 20:00	1	1
02/21/2020 21:00	1	1
02/21/2020 22:00	1	1
02/21/2020 23:00	1	2
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/22/2020 00:00	1	2
02/22/2020 01:00	1	2
02/22/2020 02:00	1	2
02/22/2020 03:00	1	2
02/22/2020 04:00	1	2
02/22/2020 05:00	1	2
02/22/2020 06:00	1	2
02/22/2020 07:00	1	2
02/22/2020 08:00	1	2
02/22/2020 09:00	1	2
02/22/2020 10:00	1	2
02/22/2020 11:00	1	2
02/22/2020 12:00	1	2
02/22/2020 13:00	1	2
02/22/2020 14:00	1	2
02/22/2020 15:00	1	2
02/22/2020 16:00	1	2
02/22/2020 17:00	1	2
02/22/2020 18:00	1	2
02/22/2020 19:00	1	2
02/22/2020 20:00	1	2
02/22/2020 21:00	1	2
02/22/2020 22:00	1	2
02/22/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/23/2020 00:00	1	2
02/23/2020 01:00	1	2
02/23/2020 02:00	1	2
02/23/2020 03:00	1	2
02/23/2020 04:00	1	2
02/23/2020 05:00	1	2
02/23/2020 06:00	1	2
02/23/2020 07:00	1	2
02/23/2020 08:00	1	2
02/23/2020 09:00	1	2
02/23/2020 10:00	1	2
02/23/2020 11:00	1	2
02/23/2020 12:00	1	2
02/23/2020 13:00	1	2
02/23/2020 14:00	1	2
02/23/2020 15:00	1	2
02/23/2020 16:00	1	2
02/23/2020 17:00	1	2
02/23/2020 18:00	1	2
02/23/2020 19:00	1	2
02/23/2020 20:00	1	2
02/23/2020 21:00	1	2
02/23/2020 22:00	1	2
02/23/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/24/2020 00:00	1	2
02/24/2020 01:00	1	2
02/24/2020 02:00	1	2
02/24/2020 03:00	1	2
02/24/2020 04:00	1	2
02/24/2020 05:00	1	2
02/24/2020 06:00	1	2
02/24/2020 07:00	1	2
02/24/2020 08:00	1	2
02/24/2020 09:00	1	2
02/24/2020 10:00	1	2
02/24/2020 11:00	1	2
02/24/2020 12:00	1	2
02/24/2020 13:00	1	15
02/24/2020 14:00	1	22
02/24/2020 15:00	1	28
02/24/2020 16:00	1	27
02/24/2020 17:00	1	13
02/24/2020 18:00	1	7
02/24/2020 19:00	1	1
02/24/2020 20:00	1	1
02/24/2020 21:00	1	1
02/24/2020 22:00	1	1
02/24/2020 23:00	1	1
Average/Sum#:	1	6
Minimum:	1	1
Maximum:	1	28
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/25/2020 00:00	1	1
02/25/2020 01:00	1	1
02/25/2020 02:00	1	0
02/25/2020 03:00	1	0
02/25/2020 04:00	1	0
02/25/2020 05:00	1	0
02/25/2020 06:00	1	1
02/25/2020 07:00	1	1
02/25/2020 08:00	1	1
02/25/2020 09:00	1	1
02/25/2020 10:00	1	0
02/25/2020 11:00	1	0
02/25/2020 12:00	1	0
02/25/2020 13:00	1	0
02/25/2020 14:00	17	0
02/25/2020 15:00	25	0
02/25/2020 16:00	25	0
02/25/2020 17:00	24	0
02/25/2020 18:00	9	0
02/25/2020 19:00	1	1
02/25/2020 20:00	1	1
02/25/2020 21:00	1	1
02/25/2020 22:00	1	1
02/25/2020 23:00	1	1
Average/Sum#:	5	0
Minimum:	1	0
Maximum:	25	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/26/2020 00:00	1	1
02/26/2020 01:00	1	1
02/26/2020 02:00	1	1
02/26/2020 03:00	1	1
02/26/2020 04:00	1	1
02/26/2020 05:00	1	1
02/26/2020 06:00	1	1
02/26/2020 07:00	1	1
02/26/2020 08:00	1	2
02/26/2020 09:00	1	2
02/26/2020 10:00	1	2
02/26/2020 11:00	1	2
02/26/2020 12:00	1	2
02/26/2020 13:00	1	2
02/26/2020 14:00	1	2
02/26/2020 15:00	1	13
02/26/2020 16:00	1	14
02/26/2020 17:00	1	14
02/26/2020 18:00	1	14
02/26/2020 19:00	1	3
02/26/2020 20:00	1	1
02/26/2020 21:00	1	1
02/26/2020 22:00	1	1
02/26/2020 23:00	1	1
Average/Sum#:	1	4
Minimum:	1	1
Maximum:	1	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/27/2020 00:00	1	1
02/27/2020 01:00	1	1
02/27/2020 02:00	14	0
02/27/2020 03:00	18	0
02/27/2020 04:00	18	0
02/27/2020 05:00	18	0
02/27/2020 06:00	5	0
02/27/2020 07:00	1	0
02/27/2020 08:00	1	0
02/27/2020 09:00	1	0
02/27/2020 10:00	1	0
02/27/2020 11:00	1	1
02/27/2020 12:00	1	1
02/27/2020 13:00	1	1
02/27/2020 14:00	1	1
02/27/2020 15:00	1	0
02/27/2020 16:00	1	0
02/27/2020 17:00	1	1
02/27/2020 18:00	1	1
02/27/2020 19:00	1	1
02/27/2020 20:00	2	1
02/27/2020 21:00	2	1
02/27/2020 22:00	2	1
02/27/2020 23:00	2	1
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	18	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/28/2020 00:00	2	1
02/28/2020 01:00	1	1
02/28/2020 02:00	1	1
02/28/2020 03:00	1	0
02/28/2020 04:00	1	0
02/28/2020 05:00	1	0
02/28/2020 06:00	1	0
02/28/2020 07:00	1	0
02/28/2020 08:00	1	0
02/28/2020 09:00	1	0
02/28/2020 10:00	1	0
02/28/2020 11:00	1	0
02/28/2020 12:00	1	0
02/28/2020 13:00	1	0
02/28/2020 14:00	1	0
02/28/2020 15:00	1	0
02/28/2020 16:00	1	0
02/28/2020 17:00	1	1
02/28/2020 18:00	1	1
02/28/2020 19:00	1	1
02/28/2020 20:00	1	1
02/28/2020 21:00	1	1
02/28/2020 22:00	1	1
02/28/2020 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
02/29/2020 00:00	1	1
02/29/2020 01:00	1	1
02/29/2020 02:00	1	1
02/29/2020 03:00	1	1
02/29/2020 04:00	1	1
02/29/2020 05:00	1	1
02/29/2020 06:00	1	1
02/29/2020 07:00	1	1
02/29/2020 08:00	1	1
02/29/2020 09:00	1	1
02/29/2020 10:00	1	1
02/29/2020 11:00	1	1
02/29/2020 12:00	1	1
02/29/2020 13:00	1	1
02/29/2020 14:00	1	1
02/29/2020 15:00	1	1
02/29/2020 16:00	1	1
02/29/2020 17:00	1	1
02/29/2020 18:00	1	1
02/29/2020 19:00	1	1
02/29/2020 20:00	1	1
02/29/2020 21:00	1	1
02/29/2020 22:00	1	1
02/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/01/2020 00:00	1	1
03/01/2020 01:00	1	1
03/01/2020 02:00	1	1
03/01/2020 03:00	1	1
03/01/2020 04:00	1	1
03/01/2020 05:00	1	1
03/01/2020 06:00	1	1
03/01/2020 07:00	1	1
03/01/2020 08:00	1	1
03/01/2020 09:00	1	1
03/01/2020 10:00	1	1
03/01/2020 11:00	1	1
03/01/2020 12:00	1	1
03/01/2020 13:00	1	1
03/01/2020 14:00	1	1
03/01/2020 15:00	1	1
03/01/2020 16:00	1	1
03/01/2020 17:00	1	1
03/01/2020 18:00	1	1
03/01/2020 19:00	1	1
03/01/2020 20:00	1	1
03/01/2020 21:00	1	1
03/01/2020 22:00	1	1
03/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/02/2020 00:00	1	1
03/02/2020 01:00	1	1
03/02/2020 02:00	1	1
03/02/2020 03:00	1	1
03/02/2020 04:00	1	1
03/02/2020 05:00	1	1
03/02/2020 06:00	1	1
03/02/2020 07:00	1	1
03/02/2020 08:00	1	1
03/02/2020 09:00	1	1
03/02/2020 10:00	1	1
03/02/2020 11:00	1	1
03/02/2020 12:00	1	1
03/02/2020 13:00	1	1
03/02/2020 14:00	1	1
03/02/2020 15:00	1	1
03/02/2020 16:00	1	1
03/02/2020 17:00	1	1
03/02/2020 18:00	1	1
03/02/2020 19:00	1	1
03/02/2020 20:00	1	1
03/02/2020 21:00	1	1
03/02/2020 22:00	1	1
03/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/03/2020 00:00	1	1
03/03/2020 01:00	1	1
03/03/2020 02:00	1	1
03/03/2020 03:00	1	1
03/03/2020 04:00	1	1
03/03/2020 05:00	1	1
03/03/2020 06:00	1	1
03/03/2020 07:00	1	1
03/03/2020 08:00	1	7
03/03/2020 09:00	1	18
03/03/2020 10:00	1	22
03/03/2020 11:00	1	28
03/03/2020 12:00	1	25
03/03/2020 13:00	1	13
03/03/2020 14:00	1	9
03/03/2020 15:00	17	3
03/03/2020 16:00	25	0
03/03/2020 17:00	25	0
03/03/2020 18:00	25	1
03/03/2020 19:00	9	1
03/03/2020 20:00	1	1
03/03/2020 21:00	1	1
03/03/2020 22:00	1	1
03/03/2020 23:00	1	1
Average/Sum#:	5	6
Minimum:	1	0
Maximum:	25	28
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/04/2020 00:00	1	1
03/04/2020 01:00	1	1
03/04/2020 02:00	1	1
03/04/2020 03:00	1	1
03/04/2020 04:00	1	1
03/04/2020 05:00	1	1
03/04/2020 06:00	1	1
03/04/2020 07:00	1	1
03/04/2020 08:00	1	1
03/04/2020 09:00	1	1
03/04/2020 10:00	1	1
03/04/2020 11:00	1	0
03/04/2020 12:00	1	0
03/04/2020 13:00	1	0
03/04/2020 14:00	1	0
03/04/2020 15:00	1	0
03/04/2020 16:00	1	0
03/04/2020 17:00	1	1
03/04/2020 18:00	1	1
03/04/2020 19:00	1	1
03/04/2020 20:00	1	1
03/04/2020 21:00	1	1
03/04/2020 22:00	1	1
03/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/05/2020 00:00	1	1
03/05/2020 01:00	1	1
03/05/2020 02:00	1	1
03/05/2020 03:00	1	1
03/05/2020 04:00	1	1
03/05/2020 05:00	1	1
03/05/2020 06:00	1	1
03/05/2020 07:00	1	1
03/05/2020 08:00	1	1
03/05/2020 09:00	1	1
03/05/2020 10:00	1	1
03/05/2020 11:00	1	0
03/05/2020 12:00	1	0
03/05/2020 13:00	1	0
03/05/2020 14:00	1	0
03/05/2020 15:00	1	0
03/05/2020 16:00	1	0
03/05/2020 17:00	1	1
03/05/2020 18:00	1	1
03/05/2020 19:00	1	1
03/05/2020 20:00	1	1
03/05/2020 21:00	1	1
03/05/2020 22:00	1	1
03/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/06/2020 00:00	1	1
03/06/2020 01:00	1	1
03/06/2020 02:00	1	1
03/06/2020 03:00	1	1
03/06/2020 04:00	1	1
03/06/2020 05:00	1	1
03/06/2020 06:00	1	1
03/06/2020 07:00	1	1
03/06/2020 08:00	1	1
03/06/2020 09:00	1	1
03/06/2020 10:00	1	1
03/06/2020 11:00	1	1
03/06/2020 12:00	1	0
03/06/2020 13:00	1	0
03/06/2020 14:00	1	0
03/06/2020 15:00	1	0
03/06/2020 16:00	1	0
03/06/2020 17:00	1	1
03/06/2020 18:00	1	1
03/06/2020 19:00	1	1
03/06/2020 20:00	1	1
03/06/2020 21:00	1	1
03/06/2020 22:00	1	1
03/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/07/2020 00:00	1	2
03/07/2020 01:00	1	2
03/07/2020 02:00	1	2
03/07/2020 03:00	1	2
03/07/2020 04:00	1	2
03/07/2020 05:00	1	2
03/07/2020 06:00	1	2
03/07/2020 07:00	1	2
03/07/2020 08:00	1	2
03/07/2020 09:00	1	2
03/07/2020 10:00	1	2
03/07/2020 11:00	1	2
03/07/2020 12:00	1	2
03/07/2020 13:00	1	2
03/07/2020 14:00	1	2
03/07/2020 15:00	1	2
03/07/2020 16:00	1	2
03/07/2020 17:00	1	2
03/07/2020 18:00	1	2
03/07/2020 19:00	1	2
03/07/2020 20:00	1	2
03/07/2020 21:00	1	2
03/07/2020 22:00	1	2
03/07/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/08/2020 00:00	1	2
03/08/2020 01:00	1	2
03/08/2020 02:00	1	2
03/08/2020 03:00	1	2
03/08/2020 04:00	1	2
03/08/2020 05:00	1	2
03/08/2020 06:00	1	2
03/08/2020 07:00	1	2
03/08/2020 08:00	1	2
03/08/2020 09:00	1	2
03/08/2020 10:00	1	2
03/08/2020 11:00	1	2
03/08/2020 12:00	1	2
03/08/2020 13:00	1	2
03/08/2020 14:00	1	2
03/08/2020 15:00	1	2
03/08/2020 16:00	1	2
03/08/2020 17:00	1	2
03/08/2020 18:00	1	2
03/08/2020 19:00	1	2
03/08/2020 20:00	1	14
03/08/2020 21:00	1	18
03/08/2020 22:00	1	19
03/08/2020 23:00	1	18
Average/Sum#:	1	5
Minimum:	1	2
Maximum:	1	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/09/2020 00:00	1	6
03/09/2020 01:00	10	2
03/09/2020 02:00	21	0
03/09/2020 03:00	21	0
03/09/2020 04:00	21	0
03/09/2020 05:00	12	0
03/09/2020 06:00	1	1
03/09/2020 07:00	1	1
03/09/2020 08:00	1	1
03/09/2020 09:00	1	1
03/09/2020 10:00	1	1
03/09/2020 11:00	1	1
03/09/2020 12:00	1	0
03/09/2020 13:00	1	0
03/09/2020 14:00	1	0
03/09/2020 15:00	1	0
03/09/2020 16:00	1	0
03/09/2020 17:00	1	1
03/09/2020 18:00	1	1
03/09/2020 19:00	1	1
03/09/2020 20:00	1	1
03/09/2020 21:00	1	1
03/09/2020 22:00	1	1
03/09/2020 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	21	6
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/10/2020 00:00	1	1
03/10/2020 01:00	1	1
03/10/2020 02:00	1	1
03/10/2020 03:00	1	1
03/10/2020 04:00	1	1
03/10/2020 05:00	1	1
03/10/2020 06:00	1	1
03/10/2020 07:00	1	1
03/10/2020 08:00	1	1
03/10/2020 09:00	1	1
03/10/2020 10:00	1	1
03/10/2020 11:00	1	1
03/10/2020 12:00	1	1
03/10/2020 13:00	1	1
03/10/2020 14:00	1	1
03/10/2020 15:00	1	1
03/10/2020 16:00	1	1
03/10/2020 17:00	1	1
03/10/2020 18:00	1	1
03/10/2020 19:00	1	1
03/10/2020 20:00	1	1
03/10/2020 21:00	1	1
03/10/2020 22:00	1	1
03/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/11/2020 00:00	1	1
03/11/2020 01:00	1	1
03/11/2020 02:00	1	1
03/11/2020 03:00	1	1
03/11/2020 04:00	1	1
03/11/2020 05:00	1	1
03/11/2020 06:00	1	1
03/11/2020 07:00	1	1
03/11/2020 08:00	1	1
03/11/2020 09:00	1	1
03/11/2020 10:00	1	1
03/11/2020 11:00	1	1
03/11/2020 12:00	1	1
03/11/2020 13:00	1	1
03/11/2020 14:00	1	1
03/11/2020 15:00	1	1
03/11/2020 16:00	1	1
03/11/2020 17:00	1	1
03/11/2020 18:00	1	1
03/11/2020 19:00	1	1
03/11/2020 20:00	1	1
03/11/2020 21:00	1	1
03/11/2020 22:00	1	1
03/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/12/2020 00:00	1	1
03/12/2020 01:00	1	1
03/12/2020 02:00	1	1
03/12/2020 03:00	1	1
03/12/2020 04:00	1	1
03/12/2020 05:00	1	1
03/12/2020 06:00	1	1
03/12/2020 07:00	1	1
03/12/2020 08:00	1	1
03/12/2020 09:00	1	1
03/12/2020 10:00	1	1
03/12/2020 11:00	1	1
03/12/2020 12:00	1	1
03/12/2020 13:00	1	1
03/12/2020 14:00	1	1
03/12/2020 15:00	1	1
03/12/2020 16:00	1	1
03/12/2020 17:00	1	1
03/12/2020 18:00	1	1
03/12/2020 19:00	1	1
03/12/2020 20:00	1	1
03/12/2020 21:00	1	1
03/12/2020 22:00	1	1
03/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/13/2020 00:00	1	1
03/13/2020 01:00	1	1
03/13/2020 02:00	1	1
03/13/2020 03:00	1	1
03/13/2020 04:00	1	1
03/13/2020 05:00	1	1
03/13/2020 06:00	1	1
03/13/2020 07:00	1	1
03/13/2020 08:00	1	1
03/13/2020 09:00	1	1
03/13/2020 10:00	1	1
03/13/2020 11:00	1	1
03/13/2020 12:00	1	1
03/13/2020 13:00	1	1
03/13/2020 14:00	1	1
03/13/2020 15:00	1	1
03/13/2020 16:00	1	1
03/13/2020 17:00	1	1
03/13/2020 18:00	1	1
03/13/2020 19:00	1	1
03/13/2020 20:00	1	1
03/13/2020 21:00	1	1
03/13/2020 22:00	1	1
03/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/14/2020 00:00	1	1
03/14/2020 01:00	1	1
03/14/2020 02:00	1	1
03/14/2020 03:00	1	1
03/14/2020 04:00	1	1
03/14/2020 05:00	1	1
03/14/2020 06:00	1	1
03/14/2020 07:00	1	1
03/14/2020 08:00	1	1
03/14/2020 09:00	1	1
03/14/2020 10:00	1	1
03/14/2020 11:00	1	1
03/14/2020 12:00	1	1
03/14/2020 13:00	1	1
03/14/2020 14:00	1	1
03/14/2020 15:00	1	1
03/14/2020 16:00	1	1
03/14/2020 17:00	1	1
03/14/2020 18:00	1	1
03/14/2020 19:00	1	1
03/14/2020 20:00	1	1
03/14/2020 21:00	1	1
03/14/2020 22:00	1	1
03/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/15/2020 00:00	1	1
03/15/2020 01:00	1	1
03/15/2020 02:00	1	1
03/15/2020 03:00	1	1
03/15/2020 04:00	1	1
03/15/2020 05:00	1	1
03/15/2020 06:00	1	1
03/15/2020 07:00	1	1
03/15/2020 08:00	1	1
03/15/2020 09:00	1	1
03/15/2020 10:00	1	1
03/15/2020 11:00	1	1
03/15/2020 12:00	1	1
03/15/2020 13:00	1	1
03/15/2020 14:00	1	1
03/15/2020 15:00	1	1
03/15/2020 16:00	1	1
03/15/2020 17:00	1	1
03/15/2020 18:00	1	1
03/15/2020 19:00	1	1
03/15/2020 20:00	1	1
03/15/2020 21:00	1	1
03/15/2020 22:00	1	1
03/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/16/2020 00:00	1	1
03/16/2020 01:00	1	1
03/16/2020 02:00	1	1
03/16/2020 03:00	1	1
03/16/2020 04:00	1	1
03/16/2020 05:00	1	1
03/16/2020 06:00	1	1
03/16/2020 07:00	1	1
03/16/2020 08:00	1	1
03/16/2020 09:00	1	1
03/16/2020 10:00	1	1
03/16/2020 11:00	1	1
03/16/2020 12:00	1	1
03/16/2020 13:00	1	1
03/16/2020 14:00	1	1
03/16/2020 15:00	1	1
03/16/2020 16:00	1	1
03/16/2020 17:00	1	1
03/16/2020 18:00	1	1
03/16/2020 19:00	1	1
03/16/2020 20:00	1	1
03/16/2020 21:00	1	1
03/16/2020 22:00	1	1
03/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/17/2020 00:00	1	1
03/17/2020 01:00	1	1
03/17/2020 02:00	1	1
03/17/2020 03:00	1	1
03/17/2020 04:00	1	1
03/17/2020 05:00	1	1
03/17/2020 06:00	1	1
03/17/2020 07:00	1	1
03/17/2020 08:00	1	1
03/17/2020 09:00	1	1
03/17/2020 10:00	1	1
03/17/2020 11:00	1	1
03/17/2020 12:00	1	1
03/17/2020 13:00	1	1
03/17/2020 14:00	1	1
03/17/2020 15:00	1	1
03/17/2020 16:00	1	1
03/17/2020 17:00	1	1
03/17/2020 18:00	1	1
03/17/2020 19:00	1	1
03/17/2020 20:00	1	1
03/17/2020 21:00	1	1
03/17/2020 22:00	1	1
03/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/18/2020 00:00	1	1
03/18/2020 01:00	1	1
03/18/2020 02:00	1	1
03/18/2020 03:00	1	1
03/18/2020 04:00	1	1
03/18/2020 05:00	1	1
03/18/2020 06:00	1	1
03/18/2020 07:00	1	1
03/18/2020 08:00	1	1
03/18/2020 09:00	1	1
03/18/2020 10:00	1	1
03/18/2020 11:00	1	1
03/18/2020 12:00	1	1
03/18/2020 13:00	1	1
03/18/2020 14:00	1	1
03/18/2020 15:00	1	1
03/18/2020 16:00	1	1
03/18/2020 17:00	1	1
03/18/2020 18:00	1	1
03/18/2020 19:00	1	1
03/18/2020 20:00	1	1
03/18/2020 21:00	1	1
03/18/2020 22:00	1	1
03/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/19/2020 00:00	1	1
03/19/2020 01:00	1	1
03/19/2020 02:00	1	1
03/19/2020 03:00	1	1
03/19/2020 04:00	1	1
03/19/2020 05:00	1	1
03/19/2020 06:00	1	1
03/19/2020 07:00	1	1
03/19/2020 08:00	1	1
03/19/2020 09:00	1	1
03/19/2020 10:00	1	1
03/19/2020 11:00	1	1
03/19/2020 12:00	1	1
03/19/2020 13:00	1	0
03/19/2020 14:00	1	0
03/19/2020 15:00	1	0
03/19/2020 16:00	1	1
03/19/2020 17:00	1	1
03/19/2020 18:00	1	1
03/19/2020 19:00	1	1
03/19/2020 20:00	1	1
03/19/2020 21:00	1	1
03/19/2020 22:00	1	1
03/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/20/2020 00:00	1	1
03/20/2020 01:00	1	1
03/20/2020 02:00	1	1
03/20/2020 03:00	1	1
03/20/2020 04:00	1	1
03/20/2020 05:00	1	1
03/20/2020 06:00	1	1
03/20/2020 07:00	1	1
03/20/2020 08:00	1	1
03/20/2020 09:00	1	1
03/20/2020 10:00	1	1
03/20/2020 11:00	1	1
03/20/2020 12:00	1	1
03/20/2020 13:00	1	1
03/20/2020 14:00	1	1
03/20/2020 15:00	1	1
03/20/2020 16:00	1	1
03/20/2020 17:00	1	1
03/20/2020 18:00	1	1
03/20/2020 19:00	1	1
03/20/2020 20:00	1	1
03/20/2020 21:00	1	1
03/20/2020 22:00	1	1
03/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/21/2020 00:00	1	1
03/21/2020 01:00	1	1
03/21/2020 02:00	1	1
03/21/2020 03:00	1	1
03/21/2020 04:00	1	1
03/21/2020 05:00	1	1
03/21/2020 06:00	1	1
03/21/2020 07:00	1	2
03/21/2020 08:00	1	2
03/21/2020 09:00	1	2
03/21/2020 10:00	1	2
03/21/2020 11:00	1	2
03/21/2020 12:00	1	2
03/21/2020 13:00	1	2
03/21/2020 14:00	1	2
03/21/2020 15:00	1	2
03/21/2020 16:00	1	2
03/21/2020 17:00	1	2
03/21/2020 18:00	1	2
03/21/2020 19:00	1	2
03/21/2020 20:00	1	2
03/21/2020 21:00	1	2
03/21/2020 22:00	1	2
03/21/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/22/2020 00:00	1	2
03/22/2020 01:00	1	2
03/22/2020 02:00	1	2
03/22/2020 03:00	1	2
03/22/2020 04:00	1	2
03/22/2020 05:00	1	2
03/22/2020 06:00	1	2
03/22/2020 07:00	1	2
03/22/2020 08:00	1	2
03/22/2020 09:00	1	2
03/22/2020 10:00	1	2
03/22/2020 11:00	1	2
03/22/2020 12:00	1	2
03/22/2020 13:00	1	2
03/22/2020 14:00	1	2
03/22/2020 15:00	1	2
03/22/2020 16:00	1	2
03/22/2020 17:00	1	16
03/22/2020 18:00	1	21
03/22/2020 19:00	1	23
03/22/2020 20:00	1	23
03/22/2020 21:00	1	8
03/22/2020 22:00	1	3
03/22/2020 23:00	1	0
Average/Sum#:	1	5
Minimum:	1	0
Maximum:	1	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/23/2020 00:00	1	0
03/23/2020 01:00	1	0
03/23/2020 02:00	1	2
03/23/2020 03:00	1	2
03/23/2020 04:00	1	2
03/23/2020 05:00	1	2
03/23/2020 06:00	1	2
03/23/2020 07:00	1	2
03/23/2020 08:00	1	2
03/23/2020 09:00	1	2
03/23/2020 10:00	1	2
03/23/2020 11:00	1	2
03/23/2020 12:00	1	2
03/23/2020 13:00	1	2
03/23/2020 14:00	1	2
03/23/2020 15:00	1	2
03/23/2020 16:00	1	2
03/23/2020 17:00	1	17
03/23/2020 18:00	1	21
03/23/2020 19:00	1	25
03/23/2020 20:00	1	23
03/23/2020 21:00	1	8
03/23/2020 22:00	1	4
03/23/2020 23:00	1	1
Average/Sum#:	1	5
Minimum:	1	0
Maximum:	1	25
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/24/2020 00:00	1	1
03/24/2020 01:00	1	0
03/24/2020 02:00	16	0
03/24/2020 03:00	22	0
03/24/2020 04:00	22	1
03/24/2020 05:00	21	1
03/24/2020 06:00	6	1
03/24/2020 07:00	1	1
03/24/2020 08:00	1	1
03/24/2020 09:00	1	1
03/24/2020 10:00	1	1
03/24/2020 11:00	1	1
03/24/2020 12:00	1	1
03/24/2020 13:00	1	1
03/24/2020 14:00	1	1
03/24/2020 15:00	1	1
03/24/2020 16:00	1	1
03/24/2020 17:00	1	1
03/24/2020 18:00	1	1
03/24/2020 19:00	1	1
03/24/2020 20:00	1	1
03/24/2020 21:00	1	1
03/24/2020 22:00	1	1
03/24/2020 23:00	1	2
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	22	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/25/2020 00:00	1	2
03/25/2020 01:00	1	2
03/25/2020 02:00	1	2
03/25/2020 03:00	1	2
03/25/2020 04:00	1	2
03/25/2020 05:00	1	2
03/25/2020 06:00	1	2
03/25/2020 07:00	1	2
03/25/2020 08:00	1	2
03/25/2020 09:00	1	2
03/25/2020 10:00	1	2
03/25/2020 11:00	1	2
03/25/2020 12:00	1	2
03/25/2020 13:00	1	2
03/25/2020 14:00	1	2
03/25/2020 15:00	1	2
03/25/2020 16:00	1	2
03/25/2020 17:00	1	2
03/25/2020 18:00	1	2
03/25/2020 19:00	1	2
03/25/2020 20:00	1	2
03/25/2020 21:00	1	2
03/25/2020 22:00	1	2
03/25/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/26/2020 00:00	1	2
03/26/2020 01:00	1	2
03/26/2020 02:00	1	2
03/26/2020 03:00	1	2
03/26/2020 04:00	1	2
03/26/2020 05:00	1	2
03/26/2020 06:00	1	2
03/26/2020 07:00	1	2
03/26/2020 08:00	1	2
03/26/2020 09:00	1	2
03/26/2020 10:00	1	2
03/26/2020 11:00	1	2
03/26/2020 12:00	1	2
03/26/2020 13:00	1	2
03/26/2020 14:00	1	2
03/26/2020 15:00	1	2
03/26/2020 16:00	1	2
03/26/2020 17:00	1	2
03/26/2020 18:00	1	2
03/26/2020 19:00	1	2
03/26/2020 20:00	1	2
03/26/2020 21:00	1	2
03/26/2020 22:00	1	2
03/26/2020 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/27/2020 00:00	1	2
03/27/2020 01:00	1	2
03/27/2020 02:00	1	2
03/27/2020 03:00	1	2
03/27/2020 04:00	1	2
03/27/2020 05:00	1	2
03/27/2020 06:00	1	2
03/27/2020 07:00	1	2
03/27/2020 08:00	1	2
03/27/2020 09:00	1	2
03/27/2020 10:00	1	2
03/27/2020 11:00	1	2
03/27/2020 12:00	1	2
03/27/2020 13:00	1	2
03/27/2020 14:00	1	2
03/27/2020 15:00	1	2
03/27/2020 16:00	1	2
03/27/2020 17:00	1	16
03/27/2020 18:00	1	19
03/27/2020 19:00	1	23
03/27/2020 20:00	1	23
03/27/2020 21:00	1	9
03/27/2020 22:00	1	5
03/27/2020 23:00	15	0
Average/Sum#:	2	5
Minimum:	1	0
Maximum:	15	23
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/28/2020 00:00	17	1
03/28/2020 01:00	17	1
03/28/2020 02:00	17	1
03/28/2020 03:00	4	1
03/28/2020 04:00	1	1
03/28/2020 05:00	1	1
03/28/2020 06:00	1	1
03/28/2020 07:00	1	1
03/28/2020 08:00	1	1
03/28/2020 09:00	1	1
03/28/2020 10:00	1	1
03/28/2020 11:00	1	1
03/28/2020 12:00	1	1
03/28/2020 13:00	1	1
03/28/2020 14:00	1	1
03/28/2020 15:00	1	1
03/28/2020 16:00	1	1
03/28/2020 17:00	1	1
03/28/2020 18:00	1	1
03/28/2020 19:00	1	1
03/28/2020 20:00	1	1
03/28/2020 21:00	1	1
03/28/2020 22:00	1	1
03/28/2020 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	17	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/29/2020 00:00	1	1
03/29/2020 01:00	1	1
03/29/2020 02:00	1	1
03/29/2020 03:00	1	1
03/29/2020 04:00	1	1
03/29/2020 05:00	1	1
03/29/2020 06:00	1	1
03/29/2020 07:00	1	1
03/29/2020 08:00	1	1
03/29/2020 09:00	1	1
03/29/2020 10:00	1	1
03/29/2020 11:00	1	1
03/29/2020 12:00	1	1
03/29/2020 13:00	1	1
03/29/2020 14:00	1	1
03/29/2020 15:00	1	1
03/29/2020 16:00	1	1
03/29/2020 17:00	1	1
03/29/2020 18:00	1	1
03/29/2020 19:00	1	1
03/29/2020 20:00	1	1
03/29/2020 21:00	1	1
03/29/2020 22:00	1	1
03/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/30/2020 00:00	1	1
03/30/2020 01:00	1	1
03/30/2020 02:00	1	1
03/30/2020 03:00	1	1
03/30/2020 04:00	1	1
03/30/2020 05:00	1	1
03/30/2020 06:00	1	1
03/30/2020 07:00	1	1
03/30/2020 08:00	1	1
03/30/2020 09:00	1	1
03/30/2020 10:00	1	1
03/30/2020 11:00	1	1
03/30/2020 12:00	1	1
03/30/2020 13:00	1	1
03/30/2020 14:00	1	1
03/30/2020 15:00	1	1
03/30/2020 16:00	1	1
03/30/2020 17:00	1	1
03/30/2020 18:00	1	1
03/30/2020 19:00	1	1
03/30/2020 20:00	1	1
03/30/2020 21:00	1	1
03/30/2020 22:00	1	1
03/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:11 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
03/31/2020 00:00	1	1
03/31/2020 01:00	1	1
03/31/2020 02:00	1	1
03/31/2020 03:00	1	1
03/31/2020 04:00	1	1
03/31/2020 05:00	1	1
03/31/2020 06:00	1	1
03/31/2020 07:00	1	2
03/31/2020 08:00	1	2
03/31/2020 09:00	1	2
03/31/2020 10:00	1	2
03/31/2020 11:00	1	2
03/31/2020 12:00	1	2
03/31/2020 13:00	1	2
03/31/2020 14:00	1	2
03/31/2020 15:00	1	2
03/31/2020 16:00	1	2
03/31/2020 17:00	1	2
03/31/2020 18:00	1	12
03/31/2020 19:00	1	15
03/31/2020 20:00	1	15
03/31/2020 21:00	1	15
03/31/2020 22:00	1	4
03/31/2020 23:00	1	0
Average/Sum#:	1	4
Minimum:	1	0
Maximum:	1	15
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:15 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 67.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 24.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**67.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:16 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #28

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59
Generated: 04/08/2020 08:20

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,348.00 Hour(s)
Operating time for CMS: 1,348.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:21 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,348.00 Hour(s)
Operating time for CMS: 1,348.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:21 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,348.00 Hour(s)
Operating time for CMS: 1,348.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	2
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:22 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,348.00 Hour(s)
Operating time for CMS: 1,348.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.15
4. Total Availability as a percentage of operating time	99.85

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59
Generated: 04/08/2020 08:22

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,481.00 Hour(s)
Operating time for CMS: 1,481.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:22 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,481.00 Hour(s)
Operating time for CMS: 1,481.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:23 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,481.00 Hour(s)
Operating time for CMS: 1,481.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59
Generated: 04/08/2020 08:23

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,481.00 Hour(s)
Operating time for CMS: 1,481.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	3
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.27
4. Total Availability as a percentage of operating time	99.73

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:24 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:25 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:25 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:27 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:28 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:28 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:29 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:29 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:41 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,348.00 Hour(s)
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/14/2020 14:00	01/14/2020 14:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	03/10/2020 08:00	03/10/2020 08:59	1	13 - Maintenance	8 - Quarterly Maintenance

Total Operating Time:	**1,348.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.85 %**
Percent Monitor Downtime:	**0.15 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	1	50.00
3	Reason	Quality assurance calibration	1	50.00
4	Action	Quarterly linearity/cga	1	50.00
8	Action	Quarterly Maintenance	1	50.00

Invalid Data Report

CT1 - Stack NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:41 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,348.00 Hour(s)
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/14/2020 14:00	01/14/2020 14:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	03/10/2020 08:00	03/10/2020 08:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	**1,348.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.85 %**
Percent Monitor Downtime:	**0.15 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00
4	Action	Quarterly linearity/cga	2	100.00

Invalid Data Report

CT2 - Stack CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:42 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,481.00 Hour(s)
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/14/2020 10:00	01/14/2020 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	01/14/2020 13:00	01/14/2020 14:59	2	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	03/10/2020 11:00	03/10/2020 11:59	1	13 - Maintenance	8 - Quarterly Maintenance

Total Operating Time:	**1,481.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.73 %**
Percent Monitor Downtime:	**0.27 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	1	25.00
3	Reason	Quality assurance calibration	3	75.00
4	Action	Quarterly linearity/cga	3	75.00
8	Action	Quarterly Maintenance	1	25.00

Invalid Data Report

CT2 - Stack NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:42 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,481.00 Hour(s)
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	01/14/2020 10:00	01/14/2020 10:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
2	01/14/2020 13:00	01/14/2020 14:59	2	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	03/10/2020 11:00	03/10/2020 11:59	1	13 - Maintenance	8 - Quarterly Maintenance

Total Operating Time:	**1,481.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.73 %**
Percent Monitor Downtime:	**0.27 %**

Report Code	Type	Text	Duration	Duration Percent
13	Reason	Maintenance	1	25.00
3	Reason	Quality assurance calibration	3	75.00
4	Action	Quarterly linearity/cga	3	75.00
8	Action	Quarterly Maintenance	1	25.00

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2020 00:00	0.1	12.6	2,047.4	0.2	1.4	1	1	1
01/01/2020 01:00	0.2	12.7	2,032.6	0.4	1.4	1	1	1
01/01/2020 02:00	0.0	14.6	1,132.0	0.0	0.8	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.3	1,737.3	0.2	1.2	3 #	2 #	3 #
Minimum:	0.0	12.6	1,132.0	0.0	0.8	0	0	0
Maximum:	0.2	14.6	2,047.4	0.4	1.4	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 07:00	0.0	18.2	375.4	0.0	0.3	1	0	0
01/02/2020 08:00	0.0	15.8	794.9	0.0	0.6	1	0	0
01/02/2020 09:00	0.6	13.9	1,520.1	0.6	1.1	1	1	0
01/02/2020 10:00	0.6	13.9	1,653.2	0.6	1.2	1	1	0
01/02/2020 11:00	0.6	13.9	1,669.7	0.6	1.2	1	1	0
01/02/2020 12:00	0.6	13.9	1,615.8	0.6	1.1	1	1	0
01/02/2020 13:00	0.6	13.9	1,639.0	0.6	1.1	1	1	0
01/02/2020 14:00	0.6	13.9	1,625.1	0.6	1.1	1	1	0
01/02/2020 15:00	0.7	13.9	1,587.2	0.7	1.1	1	1	1
01/02/2020 16:00	0.2	12.6	2,022.4	0.4	1.4	1	1	1
01/02/2020 17:00	0.2	12.4	2,057.7	0.4	1.4	1	1	1
01/02/2020 18:00	0.2	12.3	2,101.3	0.4	1.5	1	1	1
01/02/2020 19:00	0.4	12.3	2,102.5	0.5	1.5	1	1	1
01/02/2020 20:00	0.2	12.3	2,108.2	0.4	1.5	1	1	1
01/02/2020 21:00	0.4	12.1	2,127.6	0.5	1.5	1	1	1
01/02/2020 22:00	0.4	12.2	2,114.6	0.5	1.5	1	1	1
01/02/2020 23:00	0.4	12.6	2,062.2	0.5	1.4	1	1	1
Average/Sum#:	0.4	13.5	1,716.3	0.5	1.2	17 #	15 #	9 #
Minimum:	0.0	12.1	375.4	0.0	0.3	0	0	0
Maximum:	0.7	18.2	2,127.6	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2020 00:00	0.4	12.7	2,043.7	0.5	1.4	1	1	1
01/03/2020 01:00	0.4	12.6	2,040.5	0.5	1.4	1	1	1
01/03/2020 02:00	0.4	12.7	2,034.5	0.5	1.4	1	1	1
01/03/2020 03:00	0.4	12.7	2,046.3	0.5	1.4	1	1	1
01/03/2020 04:00	0.4	12.7	2,048.4	0.5	1.4	1	1	1
01/03/2020 05:00	0.2	12.7	2,037.6	0.4	1.4	1	1	1
01/03/2020 06:00	0.2	12.8	2,018.8	0.4	1.4	1	1	1
01/03/2020 07:00	0.2	12.8	2,033.2	0.4	1.4	1	1	1
01/03/2020 08:00	0.2	13.3	1,883.8	0.4	1.3	1	1	1
01/03/2020 09:00	0.6	13.9	1,521.2	0.6	1.1	1	1	0
01/03/2020 10:00	0.6	13.9	1,546.6	0.6	1.1	1	1	0
01/03/2020 11:00	0.6	13.9	1,592.3	0.6	1.1	1	1	0
01/03/2020 12:00	0.6	13.9	1,674.7	0.6	1.2	1	1	0
01/03/2020 13:00	0.6	13.9	1,653.4	0.6	1.2	1	1	0
01/03/2020 14:00	0.6	13.9	1,540.0	0.6	1.1	1	1	0
01/03/2020 15:00	0.6	13.9	1,574.9	0.6	1.1	1	1	0
01/03/2020 16:00	0.2	13.0	1,947.1	0.4	1.4	1	1	1
01/03/2020 17:00	0.2	12.7	2,027.7	0.4	1.4	1	1	1
01/03/2020 18:00	0.2	12.6	2,057.3	0.4	1.4	1	1	1
01/03/2020 19:00	0.2	12.6	2,044.2	0.4	1.4	1	1	1
01/03/2020 20:00	0.2	12.6	2,062.8	0.4	1.4	1	1	1
01/03/2020 21:00	0.2	12.3	2,116.1	0.4	1.5	1	1	1
01/03/2020 22:00	0.2	12.4	2,118.5	0.4	1.5	1	1	1
01/03/2020 23:00	0.0	13.2	1,678.7	0.0	1.2	1	0	1
Average/Sum#:	0.4	13.1	1,889.3	0.5	1.3	24 #	23 #	17 #
Minimum:	0.0	12.3	1,521.2	0.0	1.1	1	0	0
Maximum:	0.6	13.9	2,118.5	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2020 00:00	0.0	19.4	0.2	0.0	0.0	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	19.4	0.2	0.0	0.0	1 #	0 #	0 #
Minimum:	0.0	19.4	0.2	0.0	0.0	0	0	0
Maximum:	0.0	19.4	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 07:00	0.0	19.5	212.8	0.0	0.1	1	0	0
01/06/2020 08:00	0.0	16.6	601.7	0.0	0.4	1	0	0
01/06/2020 09:00	0.0	14.1	1,529.5	0.0	1.1	1	0	0
01/06/2020 10:00	0.6	13.9	1,546.4	0.6	1.1	1	1	0
01/06/2020 11:00	0.6	13.9	1,643.7	0.6	1.2	1	1	0
01/06/2020 12:00	0.6	13.9	1,574.9	0.6	1.1	1	1	0
01/06/2020 13:00	0.6	13.9	1,627.9	0.6	1.1	1	1	0
01/06/2020 14:00	0.6	13.9	1,558.1	0.6	1.1	1	1	0
01/06/2020 15:00	0.7	13.9	1,543.6	0.7	1.1	1	1	1
01/06/2020 16:00	0.1	12.8	2,021.8	0.2	1.4	1	1	1
01/06/2020 17:00	0.4	12.6	2,054.0	0.5	1.4	1	1	1
01/06/2020 18:00	0.5	12.7	2,048.2	0.5	1.4	1	1	1
01/06/2020 19:00	0.5	12.8	2,036.6	0.5	1.4	1	1	1
01/06/2020 20:00	0.5	12.8	2,030.5	0.5	1.4	1	1	1
01/06/2020 21:00	0.5	12.8	2,035.0	0.5	1.4	1	1	1
01/06/2020 22:00	0.5	12.7	2,058.6	0.5	1.4	1	1	1
01/06/2020 23:00	0.5	13.0	2,018.3	0.5	1.4	1	1	1
Average/Sum#:	0.4	13.9	1,655.4	0.4	1.1	17 #	14 #	9 #
Minimum:	0.0	12.6	212.8	0.0	0.1	0	0	0
Maximum:	0.7	19.5	2,058.6	0.7	1.4	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/07/2020 00:00	0.5	12.8	2,038.3	0.5	1.4	1	1	1
01/07/2020 01:00	0.5	13.0	2,021.6	0.5	1.4	1	1	1
01/07/2020 02:00	0.4	13.0	2,010.9	0.5	1.4	1	1	1
01/07/2020 03:00	0.4	13.0	2,009.9	0.5	1.4	1	1	1
01/07/2020 04:00	0.4	12.9	2,029.6	0.5	1.4	1	1	1
01/07/2020 05:00	0.4	12.9	2,035.9	0.5	1.4	1	1	1
01/07/2020 06:00	0.4	12.9	2,035.6	0.5	1.4	1	1	1
01/07/2020 07:00	0.4	12.7	2,081.0	0.5	1.5	1	1	1
01/07/2020 08:00	0.2	13.3	1,926.0	0.4	1.3	1	1	1
01/07/2020 09:00	0.6	13.8	1,715.4	0.6	1.2	1	1	0
01/07/2020 10:00	0.6	13.8	1,617.3	0.6	1.1	1	1	0
01/07/2020 11:00	0.6	13.8	1,604.8	0.6	1.1	1	1	0
01/07/2020 12:00	0.6	13.8	1,671.1	0.6	1.2	1	1	0
01/07/2020 13:00	0.6	13.8	1,640.1	0.6	1.1	1	1	0
01/07/2020 14:00	0.6	13.8	1,586.1	0.6	1.1	1	1	0
01/07/2020 15:00	0.7	13.8	1,565.3	0.7	1.1	1	1	1
01/07/2020 16:00	-0.1	12.9	2,010.7	0.1	1.4	1	1	1
01/07/2020 17:00	0.1	12.8	2,037.7	0.2	1.4	1	1	1
01/07/2020 18:00	0.2	12.8	2,035.5	0.4	1.4	1	1	1
01/07/2020 19:00	0.2	12.8	2,024.5	0.4	1.4	1	1	1
01/07/2020 20:00	0.1	12.7	2,058.3	0.2	1.4	1	1	1
01/07/2020 21:00	0.1	12.6	2,076.5	0.2	1.5	1	1	1
01/07/2020 22:00	0.0	14.2	1,263.2	0.0	0.9	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.2	1,873.7	0.4	1.3	23 #	22 #	17 #
Minimum:	-0.1	12.6	1,263.2	0.0	0.9	0	0	0
Maximum:	0.7	14.2	2,081.0	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/09/2020 02:00	0.0	18.2	381.2	0.0	0.3	1	0	0
01/09/2020 03:00	0.0	15.4	916.2	0.0	0.6	1	0	0
01/09/2020 04:00	0.6	13.8	1,685.2	0.6	1.2	1	1	0
01/09/2020 05:00	0.6	13.8	1,628.3	0.6	1.1	1	1	0
01/09/2020 06:00	0.6	13.9	1,386.6	0.6	1.0	1	1	0
01/09/2020 07:00	0.6	13.8	1,483.0	0.6	1.0	1	1	0
01/09/2020 08:00	0.6	13.8	1,623.6	0.6	1.1	1	1	0
01/09/2020 09:00	0.6	13.8	1,697.4	0.6	1.2	1	1	0
01/09/2020 10:00	0.6	13.8	1,573.0	0.6	1.1	1	1	0
01/09/2020 11:00	0.6	13.8	1,668.1	0.6	1.2	1	1	0
01/09/2020 12:00	0.6	13.8	1,636.1	0.6	1.1	1	1	0
01/09/2020 13:00	0.6	13.9	1,677.5	0.6	1.2	1	1	0
01/09/2020 14:00	0.6	13.9	1,605.1	0.6	1.1	1	1	0
01/09/2020 15:00	0.7	13.9	1,560.0	0.7	1.1	1	1	1
01/09/2020 16:00	0.1	12.7	2,038.7	0.2	1.4	1	1	1
01/09/2020 17:00	0.2	12.4	2,100.4	0.4	1.5	1	1	1
01/09/2020 18:00	0.2	12.2	2,144.2	0.4	1.5	1	1	1
01/09/2020 19:00	0.2	12.2	2,135.9	0.4	1.5	1	1	1
01/09/2020 20:00	0.2	12.2	2,140.8	0.4	1.5	1	1	1
01/09/2020 21:00	0.2	12.3	2,113.8	0.4	1.5	1	1	1
01/09/2020 22:00	0.2	12.3	2,128.4	0.4	1.5	1	1	1
01/09/2020 23:00	0.2	12.3	2,125.5	0.4	1.5	1	1	1
Average/Sum#:	0.4	13.6	1,702.2	0.5	1.2	22 #	20 #	9 #
Minimum:	0.0	12.2	381.2	0.0	0.3	0	0	0
Maximum:	0.7	18.2	2,144.2	0.7	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/10/2020 00:00	0.4	12.5	2,074.3	0.5	1.5	1	1	1
01/10/2020 01:00	0.4	12.7	2,055.4	0.5	1.4	1	1	1
01/10/2020 02:00	0.2	12.4	2,119.4	0.4	1.5	1	1	1
01/10/2020 03:00	0.2	12.3	2,124.4	0.4	1.5	1	1	1
01/10/2020 04:00	0.4	12.7	2,044.1	0.5	1.4	1	1	1
01/10/2020 05:00	0.2	12.7	2,061.3	0.4	1.4	1	1	1
01/10/2020 06:00	0.1	12.5	2,141.0	0.2	1.5	1	1	1
01/10/2020 07:00	0.2	12.1	2,203.0	0.4	1.5	1	1	1
01/10/2020 08:00	0.4	12.7	2,076.8	0.5	1.5	1	1	1
01/10/2020 09:00	0.2	13.3	1,914.2	0.4	1.3	1	1	1
01/10/2020 10:00	0.6	13.9	1,696.9	0.6	1.2	1	1	0
01/10/2020 11:00	0.6	13.8	1,656.6	0.6	1.2	1	1	0
01/10/2020 12:00	0.6	13.8	1,630.8	0.6	1.1	1	1	0
01/10/2020 13:00	0.6	13.8	1,675.0	0.6	1.2	1	1	0
01/10/2020 14:00	0.6	13.9	1,533.2	0.6	1.1	1	1	0
01/10/2020 15:00	0.7	13.8	1,540.9	0.7	1.1	1	1	1
01/10/2020 16:00	0.1	12.8	2,034.1	0.2	1.4	1	1	1
01/10/2020 17:00	0.1	12.5	2,084.9	0.2	1.5	1	1	1
01/10/2020 18:00	0.1	12.4	2,117.8	0.2	1.5	1	1	1
01/10/2020 19:00	0.2	12.5	2,094.9	0.4	1.5	1	1	1
01/10/2020 20:00	0.2	12.6	2,082.0	0.4	1.5	1	1	1
01/10/2020 21:00	0.2	12.6	2,069.1	0.4	1.4	1	1	1
01/10/2020 22:00	0.2	12.7	2,038.2	0.4	1.4	1	1	1
01/10/2020 23:00	0.2	12.8	2,021.5	0.4	1.4	1	1	1
Average/Sum#:	0.3	12.9	1,962.1	0.4	1.4	24 #	24 #	19 #
Minimum:	0.1	12.1	1,533.2	0.2	1.1	1	1	0
Maximum:	0.7	13.9	2,203.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2020 00:00	0.2	12.8	2,034.9	0.4	1.4	1	1	1
01/11/2020 01:00	0.2	12.8	2,029.7	0.4	1.4	1	1	1
01/11/2020 02:00	0.2	12.8	2,037.5	0.4	1.4	1	1	1
01/11/2020 03:00	0.2	12.9	2,038.0	0.4	1.4	1	1	1
01/11/2020 04:00	0.2	12.8	2,045.4	0.4	1.4	1	1	1
01/11/2020 05:00	0.2	12.8	2,033.9	0.4	1.4	1	1	1
01/11/2020 06:00	0.2	12.8	2,036.6	0.4	1.4	1	1	1
01/11/2020 07:00	0.2	12.8	2,042.0	0.4	1.4	1	1	1
01/11/2020 08:00	0.0	14.2	1,290.8	0.0	0.9	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.0	1,954.3	0.4	1.3	9 #	8 #	9 #
Minimum:	0.0	12.8	1,290.8	0.0	0.9	0	0	0
Maximum:	0.2	14.2	2,045.4	0.4	1.4	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/13/2020 03:00	0.0	18.8	311.8	0.0	0.2	1	0	0
01/13/2020 04:00	0.0	16.7	590.4	0.0	0.4	1	0	0
01/13/2020 05:00	0.0	15.4	811.9	0.0	0.6	1	0	0
01/13/2020 06:00	0.0	13.8	1,629.4	0.0	1.1	1	0	0
01/13/2020 07:00	0.6	13.8	1,613.3	0.6	1.1	1	1	0
01/13/2020 08:00	0.6	13.8	1,540.0	0.6	1.1	1	1	0
01/13/2020 09:00	0.6	13.8	1,661.0	0.6	1.2	1	1	0
01/13/2020 10:00	0.6	13.8	1,591.1	0.6	1.1	1	1	0
01/13/2020 11:00	0.6	13.8	1,520.2	0.6	1.1	1	1	0
01/13/2020 12:00	0.6	13.8	1,612.6	0.6	1.1	1	1	0
01/13/2020 13:00	0.6	13.8	1,689.3	0.6	1.2	1	1	0
01/13/2020 14:00	0.6	13.9	1,571.8	0.6	1.1	1	1	0
01/13/2020 15:00	0.7	13.8	1,547.6	0.7	1.1	1	1	1
01/13/2020 16:00	-0.2	12.7	2,028.5	0.1	1.4	1	1	1
01/13/2020 17:00	-0.2	12.0	2,152.7	0.1	1.5	1	1	1
01/13/2020 18:00	-0.1	11.9	2,171.5	0.2	1.5	1	1	1
01/13/2020 19:00	-0.1	12.0	2,158.4	0.2	1.5	1	1	1
01/13/2020 20:00	-0.1	12.0	2,145.6	0.2	1.5	1	1	1
01/13/2020 21:00	-0.1	12.3	2,091.7	0.2	1.5	1	1	1
01/13/2020 22:00	-0.1	12.4	2,057.4	0.2	1.4	1	1	1
01/13/2020 23:00	-0.1	12.5	2,041.2	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.7	1,644.6	0.3	1.1	21 #	17 #	9 #
Minimum:	-0.2	11.9	311.8	0.0	0.2	0	0	0
Maximum:	0.7	18.8	2,171.5	0.7	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/14/2020 00:00	-0.1	12.5	2,050.6	0.1	1.4	1	1	1
01/14/2020 01:00	-0.1	12.5	2,039.4	0.1	1.4	1	1	1
01/14/2020 02:00	-0.1	12.5	2,043.5	0.1	1.4	1	1	1
01/14/2020 03:00	-0.1	12.5	2,041.6	0.1	1.4	1	1	1
01/14/2020 04:00	-0.1	12.6	2,042.3	0.1	1.4	1	1	1
01/14/2020 05:00	-0.2	12.4	2,072.5	0.1	1.5	1	1	1
01/14/2020 06:00	-0.2	12.3	2,112.3	0.1	1.5	1	1	1
01/14/2020 07:00	-0.1	12.0	2,182.9	0.2	1.5	1	1	1
01/14/2020 08:00	-0.1	12.6	2,051.7	0.1	1.4	1	1	1
01/14/2020 09:00	-0.1	12.6	1,990.6	0.1	1.4	1	1	1
01/14/2020 10:00	0.6	13.8	1,676.4	0.6	1.2	1	1	0
01/14/2020 11:00	0.6	13.8	1,689.2	0.6	1.2	1	1	0
01/14/2020 12:00	0.6	13.8	1,659.1	0.6	1.2	1	1	0
01/14/2020 13:00	0.6	13.8	1,681.2	0.6	1.2	1	1	0
01/14/2020 14:00	0.6	0.0	1,625.9	0.6	1.1	1	1	0
01/14/2020 15:00	0.6	13.8	1,533.7	0.6	1.1	1	1	0
01/14/2020 16:00	0.5	13.8	1,548.7	0.5	1.1	1	1	1
01/14/2020 17:00	-0.4	12.8	2,001.0	-0.1	1.4	1	1	1
01/14/2020 18:00	-0.2	12.6	2,044.7	0.1	1.4	1	1	1
01/14/2020 19:00	-0.1	12.6	2,053.8	0.1	1.4	1	1	1
01/14/2020 20:00	-0.2	12.4	2,093.2	0.1	1.5	1	1	1
01/14/2020 21:00	-0.2	12.5	2,076.4	0.1	1.5	1	1	1
01/14/2020 22:00	-0.1	12.7	2,043.8	0.1	1.4	1	1	1
01/14/2020 23:00	-0.2	13.0	1,985.9	0.1	1.4	1	1	1
Average/Sum#:	0.0	12.9	1,930.9	0.2	1.4	24 #	24 #	18 #
Minimum:	-0.4	12.0	1,533.7	-0.1	1.1	1	1	0
Maximum:	0.6	13.8	2,182.9	0.6	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2020 00:00	-0.1	12.8	2,036.4	0.1	1.4	1	1	1
01/15/2020 01:00	-0.1	12.7	2,039.9	0.1	1.4	1	1	1
01/15/2020 02:00	-0.1	12.7	2,042.7	0.1	1.4	1	1	1
01/15/2020 03:00	-0.1	12.8	2,039.6	0.1	1.4	1	1	1
01/15/2020 04:00	-0.1	12.8	2,041.3	0.1	1.4	1	1	1
01/15/2020 05:00	-0.2	12.6	2,068.0	0.1	1.4	1	1	1
01/15/2020 06:00	-0.2	12.2	2,180.0	0.1	1.5	1	1	1
01/15/2020 07:00	-0.2	11.7	2,289.4	0.1	1.6	1	1	1
01/15/2020 08:00	-0.1	12.7	2,038.9	0.1	1.4	1	1	1
01/15/2020 09:00	0.6	13.8	1,610.9	0.6	1.1	1	1	0
01/15/2020 10:00	0.6	13.8	1,652.5	0.6	1.2	1	1	0
01/15/2020 11:00	0.6	13.8	1,668.7	0.6	1.2	1	1	0
01/15/2020 12:00	0.6	13.8	1,627.7	0.6	1.1	1	1	0
01/15/2020 13:00	0.6	13.8	1,672.1	0.6	1.2	1	1	0
01/15/2020 14:00	0.6	13.8	1,687.2	0.6	1.2	1	1	0
01/15/2020 15:00	0.7	13.8	1,590.5	0.7	1.1	1	1	1
01/15/2020 16:00	-0.4	12.5	2,055.4	-0.1	1.4	1	1	1
01/15/2020 17:00	-0.2	12.0	2,157.4	0.1	1.5	1	1	1
01/15/2020 18:00	-0.2	12.2	2,131.7	0.1	1.5	1	1	1
01/15/2020 19:00	-0.2	11.9	2,194.2	0.1	1.5	1	1	1
01/15/2020 20:00	-0.1	11.9	2,187.8	0.2	1.5	1	1	1
01/15/2020 21:00	-0.1	11.9	2,172.1	0.2	1.5	1	1	1
01/15/2020 22:00	-0.1	12.3	2,091.6	0.2	1.5	1	1	1
01/15/2020 23:00	-0.1	12.5	2,055.1	0.1	1.4	1	1	1
Average/Sum#:	0.1	12.8	1,972.1	0.3	1.4	24 #	24 #	18 #
Minimum:	-0.4	11.7	1,590.5	-0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,289.4	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2020 00:00	-0.1	12.6	2,039.7	0.1	1.4	1	1	1
01/16/2020 01:00	-0.2	12.5	2,042.3	0.1	1.4	1	1	1
01/16/2020 02:00	-0.2	12.5	2,045.3	0.1	1.4	1	1	1
01/16/2020 03:00	-0.2	12.5	2,047.5	0.1	1.4	1	1	1
01/16/2020 04:00	-0.2	12.5	2,050.7	0.1	1.4	1	1	1
01/16/2020 05:00	-0.2	12.4	2,046.7	0.1	1.4	1	1	1
01/16/2020 06:00	-0.2	12.3	2,078.5	0.1	1.5	1	1	1
01/16/2020 07:00	-0.2	11.9	2,169.9	0.1	1.5	1	1	1
01/16/2020 08:00	-0.2	12.3	2,071.2	0.1	1.4	1	1	1
01/16/2020 09:00	-0.2	12.8	1,966.5	0.1	1.4	1	1	1
01/16/2020 10:00	0.6	13.8	1,659.5	0.6	1.2	1	1	0
01/16/2020 11:00	0.6	13.8	1,574.7	0.6	1.1	1	1	0
01/16/2020 12:00	0.6	13.8	1,521.4	0.6	1.1	1	1	0
01/16/2020 13:00	0.6	13.8	1,656.8	0.6	1.2	1	1	0
01/16/2020 14:00	0.6	13.8	1,596.4	0.6	1.1	1	1	0
01/16/2020 15:00	0.7	13.8	1,727.3	0.7	1.2	1	1	1
01/16/2020 16:00	-0.2	12.6	2,024.8	0.1	1.4	1	1	1
01/16/2020 17:00	-0.2	12.5	2,037.7	0.1	1.4	1	1	1
01/16/2020 18:00	-0.1	12.6	2,033.0	0.1	1.4	1	1	1
01/16/2020 19:00	-0.1	12.6	2,049.0	0.1	1.4	1	1	1
01/16/2020 20:00	-0.2	12.4	2,094.1	0.1	1.5	1	1	1
01/16/2020 21:00	-0.2	12.4	2,099.0	0.1	1.5	1	1	1
01/16/2020 22:00	-0.1	12.7	2,031.1	0.1	1.4	1	1	1
01/16/2020 23:00	-0.1	12.7	2,037.4	0.1	1.4	1	1	1
Average/Sum#:	0.0	12.8	1,945.9	0.2	1.4	24 #	24 #	19 #
Minimum:	-0.2	11.9	1,521.4	0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,169.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2020 00:00	-0.1	12.7	2,045.2	0.1	1.4	1	1	1
01/17/2020 01:00	-0.1	12.8	2,017.8	0.1	1.4	1	1	1
01/17/2020 02:00	-0.1	12.8	2,041.4	0.1	1.4	1	1	1
01/17/2020 03:00	-0.1	12.9	2,037.3	0.1	1.4	1	1	1
01/17/2020 04:00	-0.1	12.8	2,050.8	0.1	1.4	1	1	1
01/17/2020 05:00	-0.2	12.7	2,065.2	0.1	1.4	1	1	1
01/17/2020 06:00	-0.2	12.1	2,208.2	0.1	1.5	1	1	1
01/17/2020 07:00	-0.2	11.7	2,284.1	0.1	1.6	1	1	1
01/17/2020 08:00	-0.1	12.7	2,060.1	0.1	1.4	1	1	1
01/17/2020 09:00	-0.1	13.0	1,966.5	0.1	1.4	1	1	1
01/17/2020 10:00	0.6	13.8	1,682.9	0.6	1.2	1	1	0
01/17/2020 11:00	0.6	13.8	1,633.2	0.6	1.1	1	1	0
01/17/2020 12:00	0.6	13.8	1,664.0	0.6	1.2	1	1	0
01/17/2020 13:00	0.6	13.8	1,649.5	0.6	1.2	1	1	0
01/17/2020 14:00	0.6	13.8	1,623.2	0.6	1.1	1	1	0
01/17/2020 15:00	0.7	13.8	1,507.0	0.7	1.1	1	1	1
01/17/2020 16:00	-0.2	12.8	2,003.8	0.1	1.4	1	1	1
01/17/2020 17:00	-0.1	13.0	1,958.6	0.1	1.4	1	1	1
01/17/2020 18:00	-0.1	13.0	1,967.6	0.1	1.4	1	1	1
01/17/2020 19:00	-0.2	12.5	2,094.8	0.1	1.5	1	1	1
01/17/2020 20:00	-0.2	12.3	2,127.6	0.1	1.5	1	1	1
01/17/2020 21:00	-0.1	12.4	2,118.9	0.2	1.5	1	1	1
01/17/2020 22:00	-0.1	12.5	2,096.4	0.1	1.5	1	1	1
01/17/2020 23:00	-0.1	12.6	2,074.6	0.1	1.5	1	1	1
Average/Sum#:	0.1	12.9	1,957.4	0.2	1.4	24 #	24 #	19 #
Minimum:	-0.2	11.7	1,507.0	0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,284.1	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2020 00:00	-0.1	12.7	2,054.8	0.1	1.4	1	1	1
01/18/2020 01:00	-0.1	12.6	2,064.2	0.1	1.4	1	1	1
01/18/2020 02:00	0.1	12.8	2,036.9	0.2	1.4	1	1	1
01/18/2020 03:00	-0.1	12.8	2,038.0	0.1	1.4	1	1	1
01/18/2020 04:00	0.1	12.8	2,038.1	0.2	1.4	1	1	1
01/18/2020 05:00	-0.1	12.8	2,037.8	0.1	1.4	1	1	1
01/18/2020 06:00	-0.1	12.8	2,044.1	0.1	1.4	1	1	1
01/18/2020 07:00	-0.1	12.8	2,038.4	0.1	1.4	1	1	1
01/18/2020 08:00	-0.1	13.1	1,983.9	0.1	1.4	1	1	1
01/18/2020 09:00	0.6	13.8	1,679.4	0.6	1.2	1	1	0
01/18/2020 10:00	0.6	13.8	1,635.0	0.6	1.1	1	1	0
01/18/2020 11:00	0.6	13.8	1,611.4	0.6	1.1	1	1	0
01/18/2020 12:00	0.6	13.8	1,628.4	0.6	1.1	1	1	0
01/18/2020 13:00	0.6	13.8	1,651.5	0.6	1.2	1	1	0
01/18/2020 14:00	0.6	13.8	1,617.0	0.6	1.1	1	1	0
01/18/2020 15:00	0.7	13.8	1,600.9	0.7	1.1	1	1	1
01/18/2020 16:00	-0.2	12.8	2,012.6	0.1	1.4	1	1	1
01/18/2020 17:00	-0.1	12.7	2,041.7	0.1	1.4	1	1	1
01/18/2020 18:00	-0.1	13.0	1,957.5	0.1	1.4	1	1	1
01/18/2020 19:00	-0.1	12.6	2,060.8	0.1	1.4	1	1	1
01/18/2020 20:00	-0.1	12.3	2,119.2	0.2	1.5	1	1	1
01/18/2020 21:00	-0.1	12.3	2,127.2	0.2	1.5	1	1	1
01/18/2020 22:00	-0.1	12.2	2,140.7	0.2	1.5	1	1	1
01/18/2020 23:00	-0.1	12.3	2,115.9	0.2	1.5	1	1	1
Average/Sum#:	0.1	13.0	1,930.6	0.3	1.3	24 #	24 #	18 #
Minimum:	-0.2	12.2	1,600.9	0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,140.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2020 00:00	-0.1	12.5	2,029.0	0.1	1.4	1	1	1
01/19/2020 01:00	0.6	13.8	1,700.3	0.6	1.2	1	1	0
01/19/2020 02:00	0.6	13.8	1,552.0	0.6	1.1	1	1	0
01/19/2020 03:00	0.6	13.8	1,628.7	0.6	1.1	1	1	0
01/19/2020 04:00	0.6	13.8	1,620.8	0.6	1.1	1	1	0
01/19/2020 05:00	0.6	13.8	1,673.3	0.6	1.2	1	1	0
01/19/2020 06:00	0.6	13.8	1,692.8	0.6	1.2	1	1	0
01/19/2020 07:00	0.6	13.8	1,601.4	0.6	1.1	1	1	0
01/19/2020 08:00	0.6	13.8	1,555.3	0.6	1.1	1	1	0
01/19/2020 09:00	0.6	13.8	1,616.4	0.6	1.1	1	1	0
01/19/2020 10:00	0.6	13.8	1,565.8	0.6	1.1	1	1	0
01/19/2020 11:00	0.6	13.8	1,639.9	0.6	1.1	1	1	0
01/19/2020 12:00	0.6	13.8	1,658.6	0.6	1.2	1	1	0
01/19/2020 13:00	0.6	13.8	1,671.7	0.6	1.2	1	1	0
01/19/2020 14:00	0.6	13.8	1,582.0	0.6	1.1	1	1	0
01/19/2020 15:00	0.6	13.8	1,620.0	0.6	1.1	1	1	0
01/19/2020 16:00	0.7	13.8	1,614.5	0.7	1.1	1	1	1
01/19/2020 17:00	-0.4	12.8	2,011.7	-0.1	1.4	1	1	1
01/19/2020 18:00	-0.2	12.6	2,046.3	0.1	1.4	1	1	1
01/19/2020 19:00	-0.2	12.6	2,039.5	0.1	1.4	1	1	1
01/19/2020 20:00	-0.2	12.3	2,105.5	0.1	1.5	1	1	1
01/19/2020 21:00	-0.2	12.2	2,133.5	0.1	1.5	1	1	1
01/19/2020 22:00	-0.2	12.2	2,130.1	0.1	1.5	1	1	1
01/19/2020 23:00	-0.2	12.3	2,118.5	0.1	1.5	1	1	1
Average/Sum#:	0.3	13.3	1,775.3	0.4	1.2	24 #	24 #	9 #
Minimum:	-0.4	12.2	1,552.0	-0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,133.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/20/2020 00:00	-0.2	12.4	2,084.3	0.1	1.5	1	1	1
01/20/2020 01:00	-0.2	12.6	2,047.3	0.1	1.4	1	1	1
01/20/2020 02:00	-0.1	12.7	2,030.2	0.1	1.4	1	1	1
01/20/2020 03:00	-0.1	12.7	2,036.9	0.1	1.4	1	1	1
01/20/2020 04:00	-0.1	12.6	2,041.2	0.1	1.4	1	1	1
01/20/2020 05:00	-0.2	12.5	2,053.5	0.1	1.4	1	1	1
01/20/2020 06:00	-0.2	12.6	2,061.1	0.1	1.4	1	1	1
01/20/2020 07:00	-0.2	12.3	2,123.4	0.1	1.5	1	1	1
01/20/2020 08:00	-0.2	12.2	2,143.1	0.1	1.5	1	1	1
01/20/2020 09:00	-0.1	12.2	2,121.3	0.2	1.5	1	1	1
01/20/2020 10:00	-0.2	12.1	2,143.4	0.1	1.5	1	1	1
01/20/2020 11:00	-0.1	12.2	2,117.0	0.2	1.5	1	1	1
01/20/2020 12:00	-0.1	12.0	2,138.3	0.2	1.5	1	1	1
01/20/2020 13:00	-0.1	12.1	2,132.1	0.2	1.5	1	1	1
01/20/2020 14:00	-0.1	11.9	2,153.9	0.2	1.5	1	1	1
01/20/2020 15:00	-0.1	12.1	2,116.9	0.2	1.5	1	1	1
01/20/2020 16:00	-0.1	12.3	2,073.6	0.2	1.5	1	1	1
01/20/2020 17:00	-0.2	12.1	2,126.3	0.1	1.5	1	1	1
01/20/2020 18:00	-0.2	12.1	2,121.6	0.1	1.5	1	1	1
01/20/2020 19:00	-0.2	12.2	2,120.1	0.1	1.5	1	1	1
01/20/2020 20:00	-0.2	12.2	2,118.1	0.1	1.5	1	1	1
01/20/2020 21:00	-0.2	12.2	2,118.3	0.1	1.5	1	1	1
01/20/2020 22:00	-0.2	12.3	2,102.6	0.1	1.5	1	1	1
01/20/2020 23:00	-0.2	12.4	2,071.0	0.1	1.4	1	1	1
Average/Sum#:	-0.2	12.3	2,099.8	0.1	1.5	24 #	24 #	24 #
Minimum:	-0.2	11.9	2,030.2	0.1	1.4	1	1	1
Maximum:	-0.1	12.7	2,153.9	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2020 00:00	-0.1	12.6	2,045.0	0.1	1.4	1	1	1
01/21/2020 01:00	-0.2	12.6	2,036.2	0.1	1.4	1	1	1
01/21/2020 02:00	-0.2	12.6	2,041.0	0.1	1.4	1	1	1
01/21/2020 03:00	-0.2	12.6	2,033.9	0.1	1.4	1	1	1
01/21/2020 04:00	-0.2	12.6	2,038.6	0.1	1.4	1	1	1
01/21/2020 05:00	-0.2	12.6	2,041.2	0.1	1.4	1	1	1
01/21/2020 06:00	-0.2	12.7	2,010.3	0.1	1.4	1	1	1
01/21/2020 07:00	-0.2	12.3	2,093.8	0.1	1.5	1	1	1
01/21/2020 08:00	-0.2	12.5	2,059.5	0.1	1.4	1	1	1
01/21/2020 09:00	-0.2	12.8	1,969.7	0.1	1.4	1	1	1
01/21/2020 10:00	0.6	13.8	1,674.5	0.6	1.2	1	1	0
01/21/2020 11:00	0.6	13.8	1,685.4	0.6	1.2	1	1	0
01/21/2020 12:00	0.6	13.8	1,650.7	0.6	1.2	1	1	0
01/21/2020 13:00	0.6	13.8	1,622.5	0.6	1.1	1	1	0
01/21/2020 14:00	0.6	13.8	1,632.0	0.6	1.1	1	1	0
01/21/2020 15:00	0.7	13.8	1,552.1	0.7	1.1	1	1	1
01/21/2020 16:00	-0.4	12.5	2,028.0	-0.1	1.4	1	1	1
01/21/2020 17:00	-0.2	12.4	2,054.3	0.1	1.4	1	1	1
01/21/2020 18:00	-0.2	12.4	2,048.2	0.1	1.4	1	1	1
01/21/2020 19:00	-0.2	12.4	2,043.8	0.1	1.4	1	1	1
01/21/2020 20:00	-0.1	12.4	2,039.7	0.2	1.4	1	1	1
01/21/2020 21:00	-0.1	12.5	2,036.1	0.1	1.4	1	1	1
01/21/2020 22:00	-0.2	12.3	2,072.6	0.1	1.5	1	1	1
01/21/2020 23:00	-0.1	12.5	2,044.7	0.1	1.4	1	1	1
Average/Sum#:	0.0	12.8	1,939.7	0.2	1.3	24 #	24 #	19 #
Minimum:	-0.4	12.3	1,552.1	-0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,093.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2020 00:00	0.1	13.1	1,828.3	0.2	1.3	1	1	1
01/22/2020 01:00	0.6	13.8	1,303.7	0.6	0.9	1	1	0
01/22/2020 02:00	0.6	13.8	1,365.4	0.6	1.0	1	1	0
01/22/2020 03:00	0.6	13.8	1,330.9	0.6	0.9	1	1	0
01/22/2020 04:00	0.6	13.7	1,515.3	0.6	1.1	1	1	0
01/22/2020 05:00	0.6	13.7	1,451.4	0.6	1.0	1	1	0
01/22/2020 06:00	0.6	13.7	1,585.6	0.6	1.1	1	1	0
01/22/2020 07:00	0.6	13.7	1,640.0	0.6	1.1	1	1	0
01/22/2020 08:00	0.6	13.8	1,483.2	0.6	1.0	1	1	0
01/22/2020 09:00	0.6	13.7	1,584.1	0.6	1.1	1	1	0
01/22/2020 10:00	0.6	13.7	1,613.9	0.6	1.1	1	1	0
01/22/2020 11:00	0.6	13.7	1,695.4	0.6	1.2	1	1	0
01/22/2020 12:00	0.6	13.8	1,694.9	0.6	1.2	1	1	0
01/22/2020 13:00	0.6	13.8	1,653.4	0.6	1.2	1	1	0
01/22/2020 14:00	0.6	13.8	1,632.4	0.6	1.1	1	1	0
01/22/2020 15:00	0.7	13.8	1,599.2	0.7	1.1	1	1	1
01/22/2020 16:00	-0.2	12.6	2,029.5	0.1	1.4	1	1	1
01/22/2020 17:00	-0.1	12.6	2,008.8	0.1	1.4	1	1	1
01/22/2020 18:00	-0.2	12.1	2,126.3	0.1	1.5	1	1	1
01/22/2020 19:00	-0.1	12.2	2,119.6	0.2	1.5	1	1	1
01/22/2020 20:00	-0.1	12.5	2,049.9	0.1	1.4	1	1	1
01/22/2020 21:00	-0.1	12.6	2,042.0	0.1	1.4	1	1	1
01/22/2020 22:00	-0.1	12.6	2,048.9	0.1	1.4	1	1	1
01/22/2020 23:00	-0.2	13.0	1,953.5	0.1	1.4	1	1	1
Average/Sum#:	0.3	13.3	1,723.2	0.4	1.2	24 #	24 #	10 #
Minimum:	-0.2	12.1	1,303.7	0.1	0.9	1	1	0
Maximum:	0.7	13.8	2,126.3	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2020 00:00	-0.2	12.3	2,098.2	0.1	1.5	1	1	1
01/23/2020 01:00	-0.2	12.3	2,098.0	0.1	1.5	1	1	1
01/23/2020 02:00	-0.1	12.6	2,046.4	0.1	1.4	1	1	1
01/23/2020 03:00	-0.1	12.6	2,046.2	0.1	1.4	1	1	1
01/23/2020 04:00	-0.2	12.2	2,121.4	0.1	1.5	1	1	1
01/23/2020 05:00	-0.1	12.6	2,062.0	0.1	1.4	1	1	1
01/23/2020 06:00	-0.2	12.2	2,157.5	0.1	1.5	1	1	1
01/23/2020 07:00	-0.1	12.4	2,113.5	0.2	1.5	1	1	1
01/23/2020 08:00	-0.1	13.0	1,940.1	0.1	1.4	1	1	1
01/23/2020 09:00	0.6	13.7	1,671.7	0.6	1.2	1	1	0
01/23/2020 10:00	0.6	13.8	1,547.6	0.6	1.1	1	1	0
01/23/2020 11:00	0.6	13.8	1,603.8	0.6	1.1	1	1	0
01/23/2020 12:00	0.6	13.8	1,630.2	0.6	1.1	1	1	0
01/23/2020 13:00	0.6	13.8	1,660.7	0.6	1.2	1	1	0
01/23/2020 14:00	0.6	13.8	1,649.9	0.6	1.2	1	1	0
01/23/2020 15:00	0.6	13.8	1,616.6	0.6	1.1	1	1	0
01/23/2020 16:00	0.6	13.8	1,496.6	0.6	1.0	1	1	0
01/23/2020 17:00	-0.1	12.9	1,919.5	0.1	1.3	1	1	1
01/23/2020 18:00	-0.2	12.1	2,126.8	0.1	1.5	1	1	1
01/23/2020 19:00	-0.2	12.1	2,124.2	0.1	1.5	1	1	1
01/23/2020 20:00	-0.1	12.1	2,120.9	0.2	1.5	1	1	1
01/23/2020 21:00	-0.1	12.2	2,108.3	0.2	1.5	1	1	1
01/23/2020 22:00	-0.1	12.4	2,070.6	0.2	1.4	1	1	1
01/23/2020 23:00	-0.2	13.0	1,934.3	0.1	1.4	1	1	1
Average/Sum#:	0.1	12.9	1,915.2	0.3	1.3	24 #	24 #	16 #
Minimum:	-0.2	12.1	1,496.6	0.1	1.0	1	1	0
Maximum:	0.6	13.8	2,157.5	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2020 00:00	-0.2	13.1	1,913.9	-0.1	1.3	1	1	1
01/24/2020 01:00	0.6	13.7	1,630.9	0.6	1.1	1	1	0
01/24/2020 02:00	0.6	13.7	1,659.8	0.6	1.2	1	1	0
01/24/2020 03:00	0.6	13.7	1,693.1	0.6	1.2	1	1	0
01/24/2020 04:00	0.6	13.7	1,694.3	0.6	1.2	1	1	0
01/24/2020 05:00	0.6	13.7	1,593.1	0.6	1.1	1	1	0
01/24/2020 06:00	0.6	13.7	1,652.2	0.6	1.2	1	1	0
01/24/2020 07:00	0.6	13.7	1,647.7	0.6	1.2	1	1	0
01/24/2020 08:00	0.6	13.7	1,589.3	0.6	1.1	1	1	0
01/24/2020 09:00	0.6	13.7	1,661.4	0.6	1.2	1	1	0
01/24/2020 10:00	0.6	13.8	1,470.8	0.6	1.0	1	1	0
01/24/2020 11:00	0.6	13.7	1,653.5	0.6	1.2	1	1	0
01/24/2020 12:00	0.6	13.7	1,624.2	0.6	1.1	1	1	0
01/24/2020 13:00	0.6	13.7	1,666.2	0.6	1.2	1	1	0
01/24/2020 14:00	0.6	13.7	1,642.4	0.6	1.1	1	1	0
01/24/2020 15:00	0.6	13.8	1,548.8	0.6	1.1	1	1	0
01/24/2020 16:00	0.7	13.8	1,579.7	0.7	1.1	1	1	1
01/24/2020 17:00	-0.4	12.6	2,030.5	-0.1	1.4	1	1	1
01/24/2020 18:00	-0.2	12.1	2,121.2	0.1	1.5	1	1	1
01/24/2020 19:00	-0.2	12.1	2,117.7	0.1	1.5	1	1	1
01/24/2020 20:00	-0.2	12.1	2,112.0	0.1	1.5	1	1	1
01/24/2020 21:00	-0.1	12.3	2,083.6	0.2	1.5	1	1	1
01/24/2020 22:00	-0.1	12.4	2,050.7	0.2	1.4	1	1	1
01/24/2020 23:00	0.0	14.0	1,267.4	0.0	0.9	1	0	1
Average/Sum#:	0.3	13.3	1,737.7	0.4	1.2	24 #	23 #	9 #
Minimum:	-0.4	12.1	1,267.4	-0.1	0.9	1	0	0
Maximum:	0.7	14.0	2,121.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/28/2020 03:00	0.0	17.6	453.6	0.0	0.3	1	0	0
01/28/2020 04:00	0.0	15.1	1,005.9	0.0	0.7	1	0	0
01/28/2020 05:00	0.6	13.7	1,596.0	0.6	1.1	1	1	0
01/28/2020 06:00	0.6	13.7	1,696.1	0.6	1.2	1	1	0
01/28/2020 07:00	0.6	13.8	1,604.8	0.6	1.1	1	1	0
01/28/2020 08:00	0.6	13.7	1,666.6	0.6	1.2	1	1	0
01/28/2020 09:00	0.6	13.7	1,679.4	0.6	1.2	1	1	0
01/28/2020 10:00	0.6	13.8	1,528.8	0.6	1.1	1	1	0
01/28/2020 11:00	0.6	13.7	1,609.3	0.6	1.1	1	1	0
01/28/2020 12:00	0.6	13.8	1,598.1	0.6	1.1	1	1	0
01/28/2020 13:00	0.6	13.8	1,655.0	0.6	1.2	1	1	0
01/28/2020 14:00	0.6	13.7	1,569.9	0.6	1.1	1	1	0
01/28/2020 15:00	0.6	13.8	1,559.2	0.6	1.1	1	1	0
01/28/2020 16:00	0.7	13.7	1,566.5	0.7	1.1	1	1	1
01/28/2020 17:00	-0.4	12.6	2,021.2	-0.1	1.4	1	1	1
01/28/2020 18:00	-0.2	12.3	2,063.4	0.1	1.4	1	1	1
01/28/2020 19:00	-0.1	12.3	2,085.0	0.2	1.5	1	1	1
01/28/2020 20:00	-0.2	12.1	2,116.2	0.1	1.5	1	1	1
01/28/2020 21:00	-0.1	12.1	2,119.1	0.2	1.5	1	1	1
01/28/2020 22:00	0.0	14.0	1,276.7	0.0	0.9	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.7	1,623.5	0.4	1.1	20 #	17 #	7 #
Minimum:	-0.4	12.1	453.6	-0.1	0.3	0	0	0
Maximum:	0.7	17.6	2,119.1	0.7	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/30/2020 02:00	0.0	17.5	460.1	0.0	0.3	1	0	0
01/30/2020 03:00	0.0	14.6	1,102.0	0.0	0.8	1	0	0
01/30/2020 04:00	0.6	13.7	1,635.4	0.6	1.1	1	1	0
01/30/2020 05:00	0.6	13.8	1,383.8	0.6	1.0	1	1	0
01/30/2020 06:00	0.1	13.2	1,845.9	0.2	1.3	1	1	1
01/30/2020 07:00	-0.2	12.5	2,084.1	0.1	1.5	1	1	1
01/30/2020 08:00	-0.2	13.0	1,925.2	0.1	1.3	1	1	1
01/30/2020 09:00	0.6	13.7	1,626.9	0.6	1.1	1	1	0
01/30/2020 10:00	0.6	13.8	1,629.6	0.6	1.1	1	1	0
01/30/2020 11:00	0.6	13.8	1,681.9	0.6	1.2	1	1	0
01/30/2020 12:00	0.6	13.8	1,494.1	0.6	1.0	1	1	0
01/30/2020 13:00	0.6	13.8	1,650.4	0.6	1.2	1	1	0
01/30/2020 14:00	0.6	13.8	1,550.0	0.6	1.1	1	1	0
01/30/2020 15:00	0.6	13.8	1,630.1	0.6	1.1	1	1	0
01/30/2020 16:00	0.6	13.8	1,511.7	0.6	1.1	1	1	0
01/30/2020 17:00	0.6	13.8	1,632.9	0.6	1.1	1	1	0
01/30/2020 18:00	0.7	13.8	1,708.9	0.7	1.2	1	1	1
01/30/2020 19:00	-0.2	12.4	2,039.3	0.1	1.4	1	1	1
01/30/2020 20:00	-0.1	11.9	2,143.9	0.2	1.5	1	1	1
01/30/2020 21:00	-0.1	12.0	2,125.4	0.2	1.5	1	1	1
01/30/2020 22:00	-0.1	12.3	2,073.7	0.2	1.5	1	1	1
01/30/2020 23:00	0.5	13.3	1,751.3	0.5	1.2	1	1	1
Average/Sum#:	0.3	13.6	1,667.6	0.4	1.2	22 #	20 #	9 #
Minimum:	-0.2	11.9	460.1	0.0	0.3	0	0	0
Maximum:	0.7	17.5	2,143.9	0.7	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2020 00:00	0.0	14.4	1,058.6	0.0	0.7	1	0	0
01/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/31/2020 05:00	0.0	16.7	519.4	0.0	0.4	1	0	0
01/31/2020 06:00	0.0	14.3	1,278.2	0.0	0.9	1	0	0
01/31/2020 07:00	0.6	13.7	1,591.9	0.6	1.1	1	1	0
01/31/2020 08:00	0.6	13.8	1,524.1	0.6	1.1	1	1	0
01/31/2020 09:00	0.6	13.8	1,617.4	0.6	1.1	1	1	0
01/31/2020 10:00	0.6	13.7	1,627.0	0.6	1.1	1	1	0
01/31/2020 11:00	0.6	13.8	1,637.6	0.6	1.1	1	1	0
01/31/2020 12:00	0.6	13.8	1,615.7	0.6	1.1	1	1	0
01/31/2020 13:00	0.6	13.8	1,692.2	0.6	1.2	1	1	0
01/31/2020 14:00	0.6	13.8	1,678.2	0.6	1.2	1	1	0
01/31/2020 15:00	0.6	13.8	1,662.5	0.6	1.2	1	1	0
01/31/2020 16:00	0.6	13.8	1,481.5	0.6	1.0	1	1	0
01/31/2020 17:00	0.6	13.8	1,672.6	0.6	1.2	1	1	0
01/31/2020 18:00	0.2	13.2	1,826.3	0.4	1.3	1	1	1
01/31/2020 19:00	-0.2	12.6	2,009.4	0.1	1.4	1	1	1
01/31/2020 20:00	-0.2	12.1	2,101.7	0.1	1.5	1	1	1
01/31/2020 21:00	-0.2	12.1	2,103.7	0.1	1.5	1	1	1
01/31/2020 22:00	-0.2	12.2	2,095.8	0.1	1.5	1	1	1
01/31/2020 23:00	0.0	14.0	1,284.9	0.0	0.9	1	0	1
Average/Sum#:	0.3	13.7	1,603.9	0.4	1.1	20 #	16 #	6 #
Minimum:	-0.2	12.1	519.4	0.0	0.4	0	0	0
Maximum:	0.6	16.7	2,103.7	0.6	1.5	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 03:00	0.0	19.8	175.5	0.0	0.1	1	0	0
02/03/2020 04:00	0.0	16.9	563.0	0.0	0.4	1	0	0
02/03/2020 05:00	0.0	14.2	1,373.4	0.0	1.0	1	0	0
02/03/2020 06:00	0.6	13.8	1,701.3	0.6	1.2	1	1	0
02/03/2020 07:00	0.6	13.8	1,615.6	0.6	1.1	1	1	0
02/03/2020 08:00	0.6	13.8	1,549.0	0.6	1.1	1	1	0
02/03/2020 09:00	0.6	13.8	1,477.8	0.6	1.0	1	1	0
02/03/2020 10:00	0.6	13.8	1,561.3	0.6	1.1	1	1	0
02/03/2020 11:00	0.6	13.8	1,694.0	0.6	1.2	1	1	0
02/03/2020 12:00	0.6	13.8	1,656.3	0.6	1.2	1	1	0
02/03/2020 13:00	0.6	13.8	1,641.1	0.6	1.1	1	1	0
02/03/2020 14:00	0.6	13.8	1,563.8	0.6	1.1	1	1	0
02/03/2020 15:00	0.6	13.8	1,654.5	0.6	1.2	1	1	0
02/03/2020 16:00	0.7	13.8	1,584.6	0.7	1.1	1	1	1
02/03/2020 17:00	-0.2	12.6	2,058.6	0.1	1.4	1	1	1
02/03/2020 18:00	-0.2	11.8	2,248.7	0.1	1.6	1	1	1
02/03/2020 19:00	-0.1	11.5	2,287.2	0.2	1.6	1	1	1
02/03/2020 20:00	-0.1	11.5	2,293.3	0.2	1.6	1	1	1
02/03/2020 21:00	-0.1	12.2	2,154.0	0.2	1.5	1	1	1
02/03/2020 22:00	-0.1	12.3	2,142.6	0.2	1.5	1	1	1
02/03/2020 23:00	-0.1	12.5	2,108.8	0.1	1.5	1	1	1
Average/Sum#:	0.3	13.7	1,671.6	0.4	1.2	21 #	18 #	8 #
Minimum:	-0.2	11.5	175.5	0.0	0.1	0	0	0
Maximum:	0.7	19.8	2,293.3	0.7	1.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2020 00:00	-0.1	12.6	2,075.7	0.1	1.5	1	1	1
02/04/2020 01:00	0.1	12.8	2,052.1	0.2	1.4	1	1	1
02/04/2020 02:00	-0.1	12.8	2,058.0	0.1	1.4	1	1	1
02/04/2020 03:00	-0.1	12.8	2,051.7	0.1	1.4	1	1	1
02/04/2020 04:00	-0.1	12.7	2,078.4	0.1	1.5	1	1	1
02/04/2020 05:00	-0.2	12.3	2,113.3	0.1	1.5	1	1	1
02/04/2020 06:00	-0.1	12.3	2,167.2	0.2	1.5	1	1	1
02/04/2020 07:00	-0.1	12.1	2,188.3	0.2	1.5	1	1	1
02/04/2020 08:00	0.1	12.7	2,047.2	0.2	1.4	1	1	1
02/04/2020 09:00	0.6	13.8	1,755.6	0.6	1.2	1	1	0
02/04/2020 10:00	0.6	13.8	1,756.3	0.6	1.2	1	1	0
02/04/2020 11:00	0.6	13.8	1,754.5	0.6	1.2	1	1	0
02/04/2020 12:00	0.6	13.9	1,754.6	0.6	1.2	1	1	0
02/04/2020 13:00	0.6	13.9	1,755.0	0.6	1.2	1	1	0
02/04/2020 14:00	0.6	13.9	1,756.1	0.6	1.2	1	1	0
02/04/2020 15:00	0.6	13.9	1,755.5	0.6	1.2	1	1	0
02/04/2020 16:00	0.4	13.4	1,829.6	0.4	1.3	1	1	1
02/04/2020 17:00	-0.1	12.8	2,010.6	0.1	1.4	1	1	1
02/04/2020 18:00	-0.2	12.3	2,123.7	0.1	1.5	1	1	1
02/04/2020 19:00	-0.1	11.9	2,202.7	0.2	1.5	1	1	1
02/04/2020 20:00	-0.1	12.0	2,185.9	0.2	1.5	1	1	1
02/04/2020 21:00	-0.1	11.7	2,262.8	0.2	1.6	1	1	1
02/04/2020 22:00	-0.1	12.3	2,113.8	0.2	1.5	1	1	1
02/04/2020 23:00	-0.1	12.4	2,093.8	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.9	1,997.6	0.3	1.4	24 #	24 #	17 #
Minimum:	-0.2	11.7	1,754.5	0.1	1.2	1	1	0
Maximum:	0.6	13.9	2,262.8	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2020 00:00	-0.1	12.3	2,119.0	0.2	1.5	1	1	1
02/05/2020 01:00	-0.1	12.5	2,085.4	0.1	1.5	1	1	1
02/05/2020 02:00	-0.1	12.6	2,050.6	0.1	1.4	1	1	1
02/05/2020 03:00	-0.1	12.6	2,048.4	0.1	1.4	1	1	1
02/05/2020 04:00	-0.1	12.5	2,072.3	0.1	1.5	1	1	1
02/05/2020 05:00	-0.2	12.9	1,990.5	0.1	1.4	1	1	1
02/05/2020 06:00	-0.1	12.8	2,014.3	0.1	1.4	1	1	1
02/05/2020 07:00	-0.1	11.9	2,208.8	0.2	1.5	1	1	1
02/05/2020 08:00	-0.1	12.6	2,071.9	0.1	1.5	1	1	1
02/05/2020 09:00	-0.1	13.0	1,945.8	0.1	1.4	1	1	1
02/05/2020 10:00	0.6	13.8	1,605.6	0.6	1.1	1	1	0
02/05/2020 11:00	0.6	13.8	1,608.1	0.6	1.1	1	1	0
02/05/2020 12:00	0.6	13.8	1,655.7	0.6	1.2	1	1	0
02/05/2020 13:00	0.6	13.8	1,663.4	0.6	1.2	1	1	0
02/05/2020 14:00	0.6	13.8	1,589.9	0.6	1.1	1	1	0
02/05/2020 15:00	0.6	13.8	1,673.9	0.6	1.2	1	1	0
02/05/2020 16:00	0.2	13.3	1,828.9	0.4	1.3	1	1	1
02/05/2020 17:00	-0.2	12.8	1,971.3	0.1	1.4	1	1	1
02/05/2020 18:00	-0.2	11.8	2,189.5	0.1	1.5	1	1	1
02/05/2020 19:00	-0.2	12.1	2,132.6	0.1	1.5	1	1	1
02/05/2020 20:00	-0.1	11.9	2,164.6	0.2	1.5	1	1	1
02/05/2020 21:00	-0.2	12.2	2,106.4	0.1	1.5	1	1	1
02/05/2020 22:00	-0.2	12.1	2,121.1	0.1	1.5	1	1	1
02/05/2020 23:00	-0.2	12.4	2,057.4	0.1	1.4	1	1	1
Average/Sum#:	0.1	12.8	1,957.3	0.3	1.4	24 #	24 #	18 #
Minimum:	-0.2	11.8	1,589.9	0.1	1.1	1	1	0
Maximum:	0.6	13.8	2,208.8	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2020 00:00	-0.2	12.6	2,029.0	0.1	1.4	1	1	1
02/06/2020 01:00	-0.1	12.8	2,007.6	0.1	1.4	1	1	1
02/06/2020 02:00	-0.1	12.8	2,003.9	0.1	1.4	1	1	1
02/06/2020 03:00	-0.2	12.7	2,029.9	0.1	1.4	1	1	1
02/06/2020 04:00	-0.1	12.8	2,015.7	0.1	1.4	1	1	1
02/06/2020 05:00	-0.2	12.6	2,041.7	0.1	1.4	1	1	1
02/06/2020 06:00	-0.4	12.5	2,074.6	-0.1	1.5	1	1	1
02/06/2020 07:00	-0.2	12.4	2,096.5	0.1	1.5	1	1	1
02/06/2020 08:00	-0.1	13.2	1,923.0	0.1	1.3	1	1	1
02/06/2020 09:00	0.6	13.8	1,694.5	0.6	1.2	1	1	0
02/06/2020 10:00	0.6	13.8	1,681.5	0.6	1.2	1	1	0
02/06/2020 11:00	0.6	13.8	1,675.7	0.6	1.2	1	1	0
02/06/2020 12:00	0.6	13.8	1,589.7	0.6	1.1	1	1	0
02/06/2020 13:00	0.6	13.8	1,682.7	0.6	1.2	1	1	0
02/06/2020 14:00	0.6	13.8	1,658.3	0.6	1.2	1	1	0
02/06/2020 15:00	0.6	13.8	1,545.8	0.6	1.1	1	1	0
02/06/2020 16:00	0.7	13.8	1,563.9	0.7	1.1	1	1	1
02/06/2020 17:00	-0.4	12.6	1,999.3	-0.1	1.4	1	1	1
02/06/2020 18:00	-0.4	12.1	2,104.1	-0.1	1.5	1	1	1
02/06/2020 19:00	-0.2	12.1	2,091.6	0.1	1.5	1	1	1
02/06/2020 20:00	-0.2	12.2	2,114.7	0.1	1.5	1	1	1
02/06/2020 21:00	-0.2	12.1	2,117.5	0.1	1.5	1	1	1
02/06/2020 22:00	-0.2	12.2	2,093.6	0.1	1.5	1	1	1
02/06/2020 23:00	-0.2	13.0	1,932.7	0.1	1.4	1	1	1
Average/Sum#:	0.1	13.0	1,907.0	0.2	1.3	24 #	24 #	17 #
Minimum:	-0.4	12.1	1,545.8	-0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,117.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2020 00:00	-0.2	13.1	1,911.3	-0.1	1.3	1	1	1
02/07/2020 01:00	0.6	13.8	1,698.1	0.6	1.2	1	1	0
02/07/2020 02:00	0.6	13.8	1,561.1	0.6	1.1	1	1	0
02/07/2020 03:00	0.6	13.8	1,557.0	0.6	1.1	1	1	0
02/07/2020 04:00	0.6	13.8	1,526.6	0.6	1.1	1	1	0
02/07/2020 05:00	0.5	13.7	1,557.5	0.5	1.1	1	1	1
02/07/2020 06:00	-0.5	12.7	2,025.3	-0.2	1.4	1	1	1
02/07/2020 07:00	-0.4	12.5	2,081.2	-0.1	1.5	1	1	1
02/07/2020 08:00	-0.2	13.0	1,939.4	0.1	1.4	1	1	1
02/07/2020 09:00	0.6	13.8	1,649.6	0.6	1.2	1	1	0
02/07/2020 10:00	0.6	13.8	1,660.6	0.6	1.2	1	1	0
02/07/2020 11:00	0.6	13.8	1,682.7	0.6	1.2	1	1	0
02/07/2020 12:00	0.6	13.8	1,685.2	0.6	1.2	1	1	0
02/07/2020 13:00	0.6	13.8	1,688.1	0.6	1.2	1	1	0
02/07/2020 14:00	0.6	13.8	1,660.8	0.6	1.2	1	1	0
02/07/2020 15:00	0.6	13.8	1,677.3	0.6	1.2	1	1	0
02/07/2020 16:00	0.7	13.8	1,588.9	0.7	1.1	1	1	1
02/07/2020 17:00	-0.4	12.5	2,010.9	-0.1	1.4	1	1	1
02/07/2020 18:00	-0.2	12.0	2,112.5	0.1	1.5	1	1	1
02/07/2020 19:00	-0.2	12.1	2,091.3	0.1	1.5	1	1	1
02/07/2020 20:00	-0.2	12.1	2,106.1	0.1	1.5	1	1	1
02/07/2020 21:00	-0.2	12.1	2,106.4	0.1	1.5	1	1	1
02/07/2020 22:00	-0.2	12.4	2,051.2	0.1	1.4	1	1	1
02/07/2020 23:00	0.0	13.9	1,282.5	0.0	0.9	1	0	1
Average/Sum#:	0.2	13.2	1,788.0	0.3	1.3	24 #	23 #	13 #
Minimum:	-0.5	12.0	1,282.5	-0.2	0.9	1	0	0
Maximum:	0.7	13.9	2,112.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2020 03:00	0.0	17.6	463.3	0.0	0.3	1	0	0
02/10/2020 04:00	0.0	15.7	707.0	0.0	0.5	1	0	0
02/10/2020 05:00	0.0	14.4	1,158.6	0.0	0.8	1	0	0
02/10/2020 06:00	0.6	13.8	1,696.7	0.6	1.2	1	1	0
02/10/2020 07:00	0.6	13.8	1,698.9	0.6	1.2	1	1	0
02/10/2020 08:00	0.6	13.9	1,651.9	0.6	1.2	1	1	0
02/10/2020 09:00	0.6	13.9	1,650.7	0.6	1.2	1	1	0
02/10/2020 10:00	0.6	13.9	1,636.9	0.6	1.1	1	1	0
02/10/2020 11:00	0.6	13.9	1,668.8	0.6	1.2	1	1	0
02/10/2020 12:00	0.6	13.9	1,666.9	0.6	1.2	1	1	0
02/10/2020 13:00	0.6	13.9	1,654.2	0.6	1.2	1	1	0
02/10/2020 14:00	0.6	13.9	1,648.3	0.6	1.2	1	1	0
02/10/2020 15:00	0.6	13.9	1,655.4	0.6	1.2	1	1	0
02/10/2020 16:00	0.6	13.9	1,685.7	0.6	1.2	1	1	0
02/10/2020 17:00	0.2	13.3	1,836.0	0.4	1.3	1	1	1
02/10/2020 18:00	-0.2	12.5	2,049.4	0.1	1.4	1	1	1
02/10/2020 19:00	-0.2	12.4	2,065.7	0.1	1.4	1	1	1
02/10/2020 20:00	-0.2	12.2	2,109.4	0.1	1.5	1	1	1
02/10/2020 21:00	-0.2	12.2	2,121.9	0.1	1.5	1	1	1
02/10/2020 22:00	-0.2	12.3	2,101.9	0.1	1.5	1	1	1
02/10/2020 23:00	-0.2	12.6	2,039.4	0.1	1.4	1	1	1
Average/Sum#:	0.3	13.7	1,665.1	0.4	1.2	21 #	18 #	7 #
Minimum:	-0.2	12.2	463.3	0.0	0.3	0	0	0
Maximum:	0.6	17.6	2,121.9	0.6	1.5	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2020 00:00	-0.2	13.1	1,916.2	-0.1	1.3	1	1	1
02/11/2020 01:00	0.6	13.8	1,566.8	0.6	1.1	1	1	0
02/11/2020 02:00	0.6	13.9	1,463.8	0.6	1.0	1	1	0
02/11/2020 03:00	0.6	13.9	1,532.0	0.6	1.1	1	1	0
02/11/2020 04:00	0.6	13.8	1,506.6	0.6	1.1	1	1	0
02/11/2020 05:00	0.6	13.8	1,635.4	0.6	1.1	1	1	0
02/11/2020 06:00	0.6	13.8	1,637.0	0.6	1.1	1	1	0
02/11/2020 07:00	0.6	13.8	1,569.1	0.6	1.1	1	1	0
02/11/2020 08:00	0.6	13.9	1,379.6	0.6	1.0	1	1	0
02/11/2020 09:00	0.6	13.9	1,549.0	0.6	1.1	1	1	0
02/11/2020 10:00	0.6	13.9	1,601.2	0.6	1.1	1	1	0
02/11/2020 11:00	0.6	13.9	1,621.6	0.6	1.1	1	1	0
02/11/2020 12:00	0.6	13.9	1,661.6	0.6	1.2	1	1	0
02/11/2020 13:00	0.6	13.9	1,679.3	0.6	1.2	1	1	0
02/11/2020 14:00	0.6	13.9	1,648.6	0.6	1.2	1	1	0
02/11/2020 15:00	0.6	13.9	1,530.3	0.6	1.1	1	1	0
02/11/2020 16:00	0.6	13.9	1,473.9	0.6	1.0	1	1	0
02/11/2020 17:00	0.6	13.9	1,623.8	0.6	1.1	1	1	0
02/11/2020 18:00	0.2	13.2	1,849.1	0.4	1.3	1	1	1
02/11/2020 19:00	-0.2	11.9	2,163.5	0.1	1.5	1	1	1
02/11/2020 20:00	-0.2	11.8	2,180.5	0.1	1.5	1	1	1
02/11/2020 21:00	-0.1	11.7	2,176.4	0.2	1.5	1	1	1
02/11/2020 22:00	-0.1	11.8	2,149.9	0.2	1.5	1	1	1
02/11/2020 23:00	-0.1	12.1	2,086.9	0.2	1.5	1	1	1
Average/Sum#:	0.4	13.4	1,716.8	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.2	11.7	1,379.6	-0.1	1.0	1	1	0
Maximum:	0.6	13.9	2,180.5	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2020 00:00	0.1	12.8	1,923.8	0.2	1.3	1	1	1
02/12/2020 01:00	0.6	13.9	1,562.3	0.6	1.1	1	1	0
02/12/2020 02:00	0.6	13.8	1,541.9	0.6	1.1	1	1	0
02/12/2020 03:00	0.6	13.8	1,500.9	0.6	1.1	1	1	0
02/12/2020 04:00	0.6	13.8	1,647.0	0.6	1.2	1	1	0
02/12/2020 05:00	0.6	13.8	1,648.5	0.6	1.2	1	1	0
02/12/2020 06:00	0.6	13.8	1,613.5	0.6	1.1	1	1	0
02/12/2020 07:00	0.6	13.8	1,553.4	0.6	1.1	1	1	0
02/12/2020 08:00	0.6	13.8	1,690.5	0.6	1.2	1	1	0
02/12/2020 09:00	0.6	13.8	1,677.1	0.6	1.2	1	1	0
02/12/2020 10:00	0.6	13.8	1,668.5	0.6	1.2	1	1	0
02/12/2020 11:00	0.6	13.9	1,671.9	0.6	1.2	1	1	0
02/12/2020 12:00	0.6	13.9	1,636.8	0.6	1.1	1	1	0
02/12/2020 13:00	0.6	13.9	1,680.8	0.6	1.2	1	1	0
02/12/2020 14:00	0.6	13.9	1,619.0	0.6	1.1	1	1	0
02/12/2020 15:00	0.6	13.9	1,613.1	0.6	1.1	1	1	0
02/12/2020 16:00	0.6	13.9	1,405.6	0.6	1.0	1	1	0
02/12/2020 17:00	0.6	13.9	1,628.4	0.6	1.1	1	1	0
02/12/2020 18:00	0.7	13.9	1,699.1	0.7	1.2	1	1	1
02/12/2020 19:00	-0.4	12.4	2,057.1	-0.1	1.4	1	1	1
02/12/2020 20:00	-0.2	11.7	2,196.0	0.1	1.5	1	1	1
02/12/2020 21:00	-0.2	11.9	2,156.1	0.1	1.5	1	1	1
02/12/2020 22:00	-0.2	12.0	2,142.0	0.1	1.5	1	1	1
02/12/2020 23:00	-0.2	12.3	2,077.8	0.1	1.5	1	1	1
Average/Sum#:	0.4	13.4	1,733.8	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.4	11.7	1,405.6	-0.1	1.0	1	1	0
Maximum:	0.7	13.9	2,196.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2020 00:00	-0.2	12.3	2,060.0	0.1	1.4	1	1	1
02/13/2020 01:00	-0.2	12.5	2,025.5	0.1	1.4	1	1	1
02/13/2020 02:00	-0.2	12.6	2,033.8	0.1	1.4	1	1	1
02/13/2020 03:00	-0.2	12.5	2,037.4	0.1	1.4	1	1	1
02/13/2020 04:00	-0.2	12.5	2,035.8	0.1	1.4	1	1	1
02/13/2020 05:00	-0.4	12.5	2,044.6	-0.1	1.4	1	1	1
02/13/2020 06:00	-0.4	12.1	2,157.5	-0.1	1.5	1	1	1
02/13/2020 07:00	-0.2	12.3	2,088.9	0.1	1.5	1	1	1
02/13/2020 08:00	-0.2	13.1	1,917.0	-0.1	1.3	1	1	1
02/13/2020 09:00	0.6	13.8	1,657.3	0.6	1.2	1	1	0
02/13/2020 10:00	0.6	13.8	1,643.1	0.6	1.2	1	1	0
02/13/2020 11:00	0.6	13.8	1,649.8	0.6	1.2	1	1	0
02/13/2020 12:00	0.6	13.8	1,677.2	0.6	1.2	1	1	0
02/13/2020 13:00	0.6	13.8	1,616.3	0.6	1.1	1	1	0
02/13/2020 14:00	0.6	13.8	1,632.9	0.6	1.1	1	1	0
02/13/2020 15:00	0.6	13.8	1,583.2	0.6	1.1	1	1	0
02/13/2020 16:00	0.7	13.8	1,593.6	0.7	1.1	1	1	1
02/13/2020 17:00	-0.5	12.4	2,045.2	-0.2	1.4	1	1	1
02/13/2020 18:00	-0.4	12.0	2,137.4	-0.1	1.5	1	1	1
02/13/2020 19:00	-0.4	11.9	2,154.5	-0.1	1.5	1	1	1
02/13/2020 20:00	-0.4	11.9	2,146.4	-0.1	1.5	1	1	1
02/13/2020 21:00	-0.4	12.0	2,143.3	-0.1	1.5	1	1	1
02/13/2020 22:00	-0.4	12.2	2,111.2	-0.1	1.5	1	1	1
02/13/2020 23:00	-0.2	12.2	2,101.8	0.1	1.5	1	1	1
Average/Sum#:	0.0	12.8	1,928.9	0.2	1.3	24 #	24 #	17 #
Minimum:	-0.5	11.9	1,583.2	-0.2	1.1	1	1	0
Maximum:	0.7	13.8	2,157.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2020 00:00	0.0	13.6	1,577.0	0.0	1.1	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.6	1,577.0	0.0	1.1	1 #	0 #	1 #
Minimum:	0.0	13.6	1,577.0	0.0	1.1	0	0	0
Maximum:	0.0	13.6	1,577.0	0.0	1.1	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 15:00	0.0	17.3	476.4	0.0	0.3	1	0	0
02/17/2020 16:00	0.0	14.8	1,059.7	0.0	0.7	1	0	0
02/17/2020 17:00	0.6	13.8	1,688.1	0.6	1.2	1	1	0
02/17/2020 18:00	0.7	13.8	1,736.9	0.7	1.2	1	1	1
02/17/2020 19:00	-0.2	12.8	2,027.7	0.1	1.4	1	1	1
02/17/2020 20:00	-0.2	11.9	2,156.5	0.1	1.5	1	1	1
02/17/2020 21:00	-0.2	12.0	2,146.0	0.1	1.5	1	1	1
02/17/2020 22:00	-0.1	12.1	2,124.4	0.2	1.5	1	1	1
02/17/2020 23:00	-0.1	12.4	2,071.6	0.2	1.5	1	1	1
Average/Sum#:	0.1	13.4	1,720.8	0.2	1.2	9 #	7 #	6 #
Minimum:	-0.2	11.9	476.4	0.0	0.3	0	0	0
Maximum:	0.7	17.3	2,156.5	0.7	1.5	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2020 00:00	-0.1	12.4	2,066.5	0.2	1.4	1	1	1
02/18/2020 01:00	-0.2	12.4	2,066.8	0.1	1.4	1	1	1
02/18/2020 02:00	-0.1	12.6	2,040.1	0.1	1.4	1	1	1
02/18/2020 03:00	-0.2	12.5	2,066.0	0.1	1.4	1	1	1
02/18/2020 04:00	-0.2	12.5	2,068.7	0.1	1.4	1	1	1
02/18/2020 05:00	-0.2	12.3	2,092.3	0.1	1.5	1	1	1
02/18/2020 06:00	-0.2	12.2	2,133.3	0.1	1.5	1	1	1
02/18/2020 07:00	-0.2	12.2	2,122.7	0.1	1.5	1	1	1
02/18/2020 08:00	-0.1	12.4	2,064.2	0.2	1.4	1	1	1
02/18/2020 09:00	-0.1	13.0	1,941.2	0.1	1.4	1	1	1
02/18/2020 10:00	-0.4	13.1	1,937.3	-0.1	1.4	1	1	1
02/18/2020 11:00	-0.4	13.1	1,939.2	-0.1	1.4	1	1	1
02/18/2020 12:00	-0.4	13.0	1,938.0	-0.1	1.4	1	1	1
02/18/2020 13:00	0.5	13.5	1,762.5	0.5	1.2	1	1	1
02/18/2020 14:00	0.6	13.8	1,407.4	0.6	1.0	1	1	0
02/18/2020 15:00	0.7	13.8	1,496.5	0.7	1.0	1	1	1
02/18/2020 16:00	-0.4	12.7	2,010.6	-0.1	1.4	1	1	1
02/18/2020 17:00	-0.4	12.0	2,148.3	-0.1	1.5	1	1	1
02/18/2020 18:00	-0.2	11.9	2,168.1	0.1	1.5	1	1	1
02/18/2020 19:00	-0.2	11.7	2,225.2	0.1	1.6	1	1	1
02/18/2020 20:00	-0.2	11.6	2,244.2	0.1	1.6	1	1	1
02/18/2020 21:00	-0.1	11.8	2,171.7	0.2	1.5	1	1	1
02/18/2020 22:00	-0.1	12.0	2,124.2	0.2	1.5	1	1	1
02/18/2020 23:00	-0.1	12.4	2,064.9	0.2	1.4	1	1	1
Average/Sum#:	-0.1	12.5	2,012.5	0.1	1.4	24 #	24 #	23 #
Minimum:	-0.4	11.6	1,407.4	-0.1	1.0	1	1	0
Maximum:	0.7	13.8	2,244.2	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/19/2020 00:00	-0.2	11.7	2,249.6	0.1	1.6	1	1	1
02/19/2020 01:00	-0.1	12.6	2,031.7	0.1	1.4	1	1	1
02/19/2020 02:00	-0.1	13.1	1,922.5	0.1	1.3	1	1	1
02/19/2020 03:00	-0.2	13.1	1,928.7	-0.1	1.4	1	1	1
02/19/2020 04:00	-0.2	12.4	2,077.8	0.1	1.5	1	1	1
02/19/2020 05:00	-0.4	12.4	2,109.0	-0.1	1.5	1	1	1
02/19/2020 06:00	-0.2	12.3	2,116.3	0.1	1.5	1	1	1
02/19/2020 07:00	-0.2	11.8	2,208.7	0.1	1.5	1	1	1
02/19/2020 08:00	-0.1	12.8	1,979.8	0.1	1.4	1	1	1
02/19/2020 09:00	-0.2	13.0	1,893.9	0.1	1.3	1	1	1
02/19/2020 10:00	-0.7	13.1	1,904.0	-0.4	1.3	1	1	1
02/19/2020 11:00	-0.8	13.1	1,905.4	-0.5	1.3	1	1	1
02/19/2020 12:00	-0.8	13.1	1,902.5	-0.5	1.3	1	1	1
02/19/2020 13:00	-0.8	13.0	1,911.6	-0.4	1.3	1	1	1
02/19/2020 14:00	-0.7	13.0	1,914.0	-0.4	1.3	1	1	1
02/19/2020 15:00	-0.7	13.0	1,909.1	-0.4	1.3	1	1	1
02/19/2020 16:00	-0.4	12.5	2,010.2	-0.1	1.4	1	1	1
02/19/2020 17:00	-0.2	11.9	2,143.0	0.1	1.5	1	1	1
02/19/2020 18:00	-0.2	11.8	2,145.6	0.1	1.5	1	1	1
02/19/2020 19:00	-0.2	11.5	2,223.4	0.1	1.6	1	1	1
02/19/2020 20:00	-0.2	11.6	2,201.3	0.1	1.5	1	1	1
02/19/2020 21:00	-0.2	11.6	2,192.1	0.1	1.5	1	1	1
02/19/2020 22:00	-0.2	12.3	2,054.7	0.1	1.4	1	1	1
02/19/2020 23:00	-0.2	12.5	2,018.0	0.1	1.4	1	1	1
Average/Sum#:	-0.3	12.5	2,039.7	-0.1	1.4	24 #	24 #	24 #
Minimum:	-0.8	11.5	1,893.9	-0.5	1.3	1	1	1
Maximum:	-0.1	13.1	2,249.6	0.1	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2020 00:00	-0.1	12.7	1,994.1	0.1	1.4	1	1	1
02/20/2020 01:00	-0.2	12.6	2,011.8	0.1	1.4	1	1	1
02/20/2020 02:00	-0.2	12.5	2,012.7	0.1	1.4	1	1	1
02/20/2020 03:00	-0.2	12.5	2,011.7	0.1	1.4	1	1	1
02/20/2020 04:00	-0.2	12.5	2,011.9	0.1	1.4	1	1	1
02/20/2020 05:00	-0.2	12.5	2,026.7	0.1	1.4	1	1	1
02/20/2020 06:00	-0.4	12.4	2,046.5	-0.1	1.4	1	1	1
02/20/2020 07:00	-0.2	12.4	2,052.1	0.1	1.4	1	1	1
02/20/2020 08:00	-0.2	12.5	2,022.8	0.1	1.4	1	1	1
02/20/2020 09:00	-0.1	13.0	1,907.2	0.1	1.3	1	1	1
02/20/2020 10:00	-0.2	13.0	1,906.6	0.1	1.3	1	1	1
02/20/2020 11:00	-0.2	13.0	1,906.0	0.1	1.3	1	1	1
02/20/2020 12:00	-0.2	13.0	1,908.2	0.1	1.3	1	1	1
02/20/2020 13:00	-0.2	13.0	1,907.3	0.1	1.3	1	1	1
02/20/2020 14:00	-0.2	12.9	1,924.7	0.1	1.3	1	1	1
02/20/2020 15:00	-0.2	12.7	1,969.4	0.1	1.4	1	1	1
02/20/2020 16:00	-0.2	12.3	2,056.7	0.1	1.4	1	1	1
02/20/2020 17:00	-0.2	12.2	2,066.3	0.1	1.4	1	1	1
02/20/2020 18:00	-0.4	12.2	2,068.5	-0.1	1.4	1	1	1
02/20/2020 19:00	-0.4	12.1	2,089.9	-0.1	1.5	1	1	1
02/20/2020 20:00	-0.4	12.0	2,112.5	-0.1	1.5	1	1	1
02/20/2020 21:00	-0.2	12.0	2,127.1	0.1	1.5	1	1	1
02/20/2020 22:00	-0.2	12.0	2,114.6	0.1	1.5	1	1	1
02/20/2020 23:00	-0.2	12.4	2,042.5	0.1	1.4	1	1	1
Average/Sum#:	-0.2	12.5	2,012.4	0.1	1.4	24 #	24 #	24 #
Minimum:	-0.4	12.0	1,906.0	-0.1	1.3	1	1	1
Maximum:	-0.1	13.0	2,127.1	0.1	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/21/2020 00:00	-0.1	12.9	1,885.5	0.1	1.3	1	1	1
02/21/2020 01:00	0.6	13.8	1,507.6	0.6	1.1	1	1	0
02/21/2020 02:00	0.6	13.8	1,450.8	0.6	1.0	1	1	0
02/21/2020 03:00	0.6	13.8	1,534.4	0.6	1.1	1	1	0
02/21/2020 04:00	0.6	13.8	1,650.6	0.6	1.2	1	1	0
02/21/2020 05:00	0.6	13.8	1,556.8	0.6	1.1	1	1	0
02/21/2020 06:00	0.6	13.8	1,647.8	0.6	1.2	1	1	0
02/21/2020 07:00	0.6	13.7	1,610.7	0.6	1.1	1	1	0
02/21/2020 08:00	0.6	13.7	1,520.8	0.6	1.1	1	1	0
02/21/2020 09:00	0.6	13.7	1,643.6	0.6	1.2	1	1	0
02/21/2020 10:00	0.6	13.8	1,590.4	0.6	1.1	1	1	0
02/21/2020 11:00	0.6	13.8	1,579.0	0.6	1.1	1	1	0
02/21/2020 12:00	0.6	13.7	1,644.4	0.6	1.2	1	1	0
02/21/2020 13:00	0.6	13.7	1,642.8	0.6	1.1	1	1	0
02/21/2020 14:00	0.6	13.7	1,666.4	0.6	1.2	1	1	0
02/21/2020 15:00	0.6	13.7	1,654.8	0.6	1.2	1	1	0
02/21/2020 16:00	0.7	13.7	1,665.5	0.7	1.2	1	1	1
02/21/2020 17:00	-0.4	12.6	1,969.1	-0.1	1.4	1	1	1
02/21/2020 18:00	-0.4	12.0	2,074.9	-0.1	1.5	1	1	1
02/21/2020 19:00	-0.2	12.2	2,045.6	0.1	1.4	1	1	1
02/21/2020 20:00	-0.2	12.1	2,057.5	0.1	1.4	1	1	1
02/21/2020 21:00	-0.2	12.3	2,033.5	0.1	1.4	1	1	1
02/21/2020 22:00	-0.2	12.1	2,065.4	0.1	1.4	1	1	1
02/21/2020 23:00	0.0	13.9	1,250.8	0.0	0.9	1	0	1
Average/Sum#:	0.3	13.3	1,706.2	0.4	1.2	24 #	23 #	9 #
Minimum:	-0.4	12.0	1,250.8	-0.1	0.9	1	0	0
Maximum:	0.7	13.9	2,074.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/25/2020 14:00	0.0	17.4	455.6	0.0	0.3	1	0	0
02/25/2020 15:00	0.0	15.3	804.4	0.0	0.6	1	0	0
02/25/2020 16:00	0.6	13.8	1,602.6	0.6	1.1	1	1	0
02/25/2020 17:00	0.7	13.8	1,522.9	0.7	1.1	1	1	1
02/25/2020 18:00	-0.2	12.7	1,961.2	0.1	1.4	1	1	1
02/25/2020 19:00	-0.2	11.9	2,107.0	0.1	1.5	1	1	1
02/25/2020 20:00	-0.2	11.8	2,141.5	0.1	1.5	1	1	1
02/25/2020 21:00	-0.2	11.9	2,122.5	0.1	1.5	1	1	1
02/25/2020 22:00	-0.2	11.9	2,115.1	0.1	1.5	1	1	1
02/25/2020 23:00	-0.2	12.0	2,106.7	0.1	1.5	1	1	1
Average/Sum#:	0.0	13.3	1,694.0	0.2	1.2	10 #	8 #	7 #
Minimum:	-0.2	11.8	455.6	0.0	0.3	0	0	0
Maximum:	0.7	17.4	2,141.5	0.7	1.5	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2020 00:00	-0.2	12.4	2,020.7	0.1	1.4	1	1	1
02/26/2020 01:00	-0.2	12.3	2,021.8	0.1	1.4	1	1	1
02/26/2020 02:00	-0.2	12.3	2,020.8	0.1	1.4	1	1	1
02/26/2020 03:00	-0.2	12.4	2,016.4	0.1	1.4	1	1	1
02/26/2020 04:00	-0.2	12.5	2,013.9	0.1	1.4	1	1	1
02/26/2020 05:00	-0.2	12.5	2,005.6	0.1	1.4	1	1	1
02/26/2020 06:00	-0.2	12.6	2,000.6	0.1	1.4	1	1	1
02/26/2020 07:00	-0.1	12.7	1,987.0	0.1	1.4	1	1	1
02/26/2020 08:00	0.0	14.2	1,195.8	0.0	0.8	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.2	12.7	1,920.3	0.1	1.3	9 #	8 #	9 #
Minimum:	-0.2	12.3	1,195.8	0.0	0.8	0	0	0
Maximum:	0.0	14.2	2,021.8	0.1	1.4	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/27/2020 02:00	0.0	17.8	412.9	0.0	0.3	1	0	0
02/27/2020 03:00	0.0	15.0	954.0	0.0	0.7	1	0	0
02/27/2020 04:00	0.6	13.7	1,724.7	0.6	1.2	1	1	0
02/27/2020 05:00	0.6	13.7	1,726.4	0.6	1.2	1	1	0
02/27/2020 06:00	0.6	13.7	1,720.7	0.6	1.2	1	1	0
02/27/2020 07:00	0.6	13.7	1,725.1	0.6	1.2	1	1	0
02/27/2020 08:00	0.6	13.7	1,722.2	0.6	1.2	1	1	0
02/27/2020 09:00	0.6	13.7	1,726.6	0.6	1.2	1	1	0
02/27/2020 10:00	0.6	13.7	1,727.3	0.6	1.2	1	1	0
02/27/2020 11:00	0.6	13.7	1,723.8	0.6	1.2	1	1	0
02/27/2020 12:00	0.6	13.7	1,706.6	0.6	1.2	1	1	0
02/27/2020 13:00	0.6	13.7	1,656.0	0.6	1.2	1	1	0
02/27/2020 14:00	0.6	13.7	1,645.9	0.6	1.2	1	1	0
02/27/2020 15:00	0.6	13.7	1,633.4	0.6	1.1	1	1	0
02/27/2020 16:00	0.1	13.1	1,809.7	0.2	1.3	1	1	1
02/27/2020 17:00	-0.4	12.2	2,033.9	-0.1	1.4	1	1	1
02/27/2020 18:00	-0.4	12.2	2,035.4	-0.1	1.4	1	1	1
02/27/2020 19:00	-0.4	12.2	2,038.8	-0.1	1.4	1	1	1
02/27/2020 20:00	-0.4	12.1	2,078.5	-0.1	1.5	1	1	1
02/27/2020 21:00	-0.4	12.0	2,080.8	-0.1	1.5	1	1	1
02/27/2020 22:00	-0.4	12.0	2,085.8	-0.1	1.5	1	1	1
02/27/2020 23:00	-0.2	12.5	1,993.6	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.4	1,725.6	0.3	1.2	22 #	20 #	8 #
Minimum:	-0.4	12.0	412.9	-0.1	0.3	0	0	0
Maximum:	0.6	17.8	2,085.8	0.6	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2020 00:00	-0.2	13.0	1,887.0	0.1	1.3	1	1	1
02/28/2020 01:00	0.6	13.7	1,557.1	0.6	1.1	1	1	0
02/28/2020 02:00	0.6	13.7	1,468.7	0.6	1.0	1	1	0
02/28/2020 03:00	0.6	13.7	1,493.7	0.6	1.0	1	1	0
02/28/2020 04:00	0.6	13.7	1,487.3	0.6	1.0	1	1	0
02/28/2020 05:00	0.6	13.7	1,616.7	0.6	1.1	1	1	0
02/28/2020 06:00	0.6	13.7	1,654.1	0.6	1.2	1	1	0
02/28/2020 07:00	0.6	13.7	1,614.9	0.6	1.1	1	1	0
02/28/2020 08:00	0.6	13.7	1,520.5	0.6	1.1	1	1	0
02/28/2020 09:00	0.6	13.7	1,506.4	0.6	1.1	1	1	0
02/28/2020 10:00	0.6	13.8	1,450.9	0.6	1.0	1	1	0
02/28/2020 11:00	0.6	13.8	1,484.2	0.6	1.0	1	1	0
02/28/2020 12:00	0.6	13.8	1,544.1	0.6	1.1	1	1	0
02/28/2020 13:00	0.6	13.8	1,577.6	0.6	1.1	1	1	0
02/28/2020 14:00	0.6	13.8	1,423.0	0.6	1.0	1	1	0
02/28/2020 15:00	0.7	13.7	1,534.4	0.7	1.1	1	1	1
02/28/2020 16:00	-0.5	12.3	1,998.1	-0.1	1.4	1	1	1
02/28/2020 17:00	-0.5	12.1	2,028.7	-0.1	1.4	1	1	1
02/28/2020 18:00	-0.4	12.2	2,014.6	-0.1	1.4	1	1	1
02/28/2020 19:00	-0.5	12.2	2,024.8	-0.1	1.4	1	1	1
02/28/2020 20:00	-0.4	12.3	2,006.3	-0.1	1.4	1	1	1
02/28/2020 21:00	-0.5	12.2	2,038.9	-0.1	1.4	1	1	1
02/28/2020 22:00	-0.4	12.3	2,014.9	-0.1	1.4	1	1	1
02/28/2020 23:00	0.0	14.0	1,212.1	0.0	0.8	1	0	1
Average/Sum#:	0.2	13.3	1,673.3	0.4	1.2	24 #	23 #	10 #
Minimum:	-0.5	12.1	1,212.1	-0.1	0.8	1	0	0
Maximum:	0.7	14.0	2,038.9	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 15:00	0.0	17.5	437.3	0.0	0.3	1	0	0
03/03/2020 16:00	0.0	15.4	820.8	0.0	0.6	1	0	0
03/03/2020 17:00	0.7	13.7	1,578.6	0.7	1.1	1	1	1
03/03/2020 18:00	-0.2	12.0	2,074.2	0.1	1.5	1	1	1
03/03/2020 19:00	-0.2	11.6	2,145.8	0.1	1.5	1	1	1
03/03/2020 20:00	-0.2	11.6	2,146.2	0.1	1.5	1	1	1
03/03/2020 21:00	-0.1	11.6	2,149.4	0.2	1.5	1	1	1
03/03/2020 22:00	-0.1	11.8	2,115.9	0.2	1.5	1	1	1
03/03/2020 23:00	-0.2	12.0	2,083.0	0.1	1.5	1	1	1
Average/Sum#:	0.0	13.0	1,727.9	0.2	1.2	9 #	7 #	7 #
Minimum:	-0.2	11.6	437.3	0.0	0.3	0	0	0
Maximum:	0.7	17.5	2,149.4	0.7	1.5	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2020 00:00	-0.2	12.3	2,029.8	0.1	1.4	1	1	1
03/04/2020 01:00	-0.2	12.3	2,018.3	0.1	1.4	1	1	1
03/04/2020 02:00	-0.1	12.6	1,967.9	0.1	1.4	1	1	1
03/04/2020 03:00	-0.1	12.7	1,963.5	0.1	1.4	1	1	1
03/04/2020 04:00	-0.2	12.4	2,016.0	0.1	1.4	1	1	1
03/04/2020 05:00	-0.2	12.4	2,014.7	0.1	1.4	1	1	1
03/04/2020 06:00	-0.2	12.4	2,013.8	0.1	1.4	1	1	1
03/04/2020 07:00	-0.2	12.4	2,002.8	0.1	1.4	1	1	1
03/04/2020 08:00	0.7	13.7	1,479.7	0.7	1.0	1	1	1
03/04/2020 09:00	0.6	13.8	1,353.7	0.6	0.9	1	1	0
03/04/2020 10:00	0.6	13.8	1,354.8	0.6	0.9	1	1	0
03/04/2020 11:00	0.6	13.8	1,549.6	0.6	1.1	1	1	0
03/04/2020 12:00	0.6	13.8	1,675.0	0.6	1.2	1	1	0
03/04/2020 13:00	0.6	13.8	1,511.4	0.6	1.1	1	1	0
03/04/2020 14:00	0.6	13.8	1,600.8	0.6	1.1	1	1	0
03/04/2020 15:00	0.6	13.8	1,577.7	0.6	1.1	1	1	0
03/04/2020 16:00	0.7	13.8	1,521.5	0.7	1.1	1	1	1
03/04/2020 17:00	-0.4	12.3	2,009.6	-0.1	1.4	1	1	1
03/04/2020 18:00	-0.4	12.2	2,034.2	-0.1	1.4	1	1	1
03/04/2020 19:00	-0.4	12.2	2,030.5	-0.1	1.4	1	1	1
03/04/2020 20:00	-0.4	11.9	2,101.7	-0.1	1.5	1	1	1
03/04/2020 21:00	-0.4	11.8	2,112.9	-0.1	1.5	1	1	1
03/04/2020 22:00	-0.2	11.9	2,098.3	0.1	1.5	1	1	1
03/04/2020 23:00	-0.2	12.2	2,041.8	0.1	1.4	1	1	1
Average/Sum#:	0.1	12.8	1,836.7	0.3	1.3	24 #	24 #	17 #
Minimum:	-0.4	11.8	1,353.7	-0.1	0.9	1	1	0
Maximum:	0.7	13.8	2,112.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2020 00:00	-0.2	12.6	1,966.1	0.1	1.4	1	1	1
03/05/2020 01:00	-0.2	12.6	1,952.8	0.1	1.4	1	1	1
03/05/2020 02:00	-0.2	12.6	1,960.2	0.1	1.4	1	1	1
03/05/2020 03:00	-0.2	12.6	1,960.5	0.1	1.4	1	1	1
03/05/2020 04:00	-0.4	12.2	2,034.1	-0.1	1.4	1	1	1
03/05/2020 05:00	-0.4	12.2	2,034.5	-0.1	1.4	1	1	1
03/05/2020 06:00	-0.4	12.3	2,021.4	-0.1	1.4	1	1	1
03/05/2020 07:00	-0.2	12.6	1,959.5	0.1	1.4	1	1	1
03/05/2020 08:00	0.6	13.7	1,597.3	0.6	1.1	1	1	0
03/05/2020 09:00	0.6	13.7	1,662.5	0.6	1.2	1	1	0
03/05/2020 10:00	0.6	13.7	1,668.7	0.6	1.2	1	1	0
03/05/2020 11:00	0.6	13.7	1,657.3	0.6	1.2	1	1	0
03/05/2020 12:00	0.6	13.7	1,630.3	0.6	1.1	1	1	0
03/05/2020 13:00	0.6	13.7	1,666.1	0.6	1.2	1	1	0
03/05/2020 14:00	0.6	13.6	1,563.5	0.6	1.1	1	1	0
03/05/2020 15:00	0.6	13.7	1,497.7	0.6	1.0	1	1	0
03/05/2020 16:00	0.5	13.7	1,458.4	0.5	1.0	1	1	1
03/05/2020 17:00	-0.5	12.3	1,979.7	-0.1	1.4	1	1	1
03/05/2020 18:00	-0.4	12.0	2,041.5	-0.1	1.4	1	1	1
03/05/2020 19:00	-0.4	12.1	2,040.7	-0.1	1.4	1	1	1
03/05/2020 20:00	-0.4	12.2	2,029.4	-0.1	1.4	1	1	1
03/05/2020 21:00	-0.4	12.1	2,059.0	-0.1	1.4	1	1	1
03/05/2020 22:00	-0.4	12.1	2,058.2	-0.1	1.4	1	1	1
03/05/2020 23:00	-0.4	12.5	1,965.0	-0.1	1.4	1	1	1
Average/Sum#:	0.0	12.8	1,852.7	0.2	1.3	24 #	24 #	16 #
Minimum:	-0.5	12.0	1,458.4	-0.1	1.0	1	1	0
Maximum:	0.6	13.7	2,059.0	0.6	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2020 00:00	-0.5	12.2	2,036.4	-0.1	1.4	1	1	1
03/06/2020 01:00	-0.4	12.2	2,039.3	-0.1	1.4	1	1	1
03/06/2020 02:00	-0.4	12.5	1,968.2	-0.1	1.4	1	1	1
03/06/2020 03:00	-0.4	12.4	2,000.8	-0.1	1.4	1	1	1
03/06/2020 04:00	-0.5	12.3	2,013.8	-0.1	1.4	1	1	1
03/06/2020 05:00	-0.5	12.2	2,032.9	-0.1	1.4	1	1	1
03/06/2020 06:00	-0.5	12.3	2,023.9	-0.1	1.4	1	1	1
03/06/2020 07:00	-0.4	12.4	2,004.9	-0.1	1.4	1	1	1
03/06/2020 08:00	-0.4	12.7	1,919.4	-0.1	1.3	1	1	1
03/06/2020 09:00	0.6	13.7	1,604.2	0.6	1.1	1	1	0
03/06/2020 10:00	0.6	13.7	1,647.6	0.6	1.2	1	1	0
03/06/2020 11:00	0.6	13.7	1,663.3	0.6	1.2	1	1	0
03/06/2020 12:00	0.2	13.7	1,633.4	0.3	1.1	1	1	0
03/06/2020 13:00	0.6	13.7	1,655.1	0.6	1.2	1	1	0
03/06/2020 14:00	0.6	13.7	1,619.0	0.6	1.1	1	1	0
03/06/2020 15:00	0.6	13.7	1,601.2	0.6	1.1	1	1	0
03/06/2020 16:00	0.7	13.7	1,497.5	0.7	1.0	1	1	1
03/06/2020 17:00	-0.5	12.4	1,977.0	-0.2	1.4	1	1	1
03/06/2020 18:00	-0.4	12.2	2,017.0	-0.1	1.4	1	1	1
03/06/2020 19:00	-0.4	12.2	2,021.3	-0.1	1.4	1	1	1
03/06/2020 20:00	-0.4	11.9	2,080.6	-0.1	1.5	1	1	1
03/06/2020 21:00	-0.2	11.8	2,105.2	0.1	1.5	1	1	1
03/06/2020 22:00	-0.2	12.0	2,069.3	0.1	1.4	1	1	1
03/06/2020 23:00	-0.4	12.1	2,033.4	-0.1	1.4	1	1	1
Average/Sum#:	-0.1	12.7	1,886.0	0.1	1.3	24 #	24 #	17 #
Minimum:	-0.5	11.8	1,497.5	-0.2	1.0	1	1	0
Maximum:	0.7	13.7	2,105.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2020 00:00	0.0	13.9	1,233.3	0.0	0.9	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.9	1,233.3	0.0	0.9	1 #	0 #	1 #
Minimum:	0.0	13.9	1,233.3	0.0	0.9	0	0	0
Maximum:	0.0	13.9	1,233.3	0.0	0.9	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/09/2020 01:00	0.0	18.6	326.1	0.0	0.2	1	0	0
03/09/2020 02:00	0.0	16.3	622.9	0.0	0.4	1	0	0
03/09/2020 03:00	0.0	13.7	1,466.3	0.0	1.0	1	0	0
03/09/2020 04:00	0.7	13.7	1,559.0	0.7	1.1	1	1	1
03/09/2020 05:00	-0.1	12.6	1,997.4	0.1	1.4	1	1	1
03/09/2020 06:00	-0.1	12.0	2,130.1	0.2	1.5	1	1	1
03/09/2020 07:00	0.1	12.0	2,111.7	0.2	1.5	1	1	1
03/09/2020 08:00	0.1	12.0	2,100.6	0.2	1.5	1	1	1
03/09/2020 09:00	0.7	13.5	1,646.5	0.7	1.2	1	1	1
03/09/2020 10:00	0.6	13.7	1,567.7	0.6	1.1	1	1	0
03/09/2020 11:00	0.6	13.7	1,541.6	0.6	1.1	1	1	0
03/09/2020 12:00	0.6	13.7	1,665.3	0.6	1.2	1	1	0
03/09/2020 13:00	0.6	13.7	1,668.1	0.6	1.2	1	1	0
03/09/2020 14:00	0.6	13.7	1,664.9	0.6	1.2	1	1	0
03/09/2020 15:00	0.6	13.7	1,639.8	0.6	1.1	1	1	0
03/09/2020 16:00	0.7	13.7	1,657.1	0.7	1.2	1	1	1
03/09/2020 17:00	-0.4	12.4	1,999.7	-0.1	1.4	1	1	1
03/09/2020 18:00	-0.4	11.7	2,141.2	0.1	1.5	1	1	1
03/09/2020 19:00	-0.4	11.7	2,146.6	0.1	1.5	1	1	1
03/09/2020 20:00	-0.2	11.9	2,111.3	0.1	1.5	1	1	1
03/09/2020 21:00	-0.2	11.8	2,114.6	0.1	1.5	1	1	1
03/09/2020 22:00	-0.2	11.8	2,114.0	0.1	1.5	1	1	1
03/09/2020 23:00	-0.2	11.8	2,113.7	0.1	1.5	1	1	1
Average/Sum#:	0.2	13.2	1,743.7	0.3	1.2	23 #	20 #	14 #
Minimum:	-0.4	11.7	326.1	-0.1	0.2	0	0	0
Maximum:	0.7	18.6	2,146.6	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/10/2020 00:00	-0.2	11.8	2,115.8	0.1	1.5	1	1	1
03/10/2020 01:00	-0.2	11.9	2,105.0	0.1	1.5	1	1	1
03/10/2020 02:00	-0.2	11.9	2,094.0	0.1	1.5	1	1	1
03/10/2020 03:00	-0.2	12.2	2,048.8	0.1	1.4	1	1	1
03/10/2020 04:00	-0.2	12.2	2,051.9	0.1	1.4	1	1	1
03/10/2020 05:00	-0.4	11.6	2,145.4	0.1	1.5	1	1	1
03/10/2020 06:00	-0.2	11.4	2,215.2	0.1	1.6	1	1	1
03/10/2020 07:00	-0.2	11.5	2,176.7	0.1	1.5	1	1	1
03/10/2020 08:00	0.7	0.0	2,150.2	0.7	1.5	1	1	1
03/10/2020 09:00	-0.1	12.3	2,099.1	0.2	1.5	1	1	1
03/10/2020 10:00	0.1	12.4	2,063.7	0.2	1.4	1	1	1
03/10/2020 11:00	0.1	12.2	2,093.0	0.2	1.5	1	1	1
03/10/2020 12:00	0.1	12.1	2,114.6	0.2	1.5	1	1	1
03/10/2020 13:00	0.1	12.1	2,099.9	0.2	1.5	1	1	1
03/10/2020 14:00	0.2	12.0	2,114.1	0.4	1.5	1	1	1
03/10/2020 15:00	0.2	12.2	2,089.1	0.4	1.5	1	1	1
03/10/2020 16:00	0.2	12.1	2,090.0	0.4	1.5	1	1	1
03/10/2020 17:00	0.2	12.3	2,060.3	0.4	1.4	1	1	1
03/10/2020 18:00	0.2	11.8	2,159.1	0.4	1.5	1	1	1
03/10/2020 19:00	0.2	11.6	2,194.4	0.4	1.5	1	1	1
03/10/2020 20:00	0.2	11.7	2,192.6	0.4	1.5	1	1	1
03/10/2020 21:00	0.2	12.0	2,115.1	0.4	1.5	1	1	1
03/10/2020 22:00	0.2	12.2	2,099.5	0.4	1.5	1	1	1
03/10/2020 23:00	0.2	12.2	2,072.5	0.4	1.5	1	1	1
Average/Sum#:	0.0	12.0	2,115.0	0.3	1.5	24 #	24 #	24 #
Minimum:	-0.4	11.4	2,048.8	0.1	1.4	1	1	1
Maximum:	0.2	12.4	2,215.2	0.4	1.6	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2020 00:00	0.2	12.6	2,007.3	0.4	1.4	1	1	1
03/11/2020 01:00	0.1	12.6	2,001.4	0.2	1.4	1	1	1
03/11/2020 02:00	0.1	12.5	2,014.6	0.2	1.4	1	1	1
03/11/2020 03:00	-0.1	12.5	2,017.7	0.1	1.4	1	1	1
03/11/2020 04:00	-0.1	12.5	2,046.2	0.1	1.4	1	1	1
03/11/2020 05:00	-0.1	12.0	2,104.5	0.2	1.5	1	1	1
03/11/2020 06:00	0.1	11.7	2,189.2	0.2	1.5	1	1	1
03/11/2020 07:00	0.1	12.2	2,105.0	0.2	1.5	1	1	1
03/11/2020 08:00	0.1	12.2	2,099.4	0.2	1.5	1	1	1
03/11/2020 09:00	0.7	13.7	1,684.2	0.7	1.2	1	1	1
03/11/2020 10:00	0.6	13.9	1,618.7	0.6	1.1	1	1	0
03/11/2020 11:00	0.6	13.9	1,533.3	0.6	1.1	1	1	0
03/11/2020 12:00	0.6	14.0	1,567.8	0.6	1.1	1	1	0
03/11/2020 13:00	0.6	14.0	1,654.9	0.6	1.2	1	1	0
03/11/2020 14:00	0.6	14.0	1,621.7	0.6	1.1	1	1	0
03/11/2020 15:00	0.6	14.0	1,529.6	0.6	1.1	1	1	0
03/11/2020 16:00	0.6	14.1	1,323.4	0.6	0.9	1	1	0
03/11/2020 17:00	0.6	14.0	1,609.1	0.6	1.1	1	1	0
03/11/2020 18:00	0.7	13.9	1,675.6	0.7	1.2	1	1	1
03/11/2020 19:00	-0.2	12.6	2,002.8	0.1	1.4	1	1	1
03/11/2020 20:00	-0.1	11.7	2,170.1	0.2	1.5	1	1	1
03/11/2020 21:00	-0.1	12.0	2,114.6	0.2	1.5	1	1	1
03/11/2020 22:00	-0.1	12.3	2,054.4	0.2	1.4	1	1	1
03/11/2020 23:00	-0.1	12.2	2,098.7	0.2	1.5	1	1	1
Average/Sum#:	0.3	13.0	1,868.5	0.4	1.3	24 #	24 #	16 #
Minimum:	-0.2	11.7	1,323.4	0.1	0.9	1	1	0
Maximum:	0.7	14.1	2,189.2	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2020 00:00	0.1	12.3	2,055.5	0.2	1.4	1	1	1
03/12/2020 01:00	0.1	12.5	2,022.4	0.2	1.4	1	1	1
03/12/2020 02:00	0.1	12.7	1,963.5	0.2	1.4	1	1	1
03/12/2020 03:00	0.1	12.5	2,018.6	0.2	1.4	1	1	1
03/12/2020 04:00	0.1	12.3	2,056.9	0.2	1.4	1	1	1
03/12/2020 05:00	0.1	12.0	2,072.2	0.2	1.5	1	1	1
03/12/2020 06:00	0.1	11.6	2,194.7	0.2	1.5	1	1	1
03/12/2020 07:00	0.1	11.8	2,182.0	0.2	1.5	1	1	1
03/12/2020 08:00	0.2	12.2	2,052.2	0.4	1.4	1	1	1
03/12/2020 09:00	0.6	13.9	1,636.4	0.6	1.1	1	1	0
03/12/2020 10:00	0.6	13.9	1,646.8	0.6	1.2	1	1	0
03/12/2020 11:00	0.6	14.0	1,630.8	0.6	1.1	1	1	0
03/12/2020 12:00	0.6	14.0	1,664.1	0.6	1.2	1	1	0
03/12/2020 13:00	0.6	14.0	1,557.2	0.6	1.1	1	1	0
03/12/2020 14:00	0.6	13.9	1,643.3	0.6	1.2	1	1	0
03/12/2020 15:00	0.5	13.3	1,804.7	0.5	1.3	1	1	1
03/12/2020 16:00	0.1	12.1	2,081.5	0.2	1.5	1	1	1
03/12/2020 17:00	0.1	11.8	2,146.6	0.2	1.5	1	1	1
03/12/2020 18:00	0.2	11.6	2,186.7	0.4	1.5	1	1	1
03/12/2020 19:00	0.2	11.6	2,196.4	0.4	1.5	1	1	1
03/12/2020 20:00	0.2	12.2	2,077.6	0.4	1.5	1	1	1
03/12/2020 21:00	0.2	11.7	2,170.3	0.4	1.5	1	1	1
03/12/2020 22:00	0.2	11.6	2,190.6	0.4	1.5	1	1	1
03/12/2020 23:00	0.2	11.7	2,182.4	0.4	1.5	1	1	1
Average/Sum#:	0.3	12.6	1,976.4	0.4	1.4	24 #	24 #	18 #
Minimum:	0.1	11.6	1,557.2	0.2	1.1	1	1	0
Maximum:	0.6	14.0	2,196.4	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2020 00:00	0.2	11.7	2,175.0	0.4	1.5	1	1	1
03/13/2020 01:00	0.1	11.8	2,173.7	0.2	1.5	1	1	1
03/13/2020 02:00	0.1	11.8	2,161.9	0.2	1.5	1	1	1
03/13/2020 03:00	0.1	11.8	2,157.8	0.2	1.5	1	1	1
03/13/2020 04:00	0.1	12.1	2,111.2	0.2	1.5	1	1	1
03/13/2020 05:00	0.1	11.6	2,189.2	0.2	1.5	1	1	1
03/13/2020 06:00	0.1	11.8	2,165.8	0.2	1.5	1	1	1
03/13/2020 07:00	0.1	12.0	2,142.1	0.2	1.5	1	1	1
03/13/2020 08:00	0.1	11.9	2,148.7	0.2	1.5	1	1	1
03/13/2020 09:00	0.7	13.6	1,689.9	0.7	1.2	1	1	1
03/13/2020 10:00	0.6	14.0	1,572.2	0.6	1.1	1	1	0
03/13/2020 11:00	0.6	14.0	1,606.7	0.6	1.1	1	1	0
03/13/2020 12:00	0.6	14.0	1,652.9	0.6	1.2	1	1	0
03/13/2020 13:00	0.6	14.0	1,603.7	0.6	1.1	1	1	0
03/13/2020 14:00	0.6	13.9	1,638.9	0.6	1.1	1	1	0
03/13/2020 15:00	0.6	14.0	1,645.5	0.6	1.2	1	1	0
03/13/2020 16:00	0.6	14.0	1,660.3	0.6	1.2	1	1	0
03/13/2020 17:00	0.4	13.3	1,791.3	0.4	1.3	1	1	1
03/13/2020 18:00	-0.1	12.4	2,029.0	0.2	1.4	1	1	1
03/13/2020 19:00	0.1	11.7	2,173.5	0.2	1.5	1	1	1
03/13/2020 20:00	0.1	11.6	2,194.0	0.2	1.5	1	1	1
03/13/2020 21:00	0.1	12.0	2,125.1	0.2	1.5	1	1	1
03/13/2020 22:00	0.1	12.2	2,082.7	0.2	1.5	1	1	1
03/13/2020 23:00	0.1	12.4	2,035.7	0.2	1.4	1	1	1
Average/Sum#:	0.3	12.7	1,955.3	0.4	1.4	24 #	24 #	17 #
Minimum:	-0.1	11.6	1,572.2	0.2	1.1	1	1	0
Maximum:	0.7	14.0	2,194.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2020 00:00	0.1	12.1	2,102.7	0.2	1.5	1	1	1
03/14/2020 01:00	0.1	12.0	2,111.9	0.2	1.5	1	1	1
03/14/2020 02:00	0.1	12.1	2,104.4	0.2	1.5	1	1	1
03/14/2020 03:00	0.1	12.1	2,099.9	0.2	1.5	1	1	1
03/14/2020 04:00	0.1	12.5	2,028.5	0.2	1.4	1	1	1
03/14/2020 05:00	-0.1	12.2	2,071.7	0.2	1.5	1	1	1
03/14/2020 06:00	-0.1	12.1	2,112.3	0.2	1.5	1	1	1
03/14/2020 07:00	0.1	12.3	2,065.5	0.2	1.4	1	1	1
03/14/2020 08:00	0.6	14.0	1,723.4	0.6	1.2	1	1	0
03/14/2020 09:00	0.6	14.0	1,717.0	0.6	1.2	1	1	0
03/14/2020 10:00	0.6	14.0	1,713.7	0.6	1.2	1	1	0
03/14/2020 11:00	0.6	14.0	1,714.1	0.6	1.2	1	1	0
03/14/2020 12:00	0.6	14.0	1,712.4	0.6	1.2	1	1	0
03/14/2020 13:00	0.6	14.0	1,708.3	0.6	1.2	1	1	0
03/14/2020 14:00	0.6	14.0	1,711.3	0.6	1.2	1	1	0
03/14/2020 15:00	0.6	14.0	1,711.1	0.6	1.2	1	1	0
03/14/2020 16:00	0.6	14.0	1,718.1	0.6	1.2	1	1	0
03/14/2020 17:00	0.5	13.4	1,802.0	0.5	1.3	1	1	1
03/14/2020 18:00	-0.1	12.3	2,088.0	0.2	1.5	1	1	1
03/14/2020 19:00	0.1	11.8	2,175.9	0.2	1.5	1	1	1
03/14/2020 20:00	0.1	12.0	2,141.1	0.2	1.5	1	1	1
03/14/2020 21:00	-0.1	12.3	2,094.0	0.2	1.5	1	1	1
03/14/2020 22:00	0.1	12.6	2,021.6	0.2	1.4	1	1	1
03/14/2020 23:00	0.1	12.7	2,012.5	0.2	1.4	1	1	1
Average/Sum#:	0.3	12.9	1,935.9	0.4	1.4	24 #	24 #	15 #
Minimum:	-0.1	11.8	1,708.3	0.2	1.2	1	1	0
Maximum:	0.6	14.0	2,175.9	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2020 00:00	-0.1	12.4	2,063.4	0.2	1.4	1	1	1
03/15/2020 01:00	0.1	12.6	2,026.4	0.2	1.4	1	1	1
03/15/2020 02:00	0.1	12.7	2,015.0	0.2	1.4	1	1	1
03/15/2020 03:00	0.1	12.7	2,015.7	0.2	1.4	1	1	1
03/15/2020 04:00	-0.1	12.6	2,028.1	0.1	1.4	1	1	1
03/15/2020 05:00	-0.1	12.7	2,025.5	0.1	1.4	1	1	1
03/15/2020 06:00	-0.1	12.5	2,046.5	0.1	1.4	1	1	1
03/15/2020 07:00	0.1	12.5	2,044.5	0.2	1.4	1	1	1
03/15/2020 08:00	0.1	12.6	1,997.9	0.2	1.4	1	1	1
03/15/2020 09:00	0.6	13.9	1,719.8	0.6	1.2	1	1	0
03/15/2020 10:00	0.6	13.9	1,724.4	0.6	1.2	1	1	0
03/15/2020 11:00	0.6	13.9	1,714.7	0.6	1.2	1	1	0
03/15/2020 12:00	0.6	14.0	1,715.4	0.6	1.2	1	1	0
03/15/2020 13:00	0.6	14.0	1,717.8	0.6	1.2	1	1	0
03/15/2020 14:00	0.6	14.0	1,557.9	0.6	1.1	1	1	0
03/15/2020 15:00	0.6	14.0	1,492.1	0.6	1.0	1	1	0
03/15/2020 16:00	0.6	14.0	1,488.3	0.6	1.0	1	1	0
03/15/2020 17:00	0.5	13.5	1,794.4	0.5	1.3	1	1	1
03/15/2020 18:00	-0.1	11.9	2,170.7	0.2	1.5	1	1	1
03/15/2020 19:00	0.1	11.7	2,218.3	0.2	1.6	1	1	1
03/15/2020 20:00	0.1	11.7	2,201.8	0.2	1.5	1	1	1
03/15/2020 21:00	0.1	11.8	2,198.1	0.2	1.5	1	1	1
03/15/2020 22:00	0.1	12.4	2,081.0	0.2	1.5	1	1	1
03/15/2020 23:00	0.1	12.4	2,089.1	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.9	1,922.8	0.3	1.3	24 #	24 #	16 #
Minimum:	-0.1	11.7	1,488.3	0.1	1.0	1	1	0
Maximum:	0.6	14.0	2,218.3	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2020 00:00	-0.1	12.3	2,100.3	0.2	1.5	1	1	1
03/16/2020 01:00	-0.1	12.4	2,086.3	0.2	1.5	1	1	1
03/16/2020 02:00	-0.1	12.3	2,100.7	0.2	1.5	1	1	1
03/16/2020 03:00	-0.1	12.4	2,093.7	0.2	1.5	1	1	1
03/16/2020 04:00	-0.1	12.1	2,159.1	0.2	1.5	1	1	1
03/16/2020 05:00	-0.1	11.9	2,181.7	0.2	1.5	1	1	1
03/16/2020 06:00	0.1	11.7	2,231.6	0.2	1.6	1	1	1
03/16/2020 07:00	0.1	12.3	2,121.9	0.2	1.5	1	1	1
03/16/2020 08:00	0.1	12.3	2,108.2	0.2	1.5	1	1	1
03/16/2020 09:00	0.1	12.3	2,097.4	0.2	1.5	1	1	1
03/16/2020 10:00	0.1	12.3	2,097.8	0.2	1.5	1	1	1
03/16/2020 11:00	0.1	12.2	2,110.7	0.2	1.5	1	1	1
03/16/2020 12:00	0.1	12.3	2,092.9	0.2	1.5	1	1	1
03/16/2020 13:00	0.1	12.4	2,061.4	0.2	1.4	1	1	1
03/16/2020 14:00	0.1	12.4	2,042.2	0.2	1.4	1	1	1
03/16/2020 15:00	0.1	12.6	2,008.7	0.2	1.4	1	1	1
03/16/2020 16:00	0.1	12.6	2,007.2	0.2	1.4	1	1	1
03/16/2020 17:00	0.1	12.6	2,019.2	0.2	1.4	1	1	1
03/16/2020 18:00	0.1	11.8	2,196.5	0.2	1.5	1	1	1
03/16/2020 19:00	0.1	11.7	2,201.6	0.2	1.5	1	1	1
03/16/2020 20:00	0.1	12.0	2,146.1	0.2	1.5	1	1	1
03/16/2020 21:00	-0.1	11.9	2,161.9	0.2	1.5	1	1	1
03/16/2020 22:00	-0.1	12.2	2,094.0	0.2	1.5	1	1	1
03/16/2020 23:00	-0.1	12.2	2,094.6	0.2	1.5	1	1	1
Average/Sum#:	0.0	12.2	2,109.0	0.2	1.5	24 #	24 #	24 #
Minimum:	-0.1	11.7	2,007.2	0.2	1.4	1	1	1
Maximum:	0.1	12.6	2,231.6	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2020 00:00	-0.1	12.3	2,079.2	0.2	1.5	1	1	1
03/17/2020 01:00	-0.1	12.4	2,072.9	0.2	1.5	1	1	1
03/17/2020 02:00	0.1	12.7	2,012.9	0.2	1.4	1	1	1
03/17/2020 03:00	0.1	12.6	2,042.0	0.2	1.4	1	1	1
03/17/2020 04:00	0.1	12.7	2,006.1	0.2	1.4	1	1	1
03/17/2020 05:00	-0.2	12.2	2,092.2	0.1	1.5	1	1	1
03/17/2020 06:00	-0.1	12.1	2,149.1	0.2	1.5	1	1	1
03/17/2020 07:00	0.1	12.8	2,007.9	0.2	1.4	1	1	1
03/17/2020 08:00	0.1	13.2	1,880.6	0.2	1.3	1	1	1
03/17/2020 09:00	0.6	13.9	1,710.7	0.6	1.2	1	1	0
03/17/2020 10:00	0.6	13.9	1,721.0	0.6	1.2	1	1	0
03/17/2020 11:00	0.6	13.9	1,724.1	0.6	1.2	1	1	0
03/17/2020 12:00	0.6	13.9	1,724.9	0.6	1.2	1	1	0
03/17/2020 13:00	0.5	13.9	1,723.7	0.5	1.2	1	1	0
03/17/2020 14:00	0.6	13.9	1,722.0	0.6	1.2	1	1	0
03/17/2020 15:00	0.6	13.9	1,721.6	0.6	1.2	1	1	0
03/17/2020 16:00	0.7	13.9	1,725.8	0.7	1.2	1	1	1
03/17/2020 17:00	-0.1	12.8	1,979.8	0.1	1.4	1	1	1
03/17/2020 18:00	-0.1	12.3	2,081.9	0.2	1.5	1	1	1
03/17/2020 19:00	-0.1	12.2	2,094.9	0.2	1.5	1	1	1
03/17/2020 20:00	0.1	12.5	2,036.4	0.2	1.4	1	1	1
03/17/2020 21:00	-0.1	12.5	2,042.4	0.1	1.4	1	1	1
03/17/2020 22:00	-0.1	12.5	2,043.6	0.1	1.4	1	1	1
03/17/2020 23:00	0.1	12.7	2,004.9	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.0	1,933.4	0.3	1.4	24 #	24 #	17 #
Minimum:	-0.2	12.1	1,710.7	0.1	1.2	1	1	0
Maximum:	0.7	13.9	2,149.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2020 00:00	0.1	12.7	2,002.2	0.2	1.4	1	1	1
03/18/2020 01:00	0.1	12.7	2,002.4	0.2	1.4	1	1	1
03/18/2020 02:00	0.1	12.7	2,003.2	0.2	1.4	1	1	1
03/18/2020 03:00	0.1	12.7	2,007.3	0.2	1.4	1	1	1
03/18/2020 04:00	0.1	12.7	1,998.3	0.2	1.4	1	1	1
03/18/2020 05:00	-0.1	12.5	1,998.7	0.1	1.4	1	1	1
03/18/2020 06:00	-0.1	12.2	2,097.3	0.2	1.5	1	1	1
03/18/2020 07:00	-0.1	12.4	2,064.0	0.2	1.4	1	1	1
03/18/2020 08:00	0.1	12.6	1,998.1	0.2	1.4	1	1	1
03/18/2020 09:00	0.6	13.9	1,621.1	0.6	1.1	1	1	0
03/18/2020 10:00	0.6	13.9	1,599.2	0.6	1.1	1	1	0
03/18/2020 11:00	0.6	13.9	1,585.1	0.6	1.1	1	1	0
03/18/2020 12:00	0.6	13.9	1,608.1	0.6	1.1	1	1	0
03/18/2020 13:00	0.6	13.9	1,586.3	0.6	1.1	1	1	0
03/18/2020 14:00	0.6	13.9	1,620.8	0.6	1.1	1	1	0
03/18/2020 15:00	0.6	13.9	1,598.7	0.6	1.1	1	1	0
03/18/2020 16:00	0.6	13.9	1,652.3	0.6	1.2	1	1	0
03/18/2020 17:00	0.6	13.9	1,533.8	0.6	1.1	1	1	0
03/18/2020 18:00	0.1	12.8	1,954.4	0.2	1.4	1	1	1
03/18/2020 19:00	0.1	12.7	1,983.7	0.2	1.4	1	1	1
03/18/2020 20:00	-0.1	12.5	2,035.7	0.1	1.4	1	1	1
03/18/2020 21:00	-0.1	12.6	2,018.3	0.1	1.4	1	1	1
03/18/2020 22:00	-0.1	12.6	2,020.3	0.1	1.4	1	1	1
03/18/2020 23:00	0.1	12.8	1,977.1	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.1	1,856.9	0.3	1.3	24 #	24 #	15 #
Minimum:	-0.1	12.2	1,533.8	0.1	1.1	1	1	0
Maximum:	0.6	13.9	2,097.3	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2020 00:00	0.1	13.2	1,891.9	0.2	1.3	1	1	1
03/19/2020 01:00	0.1	13.2	1,891.7	0.2	1.3	1	1	1
03/19/2020 02:00	-0.1	13.3	1,899.4	0.1	1.3	1	1	1
03/19/2020 03:00	-0.1	13.1	1,943.5	0.1	1.4	1	1	1
03/19/2020 04:00	-0.2	12.4	2,084.9	0.1	1.5	1	1	1
03/19/2020 05:00	-0.1	13.0	1,951.0	0.1	1.4	1	1	1
03/19/2020 06:00	-0.2	12.5	2,074.9	0.1	1.5	1	1	1
03/19/2020 07:00	-0.1	12.5	2,077.5	0.1	1.5	1	1	1
03/19/2020 08:00	0.1	12.8	1,964.4	0.2	1.4	1	1	1
03/19/2020 09:00	0.6	13.9	1,521.8	0.6	1.1	1	1	0
03/19/2020 10:00	0.6	13.9	1,558.8	0.6	1.1	1	1	0
03/19/2020 11:00	0.6	14.0	1,441.0	0.6	1.0	1	1	0
03/19/2020 12:00	0.6	13.9	1,500.2	0.6	1.1	1	1	0
03/19/2020 13:00	0.6	14.0	1,347.7	0.6	0.9	1	1	0
03/19/2020 14:00	0.6	14.0	1,276.5	0.6	0.9	1	1	0
03/19/2020 15:00	0.6	14.0	1,536.0	0.6	1.1	1	1	0
03/19/2020 16:00	0.7	14.0	1,510.6	0.7	1.1	1	1	1
03/19/2020 17:00	-0.1	12.7	1,985.8	0.1	1.4	1	1	1
03/19/2020 18:00	-0.1	12.4	2,035.6	0.2	1.4	1	1	1
03/19/2020 19:00	-0.1	12.2	2,088.6	0.2	1.5	1	1	1
03/19/2020 20:00	-0.1	12.2	2,091.7	0.2	1.5	1	1	1
03/19/2020 21:00	-0.1	12.3	2,068.3	0.2	1.4	1	1	1
03/19/2020 22:00	-0.1	12.4	2,059.9	0.2	1.4	1	1	1
03/19/2020 23:00	0.1	12.7	2,009.8	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.1	1,825.5	0.3	1.3	24 #	24 #	17 #
Minimum:	-0.2	12.2	1,276.5	0.1	0.9	1	1	0
Maximum:	0.7	14.0	2,091.7	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2020 00:00	0.1	12.8	2,003.8	0.2	1.4	1	1	1
03/20/2020 01:00	0.1	12.8	2,007.0	0.2	1.4	1	1	1
03/20/2020 02:00	0.1	12.8	2,005.1	0.2	1.4	1	1	1
03/20/2020 03:00	0.1	12.8	2,003.8	0.2	1.4	1	1	1
03/20/2020 04:00	0.1	12.8	2,004.6	0.2	1.4	1	1	1
03/20/2020 05:00	0.1	13.1	1,942.3	0.2	1.4	1	1	1
03/20/2020 06:00	-0.1	12.8	2,026.8	0.1	1.4	1	1	1
03/20/2020 07:00	0.1	13.3	1,883.0	0.2	1.3	1	1	1
03/20/2020 08:00	0.6	13.9	1,590.6	0.6	1.1	1	1	0
03/20/2020 09:00	0.6	14.0	1,350.6	0.6	0.9	1	1	0
03/20/2020 10:00	0.6	13.9	1,620.5	0.6	1.1	1	1	0
03/20/2020 11:00	0.6	13.9	1,525.4	0.6	1.1	1	1	0
03/20/2020 12:00	0.6	14.0	1,499.9	0.6	1.0	1	1	0
03/20/2020 13:00	0.6	14.0	1,613.8	0.6	1.1	1	1	0
03/20/2020 14:00	0.6	14.0	1,503.6	0.6	1.1	1	1	0
03/20/2020 15:00	0.7	13.9	1,551.6	0.7	1.1	1	1	1
03/20/2020 16:00	-0.1	12.7	1,980.0	0.1	1.4	1	1	1
03/20/2020 17:00	-0.1	12.5	2,019.0	0.1	1.4	1	1	1
03/20/2020 18:00	-0.1	12.5	2,021.3	0.1	1.4	1	1	1
03/20/2020 19:00	-0.1	12.4	2,030.2	0.2	1.4	1	1	1
03/20/2020 20:00	-0.1	12.4	2,054.4	0.2	1.4	1	1	1
03/20/2020 21:00	-0.1	12.3	2,070.3	0.2	1.4	1	1	1
03/20/2020 22:00	0.1	12.4	2,050.9	0.2	1.4	1	1	1
03/20/2020 23:00	0.1	12.6	2,011.9	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.1	1,848.8	0.3	1.3	24 #	24 #	17 #
Minimum:	-0.1	12.3	1,350.6	0.1	0.9	1	1	0
Maximum:	0.7	14.0	2,070.3	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2020 00:00	-0.1	12.5	2,052.2	0.1	1.4	1	1	1
03/21/2020 01:00	-0.1	12.5	2,073.5	0.1	1.5	1	1	1
03/21/2020 02:00	-0.1	12.4	2,066.3	0.2	1.4	1	1	1
03/21/2020 03:00	-0.1	12.4	2,073.9	0.2	1.5	1	1	1
03/21/2020 04:00	0.1	12.5	2,042.9	0.2	1.4	1	1	1
03/21/2020 05:00	-0.1	12.5	2,034.4	0.1	1.4	1	1	1
03/21/2020 06:00	0.1	12.8	1,971.8	0.2	1.4	1	1	1
03/21/2020 07:00	0.0	14.5	1,168.2	0.0	0.8	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	12.8	1,935.4	0.1	1.4	8 #	7 #	8 #
Minimum:	-0.1	12.4	1,168.2	0.0	0.8	0	0	0
Maximum:	0.1	14.5	2,073.9	0.2	1.5	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/24/2020 02:00	0.0	17.7	451.6	0.0	0.3	1	0	0
03/24/2020 03:00	0.0	15.7	832.3	0.0	0.6	1	0	0
03/24/2020 04:00	0.6	13.8	1,694.2	0.6	1.2	1	1	0
03/24/2020 05:00	0.6	13.9	1,566.4	0.6	1.1	1	1	0
03/24/2020 06:00	0.6	13.9	1,657.2	0.6	1.2	1	1	0
03/24/2020 07:00	0.6	13.9	1,667.4	0.6	1.2	1	1	0
03/24/2020 08:00	0.6	13.9	1,546.4	0.6	1.1	1	1	0
03/24/2020 09:00	0.6	13.9	1,651.1	0.6	1.2	1	1	0
03/24/2020 10:00	0.6	13.9	1,671.1	0.6	1.2	1	1	0
03/24/2020 11:00	0.6	13.9	1,583.5	0.6	1.1	1	1	0
03/24/2020 12:00	0.6	13.9	1,611.7	0.6	1.1	1	1	0
03/24/2020 13:00	0.6	13.9	1,514.7	0.6	1.1	1	1	0
03/24/2020 14:00	0.6	13.9	1,536.0	0.6	1.1	1	1	0
03/24/2020 15:00	0.6	14.0	1,551.9	0.6	1.1	1	1	0
03/24/2020 16:00	0.7	14.0	1,568.9	0.7	1.1	1	1	1
03/24/2020 17:00	-0.1	12.7	1,992.1	0.1	1.4	1	1	1
03/24/2020 18:00	0.1	12.8	1,959.9	0.2	1.4	1	1	1
03/24/2020 19:00	0.1	12.8	1,983.3	0.2	1.4	1	1	1
03/24/2020 20:00	-0.1	12.3	2,086.5	0.2	1.5	1	1	1
03/24/2020 21:00	0.1	12.6	2,017.5	0.2	1.4	1	1	1
03/24/2020 22:00	-0.1	12.7	2,027.9	0.1	1.4	1	1	1
03/24/2020 23:00	0.0	14.4	1,214.5	0.0	0.9	1	0	1
Average/Sum#:	0.4	13.8	1,608.5	0.4	1.1	22 #	19 #	8 #
Minimum:	-0.1	12.3	451.6	0.0	0.3	0	0	0
Maximum:	0.7	17.7	2,086.5	0.7	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 23:00	0.0	17.5	469.6	0.0	0.3	1	0	0
Average/Sum#:	0.0	17.5	469.6	0.0	0.3	1 #	0 #	0 #
Minimum:	0.0	17.5	469.6	0.0	0.3	0	0	0
Maximum:	0.0	17.5	469.6	0.0	0.3	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2020 00:00	0.0	15.1	1,005.4	0.0	0.7	1	0	0
03/28/2020 01:00	0.6	13.9	1,654.1	0.6	1.2	1	1	0
03/28/2020 02:00	0.6	13.9	1,663.3	0.6	1.2	1	1	0
03/28/2020 03:00	0.6	13.9	1,665.2	0.6	1.2	1	1	0
03/28/2020 04:00	0.6	13.9	1,645.2	0.6	1.2	1	1	0
03/28/2020 05:00	0.6	13.9	1,647.5	0.6	1.2	1	1	0
03/28/2020 06:00	0.6	13.9	1,526.6	0.6	1.1	1	1	0
03/28/2020 07:00	0.6	13.9	1,495.6	0.6	1.0	1	1	0
03/28/2020 08:00	0.6	13.9	1,607.9	0.6	1.1	1	1	0
03/28/2020 09:00	0.6	13.9	1,631.6	0.6	1.1	1	1	0
03/28/2020 10:00	0.6	13.9	1,653.8	0.6	1.2	1	1	0
03/28/2020 11:00	0.6	13.9	1,661.3	0.6	1.2	1	1	0
03/28/2020 12:00	0.6	13.9	1,651.0	0.6	1.2	1	1	0
03/28/2020 13:00	0.6	13.9	1,652.2	0.6	1.2	1	1	0
03/28/2020 14:00	0.6	13.9	1,631.6	0.6	1.1	1	1	0
03/28/2020 15:00	0.6	13.9	1,632.4	0.6	1.1	1	1	0
03/28/2020 16:00	0.6	13.9	1,661.3	0.6	1.2	1	1	0
03/28/2020 17:00	0.5	13.4	1,797.9	0.5	1.3	1	1	1
03/28/2020 18:00	0.2	12.2	2,079.6	0.4	1.5	1	1	1
03/28/2020 19:00	0.2	12.4	2,047.3	0.4	1.4	1	1	1
03/28/2020 20:00	0.4	12.2	2,089.1	0.5	1.5	1	1	1
03/28/2020 21:00	0.2	12.5	2,034.5	0.4	1.4	1	1	1
03/28/2020 22:00	0.2	12.5	2,026.8	0.4	1.4	1	1	1
03/28/2020 23:00	0.4	12.9	1,933.9	0.5	1.4	1	1	1
Average/Sum#:	0.5	13.6	1,712.3	0.5	1.2	24 #	23 #	7 #
Minimum:	0.0	12.2	1,005.4	0.0	0.7	1	0	0
Maximum:	0.6	15.1	2,089.1	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.6	13.9	1,613.0	0.6	1.1	1	1	0
03/29/2020 01:00	0.6	13.9	1,574.2	0.6	1.1	1	1	0
03/29/2020 02:00	0.6	13.9	1,580.4	0.6	1.1	1	1	0
03/29/2020 03:00	0.6	13.9	1,531.6	0.6	1.1	1	1	0
03/29/2020 04:00	0.6	13.9	1,659.1	0.6	1.2	1	1	0
03/29/2020 05:00	0.6	13.9	1,580.5	0.6	1.1	1	1	0
03/29/2020 06:00	0.6	13.9	1,562.2	0.6	1.1	1	1	0
03/29/2020 07:00	0.6	13.9	1,584.7	0.6	1.1	1	1	0
03/29/2020 08:00	0.6	13.9	1,568.1	0.6	1.1	1	1	0
03/29/2020 09:00	0.6	13.9	1,638.2	0.6	1.1	1	1	0
03/29/2020 10:00	0.6	13.9	1,662.6	0.6	1.2	1	1	0
03/29/2020 11:00	0.6	13.9	1,644.1	0.6	1.2	1	1	0
03/29/2020 12:00	0.6	13.9	1,537.1	0.6	1.1	1	1	0
03/29/2020 13:00	0.6	13.9	1,578.6	0.6	1.1	1	1	0
03/29/2020 14:00	0.6	13.9	1,568.1	0.6	1.1	1	1	0
03/29/2020 15:00	0.6	14.0	1,565.1	0.6	1.1	1	1	0
03/29/2020 16:00	0.6	13.9	1,619.2	0.6	1.1	1	1	0
03/29/2020 17:00	0.7	13.9	1,532.7	0.7	1.1	1	1	1
03/29/2020 18:00	0.1	12.6	2,010.5	0.2	1.4	1	1	1
03/29/2020 19:00	0.4	12.1	2,091.9	0.5	1.5	1	1	1
03/29/2020 20:00	0.4	12.2	2,068.0	0.5	1.4	1	1	1
03/29/2020 21:00	0.4	12.3	2,060.4	0.5	1.4	1	1	1
03/29/2020 22:00	0.4	13.0	1,913.3	0.5	1.3	1	1	1
03/29/2020 23:00	0.4	12.9	1,927.1	0.5	1.3	1	1	1
Average/Sum#:	0.5	13.6	1,694.6	0.6	1.2	24 #	24 #	7 #
Minimum:	0.1	12.1	1,531.6	0.2	1.1	1	1	0
Maximum:	0.7	14.0	2,091.9	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2020 00:00	0.6	13.9	1,653.5	0.6	1.2	1	1	0
03/30/2020 01:00	0.6	13.9	1,654.5	0.6	1.2	1	1	0
03/30/2020 02:00	0.6	13.9	1,643.8	0.6	1.2	1	1	0
03/30/2020 03:00	0.6	13.9	1,614.2	0.6	1.1	1	1	0
03/30/2020 04:00	0.6	13.9	1,590.6	0.6	1.1	1	1	0
03/30/2020 05:00	0.6	13.9	1,641.7	0.6	1.1	1	1	0
03/30/2020 06:00	0.6	13.9	1,654.8	0.6	1.2	1	1	0
03/30/2020 07:00	0.6	13.9	1,632.0	0.6	1.1	1	1	0
03/30/2020 08:00	0.6	13.9	1,608.7	0.6	1.1	1	1	0
03/30/2020 09:00	0.6	13.9	1,628.0	0.6	1.1	1	1	0
03/30/2020 10:00	0.6	13.9	1,630.2	0.6	1.1	1	1	0
03/30/2020 11:00	0.6	13.9	1,607.6	0.6	1.1	1	1	0
03/30/2020 12:00	0.6	13.9	1,576.3	0.6	1.1	1	1	0
03/30/2020 13:00	0.6	13.9	1,565.2	0.6	1.1	1	1	0
03/30/2020 14:00	0.6	13.9	1,619.3	0.6	1.1	1	1	0
03/30/2020 15:00	0.6	13.9	1,582.7	0.6	1.1	1	1	0
03/30/2020 16:00	0.6	13.9	1,630.2	0.6	1.1	1	1	0
03/30/2020 17:00	0.7	13.9	1,623.8	0.7	1.1	1	1	1
03/30/2020 18:00	-0.1	12.7	1,980.9	0.1	1.4	1	1	1
03/30/2020 19:00	-0.1	12.4	2,035.9	0.2	1.4	1	1	1
03/30/2020 20:00	-0.1	12.0	2,109.7	0.2	1.5	1	1	1
03/30/2020 21:00	0.1	12.0	2,111.8	0.2	1.5	1	1	1
03/30/2020 22:00	0.1	12.2	2,089.0	0.2	1.5	1	1	1
03/30/2020 23:00	0.1	12.6	2,001.1	0.2	1.4	1	1	1
Average/Sum#:	0.5	13.5	1,728.6	0.5	1.2	24 #	24 #	7 #
Minimum:	-0.1	12.0	1,565.2	0.1	1.1	1	1	0
Maximum:	0.7	13.9	2,111.8	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:44 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/31/2020 00:00	0.1	12.5	2,015.0	0.2	1.4	1	1	1
03/31/2020 01:00	0.1	12.5	2,017.2	0.2	1.4	1	1	1
03/31/2020 02:00	0.1	12.6	2,015.0	0.2	1.4	1	1	1
03/31/2020 03:00	0.1	12.6	2,012.6	0.2	1.4	1	1	1
03/31/2020 04:00	0.1	12.7	1,995.7	0.2	1.4	1	1	1
03/31/2020 05:00	0.1	13.1	1,907.7	0.2	1.3	1	1	1
03/31/2020 06:00	-0.1	12.6	2,013.5	0.1	1.4	1	1	1
03/31/2020 07:00	0.0	14.2	1,224.0	0.0	0.9	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	12.9	1,900.1	0.2	1.3	8 #	7 #	8 #
Minimum:	-0.1	12.5	1,224.0	0.0	0.9	0	0	0
Maximum:	0.1	14.2	2,017.2	0.2	1.4	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2020 00:00	0.7	12.6	2,035.3	0.7	0.6	1	1	1
01/01/2020 01:00	0.7	12.6	2,026.0	0.7	0.6	1	1	1
01/01/2020 02:00	0.0	14.4	1,144.9	0.0	0.3	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	13.2	1,735.4	0.5	0.5	3 #	2 #	3 #
Minimum:	0.0	12.6	1,144.9	0.0	0.3	0	0	0
Maximum:	0.7	14.4	2,035.3	0.7	0.6	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 01:00	0.0	17.4	462.5	0.0	0.1	1	0	0
01/02/2020 02:00	0.0	15.6	700.4	0.0	0.2	1	0	0
01/02/2020 03:00	0.0	14.8	966.5	0.0	0.3	1	0	0
01/02/2020 04:00	0.6	13.6	1,542.2	0.6	0.5	1	1	0
01/02/2020 05:00	0.7	13.1	1,864.2	0.7	0.6	1	1	1
01/02/2020 06:00	0.7	12.1	2,117.0	0.7	0.6	1	1	1
01/02/2020 07:00	0.6	13.6	1,755.7	0.6	0.5	1	1	0
01/02/2020 08:00	0.6	13.6	1,537.2	0.6	0.5	1	1	0
01/02/2020 09:00	0.6	13.6	1,524.6	0.6	0.5	1	1	0
01/02/2020 10:00	0.6	13.6	1,660.3	0.6	0.5	1	1	0
01/02/2020 11:00	0.6	13.7	1,680.4	0.6	0.5	1	1	0
01/02/2020 12:00	0.6	13.7	1,626.2	0.6	0.5	1	1	0
01/02/2020 13:00	0.6	13.7	1,646.2	0.6	0.5	1	1	0
01/02/2020 14:00	0.6	13.7	1,633.3	0.6	0.5	1	1	0
01/02/2020 15:00	0.7	13.6	1,594.6	0.7	0.5	1	1	1
01/02/2020 16:00	0.7	12.5	2,015.8	0.7	0.6	1	1	1
01/02/2020 17:00	0.7	12.4	2,045.9	0.7	0.6	1	1	1
01/02/2020 18:00	0.7	12.3	2,077.0	0.7	0.6	1	1	1
01/02/2020 19:00	0.7	12.3	2,082.2	0.7	0.6	1	1	1
01/02/2020 20:00	0.7	12.3	2,082.4	0.7	0.6	1	1	1
01/02/2020 21:00	0.7	12.2	2,092.7	0.7	0.6	1	1	1
01/02/2020 22:00	0.7	12.2	2,080.3	0.7	0.6	1	1	1
01/02/2020 23:00	0.7	12.5	2,048.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.4	1,688.5	0.6	0.5	23 #	20 #	11 #
Minimum:	0.0	12.1	462.5	0.0	0.1	0	0	0
Maximum:	0.7	17.4	2,117.0	0.7	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/03/2020 00:00	0.7	12.6	2,035.4	0.7	0.6	1	1	1
01/03/2020 01:00	0.7	12.5	2,028.9	0.7	0.6	1	1	1
01/03/2020 02:00	0.7	12.7	2,024.1	0.7	0.6	1	1	1
01/03/2020 03:00	0.7	12.6	2,037.3	0.7	0.6	1	1	1
01/03/2020 04:00	0.7	12.6	2,037.7	0.7	0.6	1	1	1
01/03/2020 05:00	0.7	12.6	2,030.5	0.7	0.6	1	1	1
01/03/2020 06:00	0.7	12.7	2,017.3	0.7	0.6	1	1	1
01/03/2020 07:00	0.7	12.7	2,027.9	0.7	0.6	1	1	1
01/03/2020 08:00	0.7	13.1	1,904.9	0.7	0.6	1	1	1
01/03/2020 09:00	0.6	13.7	1,532.8	0.6	0.5	1	1	0
01/03/2020 10:00	0.6	13.6	1,557.2	0.6	0.5	1	1	0
01/03/2020 11:00	0.6	13.6	1,606.4	0.6	0.5	1	1	0
01/03/2020 12:00	0.6	13.6	1,690.7	0.6	0.5	1	1	0
01/03/2020 13:00	0.6	13.6	1,668.8	0.6	0.5	1	1	0
01/03/2020 14:00	0.6	13.7	1,545.8	0.6	0.5	1	1	0
01/03/2020 15:00	0.6	13.7	1,581.2	0.6	0.5	1	1	0
01/03/2020 16:00	0.7	12.8	1,952.8	0.7	0.6	1	1	1
01/03/2020 17:00	0.7	12.5	2,034.8	0.7	0.6	1	1	1
01/03/2020 18:00	0.7	12.5	2,056.3	0.7	0.6	1	1	1
01/03/2020 19:00	0.7	12.5	2,041.2	0.7	0.6	1	1	1
01/03/2020 20:00	0.7	12.5	2,053.0	0.7	0.6	1	1	1
01/03/2020 21:00	0.7	12.3	2,095.6	0.7	0.6	1	1	1
01/03/2020 22:00	0.7	12.4	2,098.3	0.7	0.6	1	1	1
01/03/2020 23:00	0.0	13.1	1,674.2	0.0	0.5	1	0	1
Average/Sum#:	0.6	12.9	1,888.9	0.6	0.6	24 #	23 #	17 #
Minimum:	0.0	12.3	1,532.8	0.0	0.5	1	0	0
Maximum:	0.7	13.7	2,098.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/04/2020 00:00	0.0	19.1	0.2	0.0	0.0	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	19.1	0.2	0.0	0.0	1 #	0 #	0 #
Minimum:	0.0	19.1	0.2	0.0	0.0	0	0	0
Maximum:	0.0	19.1	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 04:00	0.0	17.6	443.8	0.0	0.1	1	0	0
01/06/2020 05:00	0.0	16.5	601.7	0.0	0.2	1	0	0
01/06/2020 06:00	0.0	15.2	842.6	0.0	0.3	1	0	0
01/06/2020 07:00	0.6	13.7	1,588.4	0.6	0.5	1	1	0
01/06/2020 08:00	0.6	13.6	1,755.9	0.6	0.5	1	1	0
01/06/2020 09:00	0.6	13.6	1,667.1	0.6	0.5	1	1	0
01/06/2020 10:00	0.6	13.7	1,555.8	0.6	0.5	1	1	0
01/06/2020 11:00	0.6	13.7	1,654.8	0.6	0.5	1	1	0
01/06/2020 12:00	0.6	13.7	1,583.5	0.6	0.5	1	1	0
01/06/2020 13:00	0.6	13.7	1,638.7	0.6	0.5	1	1	0
01/06/2020 14:00	0.6	13.7	1,567.1	0.6	0.5	1	1	0
01/06/2020 15:00	0.7	13.6	1,552.6	0.7	0.5	1	1	1
01/06/2020 16:00	0.7	12.7	2,014.8	0.7	0.6	1	1	1
01/06/2020 17:00	0.7	12.5	2,053.4	0.7	0.6	1	1	1
01/06/2020 18:00	0.7	12.6	2,049.6	0.7	0.6	1	1	1
01/06/2020 19:00	0.7	12.6	2,036.0	0.7	0.6	1	1	1
01/06/2020 20:00	0.7	12.7	2,031.6	0.7	0.6	1	1	1
01/06/2020 21:00	0.7	12.7	2,034.9	0.7	0.6	1	1	1
01/06/2020 22:00	0.7	12.6	2,052.9	0.7	0.6	1	1	1
01/06/2020 23:00	0.7	12.8	2,017.5	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.7	1,637.1	0.6	0.5	20 #	17 #	9 #
Minimum:	0.0	12.5	443.8	0.0	0.1	0	0	0
Maximum:	0.7	17.6	2,053.4	0.7	0.6	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/07/2020 00:00	0.7	12.7	2,036.3	0.7	0.6	1	1	1
01/07/2020 01:00	0.7	12.8	2,016.4	0.7	0.6	1	1	1
01/07/2020 02:00	0.7	12.8	2,008.2	0.7	0.6	1	1	1
01/07/2020 03:00	0.7	12.8	2,009.9	0.7	0.6	1	1	1
01/07/2020 04:00	0.7	12.8	2,025.5	0.7	0.6	1	1	1
01/07/2020 05:00	0.7	12.8	2,028.6	0.7	0.6	1	1	1
01/07/2020 06:00	0.7	12.7	2,031.0	0.7	0.6	1	1	1
01/07/2020 07:00	0.7	12.6	2,070.4	0.7	0.6	1	1	1
01/07/2020 08:00	0.7	13.1	1,960.5	0.7	0.6	1	1	1
01/07/2020 09:00	0.6	13.6	1,723.4	0.6	0.5	1	1	0
01/07/2020 10:00	0.6	13.6	1,625.3	0.6	0.5	1	1	0
01/07/2020 11:00	0.6	13.6	1,614.8	0.6	0.5	1	1	0
01/07/2020 12:00	0.6	13.6	1,677.6	0.6	0.5	1	1	0
01/07/2020 13:00	0.6	13.6	1,645.7	0.6	0.5	1	1	0
01/07/2020 14:00	0.6	13.6	1,593.5	0.6	0.5	1	1	0
01/07/2020 15:00	0.7	13.6	1,573.8	0.7	0.5	1	1	1
01/07/2020 16:00	0.7	12.7	2,015.1	0.7	0.6	1	1	1
01/07/2020 17:00	0.7	12.6	2,038.8	0.7	0.6	1	1	1
01/07/2020 18:00	0.7	12.6	2,036.1	0.7	0.6	1	1	1
01/07/2020 19:00	0.7	12.7	2,025.4	0.7	0.6	1	1	1
01/07/2020 20:00	0.7	12.6	2,056.1	0.7	0.6	1	1	1
01/07/2020 21:00	0.7	12.5	2,064.1	0.7	0.6	1	1	1
01/07/2020 22:00	0.0	14.1	1,265.4	0.0	0.4	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.0	1,875.7	0.6	0.6	23 #	22 #	17 #
Minimum:	0.0	12.5	1,265.4	0.0	0.4	0	0	0
Maximum:	0.7	14.1	2,070.4	0.7	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 21:00	0.0	17.4	466.5	0.0	0.1	1	0	0
01/08/2020 22:00	0.0	16.9	529.7	0.0	0.2	1	0	0
01/08/2020 23:00	0.0	15.4	867.5	0.0	0.3	1	0	0
Average/Sum#:	0.0	16.6	621.2	0.0	0.2	3 #	0 #	0 #
Minimum:	0.0	15.4	466.5	0.0	0.1	0	0	0
Maximum:	0.0	17.4	867.5	0.0	0.3	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/09/2020 00:00	0.6	13.6	1,483.0	0.6	0.4	1	1	0
01/09/2020 01:00	0.6	13.7	1,373.4	0.6	0.4	1	1	0
01/09/2020 02:00	0.6	13.6	1,675.7	0.6	0.5	1	1	0
01/09/2020 03:00	0.6	13.6	1,512.9	0.6	0.5	1	1	0
01/09/2020 04:00	0.6	13.6	1,694.8	0.6	0.5	1	1	0
01/09/2020 05:00	0.6	13.6	1,634.8	0.6	0.5	1	1	0
01/09/2020 06:00	0.6	13.6	1,397.1	0.6	0.4	1	1	0
01/09/2020 07:00	0.6	13.6	1,491.7	0.6	0.4	1	1	0
01/09/2020 08:00	0.6	13.6	1,629.8	0.6	0.5	1	1	0
01/09/2020 09:00	0.6	13.6	1,707.6	0.6	0.5	1	1	0
01/09/2020 10:00	0.6	13.6	1,578.3	0.6	0.5	1	1	0
01/09/2020 11:00	0.6	13.6	1,674.2	0.6	0.5	1	1	0
01/09/2020 12:00	0.6	13.6	1,645.8	0.6	0.5	1	1	0
01/09/2020 13:00	0.6	13.6	1,690.6	0.6	0.5	1	1	0
01/09/2020 14:00	0.6	13.6	1,614.5	0.6	0.5	1	1	0
01/09/2020 15:00	0.6	13.6	1,567.8	0.6	0.5	1	1	0
01/09/2020 16:00	0.7	12.6	2,007.7	0.7	0.6	1	1	1
01/09/2020 17:00	0.7	12.4	2,076.0	0.7	0.6	1	1	1
01/09/2020 18:00	0.7	12.3	2,116.7	0.7	0.6	1	1	1
01/09/2020 19:00	0.7	12.2	2,110.6	0.7	0.6	1	1	1
01/09/2020 20:00	0.7	12.2	2,113.0	0.7	0.6	1	1	1
01/09/2020 21:00	0.7	12.3	2,094.0	0.7	0.6	1	1	1
01/09/2020 22:00	0.7	12.3	2,103.8	0.7	0.6	1	1	1
01/09/2020 23:00	0.7	12.3	2,100.4	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,753.9	0.6	0.5	24 #	24 #	8 #
Minimum:	0.6	12.2	1,373.4	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,116.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2020 00:00	0.7	12.5	2,060.6	0.7	0.6	1	1	1
01/10/2020 01:00	0.7	12.6	2,043.4	0.7	0.6	1	1	1
01/10/2020 02:00	0.7	12.4	2,094.0	0.7	0.6	1	1	1
01/10/2020 03:00	0.7	12.4	2,097.6	0.7	0.6	1	1	1
01/10/2020 04:00	0.7	12.6	2,032.0	0.7	0.6	1	1	1
01/10/2020 05:00	0.7	12.6	2,049.4	0.7	0.6	1	1	1
01/10/2020 06:00	0.7	12.3	2,118.6	0.7	0.6	1	1	1
01/10/2020 07:00	0.7	12.2	2,158.0	0.7	0.6	1	1	1
01/10/2020 08:00	0.7	12.6	2,069.5	0.7	0.6	1	1	1
01/10/2020 09:00	0.7	13.0	1,935.5	0.7	0.6	1	1	1
01/10/2020 10:00	0.6	13.6	1,703.7	0.6	0.5	1	1	0
01/10/2020 11:00	0.6	13.6	1,668.0	0.6	0.5	1	1	0
01/10/2020 12:00	0.6	13.6	1,639.3	0.6	0.5	1	1	0
01/10/2020 13:00	0.6	13.6	1,680.8	0.6	0.5	1	1	0
01/10/2020 14:00	0.6	13.6	1,544.2	0.6	0.5	1	1	0
01/10/2020 15:00	0.7	13.6	1,552.5	0.7	0.5	1	1	1
01/10/2020 16:00	0.7	12.7	2,036.5	0.7	0.6	1	1	1
01/10/2020 17:00	0.7	12.4	2,082.9	0.7	0.6	1	1	1
01/10/2020 18:00	0.7	12.3	2,108.5	0.7	0.6	1	1	1
01/10/2020 19:00	0.7	12.4	2,088.6	0.7	0.6	1	1	1
01/10/2020 20:00	0.7	12.5	2,079.1	0.7	0.6	1	1	1
01/10/2020 21:00	0.7	12.5	2,066.4	0.7	0.6	1	1	1
01/10/2020 22:00	0.7	12.6	2,037.4	0.7	0.6	1	1	1
01/10/2020 23:00	0.7	12.7	2,023.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,957.1	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.2	1,544.2	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,158.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/11/2020 00:00	0.7	12.7	2,028.9	0.7	0.6	1	1	1
01/11/2020 01:00	0.7	12.7	2,023.8	0.7	0.6	1	1	1
01/11/2020 02:00	0.7	12.7	2,028.4	0.7	0.6	1	1	1
01/11/2020 03:00	0.7	12.7	2,027.7	0.7	0.6	1	1	1
01/11/2020 04:00	0.7	12.7	2,034.1	0.7	0.6	1	1	1
01/11/2020 05:00	0.7	12.7	2,026.6	0.7	0.6	1	1	1
01/11/2020 06:00	0.7	12.7	2,030.0	0.7	0.6	1	1	1
01/11/2020 07:00	0.7	12.7	2,032.9	0.7	0.6	1	1	1
01/11/2020 08:00	0.0	14.0	1,305.5	0.0	0.4	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	12.8	1,948.7	0.6	0.6	9 #	8 #	9 #
Minimum:	0.0	12.7	1,305.5	0.0	0.4	0	0	0
Maximum:	0.7	14.0	2,034.1	0.7	0.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 23:00	0.0	17.6	441.6	0.0	0.1	1	0	0
Average/Sum#:	0.0	17.6	441.6	0.0	0.1	1 #	0 #	0 #
Minimum:	0.0	17.6	441.6	0.0	0.1	0	0	0
Maximum:	0.0	17.6	441.6	0.0	0.1	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/13/2020 00:00	0.0	16.0	661.7	0.0	0.2	1	0	0
01/13/2020 01:00	0.0	14.8	987.5	0.0	0.3	1	0	0
01/13/2020 02:00	0.6	13.6	1,448.4	0.6	0.4	1	1	0
01/13/2020 03:00	0.6	13.6	1,451.3	0.6	0.4	1	1	0
01/13/2020 04:00	0.6	13.6	1,670.8	0.6	0.5	1	1	0
01/13/2020 05:00	0.6	13.6	1,668.2	0.6	0.5	1	1	0
01/13/2020 06:00	0.6	13.6	1,646.5	0.6	0.5	1	1	0
01/13/2020 07:00	0.6	13.6	1,631.2	0.6	0.5	1	1	0
01/13/2020 08:00	0.6	13.6	1,555.4	0.6	0.5	1	1	0
01/13/2020 09:00	0.6	13.6	1,679.3	0.6	0.5	1	1	0
01/13/2020 10:00	0.6	13.6	1,602.4	0.6	0.5	1	1	0
01/13/2020 11:00	0.6	13.6	1,526.5	0.6	0.5	1	1	0
01/13/2020 12:00	0.6	13.6	1,619.3	0.6	0.5	1	1	0
01/13/2020 13:00	0.6	13.6	1,695.9	0.6	0.5	1	1	0
01/13/2020 14:00	0.6	13.6	1,584.8	0.6	0.5	1	1	0
01/13/2020 15:00	0.7	13.6	1,558.6	0.7	0.5	1	1	1
01/13/2020 16:00	0.7	12.6	2,023.2	0.7	0.6	1	1	1
01/13/2020 17:00	0.7	12.1	2,141.0	0.7	0.6	1	1	1
01/13/2020 18:00	0.7	12.0	2,154.5	0.7	0.6	1	1	1
01/13/2020 19:00	0.7	12.0	2,143.7	0.7	0.6	1	1	1
01/13/2020 20:00	0.7	12.1	2,133.0	0.7	0.6	1	1	1
01/13/2020 21:00	0.7	12.3	2,088.1	0.7	0.6	1	1	1
01/13/2020 22:00	0.7	12.4	2,057.2	0.7	0.6	1	1	1
01/13/2020 23:00	0.7	12.5	2,041.9	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.3	1,698.8	0.6	0.5	24 #	22 #	9 #
Minimum:	0.0	12.0	661.7	0.0	0.2	1	0	0
Maximum:	0.7	16.0	2,154.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/14/2020 00:00	0.7	12.5	2,051.1	0.7	0.6	1	1	1
01/14/2020 01:00	0.7	12.5	2,039.4	0.7	0.6	1	1	1
01/14/2020 02:00	0.7	12.5	2,041.0	0.7	0.6	1	1	1
01/14/2020 03:00	0.7	12.5	2,038.9	0.7	0.6	1	1	1
01/14/2020 04:00	0.7	12.6	2,040.0	0.7	0.6	1	1	1
01/14/2020 05:00	0.7	12.5	2,066.2	0.7	0.6	1	1	1
01/14/2020 06:00	0.7	12.3	2,101.0	0.7	0.6	1	1	1
01/14/2020 07:00	0.7	12.1	2,160.1	0.7	0.6	1	1	1
01/14/2020 08:00	0.7	12.6	2,045.8	0.7	0.6	1	1	1
01/14/2020 09:00	0.7	12.7	1,989.4	0.7	0.6	1	1	1
01/14/2020 10:00	0.6	0.0	1,683.1	0.6	0.5	1	1	0
01/14/2020 11:00	0.6	13.6	1,700.2	0.6	0.5	1	1	0
01/14/2020 12:00	0.6	13.6	1,666.5	0.6	0.5	1	1	0
01/14/2020 13:00	0.6	0.0	1,688.7	0.6	0.5	1	1	0
01/14/2020 14:00	0.6	0.0	1,630.2	0.6	0.5	1	1	0
01/14/2020 15:00	0.6	13.6	1,542.0	0.6	0.5	1	1	0
01/14/2020 16:00	0.7	13.6	1,559.5	0.7	0.5	1	1	1
01/14/2020 17:00	0.7	12.7	2,008.7	0.7	0.6	1	1	1
01/14/2020 18:00	0.7	12.6	2,045.2	0.7	0.6	1	1	1
01/14/2020 19:00	0.7	12.6	2,051.3	0.7	0.6	1	1	1
01/14/2020 20:00	0.7	12.4	2,087.9	0.7	0.6	1	1	1
01/14/2020 21:00	0.7	12.5	2,074.8	0.7	0.6	1	1	1
01/14/2020 22:00	0.7	12.6	2,045.6	0.7	0.6	1	1	1
01/14/2020 23:00	0.7	12.9	1,998.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	1,931.4	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.1	1,542.0	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,160.1	0.7	0.6	1	1	1
%SI	12.50	12.50	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/15/2020 00:00	0.7	12.7	2,039.3	0.7	0.6	1	1	1
01/15/2020 01:00	0.7	12.7	2,043.2	0.7	0.6	1	1	1
01/15/2020 02:00	0.7	12.7	2,042.0	0.7	0.6	1	1	1
01/15/2020 03:00	0.7	12.7	2,045.1	0.7	0.6	1	1	1
01/15/2020 04:00	0.7	12.7	2,043.0	0.7	0.6	1	1	1
01/15/2020 05:00	0.7	12.6	2,070.1	0.7	0.6	1	1	1
01/15/2020 06:00	0.7	12.1	2,164.6	0.7	0.6	1	1	1
01/15/2020 07:00	0.7	11.9	2,252.3	0.7	0.7	1	1	1
01/15/2020 08:00	0.7	12.6	2,048.1	0.7	0.6	1	1	1
01/15/2020 09:00	0.6	13.6	1,620.5	0.6	0.5	1	1	0
01/15/2020 10:00	0.6	13.6	1,658.9	0.6	0.5	1	1	0
01/15/2020 11:00	0.6	13.6	1,676.0	0.6	0.5	1	1	0
01/15/2020 12:00	0.6	13.6	1,635.8	0.6	0.5	1	1	0
01/15/2020 13:00	0.6	13.6	1,681.8	0.6	0.5	1	1	0
01/15/2020 14:00	0.6	13.6	1,696.5	0.6	0.5	1	1	0
01/15/2020 15:00	0.7	13.6	1,600.5	0.7	0.5	1	1	1
01/15/2020 16:00	0.7	12.5	2,069.1	0.7	0.6	1	1	1
01/15/2020 17:00	0.7	12.0	2,163.9	0.7	0.6	1	1	1
01/15/2020 18:00	0.7	12.1	2,140.1	0.7	0.6	1	1	1
01/15/2020 19:00	0.7	11.9	2,194.1	0.7	0.7	1	1	1
01/15/2020 20:00	0.7	11.9	2,188.0	0.7	0.7	1	1	1
01/15/2020 21:00	0.7	12.0	2,172.6	0.7	0.7	1	1	1
01/15/2020 22:00	0.7	12.3	2,093.7	0.7	0.6	1	1	1
01/15/2020 23:00	0.7	12.5	2,055.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	1,974.8	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,600.5	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,252.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/16/2020 00:00	0.7	12.5	2,039.7	0.7	0.6	1	1	1
01/16/2020 01:00	0.7	12.5	2,046.8	0.7	0.6	1	1	1
01/16/2020 02:00	0.7	12.5	2,051.3	0.7	0.6	1	1	1
01/16/2020 03:00	0.7	12.5	2,054.4	0.7	0.6	1	1	1
01/16/2020 04:00	0.7	12.5	2,058.2	0.7	0.6	1	1	1
01/16/2020 05:00	0.7	12.5	2,056.4	0.7	0.6	1	1	1
01/16/2020 06:00	0.7	12.3	2,095.9	0.7	0.6	1	1	1
01/16/2020 07:00	0.7	11.9	2,179.2	0.7	0.7	1	1	1
01/16/2020 08:00	0.7	12.4	2,073.8	0.7	0.6	1	1	1
01/16/2020 09:00	0.7	12.7	1,978.0	0.7	0.6	1	1	1
01/16/2020 10:00	0.6	13.6	1,670.4	0.6	0.5	1	1	0
01/16/2020 11:00	0.6	13.6	1,582.6	0.6	0.5	1	1	0
01/16/2020 12:00	0.6	13.6	1,529.2	0.6	0.5	1	1	0
01/16/2020 13:00	0.6	13.6	1,663.4	0.6	0.5	1	1	0
01/16/2020 14:00	0.6	13.6	1,602.9	0.6	0.5	1	1	0
01/16/2020 15:00	0.7	13.6	1,736.8	0.7	0.5	1	1	1
01/16/2020 16:00	0.7	12.6	2,021.4	0.7	0.6	1	1	1
01/16/2020 17:00	0.7	12.5	2,045.6	0.7	0.6	1	1	1
01/16/2020 18:00	0.7	12.5	2,039.3	0.7	0.6	1	1	1
01/16/2020 19:00	0.7	12.5	2,049.6	0.7	0.6	1	1	1
01/16/2020 20:00	0.7	12.4	2,086.3	0.7	0.6	1	1	1
01/16/2020 21:00	0.7	12.4	2,091.1	0.7	0.6	1	1	1
01/16/2020 22:00	0.7	12.7	2,030.5	0.7	0.6	1	1	1
01/16/2020 23:00	0.7	12.7	2,037.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,950.9	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	11.9	1,529.2	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,179.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/17/2020 00:00	0.7	12.7	2,045.2	0.7	0.6	1	1	1
01/17/2020 01:00	0.7	12.8	2,021.3	0.7	0.6	1	1	1
01/17/2020 02:00	0.7	12.7	2,042.7	0.7	0.6	1	1	1
01/17/2020 03:00	0.7	12.8	2,041.2	0.7	0.6	1	1	1
01/17/2020 04:00	0.7	12.7	2,050.0	0.7	0.6	1	1	1
01/17/2020 05:00	0.7	12.7	2,064.2	0.7	0.6	1	1	1
01/17/2020 06:00	0.7	12.0	2,193.2	0.7	0.7	1	1	1
01/17/2020 07:00	0.7	11.9	2,248.6	0.7	0.7	1	1	1
01/17/2020 08:00	0.7	12.7	2,057.1	0.7	0.6	1	1	1
01/17/2020 09:00	0.7	12.9	1,983.8	0.7	0.6	1	1	1
01/17/2020 10:00	0.6	13.6	1,692.8	0.6	0.5	1	1	0
01/17/2020 11:00	0.6	13.6	1,637.7	0.6	0.5	1	1	0
01/17/2020 12:00	0.6	13.6	1,669.2	0.6	0.5	1	1	0
01/17/2020 13:00	0.6	13.6	1,656.5	0.6	0.5	1	1	0
01/17/2020 14:00	0.6	13.6	1,632.7	0.6	0.5	1	1	0
01/17/2020 15:00	0.7	13.6	1,517.8	0.7	0.5	1	1	1
01/17/2020 16:00	0.7	12.7	2,010.2	0.7	0.6	1	1	1
01/17/2020 17:00	0.7	12.8	1,972.3	0.7	0.6	1	1	1
01/17/2020 18:00	0.7	12.9	1,979.7	0.7	0.6	1	1	1
01/17/2020 19:00	0.7	12.4	2,087.5	0.7	0.6	1	1	1
01/17/2020 20:00	0.7	12.3	2,116.9	0.7	0.6	1	1	1
01/17/2020 21:00	0.7	12.4	2,106.8	0.7	0.6	1	1	1
01/17/2020 22:00	0.7	12.4	2,086.2	0.7	0.6	1	1	1
01/17/2020 23:00	0.7	12.6	2,065.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,957.5	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	11.9	1,517.8	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,248.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/18/2020 00:00	0.7	12.6	2,047.8	0.7	0.6	1	1	1
01/18/2020 01:00	0.7	12.6	2,060.0	0.7	0.6	1	1	1
01/18/2020 02:00	0.7	12.7	2,031.0	0.7	0.6	1	1	1
01/18/2020 03:00	0.7	12.7	2,033.6	0.7	0.6	1	1	1
01/18/2020 04:00	0.7	12.7	2,034.3	0.7	0.6	1	1	1
01/18/2020 05:00	0.7	12.7	2,033.7	0.7	0.6	1	1	1
01/18/2020 06:00	0.7	12.7	2,035.8	0.7	0.6	1	1	1
01/18/2020 07:00	0.7	12.7	2,032.1	0.7	0.6	1	1	1
01/18/2020 08:00	0.7	13.0	2,008.0	0.7	0.6	1	1	1
01/18/2020 09:00	0.7	13.6	1,685.4	0.7	0.5	1	1	1
01/18/2020 10:00	0.6	13.6	1,636.9	0.6	0.5	1	1	0
01/18/2020 11:00	0.6	13.6	1,616.7	0.6	0.5	1	1	0
01/18/2020 12:00	0.6	13.6	1,634.4	0.6	0.5	1	1	0
01/18/2020 13:00	0.6	13.6	1,663.8	0.6	0.5	1	1	0
01/18/2020 14:00	0.6	13.6	1,631.3	0.6	0.5	1	1	0
01/18/2020 15:00	0.7	13.6	1,611.6	0.7	0.5	1	1	1
01/18/2020 16:00	0.7	12.7	2,018.3	0.7	0.6	1	1	1
01/18/2020 17:00	0.7	12.6	2,041.6	0.7	0.6	1	1	1
01/18/2020 18:00	0.7	12.9	1,972.5	0.7	0.6	1	1	1
01/18/2020 19:00	0.7	12.5	2,060.4	0.7	0.6	1	1	1
01/18/2020 20:00	0.7	12.3	2,113.0	0.7	0.6	1	1	1
01/18/2020 21:00	0.7	12.3	2,118.6	0.7	0.6	1	1	1
01/18/2020 22:00	0.7	12.2	2,128.9	0.7	0.6	1	1	1
01/18/2020 23:00	0.7	12.3	2,107.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,931.6	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.2	1,611.6	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,128.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/19/2020 00:00	0.7	12.5	2,026.4	0.7	0.6	1	1	1
01/19/2020 01:00	0.6	13.6	1,708.0	0.6	0.5	1	1	0
01/19/2020 02:00	0.6	13.6	1,559.6	0.6	0.5	1	1	0
01/19/2020 03:00	0.6	13.6	1,637.5	0.6	0.5	1	1	0
01/19/2020 04:00	0.6	13.6	1,630.0	0.6	0.5	1	1	0
01/19/2020 05:00	0.6	13.6	1,678.4	0.6	0.5	1	1	0
01/19/2020 06:00	0.6	13.6	1,699.9	0.6	0.5	1	1	0
01/19/2020 07:00	0.6	13.6	1,603.0	0.6	0.5	1	1	0
01/19/2020 08:00	0.6	13.6	1,563.8	0.6	0.5	1	1	0
01/19/2020 09:00	0.6	13.6	1,632.9	0.6	0.5	1	1	0
01/19/2020 10:00	0.6	13.6	1,576.8	0.6	0.5	1	1	0
01/19/2020 11:00	0.6	13.6	1,649.1	0.6	0.5	1	1	0
01/19/2020 12:00	0.6	13.6	1,668.4	0.6	0.5	1	1	0
01/19/2020 13:00	0.6	13.6	1,686.3	0.6	0.5	1	1	0
01/19/2020 14:00	0.6	13.6	1,595.7	0.6	0.5	1	1	0
01/19/2020 15:00	0.6	13.6	1,628.8	0.6	0.5	1	1	0
01/19/2020 16:00	0.7	13.6	1,623.0	0.7	0.5	1	1	1
01/19/2020 17:00	0.7	12.7	2,015.6	0.7	0.6	1	1	1
01/19/2020 18:00	0.7	12.5	2,047.9	0.7	0.6	1	1	1
01/19/2020 19:00	0.7	12.6	2,041.9	0.7	0.6	1	1	1
01/19/2020 20:00	0.7	12.3	2,102.5	0.7	0.6	1	1	1
01/19/2020 21:00	0.7	12.2	2,125.7	0.7	0.6	1	1	1
01/19/2020 22:00	0.7	12.2	2,120.0	0.7	0.6	1	1	1
01/19/2020 23:00	0.7	12.3	2,111.0	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,780.5	0.6	0.5	24 #	24 #	9 #
Minimum:	0.6	12.2	1,559.6	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,125.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/20/2020 00:00	0.7	12.4	2,079.7	0.7	0.6	1	1	1
01/20/2020 01:00	0.7	12.6	2,045.1	0.7	0.6	1	1	1
01/20/2020 02:00	0.7	12.6	2,027.0	0.7	0.6	1	1	1
01/20/2020 03:00	0.7	12.6	2,033.0	0.7	0.6	1	1	1
01/20/2020 04:00	0.7	12.6	2,037.0	0.7	0.6	1	1	1
01/20/2020 05:00	0.7	12.5	2,048.2	0.7	0.6	1	1	1
01/20/2020 06:00	0.7	12.5	2,054.6	0.7	0.6	1	1	1
01/20/2020 07:00	0.7	12.3	2,111.4	0.7	0.6	1	1	1
01/20/2020 08:00	0.7	12.2	2,128.5	0.7	0.6	1	1	1
01/20/2020 09:00	0.7	12.2	2,108.7	0.7	0.6	1	1	1
01/20/2020 10:00	0.7	12.2	2,124.2	0.7	0.6	1	1	1
01/20/2020 11:00	0.7	12.2	2,103.7	0.7	0.6	1	1	1
01/20/2020 12:00	0.7	12.1	2,117.8	0.7	0.6	1	1	1
01/20/2020 13:00	0.7	12.2	2,112.3	0.7	0.6	1	1	1
01/20/2020 14:00	0.7	12.1	2,131.1	0.7	0.6	1	1	1
01/20/2020 15:00	0.7	12.2	2,101.1	0.7	0.6	1	1	1
01/20/2020 16:00	0.7	12.4	2,065.6	0.7	0.6	1	1	1
01/20/2020 17:00	0.7	12.2	2,111.9	0.7	0.6	1	1	1
01/20/2020 18:00	0.7	12.2	2,113.8	0.7	0.6	1	1	1
01/20/2020 19:00	0.7	12.2	2,109.9	0.7	0.6	1	1	1
01/20/2020 20:00	0.7	12.2	2,109.6	0.7	0.6	1	1	1
01/20/2020 21:00	0.7	12.3	2,104.2	0.7	0.6	1	1	1
01/20/2020 22:00	0.7	12.3	2,090.5	0.7	0.6	1	1	1
01/20/2020 23:00	0.7	12.4	2,065.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.3	2,088.9	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.1	2,027.0	0.7	0.6	1	1	1
Maximum:	0.7	12.6	2,131.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/21/2020 00:00	0.7	12.5	2,039.9	0.7	0.6	1	1	1
01/21/2020 01:00	0.7	12.6	2,032.9	0.7	0.6	1	1	1
01/21/2020 02:00	0.7	12.6	2,037.9	0.7	0.6	1	1	1
01/21/2020 03:00	0.7	12.5	2,039.8	0.7	0.6	1	1	1
01/21/2020 04:00	0.7	12.5	2,036.1	0.7	0.6	1	1	1
01/21/2020 05:00	0.7	12.5	2,037.0	0.7	0.6	1	1	1
01/21/2020 06:00	0.7	12.6	2,010.2	0.7	0.6	1	1	1
01/21/2020 07:00	0.7	12.3	2,085.0	0.7	0.6	1	1	1
01/21/2020 08:00	0.7	12.5	2,053.1	0.7	0.6	1	1	1
01/21/2020 09:00	0.7	12.7	1,982.7	0.7	0.6	1	1	1
01/21/2020 10:00	0.7	13.5	1,681.4	0.7	0.5	1	1	1
01/21/2020 11:00	0.6	13.6	1,692.8	0.6	0.5	1	1	0
01/21/2020 12:00	0.6	13.6	1,659.1	0.6	0.5	1	1	0
01/21/2020 13:00	0.6	13.6	1,630.8	0.6	0.5	1	1	0
01/21/2020 14:00	0.6	13.6	1,640.3	0.6	0.5	1	1	0
01/21/2020 15:00	0.7	13.6	1,563.7	0.7	0.5	1	1	1
01/21/2020 16:00	0.7	12.5	2,034.2	0.7	0.6	1	1	1
01/21/2020 17:00	0.7	12.4	2,056.2	0.7	0.6	1	1	1
01/21/2020 18:00	0.7	12.4	2,048.2	0.7	0.6	1	1	1
01/21/2020 19:00	0.7	12.4	2,044.8	0.7	0.6	1	1	1
01/21/2020 20:00	0.7	12.4	2,039.9	0.7	0.6	1	1	1
01/21/2020 21:00	0.7	12.5	2,034.2	0.7	0.6	1	1	1
01/21/2020 22:00	0.7	12.3	2,070.4	0.7	0.6	1	1	1
01/21/2020 23:00	0.7	12.5	2,044.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,941.5	0.7	0.6	24 #	24 #	20 #
Minimum:	0.6	12.3	1,563.7	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,085.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2020 00:00	0.7	13.0	1,841.4	0.7	0.6	1	1	1
01/22/2020 01:00	0.6	13.6	1,309.8	0.6	0.4	1	1	0
01/22/2020 02:00	0.6	13.6	1,381.3	0.6	0.4	1	1	0
01/22/2020 03:00	0.6	13.6	1,345.7	0.6	0.4	1	1	0
01/22/2020 04:00	0.6	13.6	1,527.5	0.6	0.5	1	1	0
01/22/2020 05:00	0.6	13.6	1,463.0	0.6	0.4	1	1	0
01/22/2020 06:00	0.6	13.6	1,596.4	0.6	0.5	1	1	0
01/22/2020 07:00	0.6	13.6	1,646.4	0.6	0.5	1	1	0
01/22/2020 08:00	0.6	13.6	1,493.5	0.6	0.4	1	1	0
01/22/2020 09:00	0.6	13.6	1,595.0	0.6	0.5	1	1	0
01/22/2020 10:00	0.6	13.6	1,624.5	0.6	0.5	1	1	0
01/22/2020 11:00	0.6	13.6	1,705.1	0.6	0.5	1	1	0
01/22/2020 12:00	0.6	13.6	1,710.3	0.6	0.5	1	1	0
01/22/2020 13:00	0.6	13.6	1,669.7	0.6	0.5	1	1	0
01/22/2020 14:00	0.6	13.6	1,640.8	0.6	0.5	1	1	0
01/22/2020 15:00	0.7	13.6	1,608.1	0.7	0.5	1	1	1
01/22/2020 16:00	0.7	12.6	2,032.9	0.7	0.6	1	1	1
01/22/2020 17:00	0.7	12.6	2,017.9	0.7	0.6	1	1	1
01/22/2020 18:00	0.7	12.2	2,121.4	0.7	0.6	1	1	1
01/22/2020 19:00	0.7	12.2	2,114.1	0.7	0.6	1	1	1
01/22/2020 20:00	0.7	12.5	2,048.7	0.7	0.6	1	1	1
01/22/2020 21:00	0.7	12.6	2,040.8	0.7	0.6	1	1	1
01/22/2020 22:00	0.7	12.5	2,045.9	0.7	0.6	1	1	1
01/22/2020 23:00	0.7	12.9	1,969.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,731.2	0.6	0.5	24 #	24 #	10 #
Minimum:	0.6	12.2	1,309.8	0.6	0.4	1	1	0
Maximum:	0.7	13.6	2,121.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/23/2020 00:00	0.7	12.4	2,093.9	0.7	0.6	1	1	1
01/23/2020 01:00	0.7	12.3	2,092.7	0.7	0.6	1	1	1
01/23/2020 02:00	0.7	12.5	2,044.9	0.7	0.6	1	1	1
01/23/2020 03:00	0.7	12.6	2,042.8	0.7	0.6	1	1	1
01/23/2020 04:00	0.7	12.3	2,107.6	0.7	0.6	1	1	1
01/23/2020 05:00	0.7	12.6	2,053.0	0.7	0.6	1	1	1
01/23/2020 06:00	0.7	12.2	2,134.5	0.7	0.6	1	1	1
01/23/2020 07:00	0.7	12.4	2,097.9	0.7	0.6	1	1	1
01/23/2020 08:00	0.7	12.9	1,950.8	0.7	0.6	1	1	1
01/23/2020 09:00	0.6	13.6	1,683.4	0.6	0.5	1	1	0
01/23/2020 10:00	0.6	13.6	1,559.2	0.6	0.5	1	1	0
01/23/2020 11:00	0.6	13.6	1,615.7	0.6	0.5	1	1	0
01/23/2020 12:00	0.6	13.6	1,642.0	0.6	0.5	1	1	0
01/23/2020 13:00	0.6	13.6	1,672.7	0.6	0.5	1	1	0
01/23/2020 14:00	0.6	13.6	1,662.7	0.6	0.5	1	1	0
01/23/2020 15:00	0.6	13.6	1,631.3	0.6	0.5	1	1	0
01/23/2020 16:00	0.6	13.6	1,505.8	0.6	0.5	1	1	0
01/23/2020 17:00	0.7	12.9	1,927.7	0.7	0.6	1	1	1
01/23/2020 18:00	0.7	12.1	2,123.8	0.7	0.6	1	1	1
01/23/2020 19:00	0.7	12.1	2,119.7	0.7	0.6	1	1	1
01/23/2020 20:00	0.7	12.2	2,116.2	0.7	0.6	1	1	1
01/23/2020 21:00	0.7	12.2	2,102.1	0.7	0.6	1	1	1
01/23/2020 22:00	0.7	12.4	2,066.4	0.7	0.6	1	1	1
01/23/2020 23:00	0.7	12.9	1,955.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,916.8	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	12.1	1,505.8	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,134.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2020 00:00	0.7	12.9	1,936.9	0.7	0.6	1	1	1
01/24/2020 01:00	0.6	13.6	1,646.8	0.6	0.5	1	1	0
01/24/2020 02:00	0.6	13.6	1,665.5	0.6	0.5	1	1	0
01/24/2020 03:00	0.6	13.6	1,699.4	0.6	0.5	1	1	0
01/24/2020 04:00	0.6	13.6	1,701.8	0.6	0.5	1	1	0
01/24/2020 05:00	0.6	13.6	1,600.3	0.6	0.5	1	1	0
01/24/2020 06:00	0.6	13.6	1,657.8	0.6	0.5	1	1	0
01/24/2020 07:00	0.6	13.6	1,654.5	0.6	0.5	1	1	0
01/24/2020 08:00	0.6	13.6	1,597.3	0.6	0.5	1	1	0
01/24/2020 09:00	0.6	13.6	1,669.6	0.6	0.5	1	1	0
01/24/2020 10:00	0.6	13.6	1,482.9	0.6	0.4	1	1	0
01/24/2020 11:00	0.6	13.6	1,665.0	0.6	0.5	1	1	0
01/24/2020 12:00	0.6	13.6	1,639.1	0.6	0.5	1	1	0
01/24/2020 13:00	0.6	13.6	1,681.7	0.6	0.5	1	1	0
01/24/2020 14:00	0.6	13.6	1,653.2	0.6	0.5	1	1	0
01/24/2020 15:00	0.6	13.6	1,557.3	0.6	0.5	1	1	0
01/24/2020 16:00	0.7	13.6	1,589.3	0.7	0.5	1	1	1
01/24/2020 17:00	0.7	12.5	2,029.3	0.7	0.6	1	1	1
01/24/2020 18:00	0.7	12.2	2,115.6	0.7	0.6	1	1	1
01/24/2020 19:00	0.7	12.2	2,112.0	0.7	0.6	1	1	1
01/24/2020 20:00	0.7	12.2	2,104.4	0.7	0.6	1	1	1
01/24/2020 21:00	0.7	12.3	2,077.7	0.7	0.6	1	1	1
01/24/2020 22:00	0.7	12.5	2,048.2	0.7	0.6	1	1	1
01/24/2020 23:00	0.0	13.9	1,278.7	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.3	1,744.3	0.6	0.5	24 #	23 #	9 #
Minimum:	0.0	12.2	1,278.7	0.0	0.4	1	0	0
Maximum:	0.7	13.9	2,115.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 18:00	0.0	17.3	476.2	0.0	0.1	1	0	0
01/27/2020 19:00	0.0	16.8	534.7	0.0	0.2	1	0	0
01/27/2020 20:00	0.0	15.3	882.3	0.0	0.3	1	0	0
01/27/2020 21:00	0.6	13.6	1,433.6	0.6	0.4	1	1	0
01/27/2020 22:00	0.6	13.7	1,367.5	0.6	0.4	1	1	0
01/27/2020 23:00	0.6	13.7	1,370.1	0.6	0.4	1	1	0
Average/Sum#:	0.3	15.1	1,010.7	0.3	0.3	6 #	3 #	0 #
Minimum:	0.0	13.6	476.2	0.0	0.1	0	0	0
Maximum:	0.6	17.3	1,433.6	0.6	0.4	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/28/2020 00:00	0.6	13.7	1,367.3	0.6	0.4	1	1	0
01/28/2020 01:00	0.6	13.6	1,362.7	0.6	0.4	1	1	0
01/28/2020 02:00	0.6	13.6	1,362.1	0.6	0.4	1	1	0
01/28/2020 03:00	0.6	13.6	1,634.5	0.6	0.5	1	1	0
01/28/2020 04:00	0.6	13.6	1,495.1	0.6	0.4	1	1	0
01/28/2020 05:00	0.6	13.6	1,602.4	0.6	0.5	1	1	0
01/28/2020 06:00	0.6	13.6	1,703.4	0.6	0.5	1	1	0
01/28/2020 07:00	0.6	13.6	1,611.7	0.6	0.5	1	1	0
01/28/2020 08:00	0.6	13.6	1,672.8	0.6	0.5	1	1	0
01/28/2020 09:00	0.6	13.6	1,687.1	0.6	0.5	1	1	0
01/28/2020 10:00	0.6	13.6	1,538.9	0.6	0.5	1	1	0
01/28/2020 11:00	0.6	13.6	1,621.0	0.6	0.5	1	1	0
01/28/2020 12:00	0.6	13.6	1,613.2	0.6	0.5	1	1	0
01/28/2020 13:00	0.6	13.6	1,671.5	0.6	0.5	1	1	0
01/28/2020 14:00	0.6	13.6	1,580.4	0.6	0.5	1	1	0
01/28/2020 15:00	0.6	13.6	1,569.9	0.6	0.5	1	1	0
01/28/2020 16:00	0.7	13.6	1,573.9	0.7	0.5	1	1	1
01/28/2020 17:00	0.7	12.6	2,024.2	0.7	0.6	1	1	1
01/28/2020 18:00	0.7	12.4	2,066.7	0.7	0.6	1	1	1
01/28/2020 19:00	0.7	12.3	2,086.3	0.7	0.6	1	1	1
01/28/2020 20:00	0.7	12.2	2,113.2	0.7	0.6	1	1	1
01/28/2020 21:00	0.7	12.2	2,112.7	0.7	0.6	1	1	1
01/28/2020 22:00	0.0	13.9	1,290.1	0.0	0.4	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.3	1,667.9	0.6	0.5	23 #	22 #	7 #
Minimum:	0.0	12.2	1,290.1	0.0	0.4	0	0	0
Maximum:	0.7	13.9	2,113.2	0.7	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 17:00	0.0	17.3	460.5	0.0	0.1	1	0	0
01/29/2020 18:00	0.0	15.9	657.2	0.0	0.2	1	0	0
01/29/2020 19:00	0.0	14.2	1,327.0	0.0	0.4	1	0	0
01/29/2020 20:00	0.7	13.0	1,853.0	0.7	0.6	1	1	1
01/29/2020 21:00	0.7	11.8	2,158.1	0.7	0.6	1	1	1
01/29/2020 22:00	0.7	13.3	1,632.5	0.7	0.5	1	1	1
01/29/2020 23:00	0.6	13.7	1,528.4	0.6	0.5	1	1	0
Average/Sum#:	0.4	14.2	1,373.8	0.4	0.4	7 #	4 #	3 #
Minimum:	0.0	11.8	460.5	0.0	0.1	0	0	0
Maximum:	0.7	17.3	2,158.1	0.7	0.6	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/30/2020 00:00	0.6	13.6	1,552.4	0.6	0.5	1	1	0
01/30/2020 01:00	0.6	13.6	1,556.1	0.6	0.5	1	1	0
01/30/2020 02:00	0.6	13.6	1,692.0	0.6	0.5	1	1	0
01/30/2020 03:00	0.6	13.6	1,472.5	0.6	0.4	1	1	0
01/30/2020 04:00	0.6	13.6	1,642.6	0.6	0.5	1	1	0
01/30/2020 05:00	0.6	13.6	1,391.3	0.6	0.4	1	1	0
01/30/2020 06:00	0.7	12.9	1,859.5	0.7	0.6	1	1	1
01/30/2020 07:00	0.7	12.4	2,091.1	0.7	0.6	1	1	1
01/30/2020 08:00	0.7	12.9	1,946.8	0.7	0.6	1	1	1
01/30/2020 09:00	0.6	13.6	1,635.6	0.6	0.5	1	1	0
01/30/2020 10:00	0.6	13.6	1,643.1	0.6	0.5	1	1	0
01/30/2020 11:00	0.6	13.6	1,694.3	0.6	0.5	1	1	0
01/30/2020 12:00	0.6	13.6	1,499.8	0.6	0.4	1	1	0
01/30/2020 13:00	0.6	13.6	1,657.3	0.6	0.5	1	1	0
01/30/2020 14:00	0.6	13.6	1,554.7	0.6	0.5	1	1	0
01/30/2020 15:00	0.6	13.6	1,633.8	0.6	0.5	1	1	0
01/30/2020 16:00	0.6	13.6	1,516.4	0.6	0.5	1	1	0
01/30/2020 17:00	0.6	13.6	1,642.3	0.6	0.5	1	1	0
01/30/2020 18:00	0.7	13.6	1,718.5	0.7	0.5	1	1	1
01/30/2020 19:00	0.7	12.4	2,025.8	0.7	0.6	1	1	1
01/30/2020 20:00	0.7	12.0	2,117.0	0.7	0.6	1	1	1
01/30/2020 21:00	0.7	12.1	2,100.4	0.7	0.6	1	1	1
01/30/2020 22:00	0.7	12.3	2,053.8	0.7	0.6	1	1	1
01/30/2020 23:00	0.7	13.2	1,755.7	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.2	1,727.2	0.6	0.5	24 #	24 #	9 #
Minimum:	0.6	12.0	1,391.3	0.6	0.4	1	1	0
Maximum:	0.7	13.6	2,117.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/31/2020 00:00	0.6	13.7	1,427.0	0.6	0.4	1	1	0
01/31/2020 01:00	0.6	13.7	1,387.7	0.6	0.4	1	1	0
01/31/2020 02:00	0.6	13.7	1,385.5	0.6	0.4	1	1	0
01/31/2020 03:00	0.6	13.6	1,396.6	0.6	0.4	1	1	0
01/31/2020 04:00	0.6	13.6	1,463.0	0.6	0.4	1	1	0
01/31/2020 05:00	0.6	13.6	1,703.6	0.6	0.5	1	1	0
01/31/2020 06:00	0.6	13.6	1,548.2	0.6	0.5	1	1	0
01/31/2020 07:00	0.6	13.6	1,599.8	0.6	0.5	1	1	0
01/31/2020 08:00	0.6	13.6	1,532.8	0.6	0.5	1	1	0
01/31/2020 09:00	0.6	13.6	1,630.4	0.6	0.5	1	1	0
01/31/2020 10:00	0.6	13.6	1,643.8	0.6	0.5	1	1	0
01/31/2020 11:00	0.6	13.6	1,650.4	0.6	0.5	1	1	0
01/31/2020 12:00	0.6	13.6	1,623.4	0.6	0.5	1	1	0
01/31/2020 13:00	0.6	13.6	1,697.8	0.6	0.5	1	1	0
01/31/2020 14:00	0.6	13.6	1,685.6	0.6	0.5	1	1	0
01/31/2020 15:00	0.6	13.6	1,670.4	0.6	0.5	1	1	0
01/31/2020 16:00	0.6	13.7	1,488.7	0.6	0.4	1	1	0
01/31/2020 17:00	0.6	13.6	1,679.8	0.6	0.5	1	1	0
01/31/2020 18:00	0.7	13.1	1,828.9	0.7	0.5	1	1	1
01/31/2020 19:00	0.7	12.5	2,014.8	0.7	0.6	1	1	1
01/31/2020 20:00	0.7	12.2	2,098.2	0.7	0.6	1	1	1
01/31/2020 21:00	0.7	12.2	2,099.3	0.7	0.6	1	1	1
01/31/2020 22:00	0.7	12.2	2,092.4	0.7	0.6	1	1	1
01/31/2020 23:00	0.0	14.0	1,276.7	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.4	1,651.0	0.6	0.5	24 #	23 #	6 #
Minimum:	0.0	12.2	1,276.7	0.0	0.4	1	0	0
Maximum:	0.7	14.0	2,099.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 23:00	0.0	17.3	477.5	0.0	0.1	1	0	0
Average/Sum#:	0.0	17.3	477.5	0.0	0.1	1 #	0 #	0 #
Minimum:	0.0	17.3	477.5	0.0	0.1	0	0	0
Maximum:	0.0	17.3	477.5	0.0	0.1	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/03/2020 00:00	0.0	16.9	528.4	0.0	0.2	1	0	0
02/03/2020 01:00	0.0	15.9	715.4	0.0	0.2	1	0	0
02/03/2020 02:00	0.0	13.7	1,442.4	0.0	0.4	1	0	0
02/03/2020 03:00	0.6	13.7	1,465.0	0.6	0.4	1	1	0
02/03/2020 04:00	0.6	13.6	1,708.3	0.6	0.5	1	1	0
02/03/2020 05:00	0.6	13.7	1,559.5	0.6	0.5	1	1	0
02/03/2020 06:00	0.6	13.6	1,710.4	0.6	0.5	1	1	0
02/03/2020 07:00	0.6	13.6	1,622.5	0.6	0.5	1	1	0
02/03/2020 08:00	0.6	13.7	1,552.9	0.6	0.5	1	1	0
02/03/2020 09:00	0.6	13.7	1,483.7	0.6	0.4	1	1	0
02/03/2020 10:00	0.6	13.7	1,566.7	0.6	0.5	1	1	0
02/03/2020 11:00	0.6	13.7	1,701.3	0.6	0.5	1	1	0
02/03/2020 12:00	0.6	13.7	1,664.6	0.6	0.5	1	1	0
02/03/2020 13:00	0.6	13.7	1,651.6	0.6	0.5	1	1	0
02/03/2020 14:00	0.6	13.7	1,575.5	0.6	0.5	1	1	0
02/03/2020 15:00	0.6	13.7	1,666.2	0.6	0.5	1	1	0
02/03/2020 16:00	0.7	13.7	1,593.4	0.7	0.5	1	1	1
02/03/2020 17:00	0.7	12.6	2,059.2	0.7	0.6	1	1	1
02/03/2020 18:00	0.7	11.9	2,216.8	0.7	0.7	1	1	1
02/03/2020 19:00	0.7	11.8	2,245.3	0.7	0.7	1	1	1
02/03/2020 20:00	0.7	11.8	2,248.2	0.7	0.7	1	1	1
02/03/2020 21:00	0.7	12.3	2,139.4	0.7	0.6	1	1	1
02/03/2020 22:00	0.7	12.3	2,127.7	0.7	0.6	1	1	1
02/03/2020 23:00	0.7	12.5	2,097.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,680.9	0.6	0.5	24 #	21 #	8 #
Minimum:	0.0	11.8	528.4	0.0	0.2	1	0	0
Maximum:	0.7	16.9	2,248.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/04/2020 00:00	0.7	12.6	2,067.0	0.7	0.6	1	1	1
02/04/2020 01:00	0.7	12.7	2,043.7	0.7	0.6	1	1	1
02/04/2020 02:00	0.7	12.7	2,047.7	0.7	0.6	1	1	1
02/04/2020 03:00	0.7	12.7	2,042.3	0.7	0.6	1	1	1
02/04/2020 04:00	0.7	12.6	2,066.5	0.7	0.6	1	1	1
02/04/2020 05:00	0.7	12.5	2,099.2	0.7	0.6	1	1	1
02/04/2020 06:00	0.7	12.2	2,145.7	0.7	0.6	1	1	1
02/04/2020 07:00	0.7	12.2	2,164.2	0.7	0.6	1	1	1
02/04/2020 08:00	0.7	12.6	2,041.1	0.7	0.6	1	1	1
02/04/2020 09:00	0.6	13.7	1,764.2	0.6	0.5	1	1	0
02/04/2020 10:00	0.6	13.7	1,764.5	0.6	0.5	1	1	0
02/04/2020 11:00	0.6	13.7	1,764.1	0.6	0.5	1	1	0
02/04/2020 12:00	0.6	13.7	1,764.6	0.6	0.5	1	1	0
02/04/2020 13:00	0.6	13.7	1,765.0	0.6	0.5	1	1	0
02/04/2020 14:00	0.6	13.7	1,765.6	0.6	0.5	1	1	0
02/04/2020 15:00	0.6	13.7	1,765.7	0.6	0.5	1	1	0
02/04/2020 16:00	0.7	13.3	1,836.9	0.7	0.6	1	1	1
02/04/2020 17:00	0.7	12.8	1,997.4	0.7	0.6	1	1	1
02/04/2020 18:00	0.7	12.3	2,119.1	0.7	0.6	1	1	1
02/04/2020 19:00	0.7	12.0	2,181.9	0.7	0.7	1	1	1
02/04/2020 20:00	0.7	12.1	2,167.2	0.7	0.7	1	1	1
02/04/2020 21:00	0.7	11.9	2,225.3	0.7	0.7	1	1	1
02/04/2020 22:00	0.7	12.3	2,108.0	0.7	0.6	1	1	1
02/04/2020 23:00	0.7	12.4	2,088.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,991.5	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	11.9	1,764.1	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,225.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2020 00:00	0.7	12.3	2,109.0	0.7	0.6	1	1	1
02/05/2020 01:00	0.7	12.5	2,078.8	0.7	0.6	1	1	1
02/05/2020 02:00	0.7	12.6	2,047.2	0.7	0.6	1	1	1
02/05/2020 03:00	0.7	12.6	2,046.5	0.7	0.6	1	1	1
02/05/2020 04:00	0.7	12.5	2,067.8	0.7	0.6	1	1	1
02/05/2020 05:00	0.7	12.8	1,996.5	0.7	0.6	1	1	1
02/05/2020 06:00	0.7	12.7	2,015.4	0.7	0.6	1	1	1
02/05/2020 07:00	0.7	12.0	2,185.5	0.7	0.7	1	1	1
02/05/2020 08:00	0.7	12.5	2,067.4	0.7	0.6	1	1	1
02/05/2020 09:00	0.7	12.9	1,956.4	0.7	0.6	1	1	1
02/05/2020 10:00	0.6	13.6	1,617.9	0.6	0.5	1	1	0
02/05/2020 11:00	0.6	13.6	1,623.0	0.6	0.5	1	1	0
02/05/2020 12:00	0.6	13.6	1,671.3	0.6	0.5	1	1	0
02/05/2020 13:00	0.6	13.6	1,671.8	0.6	0.5	1	1	0
02/05/2020 14:00	0.6	13.7	1,597.6	0.6	0.5	1	1	0
02/05/2020 15:00	0.6	13.6	1,685.0	0.6	0.5	1	1	0
02/05/2020 16:00	0.7	13.2	1,837.1	0.7	0.6	1	1	1
02/05/2020 17:00	0.7	12.8	1,973.5	0.7	0.6	1	1	1
02/05/2020 18:00	0.7	12.0	2,168.5	0.7	0.7	1	1	1
02/05/2020 19:00	0.7	12.1	2,119.6	0.7	0.6	1	1	1
02/05/2020 20:00	0.7	12.1	2,144.6	0.7	0.6	1	1	1
02/05/2020 21:00	0.7	12.3	2,102.4	0.7	0.6	1	1	1
02/05/2020 22:00	0.7	12.2	2,114.5	0.7	0.6	1	1	1
02/05/2020 23:00	0.7	12.4	2,056.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,956.4	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.0	1,597.6	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,185.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2020 00:00	0.7	12.6	2,026.4	0.7	0.6	1	1	1
02/06/2020 01:00	0.7	12.7	2,008.0	0.7	0.6	1	1	1
02/06/2020 02:00	0.7	12.8	2,007.0	0.7	0.6	1	1	1
02/06/2020 03:00	0.7	12.7	2,028.1	0.7	0.6	1	1	1
02/06/2020 04:00	0.7	12.7	2,018.4	0.7	0.6	1	1	1
02/06/2020 05:00	0.7	12.7	2,042.6	0.7	0.6	1	1	1
02/06/2020 06:00	0.7	12.3	2,070.9	0.7	0.6	1	1	1
02/06/2020 07:00	0.7	12.4	2,087.5	0.7	0.6	1	1	1
02/06/2020 08:00	0.7	13.0	1,940.7	0.7	0.6	1	1	1
02/06/2020 09:00	0.6	13.6	1,701.3	0.6	0.5	1	1	0
02/06/2020 10:00	0.6	13.6	1,689.3	0.6	0.5	1	1	0
02/06/2020 11:00	0.6	13.6	1,690.2	0.6	0.5	1	1	0
02/06/2020 12:00	0.6	13.6	1,598.3	0.6	0.5	1	1	0
02/06/2020 13:00	0.6	13.6	1,688.1	0.6	0.5	1	1	0
02/06/2020 14:00	0.6	13.6	1,670.8	0.6	0.5	1	1	0
02/06/2020 15:00	0.6	13.6	1,553.6	0.6	0.5	1	1	0
02/06/2020 16:00	0.7	13.6	1,572.1	0.7	0.5	1	1	1
02/06/2020 17:00	0.7	12.6	2,001.0	0.7	0.6	1	1	1
02/06/2020 18:00	0.7	12.2	2,095.8	0.7	0.6	1	1	1
02/06/2020 19:00	0.7	12.2	2,088.1	0.7	0.6	1	1	1
02/06/2020 20:00	0.7	12.2	2,105.0	0.7	0.6	1	1	1
02/06/2020 21:00	0.7	12.2	2,107.5	0.7	0.6	1	1	1
02/06/2020 22:00	0.7	12.3	2,084.1	0.7	0.6	1	1	1
02/06/2020 23:00	0.7	12.9	1,948.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,909.3	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.2	1,553.6	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,107.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2020 00:00	0.7	12.9	1,928.1	0.7	0.6	1	1	1
02/07/2020 01:00	0.6	13.6	1,705.0	0.6	0.5	1	1	0
02/07/2020 02:00	0.6	13.6	1,570.0	0.6	0.5	1	1	0
02/07/2020 03:00	0.6	13.6	1,566.2	0.6	0.5	1	1	0
02/07/2020 04:00	0.6	13.6	1,535.6	0.6	0.5	1	1	0
02/07/2020 05:00	0.7	13.6	1,566.2	0.7	0.5	1	1	1
02/07/2020 06:00	0.7	12.5	2,036.5	0.7	0.6	1	1	1
02/07/2020 07:00	0.7	12.4	2,086.5	0.7	0.6	1	1	1
02/07/2020 08:00	0.7	12.9	1,960.4	0.7	0.6	1	1	1
02/07/2020 09:00	0.6	13.6	1,654.0	0.6	0.5	1	1	0
02/07/2020 10:00	0.6	13.6	1,668.8	0.6	0.5	1	1	0
02/07/2020 11:00	0.6	13.6	1,699.5	0.6	0.5	1	1	0
02/07/2020 12:00	0.6	13.6	1,701.9	0.6	0.5	1	1	0
02/07/2020 13:00	0.6	13.6	1,699.7	0.6	0.5	1	1	0
02/07/2020 14:00	0.6	13.6	1,669.1	0.6	0.5	1	1	0
02/07/2020 15:00	0.6	13.6	1,686.0	0.6	0.5	1	1	0
02/07/2020 16:00	0.7	13.6	1,598.3	0.7	0.5	1	1	1
02/07/2020 17:00	0.7	12.5	2,017.1	0.7	0.6	1	1	1
02/07/2020 18:00	0.7	12.1	2,105.8	0.7	0.6	1	1	1
02/07/2020 19:00	0.7	12.2	2,086.5	0.7	0.6	1	1	1
02/07/2020 20:00	0.7	12.2	2,098.2	0.7	0.6	1	1	1
02/07/2020 21:00	0.7	12.2	2,097.1	0.7	0.6	1	1	1
02/07/2020 22:00	0.7	12.4	2,050.2	0.7	0.6	1	1	1
02/07/2020 23:00	0.0	14.1	1,248.0	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.1	1,793.1	0.6	0.5	24 #	23 #	13 #
Minimum:	0.0	12.1	1,248.0	0.0	0.4	1	0	0
Maximum:	0.7	14.1	2,105.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 23:00	0.0	17.3	470.6	0.0	0.1	1	0	0
Average/Sum#:	0.0	17.3	470.6	0.0	0.1	1 #	0 #	0 #
Minimum:	0.0	17.3	470.6	0.0	0.1	0	0	0
Maximum:	0.0	17.3	470.6	0.0	0.1	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/10/2020 00:00	0.0	15.6	706.4	0.0	0.2	1	0	0
02/10/2020 01:00	0.0	14.8	998.4	0.0	0.3	1	0	0
02/10/2020 02:00	0.6	13.7	1,443.5	0.6	0.4	1	1	0
02/10/2020 03:00	0.6	13.7	1,376.4	0.6	0.4	1	1	0
02/10/2020 04:00	0.6	13.7	1,512.6	0.6	0.5	1	1	0
02/10/2020 05:00	0.6	13.7	1,436.5	0.6	0.4	1	1	0
02/10/2020 06:00	0.6	13.7	1,700.8	0.6	0.5	1	1	0
02/10/2020 07:00	0.6	13.7	1,705.2	0.6	0.5	1	1	0
02/10/2020 08:00	0.6	13.7	1,662.0	0.6	0.5	1	1	0
02/10/2020 09:00	0.6	13.7	1,663.7	0.6	0.5	1	1	0
02/10/2020 10:00	0.6	13.7	1,645.9	0.6	0.5	1	1	0
02/10/2020 11:00	0.6	13.7	1,677.2	0.6	0.5	1	1	0
02/10/2020 12:00	0.6	13.7	1,676.1	0.6	0.5	1	1	0
02/10/2020 13:00	0.6	13.7	1,661.2	0.6	0.5	1	1	0
02/10/2020 14:00	0.6	13.7	1,658.8	0.6	0.5	1	1	0
02/10/2020 15:00	0.6	13.7	1,667.9	0.6	0.5	1	1	0
02/10/2020 16:00	0.6	13.7	1,697.8	0.6	0.5	1	1	0
02/10/2020 17:00	0.7	13.2	1,841.8	0.7	0.6	1	1	1
02/10/2020 18:00	0.7	12.5	2,055.5	0.7	0.6	1	1	1
02/10/2020 19:00	0.7	12.4	2,070.2	0.7	0.6	1	1	1
02/10/2020 20:00	0.7	12.3	2,107.7	0.7	0.6	1	1	1
02/10/2020 21:00	0.7	12.2	2,115.8	0.7	0.6	1	1	1
02/10/2020 22:00	0.7	12.3	2,088.6	0.7	0.6	1	1	1
02/10/2020 23:00	0.7	12.6	2,033.7	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,675.2	0.6	0.5	24 #	22 #	7 #
Minimum:	0.0	12.2	706.4	0.0	0.2	1	0	0
Maximum:	0.7	15.6	2,115.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2020 00:00	0.7	13.0	1,930.1	0.7	0.6	1	1	1
02/11/2020 01:00	0.6	13.7	1,574.3	0.6	0.5	1	1	0
02/11/2020 02:00	0.6	13.7	1,475.4	0.6	0.4	1	1	0
02/11/2020 03:00	0.6	13.7	1,546.6	0.6	0.5	1	1	0
02/11/2020 04:00	0.6	13.7	1,518.7	0.6	0.5	1	1	0
02/11/2020 05:00	0.6	13.7	1,648.0	0.6	0.5	1	1	0
02/11/2020 06:00	0.6	13.7	1,649.7	0.6	0.5	1	1	0
02/11/2020 07:00	0.6	13.7	1,582.7	0.6	0.5	1	1	0
02/11/2020 08:00	0.6	13.8	1,389.4	0.6	0.4	1	1	0
02/11/2020 09:00	0.6	13.7	1,555.8	0.6	0.5	1	1	0
02/11/2020 10:00	0.6	13.7	1,609.2	0.6	0.5	1	1	0
02/11/2020 11:00	0.6	13.7	1,628.7	0.6	0.5	1	1	0
02/11/2020 12:00	0.6	13.7	1,665.8	0.6	0.5	1	1	0
02/11/2020 13:00	0.6	13.7	1,683.9	0.6	0.5	1	1	0
02/11/2020 14:00	0.6	13.7	1,660.1	0.6	0.5	1	1	0
02/11/2020 15:00	0.6	13.7	1,539.4	0.6	0.5	1	1	0
02/11/2020 16:00	0.6	13.7	1,481.3	0.6	0.4	1	1	0
02/11/2020 17:00	0.6	13.7	1,625.5	0.6	0.5	1	1	0
02/11/2020 18:00	0.7	13.1	1,842.5	0.7	0.6	1	1	1
02/11/2020 19:00	0.7	12.1	2,091.3	0.7	0.6	1	1	1
02/11/2020 20:00	0.7	12.0	2,110.7	0.7	0.6	1	1	1
02/11/2020 21:00	0.7	11.9	2,141.6	0.7	0.6	1	1	1
02/11/2020 22:00	0.7	12.0	2,120.6	0.7	0.6	1	1	1
02/11/2020 23:00	0.7	12.3	2,068.8	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.3	1,714.2	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	11.9	1,389.4	0.6	0.4	1	1	0
Maximum:	0.7	13.8	2,141.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2020 00:00	0.7	12.8	1,926.8	0.7	0.6	1	1	1
02/12/2020 01:00	0.6	13.7	1,569.9	0.6	0.5	1	1	0
02/12/2020 02:00	0.6	13.7	1,548.8	0.6	0.5	1	1	0
02/12/2020 03:00	0.6	13.7	1,507.2	0.6	0.5	1	1	0
02/12/2020 04:00	0.6	13.7	1,660.3	0.6	0.5	1	1	0
02/12/2020 05:00	0.6	13.7	1,664.6	0.6	0.5	1	1	0
02/12/2020 06:00	0.6	13.7	1,623.6	0.6	0.5	1	1	0
02/12/2020 07:00	0.6	13.7	1,562.6	0.6	0.5	1	1	0
02/12/2020 08:00	0.6	13.7	1,702.2	0.6	0.5	1	1	0
02/12/2020 09:00	0.6	13.7	1,692.8	0.6	0.5	1	1	0
02/12/2020 10:00	0.6	13.7	1,679.8	0.6	0.5	1	1	0
02/12/2020 11:00	0.6	13.7	1,680.9	0.6	0.5	1	1	0
02/12/2020 12:00	0.6	13.7	1,645.0	0.6	0.5	1	1	0
02/12/2020 13:00	0.6	13.7	1,689.5	0.6	0.5	1	1	0
02/12/2020 14:00	0.6	13.7	1,630.2	0.6	0.5	1	1	0
02/12/2020 15:00	0.6	13.7	1,617.6	0.6	0.5	1	1	0
02/12/2020 16:00	0.6	13.7	1,413.7	0.6	0.4	1	1	0
02/12/2020 17:00	0.6	13.7	1,634.9	0.6	0.5	1	1	0
02/12/2020 18:00	0.7	13.7	1,707.7	0.7	0.5	1	1	1
02/12/2020 19:00	0.7	12.4	2,026.9	0.7	0.6	1	1	1
02/12/2020 20:00	0.7	12.0	2,121.7	0.7	0.6	1	1	1
02/12/2020 21:00	0.7	12.1	2,104.2	0.7	0.6	1	1	1
02/12/2020 22:00	0.7	12.1	2,099.4	0.7	0.6	1	1	1
02/12/2020 23:00	0.7	12.4	2,048.1	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.4	1,731.6	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.0	1,413.7	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,121.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/13/2020 00:00	0.7	12.4	2,048.4	0.7	0.6	1	1	1
02/13/2020 01:00	0.7	12.6	2,017.6	0.7	0.6	1	1	1
02/13/2020 02:00	0.7	12.6	2,021.7	0.7	0.6	1	1	1
02/13/2020 03:00	0.7	12.6	2,031.1	0.7	0.6	1	1	1
02/13/2020 04:00	0.7	12.6	2,028.8	0.7	0.6	1	1	1
02/13/2020 05:00	0.7	12.6	2,037.2	0.7	0.6	1	1	1
02/13/2020 06:00	0.7	12.1	2,132.4	0.7	0.6	1	1	1
02/13/2020 07:00	0.7	12.4	2,075.9	0.7	0.6	1	1	1
02/13/2020 08:00	0.7	13.0	1,932.9	0.7	0.6	1	1	1
02/13/2020 09:00	0.6	13.6	1,665.6	0.6	0.5	1	1	0
02/13/2020 10:00	0.6	13.6	1,654.7	0.6	0.5	1	1	0
02/13/2020 11:00	0.6	13.7	1,662.2	0.6	0.5	1	1	0
02/13/2020 12:00	0.6	13.7	1,690.0	0.6	0.5	1	1	0
02/13/2020 13:00	0.6	13.7	1,624.3	0.6	0.5	1	1	0
02/13/2020 14:00	0.6	13.7	1,640.4	0.6	0.5	1	1	0
02/13/2020 15:00	0.6	13.7	1,591.0	0.6	0.5	1	1	0
02/13/2020 16:00	0.7	13.6	1,599.3	0.7	0.5	1	1	1
02/13/2020 17:00	0.7	12.5	2,006.2	0.7	0.6	1	1	1
02/13/2020 18:00	0.7	12.1	2,092.0	0.7	0.6	1	1	1
02/13/2020 19:00	0.7	12.1	2,105.6	0.7	0.6	1	1	1
02/13/2020 20:00	0.7	12.1	2,101.3	0.7	0.6	1	1	1
02/13/2020 21:00	0.7	12.1	2,103.7	0.7	0.6	1	1	1
02/13/2020 22:00	0.7	12.3	2,088.7	0.7	0.6	1	1	1
02/13/2020 23:00	0.7	12.3	2,080.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,918.0	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.1	1,591.0	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,132.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2020 00:00	0.0	13.5	1,589.0	0.0	0.5	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.5	1,589.0	0.0	0.5	1 #	0 #	1 #
Minimum:	0.0	13.5	1,589.0	0.0	0.5	0	0	0
Maximum:	0.0	13.5	1,589.0	0.0	0.5	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 09:00	0.0	17.3	473.6	0.0	0.1	1	0	0
02/17/2020 10:00	0.0	16.9	528.5	0.0	0.2	1	0	0
02/17/2020 11:00	0.0	16.0	660.9	0.0	0.2	1	0	0
02/17/2020 12:00	0.0	15.0	968.9	0.0	0.3	1	0	0
02/17/2020 13:00	0.6	13.7	1,393.2	0.6	0.4	1	1	0
02/17/2020 14:00	0.6	13.7	1,392.7	0.6	0.4	1	1	0
02/17/2020 15:00	0.6	13.7	1,620.5	0.6	0.5	1	1	0
02/17/2020 16:00	0.6	13.7	1,517.4	0.6	0.5	1	1	0
02/17/2020 17:00	0.6	13.7	1,693.1	0.6	0.5	1	1	0
02/17/2020 18:00	0.7	13.7	1,746.3	0.7	0.5	1	1	1
02/17/2020 19:00	0.7	12.6	2,017.8	0.7	0.6	1	1	1
02/17/2020 20:00	0.7	12.1	2,129.0	0.7	0.6	1	1	1
02/17/2020 21:00	0.7	12.1	2,118.2	0.7	0.6	1	1	1
02/17/2020 22:00	0.7	12.2	2,099.4	0.7	0.6	1	1	1
02/17/2020 23:00	0.7	12.5	2,054.0	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.9	1,494.2	0.5	0.4	15 #	11 #	6 #
Minimum:	0.0	12.1	473.6	0.0	0.1	0	0	0
Maximum:	0.7	17.3	2,129.0	0.7	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2020 00:00	0.7	12.5	2,047.5	0.7	0.6	1	1	1
02/18/2020 01:00	0.7	12.5	2,046.5	0.7	0.6	1	1	1
02/18/2020 02:00	0.7	12.6	2,022.3	0.7	0.6	1	1	1
02/18/2020 03:00	0.7	12.5	2,046.4	0.7	0.6	1	1	1
02/18/2020 04:00	0.7	12.5	2,048.8	0.7	0.6	1	1	1
02/18/2020 05:00	0.7	12.4	2,068.8	0.7	0.6	1	1	1
02/18/2020 06:00	0.7	12.3	2,105.3	0.7	0.6	1	1	1
02/18/2020 07:00	0.7	12.3	2,104.8	0.7	0.6	1	1	1
02/18/2020 08:00	0.7	12.5	2,060.0	0.7	0.6	1	1	1
02/18/2020 09:00	0.7	12.9	1,957.3	0.7	0.6	1	1	1
02/18/2020 10:00	0.7	13.0	1,955.7	0.7	0.6	1	1	1
02/18/2020 11:00	0.7	13.0	1,953.4	0.7	0.6	1	1	1
02/18/2020 12:00	0.7	13.0	1,950.7	0.7	0.6	1	1	1
02/18/2020 13:00	0.7	13.4	1,773.7	0.7	0.5	1	1	1
02/18/2020 14:00	0.6	13.7	1,414.9	0.6	0.4	1	1	0
02/18/2020 15:00	0.7	13.7	1,503.6	0.7	0.5	1	1	1
02/18/2020 16:00	0.7	12.7	2,015.5	0.7	0.6	1	1	1
02/18/2020 17:00	0.7	12.1	2,134.8	0.7	0.6	1	1	1
02/18/2020 18:00	0.7	12.1	2,153.0	0.7	0.6	1	1	1
02/18/2020 19:00	0.7	11.9	2,196.2	0.7	0.7	1	1	1
02/18/2020 20:00	0.7	11.9	2,196.0	0.7	0.7	1	1	1
02/18/2020 21:00	0.7	12.0	2,149.6	0.7	0.6	1	1	1
02/18/2020 22:00	0.7	12.2	2,109.3	0.7	0.6	1	1	1
02/18/2020 23:00	0.7	12.5	2,053.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,002.8	0.7	0.6	24 #	24 #	23 #
Minimum:	0.6	11.9	1,414.9	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,196.2	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/19/2020 00:00	0.7	11.9	2,212.6	0.7	0.7	1	1	1
02/19/2020 01:00	0.7	12.6	2,032.5	0.7	0.6	1	1	1
02/19/2020 02:00	0.7	13.0	1,942.7	0.7	0.6	1	1	1
02/19/2020 03:00	0.7	13.0	1,943.9	0.7	0.6	1	1	1
02/19/2020 04:00	0.7	12.5	2,066.0	0.7	0.6	1	1	1
02/19/2020 05:00	0.7	12.4	2,094.6	0.7	0.6	1	1	1
02/19/2020 06:00	0.7	12.2	2,100.0	0.7	0.6	1	1	1
02/19/2020 07:00	0.7	12.0	2,178.1	0.7	0.7	1	1	1
02/19/2020 08:00	0.7	12.8	1,995.8	0.7	0.6	1	1	1
02/19/2020 09:00	0.7	13.0	1,946.8	0.7	0.6	1	1	1
02/19/2020 10:00	0.7	13.0	1,947.3	0.7	0.6	1	1	1
02/19/2020 11:00	0.7	13.0	1,948.8	0.7	0.6	1	1	1
02/19/2020 12:00	0.7	13.0	1,949.5	0.7	0.6	1	1	1
02/19/2020 13:00	0.7	13.0	1,948.8	0.7	0.6	1	1	1
02/19/2020 14:00	0.7	13.0	1,945.4	0.7	0.6	1	1	1
02/19/2020 15:00	0.7	13.0	1,941.5	0.7	0.6	1	1	1
02/19/2020 16:00	0.7	12.6	2,035.5	0.7	0.6	1	1	1
02/19/2020 17:00	0.7	12.1	2,108.7	0.7	0.6	1	1	1
02/19/2020 18:00	0.7	12.1	2,113.8	0.7	0.6	1	1	1
02/19/2020 19:00	0.7	11.8	2,176.3	0.7	0.7	1	1	1
02/19/2020 20:00	0.7	11.9	2,164.0	0.7	0.6	1	1	1
02/19/2020 21:00	0.7	12.0	2,159.2	0.7	0.6	1	1	1
02/19/2020 22:00	0.7	12.4	2,051.8	0.7	0.6	1	1	1
02/19/2020 23:00	0.7	12.5	2,046.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	2,043.8	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	1,941.5	0.7	0.6	1	1	1
Maximum:	0.7	13.0	2,212.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2020 00:00	0.7	12.7	2,026.1	0.7	0.6	1	1	1
02/20/2020 01:00	0.7	12.6	2,040.0	0.7	0.6	1	1	1
02/20/2020 02:00	0.7	12.6	2,042.7	0.7	0.6	1	1	1
02/20/2020 03:00	0.7	12.6	2,038.6	0.7	0.6	1	1	1
02/20/2020 04:00	0.7	12.5	2,037.9	0.7	0.6	1	1	1
02/20/2020 05:00	0.7	12.6	2,053.2	0.7	0.6	1	1	1
02/20/2020 06:00	0.7	12.5	2,070.2	0.7	0.6	1	1	1
02/20/2020 07:00	0.7	12.5	2,078.3	0.7	0.6	1	1	1
02/20/2020 08:00	0.7	12.6	2,044.8	0.7	0.6	1	1	1
02/20/2020 09:00	0.7	12.9	1,952.5	0.7	0.6	1	1	1
02/20/2020 10:00	0.7	13.0	1,949.9	0.7	0.6	1	1	1
02/20/2020 11:00	0.7	13.0	1,948.0	0.7	0.6	1	1	1
02/20/2020 12:00	0.7	12.9	1,949.6	0.7	0.6	1	1	1
02/20/2020 13:00	0.7	12.9	1,950.1	0.7	0.6	1	1	1
02/20/2020 14:00	0.7	12.8	1,963.6	0.7	0.6	1	1	1
02/20/2020 15:00	0.7	12.7	1,995.9	0.7	0.6	1	1	1
02/20/2020 16:00	0.7	12.4	2,076.7	0.7	0.6	1	1	1
02/20/2020 17:00	0.7	12.3	2,087.7	0.7	0.6	1	1	1
02/20/2020 18:00	0.7	12.3	2,089.7	0.7	0.6	1	1	1
02/20/2020 19:00	0.7	12.3	2,087.8	0.7	0.6	1	1	1
02/20/2020 20:00	0.7	12.2	2,088.0	0.7	0.6	1	1	1
02/20/2020 21:00	0.7	12.2	2,098.3	0.7	0.6	1	1	1
02/20/2020 22:00	0.7	12.2	2,086.1	0.7	0.6	1	1	1
02/20/2020 23:00	0.7	12.5	2,023.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	2,032.5	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.2	1,948.0	0.7	0.6	1	1	1
Maximum:	0.7	13.0	2,098.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2020 00:00	0.7	12.9	1,915.5	0.7	0.6	1	1	1
02/21/2020 01:00	0.6	13.7	1,540.2	0.6	0.5	1	1	0
02/21/2020 02:00	0.6	13.7	1,484.5	0.6	0.4	1	1	0
02/21/2020 03:00	0.6	13.7	1,567.0	0.6	0.5	1	1	0
02/21/2020 04:00	0.6	13.7	1,685.5	0.6	0.5	1	1	0
02/21/2020 05:00	0.6	13.7	1,590.9	0.6	0.5	1	1	0
02/21/2020 06:00	0.6	13.7	1,688.6	0.6	0.5	1	1	0
02/21/2020 07:00	0.6	13.7	1,649.8	0.6	0.5	1	1	0
02/21/2020 08:00	0.6	13.6	1,553.8	0.6	0.5	1	1	0
02/21/2020 09:00	0.6	13.6	1,684.7	0.6	0.5	1	1	0
02/21/2020 10:00	0.6	13.7	1,625.3	0.6	0.5	1	1	0
02/21/2020 11:00	0.6	13.7	1,608.2	0.6	0.5	1	1	0
02/21/2020 12:00	0.6	13.7	1,676.5	0.6	0.5	1	1	0
02/21/2020 13:00	0.6	13.6	1,677.0	0.6	0.5	1	1	0
02/21/2020 14:00	0.6	13.6	1,697.8	0.6	0.5	1	1	0
02/21/2020 15:00	0.6	13.6	1,686.6	0.6	0.5	1	1	0
02/21/2020 16:00	0.7	13.6	1,692.8	0.7	0.5	1	1	1
02/21/2020 17:00	0.7	12.6	1,986.0	0.7	0.6	1	1	1
02/21/2020 18:00	0.7	12.2	2,097.5	0.7	0.6	1	1	1
02/21/2020 19:00	0.7	12.3	2,077.5	0.7	0.6	1	1	1
02/21/2020 20:00	0.7	12.3	2,094.5	0.7	0.6	1	1	1
02/21/2020 21:00	0.7	12.4	2,066.2	0.7	0.6	1	1	1
02/21/2020 22:00	0.7	12.3	2,094.4	0.7	0.6	1	1	1
02/21/2020 23:00	0.0	13.9	1,282.6	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.3	1,738.5	0.6	0.5	24 #	23 #	9 #
Minimum:	0.0	12.2	1,282.6	0.0	0.4	1	0	0
Maximum:	0.7	13.9	2,097.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 13:00	0.0	17.3	476.5	0.0	0.1	1	0	0
02/24/2020 14:00	0.0	16.1	626.2	0.0	0.2	1	0	0
02/24/2020 15:00	0.0	15.0	880.3	0.0	0.3	1	0	0
02/24/2020 16:00	0.7	13.7	1,505.3	0.7	0.5	1	1	1
02/24/2020 17:00	0.7	12.5	2,085.8	0.7	0.6	1	1	1
02/24/2020 18:00	0.7	12.0	2,167.5	0.7	0.7	1	1	1
02/24/2020 19:00	0.7	12.1	2,161.0	0.7	0.6	1	1	1
02/24/2020 20:00	0.7	12.4	2,091.2	0.7	0.6	1	1	1
02/24/2020 21:00	0.7	12.4	2,087.4	0.7	0.6	1	1	1
02/24/2020 22:00	0.7	12.9	1,964.8	0.7	0.6	1	1	1
02/24/2020 23:00	0.7	12.6	2,023.8	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.5	1,642.7	0.5	0.5	11 #	8 #	8 #
Minimum:	0.0	12.0	476.5	0.0	0.1	0	0	0
Maximum:	0.7	17.3	2,167.5	0.7	0.7	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.6	13.7	1,562.5	0.6	0.5	1	1	0
02/25/2020 01:00	0.6	13.7	1,513.6	0.6	0.5	1	1	0
02/25/2020 02:00	0.6	13.7	1,365.0	0.6	0.4	1	1	0
02/25/2020 03:00	0.6	13.7	1,360.5	0.6	0.4	1	1	0
02/25/2020 04:00	0.7	13.7	1,473.4	0.7	0.4	1	1	1
02/25/2020 05:00	0.7	13.0	1,953.5	0.7	0.6	1	1	1
02/25/2020 06:00	0.7	12.9	1,968.3	0.7	0.6	1	1	1
02/25/2020 07:00	0.7	12.9	1,949.7	0.7	0.6	1	1	1
02/25/2020 08:00	0.6	13.7	1,389.1	0.6	0.4	1	1	0
02/25/2020 09:00	0.6	13.7	1,379.8	0.6	0.4	1	1	0
02/25/2020 10:00	0.6	13.7	1,380.4	0.6	0.4	1	1	0
02/25/2020 11:00	0.6	13.7	1,372.4	0.6	0.4	1	1	0
02/25/2020 12:00	0.6	13.7	1,376.1	0.6	0.4	1	1	0
02/25/2020 13:00	0.6	13.7	1,377.8	0.6	0.4	1	1	0
02/25/2020 14:00	0.6	13.7	1,644.3	0.6	0.5	1	1	0
02/25/2020 15:00	0.6	13.7	1,540.5	0.6	0.5	1	1	0
02/25/2020 16:00	0.6	13.7	1,634.0	0.6	0.5	1	1	0
02/25/2020 17:00	0.7	13.7	1,551.5	0.7	0.5	1	1	1
02/25/2020 18:00	0.7	12.7	1,987.1	0.7	0.6	1	1	1
02/25/2020 19:00	0.7	12.1	2,125.9	0.7	0.6	1	1	1
02/25/2020 20:00	0.7	12.0	2,156.8	0.7	0.6	1	1	1
02/25/2020 21:00	0.7	12.1	2,142.4	0.7	0.6	1	1	1
02/25/2020 22:00	0.7	12.1	2,135.7	0.7	0.6	1	1	1
02/25/2020 23:00	0.7	12.2	2,128.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,686.2	0.6	0.5	24 #	24 #	11 #
Minimum:	0.6	12.0	1,360.5	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,156.8	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2020 00:00	0.7	12.5	2,065.6	0.7	0.6	1	1	1
02/26/2020 01:00	0.7	12.5	2,047.7	0.7	0.6	1	1	1
02/26/2020 02:00	0.7	12.5	2,042.5	0.7	0.6	1	1	1
02/26/2020 03:00	0.7	12.5	2,036.1	0.7	0.6	1	1	1
02/26/2020 04:00	0.7	12.6	2,031.3	0.7	0.6	1	1	1
02/26/2020 05:00	0.7	12.6	2,026.1	0.7	0.6	1	1	1
02/26/2020 06:00	0.7	12.7	2,021.5	0.7	0.6	1	1	1
02/26/2020 07:00	0.7	12.7	2,012.8	0.7	0.6	1	1	1
02/26/2020 08:00	0.0	14.1	1,229.8	0.0	0.4	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 15:00	0.0	17.1	502.2	0.0	0.2	1	0	0
02/26/2020 16:00	0.0	14.1	1,308.9	0.0	0.4	1	0	1
02/26/2020 17:00	0.7	12.5	2,032.0	0.7	0.6	1	1	1
02/26/2020 18:00	0.7	12.4	2,042.2	0.7	0.6	1	1	1
02/26/2020 19:00	0.7	12.9	1,951.8	0.7	0.6	1	1	1
02/26/2020 20:00	0.7	12.3	2,087.3	0.7	0.6	1	1	1
02/26/2020 21:00	0.7	12.7	1,996.3	0.7	0.6	1	1	1
02/26/2020 22:00	0.7	12.9	1,959.3	0.7	0.6	1	1	1
02/26/2020 23:00	0.7	13.2	1,798.9	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.0	1,844.0	0.6	0.6	18 #	15 #	17 #
Minimum:	0.0	12.3	502.2	0.0	0.2	0	0	0
Maximum:	0.7	17.1	2,087.3	0.7	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.6	13.6	1,508.5	0.6	0.5	1	1	0
02/27/2020 01:00	0.6	13.7	1,473.8	0.6	0.4	1	1	0
02/27/2020 02:00	0.6	13.7	1,575.0	0.6	0.5	1	1	0
02/27/2020 03:00	0.6	13.7	1,498.2	0.6	0.4	1	1	0
02/27/2020 04:00	0.6	13.6	1,761.8	0.6	0.5	1	1	0
02/27/2020 05:00	0.6	13.6	1,764.3	0.6	0.5	1	1	0
02/27/2020 06:00	0.6	13.6	1,759.8	0.6	0.5	1	1	0
02/27/2020 07:00	0.6	13.6	1,759.3	0.6	0.5	1	1	0
02/27/2020 08:00	0.6	13.6	1,761.7	0.6	0.5	1	1	0
02/27/2020 09:00	0.6	13.6	1,764.4	0.6	0.5	1	1	0
02/27/2020 10:00	0.6	13.6	1,763.8	0.6	0.5	1	1	0
02/27/2020 11:00	0.6	13.5	1,759.0	0.6	0.5	1	1	0
02/27/2020 12:00	0.6	13.6	1,741.7	0.6	0.5	1	1	0
02/27/2020 13:00	0.6	13.6	1,688.5	0.6	0.5	1	1	0
02/27/2020 14:00	0.6	13.6	1,677.6	0.6	0.5	1	1	0
02/27/2020 15:00	0.6	13.6	1,665.2	0.6	0.5	1	1	0
02/27/2020 16:00	0.7	13.1	1,836.3	0.7	0.6	1	1	1
02/27/2020 17:00	0.7	12.3	2,049.6	0.7	0.6	1	1	1
02/27/2020 18:00	0.7	12.4	2,050.0	0.7	0.6	1	1	1
02/27/2020 19:00	0.7	12.4	2,053.4	0.7	0.6	1	1	1
02/27/2020 20:00	0.7	12.3	2,087.5	0.7	0.6	1	1	1
02/27/2020 21:00	0.7	12.2	2,092.2	0.7	0.6	1	1	1
02/27/2020 22:00	0.7	12.2	2,096.2	0.7	0.6	1	1	1
02/27/2020 23:00	0.7	12.6	2,016.2	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.2	1,800.2	0.6	0.5	24 #	24 #	8 #
Minimum:	0.6	12.2	1,473.8	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,096.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2020 00:00	0.7	13.0	1,925.9	0.7	0.6	1	1	1
02/28/2020 01:00	0.6	13.7	1,591.0	0.6	0.5	1	1	0
02/28/2020 02:00	0.6	13.7	1,500.7	0.6	0.5	1	1	0
02/28/2020 03:00	0.6	13.7	1,520.9	0.6	0.5	1	1	0
02/28/2020 04:00	0.6	13.7	1,513.5	0.6	0.5	1	1	0
02/28/2020 05:00	0.6	13.6	1,652.7	0.6	0.5	1	1	0
02/28/2020 06:00	0.6	13.6	1,694.8	0.6	0.5	1	1	0
02/28/2020 07:00	0.6	13.6	1,653.6	0.6	0.5	1	1	0
02/28/2020 08:00	0.6	13.6	1,552.3	0.6	0.5	1	1	0
02/28/2020 09:00	0.6	13.7	1,533.3	0.6	0.5	1	1	0
02/28/2020 10:00	0.6	13.7	1,476.4	0.6	0.4	1	1	0
02/28/2020 11:00	0.6	13.7	1,513.9	0.6	0.5	1	1	0
02/28/2020 12:00	0.6	13.7	1,574.7	0.6	0.5	1	1	0
02/28/2020 13:00	0.6	13.7	1,609.1	0.6	0.5	1	1	0
02/28/2020 14:00	0.6	13.7	1,452.9	0.6	0.4	1	1	0
02/28/2020 15:00	0.7	13.6	1,563.8	0.7	0.5	1	1	1
02/28/2020 16:00	0.7	12.5	2,014.8	0.7	0.6	1	1	1
02/28/2020 17:00	0.7	12.3	2,048.7	0.7	0.6	1	1	1
02/28/2020 18:00	0.7	12.4	2,034.8	0.7	0.6	1	1	1
02/28/2020 19:00	0.7	12.3	2,043.5	0.7	0.6	1	1	1
02/28/2020 20:00	0.7	12.5	2,026.5	0.7	0.6	1	1	1
02/28/2020 21:00	0.7	12.3	2,054.5	0.7	0.6	1	1	1
02/28/2020 22:00	0.7	12.4	2,031.8	0.7	0.6	1	1	1
02/28/2020 23:00	0.0	14.0	1,248.2	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.3	1,701.3	0.6	0.5	24 #	23 #	10 #
Minimum:	0.0	12.3	1,248.2	0.0	0.4	1	0	0
Maximum:	0.7	14.0	2,054.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 08:00	0.0	18.7	286.2	0.0	0.1	1	0	0
03/03/2020 09:00	0.0	16.9	526.7	0.0	0.2	1	0	0
03/03/2020 10:00	0.0	16.6	572.6	0.0	0.2	1	0	0
03/03/2020 11:00	0.0	15.5	722.2	0.0	0.2	1	0	0
03/03/2020 12:00	0.0	14.4	1,140.8	0.0	0.3	1	0	0
03/03/2020 13:00	0.6	13.8	1,396.8	0.6	0.4	1	1	0
03/03/2020 14:00	0.6	13.8	1,393.5	0.6	0.4	1	1	0
03/03/2020 15:00	0.6	13.8	1,559.0	0.6	0.5	1	1	0
03/03/2020 16:00	0.6	13.8	1,569.6	0.6	0.5	1	1	0
03/03/2020 17:00	0.7	13.7	1,601.7	0.7	0.5	1	1	1
03/03/2020 18:00	0.7	12.2	2,098.3	0.7	0.6	1	1	1
03/03/2020 19:00	0.7	11.9	2,162.7	0.7	0.6	1	1	1
03/03/2020 20:00	0.7	11.9	2,156.3	0.7	0.6	1	1	1
03/03/2020 21:00	0.7	11.9	2,156.0	0.7	0.6	1	1	1
03/03/2020 22:00	0.7	12.0	2,129.3	0.7	0.6	1	1	1
03/03/2020 23:00	0.7	12.2	2,104.5	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.9	1,473.5	0.5	0.4	16 #	11 #	7 #
Minimum:	0.0	11.9	286.2	0.0	0.1	0	0	0
Maximum:	0.7	18.7	2,162.7	0.7	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2020 00:00	0.7	12.5	2,059.3	0.7	0.6	1	1	1
03/04/2020 01:00	0.7	12.5	2,049.8	0.7	0.6	1	1	1
03/04/2020 02:00	0.7	12.7	2,001.7	0.7	0.6	1	1	1
03/04/2020 03:00	0.7	12.7	1,997.8	0.7	0.6	1	1	1
03/04/2020 04:00	0.7	12.5	2,046.9	0.7	0.6	1	1	1
03/04/2020 05:00	0.7	12.6	2,044.4	0.7	0.6	1	1	1
03/04/2020 06:00	0.7	12.5	2,043.1	0.7	0.6	1	1	1
03/04/2020 07:00	0.7	12.5	2,029.1	0.7	0.6	1	1	1
03/04/2020 08:00	0.7	13.6	1,508.5	0.7	0.5	1	1	1
03/04/2020 09:00	0.6	13.7	1,379.5	0.6	0.4	1	1	0
03/04/2020 10:00	0.6	13.7	1,382.6	0.6	0.4	1	1	0
03/04/2020 11:00	0.6	13.7	1,580.0	0.6	0.5	1	1	0
03/04/2020 12:00	0.6	13.7	1,708.4	0.6	0.5	1	1	0
03/04/2020 13:00	0.6	13.7	1,539.6	0.6	0.5	1	1	0
03/04/2020 14:00	0.6	13.7	1,636.6	0.6	0.5	1	1	0
03/04/2020 15:00	0.6	13.7	1,609.1	0.6	0.5	1	1	0
03/04/2020 16:00	0.7	13.7	1,553.5	0.7	0.5	1	1	1
03/04/2020 17:00	0.7	12.5	2,030.1	0.7	0.6	1	1	1
03/04/2020 18:00	0.7	12.3	2,054.6	0.7	0.6	1	1	1
03/04/2020 19:00	0.7	12.4	2,050.6	0.7	0.6	1	1	1
03/04/2020 20:00	0.7	12.1	2,113.0	0.7	0.6	1	1	1
03/04/2020 21:00	0.7	12.1	2,121.5	0.7	0.6	1	1	1
03/04/2020 22:00	0.7	12.1	2,109.1	0.7	0.6	1	1	1
03/04/2020 23:00	0.7	12.4	2,060.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,862.9	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.1	1,379.5	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,121.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2020 00:00	0.7	12.7	2,008.7	0.7	0.6	1	1	1
03/05/2020 01:00	0.7	12.7	1,998.5	0.7	0.6	1	1	1
03/05/2020 02:00	0.7	12.7	1,990.0	0.7	0.6	1	1	1
03/05/2020 03:00	0.7	12.7	1,989.3	0.7	0.6	1	1	1
03/05/2020 04:00	0.7	12.4	2,055.6	0.7	0.6	1	1	1
03/05/2020 05:00	0.7	12.4	2,052.3	0.7	0.6	1	1	1
03/05/2020 06:00	0.7	12.6	2,042.3	0.7	0.6	1	1	1
03/05/2020 07:00	0.7	12.7	1,984.6	0.7	0.6	1	1	1
03/05/2020 08:00	0.6	13.6	1,636.4	0.6	0.5	1	1	0
03/05/2020 09:00	0.6	13.6	1,704.5	0.6	0.5	1	1	0
03/05/2020 10:00	0.6	13.7	1,705.5	0.6	0.5	1	1	0
03/05/2020 11:00	0.6	13.6	1,688.6	0.6	0.5	1	1	0
03/05/2020 12:00	0.6	13.6	1,661.7	0.6	0.5	1	1	0
03/05/2020 13:00	0.6	13.6	1,698.8	0.6	0.5	1	1	0
03/05/2020 14:00	0.6	13.6	1,594.6	0.6	0.5	1	1	0
03/05/2020 15:00	0.6	13.6	1,528.7	0.6	0.5	1	1	0
03/05/2020 16:00	0.7	13.6	1,488.9	0.7	0.4	1	1	1
03/05/2020 17:00	0.7	12.5	1,990.0	0.7	0.6	1	1	1
03/05/2020 18:00	0.7	12.2	2,066.1	0.7	0.6	1	1	1
03/05/2020 19:00	0.7	12.3	2,059.4	0.7	0.6	1	1	1
03/05/2020 20:00	0.7	12.3	2,053.9	0.7	0.6	1	1	1
03/05/2020 21:00	0.7	12.3	2,075.9	0.7	0.6	1	1	1
03/05/2020 22:00	0.7	12.3	2,076.5	0.7	0.6	1	1	1
03/05/2020 23:00	0.7	12.6	1,993.9	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,881.0	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	12.2	1,488.9	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,076.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2020 00:00	0.7	12.4	2,055.1	0.7	0.6	1	1	1
03/06/2020 01:00	0.7	12.4	2,057.8	0.7	0.6	1	1	1
03/06/2020 02:00	0.7	12.6	1,994.5	0.7	0.6	1	1	1
03/06/2020 03:00	0.7	12.5	2,024.2	0.7	0.6	1	1	1
03/06/2020 04:00	0.7	12.5	2,038.8	0.7	0.6	1	1	1
03/06/2020 05:00	0.7	12.4	2,056.5	0.7	0.6	1	1	1
03/06/2020 06:00	0.7	12.5	2,044.7	0.7	0.6	1	1	1
03/06/2020 07:00	0.7	12.5	2,029.0	0.7	0.6	1	1	1
03/06/2020 08:00	0.7	12.8	1,952.1	0.7	0.6	1	1	1
03/06/2020 09:00	0.6	13.6	1,636.3	0.6	0.5	1	1	0
03/06/2020 10:00	0.6	13.6	1,682.9	0.6	0.5	1	1	0
03/06/2020 11:00	0.6	13.6	1,700.5	0.6	0.5	1	1	0
03/06/2020 12:00	0.6	13.6	1,673.0	0.6	0.5	1	1	0
03/06/2020 13:00	0.6	13.6	1,694.7	0.6	0.5	1	1	0
03/06/2020 14:00	0.6	13.6	1,657.8	0.6	0.5	1	1	0
03/06/2020 15:00	0.6	13.6	1,641.2	0.6	0.5	1	1	0
03/06/2020 16:00	0.7	13.6	1,529.2	0.7	0.5	1	1	1
03/06/2020 17:00	0.7	12.5	2,007.7	0.7	0.6	1	1	1
03/06/2020 18:00	0.7	12.3	2,044.3	0.7	0.6	1	1	1
03/06/2020 19:00	0.7	12.3	2,050.9	0.7	0.6	1	1	1
03/06/2020 20:00	0.7	12.1	2,099.4	0.7	0.6	1	1	1
03/06/2020 21:00	0.7	12.0	2,120.6	0.7	0.6	1	1	1
03/06/2020 22:00	0.7	12.2	2,086.0	0.7	0.6	1	1	1
03/06/2020 23:00	0.7	12.3	2,054.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,913.8	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.0	1,529.2	0.6	0.5	1	1	0
Maximum:	0.7	13.6	2,120.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2020 00:00	0.0	14.1	1,220.5	0.0	0.4	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	14.1	1,220.5	0.0	0.4	1 #	0 #	1 #
Minimum:	0.0	14.1	1,220.5	0.0	0.4	0	0	0
Maximum:	0.0	14.1	1,220.5	0.0	0.4	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 20:00	0.0	17.3	468.7	0.0	0.1	1	0	0
03/08/2020 21:00	0.0	16.9	529.5	0.0	0.2	1	0	0
03/08/2020 22:00	0.0	14.5	1,159.1	0.0	0.3	1	0	0
03/08/2020 23:00	0.6	13.6	1,549.1	0.6	0.5	1	1	0
Average/Sum#:	0.2	15.6	926.6	0.2	0.3	4 #	1 #	0 #
Minimum:	0.0	13.6	468.7	0.0	0.1	0	0	0
Maximum:	0.6	17.3	1,549.1	0.6	0.5	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/09/2020 00:00	0.6	13.6	1,545.8	0.6	0.5	1	1	0
03/09/2020 01:00	0.6	13.6	1,647.7	0.6	0.5	1	1	0
03/09/2020 02:00	0.6	13.6	1,608.2	0.6	0.5	1	1	0
03/09/2020 03:00	0.6	13.6	1,503.5	0.6	0.5	1	1	0
03/09/2020 04:00	0.7	13.6	1,591.5	0.7	0.5	1	1	1
03/09/2020 05:00	0.7	12.7	2,030.9	0.7	0.6	1	1	1
03/09/2020 06:00	0.7	12.2	2,153.8	0.7	0.6	1	1	1
03/09/2020 07:00	0.7	12.2	2,138.7	0.7	0.6	1	1	1
03/09/2020 08:00	0.7	12.2	2,127.0	0.7	0.6	1	1	1
03/09/2020 09:00	0.7	13.5	1,683.7	0.7	0.5	1	1	1
03/09/2020 10:00	0.6	13.6	1,601.6	0.6	0.5	1	1	0
03/09/2020 11:00	0.6	13.6	1,571.5	0.6	0.5	1	1	0
03/09/2020 12:00	0.6	13.6	1,697.9	0.6	0.5	1	1	0
03/09/2020 13:00	0.6	13.7	1,698.6	0.6	0.5	1	1	0
03/09/2020 14:00	0.6	13.7	1,698.9	0.6	0.5	1	1	0
03/09/2020 15:00	0.6	13.7	1,672.5	0.6	0.5	1	1	0
03/09/2020 16:00	0.7	13.6	1,688.6	0.7	0.5	1	1	1
03/09/2020 17:00	0.7	12.6	2,022.0	0.7	0.6	1	1	1
03/09/2020 18:00	0.7	12.0	2,157.7	0.7	0.6	1	1	1
03/09/2020 19:00	0.7	12.0	2,162.6	0.7	0.6	1	1	1
03/09/2020 20:00	0.7	12.1	2,130.8	0.7	0.6	1	1	1
03/09/2020 21:00	0.7	12.1	2,127.5	0.7	0.6	1	1	1
03/09/2020 22:00	0.7	12.1	2,127.2	0.7	0.6	1	1	1
03/09/2020 23:00	0.7	12.1	2,125.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,854.7	0.7	0.5	24 #	24 #	14 #
Minimum:	0.6	12.0	1,503.5	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,162.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/10/2020 00:00	0.7	12.1	2,126.8	0.7	0.6	1	1	1
03/10/2020 01:00	0.7	12.1	2,116.3	0.7	0.6	1	1	1
03/10/2020 02:00	0.7	12.2	2,105.4	0.7	0.6	1	1	1
03/10/2020 03:00	0.7	12.4	2,065.1	0.7	0.6	1	1	1
03/10/2020 04:00	0.7	12.4	2,068.2	0.7	0.6	1	1	1
03/10/2020 05:00	0.7	12.0	2,149.7	0.7	0.6	1	1	1
03/10/2020 06:00	0.7	11.8	2,202.0	0.7	0.7	1	1	1
03/10/2020 07:00	0.7	11.9	2,163.8	0.7	0.6	1	1	1
03/10/2020 08:00	0.7	12.0	2,153.5	0.7	0.6	1	1	1
03/10/2020 09:00	0.7	12.2	2,113.4	0.7	0.6	1	1	1
03/10/2020 10:00	0.7	12.3	2,090.0	0.7	0.6	1	1	1
03/10/2020 11:00	0.7	0.0	2,114.9	0.7	0.6	1	1	1
03/10/2020 12:00	0.7	12.2	2,129.0	0.7	0.6	1	1	1
03/10/2020 13:00	0.7	12.3	2,114.8	0.7	0.6	1	1	1
03/10/2020 14:00	0.7	12.2	2,124.9	0.7	0.6	1	1	1
03/10/2020 15:00	0.7	12.3	2,103.1	0.7	0.6	1	1	1
03/10/2020 16:00	0.7	12.3	2,105.2	0.7	0.6	1	1	1
03/10/2020 17:00	0.7	12.4	2,074.3	0.7	0.6	1	1	1
03/10/2020 18:00	0.7	12.1	2,156.5	0.7	0.6	1	1	1
03/10/2020 19:00	0.7	12.0	2,182.4	0.7	0.7	1	1	1
03/10/2020 20:00	0.7	12.0	2,182.0	0.7	0.7	1	1	1
03/10/2020 21:00	0.7	12.3	2,124.9	0.7	0.6	1	1	1
03/10/2020 22:00	0.7	12.4	2,121.6	0.7	0.6	1	1	1
03/10/2020 23:00	0.7	12.4	2,089.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.2	2,124.1	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.8	2,065.1	0.7	0.6	1	1	1
Maximum:	0.7	12.4	2,202.0	0.7	0.7	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2020 00:00	0.7	12.6	2,034.8	0.7	0.6	1	1	1
03/11/2020 01:00	0.7	12.7	2,026.3	0.7	0.6	1	1	1
03/11/2020 02:00	0.7	12.6	2,046.5	0.7	0.6	1	1	1
03/11/2020 03:00	0.7	12.6	2,046.6	0.7	0.6	1	1	1
03/11/2020 04:00	0.7	12.5	2,070.4	0.7	0.6	1	1	1
03/11/2020 05:00	0.7	12.4	2,121.6	0.7	0.6	1	1	1
03/11/2020 06:00	0.7	12.0	2,191.3	0.7	0.7	1	1	1
03/11/2020 07:00	0.7	12.3	2,124.5	0.7	0.6	1	1	1
03/11/2020 08:00	0.7	12.3	2,116.3	0.7	0.6	1	1	1
03/11/2020 09:00	0.7	13.6	1,719.1	0.7	0.5	1	1	1
03/11/2020 10:00	0.6	13.8	1,649.8	0.6	0.5	1	1	0
03/11/2020 11:00	0.6	13.8	1,562.1	0.6	0.5	1	1	0
03/11/2020 12:00	0.6	13.9	1,598.0	0.6	0.5	1	1	0
03/11/2020 13:00	0.6	13.9	1,687.2	0.6	0.5	1	1	0
03/11/2020 14:00	0.6	13.9	1,653.1	0.6	0.5	1	1	0
03/11/2020 15:00	0.6	13.9	1,560.0	0.6	0.5	1	1	0
03/11/2020 16:00	0.6	14.0	1,350.6	0.6	0.4	1	1	0
03/11/2020 17:00	0.6	13.9	1,645.4	0.6	0.5	1	1	0
03/11/2020 18:00	0.7	13.8	1,706.9	0.7	0.5	1	1	1
03/11/2020 19:00	0.7	12.7	2,029.1	0.7	0.6	1	1	1
03/11/2020 20:00	0.7	12.0	2,172.6	0.7	0.7	1	1	1
03/11/2020 21:00	0.7	12.2	2,125.6	0.7	0.6	1	1	1
03/11/2020 22:00	0.7	12.5	2,072.5	0.7	0.6	1	1	1
03/11/2020 23:00	0.7	12.3	2,115.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,892.7	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	12.0	1,350.6	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,191.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/12/2020 00:00	0.7	12.4	2,075.2	0.7	0.6	1	1	1
03/12/2020 01:00	0.7	12.6	2,044.0	0.7	0.6	1	1	1
03/12/2020 02:00	0.7	12.8	1,989.9	0.7	0.6	1	1	1
03/12/2020 03:00	0.7	12.6	2,038.8	0.7	0.6	1	1	1
03/12/2020 04:00	0.7	12.4	2,071.6	0.7	0.6	1	1	1
03/12/2020 05:00	0.7	12.4	2,081.3	0.7	0.6	1	1	1
03/12/2020 06:00	0.7	12.0	2,178.0	0.7	0.7	1	1	1
03/12/2020 07:00	0.7	12.0	2,168.8	0.7	0.7	1	1	1
03/12/2020 08:00	0.7	12.4	2,066.4	0.7	0.6	1	1	1
03/12/2020 09:00	0.6	13.8	1,667.7	0.6	0.5	1	1	0
03/12/2020 10:00	0.6	13.8	1,676.7	0.6	0.5	1	1	0
03/12/2020 11:00	0.6	13.9	1,663.4	0.6	0.5	1	1	0
03/12/2020 12:00	0.6	13.8	1,699.6	0.6	0.5	1	1	0
03/12/2020 13:00	0.6	13.9	1,587.1	0.6	0.5	1	1	0
03/12/2020 14:00	0.6	13.9	1,676.7	0.6	0.5	1	1	0
03/12/2020 15:00	0.7	13.3	1,825.9	0.7	0.5	1	1	1
03/12/2020 16:00	0.7	12.3	2,095.5	0.7	0.6	1	1	1
03/12/2020 17:00	0.7	12.0	2,146.7	0.7	0.6	1	1	1
03/12/2020 18:00	0.7	12.0	2,176.4	0.7	0.7	1	1	1
03/12/2020 19:00	0.7	11.9	2,182.9	0.7	0.7	1	1	1
03/12/2020 20:00	0.7	12.3	2,088.8	0.7	0.6	1	1	1
03/12/2020 21:00	0.7	12.1	2,115.5	0.7	0.6	1	1	1
03/12/2020 22:00	0.7	12.1	2,121.4	0.7	0.6	1	1	1
03/12/2020 23:00	0.7	12.1	2,116.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.7	1,981.5	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.9	1,587.1	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,182.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2020 00:00	0.7	12.1	2,104.1	0.7	0.6	1	1	1
03/13/2020 01:00	0.7	12.1	2,105.6	0.7	0.6	1	1	1
03/13/2020 02:00	0.7	12.2	2,104.7	0.7	0.6	1	1	1
03/13/2020 03:00	0.7	12.2	2,105.0	0.7	0.6	1	1	1
03/13/2020 04:00	0.7	12.4	2,068.0	0.7	0.6	1	1	1
03/13/2020 05:00	0.7	12.1	2,127.2	0.7	0.6	1	1	1
03/13/2020 06:00	0.7	12.2	2,112.9	0.7	0.6	1	1	1
03/13/2020 07:00	0.7	12.2	2,120.9	0.7	0.6	1	1	1
03/13/2020 08:00	0.7	12.1	2,167.3	0.7	0.7	1	1	1
03/13/2020 09:00	0.7	13.6	1,722.3	0.7	0.5	1	1	1
03/13/2020 10:00	0.6	13.9	1,601.6	0.6	0.5	1	1	0
03/13/2020 11:00	0.6	13.9	1,637.0	0.6	0.5	1	1	0
03/13/2020 12:00	0.6	13.9	1,682.0	0.6	0.5	1	1	0
03/13/2020 13:00	0.6	13.9	1,634.8	0.6	0.5	1	1	0
03/13/2020 14:00	0.6	13.8	1,673.9	0.6	0.5	1	1	0
03/13/2020 15:00	0.6	13.9	1,678.5	0.6	0.5	1	1	0
03/13/2020 16:00	0.6	13.9	1,693.4	0.6	0.5	1	1	0
03/13/2020 17:00	0.7	13.3	1,816.5	0.7	0.5	1	1	1
03/13/2020 18:00	0.7	12.5	2,053.3	0.7	0.6	1	1	1
03/13/2020 19:00	0.7	12.0	2,170.0	0.7	0.7	1	1	1
03/13/2020 20:00	0.7	11.9	2,189.1	0.7	0.7	1	1	1
03/13/2020 21:00	0.7	12.2	2,137.0	0.7	0.6	1	1	1
03/13/2020 22:00	0.7	12.4	2,102.5	0.7	0.6	1	1	1
03/13/2020 23:00	0.7	12.5	2,059.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,952.8	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	11.9	1,601.6	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,189.1	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/14/2020 00:00	0.7	12.3	2,114.7	0.7	0.6	1	1	1
03/14/2020 01:00	0.7	12.3	2,117.8	0.7	0.6	1	1	1
03/14/2020 02:00	0.7	12.3	2,113.1	0.7	0.6	1	1	1
03/14/2020 03:00	0.7	12.3	2,110.9	0.7	0.6	1	1	1
03/14/2020 04:00	0.7	12.6	2,046.9	0.7	0.6	1	1	1
03/14/2020 05:00	0.7	12.5	2,087.0	0.7	0.6	1	1	1
03/14/2020 06:00	0.7	12.4	2,121.3	0.7	0.6	1	1	1
03/14/2020 07:00	0.7	12.4	2,077.3	0.7	0.6	1	1	1
03/14/2020 08:00	0.6	13.9	1,760.8	0.6	0.5	1	1	0
03/14/2020 09:00	0.6	13.9	1,750.9	0.6	0.5	1	1	0
03/14/2020 10:00	0.6	13.9	1,745.9	0.6	0.5	1	1	0
03/14/2020 11:00	0.6	13.9	1,747.5	0.6	0.5	1	1	0
03/14/2020 12:00	0.6	13.9	1,748.0	0.6	0.5	1	1	0
03/14/2020 13:00	0.6	13.9	1,747.5	0.6	0.5	1	1	0
03/14/2020 14:00	0.6	13.9	1,749.9	0.6	0.5	1	1	0
03/14/2020 15:00	0.6	13.9	1,750.6	0.6	0.5	1	1	0
03/14/2020 16:00	0.6	13.9	1,755.6	0.6	0.5	1	1	0
03/14/2020 17:00	0.7	13.4	1,837.9	0.7	0.6	1	1	1
03/14/2020 18:00	0.7	12.4	2,114.7	0.7	0.6	1	1	1
03/14/2020 19:00	0.7	12.1	2,185.9	0.7	0.7	1	1	1
03/14/2020 20:00	0.7	12.2	2,153.3	0.7	0.6	1	1	1
03/14/2020 21:00	0.7	12.4	2,110.3	0.7	0.6	1	1	1
03/14/2020 22:00	0.7	12.7	2,048.7	0.7	0.6	1	1	1
03/14/2020 23:00	0.7	12.7	2,040.0	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,959.9	0.7	0.6	24 #	24 #	15 #
Minimum:	0.6	12.1	1,745.9	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,185.9	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2020 00:00	0.7	12.6	2,080.7	0.7	0.6	1	1	1
03/15/2020 01:00	0.7	12.7	2,047.4	0.7	0.6	1	1	1
03/15/2020 02:00	0.7	12.7	2,037.8	0.7	0.6	1	1	1
03/15/2020 03:00	0.7	12.7	2,037.4	0.7	0.6	1	1	1
03/15/2020 04:00	0.7	12.7	2,047.4	0.7	0.6	1	1	1
03/15/2020 05:00	0.7	12.7	2,044.8	0.7	0.6	1	1	1
03/15/2020 06:00	0.7	12.7	2,062.7	0.7	0.6	1	1	1
03/15/2020 07:00	0.7	12.6	2,061.9	0.7	0.6	1	1	1
03/15/2020 08:00	0.7	12.7	2,017.9	0.7	0.6	1	1	1
03/15/2020 09:00	0.6	13.8	1,752.8	0.6	0.5	1	1	0
03/15/2020 10:00	0.6	13.8	1,758.3	0.6	0.5	1	1	0
03/15/2020 11:00	0.6	13.8	1,746.1	0.6	0.5	1	1	0
03/15/2020 12:00	0.6	13.8	1,747.4	0.6	0.5	1	1	0
03/15/2020 13:00	0.6	13.9	1,751.7	0.6	0.5	1	1	0
03/15/2020 14:00	0.6	13.9	1,592.7	0.6	0.5	1	1	0
03/15/2020 15:00	0.6	13.9	1,522.6	0.6	0.5	1	1	0
03/15/2020 16:00	0.6	13.9	1,520.6	0.6	0.5	1	1	0
03/15/2020 17:00	0.7	13.4	1,831.2	0.7	0.5	1	1	1
03/15/2020 18:00	0.7	12.1	2,184.0	0.7	0.7	1	1	1
03/15/2020 19:00	0.7	11.9	2,221.3	0.7	0.7	1	1	1
03/15/2020 20:00	0.7	12.0	2,211.2	0.7	0.7	1	1	1
03/15/2020 21:00	0.7	12.1	2,199.6	0.7	0.7	1	1	1
03/15/2020 22:00	0.7	12.5	2,105.6	0.7	0.6	1	1	1
03/15/2020 23:00	0.7	12.5	2,108.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,945.5	0.7	0.6	24 #	24 #	16 #
Minimum:	0.6	11.9	1,520.6	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,221.3	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2020 00:00	0.7	12.4	2,114.4	0.7	0.6	1	1	1
03/16/2020 01:00	0.7	12.5	2,101.3	0.7	0.6	1	1	1
03/16/2020 02:00	0.7	12.4	2,115.6	0.7	0.6	1	1	1
03/16/2020 03:00	0.7	12.5	2,112.4	0.7	0.6	1	1	1
03/16/2020 04:00	0.7	12.3	2,164.5	0.7	0.6	1	1	1
03/16/2020 05:00	0.7	12.2	2,182.4	0.7	0.7	1	1	1
03/16/2020 06:00	0.7	12.0	2,221.5	0.7	0.7	1	1	1
03/16/2020 07:00	0.7	12.4	2,129.1	0.7	0.6	1	1	1
03/16/2020 08:00	0.7	12.4	2,122.0	0.7	0.6	1	1	1
03/16/2020 09:00	0.7	12.4	2,110.6	0.7	0.6	1	1	1
03/16/2020 10:00	0.7	12.4	2,110.4	0.7	0.6	1	1	1
03/16/2020 11:00	0.7	12.4	2,121.0	0.7	0.6	1	1	1
03/16/2020 12:00	0.7	12.4	2,106.5	0.7	0.6	1	1	1
03/16/2020 13:00	0.7	12.5	2,081.9	0.7	0.6	1	1	1
03/16/2020 14:00	0.7	12.6	2,066.6	0.7	0.6	1	1	1
03/16/2020 15:00	0.7	12.7	2,038.7	0.7	0.6	1	1	1
03/16/2020 16:00	0.7	12.7	2,041.4	0.7	0.6	1	1	1
03/16/2020 17:00	0.7	12.6	2,052.2	0.7	0.6	1	1	1
03/16/2020 18:00	0.7	12.0	2,198.0	0.7	0.7	1	1	1
03/16/2020 19:00	0.7	12.0	2,204.5	0.7	0.7	1	1	1
03/16/2020 20:00	0.7	12.2	2,161.9	0.7	0.6	1	1	1
03/16/2020 21:00	0.7	12.1	2,168.2	0.7	0.7	1	1	1
03/16/2020 22:00	0.7	12.4	2,118.9	0.7	0.6	1	1	1
03/16/2020 23:00	0.7	12.4	2,115.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,123.3	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	12.0	2,038.7	0.7	0.6	1	1	1
Maximum:	0.7	12.7	2,221.5	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2020 00:00	0.7	12.5	2,100.7	0.7	0.6	1	1	1
03/17/2020 01:00	0.7	12.5	2,090.2	0.7	0.6	1	1	1
03/17/2020 02:00	0.7	12.8	2,036.4	0.7	0.6	1	1	1
03/17/2020 03:00	0.7	12.7	2,062.1	0.7	0.6	1	1	1
03/17/2020 04:00	0.7	12.8	2,034.1	0.7	0.6	1	1	1
03/17/2020 05:00	0.7	12.5	2,113.7	0.7	0.6	1	1	1
03/17/2020 06:00	0.7	12.3	2,157.3	0.7	0.6	1	1	1
03/17/2020 07:00	0.7	12.8	2,037.5	0.7	0.6	1	1	1
03/17/2020 08:00	0.7	13.2	1,928.1	0.7	0.6	1	1	1
03/17/2020 09:00	0.6	13.8	1,757.0	0.6	0.5	1	1	0
03/17/2020 10:00	0.6	13.8	1,758.6	0.6	0.5	1	1	0
03/17/2020 11:00	0.6	13.8	1,761.8	0.6	0.5	1	1	0
03/17/2020 12:00	0.6	13.8	1,763.8	0.6	0.5	1	1	0
03/17/2020 13:00	0.6	13.8	1,760.2	0.6	0.5	1	1	0
03/17/2020 14:00	0.6	13.8	1,759.6	0.6	0.5	1	1	0
03/17/2020 15:00	0.6	13.8	1,758.8	0.6	0.5	1	1	0
03/17/2020 16:00	0.7	13.8	1,760.9	0.7	0.5	1	1	1
03/17/2020 17:00	0.7	12.8	2,023.9	0.7	0.6	1	1	1
03/17/2020 18:00	0.7	12.4	2,115.6	0.7	0.6	1	1	1
03/17/2020 19:00	0.7	12.3	2,125.0	0.7	0.6	1	1	1
03/17/2020 20:00	0.7	12.6	2,070.6	0.7	0.6	1	1	1
03/17/2020 21:00	0.7	12.6	2,073.7	0.7	0.6	1	1	1
03/17/2020 22:00	0.7	12.5	2,073.6	0.7	0.6	1	1	1
03/17/2020 23:00	0.7	12.7	2,040.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.0	1,965.1	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.3	1,757.0	0.6	0.5	1	1	0
Maximum:	0.7	13.8	2,157.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2020 00:00	0.7	12.7	2,032.6	0.7	0.6	1	1	1
03/18/2020 01:00	0.7	12.8	2,029.6	0.7	0.6	1	1	1
03/18/2020 02:00	0.7	12.8	2,030.8	0.7	0.6	1	1	1
03/18/2020 03:00	0.7	12.7	2,041.1	0.7	0.6	1	1	1
03/18/2020 04:00	0.7	12.8	2,031.3	0.7	0.6	1	1	1
03/18/2020 05:00	0.7	12.8	2,006.4	0.7	0.6	1	1	1
03/18/2020 06:00	0.7	12.4	2,091.5	0.7	0.6	1	1	1
03/18/2020 07:00	0.7	12.5	2,067.0	0.7	0.6	1	1	1
03/18/2020 08:00	0.7	12.7	2,010.8	0.7	0.6	1	1	1
03/18/2020 09:00	0.6	13.8	1,654.6	0.6	0.5	1	1	0
03/18/2020 10:00	0.6	13.8	1,630.1	0.6	0.5	1	1	0
03/18/2020 11:00	0.6	13.8	1,615.1	0.6	0.5	1	1	0
03/18/2020 12:00	0.6	13.8	1,640.0	0.6	0.5	1	1	0
03/18/2020 13:00	0.6	13.8	1,616.6	0.6	0.5	1	1	0
03/18/2020 14:00	0.6	13.8	1,650.2	0.6	0.5	1	1	0
03/18/2020 15:00	0.6	13.8	1,632.9	0.6	0.5	1	1	0
03/18/2020 16:00	0.6	13.8	1,681.8	0.6	0.5	1	1	0
03/18/2020 17:00	0.6	13.8	1,563.7	0.6	0.5	1	1	0
03/18/2020 18:00	0.7	12.9	1,992.5	0.7	0.6	1	1	1
03/18/2020 19:00	0.7	12.8	2,022.6	0.7	0.6	1	1	1
03/18/2020 20:00	0.7	12.6	2,066.1	0.7	0.6	1	1	1
03/18/2020 21:00	0.7	12.7	2,051.9	0.7	0.6	1	1	1
03/18/2020 22:00	0.7	12.7	2,053.4	0.7	0.6	1	1	1
03/18/2020 23:00	0.7	12.8	2,015.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,884.5	0.7	0.6	24 #	24 #	15 #
Minimum:	0.6	12.4	1,563.7	0.6	0.5	1	1	0
Maximum:	0.7	13.8	2,091.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/19/2020 00:00	0.7	13.2	1,941.1	0.7	0.6	1	1	1
03/19/2020 01:00	0.7	13.2	1,941.8	0.7	0.6	1	1	1
03/19/2020 02:00	0.7	13.2	1,948.4	0.7	0.6	1	1	1
03/19/2020 03:00	0.7	13.2	1,948.8	0.7	0.6	1	1	1
03/19/2020 04:00	0.7	13.1	1,980.5	0.7	0.6	1	1	1
03/19/2020 05:00	0.7	13.0	1,989.0	0.7	0.6	1	1	1
03/19/2020 06:00	0.7	12.6	2,103.3	0.7	0.6	1	1	1
03/19/2020 07:00	0.7	12.6	2,100.4	0.7	0.6	1	1	1
03/19/2020 08:00	0.7	12.9	1,998.8	0.7	0.6	1	1	1
03/19/2020 09:00	0.6	13.8	1,554.5	0.6	0.5	1	1	0
03/19/2020 10:00	0.6	13.8	1,593.5	0.6	0.5	1	1	0
03/19/2020 11:00	0.6	13.9	1,473.0	0.6	0.4	1	1	0
03/19/2020 12:00	0.6	13.9	1,531.7	0.6	0.5	1	1	0
03/19/2020 13:00	0.6	13.9	1,374.0	0.6	0.4	1	1	0
03/19/2020 14:00	0.6	13.9	1,299.8	0.6	0.4	1	1	0
03/19/2020 15:00	0.6	13.9	1,566.5	0.6	0.5	1	1	0
03/19/2020 16:00	0.7	13.9	1,539.2	0.7	0.5	1	1	1
03/19/2020 17:00	0.7	12.7	2,018.0	0.7	0.6	1	1	1
03/19/2020 18:00	0.7	12.5	2,063.4	0.7	0.6	1	1	1
03/19/2020 19:00	0.7	12.3	2,109.3	0.7	0.6	1	1	1
03/19/2020 20:00	0.7	12.4	2,112.9	0.7	0.6	1	1	1
03/19/2020 21:00	0.7	12.4	2,093.9	0.7	0.6	1	1	1
03/19/2020 22:00	0.7	12.6	2,081.3	0.7	0.6	1	1	1
03/19/2020 23:00	0.7	12.8	2,035.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.2	1,850.0	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.3	1,299.8	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,112.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2020 00:00	0.7	12.9	2,031.3	0.7	0.6	1	1	1
03/20/2020 01:00	0.7	12.9	2,032.7	0.7	0.6	1	1	1
03/20/2020 02:00	0.7	12.8	2,030.9	0.7	0.6	1	1	1
03/20/2020 03:00	0.7	12.9	2,029.7	0.7	0.6	1	1	1
03/20/2020 04:00	0.7	12.9	2,029.8	0.7	0.6	1	1	1
03/20/2020 05:00	0.7	13.1	1,983.2	0.7	0.6	1	1	1
03/20/2020 06:00	0.7	12.9	2,049.1	0.7	0.6	1	1	1
03/20/2020 07:00	0.7	13.2	1,928.7	0.7	0.6	1	1	1
03/20/2020 08:00	0.6	13.8	1,617.2	0.6	0.5	1	1	0
03/20/2020 09:00	0.6	13.9	1,381.3	0.6	0.4	1	1	0
03/20/2020 10:00	0.6	13.8	1,659.9	0.6	0.5	1	1	0
03/20/2020 11:00	0.6	13.9	1,557.8	0.6	0.5	1	1	0
03/20/2020 12:00	0.6	13.9	1,527.2	0.6	0.5	1	1	0
03/20/2020 13:00	0.6	13.9	1,644.7	0.6	0.5	1	1	0
03/20/2020 14:00	0.6	13.9	1,531.9	0.6	0.5	1	1	0
03/20/2020 15:00	0.7	13.9	1,581.6	0.7	0.5	1	1	1
03/20/2020 16:00	0.7	12.8	2,006.0	0.7	0.6	1	1	1
03/20/2020 17:00	0.7	12.6	2,042.3	0.7	0.6	1	1	1
03/20/2020 18:00	0.7	12.6	2,042.8	0.7	0.6	1	1	1
03/20/2020 19:00	0.7	12.6	2,055.5	0.7	0.6	1	1	1
03/20/2020 20:00	0.7	12.5	2,078.7	0.7	0.6	1	1	1
03/20/2020 21:00	0.7	12.4	2,094.3	0.7	0.6	1	1	1
03/20/2020 22:00	0.7	12.5	2,073.4	0.7	0.6	1	1	1
03/20/2020 23:00	0.7	12.7	2,037.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,877.0	0.7	0.6	24 #	24 #	17 #
Minimum:	0.6	12.4	1,381.3	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,094.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2020 00:00	0.7	12.7	2,070.8	0.7	0.6	1	1	1
03/21/2020 01:00	0.7	12.6	2,091.2	0.7	0.6	1	1	1
03/21/2020 02:00	0.7	12.5	2,085.7	0.7	0.6	1	1	1
03/21/2020 03:00	0.7	12.5	2,094.3	0.7	0.6	1	1	1
03/21/2020 04:00	0.7	12.6	2,064.0	0.7	0.6	1	1	1
03/21/2020 05:00	0.7	12.6	2,055.9	0.7	0.6	1	1	1
03/21/2020 06:00	0.7	13.1	2,002.1	0.7	0.6	1	1	1
03/21/2020 07:00	0.0	14.5	1,201.0	0.0	0.4	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	12.9	1,958.1	0.6	0.6	8 #	7 #	8 #
Minimum:	0.0	12.5	1,201.0	0.0	0.4	0	0	0
Maximum:	0.7	14.5	2,094.3	0.7	0.6	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 17:00	0.0	17.6	464.8	0.0	0.1	1	0	0
03/22/2020 18:00	0.0	17.1	521.9	0.0	0.2	1	0	0
03/22/2020 19:00	0.0	15.5	920.8	0.0	0.3	1	0	0
03/22/2020 20:00	0.6	13.9	1,478.7	0.6	0.4	1	1	0
03/22/2020 21:00	0.6	13.9	1,416.5	0.6	0.4	1	1	0
03/22/2020 22:00	0.6	13.9	1,439.7	0.6	0.4	1	1	0
03/22/2020 23:00	0.6	13.9	1,477.7	0.6	0.4	1	1	0
Average/Sum#:	0.3	15.1	1,102.9	0.3	0.3	7 #	4 #	0 #
Minimum:	0.0	13.9	464.8	0.0	0.1	0	0	0
Maximum:	0.6	17.6	1,478.7	0.6	0.4	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.6	13.9	1,367.8	0.6	0.4	1	1	0
03/23/2020 01:00	0.6	13.9	1,351.3	0.6	0.4	1	1	0
03/23/2020 02:00	0.0	16.6	343.8	0.0	0.1	1	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 17:00	0.0	17.6	462.2	0.0	0.1	1	0	0
03/23/2020 18:00	0.0	17.1	521.7	0.0	0.2	1	0	0
03/23/2020 19:00	0.0	15.6	864.1	0.0	0.3	1	0	0
03/23/2020 20:00	0.6	13.9	1,551.4	0.6	0.5	1	1	0
03/23/2020 21:00	0.6	13.9	1,538.5	0.6	0.5	1	1	0
03/23/2020 22:00	0.6	13.9	1,547.8	0.6	0.5	1	1	0
03/23/2020 23:00	0.6	13.8	1,648.1	0.6	0.5	1	1	0
Average/Sum#:	0.4	15.0	1,119.7	0.4	0.4	10 #	6 #	0 #
Minimum:	0.0	13.8	343.8	0.0	0.1	0	0	0
Maximum:	0.6	17.6	1,648.1	0.6	0.5	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/24/2020 00:00	0.6	13.9	1,432.3	0.6	0.4	1	1	0
03/24/2020 01:00	0.6	13.9	1,379.4	0.6	0.4	1	1	0
03/24/2020 02:00	0.6	13.8	1,580.7	0.6	0.5	1	1	0
03/24/2020 03:00	0.6	13.8	1,524.7	0.6	0.5	1	1	0
03/24/2020 04:00	0.6	13.8	1,725.2	0.6	0.5	1	1	0
03/24/2020 05:00	0.6	13.8	1,700.6	0.6	0.5	1	1	0
03/24/2020 06:00	0.6	13.8	1,686.9	0.6	0.5	1	1	0
03/24/2020 07:00	0.6	13.8	1,701.5	0.6	0.5	1	1	0
03/24/2020 08:00	0.6	13.8	1,575.3	0.6	0.5	1	1	0
03/24/2020 09:00	0.6	13.8	1,681.6	0.6	0.5	1	1	0
03/24/2020 10:00	0.6	13.8	1,701.8	0.6	0.5	1	1	0
03/24/2020 11:00	0.6	13.8	1,614.3	0.6	0.5	1	1	0
03/24/2020 12:00	0.6	13.8	1,648.1	0.6	0.5	1	1	0
03/24/2020 13:00	0.6	13.9	1,548.1	0.6	0.5	1	1	0
03/24/2020 14:00	0.6	13.9	1,570.7	0.6	0.5	1	1	0
03/24/2020 15:00	0.6	13.9	1,586.9	0.6	0.5	1	1	0
03/24/2020 16:00	0.7	13.9	1,604.7	0.7	0.5	1	1	1
03/24/2020 17:00	0.7	12.7	2,020.6	0.7	0.6	1	1	1
03/24/2020 18:00	0.7	12.9	1,996.4	0.7	0.6	1	1	1
03/24/2020 19:00	0.7	12.8	2,019.1	0.7	0.6	1	1	1
03/24/2020 20:00	0.7	12.4	2,110.1	0.7	0.6	1	1	1
03/24/2020 21:00	0.7	12.7	2,046.7	0.7	0.6	1	1	1
03/24/2020 22:00	0.7	12.8	2,047.3	0.7	0.6	1	1	1
03/24/2020 23:00	0.0	14.3	1,244.1	0.0	0.4	1	0	1
Average/Sum#:	0.6	13.6	1,697.8	0.6	0.5	24 #	23 #	8 #
Minimum:	0.0	12.4	1,244.1	0.0	0.4	1	0	0
Maximum:	0.7	14.3	2,110.1	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 17:00	0.0	17.5	483.2	0.0	0.1	1	0	0
03/27/2020 18:00	0.0	17.2	524.0	0.0	0.2	1	0	0
03/27/2020 19:00	0.0	15.4	882.5	0.0	0.3	1	0	0
03/27/2020 20:00	0.6	13.9	1,598.1	0.6	0.5	1	1	0
03/27/2020 21:00	0.6	13.9	1,427.6	0.6	0.4	1	1	0
03/27/2020 22:00	0.6	13.9	1,428.1	0.6	0.4	1	1	0
03/27/2020 23:00	0.6	13.8	1,683.7	0.6	0.5	1	1	0
Average/Sum#:	0.3	15.1	1,146.7	0.3	0.3	7 #	4 #	0 #
Minimum:	0.0	13.8	483.2	0.0	0.1	0	0	0
Maximum:	0.6	17.5	1,683.7	0.6	0.5	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2020 00:00	0.6	13.9	1,514.3	0.6	0.5	1	1	0
03/28/2020 01:00	0.6	13.8	1,683.8	0.6	0.5	1	1	0
03/28/2020 02:00	0.6	13.8	1,693.4	0.6	0.5	1	1	0
03/28/2020 03:00	0.6	13.8	1,696.4	0.6	0.5	1	1	0
03/28/2020 04:00	0.6	13.8	1,676.9	0.6	0.5	1	1	0
03/28/2020 05:00	0.6	13.8	1,678.7	0.6	0.5	1	1	0
03/28/2020 06:00	0.6	13.8	1,559.6	0.6	0.5	1	1	0
03/28/2020 07:00	0.6	13.8	1,527.0	0.6	0.5	1	1	0
03/28/2020 08:00	0.6	13.8	1,639.4	0.6	0.5	1	1	0
03/28/2020 09:00	0.6	13.8	1,665.2	0.6	0.5	1	1	0
03/28/2020 10:00	0.6	13.8	1,692.7	0.6	0.5	1	1	0
03/28/2020 11:00	0.6	13.8	1,698.4	0.6	0.5	1	1	0
03/28/2020 12:00	0.6	13.8	1,687.9	0.6	0.5	1	1	0
03/28/2020 13:00	0.6	13.8	1,691.7	0.6	0.5	1	1	0
03/28/2020 14:00	0.6	13.8	1,670.2	0.6	0.5	1	1	0
03/28/2020 15:00	0.6	13.9	1,670.5	0.6	0.5	1	1	0
03/28/2020 16:00	0.6	13.8	1,698.8	0.6	0.5	1	1	0
03/28/2020 17:00	0.7	13.3	1,846.2	0.7	0.6	1	1	1
03/28/2020 18:00	0.7	12.4	2,114.3	0.7	0.6	1	1	1
03/28/2020 19:00	0.7	12.5	2,080.3	0.7	0.6	1	1	1
03/28/2020 20:00	0.7	12.3	2,117.6	0.7	0.6	1	1	1
03/28/2020 21:00	0.7	12.6	2,064.6	0.7	0.6	1	1	1
03/28/2020 22:00	0.7	12.6	2,055.4	0.7	0.6	1	1	1
03/28/2020 23:00	0.7	12.9	1,968.9	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,766.3	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.3	1,514.3	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,117.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.6	13.8	1,646.7	0.6	0.5	1	1	0
03/29/2020 01:00	0.6	13.8	1,606.5	0.6	0.5	1	1	0
03/29/2020 02:00	0.6	13.8	1,615.4	0.6	0.5	1	1	0
03/29/2020 03:00	0.6	13.8	1,564.6	0.6	0.5	1	1	0
03/29/2020 04:00	0.6	13.8	1,699.9	0.6	0.5	1	1	0
03/29/2020 05:00	0.6	13.8	1,615.7	0.6	0.5	1	1	0
03/29/2020 06:00	0.6	13.8	1,593.2	0.6	0.5	1	1	0
03/29/2020 07:00	0.6	13.8	1,618.2	0.6	0.5	1	1	0
03/29/2020 08:00	0.6	13.8	1,603.0	0.6	0.5	1	1	0
03/29/2020 09:00	0.6	13.8	1,679.2	0.6	0.5	1	1	0
03/29/2020 10:00	0.6	13.8	1,702.6	0.6	0.5	1	1	0
03/29/2020 11:00	0.6	13.8	1,679.4	0.6	0.5	1	1	0
03/29/2020 12:00	0.6	13.9	1,571.1	0.6	0.5	1	1	0
03/29/2020 13:00	0.6	13.8	1,614.5	0.6	0.5	1	1	0
03/29/2020 14:00	0.6	13.9	1,597.8	0.6	0.5	1	1	0
03/29/2020 15:00	0.6	13.9	1,595.7	0.6	0.5	1	1	0
03/29/2020 16:00	0.6	13.9	1,652.6	0.6	0.5	1	1	0
03/29/2020 17:00	0.7	13.8	1,561.9	0.7	0.5	1	1	1
03/29/2020 18:00	0.7	12.6	2,026.3	0.7	0.6	1	1	1
03/29/2020 19:00	0.7	12.3	2,096.9	0.7	0.6	1	1	1
03/29/2020 20:00	0.7	12.4	2,079.0	0.7	0.6	1	1	1
03/29/2020 21:00	0.7	12.4	2,074.3	0.7	0.6	1	1	1
03/29/2020 22:00	0.7	13.0	1,951.3	0.7	0.6	1	1	1
03/29/2020 23:00	0.7	12.9	1,958.5	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,725.2	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.3	1,561.9	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,096.9	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2020 00:00	0.6	13.8	1,687.9	0.6	0.5	1	1	0
03/30/2020 01:00	0.6	13.8	1,688.9	0.6	0.5	1	1	0
03/30/2020 02:00	0.6	13.8	1,677.1	0.6	0.5	1	1	0
03/30/2020 03:00	0.6	13.8	1,649.8	0.6	0.5	1	1	0
03/30/2020 04:00	0.6	13.8	1,626.3	0.6	0.5	1	1	0
03/30/2020 05:00	0.6	13.8	1,677.8	0.6	0.5	1	1	0
03/30/2020 06:00	0.6	13.8	1,686.9	0.6	0.5	1	1	0
03/30/2020 07:00	0.6	13.8	1,663.8	0.6	0.5	1	1	0
03/30/2020 08:00	0.6	13.8	1,640.7	0.6	0.5	1	1	0
03/30/2020 09:00	0.6	13.8	1,664.4	0.6	0.5	1	1	0
03/30/2020 10:00	0.6	13.9	1,666.9	0.6	0.5	1	1	0
03/30/2020 11:00	0.6	13.9	1,641.2	0.6	0.5	1	1	0
03/30/2020 12:00	0.6	13.9	1,606.7	0.6	0.5	1	1	0
03/30/2020 13:00	0.6	13.9	1,595.8	0.6	0.5	1	1	0
03/30/2020 14:00	0.6	13.9	1,651.7	0.6	0.5	1	1	0
03/30/2020 15:00	0.6	13.9	1,613.2	0.6	0.5	1	1	0
03/30/2020 16:00	0.6	13.9	1,663.6	0.6	0.5	1	1	0
03/30/2020 17:00	0.7	13.9	1,657.4	0.7	0.5	1	1	1
03/30/2020 18:00	0.7	12.7	2,003.2	0.7	0.6	1	1	1
03/30/2020 19:00	0.7	12.5	2,049.4	0.7	0.6	1	1	1
03/30/2020 20:00	0.7	12.3	2,103.5	0.7	0.6	1	1	1
03/30/2020 21:00	0.7	12.3	2,103.4	0.7	0.6	1	1	1
03/30/2020 22:00	0.7	12.4	2,089.8	0.7	0.6	1	1	1
03/30/2020 23:00	0.7	12.7	2,025.9	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,755.6	0.6	0.5	24 #	24 #	7 #
Minimum:	0.6	12.3	1,595.8	0.6	0.5	1	1	0
Maximum:	0.7	13.9	2,103.5	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:45 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2020 00:00	0.7	12.6	2,033.6	0.7	0.6	1	1	1
03/31/2020 01:00	0.7	12.6	2,033.7	0.7	0.6	1	1	1
03/31/2020 02:00	0.7	12.7	2,035.1	0.7	0.6	1	1	1
03/31/2020 03:00	0.7	12.7	2,032.8	0.7	0.6	1	1	1
03/31/2020 04:00	0.7	12.8	2,017.7	0.7	0.6	1	1	1
03/31/2020 05:00	0.7	13.1	1,948.6	0.7	0.6	1	1	1
03/31/2020 06:00	0.7	12.7	2,032.9	0.7	0.6	1	1	1
03/31/2020 07:00	0.0	14.3	1,217.9	0.0	0.4	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 18:00	0.0	17.5	469.7	0.0	0.1	1	0	0
03/31/2020 19:00	0.0	15.2	919.4	0.0	0.3	1	0	0
03/31/2020 20:00	0.6	13.9	1,430.6	0.6	0.4	1	1	0
03/31/2020 21:00	0.6	13.9	1,349.9	0.6	0.4	1	1	0
03/31/2020 22:00	0.6	13.9	1,359.3	0.6	0.4	1	1	0
03/31/2020 23:00	0.6	13.9	1,510.0	0.6	0.5	1	1	0
Average/Sum#:	0.5	13.7	1,599.4	0.5	0.5	14 #	11 #	8 #
Minimum:	0.0	12.6	469.7	0.0	0.1	0	0	0
Maximum:	0.7	17.5	2,035.1	0.7	0.6	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:46 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 67.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 24.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**67.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:47 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,292.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 892.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,292.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:48 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,292.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 892.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,292.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:48 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:49 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,410.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 774.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,410.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:50 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,410.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 774.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,410.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:50 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:51 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2020 00:00	1.3	12.6	2,047.4	0.9	6.10	1	1	1
01/01/2020 01:00	1.3	12.7	2,032.6	0.9	6.10	1	1	1
01/01/2020 02:00	3.6	14.6	1,132.0	3.4	5.85	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	13.3	1,737.3	1.7	18.05 #	3 #	2 #	3 #
Minimum:	1.3	12.6	1,132.0	0.9	5.85	0	0	0
Maximum:	3.6	14.6	2,047.4	3.4	6.10	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 07:00	19.9	18.2	375.4	43.5	16.83	1	0	0
01/02/2020 08:00	27.6	15.8	794.9	31.9	93.80	1	0	0
01/02/2020 09:00	0.2	13.9	1,520.1	0.2	1.50	1	1	0
01/02/2020 10:00	0.4	13.9	1,653.2	0.3	1.70	1	1	0
01/02/2020 11:00	0.5	13.9	1,669.7	0.4	3.30	1	1	0
01/02/2020 12:00	0.4	13.9	1,615.8	0.3	1.60	1	1	0
01/02/2020 13:00	0.4	13.9	1,639.0	0.3	1.60	1	1	0
01/02/2020 14:00	0.4	13.9	1,625.1	0.3	1.60	1	1	0
01/02/2020 15:00	0.5	13.9	1,587.2	0.4	3.20	1	1	1
01/02/2020 16:00	1.3	12.6	2,022.4	0.9	6.10	1	1	1
01/02/2020 17:00	1.3	12.4	2,057.7	0.9	6.20	1	1	1
01/02/2020 18:00	1.3	12.3	2,101.3	0.9	6.30	1	1	1
01/02/2020 19:00	1.3	12.3	2,102.5	0.9	6.30	1	1	1
01/02/2020 20:00	1.3	12.3	2,108.2	0.9	6.30	1	1	1
01/02/2020 21:00	1.2	12.1	2,127.6	0.8	6.40	1	1	1
01/02/2020 22:00	1.3	12.2	2,114.6	0.9	6.30	1	1	1
01/02/2020 23:00	1.2	12.6	2,062.2	0.9	6.20	1	1	1
Average/Sum#:	3.6	13.5	1,716.3	5.0	175.23 #	17 #	15 #	9 #
Minimum:	0.2	12.1	375.4	0.2	1.50	0	0	0
Maximum:	27.6	18.2	2,127.6	43.5	93.80	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/03/2020 00:00	1.3	12.7	2,043.7	0.9	6.10	1	1	1
01/03/2020 01:00	1.3	12.6	2,040.5	0.9	6.10	1	1	1
01/03/2020 02:00	1.2	12.7	2,034.5	0.9	6.10	1	1	1
01/03/2020 03:00	1.3	12.7	2,046.3	0.9	6.10	1	1	1
01/03/2020 04:00	1.3	12.7	2,048.4	0.9	6.10	1	1	1
01/03/2020 05:00	0.9	12.7	2,037.6	0.6	4.10	1	1	1
01/03/2020 06:00	1.2	12.8	2,018.8	0.9	6.10	1	1	1
01/03/2020 07:00	1.3	12.8	2,033.2	0.9	6.10	1	1	1
01/03/2020 08:00	0.8	13.3	1,883.8	0.6	3.80	1	1	1
01/03/2020 09:00	0.4	13.9	1,521.2	0.3	1.50	1	1	0
01/03/2020 10:00	0.4	13.9	1,546.6	0.3	1.50	1	1	0
01/03/2020 11:00	0.5	13.9	1,592.3	0.4	3.20	1	1	0
01/03/2020 12:00	0.5	13.9	1,674.7	0.4	3.30	1	1	0
01/03/2020 13:00	0.4	13.9	1,653.4	0.3	1.70	1	1	0
01/03/2020 14:00	0.4	13.9	1,540.0	0.3	1.38	1	1	0
01/03/2020 15:00	0.5	13.9	1,574.9	0.4	3.10	1	1	0
01/03/2020 16:00	1.1	13.0	1,947.1	0.8	5.80	1	1	1
01/03/2020 17:00	1.3	12.7	2,027.7	0.9	6.10	1	1	1
01/03/2020 18:00	1.3	12.6	2,057.3	0.9	6.20	1	1	1
01/03/2020 19:00	1.3	12.6	2,044.2	0.9	6.10	1	1	1
01/03/2020 20:00	1.3	12.6	2,062.8	0.9	6.20	1	1	1
01/03/2020 21:00	1.3	12.3	2,116.1	0.9	6.30	1	1	1
01/03/2020 22:00	1.3	12.4	2,118.5	0.9	6.40	1	1	1
01/03/2020 23:00	2.4	13.2	1,678.7	1.8	11.80	1	0	1
Average/Sum#:	1.0	13.1	1,889.3	0.7	121.18 #	24 #	23 #	17 #
Minimum:	0.4	12.3	1,521.2	0.3	1.38	1	0	0
Maximum:	2.4	13.9	2,118.5	1.8	11.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2020 00:00	0.0	19.4	0.2	0.0	0.00	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	19.4	0.2	0.0	0.00 #	1 #	0 #	0 #
Minimum:	0.0	19.4	0.2	0.0	0.00	0	0	0
Maximum:	0.0	19.4	0.2	0.0	0.00	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 07:00	4.8	19.5	212.8	20.2	1.52	1	0	0
01/06/2020 08:00	35.7	16.6	601.7	49.0	108.30	1	0	0
01/06/2020 09:00	4.3	14.1	1,529.5	3.7	21.40	1	0	0
01/06/2020 10:00	0.3	13.9	1,546.4	0.3	1.50	1	1	0
01/06/2020 11:00	0.4	13.9	1,643.7	0.3	1.60	1	1	0
01/06/2020 12:00	0.4	13.9	1,574.9	0.3	1.60	1	1	0
01/06/2020 13:00	0.4	13.9	1,627.9	0.3	1.60	1	1	0
01/06/2020 14:00	0.4	13.9	1,558.1	0.3	1.60	1	1	0
01/06/2020 15:00	0.3	13.9	1,543.6	0.3	1.50	1	1	1
01/06/2020 16:00	1.2	12.8	2,021.8	0.9	6.10	1	1	1
01/06/2020 17:00	1.3	12.6	2,054.0	0.9	6.20	1	1	1
01/06/2020 18:00	1.3	12.7	2,048.2	0.9	6.10	1	1	1
01/06/2020 19:00	1.3	12.8	2,036.6	0.9	6.10	1	1	1
01/06/2020 20:00	1.3	12.8	2,030.5	0.9	6.10	1	1	1
01/06/2020 21:00	1.3	12.8	2,035.0	0.9	6.10	1	1	1
01/06/2020 22:00	1.3	12.7	2,058.6	0.9	6.20	1	1	1
01/06/2020 23:00	1.3	13.0	2,018.3	1.0	8.10	1	1	1
Average/Sum#:	3.4	13.9	1,655.4	4.8	191.62 #	17 #	14 #	9 #
Minimum:	0.3	12.6	212.8	0.3	1.50	0	0	0
Maximum:	35.7	19.5	2,058.6	49.0	108.30	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/07/2020 00:00	1.3	12.8	2,038.3	0.9	6.10	1	1	1
01/07/2020 01:00	1.3	13.0	2,021.6	1.0	8.10	1	1	1
01/07/2020 02:00	1.3	13.0	2,010.9	1.0	8.00	1	1	1
01/07/2020 03:00	1.2	13.0	2,009.9	0.9	6.00	1	1	1
01/07/2020 04:00	1.3	12.9	2,029.6	1.0	8.10	1	1	1
01/07/2020 05:00	1.2	12.9	2,035.9	0.9	6.10	1	1	1
01/07/2020 06:00	1.2	12.9	2,035.6	0.9	6.10	1	1	1
01/07/2020 07:00	1.3	12.7	2,081.0	0.9	6.20	1	1	1
01/07/2020 08:00	0.9	13.3	1,926.0	0.7	5.80	1	1	1
01/07/2020 09:00	0.5	13.8	1,715.4	0.4	3.40	1	1	0
01/07/2020 10:00	0.4	13.8	1,617.3	0.3	1.60	1	1	0
01/07/2020 11:00	0.4	13.8	1,604.8	0.3	1.60	1	1	0
01/07/2020 12:00	0.4	13.8	1,671.1	0.3	1.70	1	1	0
01/07/2020 13:00	0.4	13.8	1,640.1	0.3	1.60	1	1	0
01/07/2020 14:00	0.4	13.8	1,586.1	0.3	1.60	1	1	0
01/07/2020 15:00	0.3	13.8	1,565.3	0.2	1.60	1	1	1
01/07/2020 16:00	1.1	12.9	2,010.7	0.8	6.00	1	1	1
01/07/2020 17:00	1.3	12.8	2,037.7	0.9	6.10	1	1	1
01/07/2020 18:00	1.3	12.8	2,035.5	0.9	6.10	1	1	1
01/07/2020 19:00	1.3	12.8	2,024.5	0.9	6.10	1	1	1
01/07/2020 20:00	1.3	12.7	2,058.3	0.9	6.20	1	1	1
01/07/2020 21:00	1.3	12.6	2,076.5	0.9	6.20	1	1	1
01/07/2020 22:00	3.2	14.2	1,263.2	2.8	6.05	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.2	1,873.7	0.8	116.35 #	23 #	22 #	17 #
Minimum:	0.3	12.6	1,263.2	0.2	1.60	0	0	0
Maximum:	3.2	14.2	2,081.0	2.8	8.10	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/09/2020 02:00	20.5	18.2	381.2	44.8	17.61	1	0	0
01/09/2020 03:00	27.2	15.4	916.2	29.2	98.00	1	0	0
01/09/2020 04:00	0.4	13.8	1,685.2	0.3	1.70	1	1	0
01/09/2020 05:00	0.4	13.8	1,628.3	0.3	1.60	1	1	0
01/09/2020 06:00	0.2	13.9	1,386.6	0.2	1.40	1	1	0
01/09/2020 07:00	0.4	13.8	1,483.0	0.3	1.50	1	1	0
01/09/2020 08:00	0.5	13.8	1,623.6	0.4	3.20	1	1	0
01/09/2020 09:00	0.4	13.8	1,697.4	0.3	1.70	1	1	0
01/09/2020 10:00	0.4	13.8	1,573.0	0.3	1.60	1	1	0
01/09/2020 11:00	0.4	13.8	1,668.1	0.3	1.70	1	1	0
01/09/2020 12:00	0.4	13.8	1,636.1	0.3	1.60	1	1	0
01/09/2020 13:00	0.4	13.9	1,677.5	0.3	1.70	1	1	0
01/09/2020 14:00	0.4	13.9	1,605.1	0.3	1.60	1	1	0
01/09/2020 15:00	0.3	13.9	1,560.0	0.3	1.60	1	1	1
01/09/2020 16:00	1.3	12.7	2,038.7	0.9	6.10	1	1	1
01/09/2020 17:00	1.3	12.4	2,100.4	0.9	6.30	1	1	1
01/09/2020 18:00	1.3	12.2	2,144.2	0.9	6.40	1	1	1
01/09/2020 19:00	1.3	12.2	2,135.9	0.9	6.40	1	1	1
01/09/2020 20:00	1.3	12.2	2,140.8	0.9	6.40	1	1	1
01/09/2020 21:00	1.3	12.3	2,113.8	0.9	6.30	1	1	1
01/09/2020 22:00	1.3	12.3	2,128.4	0.9	6.40	1	1	1
01/09/2020 23:00	1.3	12.3	2,125.5	0.9	6.40	1	1	1
Average/Sum#:	2.9	13.6	1,702.2	3.9	187.21 #	22 #	20 #	9 #
Minimum:	0.2	12.2	381.2	0.2	1.40	0	0	0
Maximum:	27.2	18.2	2,144.2	44.8	98.00	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/10/2020 00:00	1.3	12.5	2,074.3	0.9	6.20	1	1	1
01/10/2020 01:00	1.2	12.7	2,055.4	0.9	6.20	1	1	1
01/10/2020 02:00	1.3	12.4	2,119.4	0.9	6.40	1	1	1
01/10/2020 03:00	1.2	12.3	2,124.4	0.8	6.40	1	1	1
01/10/2020 04:00	1.2	12.7	2,044.1	0.9	6.10	1	1	1
01/10/2020 05:00	1.2	12.7	2,061.3	0.9	6.20	1	1	1
01/10/2020 06:00	1.3	12.5	2,141.0	0.9	6.40	1	1	1
01/10/2020 07:00	1.3	12.1	2,203.0	0.9	6.60	1	1	1
01/10/2020 08:00	1.3	12.7	2,076.8	0.9	6.20	1	1	1
01/10/2020 09:00	0.8	13.3	1,914.2	0.6	3.80	1	1	1
01/10/2020 10:00	0.4	13.9	1,696.9	0.3	1.70	1	1	0
01/10/2020 11:00	0.4	13.8	1,656.6	0.3	1.70	1	1	0
01/10/2020 12:00	0.4	13.8	1,630.8	0.3	1.60	1	1	0
01/10/2020 13:00	0.4	13.8	1,675.0	0.3	1.70	1	1	0
01/10/2020 14:00	0.4	13.9	1,533.2	0.3	1.50	1	1	0
01/10/2020 15:00	0.3	13.8	1,540.9	0.2	1.50	1	1	1
01/10/2020 16:00	1.2	12.8	2,034.1	0.9	6.10	1	1	1
01/10/2020 17:00	1.3	12.5	2,084.9	0.9	6.30	1	1	1
01/10/2020 18:00	1.3	12.4	2,117.8	0.9	6.40	1	1	1
01/10/2020 19:00	1.3	12.5	2,094.9	0.9	6.30	1	1	1
01/10/2020 20:00	1.3	12.6	2,082.0	0.9	6.20	1	1	1
01/10/2020 21:00	1.3	12.6	2,069.1	0.9	6.20	1	1	1
01/10/2020 22:00	1.3	12.7	2,038.2	0.9	6.10	1	1	1
01/10/2020 23:00	1.3	12.8	2,021.5	0.9	6.10	1	1	1
Average/Sum#:	1.0	12.9	1,962.1	0.7	119.90 #	24 #	24 #	19 #
Minimum:	0.3	12.1	1,533.2	0.2	1.50	1	1	0
Maximum:	1.3	13.9	2,203.0	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2020 00:00	1.3	12.8	2,034.9	0.9	6.10	1	1	1
01/11/2020 01:00	1.3	12.8	2,029.7	0.9	6.10	1	1	1
01/11/2020 02:00	1.3	12.8	2,037.5	0.9	6.10	1	1	1
01/11/2020 03:00	1.3	12.9	2,038.0	1.0	8.20	1	1	1
01/11/2020 04:00	1.3	12.8	2,045.4	0.9	6.10	1	1	1
01/11/2020 05:00	1.3	12.8	2,033.9	0.9	6.10	1	1	1
01/11/2020 06:00	1.3	12.8	2,036.6	0.9	6.10	1	1	1
01/11/2020 07:00	1.3	12.8	2,042.0	0.9	6.10	1	1	1
01/11/2020 08:00	3.0	14.2	1,290.8	2.6	6.71	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	13.0	1,954.3	1.1	57.61 #	9 #	8 #	9 #
Minimum:	1.3	12.8	1,290.8	0.9	6.10	0	0	0
Maximum:	3.0	14.2	2,045.4	2.6	8.20	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/13/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/13/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/13/2020 03:00	13.8	18.8	311.8	38.8	8.92	1	0	0
01/13/2020 04:00	30.5	16.7	590.4	42.8	93.30	1	0	0
01/13/2020 05:00	20.0	15.4	811.9	21.5	64.10	1	0	0
01/13/2020 06:00	0.2	13.8	1,629.4	0.2	1.60	1	0	0
01/13/2020 07:00	0.4	13.8	1,613.3	0.3	1.60	1	1	0
01/13/2020 08:00	0.3	13.8	1,540.0	0.2	1.50	1	1	0
01/13/2020 09:00	0.4	13.8	1,661.0	0.3	1.70	1	1	0
01/13/2020 10:00	0.4	13.8	1,591.1	0.3	1.60	1	1	0
01/13/2020 11:00	0.4	13.8	1,520.2	0.3	1.50	1	1	0
01/13/2020 12:00	0.4	13.8	1,612.6	0.3	1.60	1	1	0
01/13/2020 13:00	0.5	13.8	1,689.3	0.4	3.40	1	1	0
01/13/2020 14:00	0.4	13.9	1,571.8	0.3	1.60	1	1	0
01/13/2020 15:00	0.4	13.8	1,547.6	0.3	1.50	1	1	1
01/13/2020 16:00	1.2	12.7	2,028.5	0.9	6.10	1	1	1
01/13/2020 17:00	1.3	12.0	2,152.7	0.9	6.50	1	1	1
01/13/2020 18:00	1.3	11.9	2,171.5	0.9	6.50	1	1	1
01/13/2020 19:00	1.3	12.0	2,158.4	0.9	6.50	1	1	1
01/13/2020 20:00	1.3	12.0	2,145.6	0.9	6.40	1	1	1
01/13/2020 21:00	1.3	12.3	2,091.7	0.9	6.30	1	1	1
01/13/2020 22:00	1.3	12.4	2,057.4	0.9	6.20	1	1	1
01/13/2020 23:00	1.3	12.5	2,041.2	0.9	6.10	1	1	1
Average/Sum#:	3.7	13.7	1,644.6	5.4	234.52 #	21 #	17 #	9 #
Minimum:	0.2	11.9	311.8	0.2	1.50	0	0	0
Maximum:	30.5	18.8	2,171.5	42.8	93.30	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/14/2020 00:00	1.3	12.5	2,050.6	0.9	6.20	1	1	1
01/14/2020 01:00	1.3	12.5	2,039.4	0.9	6.10	1	1	1
01/14/2020 02:00	1.3	12.5	2,043.5	0.9	6.10	1	1	1
01/14/2020 03:00	1.2	12.5	2,041.6	0.8	6.10	1	1	1
01/14/2020 04:00	1.3	12.6	2,042.3	0.9	6.10	1	1	1
01/14/2020 05:00	1.1	12.4	2,072.5	0.8	6.20	1	1	1
01/14/2020 06:00	1.3	12.3	2,112.3	0.9	6.30	1	1	1
01/14/2020 07:00	1.3	12.0	2,182.9	0.9	6.50	1	1	1
01/14/2020 08:00	1.4	12.6	2,051.7	1.0	8.20	1	1	1
01/14/2020 09:00	1.2	12.6	1,990.6	0.9	6.00	1	1	1
01/14/2020 10:00	0.7	13.8	1,676.4	0.6	3.40	1	1	0
01/14/2020 11:00	0.8	13.8	1,689.2	0.7	3.40	1	1	0
01/14/2020 12:00	0.9	13.8	1,659.1	0.7	5.00	1	1	0
01/14/2020 13:00	0.9	13.8	1,681.2	0.7	5.00	1	1	0
01/14/2020 14:00	0.0	0.0	1,625.9	0.0	0.00	1	1	0
01/14/2020 15:00	0.9	13.8	1,533.7	0.7	4.60	1	1	0
01/14/2020 16:00	1.0	13.8	1,548.7	0.8	4.60	1	1	1
01/14/2020 17:00	1.3	12.8	2,001.0	0.9	6.00	1	1	1
01/14/2020 18:00	1.3	12.6	2,044.7	0.9	6.10	1	1	1
01/14/2020 19:00	1.3	12.6	2,053.8	0.9	6.20	1	1	1
01/14/2020 20:00	1.3	12.4	2,093.2	0.9	6.30	1	1	1
01/14/2020 21:00	1.3	12.5	2,076.4	0.9	6.20	1	1	1
01/14/2020 22:00	1.3	12.7	2,043.8	0.9	6.10	1	1	1
01/14/2020 23:00	1.2	13.0	1,985.9	0.9	6.00	1	1	1
Average/Sum#:	1.2	12.9	1,930.9	0.8	132.70 #	24 #	24 #	18 #
Minimum:	0.7	12.0	1,533.7	0.6	3.40	1	1	0
Maximum:	1.4	13.8	2,182.9	1.0	8.20	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2020 00:00	1.3	12.8	2,036.4	0.9	6.10	1	1	1
01/15/2020 01:00	1.3	12.7	2,039.9	0.9	6.10	1	1	1
01/15/2020 02:00	1.3	12.7	2,042.7	0.9	6.10	1	1	1
01/15/2020 03:00	1.3	12.8	2,039.6	0.9	6.10	1	1	1
01/15/2020 04:00	1.3	12.8	2,041.3	0.9	6.10	1	1	1
01/15/2020 05:00	1.3	12.6	2,068.0	0.9	6.20	1	1	1
01/15/2020 06:00	1.4	12.2	2,180.0	0.9	6.50	1	1	1
01/15/2020 07:00	1.4	11.7	2,289.4	0.9	6.90	1	1	1
01/15/2020 08:00	1.2	12.7	2,038.9	0.9	6.10	1	1	1
01/15/2020 09:00	1.0	13.8	1,610.9	0.8	4.80	1	1	0
01/15/2020 10:00	1.1	13.8	1,652.5	0.9	5.00	1	1	0
01/15/2020 11:00	1.1	13.8	1,668.7	0.9	5.00	1	1	0
01/15/2020 12:00	1.0	13.8	1,627.7	0.8	4.90	1	1	0
01/15/2020 13:00	1.1	13.8	1,672.1	0.9	5.00	1	1	0
01/15/2020 14:00	1.1	13.8	1,687.2	0.9	5.10	1	1	0
01/15/2020 15:00	1.0	13.8	1,590.5	0.8	4.80	1	1	1
01/15/2020 16:00	1.3	12.5	2,055.4	0.9	6.20	1	1	1
01/15/2020 17:00	1.4	12.0	2,157.4	0.9	6.50	1	1	1
01/15/2020 18:00	1.4	12.2	2,131.7	0.9	6.40	1	1	1
01/15/2020 19:00	1.4	11.9	2,194.2	0.9	6.60	1	1	1
01/15/2020 20:00	1.4	11.9	2,187.8	0.9	6.60	1	1	1
01/15/2020 21:00	1.4	11.9	2,172.1	0.9	6.50	1	1	1
01/15/2020 22:00	1.3	12.3	2,091.6	0.9	6.30	1	1	1
01/15/2020 23:00	1.3	12.5	2,055.1	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.8	1,972.1	0.9	142.10 #	24 #	24 #	18 #
Minimum:	1.0	11.7	1,590.5	0.8	4.80	1	1	0
Maximum:	1.4	13.8	2,289.4	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2020 00:00	1.3	12.6	2,039.7	0.9	6.10	1	1	1
01/16/2020 01:00	1.3	12.5	2,042.3	0.9	6.10	1	1	1
01/16/2020 02:00	1.3	12.5	2,045.3	0.9	6.10	1	1	1
01/16/2020 03:00	1.3	12.5	2,047.5	0.9	6.10	1	1	1
01/16/2020 04:00	1.3	12.5	2,050.7	0.9	6.20	1	1	1
01/16/2020 05:00	1.4	12.4	2,046.7	1.0	8.20	1	1	1
01/16/2020 06:00	1.3	12.3	2,078.5	0.9	6.20	1	1	1
01/16/2020 07:00	1.4	11.9	2,169.9	0.9	6.50	1	1	1
01/16/2020 08:00	1.3	12.3	2,071.2	0.9	6.20	1	1	1
01/16/2020 09:00	1.3	12.8	1,966.5	0.9	5.90	1	1	1
01/16/2020 10:00	1.0	13.8	1,659.5	0.8	5.00	1	1	0
01/16/2020 11:00	1.0	13.8	1,574.7	0.8	4.70	1	1	0
01/16/2020 12:00	1.0	13.8	1,521.4	0.8	4.60	1	1	0
01/16/2020 13:00	1.1	13.8	1,656.8	0.9	5.00	1	1	0
01/16/2020 14:00	1.1	13.8	1,596.4	0.9	4.80	1	1	0
01/16/2020 15:00	1.1	13.8	1,727.3	0.9	5.20	1	1	1
01/16/2020 16:00	1.3	12.6	2,024.8	0.9	6.10	1	1	1
01/16/2020 17:00	1.3	12.5	2,037.7	0.9	6.10	1	1	1
01/16/2020 18:00	1.3	12.6	2,033.0	0.9	6.10	1	1	1
01/16/2020 19:00	1.3	12.6	2,049.0	0.9	6.10	1	1	1
01/16/2020 20:00	1.3	12.4	2,094.1	0.9	6.30	1	1	1
01/16/2020 21:00	1.3	12.4	2,099.0	0.9	6.30	1	1	1
01/16/2020 22:00	1.3	12.7	2,031.1	0.9	6.10	1	1	1
01/16/2020 23:00	1.3	12.7	2,037.4	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.8	1,945.9	0.9	142.10 #	24 #	24 #	19 #
Minimum:	1.0	11.9	1,521.4	0.8	4.60	1	1	0
Maximum:	1.4	13.8	2,169.9	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/17/2020 00:00	1.3	12.7	2,045.2	0.9	6.10	1	1	1
01/17/2020 01:00	1.3	12.8	2,017.8	0.9	6.10	1	1	1
01/17/2020 02:00	1.3	12.8	2,041.4	0.9	6.10	1	1	1
01/17/2020 03:00	1.3	12.9	2,037.3	1.0	8.10	1	1	1
01/17/2020 04:00	1.3	12.8	2,050.8	0.9	6.20	1	1	1
01/17/2020 05:00	1.4	12.7	2,065.2	1.0	8.30	1	1	1
01/17/2020 06:00	1.4	12.1	2,208.2	0.9	6.60	1	1	1
01/17/2020 07:00	1.4	11.7	2,284.1	0.9	6.90	1	1	1
01/17/2020 08:00	1.3	12.7	2,060.1	0.9	6.20	1	1	1
01/17/2020 09:00	1.2	13.0	1,966.5	0.9	5.90	1	1	1
01/17/2020 10:00	1.1	13.8	1,682.9	0.9	5.00	1	1	0
01/17/2020 11:00	1.1	13.8	1,633.2	0.9	4.90	1	1	0
01/17/2020 12:00	1.1	13.8	1,664.0	0.9	5.00	1	1	0
01/17/2020 13:00	1.1	13.8	1,649.5	0.9	4.90	1	1	0
01/17/2020 14:00	1.1	13.8	1,623.2	0.9	4.90	1	1	0
01/17/2020 15:00	1.1	13.8	1,507.0	0.9	4.50	1	1	1
01/17/2020 16:00	1.3	12.8	2,003.8	0.9	6.00	1	1	1
01/17/2020 17:00	1.2	13.0	1,958.6	0.9	5.90	1	1	1
01/17/2020 18:00	1.2	13.0	1,967.6	0.9	5.90	1	1	1
01/17/2020 19:00	1.3	12.5	2,094.8	0.9	6.30	1	1	1
01/17/2020 20:00	1.3	12.3	2,127.6	0.9	6.40	1	1	1
01/17/2020 21:00	1.3	12.4	2,118.9	0.9	6.40	1	1	1
01/17/2020 22:00	1.3	12.5	2,096.4	0.9	6.30	1	1	1
01/17/2020 23:00	1.3	12.6	2,074.6	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.9	1,957.4	0.9	145.10 #	24 #	24 #	19 #
Minimum:	1.1	11.7	1,507.0	0.9	4.50	1	1	0
Maximum:	1.4	13.8	2,284.1	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/18/2020 00:00	1.3	12.7	2,054.8	0.9	6.20	1	1	1
01/18/2020 01:00	1.3	12.6	2,064.2	0.9	6.20	1	1	1
01/18/2020 02:00	1.3	12.8	2,036.9	0.9	6.10	1	1	1
01/18/2020 03:00	1.3	12.8	2,038.0	0.9	6.10	1	1	1
01/18/2020 04:00	1.3	12.8	2,038.1	0.9	6.10	1	1	1
01/18/2020 05:00	1.1	12.8	2,037.8	0.8	6.10	1	1	1
01/18/2020 06:00	1.3	12.8	2,044.1	0.9	6.10	1	1	1
01/18/2020 07:00	1.3	12.8	2,038.4	0.9	6.10	1	1	1
01/18/2020 08:00	1.2	13.1	1,983.9	0.9	6.00	1	1	1
01/18/2020 09:00	1.0	13.8	1,679.4	0.8	5.00	1	1	0
01/18/2020 10:00	1.0	13.8	1,635.0	0.8	4.90	1	1	0
01/18/2020 11:00	1.0	13.8	1,611.4	0.8	4.80	1	1	0
01/18/2020 12:00	1.1	13.8	1,628.4	0.9	4.90	1	1	0
01/18/2020 13:00	1.1	13.8	1,651.5	0.9	5.00	1	1	0
01/18/2020 14:00	1.1	13.8	1,617.0	0.9	4.90	1	1	0
01/18/2020 15:00	1.1	13.8	1,600.9	0.9	4.80	1	1	1
01/18/2020 16:00	1.2	12.8	2,012.6	0.9	6.00	1	1	1
01/18/2020 17:00	1.3	12.7	2,041.7	0.9	6.10	1	1	1
01/18/2020 18:00	1.2	13.0	1,957.5	0.9	5.90	1	1	1
01/18/2020 19:00	1.3	12.6	2,060.8	0.9	6.20	1	1	1
01/18/2020 20:00	1.3	12.3	2,119.2	0.9	6.40	1	1	1
01/18/2020 21:00	1.3	12.3	2,127.2	0.9	6.40	1	1	1
01/18/2020 22:00	1.3	12.2	2,140.7	0.9	6.40	1	1	1
01/18/2020 23:00	1.3	12.3	2,115.9	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.0	1,930.6	0.9	139.00 #	24 #	24 #	18 #
Minimum:	1.0	12.2	1,600.9	0.8	4.80	1	1	0
Maximum:	1.3	13.8	2,140.7	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2020 00:00	1.3	12.5	2,029.0	0.9	6.10	1	1	1
01/19/2020 01:00	1.0	13.8	1,700.3	0.8	5.10	1	1	0
01/19/2020 02:00	1.0	13.8	1,552.0	0.8	4.70	1	1	0
01/19/2020 03:00	1.1	13.8	1,628.7	0.9	4.90	1	1	0
01/19/2020 04:00	1.1	13.8	1,620.8	0.9	4.90	1	1	0
01/19/2020 05:00	1.1	13.8	1,673.3	0.9	5.00	1	1	0
01/19/2020 06:00	1.1	13.8	1,692.8	0.9	5.10	1	1	0
01/19/2020 07:00	1.0	13.8	1,601.4	0.8	4.80	1	1	0
01/19/2020 08:00	1.0	13.8	1,555.3	0.8	4.70	1	1	0
01/19/2020 09:00	1.1	13.8	1,616.4	0.9	4.80	1	1	0
01/19/2020 10:00	1.1	13.8	1,565.8	0.9	4.70	1	1	0
01/19/2020 11:00	1.1	13.8	1,639.9	0.9	4.90	1	1	0
01/19/2020 12:00	1.1	13.8	1,658.6	0.9	5.00	1	1	0
01/19/2020 13:00	1.1	13.8	1,671.7	0.9	5.00	1	1	0
01/19/2020 14:00	1.1	13.8	1,582.0	0.9	4.70	1	1	0
01/19/2020 15:00	1.1	13.8	1,620.0	0.9	4.90	1	1	0
01/19/2020 16:00	1.1	13.8	1,614.5	0.9	4.80	1	1	1
01/19/2020 17:00	1.3	12.8	2,011.7	0.9	6.00	1	1	1
01/19/2020 18:00	1.3	12.6	2,046.3	0.9	6.10	1	1	1
01/19/2020 19:00	1.3	12.6	2,039.5	0.9	6.10	1	1	1
01/19/2020 20:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
01/19/2020 21:00	1.4	12.2	2,133.5	0.9	6.40	1	1	1
01/19/2020 22:00	1.4	12.2	2,130.1	0.9	6.40	1	1	1
01/19/2020 23:00	1.3	12.3	2,118.5	0.9	6.40	1	1	1
Average/Sum#:	1.2	13.3	1,775.3	0.9	127.80 #	24 #	24 #	9 #
Minimum:	1.0	12.2	1,552.0	0.8	4.70	1	1	0
Maximum:	1.4	13.8	2,133.5	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/20/2020 00:00	1.3	12.4	2,084.3	0.9	6.30	1	1	1
01/20/2020 01:00	1.3	12.6	2,047.3	0.9	6.10	1	1	1
01/20/2020 02:00	1.3	12.7	2,030.2	0.9	6.10	1	1	1
01/20/2020 03:00	1.3	12.7	2,036.9	0.9	6.10	1	1	1
01/20/2020 04:00	1.3	12.6	2,041.2	0.9	6.10	1	1	1
01/20/2020 05:00	1.3	12.5	2,053.5	0.9	6.20	1	1	1
01/20/2020 06:00	1.3	12.6	2,061.1	0.9	6.20	1	1	1
01/20/2020 07:00	1.4	12.3	2,123.4	1.0	8.50	1	1	1
01/20/2020 08:00	1.4	12.2	2,143.1	0.9	6.40	1	1	1
01/20/2020 09:00	1.4	12.2	2,121.3	0.9	6.40	1	1	1
01/20/2020 10:00	1.4	12.1	2,143.4	0.9	6.40	1	1	1
01/20/2020 11:00	1.4	12.2	2,117.0	0.9	6.40	1	1	1
01/20/2020 12:00	1.4	12.0	2,138.3	0.9	6.40	1	1	1
01/20/2020 13:00	1.4	12.1	2,132.1	0.9	6.40	1	1	1
01/20/2020 14:00	1.3	11.9	2,153.9	0.9	6.50	1	1	1
01/20/2020 15:00	1.3	12.1	2,116.9	0.9	6.40	1	1	1
01/20/2020 16:00	1.3	12.3	2,073.6	0.9	6.20	1	1	1
01/20/2020 17:00	1.4	12.1	2,126.3	0.9	6.40	1	1	1
01/20/2020 18:00	1.4	12.1	2,121.6	0.9	6.40	1	1	1
01/20/2020 19:00	1.4	12.2	2,120.1	0.9	6.40	1	1	1
01/20/2020 20:00	1.4	12.2	2,118.1	0.9	6.40	1	1	1
01/20/2020 21:00	1.4	12.2	2,118.3	0.9	6.40	1	1	1
01/20/2020 22:00	1.3	12.3	2,102.6	0.9	6.30	1	1	1
01/20/2020 23:00	1.3	12.4	2,071.0	0.9	6.20	1	1	1
Average/Sum#:	1.4	12.3	2,099.8	0.9	153.60 #	24 #	24 #	24 #
Minimum:	1.3	11.9	2,030.2	0.9	6.10	1	1	1
Maximum:	1.4	12.7	2,153.9	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2020 00:00	1.3	12.6	2,045.0	0.9	6.10	1	1	1
01/21/2020 01:00	1.3	12.6	2,036.2	0.9	6.10	1	1	1
01/21/2020 02:00	1.3	12.6	2,041.0	0.9	6.10	1	1	1
01/21/2020 03:00	1.3	12.6	2,033.9	0.9	6.10	1	1	1
01/21/2020 04:00	1.3	12.6	2,038.6	0.9	6.10	1	1	1
01/21/2020 05:00	1.3	12.6	2,041.2	0.9	6.10	1	1	1
01/21/2020 06:00	1.3	12.7	2,010.3	0.9	6.00	1	1	1
01/21/2020 07:00	1.3	12.3	2,093.8	0.9	6.30	1	1	1
01/21/2020 08:00	1.3	12.5	2,059.5	0.9	6.20	1	1	1
01/21/2020 09:00	1.3	12.8	1,969.7	0.9	5.90	1	1	1
01/21/2020 10:00	1.1	13.8	1,674.5	0.9	5.00	1	1	0
01/21/2020 11:00	1.1	13.8	1,685.4	0.9	5.10	1	1	0
01/21/2020 12:00	1.1	13.8	1,650.7	0.9	5.00	1	1	0
01/21/2020 13:00	1.1	13.8	1,622.5	0.9	4.90	1	1	0
01/21/2020 14:00	1.1	13.8	1,632.0	0.9	4.90	1	1	0
01/21/2020 15:00	1.0	13.8	1,552.1	0.8	4.70	1	1	1
01/21/2020 16:00	1.3	12.5	2,028.0	0.9	6.10	1	1	1
01/21/2020 17:00	1.3	12.4	2,054.3	0.9	6.20	1	1	1
01/21/2020 18:00	1.3	12.4	2,048.2	0.9	6.10	1	1	1
01/21/2020 19:00	1.3	12.4	2,043.8	0.9	6.10	1	1	1
01/21/2020 20:00	1.3	12.4	2,039.7	0.9	6.10	1	1	1
01/21/2020 21:00	1.3	12.5	2,036.1	0.9	6.10	1	1	1
01/21/2020 22:00	1.3	12.3	2,072.6	0.9	6.20	1	1	1
01/21/2020 23:00	1.3	12.5	2,044.7	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.8	1,939.7	0.9	139.60 #	24 #	24 #	19 #
Minimum:	1.0	12.3	1,552.1	0.8	4.70	1	1	0
Maximum:	1.3	13.8	2,093.8	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2020 00:00	1.2	13.1	1,828.3	0.9	5.50	1	1	1
01/22/2020 01:00	0.9	13.8	1,303.7	0.7	3.90	1	1	0
01/22/2020 02:00	0.9	13.8	1,365.4	0.7	4.10	1	1	0
01/22/2020 03:00	0.9	13.8	1,330.9	0.7	4.00	1	1	0
01/22/2020 04:00	1.1	13.7	1,515.3	0.9	4.50	1	1	0
01/22/2020 05:00	1.1	13.7	1,451.4	0.9	4.40	1	1	0
01/22/2020 06:00	1.1	13.7	1,585.6	0.9	4.80	1	1	0
01/22/2020 07:00	1.1	13.7	1,640.0	0.9	4.90	1	1	0
01/22/2020 08:00	1.0	13.8	1,483.2	0.8	4.40	1	1	0
01/22/2020 09:00	1.1	13.7	1,584.1	0.9	4.80	1	1	0
01/22/2020 10:00	1.1	13.7	1,613.9	0.9	4.80	1	1	0
01/22/2020 11:00	1.1	13.7	1,695.4	0.9	5.10	1	1	0
01/22/2020 12:00	1.1	13.8	1,694.9	0.9	5.10	1	1	0
01/22/2020 13:00	1.1	13.8	1,653.4	0.9	5.00	1	1	0
01/22/2020 14:00	1.1	13.8	1,632.4	0.9	4.90	1	1	0
01/22/2020 15:00	1.1	13.8	1,599.2	0.9	4.80	1	1	1
01/22/2020 16:00	1.3	12.6	2,029.5	0.9	6.10	1	1	1
01/22/2020 17:00	1.3	12.6	2,008.8	0.9	6.00	1	1	1
01/22/2020 18:00	1.4	12.1	2,126.3	0.9	6.40	1	1	1
01/22/2020 19:00	1.4	12.2	2,119.6	0.9	6.40	1	1	1
01/22/2020 20:00	1.3	12.5	2,049.9	0.9	6.10	1	1	1
01/22/2020 21:00	1.3	12.6	2,042.0	0.9	6.10	1	1	1
01/22/2020 22:00	1.3	12.6	2,048.9	0.9	6.10	1	1	1
01/22/2020 23:00	1.2	13.0	1,953.5	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.3	1,723.2	0.9	124.10 #	24 #	24 #	10 #
Minimum:	0.9	12.1	1,303.7	0.7	3.90	1	1	0
Maximum:	1.4	13.8	2,126.3	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2020 00:00	1.3	12.3	2,098.2	0.9	6.30	1	1	1
01/23/2020 01:00	1.3	12.3	2,098.0	0.9	6.30	1	1	1
01/23/2020 02:00	1.3	12.6	2,046.4	0.9	6.10	1	1	1
01/23/2020 03:00	1.3	12.6	2,046.2	0.9	6.10	1	1	1
01/23/2020 04:00	1.3	12.2	2,121.4	0.9	6.40	1	1	1
01/23/2020 05:00	1.3	12.6	2,062.0	0.9	6.20	1	1	1
01/23/2020 06:00	1.3	12.2	2,157.5	0.9	6.50	1	1	1
01/23/2020 07:00	1.3	12.4	2,113.5	0.9	6.30	1	1	1
01/23/2020 08:00	1.2	13.0	1,940.1	0.9	5.80	1	1	1
01/23/2020 09:00	1.1	13.7	1,671.7	0.9	5.00	1	1	0
01/23/2020 10:00	1.1	13.8	1,547.6	0.9	4.60	1	1	0
01/23/2020 11:00	1.1	13.8	1,603.8	0.9	4.80	1	1	0
01/23/2020 12:00	1.1	13.8	1,630.2	0.9	4.90	1	1	0
01/23/2020 13:00	1.1	13.8	1,660.7	0.9	5.00	1	1	0
01/23/2020 14:00	1.1	13.8	1,649.9	0.9	4.90	1	1	0
01/23/2020 15:00	1.1	13.8	1,616.6	0.9	4.80	1	1	0
01/23/2020 16:00	1.0	13.8	1,496.6	0.8	4.50	1	1	0
01/23/2020 17:00	1.2	12.9	1,919.5	0.9	5.80	1	1	1
01/23/2020 18:00	1.4	12.1	2,126.8	0.9	6.40	1	1	1
01/23/2020 19:00	1.3	12.1	2,124.2	0.9	6.40	1	1	1
01/23/2020 20:00	1.4	12.1	2,120.9	0.9	6.40	1	1	1
01/23/2020 21:00	1.3	12.2	2,108.3	0.9	6.30	1	1	1
01/23/2020 22:00	1.3	12.4	2,070.6	0.9	6.20	1	1	1
01/23/2020 23:00	1.2	13.0	1,934.3	0.9	5.80	1	1	1
Average/Sum#:	1.2	12.9	1,915.2	0.9	137.80 #	24 #	24 #	16 #
Minimum:	1.0	12.1	1,496.6	0.8	4.50	1	1	0
Maximum:	1.4	13.8	2,157.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/24/2020 00:00	1.2	13.1	1,913.9	0.9	5.70	1	1	1
01/24/2020 01:00	1.1	13.7	1,630.9	0.9	4.90	1	1	0
01/24/2020 02:00	1.1	13.7	1,659.8	0.9	5.00	1	1	0
01/24/2020 03:00	1.1	13.7	1,693.1	0.9	5.10	1	1	0
01/24/2020 04:00	1.1	13.7	1,694.3	0.9	5.10	1	1	0
01/24/2020 05:00	1.0	13.7	1,593.1	0.8	4.80	1	1	0
01/24/2020 06:00	1.1	13.7	1,652.2	0.9	5.00	1	1	0
01/24/2020 07:00	1.1	13.7	1,647.7	0.9	4.90	1	1	0
01/24/2020 08:00	1.1	13.7	1,589.3	0.9	4.80	1	1	0
01/24/2020 09:00	1.1	13.7	1,661.4	0.9	5.00	1	1	0
01/24/2020 10:00	1.1	13.8	1,470.8	0.9	4.40	1	1	0
01/24/2020 11:00	1.1	13.7	1,653.5	0.9	5.00	1	1	0
01/24/2020 12:00	1.1	13.7	1,624.2	0.9	4.90	1	1	0
01/24/2020 13:00	1.1	13.7	1,666.2	0.9	5.00	1	1	0
01/24/2020 14:00	1.1	13.7	1,642.4	0.9	4.90	1	1	0
01/24/2020 15:00	1.1	13.8	1,548.8	0.9	4.60	1	1	0
01/24/2020 16:00	1.0	13.8	1,579.7	0.8	4.70	1	1	1
01/24/2020 17:00	1.3	12.6	2,030.5	0.9	6.10	1	1	1
01/24/2020 18:00	1.4	12.1	2,121.2	0.9	6.40	1	1	1
01/24/2020 19:00	1.4	12.1	2,117.7	0.9	6.40	1	1	1
01/24/2020 20:00	1.4	12.1	2,112.0	0.9	6.30	1	1	1
01/24/2020 21:00	1.3	12.3	2,083.6	0.9	6.30	1	1	1
01/24/2020 22:00	1.3	12.4	2,050.7	0.9	6.20	1	1	1
01/24/2020 23:00	2.4	14.0	1,267.4	2.1	5.05	1	0	1
Average/Sum#:	1.2	13.3	1,737.7	0.9	126.55 #	24 #	23 #	9 #
Minimum:	1.0	12.1	1,267.4	0.8	4.40	1	0	0
Maximum:	2.4	14.0	2,121.2	2.1	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/28/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/28/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/28/2020 03:00	28.5	17.6	453.6	51.0	52.89	1	0	0
01/28/2020 04:00	18.1	15.1	1,005.9	18.4	68.40	1	0	0
01/28/2020 05:00	0.9	13.7	1,596.0	0.7	4.80	1	1	0
01/28/2020 06:00	1.1	13.7	1,696.1	0.9	5.10	1	1	0
01/28/2020 07:00	1.1	13.8	1,604.8	0.9	4.80	1	1	0
01/28/2020 08:00	1.0	13.7	1,666.6	0.8	5.00	1	1	0
01/28/2020 09:00	1.1	13.7	1,679.4	0.9	5.00	1	1	0
01/28/2020 10:00	1.0	13.8	1,528.8	0.8	4.60	1	1	0
01/28/2020 11:00	1.1	13.7	1,609.3	0.9	4.80	1	1	0
01/28/2020 12:00	1.1	13.8	1,598.1	0.9	4.80	1	1	0
01/28/2020 13:00	1.1	13.8	1,655.0	0.9	5.00	1	1	0
01/28/2020 14:00	1.1	13.7	1,569.9	0.9	4.70	1	1	0
01/28/2020 15:00	1.1	13.8	1,559.2	0.9	4.70	1	1	0
01/28/2020 16:00	1.0	13.7	1,566.5	0.8	4.70	1	1	1
01/28/2020 17:00	1.3	12.6	2,021.2	0.9	6.10	1	1	1
01/28/2020 18:00	1.3	12.3	2,063.4	0.9	6.20	1	1	1
01/28/2020 19:00	1.3	12.3	2,085.0	0.9	6.30	1	1	1
01/28/2020 20:00	1.4	12.1	2,116.2	0.9	6.30	1	1	1
01/28/2020 21:00	1.4	12.1	2,119.1	0.9	6.40	1	1	1
01/28/2020 22:00	2.5	14.0	1,276.7	2.1	5.30	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.4	13.7	1,623.5	4.3	215.89 #	20 #	17 #	7 #
Minimum:	0.9	12.1	453.6	0.7	4.60	0	0	0
Maximum:	28.5	17.6	2,119.1	51.0	68.40	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/30/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/30/2020 02:00	31.7	17.5	460.1	55.0	62.58	1	0	0
01/30/2020 03:00	11.8	14.6	1,102.0	11.1	45.20	1	0	0
01/30/2020 04:00	1.0	13.7	1,635.4	0.8	4.90	1	1	0
01/30/2020 05:00	0.9	13.8	1,383.8	0.7	4.20	1	1	0
01/30/2020 06:00	1.4	13.2	1,845.9	1.1	7.40	1	1	1
01/30/2020 07:00	1.2	12.5	2,084.1	0.8	6.30	1	1	1
01/30/2020 08:00	1.2	13.0	1,925.2	0.9	5.80	1	1	1
01/30/2020 09:00	1.0	13.7	1,626.9	0.8	4.90	1	1	0
01/30/2020 10:00	1.0	13.8	1,629.6	0.8	4.90	1	1	0
01/30/2020 11:00	1.0	13.8	1,681.9	0.8	5.00	1	1	0
01/30/2020 12:00	1.0	13.8	1,494.1	0.8	4.50	1	1	0
01/30/2020 13:00	1.1	13.8	1,650.4	0.9	5.00	1	1	0
01/30/2020 14:00	1.0	13.8	1,550.0	0.8	4.70	1	1	0
01/30/2020 15:00	1.1	13.8	1,630.1	0.9	4.90	1	1	0
01/30/2020 16:00	1.0	13.8	1,511.7	0.8	4.50	1	1	0
01/30/2020 17:00	1.0	13.8	1,632.9	0.8	4.90	1	1	0
01/30/2020 18:00	1.1	13.8	1,708.9	0.9	5.10	1	1	1
01/30/2020 19:00	1.3	12.4	2,039.3	0.9	6.10	1	1	1
01/30/2020 20:00	1.4	11.9	2,143.9	0.9	6.40	1	1	1
01/30/2020 21:00	1.4	12.0	2,125.4	0.9	6.40	1	1	1
01/30/2020 22:00	1.3	12.3	2,073.7	0.9	6.20	1	1	1
01/30/2020 23:00	1.0	13.3	1,751.3	0.8	5.30	1	1	1
Average/Sum#:	3.0	13.6	1,667.6	3.8	215.18 #	22 #	20 #	9 #
Minimum:	0.9	11.9	460.1	0.7	4.20	0	0	0
Maximum:	31.7	17.5	2,143.9	55.0	62.58	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2020 00:00	2.0	14.4	1,058.6	1.8	4.96	1	0	0
01/31/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/31/2020 05:00	6.2	16.7	519.4	8.7	11.62	1	0	0
01/31/2020 06:00	7.8	14.3	1,278.2	7.0	33.20	1	0	0
01/31/2020 07:00	1.0	13.7	1,591.9	0.8	4.80	1	1	0
01/31/2020 08:00	1.1	13.8	1,524.1	0.9	4.60	1	1	0
01/31/2020 09:00	1.1	13.8	1,617.4	0.9	4.90	1	1	0
01/31/2020 10:00	1.1	13.7	1,627.0	0.9	4.90	1	1	0
01/31/2020 11:00	1.1	13.8	1,637.6	0.9	4.90	1	1	0
01/31/2020 12:00	1.1	13.8	1,615.7	0.9	4.80	1	1	0
01/31/2020 13:00	1.1	13.8	1,692.2	0.9	5.10	1	1	0
01/31/2020 14:00	1.1	13.8	1,678.2	0.9	5.00	1	1	0
01/31/2020 15:00	1.1	13.8	1,662.5	0.9	5.00	1	1	0
01/31/2020 16:00	1.0	13.8	1,481.5	0.8	4.40	1	1	0
01/31/2020 17:00	1.1	13.8	1,672.6	0.9	5.00	1	1	0
01/31/2020 18:00	1.2	13.2	1,826.3	0.9	5.50	1	1	1
01/31/2020 19:00	1.3	12.6	2,009.4	0.9	6.00	1	1	1
01/31/2020 20:00	1.3	12.1	2,101.7	0.9	6.30	1	1	1
01/31/2020 21:00	1.3	12.1	2,103.7	0.9	6.30	1	1	1
01/31/2020 22:00	1.4	12.2	2,095.8	0.9	6.30	1	1	1
01/31/2020 23:00	2.7	14.0	1,284.9	2.3	5.80	1	0	1
Average/Sum#:	1.9	13.7	1,603.9	1.7	139.38 #	20 #	16 #	6 #
Minimum:	1.0	12.1	519.4	0.8	4.40	0	0	0
Maximum:	7.8	16.7	2,103.7	8.7	33.20	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/03/2020 03:00	3.7	19.8	175.5	19.8	0.96	1	0	0
02/03/2020 04:00	33.1	16.9	563.0	48.8	101.30	1	0	0
02/03/2020 05:00	8.7	14.2	1,373.4	7.7	38.50	1	0	0
02/03/2020 06:00	0.9	13.8	1,701.3	0.7	5.10	1	1	0
02/03/2020 07:00	0.9	13.8	1,615.6	0.7	4.80	1	1	0
02/03/2020 08:00	0.9	13.8	1,549.0	0.7	4.60	1	1	0
02/03/2020 09:00	0.9	13.8	1,477.8	0.7	4.40	1	1	0
02/03/2020 10:00	1.0	13.8	1,561.3	0.8	4.70	1	1	0
02/03/2020 11:00	1.0	13.8	1,694.0	0.8	5.10	1	1	0
02/03/2020 12:00	1.0	13.8	1,656.3	0.8	5.00	1	1	0
02/03/2020 13:00	1.0	13.8	1,641.1	0.8	4.90	1	1	0
02/03/2020 14:00	1.0	13.8	1,563.8	0.8	4.70	1	1	0
02/03/2020 15:00	1.0	13.8	1,654.5	0.8	5.00	1	1	0
02/03/2020 16:00	1.0	13.8	1,584.6	0.8	4.80	1	1	1
02/03/2020 17:00	1.3	12.6	2,058.6	0.9	6.20	1	1	1
02/03/2020 18:00	1.3	11.8	2,248.7	0.8	6.70	1	1	1
02/03/2020 19:00	1.4	11.5	2,287.2	0.9	6.90	1	1	1
02/03/2020 20:00	1.4	11.5	2,293.3	0.9	6.90	1	1	1
02/03/2020 21:00	1.3	12.2	2,154.0	0.9	6.50	1	1	1
02/03/2020 22:00	1.3	12.3	2,142.6	0.9	6.40	1	1	1
02/03/2020 23:00	1.3	12.5	2,108.8	0.9	6.30	1	1	1
Average/Sum#:	3.1	13.7	1,671.6	4.3	239.76 #	21 #	18 #	8 #
Minimum:	0.9	11.5	175.5	0.7	0.96	0	0	0
Maximum:	33.1	19.8	2,293.3	48.8	101.30	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/04/2020 00:00	1.3	12.6	2,075.7	0.9	6.20	1	1	1
02/04/2020 01:00	1.3	12.8	2,052.1	0.9	6.20	1	1	1
02/04/2020 02:00	1.3	12.8	2,058.0	0.9	6.20	1	1	1
02/04/2020 03:00	1.3	12.8	2,051.7	0.9	6.20	1	1	1
02/04/2020 04:00	1.3	12.7	2,078.4	0.9	6.20	1	1	1
02/04/2020 05:00	1.5	12.3	2,113.3	1.0	8.50	1	1	1
02/04/2020 06:00	1.4	12.3	2,167.2	1.0	8.70	1	1	1
02/04/2020 07:00	1.3	12.1	2,188.3	0.9	6.60	1	1	1
02/04/2020 08:00	1.2	12.7	2,047.2	0.9	6.10	1	1	1
02/04/2020 09:00	0.9	13.8	1,755.6	0.7	5.30	1	1	0
02/04/2020 10:00	1.0	13.8	1,756.3	0.8	5.30	1	1	0
02/04/2020 11:00	1.0	13.8	1,754.5	0.8	5.30	1	1	0
02/04/2020 12:00	1.0	13.9	1,754.6	0.8	5.30	1	1	0
02/04/2020 13:00	1.0	13.9	1,755.0	0.8	5.30	1	1	0
02/04/2020 14:00	1.0	13.9	1,756.1	0.8	5.30	1	1	0
02/04/2020 15:00	1.0	13.9	1,755.5	0.8	5.30	1	1	0
02/04/2020 16:00	1.1	13.4	1,829.6	0.9	5.50	1	1	1
02/04/2020 17:00	1.2	12.8	2,010.6	0.9	6.00	1	1	1
02/04/2020 18:00	1.3	12.3	2,123.7	0.9	6.40	1	1	1
02/04/2020 19:00	1.3	11.9	2,202.7	0.9	6.60	1	1	1
02/04/2020 20:00	1.3	12.0	2,185.9	0.9	6.60	1	1	1
02/04/2020 21:00	1.3	11.7	2,262.8	0.8	6.80	1	1	1
02/04/2020 22:00	1.3	12.3	2,113.8	0.9	6.30	1	1	1
02/04/2020 23:00	1.3	12.4	2,093.8	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.9	1,997.6	0.9	148.50 #	24 #	24 #	17 #
Minimum:	0.9	11.7	1,754.5	0.7	5.30	1	1	0
Maximum:	1.5	13.9	2,262.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2020 00:00	1.3	12.3	2,119.0	0.9	6.40	1	1	1
02/05/2020 01:00	1.3	12.5	2,085.4	0.9	6.30	1	1	1
02/05/2020 02:00	1.2	12.6	2,050.6	0.9	6.20	1	1	1
02/05/2020 03:00	1.3	12.6	2,048.4	0.9	6.10	1	1	1
02/05/2020 04:00	1.3	12.5	2,072.3	0.9	6.20	1	1	1
02/05/2020 05:00	1.3	12.9	1,990.5	1.0	8.00	1	1	1
02/05/2020 06:00	1.2	12.8	2,014.3	0.9	6.00	1	1	1
02/05/2020 07:00	1.4	11.9	2,208.8	0.9	6.60	1	1	1
02/05/2020 08:00	1.3	12.6	2,071.9	0.9	6.20	1	1	1
02/05/2020 09:00	1.2	13.0	1,945.8	0.9	5.80	1	1	1
02/05/2020 10:00	0.9	13.8	1,605.6	0.7	4.80	1	1	0
02/05/2020 11:00	1.0	13.8	1,608.1	0.8	4.80	1	1	0
02/05/2020 12:00	1.0	13.8	1,655.7	0.8	5.00	1	1	0
02/05/2020 13:00	1.1	13.8	1,663.4	0.9	5.00	1	1	0
02/05/2020 14:00	1.0	13.8	1,589.9	0.8	4.80	1	1	0
02/05/2020 15:00	1.1	13.8	1,673.9	0.9	5.00	1	1	0
02/05/2020 16:00	1.5	13.3	1,828.9	1.2	7.30	1	1	1
02/05/2020 17:00	2.2	12.8	1,971.3	1.6	11.80	1	1	1
02/05/2020 18:00	1.8	11.8	2,189.5	1.2	8.80	1	1	1
02/05/2020 19:00	1.3	12.1	2,132.6	0.9	6.40	1	1	1
02/05/2020 20:00	1.3	11.9	2,164.6	0.9	6.50	1	1	1
02/05/2020 21:00	1.3	12.2	2,106.4	0.9	6.30	1	1	1
02/05/2020 22:00	1.4	12.1	2,121.1	0.9	6.40	1	1	1
02/05/2020 23:00	1.3	12.4	2,057.4	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.8	1,957.3	0.9	152.90 #	24 #	24 #	18 #
Minimum:	0.9	11.8	1,589.9	0.7	4.80	1	1	0
Maximum:	2.2	13.8	2,208.8	1.6	11.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2020 00:00	1.3	12.6	2,029.0	0.9	6.10	1	1	1
02/06/2020 01:00	1.3	12.8	2,007.6	0.9	6.00	1	1	1
02/06/2020 02:00	1.2	12.8	2,003.9	0.9	6.00	1	1	1
02/06/2020 03:00	1.3	12.7	2,029.9	0.9	6.10	1	1	1
02/06/2020 04:00	1.3	12.8	2,015.7	0.9	6.00	1	1	1
02/06/2020 05:00	1.4	12.6	2,041.7	1.0	8.20	1	1	1
02/06/2020 06:00	1.3	12.5	2,074.6	0.9	6.20	1	1	1
02/06/2020 07:00	1.3	12.4	2,096.5	0.9	6.30	1	1	1
02/06/2020 08:00	1.2	13.2	1,923.0	0.9	5.80	1	1	1
02/06/2020 09:00	1.1	13.8	1,694.5	0.9	5.10	1	1	0
02/06/2020 10:00	1.1	13.8	1,681.5	0.9	5.00	1	1	0
02/06/2020 11:00	1.1	13.8	1,675.7	0.9	5.00	1	1	0
02/06/2020 12:00	1.1	13.8	1,589.7	0.9	4.80	1	1	0
02/06/2020 13:00	1.1	13.8	1,682.7	0.9	5.00	1	1	0
02/06/2020 14:00	1.1	13.8	1,658.3	0.9	5.00	1	1	0
02/06/2020 15:00	1.1	13.8	1,545.8	0.9	4.60	1	1	0
02/06/2020 16:00	1.0	13.8	1,563.9	0.8	4.70	1	1	1
02/06/2020 17:00	1.3	12.6	1,999.3	0.9	6.00	1	1	1
02/06/2020 18:00	1.3	12.1	2,104.1	0.9	6.30	1	1	1
02/06/2020 19:00	1.3	12.1	2,091.6	0.9	6.30	1	1	1
02/06/2020 20:00	1.3	12.2	2,114.7	0.9	6.30	1	1	1
02/06/2020 21:00	1.3	12.1	2,117.5	0.9	6.40	1	1	1
02/06/2020 22:00	1.3	12.2	2,093.6	0.9	6.30	1	1	1
02/06/2020 23:00	1.2	13.0	1,932.7	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.0	1,907.0	0.9	139.30 #	24 #	24 #	17 #
Minimum:	1.0	12.1	1,545.8	0.8	4.60	1	1	0
Maximum:	1.4	13.8	2,117.5	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/07/2020 00:00	1.2	13.1	1,911.3	0.9	5.70	1	1	1
02/07/2020 01:00	1.1	13.8	1,698.1	0.9	5.10	1	1	0
02/07/2020 02:00	1.0	13.8	1,561.1	0.8	4.70	1	1	0
02/07/2020 03:00	1.0	13.8	1,557.0	0.8	4.70	1	1	0
02/07/2020 04:00	1.0	13.8	1,526.6	0.8	4.60	1	1	0
02/07/2020 05:00	1.1	13.7	1,557.5	0.9	4.70	1	1	1
02/07/2020 06:00	1.2	12.7	2,025.3	0.9	6.10	1	1	1
02/07/2020 07:00	1.3	12.5	2,081.2	0.9	6.20	1	1	1
02/07/2020 08:00	1.2	13.0	1,939.4	0.9	5.80	1	1	1
02/07/2020 09:00	1.1	13.8	1,649.6	0.9	4.90	1	1	0
02/07/2020 10:00	1.1	13.8	1,660.6	0.9	5.00	1	1	0
02/07/2020 11:00	1.1	13.8	1,682.7	0.9	5.00	1	1	0
02/07/2020 12:00	1.1	13.8	1,685.2	0.9	5.10	1	1	0
02/07/2020 13:00	1.1	13.8	1,688.1	0.9	5.10	1	1	0
02/07/2020 14:00	1.1	13.8	1,660.8	0.9	5.00	1	1	0
02/07/2020 15:00	1.1	13.8	1,677.3	0.9	5.00	1	1	0
02/07/2020 16:00	1.0	13.8	1,588.9	0.8	4.80	1	1	1
02/07/2020 17:00	1.3	12.5	2,010.9	0.9	6.00	1	1	1
02/07/2020 18:00	1.3	12.0	2,112.5	0.9	6.30	1	1	1
02/07/2020 19:00	1.4	12.1	2,091.3	0.9	6.30	1	1	1
02/07/2020 20:00	1.3	12.1	2,106.1	0.9	6.30	1	1	1
02/07/2020 21:00	1.3	12.1	2,106.4	0.9	6.30	1	1	1
02/07/2020 22:00	1.3	12.4	2,051.2	0.9	6.20	1	1	1
02/07/2020 23:00	2.7	13.9	1,282.5	2.3	4.94	1	0	1
Average/Sum#:	1.2	13.2	1,788.0	0.9	129.84 #	24 #	23 #	13 #
Minimum:	1.0	12.0	1,282.5	0.8	4.60	1	0	0
Maximum:	2.7	13.9	2,112.5	2.3	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/10/2020 03:00	34.9	17.6	463.3	62.4	74.62	1	0	0
02/10/2020 04:00	28.1	15.7	707.0	31.9	82.70	1	0	0
02/10/2020 05:00	10.1	14.4	1,158.6	9.2	39.40	1	0	0
02/10/2020 06:00	1.0	13.8	1,696.7	0.8	5.10	1	1	0
02/10/2020 07:00	1.0	13.8	1,698.9	0.8	5.10	1	1	0
02/10/2020 08:00	1.0	13.9	1,651.9	0.8	5.00	1	1	0
02/10/2020 09:00	1.0	13.9	1,650.7	0.8	5.00	1	1	0
02/10/2020 10:00	1.0	13.9	1,636.9	0.8	4.90	1	1	0
02/10/2020 11:00	1.0	13.9	1,668.8	0.8	5.00	1	1	0
02/10/2020 12:00	1.1	13.9	1,666.9	0.9	5.00	1	1	0
02/10/2020 13:00	1.0	13.9	1,654.2	0.8	5.00	1	1	0
02/10/2020 14:00	1.0	13.9	1,648.3	0.8	4.90	1	1	0
02/10/2020 15:00	1.1	13.9	1,655.4	0.9	5.00	1	1	0
02/10/2020 16:00	1.1	13.9	1,685.7	0.9	5.10	1	1	0
02/10/2020 17:00	1.1	13.3	1,836.0	0.9	5.50	1	1	1
02/10/2020 18:00	1.3	12.5	2,049.4	0.9	6.10	1	1	1
02/10/2020 19:00	1.3	12.4	2,065.7	0.9	6.20	1	1	1
02/10/2020 20:00	1.4	12.2	2,109.4	0.9	6.30	1	1	1
02/10/2020 21:00	1.3	12.2	2,121.9	0.9	6.40	1	1	1
02/10/2020 22:00	1.3	12.3	2,101.9	0.9	6.30	1	1	1
02/10/2020 23:00	1.3	12.6	2,039.4	0.9	6.10	1	1	1
Average/Sum#:	4.4	13.7	1,665.1	5.7	294.72 #	21 #	18 #	7 #
Minimum:	1.0	12.2	463.3	0.8	4.90	0	0	0
Maximum:	34.9	17.6	2,121.9	62.4	82.70	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2020 00:00	1.2	13.1	1,916.2	0.9	5.70	1	1	1
02/11/2020 01:00	0.9	13.8	1,566.8	0.7	4.70	1	1	0
02/11/2020 02:00	1.0	13.9	1,463.8	0.8	4.40	1	1	0
02/11/2020 03:00	1.0	13.9	1,532.0	0.8	4.60	1	1	0
02/11/2020 04:00	1.0	13.8	1,506.6	0.8	4.50	1	1	0
02/11/2020 05:00	0.9	13.8	1,635.4	0.7	4.90	1	1	0
02/11/2020 06:00	0.9	13.8	1,637.0	0.7	4.90	1	1	0
02/11/2020 07:00	0.9	13.8	1,569.1	0.7	4.70	1	1	0
02/11/2020 08:00	0.8	13.9	1,379.6	0.7	2.80	1	1	0
02/11/2020 09:00	1.0	13.9	1,549.0	0.8	4.60	1	1	0
02/11/2020 10:00	1.0	13.9	1,601.2	0.8	4.80	1	1	0
02/11/2020 11:00	1.0	13.9	1,621.6	0.8	4.90	1	1	0
02/11/2020 12:00	1.0	13.9	1,661.6	0.8	5.00	1	1	0
02/11/2020 13:00	1.1	13.9	1,679.3	0.9	5.00	1	1	0
02/11/2020 14:00	1.1	13.9	1,648.6	0.9	4.90	1	1	0
02/11/2020 15:00	1.0	13.9	1,530.3	0.8	4.60	1	1	0
02/11/2020 16:00	0.9	13.9	1,473.9	0.8	4.40	1	1	0
02/11/2020 17:00	0.8	13.9	1,623.8	0.7	3.20	1	1	0
02/11/2020 18:00	1.2	13.2	1,849.1	0.9	5.50	1	1	1
02/11/2020 19:00	1.4	11.9	2,163.5	0.9	6.50	1	1	1
02/11/2020 20:00	1.4	11.8	2,180.5	0.9	6.50	1	1	1
02/11/2020 21:00	1.4	11.7	2,176.4	0.9	6.50	1	1	1
02/11/2020 22:00	1.3	11.8	2,149.9	0.8	6.40	1	1	1
02/11/2020 23:00	1.3	12.1	2,086.9	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.4	1,716.8	0.8	120.30 #	24 #	24 #	7 #
Minimum:	0.8	11.7	1,379.6	0.7	2.80	1	1	0
Maximum:	1.4	13.9	2,180.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2020 00:00	1.2	12.8	1,923.8	0.9	5.80	1	1	1
02/12/2020 01:00	0.9	13.9	1,562.3	0.8	4.70	1	1	0
02/12/2020 02:00	1.0	13.8	1,541.9	0.8	4.60	1	1	0
02/12/2020 03:00	1.0	13.8	1,500.9	0.8	4.50	1	1	0
02/12/2020 04:00	0.8	13.8	1,647.0	0.7	3.30	1	1	0
02/12/2020 05:00	1.0	13.8	1,648.5	0.8	4.90	1	1	0
02/12/2020 06:00	1.0	13.8	1,613.5	0.8	4.80	1	1	0
02/12/2020 07:00	1.0	13.8	1,553.4	0.8	4.70	1	1	0
02/12/2020 08:00	1.0	13.8	1,690.5	0.8	5.10	1	1	0
02/12/2020 09:00	1.0	13.8	1,677.1	0.8	5.00	1	1	0
02/12/2020 10:00	1.0	13.8	1,668.5	0.8	5.00	1	1	0
02/12/2020 11:00	1.0	13.9	1,671.9	0.8	5.00	1	1	0
02/12/2020 12:00	1.0	13.9	1,636.8	0.8	4.90	1	1	0
02/12/2020 13:00	1.1	13.9	1,680.8	0.9	5.00	1	1	0
02/12/2020 14:00	1.0	13.9	1,619.0	0.8	4.90	1	1	0
02/12/2020 15:00	1.0	13.9	1,613.1	0.8	4.80	1	1	0
02/12/2020 16:00	0.9	13.9	1,405.6	0.8	4.20	1	1	0
02/12/2020 17:00	0.8	13.9	1,628.4	0.7	3.30	1	1	0
02/12/2020 18:00	1.0	13.9	1,699.1	0.8	5.10	1	1	1
02/12/2020 19:00	1.3	12.4	2,057.1	0.9	6.20	1	1	1
02/12/2020 20:00	1.4	11.7	2,196.0	0.9	6.60	1	1	1
02/12/2020 21:00	1.4	11.9	2,156.1	0.9	6.50	1	1	1
02/12/2020 22:00	1.3	12.0	2,142.0	0.9	6.40	1	1	1
02/12/2020 23:00	1.3	12.3	2,077.8	0.9	6.20	1	1	1
Average/Sum#:	1.1	13.4	1,733.8	0.8	121.50 #	24 #	24 #	7 #
Minimum:	0.8	11.7	1,405.6	0.7	3.30	1	1	0
Maximum:	1.4	13.9	2,196.0	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2020 00:00	1.3	12.3	2,060.0	0.9	6.20	1	1	1
02/13/2020 01:00	1.3	12.5	2,025.5	0.9	6.10	1	1	1
02/13/2020 02:00	1.3	12.6	2,033.8	0.9	6.10	1	1	1
02/13/2020 03:00	1.3	12.5	2,037.4	0.9	6.10	1	1	1
02/13/2020 04:00	1.3	12.5	2,035.8	0.9	6.10	1	1	1
02/13/2020 05:00	1.1	12.5	2,044.6	0.8	6.10	1	1	1
02/13/2020 06:00	1.4	12.1	2,157.5	0.9	6.50	1	1	1
02/13/2020 07:00	1.3	12.3	2,088.9	0.9	6.30	1	1	1
02/13/2020 08:00	1.2	13.1	1,917.0	0.9	5.80	1	1	1
02/13/2020 09:00	1.0	13.8	1,657.3	0.8	5.00	1	1	0
02/13/2020 10:00	1.0	13.8	1,643.1	0.8	4.90	1	1	0
02/13/2020 11:00	1.1	13.8	1,649.8	0.9	4.90	1	1	0
02/13/2020 12:00	1.0	13.8	1,677.2	0.8	5.00	1	1	0
02/13/2020 13:00	1.0	13.8	1,616.3	0.8	4.80	1	1	0
02/13/2020 14:00	1.0	13.8	1,632.9	0.8	4.90	1	1	0
02/13/2020 15:00	1.0	13.8	1,583.2	0.8	4.70	1	1	0
02/13/2020 16:00	1.0	13.8	1,593.6	0.8	4.80	1	1	1
02/13/2020 17:00	1.3	12.4	2,045.2	0.9	6.10	1	1	1
02/13/2020 18:00	1.4	12.0	2,137.4	0.9	6.40	1	1	1
02/13/2020 19:00	1.4	11.9	2,154.5	0.9	6.50	1	1	1
02/13/2020 20:00	1.3	11.9	2,146.4	0.9	6.40	1	1	1
02/13/2020 21:00	1.4	12.0	2,143.3	0.9	6.40	1	1	1
02/13/2020 22:00	1.3	12.2	2,111.2	0.9	6.30	1	1	1
02/13/2020 23:00	1.3	12.2	2,101.8	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.8	1,928.9	0.9	138.70 #	24 #	24 #	17 #
Minimum:	1.0	11.9	1,583.2	0.8	4.70	1	1	0
Maximum:	1.4	13.8	2,157.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2020 00:00	2.1	13.6	1,577.0	1.7	9.22	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.1	13.6	1,577.0	1.7	9.22 #	1 #	0 #	1 #
Minimum:	2.1	13.6	1,577.0	1.7	9.22	0	0	0
Maximum:	2.1	13.6	1,577.0	1.7	9.22	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 15:00	35.6	17.3	476.4	58.3	97.28	1	0	0
02/17/2020 16:00	15.9	14.8	1,059.7	15.4	60.40	1	0	0
02/17/2020 17:00	0.9	13.8	1,688.1	0.7	5.10	1	1	0
02/17/2020 18:00	1.1	13.8	1,736.9	0.9	5.20	1	1	1
02/17/2020 19:00	1.3	12.8	2,027.7	0.9	6.10	1	1	1
02/17/2020 20:00	1.3	11.9	2,156.5	0.9	6.50	1	1	1
02/17/2020 21:00	1.3	12.0	2,146.0	0.9	6.40	1	1	1
02/17/2020 22:00	1.3	12.1	2,124.4	0.9	6.40	1	1	1
02/17/2020 23:00	1.3	12.4	2,071.6	0.9	6.20	1	1	1
Average/Sum#:	6.7	13.4	1,720.8	8.9	199.58 #	9 #	7 #	6 #
Minimum:	0.9	11.9	476.4	0.7	5.10	0	0	0
Maximum:	35.6	17.3	2,156.5	58.3	97.28	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/18/2020 00:00	1.3	12.4	2,066.5	0.9	6.20	1	1	1
02/18/2020 01:00	1.3	12.4	2,066.8	0.9	6.20	1	1	1
02/18/2020 02:00	1.3	12.6	2,040.1	0.9	6.10	1	1	1
02/18/2020 03:00	1.3	12.5	2,066.0	0.9	6.20	1	1	1
02/18/2020 04:00	1.3	12.5	2,068.7	0.9	6.20	1	1	1
02/18/2020 05:00	1.2	12.3	2,092.3	0.8	6.30	1	1	1
02/18/2020 06:00	1.3	12.2	2,133.3	0.9	6.40	1	1	1
02/18/2020 07:00	1.3	12.2	2,122.7	0.9	6.40	1	1	1
02/18/2020 08:00	1.3	12.4	2,064.2	0.9	6.20	1	1	1
02/18/2020 09:00	1.1	13.0	1,941.2	0.8	5.80	1	1	1
02/18/2020 10:00	1.2	13.1	1,937.3	0.9	5.80	1	1	1
02/18/2020 11:00	1.3	13.1	1,939.2	1.0	7.80	1	1	1
02/18/2020 12:00	1.2	13.0	1,938.0	0.9	5.80	1	1	1
02/18/2020 13:00	1.1	13.5	1,762.5	0.9	5.30	1	1	1
02/18/2020 14:00	0.8	13.8	1,407.4	0.7	2.80	1	1	0
02/18/2020 15:00	0.8	13.8	1,496.5	0.7	3.00	1	1	1
02/18/2020 16:00	1.3	12.7	2,010.6	0.9	6.00	1	1	1
02/18/2020 17:00	1.3	12.0	2,148.3	0.9	6.40	1	1	1
02/18/2020 18:00	1.4	11.9	2,168.1	0.9	6.50	1	1	1
02/18/2020 19:00	1.4	11.7	2,225.2	0.9	6.70	1	1	1
02/18/2020 20:00	1.4	11.6	2,244.2	0.9	6.70	1	1	1
02/18/2020 21:00	1.4	11.8	2,171.7	0.9	6.50	1	1	1
02/18/2020 22:00	1.3	12.0	2,124.2	0.9	6.40	1	1	1
02/18/2020 23:00	1.3	12.4	2,064.9	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.5	2,012.5	0.9	143.90 #	24 #	24 #	23 #
Minimum:	0.8	11.6	1,407.4	0.7	2.80	1	1	0
Maximum:	1.4	13.8	2,244.2	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/19/2020 00:00	1.4	11.7	2,249.6	0.9	6.70	1	1	1
02/19/2020 01:00	1.3	12.6	2,031.7	0.9	6.10	1	1	1
02/19/2020 02:00	1.2	13.1	1,922.5	0.9	5.80	1	1	1
02/19/2020 03:00	1.2	13.1	1,928.7	0.9	5.80	1	1	1
02/19/2020 04:00	1.3	12.4	2,077.8	0.9	6.20	1	1	1
02/19/2020 05:00	1.4	12.4	2,109.0	1.0	8.40	1	1	1
02/19/2020 06:00	1.3	12.3	2,116.3	0.9	6.30	1	1	1
02/19/2020 07:00	1.3	11.8	2,208.7	0.8	6.60	1	1	1
02/19/2020 08:00	1.2	12.8	1,979.8	0.9	5.90	1	1	1
02/19/2020 09:00	1.2	13.0	1,893.9	0.9	5.70	1	1	1
02/19/2020 10:00	1.2	13.1	1,904.0	0.9	5.70	1	1	1
02/19/2020 11:00	1.2	13.1	1,905.4	0.9	5.70	1	1	1
02/19/2020 12:00	1.2	13.1	1,902.5	0.9	5.70	1	1	1
02/19/2020 13:00	1.3	13.0	1,911.6	1.0	7.60	1	1	1
02/19/2020 14:00	1.2	13.0	1,914.0	0.9	5.70	1	1	1
02/19/2020 15:00	1.2	13.0	1,909.1	0.9	5.70	1	1	1
02/19/2020 16:00	1.3	12.5	2,010.2	0.9	6.00	1	1	1
02/19/2020 17:00	1.4	11.9	2,143.0	0.9	6.40	1	1	1
02/19/2020 18:00	1.4	11.8	2,145.6	0.9	6.40	1	1	1
02/19/2020 19:00	1.4	11.5	2,223.4	0.9	6.70	1	1	1
02/19/2020 20:00	1.4	11.6	2,201.3	0.9	6.60	1	1	1
02/19/2020 21:00	1.4	11.6	2,192.1	0.9	6.60	1	1	1
02/19/2020 22:00	1.3	12.3	2,054.7	0.9	6.20	1	1	1
02/19/2020 23:00	1.3	12.5	2,018.0	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.5	2,039.7	0.9	150.60 #	24 #	24 #	24 #
Minimum:	1.2	11.5	1,893.9	0.8	5.70	1	1	1
Maximum:	1.4	13.1	2,249.6	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2020 00:00	1.3	12.7	1,994.1	0.9	6.00	1	1	1
02/20/2020 01:00	1.3	12.6	2,011.8	0.9	6.00	1	1	1
02/20/2020 02:00	1.3	12.5	2,012.7	0.9	6.00	1	1	1
02/20/2020 03:00	1.3	12.5	2,011.7	0.9	6.00	1	1	1
02/20/2020 04:00	1.3	12.5	2,011.9	0.9	6.00	1	1	1
02/20/2020 05:00	1.3	12.5	2,026.7	0.9	6.10	1	1	1
02/20/2020 06:00	1.3	12.4	2,046.5	0.9	6.10	1	1	1
02/20/2020 07:00	1.3	12.4	2,052.1	0.9	6.20	1	1	1
02/20/2020 08:00	1.3	12.5	2,022.8	0.9	6.10	1	1	1
02/20/2020 09:00	1.2	13.0	1,907.2	0.9	5.70	1	1	1
02/20/2020 10:00	1.2	13.0	1,906.6	0.9	5.70	1	1	1
02/20/2020 11:00	1.2	13.0	1,906.0	0.9	5.70	1	1	1
02/20/2020 12:00	1.2	13.0	1,908.2	0.9	5.70	1	1	1
02/20/2020 13:00	1.3	13.0	1,907.3	1.0	7.60	1	1	1
02/20/2020 14:00	1.3	12.9	1,924.7	1.0	7.70	1	1	1
02/20/2020 15:00	1.3	12.7	1,969.4	0.9	5.90	1	1	1
02/20/2020 16:00	1.3	12.3	2,056.7	0.9	6.20	1	1	1
02/20/2020 17:00	1.4	12.2	2,066.3	0.9	6.20	1	1	1
02/20/2020 18:00	1.3	12.2	2,068.5	0.9	6.20	1	1	1
02/20/2020 19:00	1.3	12.1	2,089.9	0.9	6.30	1	1	1
02/20/2020 20:00	1.3	12.0	2,112.5	0.9	6.30	1	1	1
02/20/2020 21:00	1.4	12.0	2,127.1	0.9	6.40	1	1	1
02/20/2020 22:00	1.4	12.0	2,114.6	0.9	6.30	1	1	1
02/20/2020 23:00	1.3	12.4	2,042.5	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.5	2,012.4	0.9	148.50 #	24 #	24 #	24 #
Minimum:	1.2	12.0	1,906.0	0.9	5.70	1	1	1
Maximum:	1.4	13.0	2,127.1	1.0	7.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/21/2020 00:00	1.2	12.9	1,885.5	0.9	5.70	1	1	1
02/21/2020 01:00	0.9	13.8	1,507.6	0.7	4.50	1	1	0
02/21/2020 02:00	0.9	13.8	1,450.8	0.7	4.40	1	1	0
02/21/2020 03:00	1.0	13.8	1,534.4	0.8	4.60	1	1	0
02/21/2020 04:00	1.0	13.8	1,650.6	0.8	5.00	1	1	0
02/21/2020 05:00	0.9	13.8	1,556.8	0.7	4.70	1	1	0
02/21/2020 06:00	0.9	13.8	1,647.8	0.7	4.90	1	1	0
02/21/2020 07:00	0.9	13.7	1,610.7	0.7	4.80	1	1	0
02/21/2020 08:00	0.9	13.7	1,520.8	0.7	4.60	1	1	0
02/21/2020 09:00	1.0	13.7	1,643.6	0.8	4.90	1	1	0
02/21/2020 10:00	0.9	13.8	1,590.4	0.7	4.80	1	1	0
02/21/2020 11:00	1.0	13.8	1,579.0	0.8	4.70	1	1	0
02/21/2020 12:00	1.0	13.7	1,644.4	0.8	4.90	1	1	0
02/21/2020 13:00	1.0	13.7	1,642.8	0.8	4.90	1	1	0
02/21/2020 14:00	1.0	13.7	1,666.4	0.8	5.00	1	1	0
02/21/2020 15:00	1.0	13.7	1,654.8	0.8	5.00	1	1	0
02/21/2020 16:00	1.0	13.7	1,665.5	0.8	5.00	1	1	1
02/21/2020 17:00	1.3	12.6	1,969.1	0.9	5.90	1	1	1
02/21/2020 18:00	1.4	12.0	2,074.9	0.9	6.20	1	1	1
02/21/2020 19:00	1.3	12.2	2,045.6	0.9	6.10	1	1	1
02/21/2020 20:00	1.4	12.1	2,057.5	0.9	6.20	1	1	1
02/21/2020 21:00	1.3	12.3	2,033.5	0.9	6.10	1	1	1
02/21/2020 22:00	1.4	12.1	2,065.4	0.9	6.20	1	1	1
02/21/2020 23:00	2.6	13.9	1,250.8	2.2	4.80	1	0	1
Average/Sum#:	1.1	13.3	1,706.2	0.9	123.90 #	24 #	23 #	9 #
Minimum:	0.9	12.0	1,250.8	0.7	4.40	1	0	0
Maximum:	2.6	13.9	2,074.9	2.2	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/25/2020 14:00	37.5	17.4	455.6	63.2	71.15	1	0	0
02/25/2020 15:00	30.7	15.3	804.4	32.3	95.70	1	0	0
02/25/2020 16:00	0.9	13.8	1,602.6	0.7	4.80	1	1	0
02/25/2020 17:00	1.1	13.8	1,522.9	0.9	4.60	1	1	1
02/25/2020 18:00	2.0	12.7	1,961.2	1.4	9.80	1	1	1
02/25/2020 19:00	1.2	11.9	2,107.0	0.8	6.30	1	1	1
02/25/2020 20:00	1.4	11.8	2,141.5	0.9	6.40	1	1	1
02/25/2020 21:00	1.4	11.9	2,122.5	0.9	6.40	1	1	1
02/25/2020 22:00	1.4	11.9	2,115.1	0.9	6.30	1	1	1
02/25/2020 23:00	1.4	12.0	2,106.7	0.9	6.30	1	1	1
Average/Sum#:	7.9	13.3	1,694.0	10.3	217.75 #	10 #	8 #	7 #
Minimum:	0.9	11.8	455.6	0.7	4.60	0	0	0
Maximum:	37.5	17.4	2,141.5	63.2	95.70	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/26/2020 00:00	1.3	12.4	2,020.7	0.9	6.10	1	1	1
02/26/2020 01:00	1.3	12.3	2,021.8	0.9	6.10	1	1	1
02/26/2020 02:00	1.3	12.3	2,020.8	0.9	6.10	1	1	1
02/26/2020 03:00	1.3	12.4	2,016.4	0.9	6.00	1	1	1
02/26/2020 04:00	1.3	12.5	2,013.9	0.9	6.00	1	1	1
02/26/2020 05:00	1.3	12.5	2,005.6	0.9	6.00	1	1	1
02/26/2020 06:00	1.3	12.6	2,000.6	0.9	6.00	1	1	1
02/26/2020 07:00	1.3	12.7	1,987.0	0.9	6.00	1	1	1
02/26/2020 08:00	2.8	14.2	1,195.8	2.5	5.08	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	12.7	1,920.3	1.1	53.38 #	9 #	8 #	9 #
Minimum:	1.3	12.3	1,195.8	0.9	5.08	0	0	0
Maximum:	2.8	14.2	2,021.8	2.5	6.10	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/27/2020 02:00	27.2	17.8	412.9	51.8	43.40	1	0	0
02/27/2020 03:00	17.7	15.0	954.0	17.7	62.00	1	0	0
02/27/2020 04:00	0.9	13.7	1,724.7	0.7	5.20	1	1	0
02/27/2020 05:00	1.0	13.7	1,726.4	0.8	5.20	1	1	0
02/27/2020 06:00	1.0	13.7	1,720.7	0.8	5.20	1	1	0
02/27/2020 07:00	1.0	13.7	1,725.1	0.8	5.20	1	1	0
02/27/2020 08:00	1.0	13.7	1,722.2	0.8	5.20	1	1	0
02/27/2020 09:00	1.1	13.7	1,726.6	0.9	5.20	1	1	0
02/27/2020 10:00	1.2	13.7	1,727.3	1.0	6.90	1	1	0
02/27/2020 11:00	1.2	13.7	1,723.8	1.0	6.90	1	1	0
02/27/2020 12:00	1.1	13.7	1,706.6	0.9	5.10	1	1	0
02/27/2020 13:00	1.1	13.7	1,656.0	0.9	5.00	1	1	0
02/27/2020 14:00	1.1	13.7	1,645.9	0.9	4.90	1	1	0
02/27/2020 15:00	1.1	13.7	1,633.4	0.9	4.90	1	1	0
02/27/2020 16:00	1.5	13.1	1,809.7	1.1	7.20	1	1	1
02/27/2020 17:00	2.3	12.2	2,033.9	1.6	12.20	1	1	1
02/27/2020 18:00	2.4	12.2	2,035.4	1.6	12.20	1	1	1
02/27/2020 19:00	2.4	12.2	2,038.8	1.6	12.20	1	1	1
02/27/2020 20:00	2.5	12.1	2,078.5	1.7	12.50	1	1	1
02/27/2020 21:00	2.5	12.0	2,080.8	1.7	12.50	1	1	1
02/27/2020 22:00	2.5	12.0	2,085.8	1.7	12.50	1	1	1
02/27/2020 23:00	2.2	12.5	1,993.6	1.5	12.00	1	1	1
Average/Sum#:	3.5	13.4	1,725.6	4.2	263.60 #	22 #	20 #	8 #
Minimum:	0.9	12.0	412.9	0.7	4.90	0	0	0
Maximum:	27.2	17.8	2,085.8	51.8	62.00	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2020 00:00	1.7	13.0	1,887.0	1.3	9.40	1	1	1
02/28/2020 01:00	1.1	13.7	1,557.1	0.9	4.70	1	1	0
02/28/2020 02:00	1.1	13.7	1,468.7	0.9	4.40	1	1	0
02/28/2020 03:00	1.1	13.7	1,493.7	0.9	4.50	1	1	0
02/28/2020 04:00	1.1	13.7	1,487.3	0.9	4.50	1	1	0
02/28/2020 05:00	1.0	13.7	1,616.7	0.8	4.90	1	1	0
02/28/2020 06:00	1.1	13.7	1,654.1	0.9	5.00	1	1	0
02/28/2020 07:00	1.0	13.7	1,614.9	0.8	4.80	1	1	0
02/28/2020 08:00	1.0	13.7	1,520.5	0.8	4.60	1	1	0
02/28/2020 09:00	1.0	13.7	1,506.4	0.8	4.50	1	1	0
02/28/2020 10:00	1.0	13.8	1,450.9	0.8	4.40	1	1	0
02/28/2020 11:00	1.0	13.8	1,484.2	0.8	4.50	1	1	0
02/28/2020 12:00	1.1	13.8	1,544.1	0.9	4.60	1	1	0
02/28/2020 13:00	1.0	13.8	1,577.6	0.8	4.70	1	1	0
02/28/2020 14:00	1.0	13.8	1,423.0	0.8	4.30	1	1	0
02/28/2020 15:00	1.0	13.7	1,534.4	0.8	4.60	1	1	1
02/28/2020 16:00	1.3	12.3	1,998.1	0.9	6.00	1	1	1
02/28/2020 17:00	1.4	12.1	2,028.7	0.9	6.10	1	1	1
02/28/2020 18:00	1.3	12.2	2,014.6	0.9	6.00	1	1	1
02/28/2020 19:00	1.4	12.2	2,024.8	0.9	6.10	1	1	1
02/28/2020 20:00	1.3	12.3	2,006.3	0.9	6.00	1	1	1
02/28/2020 21:00	1.4	12.2	2,038.9	0.9	6.10	1	1	1
02/28/2020 22:00	1.3	12.3	2,014.9	0.9	6.00	1	1	1
02/28/2020 23:00	2.1	14.0	1,212.1	1.8	4.42	1	0	1
Average/Sum#:	1.2	13.3	1,673.3	0.9	125.12 #	24 #	23 #	10 #
Minimum:	1.0	12.1	1,212.1	0.8	4.30	1	0	0
Maximum:	2.1	14.0	2,038.9	1.8	9.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 15:00	37.1	17.5	437.3	64.4	65.27	1	0	0
03/03/2020 16:00	30.3	15.4	820.8	32.5	98.50	1	0	0
03/03/2020 17:00	0.9	13.7	1,578.6	0.7	4.70	1	1	1
03/03/2020 18:00	1.4	12.0	2,074.2	0.9	6.20	1	1	1
03/03/2020 19:00	1.4	11.6	2,145.8	0.9	6.40	1	1	1
03/03/2020 20:00	1.3	11.6	2,146.2	0.8	6.40	1	1	1
03/03/2020 21:00	1.4	11.6	2,149.4	0.9	6.40	1	1	1
03/03/2020 22:00	1.4	11.8	2,115.9	0.9	6.30	1	1	1
03/03/2020 23:00	1.4	12.0	2,083.0	0.9	6.20	1	1	1
Average/Sum#:	8.5	13.0	1,727.9	11.4	206.37 #	9 #	7 #	7 #
Minimum:	0.9	11.6	437.3	0.7	4.70	0	0	0
Maximum:	37.1	17.5	2,149.4	64.4	98.50	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2020 00:00	1.3	12.3	2,029.8	0.9	6.10	1	1	1
03/04/2020 01:00	1.3	12.3	2,018.3	0.9	6.10	1	1	1
03/04/2020 02:00	1.3	12.6	1,967.9	0.9	5.90	1	1	1
03/04/2020 03:00	1.3	12.7	1,963.5	0.9	5.90	1	1	1
03/04/2020 04:00	1.3	12.4	2,016.0	0.9	6.00	1	1	1
03/04/2020 05:00	1.2	12.4	2,014.7	0.8	6.00	1	1	1
03/04/2020 06:00	1.3	12.4	2,013.8	0.9	6.00	1	1	1
03/04/2020 07:00	1.3	12.4	2,002.8	0.9	6.00	1	1	1
03/04/2020 08:00	0.9	13.7	1,479.7	0.7	4.40	1	1	1
03/04/2020 09:00	0.9	13.8	1,353.7	0.7	4.10	1	1	0
03/04/2020 10:00	0.9	13.8	1,354.8	0.7	4.10	1	1	0
03/04/2020 11:00	1.1	13.8	1,549.6	0.9	4.60	1	1	0
03/04/2020 12:00	1.1	13.8	1,675.0	0.9	5.00	1	1	0
03/04/2020 13:00	1.0	13.8	1,511.4	0.8	4.50	1	1	0
03/04/2020 14:00	1.0	13.8	1,600.8	0.8	4.80	1	1	0
03/04/2020 15:00	1.0	13.8	1,577.7	0.8	4.70	1	1	0
03/04/2020 16:00	0.9	13.8	1,521.5	0.7	4.60	1	1	1
03/04/2020 17:00	1.4	12.3	2,009.6	1.0	8.00	1	1	1
03/04/2020 18:00	1.3	12.2	2,034.2	0.9	6.10	1	1	1
03/04/2020 19:00	1.3	12.2	2,030.5	0.9	6.10	1	1	1
03/04/2020 20:00	1.4	11.9	2,101.7	0.9	6.30	1	1	1
03/04/2020 21:00	1.4	11.8	2,112.9	0.9	6.30	1	1	1
03/04/2020 22:00	1.4	11.9	2,098.3	0.9	6.30	1	1	1
03/04/2020 23:00	1.3	12.2	2,041.8	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.8	1,836.7	0.9	134.00 #	24 #	24 #	17 #
Minimum:	0.9	11.8	1,353.7	0.7	4.10	1	1	0
Maximum:	1.4	13.8	2,112.9	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/05/2020 00:00	1.3	12.6	1,966.1	0.9	5.90	1	1	1
03/05/2020 01:00	1.3	12.6	1,952.8	0.9	5.90	1	1	1
03/05/2020 02:00	1.3	12.6	1,960.2	0.9	5.90	1	1	1
03/05/2020 03:00	1.3	12.6	1,960.5	0.9	5.90	1	1	1
03/05/2020 04:00	1.3	12.2	2,034.1	0.9	6.10	1	1	1
03/05/2020 05:00	1.4	12.2	2,034.5	0.9	6.10	1	1	1
03/05/2020 06:00	1.3	12.3	2,021.4	0.9	6.10	1	1	1
03/05/2020 07:00	1.2	12.6	1,959.5	0.9	5.90	1	1	1
03/05/2020 08:00	1.0	13.7	1,597.3	0.8	4.80	1	1	0
03/05/2020 09:00	1.1	13.7	1,662.5	0.9	5.00	1	1	0
03/05/2020 10:00	1.1	13.7	1,668.7	0.9	5.00	1	1	0
03/05/2020 11:00	1.1	13.7	1,657.3	0.9	5.00	1	1	0
03/05/2020 12:00	1.1	13.7	1,630.3	0.9	4.90	1	1	0
03/05/2020 13:00	1.1	13.7	1,666.1	0.9	5.00	1	1	0
03/05/2020 14:00	1.1	13.6	1,563.5	0.9	4.70	1	1	0
03/05/2020 15:00	1.1	13.7	1,497.7	0.9	4.50	1	1	0
03/05/2020 16:00	1.0	13.7	1,458.4	0.8	4.40	1	1	1
03/05/2020 17:00	1.3	12.3	1,979.7	0.9	5.90	1	1	1
03/05/2020 18:00	1.4	12.0	2,041.5	0.9	6.10	1	1	1
03/05/2020 19:00	1.4	12.1	2,040.7	0.9	6.10	1	1	1
03/05/2020 20:00	1.3	12.2	2,029.4	0.9	6.10	1	1	1
03/05/2020 21:00	1.4	12.1	2,059.0	0.9	6.20	1	1	1
03/05/2020 22:00	1.4	12.1	2,058.2	0.9	6.20	1	1	1
03/05/2020 23:00	1.3	12.5	1,965.0	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.8	1,852.7	0.9	133.60 #	24 #	24 #	16 #
Minimum:	1.0	12.0	1,458.4	0.8	4.40	1	1	0
Maximum:	1.4	13.7	2,059.0	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2020 00:00	1.4	12.2	2,036.4	0.9	6.10	1	1	1
03/06/2020 01:00	1.4	12.2	2,039.3	0.9	6.10	1	1	1
03/06/2020 02:00	1.3	12.5	1,968.2	0.9	5.90	1	1	1
03/06/2020 03:00	1.3	12.4	2,000.8	0.9	6.00	1	1	1
03/06/2020 04:00	1.3	12.3	2,013.8	0.9	6.00	1	1	1
03/06/2020 05:00	1.5	12.2	2,032.9	1.0	8.10	1	1	1
03/06/2020 06:00	1.3	12.3	2,023.9	0.9	6.10	1	1	1
03/06/2020 07:00	1.3	12.4	2,004.9	0.9	6.00	1	1	1
03/06/2020 08:00	1.3	12.7	1,919.4	0.9	5.80	1	1	1
03/06/2020 09:00	1.0	13.7	1,604.2	0.8	4.80	1	1	0
03/06/2020 10:00	1.1	13.7	1,647.6	0.9	4.90	1	1	0
03/06/2020 11:00	1.1	13.7	1,663.3	0.9	5.00	1	1	0
03/06/2020 12:00	1.1	13.7	1,633.4	0.9	4.90	1	1	0
03/06/2020 13:00	1.1	13.7	1,655.1	0.9	5.00	1	1	0
03/06/2020 14:00	1.1	13.7	1,619.0	0.9	4.90	1	1	0
03/06/2020 15:00	1.1	13.7	1,601.2	0.9	4.80	1	1	0
03/06/2020 16:00	0.9	13.7	1,497.5	0.7	4.50	1	1	1
03/06/2020 17:00	1.4	12.4	1,977.0	1.0	7.90	1	1	1
03/06/2020 18:00	1.4	12.2	2,017.0	0.9	6.10	1	1	1
03/06/2020 19:00	1.4	12.2	2,021.3	0.9	6.10	1	1	1
03/06/2020 20:00	1.4	11.9	2,080.6	0.9	6.20	1	1	1
03/06/2020 21:00	1.4	11.8	2,105.2	0.9	6.30	1	1	1
03/06/2020 22:00	1.4	12.0	2,069.3	0.9	6.20	1	1	1
03/06/2020 23:00	1.4	12.1	2,033.4	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.7	1,886.0	0.9	139.80 #	24 #	24 #	17 #
Minimum:	0.9	11.8	1,497.5	0.7	4.50	1	1	0
Maximum:	1.5	13.7	2,105.2	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2020 00:00	2.7	13.9	1,233.3	2.3	4.75	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.7	13.9	1,233.3	2.3	4.75 #	1 #	0 #	1 #
Minimum:	2.7	13.9	1,233.3	2.3	4.75	0	0	0
Maximum:	2.7	13.9	1,233.3	2.3	4.75	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/09/2020 01:00	14.6	18.6	326.1	37.5	9.00	1	0	0
03/09/2020 02:00	32.9	16.3	622.9	42.2	96.50	1	0	0
03/09/2020 03:00	3.0	13.7	1,466.3	2.5	13.20	1	0	0
03/09/2020 04:00	1.0	13.7	1,559.0	0.8	4.70	1	1	1
03/09/2020 05:00	1.3	12.6	1,997.4	0.9	6.00	1	1	1
03/09/2020 06:00	1.4	12.0	2,130.1	0.9	6.40	1	1	1
03/09/2020 07:00	1.4	12.0	2,111.7	0.9	6.30	1	1	1
03/09/2020 08:00	1.4	12.0	2,100.6	0.9	6.30	1	1	1
03/09/2020 09:00	1.0	13.5	1,646.5	0.8	4.90	1	1	1
03/09/2020 10:00	1.0	13.7	1,567.7	0.8	4.70	1	1	0
03/09/2020 11:00	1.0	13.7	1,541.6	0.8	4.60	1	1	0
03/09/2020 12:00	1.0	13.7	1,665.3	0.8	5.00	1	1	0
03/09/2020 13:00	1.0	13.7	1,668.1	0.8	5.00	1	1	0
03/09/2020 14:00	1.0	13.7	1,664.9	0.8	5.00	1	1	0
03/09/2020 15:00	1.0	13.7	1,639.8	0.8	4.90	1	1	0
03/09/2020 16:00	1.1	13.7	1,657.1	0.9	5.00	1	1	1
03/09/2020 17:00	1.3	12.4	1,999.7	0.9	6.00	1	1	1
03/09/2020 18:00	1.4	11.7	2,141.2	0.9	6.40	1	1	1
03/09/2020 19:00	1.4	11.7	2,146.6	0.9	6.40	1	1	1
03/09/2020 20:00	1.4	11.9	2,111.3	0.9	6.30	1	1	1
03/09/2020 21:00	1.4	11.8	2,114.6	0.9	6.30	1	1	1
03/09/2020 22:00	1.4	11.8	2,114.0	0.9	6.30	1	1	1
03/09/2020 23:00	1.4	11.8	2,113.7	0.9	6.30	1	1	1
Average/Sum#:	3.3	13.2	1,743.7	4.3	231.50 #	23 #	20 #	14 #
Minimum:	1.0	11.7	326.1	0.8	4.60	0	0	0
Maximum:	32.9	18.6	2,146.6	42.2	96.50	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/10/2020 00:00	1.4	11.8	2,115.8	0.9	6.30	1	1	1
03/10/2020 01:00	1.4	11.9	2,105.0	0.9	6.30	1	1	1
03/10/2020 02:00	1.4	11.9	2,094.0	0.9	6.30	1	1	1
03/10/2020 03:00	1.3	12.2	2,048.8	0.9	6.10	1	1	1
03/10/2020 04:00	1.3	12.2	2,051.9	0.9	6.20	1	1	1
03/10/2020 05:00	1.5	11.6	2,145.4	1.0	8.60	1	1	1
03/10/2020 06:00	1.4	11.4	2,215.2	0.9	6.60	1	1	1
03/10/2020 07:00	1.4	11.5	2,176.7	0.9	6.50	1	1	1
03/10/2020 08:00	0.0	0.0	2,150.2	0.0	0.00	1	1	1
03/10/2020 09:00	1.3	12.3	2,099.1	0.9	6.30	1	1	1
03/10/2020 10:00	1.3	12.4	2,063.7	0.9	6.20	1	1	1
03/10/2020 11:00	1.3	12.2	2,093.0	0.9	6.30	1	1	1
03/10/2020 12:00	1.4	12.1	2,114.6	0.9	6.30	1	1	1
03/10/2020 13:00	1.3	12.1	2,099.9	0.9	6.30	1	1	1
03/10/2020 14:00	1.3	12.0	2,114.1	0.9	6.30	1	1	1
03/10/2020 15:00	1.3	12.2	2,089.1	0.9	6.30	1	1	1
03/10/2020 16:00	1.3	12.1	2,090.0	0.9	6.30	1	1	1
03/10/2020 17:00	1.3	12.3	2,060.3	0.9	6.20	1	1	1
03/10/2020 18:00	1.3	11.8	2,159.1	0.8	6.50	1	1	1
03/10/2020 19:00	1.4	11.6	2,194.4	0.9	6.60	1	1	1
03/10/2020 20:00	1.4	11.7	2,192.6	0.9	6.60	1	1	1
03/10/2020 21:00	1.3	12.0	2,115.1	0.9	6.30	1	1	1
03/10/2020 22:00	1.3	12.2	2,099.5	0.9	6.30	1	1	1
03/10/2020 23:00	1.3	12.2	2,072.5	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.0	2,115.0	0.9	147.90 #	24 #	24 #	24 #
Minimum:	1.3	11.4	2,048.8	0.8	6.10	1	1	1
Maximum:	1.5	12.4	2,215.2	1.0	8.60	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2020 00:00	1.3	12.6	2,007.3	0.9	6.00	1	1	1
03/11/2020 01:00	1.3	12.6	2,001.4	0.9	6.00	1	1	1
03/11/2020 02:00	1.3	12.5	2,014.6	0.9	6.00	1	1	1
03/11/2020 03:00	1.3	12.5	2,017.7	0.9	6.10	1	1	1
03/11/2020 04:00	1.3	12.5	2,046.2	0.9	6.10	1	1	1
03/11/2020 05:00	1.5	12.0	2,104.5	1.0	8.40	1	1	1
03/11/2020 06:00	1.3	11.7	2,189.2	0.8	6.60	1	1	1
03/11/2020 07:00	1.3	12.2	2,105.0	0.9	6.30	1	1	1
03/11/2020 08:00	1.3	12.2	2,099.4	0.9	6.30	1	1	1
03/11/2020 09:00	0.9	13.7	1,684.2	0.7	5.10	1	1	1
03/11/2020 10:00	0.9	13.9	1,618.7	0.8	4.90	1	1	0
03/11/2020 11:00	0.9	13.9	1,533.3	0.8	4.60	1	1	0
03/11/2020 12:00	0.9	14.0	1,567.8	0.8	4.70	1	1	0
03/11/2020 13:00	0.9	14.0	1,654.9	0.8	5.00	1	1	0
03/11/2020 14:00	0.9	14.0	1,621.7	0.8	4.90	1	1	0
03/11/2020 15:00	0.9	14.0	1,529.6	0.8	4.60	1	1	0
03/11/2020 16:00	0.7	14.1	1,323.4	0.6	2.60	1	1	0
03/11/2020 17:00	0.9	14.0	1,609.1	0.8	4.80	1	1	0
03/11/2020 18:00	0.9	13.9	1,675.6	0.8	5.00	1	1	1
03/11/2020 19:00	1.3	12.6	2,002.8	0.9	6.00	1	1	1
03/11/2020 20:00	1.4	11.7	2,170.1	0.9	6.50	1	1	1
03/11/2020 21:00	1.3	12.0	2,114.6	0.9	6.30	1	1	1
03/11/2020 22:00	1.3	12.3	2,054.4	0.9	6.20	1	1	1
03/11/2020 23:00	1.3	12.2	2,098.7	0.9	6.30	1	1	1
Average/Sum#:	1.1	13.0	1,868.5	0.8	135.30 #	24 #	24 #	16 #
Minimum:	0.7	11.7	1,323.4	0.6	2.60	1	1	0
Maximum:	1.5	14.1	2,189.2	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2020 00:00	1.3	12.3	2,055.5	0.9	6.20	1	1	1
03/12/2020 01:00	1.3	12.5	2,022.4	0.9	6.10	1	1	1
03/12/2020 02:00	1.2	12.7	1,963.5	0.9	5.90	1	1	1
03/12/2020 03:00	1.3	12.5	2,018.6	0.9	6.10	1	1	1
03/12/2020 04:00	1.3	12.3	2,056.9	0.9	6.20	1	1	1
03/12/2020 05:00	1.5	12.0	2,072.2	1.0	8.30	1	1	1
03/12/2020 06:00	1.4	11.6	2,194.7	0.9	6.60	1	1	1
03/12/2020 07:00	1.4	11.8	2,182.0	0.9	6.50	1	1	1
03/12/2020 08:00	1.3	12.2	2,052.2	0.9	6.20	1	1	1
03/12/2020 09:00	0.8	13.9	1,636.4	0.7	3.30	1	1	0
03/12/2020 10:00	0.8	13.9	1,646.8	0.7	3.30	1	1	0
03/12/2020 11:00	0.9	14.0	1,630.8	0.8	4.90	1	1	0
03/12/2020 12:00	1.0	14.0	1,664.1	0.9	5.00	1	1	0
03/12/2020 13:00	0.8	14.0	1,557.2	0.7	4.70	1	1	0
03/12/2020 14:00	0.8	13.9	1,643.3	0.7	3.30	1	1	0
03/12/2020 15:00	1.1	13.3	1,804.7	0.9	5.40	1	1	1
03/12/2020 16:00	1.4	12.1	2,081.5	0.9	6.20	1	1	1
03/12/2020 17:00	1.4	11.8	2,146.6	0.9	6.40	1	1	1
03/12/2020 18:00	1.4	11.6	2,186.7	0.9	6.60	1	1	1
03/12/2020 19:00	1.4	11.6	2,196.4	0.9	6.60	1	1	1
03/12/2020 20:00	1.3	12.2	2,077.6	0.9	6.20	1	1	1
03/12/2020 21:00	1.4	11.7	2,170.3	0.9	6.50	1	1	1
03/12/2020 22:00	1.4	11.6	2,190.6	0.9	6.60	1	1	1
03/12/2020 23:00	1.4	11.7	2,182.4	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.6	1,976.4	0.9	139.60 #	24 #	24 #	18 #
Minimum:	0.8	11.6	1,557.2	0.7	3.30	1	1	0
Maximum:	1.5	14.0	2,196.4	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2020 00:00	1.4	11.7	2,175.0	0.9	6.50	1	1	1
03/13/2020 01:00	1.3	11.8	2,173.7	0.8	6.50	1	1	1
03/13/2020 02:00	1.4	11.8	2,161.9	0.9	6.50	1	1	1
03/13/2020 03:00	1.3	11.8	2,157.8	0.8	6.50	1	1	1
03/13/2020 04:00	1.3	12.1	2,111.2	0.9	6.30	1	1	1
03/13/2020 05:00	1.6	11.6	2,189.2	1.0	8.80	1	1	1
03/13/2020 06:00	1.3	11.8	2,165.8	0.8	6.50	1	1	1
03/13/2020 07:00	1.3	12.0	2,142.1	0.9	6.40	1	1	1
03/13/2020 08:00	1.4	11.9	2,148.7	0.9	6.40	1	1	1
03/13/2020 09:00	1.0	13.6	1,689.9	0.8	5.10	1	1	1
03/13/2020 10:00	0.8	14.0	1,572.2	0.7	4.70	1	1	0
03/13/2020 11:00	0.9	14.0	1,606.7	0.8	4.80	1	1	0
03/13/2020 12:00	0.9	14.0	1,652.9	0.8	5.00	1	1	0
03/13/2020 13:00	0.9	14.0	1,603.7	0.8	4.80	1	1	0
03/13/2020 14:00	1.0	13.9	1,638.9	0.8	4.90	1	1	0
03/13/2020 15:00	1.0	14.0	1,645.5	0.9	4.90	1	1	0
03/13/2020 16:00	1.0	14.0	1,660.3	0.9	5.00	1	1	0
03/13/2020 17:00	1.1	13.3	1,791.3	0.9	5.40	1	1	1
03/13/2020 18:00	1.3	12.4	2,029.0	0.9	6.10	1	1	1
03/13/2020 19:00	1.4	11.7	2,173.5	0.9	6.50	1	1	1
03/13/2020 20:00	1.4	11.6	2,194.0	0.9	6.60	1	1	1
03/13/2020 21:00	1.4	12.0	2,125.1	0.9	6.40	1	1	1
03/13/2020 22:00	1.3	12.2	2,082.7	0.9	6.20	1	1	1
03/13/2020 23:00	1.3	12.4	2,035.7	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.7	1,955.3	0.9	142.90 #	24 #	24 #	17 #
Minimum:	0.8	11.6	1,572.2	0.7	4.70	1	1	0
Maximum:	1.6	14.0	2,194.0	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/14/2020 00:00	1.3	12.1	2,102.7	0.9	6.30	1	1	1
03/14/2020 01:00	1.3	12.0	2,111.9	0.9	6.30	1	1	1
03/14/2020 02:00	1.3	12.1	2,104.4	0.9	6.30	1	1	1
03/14/2020 03:00	1.4	12.1	2,099.9	0.9	6.30	1	1	1
03/14/2020 04:00	1.3	12.5	2,028.5	0.9	6.10	1	1	1
03/14/2020 05:00	1.4	12.2	2,071.7	0.9	6.20	1	1	1
03/14/2020 06:00	1.3	12.1	2,112.3	0.9	6.30	1	1	1
03/14/2020 07:00	1.3	12.3	2,065.5	0.9	6.20	1	1	1
03/14/2020 08:00	0.8	14.0	1,723.4	0.7	5.20	1	1	0
03/14/2020 09:00	0.9	14.0	1,717.0	0.8	5.20	1	1	0
03/14/2020 10:00	0.9	14.0	1,713.7	0.8	5.10	1	1	0
03/14/2020 11:00	0.9	14.0	1,714.1	0.8	5.10	1	1	0
03/14/2020 12:00	0.9	14.0	1,712.4	0.8	5.10	1	1	0
03/14/2020 13:00	0.9	14.0	1,708.3	0.8	5.10	1	1	0
03/14/2020 14:00	0.9	14.0	1,711.3	0.8	5.10	1	1	0
03/14/2020 15:00	0.9	14.0	1,711.1	0.8	5.10	1	1	0
03/14/2020 16:00	0.9	14.0	1,718.1	0.8	5.20	1	1	0
03/14/2020 17:00	1.0	13.4	1,802.0	0.8	5.40	1	1	1
03/14/2020 18:00	1.3	12.3	2,088.0	0.9	6.30	1	1	1
03/14/2020 19:00	1.4	11.8	2,175.9	0.9	6.50	1	1	1
03/14/2020 20:00	1.3	12.0	2,141.1	0.9	6.40	1	1	1
03/14/2020 21:00	1.3	12.3	2,094.0	0.9	6.30	1	1	1
03/14/2020 22:00	1.3	12.6	2,021.6	0.9	6.10	1	1	1
03/14/2020 23:00	1.3	12.7	2,012.5	0.9	6.00	1	1	1
Average/Sum#:	1.1	12.9	1,935.9	0.9	139.20 #	24 #	24 #	15 #
Minimum:	0.8	11.8	1,708.3	0.7	5.10	1	1	0
Maximum:	1.4	14.0	2,175.9	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2020 00:00	1.3	12.4	2,063.4	0.9	6.20	1	1	1
03/15/2020 01:00	1.3	12.6	2,026.4	0.9	6.10	1	1	1
03/15/2020 02:00	1.3	12.7	2,015.0	0.9	6.00	1	1	1
03/15/2020 03:00	1.3	12.7	2,015.7	0.9	6.00	1	1	1
03/15/2020 04:00	1.3	12.6	2,028.1	0.9	6.10	1	1	1
03/15/2020 05:00	1.2	12.7	2,025.5	0.9	6.10	1	1	1
03/15/2020 06:00	1.3	12.5	2,046.5	0.9	6.10	1	1	1
03/15/2020 07:00	1.3	12.5	2,044.5	0.9	6.10	1	1	1
03/15/2020 08:00	1.3	12.6	1,997.9	0.9	6.00	1	1	1
03/15/2020 09:00	0.8	13.9	1,719.8	0.7	3.40	1	1	0
03/15/2020 10:00	0.9	13.9	1,724.4	0.8	5.20	1	1	0
03/15/2020 11:00	0.9	13.9	1,714.7	0.8	5.10	1	1	0
03/15/2020 12:00	0.9	14.0	1,715.4	0.8	5.10	1	1	0
03/15/2020 13:00	0.9	14.0	1,717.8	0.8	5.20	1	1	0
03/15/2020 14:00	0.8	14.0	1,557.9	0.7	4.70	1	1	0
03/15/2020 15:00	0.8	14.0	1,492.1	0.7	4.50	1	1	0
03/15/2020 16:00	0.8	14.0	1,488.3	0.7	4.50	1	1	0
03/15/2020 17:00	1.1	13.5	1,794.4	0.9	5.40	1	1	1
03/15/2020 18:00	1.4	11.9	2,170.7	0.9	6.50	1	1	1
03/15/2020 19:00	1.4	11.7	2,218.3	0.9	6.70	1	1	1
03/15/2020 20:00	1.3	11.7	2,201.8	0.8	6.60	1	1	1
03/15/2020 21:00	1.3	11.8	2,198.1	0.8	6.60	1	1	1
03/15/2020 22:00	1.3	12.4	2,081.0	0.9	6.20	1	1	1
03/15/2020 23:00	1.3	12.4	2,089.1	0.9	6.30	1	1	1
Average/Sum#:	1.1	12.9	1,922.8	0.8	136.70 #	24 #	24 #	16 #
Minimum:	0.8	11.7	1,488.3	0.7	3.40	1	1	0
Maximum:	1.4	14.0	2,218.3	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/16/2020 00:00	1.3	12.3	2,100.3	0.9	6.30	1	1	1
03/16/2020 01:00	1.3	12.4	2,086.3	0.9	6.30	1	1	1
03/16/2020 02:00	1.3	12.3	2,100.7	0.9	6.30	1	1	1
03/16/2020 03:00	1.3	12.4	2,093.7	0.9	6.30	1	1	1
03/16/2020 04:00	1.3	12.1	2,159.1	0.9	6.50	1	1	1
03/16/2020 05:00	1.5	11.9	2,181.7	1.0	8.70	1	1	1
03/16/2020 06:00	1.3	11.7	2,231.6	0.8	6.70	1	1	1
03/16/2020 07:00	1.3	12.3	2,121.9	0.9	6.40	1	1	1
03/16/2020 08:00	1.3	12.3	2,108.2	0.9	6.30	1	1	1
03/16/2020 09:00	1.3	12.3	2,097.4	0.9	6.30	1	1	1
03/16/2020 10:00	1.3	12.3	2,097.8	0.9	6.30	1	1	1
03/16/2020 11:00	1.3	12.2	2,110.7	0.9	6.30	1	1	1
03/16/2020 12:00	1.3	12.3	2,092.9	0.9	6.30	1	1	1
03/16/2020 13:00	1.3	12.4	2,061.4	0.9	6.20	1	1	1
03/16/2020 14:00	1.3	12.4	2,042.2	0.9	6.10	1	1	1
03/16/2020 15:00	1.3	12.6	2,008.7	0.9	6.00	1	1	1
03/16/2020 16:00	1.3	12.6	2,007.2	0.9	6.00	1	1	1
03/16/2020 17:00	1.3	12.6	2,019.2	0.9	6.10	1	1	1
03/16/2020 18:00	1.4	11.8	2,196.5	0.9	6.60	1	1	1
03/16/2020 19:00	1.4	11.7	2,201.6	0.9	6.60	1	1	1
03/16/2020 20:00	1.3	12.0	2,146.1	0.9	6.40	1	1	1
03/16/2020 21:00	1.4	11.9	2,161.9	0.9	6.50	1	1	1
03/16/2020 22:00	1.3	12.2	2,094.0	0.9	6.30	1	1	1
03/16/2020 23:00	1.3	12.2	2,094.6	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.2	2,109.0	0.9	154.10 #	24 #	24 #	24 #
Minimum:	1.3	11.7	2,007.2	0.8	6.00	1	1	1
Maximum:	1.5	12.6	2,231.6	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/17/2020 00:00	1.3	12.3	2,079.2	0.9	6.20	1	1	1
03/17/2020 01:00	1.3	12.4	2,072.9	0.9	6.20	1	1	1
03/17/2020 02:00	1.3	12.7	2,012.9	0.9	6.00	1	1	1
03/17/2020 03:00	1.3	12.6	2,042.0	0.9	6.10	1	1	1
03/17/2020 04:00	1.3	12.7	2,006.1	0.9	6.00	1	1	1
03/17/2020 05:00	1.5	12.2	2,092.2	1.0	8.40	1	1	1
03/17/2020 06:00	1.3	12.1	2,149.1	0.9	6.40	1	1	1
03/17/2020 07:00	1.3	12.8	2,007.9	0.9	6.00	1	1	1
03/17/2020 08:00	1.2	13.2	1,880.6	0.9	5.60	1	1	1
03/17/2020 09:00	0.9	13.9	1,710.7	0.8	5.10	1	1	0
03/17/2020 10:00	0.9	13.9	1,721.0	0.8	5.20	1	1	0
03/17/2020 11:00	0.9	13.9	1,724.1	0.8	5.20	1	1	0
03/17/2020 12:00	0.9	13.9	1,724.9	0.8	5.20	1	1	0
03/17/2020 13:00	0.9	13.9	1,723.7	0.8	5.20	1	1	0
03/17/2020 14:00	0.9	13.9	1,722.0	0.8	5.20	1	1	0
03/17/2020 15:00	0.9	13.9	1,721.6	0.8	5.20	1	1	0
03/17/2020 16:00	0.9	13.9	1,725.8	0.8	5.20	1	1	1
03/17/2020 17:00	1.3	12.8	1,979.8	0.9	5.90	1	1	1
03/17/2020 18:00	1.3	12.3	2,081.9	0.9	6.20	1	1	1
03/17/2020 19:00	1.3	12.2	2,094.9	0.9	6.30	1	1	1
03/17/2020 20:00	1.3	12.5	2,036.4	0.9	6.10	1	1	1
03/17/2020 21:00	1.3	12.5	2,042.4	0.9	6.10	1	1	1
03/17/2020 22:00	1.3	12.5	2,043.6	0.9	6.10	1	1	1
03/17/2020 23:00	1.3	12.7	2,004.9	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.0	1,933.4	0.9	141.10 #	24 #	24 #	17 #
Minimum:	0.9	12.1	1,710.7	0.8	5.10	1	1	0
Maximum:	1.5	13.9	2,149.1	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2020 00:00	1.3	12.7	2,002.2	0.9	6.00	1	1	1
03/18/2020 01:00	1.3	12.7	2,002.4	0.9	6.00	1	1	1
03/18/2020 02:00	1.3	12.7	2,003.2	0.9	6.00	1	1	1
03/18/2020 03:00	1.3	12.7	2,007.3	0.9	6.00	1	1	1
03/18/2020 04:00	1.3	12.7	1,998.3	0.9	6.00	1	1	1
03/18/2020 05:00	1.4	12.5	1,998.7	1.0	8.00	1	1	1
03/18/2020 06:00	1.3	12.2	2,097.3	0.9	6.30	1	1	1
03/18/2020 07:00	1.3	12.4	2,064.0	0.9	6.20	1	1	1
03/18/2020 08:00	1.3	12.6	1,998.1	0.9	6.00	1	1	1
03/18/2020 09:00	0.8	13.9	1,621.1	0.7	3.20	1	1	0
03/18/2020 10:00	0.9	13.9	1,599.2	0.8	4.80	1	1	0
03/18/2020 11:00	0.9	13.9	1,585.1	0.8	4.80	1	1	0
03/18/2020 12:00	0.9	13.9	1,608.1	0.8	4.80	1	1	0
03/18/2020 13:00	0.9	13.9	1,586.3	0.8	4.80	1	1	0
03/18/2020 14:00	0.9	13.9	1,620.8	0.8	4.90	1	1	0
03/18/2020 15:00	0.9	13.9	1,598.7	0.8	4.80	1	1	0
03/18/2020 16:00	0.9	13.9	1,652.3	0.8	5.00	1	1	0
03/18/2020 17:00	0.8	13.9	1,533.8	0.7	3.10	1	1	0
03/18/2020 18:00	1.3	12.8	1,954.4	0.9	5.90	1	1	1
03/18/2020 19:00	1.3	12.7	1,983.7	0.9	6.00	1	1	1
03/18/2020 20:00	1.3	12.5	2,035.7	0.9	6.10	1	1	1
03/18/2020 21:00	1.3	12.6	2,018.3	0.9	6.10	1	1	1
03/18/2020 22:00	1.3	12.6	2,020.3	0.9	6.10	1	1	1
03/18/2020 23:00	1.2	12.8	1,977.1	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.1	1,856.9	0.9	132.80 #	24 #	24 #	15 #
Minimum:	0.8	12.2	1,533.8	0.7	3.10	1	1	0
Maximum:	1.4	13.9	2,097.3	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2020 00:00	1.3	13.2	1,891.9	1.0	7.60	1	1	1
03/19/2020 01:00	1.2	13.2	1,891.7	0.9	5.70	1	1	1
03/19/2020 02:00	1.2	13.3	1,899.4	0.9	5.70	1	1	1
03/19/2020 03:00	1.1	13.1	1,943.5	0.8	5.80	1	1	1
03/19/2020 04:00	1.3	12.4	2,084.9	0.9	6.30	1	1	1
03/19/2020 05:00	1.2	13.0	1,951.0	0.9	5.90	1	1	1
03/19/2020 06:00	1.3	12.5	2,074.9	0.9	6.20	1	1	1
03/19/2020 07:00	1.3	12.5	2,077.5	0.9	6.20	1	1	1
03/19/2020 08:00	1.2	12.8	1,964.4	0.9	5.90	1	1	1
03/19/2020 09:00	0.8	13.9	1,521.8	0.7	3.00	1	1	0
03/19/2020 10:00	0.9	13.9	1,558.8	0.8	4.70	1	1	0
03/19/2020 11:00	0.8	14.0	1,441.0	0.7	4.30	1	1	0
03/19/2020 12:00	0.9	13.9	1,500.2	0.8	4.50	1	1	0
03/19/2020 13:00	0.7	14.0	1,347.7	0.6	2.70	1	1	0
03/19/2020 14:00	0.6	14.0	1,276.5	0.5	2.60	1	1	0
03/19/2020 15:00	0.8	14.0	1,536.0	0.7	4.60	1	1	0
03/19/2020 16:00	0.8	14.0	1,510.6	0.7	4.50	1	1	1
03/19/2020 17:00	1.3	12.7	1,985.8	0.9	6.00	1	1	1
03/19/2020 18:00	1.3	12.4	2,035.6	0.9	6.10	1	1	1
03/19/2020 19:00	1.3	12.2	2,088.6	0.9	6.30	1	1	1
03/19/2020 20:00	1.3	12.2	2,091.7	0.9	6.30	1	1	1
03/19/2020 21:00	1.3	12.3	2,068.3	0.9	6.20	1	1	1
03/19/2020 22:00	1.3	12.4	2,059.9	0.9	6.20	1	1	1
03/19/2020 23:00	1.3	12.7	2,009.8	0.9	6.00	1	1	1
Average/Sum#:	1.1	13.1	1,825.5	0.8	129.30 #	24 #	24 #	17 #
Minimum:	0.6	12.2	1,276.5	0.5	2.60	1	1	0
Maximum:	1.3	14.0	2,091.7	1.0	7.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2020 00:00	1.3	12.8	2,003.8	0.9	6.00	1	1	1
03/20/2020 01:00	1.3	12.8	2,007.0	0.9	6.00	1	1	1
03/20/2020 02:00	1.2	12.8	2,005.1	0.9	6.00	1	1	1
03/20/2020 03:00	1.3	12.8	2,003.8	0.9	6.00	1	1	1
03/20/2020 04:00	1.2	12.8	2,004.6	0.9	6.00	1	1	1
03/20/2020 05:00	1.0	13.1	1,942.3	0.8	5.80	1	1	1
03/20/2020 06:00	1.3	12.8	2,026.8	0.9	6.10	1	1	1
03/20/2020 07:00	1.1	13.3	1,883.0	0.9	5.60	1	1	1
03/20/2020 08:00	0.9	13.9	1,590.6	0.8	4.80	1	1	0
03/20/2020 09:00	0.7	14.0	1,350.6	0.6	2.70	1	1	0
03/20/2020 10:00	0.9	13.9	1,620.5	0.8	4.90	1	1	0
03/20/2020 11:00	0.9	13.9	1,525.4	0.8	4.60	1	1	0
03/20/2020 12:00	0.9	14.0	1,499.9	0.8	4.50	1	1	0
03/20/2020 13:00	0.9	14.0	1,613.8	0.8	4.80	1	1	0
03/20/2020 14:00	0.9	14.0	1,503.6	0.8	4.50	1	1	0
03/20/2020 15:00	0.9	13.9	1,551.6	0.8	4.70	1	1	1
03/20/2020 16:00	2.1	12.7	1,980.0	1.5	11.90	1	1	1
03/20/2020 17:00	2.5	12.5	2,019.0	1.8	12.10	1	1	1
03/20/2020 18:00	1.6	12.5	2,021.3	1.1	8.10	1	1	1
03/20/2020 19:00	1.3	12.4	2,030.2	0.9	6.10	1	1	1
03/20/2020 20:00	1.3	12.4	2,054.4	0.9	6.20	1	1	1
03/20/2020 21:00	1.3	12.3	2,070.3	0.9	6.20	1	1	1
03/20/2020 22:00	1.3	12.4	2,050.9	0.9	6.20	1	1	1
03/20/2020 23:00	1.3	12.6	2,011.9	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.1	1,848.8	0.9	145.80 #	24 #	24 #	17 #
Minimum:	0.7	12.3	1,350.6	0.6	2.70	1	1	0
Maximum:	2.5	14.0	2,070.3	1.8	12.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/21/2020 00:00	1.3	12.5	2,052.2	0.9	6.20	1	1	1
03/21/2020 01:00	1.3	12.5	2,073.5	0.9	6.20	1	1	1
03/21/2020 02:00	1.3	12.4	2,066.3	0.9	6.20	1	1	1
03/21/2020 03:00	1.3	12.4	2,073.9	0.9	6.20	1	1	1
03/21/2020 04:00	1.3	12.5	2,042.9	0.9	6.10	1	1	1
03/21/2020 05:00	1.3	12.5	2,034.4	0.9	6.10	1	1	1
03/21/2020 06:00	1.2	12.8	1,971.8	0.9	5.90	1	1	1
03/21/2020 07:00	3.3	14.5	1,168.2	3.0	6.06	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	12.8	1,935.4	1.2	48.96 #	8 #	7 #	8 #
Minimum:	1.2	12.4	1,168.2	0.9	5.90	0	0	0
Maximum:	3.3	14.5	2,073.9	3.0	6.20	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/24/2020 02:00	32.9	17.7	451.6	60.7	72.50	1	0	0
03/24/2020 03:00	20.3	15.7	832.3	23.0	70.70	1	0	0
03/24/2020 04:00	0.8	13.8	1,694.2	0.7	3.40	1	1	0
03/24/2020 05:00	0.8	13.9	1,566.4	0.7	3.10	1	1	0
03/24/2020 06:00	0.8	13.9	1,657.2	0.7	3.30	1	1	0
03/24/2020 07:00	0.8	13.9	1,667.4	0.7	3.30	1	1	0
03/24/2020 08:00	0.8	13.9	1,546.4	0.7	3.10	1	1	0
03/24/2020 09:00	0.9	13.9	1,651.1	0.8	5.00	1	1	0
03/24/2020 10:00	0.8	13.9	1,671.1	0.7	3.30	1	1	0
03/24/2020 11:00	0.8	13.9	1,583.5	0.7	3.20	1	1	0
03/24/2020 12:00	0.8	13.9	1,611.7	0.7	3.20	1	1	0
03/24/2020 13:00	0.8	13.9	1,514.7	0.7	3.00	1	1	0
03/24/2020 14:00	0.8	13.9	1,536.0	0.7	3.10	1	1	0
03/24/2020 15:00	0.8	14.0	1,551.9	0.7	4.70	1	1	0
03/24/2020 16:00	0.9	14.0	1,568.9	0.8	4.70	1	1	1
03/24/2020 17:00	1.3	12.7	1,992.1	0.9	6.00	1	1	1
03/24/2020 18:00	1.2	12.8	1,959.9	0.9	5.90	1	1	1
03/24/2020 19:00	1.2	12.8	1,983.3	0.9	5.90	1	1	1
03/24/2020 20:00	1.3	12.3	2,086.5	0.9	6.30	1	1	1
03/24/2020 21:00	1.3	12.6	2,017.5	0.9	6.10	1	1	1
03/24/2020 22:00	1.3	12.7	2,027.9	0.9	6.10	1	1	1
03/24/2020 23:00	2.7	14.4	1,214.5	2.5	5.23	1	0	1
Average/Sum#:	3.4	13.8	1,608.5	4.6	231.13 #	22 #	19 #	8 #
Minimum:	0.8	12.3	451.6	0.7	3.00	0	0	0
Maximum:	32.9	17.7	2,086.5	60.7	72.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 23:00	31.3	17.5	469.6	54.3	87.33	1	0	0
Average/Sum#:	31.3	17.5	469.6	54.3	87.33 #	1 #	0 #	0 #
Minimum:	31.3	17.5	469.6	54.3	87.33	0	0	0
Maximum:	31.3	17.5	469.6	54.3	87.33	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2020 00:00	12.0	15.1	1,005.4	12.2	45.20	1	0	0
03/28/2020 01:00	0.9	13.9	1,654.1	0.8	5.00	1	1	0
03/28/2020 02:00	0.9	13.9	1,663.3	0.8	5.00	1	1	0
03/28/2020 03:00	1.0	13.9	1,665.2	0.8	5.00	1	1	0
03/28/2020 04:00	0.9	13.9	1,645.2	0.8	4.90	1	1	0
03/28/2020 05:00	0.9	13.9	1,647.5	0.8	4.90	1	1	0
03/28/2020 06:00	0.8	13.9	1,526.6	0.7	3.10	1	1	0
03/28/2020 07:00	0.9	13.9	1,495.6	0.8	4.50	1	1	0
03/28/2020 08:00	0.9	13.9	1,607.9	0.8	4.80	1	1	0
03/28/2020 09:00	0.9	13.9	1,631.6	0.8	4.90	1	1	0
03/28/2020 10:00	0.9	13.9	1,653.8	0.8	5.00	1	1	0
03/28/2020 11:00	0.9	13.9	1,661.3	0.8	5.00	1	1	0
03/28/2020 12:00	0.9	13.9	1,651.0	0.8	5.00	1	1	0
03/28/2020 13:00	0.9	13.9	1,652.2	0.8	5.00	1	1	0
03/28/2020 14:00	0.9	13.9	1,631.6	0.8	4.90	1	1	0
03/28/2020 15:00	0.9	13.9	1,632.4	0.8	4.90	1	1	0
03/28/2020 16:00	0.9	13.9	1,661.3	0.8	5.00	1	1	0
03/28/2020 17:00	1.1	13.4	1,797.9	0.9	5.40	1	1	1
03/28/2020 18:00	1.3	12.2	2,079.6	0.9	6.20	1	1	1
03/28/2020 19:00	1.3	12.4	2,047.3	0.9	6.10	1	1	1
03/28/2020 20:00	1.3	12.2	2,089.1	0.9	6.30	1	1	1
03/28/2020 21:00	1.3	12.5	2,034.5	0.9	6.10	1	1	1
03/28/2020 22:00	1.3	12.5	2,026.8	0.9	6.10	1	1	1
03/28/2020 23:00	1.2	12.9	1,933.9	0.9	5.80	1	1	1
Average/Sum#:	1.5	13.6	1,712.3	1.3	164.10 #	24 #	23 #	7 #
Minimum:	0.8	12.2	1,005.4	0.7	3.10	1	0	0
Maximum:	12.0	15.1	2,089.1	12.2	45.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.8	13.9	1,613.0	0.7	3.20	1	1	0
03/29/2020 01:00	0.9	13.9	1,574.2	0.8	4.70	1	1	0
03/29/2020 02:00	0.9	13.9	1,580.4	0.8	4.70	1	1	0
03/29/2020 03:00	0.9	13.9	1,531.6	0.8	4.60	1	1	0
03/29/2020 04:00	0.9	13.9	1,659.1	0.8	5.00	1	1	0
03/29/2020 05:00	0.8	13.9	1,580.5	0.7	3.20	1	1	0
03/29/2020 06:00	0.8	13.9	1,562.2	0.7	3.10	1	1	0
03/29/2020 07:00	0.9	13.9	1,584.7	0.8	4.80	1	1	0
03/29/2020 08:00	0.9	13.9	1,568.1	0.8	4.70	1	1	0
03/29/2020 09:00	0.9	13.9	1,638.2	0.8	4.90	1	1	0
03/29/2020 10:00	0.9	13.9	1,662.6	0.8	5.00	1	1	0
03/29/2020 11:00	0.9	13.9	1,644.1	0.8	4.90	1	1	0
03/29/2020 12:00	0.8	13.9	1,537.1	0.7	3.10	1	1	0
03/29/2020 13:00	0.9	13.9	1,578.6	0.8	4.70	1	1	0
03/29/2020 14:00	0.9	13.9	1,568.1	0.8	4.70	1	1	0
03/29/2020 15:00	0.8	14.0	1,565.1	0.7	4.70	1	1	0
03/29/2020 16:00	0.9	13.9	1,619.2	0.8	4.90	1	1	0
03/29/2020 17:00	0.8	13.9	1,532.7	0.7	3.10	1	1	1
03/29/2020 18:00	1.3	12.6	2,010.5	0.9	6.00	1	1	1
03/29/2020 19:00	1.3	12.1	2,091.9	0.9	6.30	1	1	1
03/29/2020 20:00	1.3	12.2	2,068.0	0.9	6.20	1	1	1
03/29/2020 21:00	1.3	12.3	2,060.4	0.9	6.20	1	1	1
03/29/2020 22:00	1.2	13.0	1,913.3	0.9	5.70	1	1	1
03/29/2020 23:00	1.2	12.9	1,927.1	0.9	5.80	1	1	1
Average/Sum#:	1.0	13.6	1,694.6	0.8	114.20 #	24 #	24 #	7 #
Minimum:	0.8	12.1	1,531.6	0.7	3.10	1	1	0
Maximum:	1.3	14.0	2,091.9	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/30/2020 00:00	0.9	13.9	1,653.5	0.8	5.00	1	1	0
03/30/2020 01:00	0.9	13.9	1,654.5	0.8	5.00	1	1	0
03/30/2020 02:00	0.9	13.9	1,643.8	0.8	4.90	1	1	0
03/30/2020 03:00	0.9	13.9	1,614.2	0.8	4.80	1	1	0
03/30/2020 04:00	0.9	13.9	1,590.6	0.8	4.80	1	1	0
03/30/2020 05:00	0.9	13.9	1,641.7	0.8	4.90	1	1	0
03/30/2020 06:00	0.9	13.9	1,654.8	0.8	5.00	1	1	0
03/30/2020 07:00	0.9	13.9	1,632.0	0.8	4.90	1	1	0
03/30/2020 08:00	0.9	13.9	1,608.7	0.8	4.80	1	1	0
03/30/2020 09:00	0.9	13.9	1,628.0	0.8	4.90	1	1	0
03/30/2020 10:00	0.9	13.9	1,630.2	0.8	4.90	1	1	0
03/30/2020 11:00	0.9	13.9	1,607.6	0.8	4.80	1	1	0
03/30/2020 12:00	0.9	13.9	1,576.3	0.8	4.70	1	1	0
03/30/2020 13:00	0.9	13.9	1,565.2	0.8	4.70	1	1	0
03/30/2020 14:00	0.9	13.9	1,619.3	0.8	4.90	1	1	0
03/30/2020 15:00	0.8	13.9	1,582.7	0.7	3.20	1	1	0
03/30/2020 16:00	0.9	13.9	1,630.2	0.8	4.90	1	1	0
03/30/2020 17:00	0.9	13.9	1,623.8	0.8	4.90	1	1	1
03/30/2020 18:00	1.3	12.7	1,980.9	0.9	5.90	1	1	1
03/30/2020 19:00	1.3	12.4	2,035.9	0.9	6.10	1	1	1
03/30/2020 20:00	1.3	12.0	2,109.7	0.9	6.30	1	1	1
03/30/2020 21:00	1.3	12.0	2,111.8	0.9	6.30	1	1	1
03/30/2020 22:00	1.3	12.2	2,089.0	0.9	6.30	1	1	1
03/30/2020 23:00	1.3	12.6	2,001.1	0.9	6.00	1	1	1
Average/Sum#:	1.0	13.5	1,728.6	0.8	122.90 #	24 #	24 #	7 #
Minimum:	0.8	12.0	1,565.2	0.7	3.20	1	1	0
Maximum:	1.3	13.9	2,111.8	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:52 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/31/2020 00:00	1.3	12.5	2,015.0	0.9	6.00	1	1	1
03/31/2020 01:00	1.3	12.5	2,017.2	0.9	6.10	1	1	1
03/31/2020 02:00	1.3	12.6	2,015.0	0.9	6.00	1	1	1
03/31/2020 03:00	1.3	12.6	2,012.6	0.9	6.00	1	1	1
03/31/2020 04:00	1.3	12.7	1,995.7	0.9	6.00	1	1	1
03/31/2020 05:00	1.1	13.1	1,907.7	0.8	5.70	1	1	1
03/31/2020 06:00	1.3	12.6	2,013.5	0.9	6.00	1	1	1
03/31/2020 07:00	2.8	14.2	1,224.0	2.5	5.28	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	12.9	1,900.1	1.1	47.08 #	8 #	7 #	8 #
Minimum:	1.1	12.5	1,224.0	0.8	5.28	0	0	0
Maximum:	2.8	14.2	2,017.2	2.5	6.10	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2020 00:00	1.3	12.6	2,035.3	0.9	6.10	1	1	1
01/01/2020 01:00	1.3	12.6	2,026.0	0.9	6.10	1	1	1
01/01/2020 02:00	4.0	14.4	1,144.9	3.6	6.41	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	13.2	1,735.4	1.8	18.61 #	3 #	2 #	3 #
Minimum:	1.3	12.6	1,144.9	0.9	6.10	0	0	0
Maximum:	4.0	14.4	2,035.3	3.6	6.41	1	1	1
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/02/2020 01:00	28.9	17.4	462.5	48.7	52.16	1	0	0
01/02/2020 02:00	19.0	15.6	700.4	21.2	54.60	1	0	0
01/02/2020 03:00	13.4	14.8	966.5	13.0	46.40	1	0	0
01/02/2020 04:00	0.2	13.6	1,542.2	0.2	1.50	1	1	0
01/02/2020 05:00	0.8	13.1	1,864.2	0.6	3.70	1	1	1
01/02/2020 06:00	1.3	12.1	2,117.0	0.9	6.40	1	1	1
01/02/2020 07:00	0.5	13.6	1,755.7	0.4	1.80	1	1	0
01/02/2020 08:00	0.3	13.6	1,537.2	0.2	1.50	1	1	0
01/02/2020 09:00	0.3	13.6	1,524.6	0.2	1.50	1	1	0
01/02/2020 10:00	0.4	13.6	1,660.3	0.3	1.70	1	1	0
01/02/2020 11:00	0.4	13.7	1,680.4	0.3	1.70	1	1	0
01/02/2020 12:00	0.3	13.7	1,626.2	0.2	1.60	1	1	0
01/02/2020 13:00	0.4	13.7	1,646.2	0.3	1.60	1	1	0
01/02/2020 14:00	0.4	13.7	1,633.3	0.3	1.60	1	1	0
01/02/2020 15:00	0.4	13.6	1,594.6	0.3	1.60	1	1	1
01/02/2020 16:00	1.3	12.5	2,015.8	0.9	6.00	1	1	1
01/02/2020 17:00	1.6	12.4	2,045.9	1.1	8.20	1	1	1
01/02/2020 18:00	1.7	12.3	2,077.0	1.2	8.30	1	1	1
01/02/2020 19:00	1.6	12.3	2,082.2	1.1	8.30	1	1	1
01/02/2020 20:00	1.6	12.3	2,082.4	1.1	8.30	1	1	1
01/02/2020 21:00	1.7	12.2	2,092.7	1.2	8.40	1	1	1
01/02/2020 22:00	1.7	12.2	2,080.3	1.2	8.30	1	1	1
01/02/2020 23:00	1.5	12.5	2,048.2	1.1	8.20	1	1	1
Average/Sum#:	3.5	13.4	1,688.5	4.2	243.36 #	23 #	20 #	11 #
Minimum:	0.2	12.1	462.5	0.2	1.50	0	0	0
Maximum:	28.9	17.4	2,117.0	48.7	54.60	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/03/2020 00:00	1.4	12.6	2,035.4	1.0	8.10	1	1	1
01/03/2020 01:00	1.6	12.5	2,028.9	1.1	8.10	1	1	1
01/03/2020 02:00	1.5	12.7	2,024.1	1.1	8.10	1	1	1
01/03/2020 03:00	1.4	12.6	2,037.3	1.0	8.10	1	1	1
01/03/2020 04:00	1.4	12.6	2,037.7	1.0	8.20	1	1	1
01/03/2020 05:00	1.4	12.6	2,030.5	1.0	8.10	1	1	1
01/03/2020 06:00	1.5	12.7	2,017.3	1.1	8.10	1	1	1
01/03/2020 07:00	1.4	12.7	2,027.9	1.0	8.10	1	1	1
01/03/2020 08:00	1.0	13.1	1,904.9	0.8	5.70	1	1	1
01/03/2020 09:00	0.4	13.7	1,532.8	0.3	1.50	1	1	0
01/03/2020 10:00	0.3	13.6	1,557.2	0.2	1.60	1	1	0
01/03/2020 11:00	0.3	13.6	1,606.4	0.2	1.60	1	1	0
01/03/2020 12:00	0.4	13.6	1,690.7	0.3	1.70	1	1	0
01/03/2020 13:00	0.4	13.6	1,668.8	0.3	1.70	1	1	0
01/03/2020 14:00	0.3	13.7	1,545.8	0.2	1.38	1	1	0
01/03/2020 15:00	0.3	13.7	1,581.2	0.2	1.60	1	1	0
01/03/2020 16:00	1.1	12.8	1,952.8	0.8	5.90	1	1	1
01/03/2020 17:00	1.3	12.5	2,034.8	0.9	6.10	1	1	1
01/03/2020 18:00	1.3	12.5	2,056.3	0.9	6.20	1	1	1
01/03/2020 19:00	1.3	12.5	2,041.2	0.9	6.10	1	1	1
01/03/2020 20:00	1.3	12.5	2,053.0	0.9	6.20	1	1	1
01/03/2020 21:00	1.3	12.3	2,095.6	0.9	6.30	1	1	1
01/03/2020 22:00	1.3	12.4	2,098.3	0.9	6.30	1	1	1
01/03/2020 23:00	2.4	13.1	1,674.2	1.8	11.70	1	0	1
Average/Sum#:	1.1	12.9	1,888.9	0.8	136.48 #	24 #	23 #	17 #
Minimum:	0.3	12.3	1,532.8	0.2	1.38	1	0	0
Maximum:	2.4	13.7	2,098.3	1.8	11.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/04/2020 00:00	0.0	19.1	0.2	0.0	0.00	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	19.1	0.2	0.0	0.00 #	1 #	0 #	0 #
Minimum:	0.0	19.1	0.2	0.0	0.00	0	0	0
Maximum:	0.0	19.1	0.2	0.0	0.00	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/06/2020 04:00	25.9	17.6	443.8	46.3	35.67	1	0	0
01/06/2020 05:00	26.4	16.5	601.7	35.4	78.20	1	0	0
01/06/2020 06:00	17.8	15.2	842.6	18.4	57.30	1	0	0
01/06/2020 07:00	0.1	13.7	1,588.4	0.1	0.00	1	1	0
01/06/2020 08:00	0.5	13.6	1,755.9	0.4	1.80	1	1	0
01/06/2020 09:00	0.3	13.6	1,667.1	0.2	1.70	1	1	0
01/06/2020 10:00	0.2	13.7	1,555.8	0.2	1.60	1	1	0
01/06/2020 11:00	0.4	13.7	1,654.8	0.3	1.70	1	1	0
01/06/2020 12:00	0.3	13.7	1,583.5	0.2	1.60	1	1	0
01/06/2020 13:00	0.3	13.7	1,638.7	0.2	1.60	1	1	0
01/06/2020 14:00	0.3	13.7	1,567.1	0.2	1.60	1	1	0
01/06/2020 15:00	0.3	13.6	1,552.6	0.2	1.60	1	1	1
01/06/2020 16:00	1.1	12.7	2,014.8	0.8	6.00	1	1	1
01/06/2020 17:00	1.4	12.5	2,053.4	1.0	8.20	1	1	1
01/06/2020 18:00	1.3	12.6	2,049.6	0.9	6.10	1	1	1
01/06/2020 19:00	1.3	12.6	2,036.0	0.9	6.10	1	1	1
01/06/2020 20:00	1.3	12.7	2,031.6	0.9	6.10	1	1	1
01/06/2020 21:00	1.3	12.7	2,034.9	0.9	6.10	1	1	1
01/06/2020 22:00	1.3	12.6	2,052.9	0.9	6.20	1	1	1
01/06/2020 23:00	1.3	12.8	2,017.5	0.9	6.10	1	1	1
Average/Sum#:	4.2	13.7	1,637.1	5.5	235.27 #	20 #	17 #	9 #
Minimum:	0.1	12.5	443.8	0.1	0.00	0	0	0
Maximum:	26.4	17.6	2,053.4	46.3	78.20	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/07/2020 00:00	1.3	12.7	2,036.3	0.9	6.10	1	1	1
01/07/2020 01:00	1.3	12.8	2,016.4	0.9	6.00	1	1	1
01/07/2020 02:00	1.3	12.8	2,008.2	0.9	6.00	1	1	1
01/07/2020 03:00	1.3	12.8	2,009.9	0.9	6.00	1	1	1
01/07/2020 04:00	1.3	12.8	2,025.5	0.9	6.10	1	1	1
01/07/2020 05:00	1.3	12.8	2,028.6	0.9	6.10	1	1	1
01/07/2020 06:00	1.3	12.7	2,031.0	0.9	6.10	1	1	1
01/07/2020 07:00	1.3	12.6	2,070.4	0.9	6.20	1	1	1
01/07/2020 08:00	1.0	13.1	1,960.5	0.8	5.90	1	1	1
01/07/2020 09:00	0.5	13.6	1,723.4	0.4	1.70	1	1	0
01/07/2020 10:00	0.3	13.6	1,625.3	0.2	1.60	1	1	0
01/07/2020 11:00	0.3	13.6	1,614.8	0.2	1.60	1	1	0
01/07/2020 12:00	0.4	13.6	1,677.6	0.3	1.70	1	1	0
01/07/2020 13:00	0.3	13.6	1,645.7	0.2	1.60	1	1	0
01/07/2020 14:00	0.3	13.6	1,593.5	0.2	1.60	1	1	0
01/07/2020 15:00	0.3	13.6	1,573.8	0.2	1.60	1	1	1
01/07/2020 16:00	1.0	12.7	2,015.1	0.7	6.00	1	1	1
01/07/2020 17:00	1.3	12.6	2,038.8	0.9	6.10	1	1	1
01/07/2020 18:00	1.3	12.6	2,036.1	0.9	6.10	1	1	1
01/07/2020 19:00	1.3	12.7	2,025.4	0.9	6.10	1	1	1
01/07/2020 20:00	1.3	12.6	2,056.1	0.9	6.20	1	1	1
01/07/2020 21:00	1.3	12.5	2,064.1	0.9	6.20	1	1	1
01/07/2020 22:00	3.3	14.1	1,265.4	2.9	6.67	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	13.0	1,875.7	0.8	109.27 #	23 #	22 #	17 #
Minimum:	0.3	12.5	1,265.4	0.2	1.60	0	0	0
Maximum:	3.3	14.1	2,070.4	2.9	6.67	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/08/2020 21:00	28.5	17.4	466.5	48.0	57.82	1	0	0
01/08/2020 22:00	10.9	16.9	529.7	16.1	31.30	1	0	0
01/08/2020 23:00	7.6	15.4	867.5	8.2	26.00	1	0	0
Average/Sum#:	15.7	16.6	621.2	24.1	115.12 #	3 #	0 #	0 #
Minimum:	7.6	15.4	466.5	8.2	26.00	0	0	0
Maximum:	28.5	17.4	867.5	48.0	57.82	1	0	0
%SI	87.50	87.50	87.50	87.50	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/09/2020 00:00	0.2	13.6	1,483.0	0.2	1.50	1	1	0
01/09/2020 01:00	0.3	13.7	1,373.4	0.2	1.40	1	1	0
01/09/2020 02:00	0.5	13.6	1,675.7	0.4	1.70	1	1	0
01/09/2020 03:00	0.3	13.6	1,512.9	0.2	1.50	1	1	0
01/09/2020 04:00	0.4	13.6	1,694.8	0.3	1.70	1	1	0
01/09/2020 05:00	0.3	13.6	1,634.8	0.2	1.60	1	1	0
01/09/2020 06:00	0.2	13.6	1,397.1	0.2	1.40	1	1	0
01/09/2020 07:00	0.2	13.6	1,491.7	0.2	1.50	1	1	0
01/09/2020 08:00	0.3	13.6	1,629.8	0.2	1.60	1	1	0
01/09/2020 09:00	0.4	13.6	1,707.6	0.3	1.70	1	1	0
01/09/2020 10:00	0.3	13.6	1,578.3	0.2	1.60	1	1	0
01/09/2020 11:00	0.4	13.6	1,674.2	0.3	1.70	1	1	0
01/09/2020 12:00	0.3	13.6	1,645.8	0.2	1.60	1	1	0
01/09/2020 13:00	0.4	13.6	1,690.6	0.3	1.70	1	1	0
01/09/2020 14:00	0.4	13.6	1,614.5	0.3	1.60	1	1	0
01/09/2020 15:00	0.3	13.6	1,567.8	0.2	1.60	1	1	0
01/09/2020 16:00	1.2	12.6	2,007.7	0.9	6.00	1	1	1
01/09/2020 17:00	1.5	12.4	2,076.0	1.0	8.30	1	1	1
01/09/2020 18:00	1.6	12.3	2,116.7	1.1	8.50	1	1	1
01/09/2020 19:00	1.6	12.2	2,110.6	1.1	8.40	1	1	1
01/09/2020 20:00	1.6	12.2	2,113.0	1.1	8.50	1	1	1
01/09/2020 21:00	1.6	12.3	2,094.0	1.1	8.40	1	1	1
01/09/2020 22:00	1.6	12.3	2,103.8	1.1	8.40	1	1	1
01/09/2020 23:00	1.6	12.3	2,100.4	1.1	8.40	1	1	1
Average/Sum#:	0.7	13.2	1,753.9	0.5	90.30 #	24 #	24 #	8 #
Minimum:	0.2	12.2	1,373.4	0.2	1.40	1	1	0
Maximum:	1.6	13.7	2,116.7	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2020 00:00	1.5	12.5	2,060.6	1.1	8.20	1	1	1
01/10/2020 01:00	1.5	12.6	2,043.4	1.1	8.20	1	1	1
01/10/2020 02:00	1.6	12.4	2,094.0	1.1	8.40	1	1	1
01/10/2020 03:00	1.5	12.4	2,097.6	1.0	8.40	1	1	1
01/10/2020 04:00	1.5	12.6	2,032.0	1.1	8.10	1	1	1
01/10/2020 05:00	1.4	12.6	2,049.4	1.0	8.20	1	1	1
01/10/2020 06:00	1.4	12.3	2,118.6	1.0	8.50	1	1	1
01/10/2020 07:00	1.4	12.2	2,158.0	0.9	6.50	1	1	1
01/10/2020 08:00	1.4	12.6	2,069.5	1.0	8.30	1	1	1
01/10/2020 09:00	0.9	13.0	1,935.5	0.7	3.90	1	1	1
01/10/2020 10:00	0.4	13.6	1,703.7	0.3	1.70	1	1	0
01/10/2020 11:00	0.3	13.6	1,668.0	0.2	1.70	1	1	0
01/10/2020 12:00	0.3	13.6	1,639.3	0.2	1.60	1	1	0
01/10/2020 13:00	0.3	13.6	1,680.8	0.2	1.70	1	1	0
01/10/2020 14:00	0.2	13.6	1,544.2	0.2	1.50	1	1	0
01/10/2020 15:00	0.3	13.6	1,552.5	0.2	1.60	1	1	1
01/10/2020 16:00	1.1	12.7	2,036.5	0.8	6.10	1	1	1
01/10/2020 17:00	1.4	12.4	2,082.9	1.0	8.30	1	1	1
01/10/2020 18:00	1.4	12.3	2,108.5	1.0	8.40	1	1	1
01/10/2020 19:00	1.4	12.4	2,088.6	1.0	8.40	1	1	1
01/10/2020 20:00	1.4	12.5	2,079.1	1.0	8.30	1	1	1
01/10/2020 21:00	1.4	12.5	2,066.4	1.0	8.30	1	1	1
01/10/2020 22:00	1.4	12.6	2,037.4	1.0	8.10	1	1	1
01/10/2020 23:00	1.3	12.7	2,023.2	0.9	6.10	1	1	1
Average/Sum#:	1.1	12.8	1,957.1	0.8	148.50 #	24 #	24 #	19 #
Minimum:	0.2	12.2	1,544.2	0.2	1.50	1	1	0
Maximum:	1.6	13.6	2,158.0	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/11/2020 00:00	1.3	12.7	2,028.9	0.9	6.10	1	1	1
01/11/2020 01:00	1.3	12.7	2,023.8	0.9	6.10	1	1	1
01/11/2020 02:00	1.3	12.7	2,028.4	0.9	6.10	1	1	1
01/11/2020 03:00	1.3	12.7	2,027.7	0.9	6.10	1	1	1
01/11/2020 04:00	1.3	12.7	2,034.1	0.9	6.10	1	1	1
01/11/2020 05:00	1.3	12.7	2,026.6	0.9	6.10	1	1	1
01/11/2020 06:00	1.4	12.7	2,030.0	1.0	8.10	1	1	1
01/11/2020 07:00	1.3	12.7	2,032.9	0.9	6.10	1	1	1
01/11/2020 08:00	3.2	14.0	1,305.5	2.7	6.81	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.5	12.8	1,948.7	1.1	57.61 #	9 #	8 #	9 #
Minimum:	1.3	12.7	1,305.5	0.9	6.10	0	0	0
Maximum:	3.2	14.0	2,034.1	2.7	8.10	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/12/2020 23:00	24.9	17.6	441.6	44.5	32.58	1	0	0
Average/Sum#:	24.9	17.6	441.6	44.5	32.58 #	1 #	0 #	0 #
Minimum:	24.9	17.6	441.6	44.5	32.58	0	0	0
Maximum:	24.9	17.6	441.6	44.5	32.58	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/13/2020 00:00	23.5	16.0	661.7	28.3	68.80	1	0	0
01/13/2020 01:00	11.7	14.8	987.5	11.3	41.50	1	0	0
01/13/2020 02:00	0.1	13.6	1,448.4	0.1	0.00	1	1	0
01/13/2020 03:00	0.2	13.6	1,451.3	0.2	1.50	1	1	0
01/13/2020 04:00	0.6	13.6	1,670.8	0.5	3.30	1	1	0
01/13/2020 05:00	0.4	13.6	1,668.2	0.3	1.70	1	1	0
01/13/2020 06:00	0.3	13.6	1,646.5	0.2	1.60	1	1	0
01/13/2020 07:00	0.3	13.6	1,631.2	0.2	1.60	1	1	0
01/13/2020 08:00	0.2	13.6	1,555.4	0.2	1.60	1	1	0
01/13/2020 09:00	0.3	13.6	1,679.3	0.2	1.70	1	1	0
01/13/2020 10:00	0.3	13.6	1,602.4	0.2	1.60	1	1	0
01/13/2020 11:00	0.2	13.6	1,526.5	0.2	1.50	1	1	0
01/13/2020 12:00	0.3	13.6	1,619.3	0.2	1.60	1	1	0
01/13/2020 13:00	0.4	13.6	1,695.9	0.3	1.70	1	1	0
01/13/2020 14:00	0.3	13.6	1,584.8	0.2	1.60	1	1	0
01/13/2020 15:00	0.4	13.6	1,558.6	0.3	1.60	1	1	1
01/13/2020 16:00	1.1	12.6	2,023.2	0.8	6.10	1	1	1
01/13/2020 17:00	1.6	12.1	2,141.0	1.1	8.60	1	1	1
01/13/2020 18:00	1.6	12.0	2,154.5	1.1	8.60	1	1	1
01/13/2020 19:00	1.6	12.0	2,143.7	1.1	8.60	1	1	1
01/13/2020 20:00	1.5	12.1	2,133.0	1.0	8.50	1	1	1
01/13/2020 21:00	1.4	12.3	2,088.1	1.0	8.40	1	1	1
01/13/2020 22:00	1.3	12.4	2,057.2	0.9	6.20	1	1	1
01/13/2020 23:00	1.3	12.5	2,041.9	0.9	6.10	1	1	1
Average/Sum#:	2.1	13.3	1,698.8	2.1	194.00 #	24 #	22 #	9 #
Minimum:	0.1	12.0	661.7	0.1	0.00	1	0	0
Maximum:	23.5	16.0	2,154.5	28.3	68.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/14/2020 00:00	1.4	12.5	2,051.1	1.0	8.20	1	1	1
01/14/2020 01:00	1.4	12.5	2,039.4	1.0	8.20	1	1	1
01/14/2020 02:00	1.5	12.5	2,041.0	1.1	8.20	1	1	1
01/14/2020 03:00	1.5	12.5	2,038.9	1.1	8.20	1	1	1
01/14/2020 04:00	1.4	12.6	2,040.0	1.0	8.20	1	1	1
01/14/2020 05:00	1.4	12.5	2,066.2	1.0	8.30	1	1	1
01/14/2020 06:00	1.5	12.3	2,101.0	1.0	8.40	1	1	1
01/14/2020 07:00	1.6	12.1	2,160.1	1.1	8.60	1	1	1
01/14/2020 08:00	1.4	12.6	2,045.8	1.0	8.20	1	1	1
01/14/2020 09:00	1.4	12.7	1,989.4	1.0	8.00	1	1	1
01/14/2020 10:00	0.0	0.0	1,683.1	0.0	0.00	1	1	0
01/14/2020 11:00	0.6	13.6	1,700.2	0.5	3.40	1	1	0
01/14/2020 12:00	0.5	13.6	1,666.5	0.4	1.70	1	1	0
01/14/2020 13:00	0.0	0.0	1,688.7	0.0	0.00	1	1	0
01/14/2020 14:00	0.0	0.0	1,630.2	0.0	0.00	1	1	0
01/14/2020 15:00	0.3	13.6	1,542.0	0.2	1.50	1	1	0
01/14/2020 16:00	0.6	13.6	1,559.5	0.5	3.10	1	1	1
01/14/2020 17:00	1.1	12.7	2,008.7	0.8	6.00	1	1	1
01/14/2020 18:00	1.4	12.6	2,045.2	1.0	8.20	1	1	1
01/14/2020 19:00	1.4	12.6	2,051.3	1.0	8.20	1	1	1
01/14/2020 20:00	1.5	12.4	2,087.9	1.0	8.40	1	1	1
01/14/2020 21:00	1.5	12.5	2,074.8	1.1	8.30	1	1	1
01/14/2020 22:00	1.4	12.6	2,045.6	1.0	8.20	1	1	1
01/14/2020 23:00	1.2	12.9	1,998.1	0.9	6.00	1	1	1
Average/Sum#:	1.2	12.7	1,931.4	0.9	145.50 #	24 #	24 #	18 #
Minimum:	0.3	12.1	1,542.0	0.2	1.50	1	1	0
Maximum:	1.6	13.6	2,160.1	1.1	8.60	1	1	1
%SI	12.50	12.50	0.00	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/15/2020 00:00	1.3	12.7	2,039.3	0.9	6.10	1	1	1
01/15/2020 01:00	1.4	12.7	2,043.2	1.0	8.20	1	1	1
01/15/2020 02:00	1.4	12.7	2,042.0	1.0	8.20	1	1	1
01/15/2020 03:00	1.3	12.7	2,045.1	0.9	6.10	1	1	1
01/15/2020 04:00	1.4	12.7	2,043.0	1.0	8.20	1	1	1
01/15/2020 05:00	1.4	12.6	2,070.1	1.0	8.30	1	1	1
01/15/2020 06:00	1.6	12.1	2,164.6	1.1	8.70	1	1	1
01/15/2020 07:00	1.6	11.9	2,252.3	1.0	9.00	1	1	1
01/15/2020 08:00	1.3	12.6	2,048.1	0.9	6.10	1	1	1
01/15/2020 09:00	0.4	13.6	1,620.5	0.3	1.60	1	1	0
01/15/2020 10:00	0.3	13.6	1,658.9	0.2	1.70	1	1	0
01/15/2020 11:00	0.3	13.6	1,676.0	0.2	1.70	1	1	0
01/15/2020 12:00	0.3	13.6	1,635.8	0.2	1.60	1	1	0
01/15/2020 13:00	0.4	13.6	1,681.8	0.3	1.70	1	1	0
01/15/2020 14:00	0.4	13.6	1,696.5	0.3	1.70	1	1	0
01/15/2020 15:00	0.3	13.6	1,600.5	0.2	1.60	1	1	1
01/15/2020 16:00	1.1	12.5	2,069.1	0.8	6.20	1	1	1
01/15/2020 17:00	1.5	12.0	2,163.9	1.0	8.70	1	1	1
01/15/2020 18:00	1.5	12.1	2,140.1	1.0	8.60	1	1	1
01/15/2020 19:00	1.6	11.9	2,194.1	1.0	8.80	1	1	1
01/15/2020 20:00	1.6	11.9	2,188.0	1.0	8.80	1	1	1
01/15/2020 21:00	1.5	12.0	2,172.6	1.0	8.70	1	1	1
01/15/2020 22:00	1.4	12.3	2,093.7	1.0	8.40	1	1	1
01/15/2020 23:00	1.4	12.5	2,055.0	1.0	8.20	1	1	1
Average/Sum#:	1.1	12.7	1,974.8	0.8	146.90 #	24 #	24 #	18 #
Minimum:	0.3	11.9	1,600.5	0.2	1.60	1	1	0
Maximum:	1.6	13.6	2,252.3	1.1	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/16/2020 00:00	1.3	12.5	2,039.7	0.9	6.10	1	1	1
01/16/2020 01:00	1.3	12.5	2,046.8	0.9	6.10	1	1	1
01/16/2020 02:00	1.3	12.5	2,051.3	0.9	6.20	1	1	1
01/16/2020 03:00	1.3	12.5	2,054.4	0.9	6.20	1	1	1
01/16/2020 04:00	1.3	12.5	2,058.2	0.9	6.20	1	1	1
01/16/2020 05:00	1.3	12.5	2,056.4	0.9	6.20	1	1	1
01/16/2020 06:00	1.5	12.3	2,095.9	1.0	8.40	1	1	1
01/16/2020 07:00	1.5	11.9	2,179.2	1.0	8.70	1	1	1
01/16/2020 08:00	1.3	12.4	2,073.8	0.9	6.20	1	1	1
01/16/2020 09:00	1.2	12.7	1,978.0	0.9	5.90	1	1	1
01/16/2020 10:00	0.5	13.6	1,670.4	0.4	1.70	1	1	0
01/16/2020 11:00	0.3	13.6	1,582.6	0.2	1.60	1	1	0
01/16/2020 12:00	0.3	13.6	1,529.2	0.2	1.50	1	1	0
01/16/2020 13:00	0.4	13.6	1,663.4	0.3	1.70	1	1	0
01/16/2020 14:00	0.3	13.6	1,602.9	0.2	1.60	1	1	0
01/16/2020 15:00	0.5	13.6	1,736.8	0.4	1.70	1	1	1
01/16/2020 16:00	1.1	12.6	2,021.4	0.8	6.10	1	1	1
01/16/2020 17:00	1.4	12.5	2,045.6	1.0	8.20	1	1	1
01/16/2020 18:00	1.4	12.5	2,039.3	1.0	8.20	1	1	1
01/16/2020 19:00	1.4	12.5	2,049.6	1.0	8.20	1	1	1
01/16/2020 20:00	1.5	12.4	2,086.3	1.0	8.30	1	1	1
01/16/2020 21:00	1.5	12.4	2,091.1	1.0	8.40	1	1	1
01/16/2020 22:00	1.4	12.7	2,030.5	1.0	8.10	1	1	1
01/16/2020 23:00	1.4	12.7	2,037.6	1.0	8.20	1	1	1
Average/Sum#:	1.1	12.8	1,950.9	0.8	139.70 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,529.2	0.2	1.50	1	1	0
Maximum:	1.5	13.6	2,179.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/17/2020 00:00	1.4	12.7	2,045.2	1.0	8.20	1	1	1
01/17/2020 01:00	1.4	12.8	2,021.3	1.0	8.10	1	1	1
01/17/2020 02:00	1.4	12.7	2,042.7	1.0	8.20	1	1	1
01/17/2020 03:00	1.4	12.8	2,041.2	1.0	8.20	1	1	1
01/17/2020 04:00	1.4	12.7	2,050.0	1.0	8.20	1	1	1
01/17/2020 05:00	1.4	12.7	2,064.2	1.0	8.30	1	1	1
01/17/2020 06:00	1.5	12.0	2,193.2	1.0	8.80	1	1	1
01/17/2020 07:00	1.6	11.9	2,248.6	1.0	9.00	1	1	1
01/17/2020 08:00	1.3	12.7	2,057.1	0.9	6.20	1	1	1
01/17/2020 09:00	1.1	12.9	1,983.8	0.8	6.00	1	1	1
01/17/2020 10:00	0.4	13.6	1,692.8	0.3	1.70	1	1	0
01/17/2020 11:00	0.3	13.6	1,637.7	0.2	1.60	1	1	0
01/17/2020 12:00	0.4	13.6	1,669.2	0.3	1.70	1	1	0
01/17/2020 13:00	0.4	13.6	1,656.5	0.3	1.70	1	1	0
01/17/2020 14:00	0.3	13.6	1,632.7	0.2	1.60	1	1	0
01/17/2020 15:00	0.3	13.6	1,517.8	0.2	1.50	1	1	1
01/17/2020 16:00	1.1	12.7	2,010.2	0.8	6.00	1	1	1
01/17/2020 17:00	1.2	12.8	1,972.3	0.9	5.90	1	1	1
01/17/2020 18:00	1.4	12.9	1,979.7	1.0	7.90	1	1	1
01/17/2020 19:00	1.5	12.4	2,087.5	1.0	8.40	1	1	1
01/17/2020 20:00	1.5	12.3	2,116.9	1.0	8.50	1	1	1
01/17/2020 21:00	1.5	12.4	2,106.8	1.0	8.40	1	1	1
01/17/2020 22:00	1.5	12.4	2,086.2	1.0	8.30	1	1	1
01/17/2020 23:00	1.4	12.6	2,065.8	1.0	8.30	1	1	1
Average/Sum#:	1.1	12.8	1,957.5	0.8	150.70 #	24 #	24 #	19 #
Minimum:	0.3	11.9	1,517.8	0.2	1.50	1	1	0
Maximum:	1.6	13.6	2,248.6	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/18/2020 00:00	1.4	12.6	2,047.8	1.0	8.20	1	1	1
01/18/2020 01:00	1.4	12.6	2,060.0	1.0	8.20	1	1	1
01/18/2020 02:00	1.4	12.7	2,031.0	1.0	8.10	1	1	1
01/18/2020 03:00	1.4	12.7	2,033.6	1.0	8.10	1	1	1
01/18/2020 04:00	1.4	12.7	2,034.3	1.0	8.10	1	1	1
01/18/2020 05:00	1.4	12.7	2,033.7	1.0	8.10	1	1	1
01/18/2020 06:00	1.4	12.7	2,035.8	1.0	8.10	1	1	1
01/18/2020 07:00	1.3	12.7	2,032.1	0.9	6.10	1	1	1
01/18/2020 08:00	1.1	13.0	2,008.0	0.8	6.00	1	1	1
01/18/2020 09:00	0.4	13.6	1,685.4	0.3	1.70	1	1	1
01/18/2020 10:00	0.3	13.6	1,636.9	0.2	1.60	1	1	0
01/18/2020 11:00	0.3	13.6	1,616.7	0.2	1.60	1	1	0
01/18/2020 12:00	0.3	13.6	1,634.4	0.2	1.60	1	1	0
01/18/2020 13:00	0.3	13.6	1,663.8	0.2	1.70	1	1	0
01/18/2020 14:00	0.3	13.6	1,631.3	0.2	1.60	1	1	0
01/18/2020 15:00	0.4	13.6	1,611.6	0.3	1.60	1	1	1
01/18/2020 16:00	1.1	12.7	2,018.3	0.8	6.10	1	1	1
01/18/2020 17:00	1.4	12.6	2,041.6	1.0	8.20	1	1	1
01/18/2020 18:00	1.2	12.9	1,972.5	0.9	5.90	1	1	1
01/18/2020 19:00	1.5	12.5	2,060.4	1.1	8.20	1	1	1
01/18/2020 20:00	1.6	12.3	2,113.0	1.1	8.50	1	1	1
01/18/2020 21:00	1.6	12.3	2,118.6	1.1	8.50	1	1	1
01/18/2020 22:00	1.6	12.2	2,128.9	1.1	8.50	1	1	1
01/18/2020 23:00	1.6	12.3	2,107.7	1.1	8.40	1	1	1
Average/Sum#:	1.1	12.9	1,931.6	0.8	142.70 #	24 #	24 #	19 #
Minimum:	0.3	12.2	1,611.6	0.2	1.60	1	1	0
Maximum:	1.6	13.6	2,128.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/19/2020 00:00	1.5	12.5	2,026.4	1.1	8.10	1	1	1
01/19/2020 01:00	0.5	13.6	1,708.0	0.4	1.70	1	1	0
01/19/2020 02:00	0.3	13.6	1,559.6	0.2	1.60	1	1	0
01/19/2020 03:00	0.3	13.6	1,637.5	0.2	1.60	1	1	0
01/19/2020 04:00	0.3	13.6	1,630.0	0.2	1.60	1	1	0
01/19/2020 05:00	0.3	13.6	1,678.4	0.2	1.70	1	1	0
01/19/2020 06:00	0.4	13.6	1,699.9	0.3	1.70	1	1	0
01/19/2020 07:00	0.3	13.6	1,603.0	0.2	1.60	1	1	0
01/19/2020 08:00	0.3	13.6	1,563.8	0.2	1.60	1	1	0
01/19/2020 09:00	0.3	13.6	1,632.9	0.2	1.60	1	1	0
01/19/2020 10:00	0.3	13.6	1,576.8	0.2	1.60	1	1	0
01/19/2020 11:00	0.3	13.6	1,649.1	0.2	1.60	1	1	0
01/19/2020 12:00	0.4	13.6	1,668.4	0.3	1.70	1	1	0
01/19/2020 13:00	0.4	13.6	1,686.3	0.3	1.70	1	1	0
01/19/2020 14:00	0.3	13.6	1,595.7	0.2	1.60	1	1	0
01/19/2020 15:00	0.4	13.6	1,628.8	0.3	1.60	1	1	0
01/19/2020 16:00	0.4	13.6	1,623.0	0.3	1.60	1	1	1
01/19/2020 17:00	1.1	12.7	2,015.6	0.8	6.00	1	1	1
01/19/2020 18:00	1.3	12.5	2,047.9	0.9	6.10	1	1	1
01/19/2020 19:00	1.4	12.6	2,041.9	1.0	8.20	1	1	1
01/19/2020 20:00	1.4	12.3	2,102.5	1.0	8.40	1	1	1
01/19/2020 21:00	1.5	12.2	2,125.7	1.0	8.50	1	1	1
01/19/2020 22:00	1.5	12.2	2,120.0	1.0	8.50	1	1	1
01/19/2020 23:00	1.4	12.3	2,111.0	1.0	8.40	1	1	1
Average/Sum#:	0.7	13.2	1,780.5	0.5	88.30 #	24 #	24 #	9 #
Minimum:	0.3	12.2	1,559.6	0.2	1.60	1	1	0
Maximum:	1.5	13.6	2,125.7	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/20/2020 00:00	1.4	12.4	2,079.7	1.0	8.30	1	1	1
01/20/2020 01:00	1.4	12.6	2,045.1	1.0	8.20	1	1	1
01/20/2020 02:00	1.4	12.6	2,027.0	1.0	8.10	1	1	1
01/20/2020 03:00	1.4	12.6	2,033.0	1.0	8.10	1	1	1
01/20/2020 04:00	1.4	12.6	2,037.0	1.0	8.10	1	1	1
01/20/2020 05:00	1.4	12.5	2,048.2	1.0	8.20	1	1	1
01/20/2020 06:00	1.4	12.5	2,054.6	1.0	8.20	1	1	1
01/20/2020 07:00	1.4	12.3	2,111.4	1.0	8.40	1	1	1
01/20/2020 08:00	1.4	12.2	2,128.5	0.9	6.40	1	1	1
01/20/2020 09:00	1.5	12.2	2,108.7	1.0	8.40	1	1	1
01/20/2020 10:00	1.5	12.2	2,124.2	1.0	8.50	1	1	1
01/20/2020 11:00	1.4	12.2	2,103.7	0.9	6.30	1	1	1
01/20/2020 12:00	1.5	12.1	2,117.8	1.0	8.50	1	1	1
01/20/2020 13:00	1.5	12.2	2,112.3	1.0	8.40	1	1	1
01/20/2020 14:00	1.6	12.1	2,131.1	1.1	8.50	1	1	1
01/20/2020 15:00	1.5	12.2	2,101.1	1.0	8.40	1	1	1
01/20/2020 16:00	1.4	12.4	2,065.6	1.0	8.30	1	1	1
01/20/2020 17:00	1.5	12.2	2,111.9	1.0	8.40	1	1	1
01/20/2020 18:00	1.5	12.2	2,113.8	1.0	8.50	1	1	1
01/20/2020 19:00	1.4	12.2	2,109.9	0.9	6.30	1	1	1
01/20/2020 20:00	1.4	12.2	2,109.6	0.9	6.30	1	1	1
01/20/2020 21:00	1.4	12.3	2,104.2	1.0	8.40	1	1	1
01/20/2020 22:00	1.4	12.3	2,090.5	1.0	8.40	1	1	1
01/20/2020 23:00	1.4	12.4	2,065.2	1.0	8.30	1	1	1
Average/Sum#:	1.4	12.3	2,088.9	1.0	191.90 #	24 #	24 #	24 #
Minimum:	1.4	12.1	2,027.0	0.9	6.30	1	1	1
Maximum:	1.6	12.6	2,131.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/21/2020 00:00	1.4	12.5	2,039.9	1.0	8.20	1	1	1
01/21/2020 01:00	1.4	12.6	2,032.9	1.0	8.10	1	1	1
01/21/2020 02:00	1.4	12.6	2,037.9	1.0	8.20	1	1	1
01/21/2020 03:00	1.4	12.5	2,039.8	1.0	8.20	1	1	1
01/21/2020 04:00	1.4	12.5	2,036.1	1.0	8.10	1	1	1
01/21/2020 05:00	1.4	12.5	2,037.0	1.0	8.10	1	1	1
01/21/2020 06:00	1.3	12.6	2,010.2	0.9	6.00	1	1	1
01/21/2020 07:00	1.4	12.3	2,085.0	1.0	8.30	1	1	1
01/21/2020 08:00	1.4	12.5	2,053.1	1.0	8.20	1	1	1
01/21/2020 09:00	1.2	12.7	1,982.7	0.9	5.90	1	1	1
01/21/2020 10:00	0.5	13.5	1,681.4	0.4	1.70	1	1	1
01/21/2020 11:00	0.5	13.6	1,692.8	0.4	1.70	1	1	0
01/21/2020 12:00	0.4	13.6	1,659.1	0.3	1.70	1	1	0
01/21/2020 13:00	0.4	13.6	1,630.8	0.3	1.60	1	1	0
01/21/2020 14:00	0.4	13.6	1,640.3	0.3	1.60	1	1	0
01/21/2020 15:00	0.4	13.6	1,563.7	0.3	1.60	1	1	1
01/21/2020 16:00	1.1	12.5	2,034.2	0.8	6.10	1	1	1
01/21/2020 17:00	1.3	12.4	2,056.2	0.9	6.20	1	1	1
01/21/2020 18:00	1.4	12.4	2,048.2	1.0	8.20	1	1	1
01/21/2020 19:00	1.4	12.4	2,044.8	1.0	8.20	1	1	1
01/21/2020 20:00	1.4	12.4	2,039.9	1.0	8.20	1	1	1
01/21/2020 21:00	1.3	12.5	2,034.2	0.9	6.10	1	1	1
01/21/2020 22:00	1.4	12.3	2,070.4	1.0	8.30	1	1	1
01/21/2020 23:00	1.3	12.5	2,044.8	0.9	6.10	1	1	1
Average/Sum#:	1.1	12.8	1,941.5	0.8	144.60 #	24 #	24 #	20 #
Minimum:	0.4	12.3	1,563.7	0.3	1.60	1	1	0
Maximum:	1.4	13.6	2,085.0	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2020 00:00	1.1	13.0	1,841.4	0.8	5.50	1	1	1
01/22/2020 01:00	0.3	13.6	1,309.8	0.2	1.30	1	1	0
01/22/2020 02:00	0.3	13.6	1,381.3	0.2	1.40	1	1	0
01/22/2020 03:00	0.3	13.6	1,345.7	0.2	1.30	1	1	0
01/22/2020 04:00	0.4	13.6	1,527.5	0.3	1.50	1	1	0
01/22/2020 05:00	0.3	13.6	1,463.0	0.2	1.50	1	1	0
01/22/2020 06:00	0.4	13.6	1,596.4	0.3	1.60	1	1	0
01/22/2020 07:00	0.4	13.6	1,646.4	0.3	1.60	1	1	0
01/22/2020 08:00	0.3	13.6	1,493.5	0.2	1.50	1	1	0
01/22/2020 09:00	0.4	13.6	1,595.0	0.3	1.60	1	1	0
01/22/2020 10:00	0.4	13.6	1,624.5	0.3	1.60	1	1	0
01/22/2020 11:00	0.4	13.6	1,705.1	0.3	1.70	1	1	0
01/22/2020 12:00	0.4	13.6	1,710.3	0.3	1.70	1	1	0
01/22/2020 13:00	0.4	13.6	1,669.7	0.3	1.70	1	1	0
01/22/2020 14:00	0.4	13.6	1,640.8	0.3	1.60	1	1	0
01/22/2020 15:00	0.4	13.6	1,608.1	0.3	1.60	1	1	1
01/22/2020 16:00	1.2	12.6	2,032.9	0.9	6.10	1	1	1
01/22/2020 17:00	1.4	12.6	2,017.9	1.0	8.10	1	1	1
01/22/2020 18:00	1.6	12.2	2,121.4	1.1	8.50	1	1	1
01/22/2020 19:00	1.5	12.2	2,114.1	1.0	8.50	1	1	1
01/22/2020 20:00	1.4	12.5	2,048.7	1.0	8.20	1	1	1
01/22/2020 21:00	1.4	12.6	2,040.8	1.0	8.20	1	1	1
01/22/2020 22:00	1.4	12.5	2,045.9	1.0	8.20	1	1	1
01/22/2020 23:00	1.2	12.9	1,969.2	0.9	5.90	1	1	1
Average/Sum#:	0.7	13.2	1,731.2	0.5	90.40 #	24 #	24 #	10 #
Minimum:	0.3	12.2	1,309.8	0.2	1.30	1	1	0
Maximum:	1.6	13.6	2,121.4	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/23/2020 00:00	1.4	12.4	2,093.9	1.0	8.40	1	1	1
01/23/2020 01:00	1.4	12.3	2,092.7	1.0	8.40	1	1	1
01/23/2020 02:00	1.4	12.5	2,044.9	1.0	8.20	1	1	1
01/23/2020 03:00	1.4	12.6	2,042.8	1.0	8.20	1	1	1
01/23/2020 04:00	1.5	12.3	2,107.6	1.0	8.40	1	1	1
01/23/2020 05:00	1.4	12.6	2,053.0	1.0	8.20	1	1	1
01/23/2020 06:00	1.4	12.2	2,134.5	0.9	6.40	1	1	1
01/23/2020 07:00	1.4	12.4	2,097.9	1.0	8.40	1	1	1
01/23/2020 08:00	1.1	12.9	1,950.8	0.8	5.90	1	1	1
01/23/2020 09:00	0.4	13.6	1,683.4	0.3	1.70	1	1	0
01/23/2020 10:00	0.3	13.6	1,559.2	0.2	1.60	1	1	0
01/23/2020 11:00	0.4	13.6	1,615.7	0.3	1.60	1	1	0
01/23/2020 12:00	0.4	13.6	1,642.0	0.3	1.60	1	1	0
01/23/2020 13:00	0.4	13.6	1,672.7	0.3	1.70	1	1	0
01/23/2020 14:00	0.4	13.6	1,662.7	0.3	1.70	1	1	0
01/23/2020 15:00	0.4	13.6	1,631.3	0.3	1.60	1	1	0
01/23/2020 16:00	0.3	13.6	1,505.8	0.2	1.50	1	1	0
01/23/2020 17:00	0.9	12.9	1,927.7	0.7	3.90	1	1	1
01/23/2020 18:00	1.4	12.1	2,123.8	0.9	6.40	1	1	1
01/23/2020 19:00	1.5	12.1	2,119.7	1.0	8.50	1	1	1
01/23/2020 20:00	1.5	12.2	2,116.2	1.0	8.50	1	1	1
01/23/2020 21:00	1.5	12.2	2,102.1	1.0	8.40	1	1	1
01/23/2020 22:00	1.4	12.4	2,066.4	1.0	8.30	1	1	1
01/23/2020 23:00	1.1	12.9	1,955.6	0.8	5.90	1	1	1
Average/Sum#:	1.0	12.8	1,916.8	0.7	133.40 #	24 #	24 #	16 #
Minimum:	0.3	12.1	1,505.8	0.2	1.50	1	1	0
Maximum:	1.5	13.6	2,134.5	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2020 00:00	1.0	12.9	1,936.9	0.7	5.80	1	1	1
01/24/2020 01:00	0.5	13.6	1,646.8	0.4	1.60	1	1	0
01/24/2020 02:00	0.4	13.6	1,665.5	0.3	1.70	1	1	0
01/24/2020 03:00	0.4	13.6	1,699.4	0.3	1.70	1	1	0
01/24/2020 04:00	0.4	13.6	1,701.8	0.3	1.70	1	1	0
01/24/2020 05:00	0.3	13.6	1,600.3	0.2	1.60	1	1	0
01/24/2020 06:00	0.5	13.6	1,657.8	0.4	1.70	1	1	0
01/24/2020 07:00	0.4	13.6	1,654.5	0.3	1.70	1	1	0
01/24/2020 08:00	0.3	13.6	1,597.3	0.2	1.60	1	1	0
01/24/2020 09:00	0.4	13.6	1,669.6	0.3	1.70	1	1	0
01/24/2020 10:00	0.3	13.6	1,482.9	0.2	1.50	1	1	0
01/24/2020 11:00	0.4	13.6	1,665.0	0.3	1.70	1	1	0
01/24/2020 12:00	0.4	13.6	1,639.1	0.3	1.60	1	1	0
01/24/2020 13:00	0.4	13.6	1,681.7	0.3	1.70	1	1	0
01/24/2020 14:00	0.4	13.6	1,653.2	0.3	1.70	1	1	0
01/24/2020 15:00	0.3	13.6	1,557.3	0.2	1.60	1	1	0
01/24/2020 16:00	0.4	13.6	1,589.3	0.3	1.60	1	1	1
01/24/2020 17:00	1.1	12.5	2,029.3	0.8	6.10	1	1	1
01/24/2020 18:00	1.4	12.2	2,115.6	0.9	6.30	1	1	1
01/24/2020 19:00	1.5	12.2	2,112.0	1.0	8.40	1	1	1
01/24/2020 20:00	1.5	12.2	2,104.4	1.0	8.40	1	1	1
01/24/2020 21:00	1.4	12.3	2,077.7	1.0	8.30	1	1	1
01/24/2020 22:00	1.4	12.5	2,048.2	1.0	8.20	1	1	1
01/24/2020 23:00	3.5	13.9	1,278.7	3.0	7.05	1	0	1
Average/Sum#:	0.8	13.3	1,744.3	0.6	84.95 #	24 #	23 #	9 #
Minimum:	0.3	12.2	1,278.7	0.2	1.50	1	0	0
Maximum:	3.5	13.9	2,115.6	3.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/27/2020 18:00	28.2	17.3	476.2	46.2	64.80	1	0	0
01/27/2020 19:00	11.1	16.8	534.7	16.0	31.50	1	0	0
01/27/2020 20:00	9.6	15.3	882.3	10.1	32.60	1	0	0
01/27/2020 21:00	0.1	13.6	1,433.6	0.1	0.00	1	1	0
01/27/2020 22:00	0.3	13.7	1,367.5	0.2	1.40	1	1	0
01/27/2020 23:00	0.3	13.7	1,370.1	0.2	1.40	1	1	0
Average/Sum#:	8.3	15.1	1,010.7	12.1	131.70 #	6 #	3 #	0 #
Minimum:	0.1	13.6	476.2	0.1	0.00	0	0	0
Maximum:	28.2	17.3	1,433.6	46.2	64.80	1	1	0
%SI	75.00	75.00	75.00	75.00	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/28/2020 00:00	0.3	13.7	1,367.3	0.2	1.40	1	1	0
01/28/2020 01:00	0.3	13.6	1,362.7	0.2	1.40	1	1	0
01/28/2020 02:00	0.3	13.6	1,362.1	0.2	1.40	1	1	0
01/28/2020 03:00	0.5	13.6	1,634.5	0.4	1.60	1	1	0
01/28/2020 04:00	0.3	13.6	1,495.1	0.2	1.50	1	1	0
01/28/2020 05:00	0.3	13.6	1,602.4	0.2	1.60	1	1	0
01/28/2020 06:00	0.5	13.6	1,703.4	0.4	1.70	1	1	0
01/28/2020 07:00	0.3	13.6	1,611.7	0.2	1.60	1	1	0
01/28/2020 08:00	0.4	13.6	1,672.8	0.3	1.70	1	1	0
01/28/2020 09:00	0.4	13.6	1,687.1	0.3	1.70	1	1	0
01/28/2020 10:00	0.3	13.6	1,538.9	0.2	1.50	1	1	0
01/28/2020 11:00	0.4	13.6	1,621.0	0.3	1.60	1	1	0
01/28/2020 12:00	0.4	13.6	1,613.2	0.3	1.60	1	1	0
01/28/2020 13:00	0.4	13.6	1,671.5	0.3	1.70	1	1	0
01/28/2020 14:00	0.4	13.6	1,580.4	0.3	1.60	1	1	0
01/28/2020 15:00	0.4	13.6	1,569.9	0.3	1.60	1	1	0
01/28/2020 16:00	0.4	13.6	1,573.9	0.3	1.60	1	1	1
01/28/2020 17:00	1.1	12.6	2,024.2	0.8	6.10	1	1	1
01/28/2020 18:00	1.4	12.4	2,066.7	1.0	8.30	1	1	1
01/28/2020 19:00	1.4	12.3	2,086.3	1.0	8.30	1	1	1
01/28/2020 20:00	1.5	12.2	2,113.2	1.0	8.50	1	1	1
01/28/2020 21:00	1.5	12.2	2,112.7	1.0	8.50	1	1	1
01/28/2020 22:00	4.4	13.9	1,290.1	3.7	9.41	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.8	13.3	1,667.9	0.6	75.91 #	23 #	22 #	7 #
Minimum:	0.3	12.2	1,290.1	0.2	1.40	0	0	0
Maximum:	4.4	13.9	2,113.2	3.7	9.41	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
01/29/2020 17:00	29.0	17.3	460.5	47.5	56.42	1	0	0
01/29/2020 18:00	17.5	15.9	657.2	20.7	49.90	1	0	0
01/29/2020 19:00	10.7	14.2	1,327.0	9.4	46.40	1	0	0
01/29/2020 20:00	1.1	13.0	1,853.0	0.8	5.60	1	1	1
01/29/2020 21:00	1.7	11.8	2,158.1	1.1	8.60	1	1	1
01/29/2020 22:00	0.8	13.3	1,632.5	0.6	3.30	1	1	1
01/29/2020 23:00	0.4	13.7	1,528.4	0.3	1.50	1	1	0
Average/Sum#:	8.7	14.2	1,373.8	11.5	171.72 #	7 #	4 #	3 #
Minimum:	0.4	11.8	460.5	0.3	1.50	0	0	0
Maximum:	29.0	17.3	2,158.1	47.5	56.42	1	1	1
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/30/2020 00:00	0.3	13.6	1,552.4	0.2	1.60	1	1	0
01/30/2020 01:00	0.3	13.6	1,556.1	0.2	1.60	1	1	0
01/30/2020 02:00	0.5	13.6	1,692.0	0.4	1.70	1	1	0
01/30/2020 03:00	0.3	13.6	1,472.5	0.2	1.50	1	1	0
01/30/2020 04:00	0.4	13.6	1,642.6	0.3	1.60	1	1	0
01/30/2020 05:00	0.2	13.6	1,391.3	0.2	1.40	1	1	0
01/30/2020 06:00	1.0	12.9	1,859.5	0.7	5.60	1	1	1
01/30/2020 07:00	1.3	12.4	2,091.1	0.9	6.30	1	1	1
01/30/2020 08:00	1.0	12.9	1,946.8	0.7	5.80	1	1	1
01/30/2020 09:00	0.4	13.6	1,635.6	0.3	1.60	1	1	0
01/30/2020 10:00	0.4	13.6	1,643.1	0.3	1.60	1	1	0
01/30/2020 11:00	0.5	13.6	1,694.3	0.4	1.70	1	1	0
01/30/2020 12:00	0.3	13.6	1,499.8	0.2	1.50	1	1	0
01/30/2020 13:00	0.4	13.6	1,657.3	0.3	1.70	1	1	0
01/30/2020 14:00	0.3	13.6	1,554.7	0.2	1.60	1	1	0
01/30/2020 15:00	0.4	13.6	1,633.8	0.3	1.60	1	1	0
01/30/2020 16:00	0.3	13.6	1,516.4	0.2	1.50	1	1	0
01/30/2020 17:00	0.4	13.6	1,642.3	0.3	1.60	1	1	0
01/30/2020 18:00	0.5	13.6	1,718.5	0.4	1.70	1	1	1
01/30/2020 19:00	1.3	12.4	2,025.8	0.9	6.10	1	1	1
01/30/2020 20:00	1.7	12.0	2,117.0	1.1	8.50	1	1	1
01/30/2020 21:00	1.7	12.1	2,100.4	1.1	8.40	1	1	1
01/30/2020 22:00	1.6	12.3	2,053.8	1.1	8.20	1	1	1
01/30/2020 23:00	0.9	13.2	1,755.7	0.7	5.30	1	1	1
Average/Sum#:	0.7	13.2	1,727.2	0.5	79.70 #	24 #	24 #	9 #
Minimum:	0.2	12.0	1,391.3	0.2	1.40	1	1	0
Maximum:	1.7	13.6	2,117.0	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/31/2020 00:00	0.3	13.7	1,427.0	0.2	1.40	1	1	0
01/31/2020 01:00	0.3	13.7	1,387.7	0.2	1.40	1	1	0
01/31/2020 02:00	0.3	13.7	1,385.5	0.2	1.40	1	1	0
01/31/2020 03:00	0.3	13.6	1,396.6	0.2	1.40	1	1	0
01/31/2020 04:00	0.3	13.6	1,463.0	0.2	1.50	1	1	0
01/31/2020 05:00	0.5	13.6	1,703.6	0.4	1.70	1	1	0
01/31/2020 06:00	0.4	13.6	1,548.2	0.3	1.50	1	1	0
01/31/2020 07:00	0.3	13.6	1,599.8	0.2	1.60	1	1	0
01/31/2020 08:00	0.3	13.6	1,532.8	0.2	1.50	1	1	0
01/31/2020 09:00	0.3	13.6	1,630.4	0.2	1.60	1	1	0
01/31/2020 10:00	0.4	13.6	1,643.8	0.3	1.60	1	1	0
01/31/2020 11:00	0.4	13.6	1,650.4	0.3	1.70	1	1	0
01/31/2020 12:00	0.4	13.6	1,623.4	0.3	1.60	1	1	0
01/31/2020 13:00	0.5	13.6	1,697.8	0.4	1.70	1	1	0
01/31/2020 14:00	0.5	13.6	1,685.6	0.4	1.70	1	1	0
01/31/2020 15:00	0.5	13.6	1,670.4	0.4	1.70	1	1	0
01/31/2020 16:00	0.4	13.7	1,488.7	0.3	1.50	1	1	0
01/31/2020 17:00	0.5	13.6	1,679.8	0.4	1.70	1	1	0
01/31/2020 18:00	0.8	13.1	1,828.9	0.6	3.70	1	1	1
01/31/2020 19:00	1.3	12.5	2,014.8	0.9	6.00	1	1	1
01/31/2020 20:00	1.6	12.2	2,098.2	1.1	8.40	1	1	1
01/31/2020 21:00	1.6	12.2	2,099.3	1.1	8.40	1	1	1
01/31/2020 22:00	1.5	12.2	2,092.4	1.0	8.40	1	1	1
01/31/2020 23:00	3.5	14.0	1,276.7	3.0	7.28	1	0	1
Average/Sum#:	0.7	13.4	1,651.0	0.5	70.38 #	24 #	23 #	6 #
Minimum:	0.3	12.2	1,276.7	0.2	1.40	1	0	0
Maximum:	3.5	14.0	2,099.3	3.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/02/2020 23:00	32.5	17.3	477.5	53.3	73.01	1	0	0
Average/Sum#:	32.5	17.3	477.5	53.3	73.01 #	1 #	0 #	0 #
Minimum:	32.5	17.3	477.5	53.3	73.01	0	0	0
Maximum:	32.5	17.3	477.5	53.3	73.01	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/03/2020 00:00	11.4	16.9	528.4	16.8	32.80	1	0	0
02/03/2020 01:00	16.1	15.9	715.4	19.0	50.10	1	0	0
02/03/2020 02:00	0.1	13.7	1,442.4	0.1	0.00	1	0	0
02/03/2020 03:00	0.3	13.7	1,465.0	0.2	1.50	1	1	0
02/03/2020 04:00	0.5	13.6	1,708.3	0.4	1.70	1	1	0
02/03/2020 05:00	0.3	13.7	1,559.5	0.2	1.60	1	1	0
02/03/2020 06:00	0.4	13.6	1,710.4	0.3	1.70	1	1	0
02/03/2020 07:00	0.3	13.6	1,622.5	0.2	1.60	1	1	0
02/03/2020 08:00	0.2	13.7	1,552.9	0.2	1.60	1	1	0
02/03/2020 09:00	0.2	13.7	1,483.7	0.2	1.50	1	1	0
02/03/2020 10:00	0.3	13.7	1,566.7	0.2	1.60	1	1	0
02/03/2020 11:00	0.4	13.7	1,701.3	0.3	1.70	1	1	0
02/03/2020 12:00	0.3	13.7	1,664.6	0.2	1.70	1	1	0
02/03/2020 13:00	0.3	13.7	1,651.6	0.2	1.70	1	1	0
02/03/2020 14:00	0.3	13.7	1,575.5	0.2	1.60	1	1	0
02/03/2020 15:00	0.4	13.7	1,666.2	0.3	1.70	1	1	0
02/03/2020 16:00	0.3	13.7	1,593.4	0.2	1.60	1	1	1
02/03/2020 17:00	1.3	12.6	2,059.2	0.9	6.20	1	1	1
02/03/2020 18:00	1.7	11.9	2,216.8	1.1	8.90	1	1	1
02/03/2020 19:00	1.7	11.8	2,245.3	1.1	9.00	1	1	1
02/03/2020 20:00	1.6	11.8	2,248.2	1.0	9.00	1	1	1
02/03/2020 21:00	1.6	12.3	2,139.4	1.1	8.60	1	1	1
02/03/2020 22:00	1.6	12.3	2,127.7	1.1	8.50	1	1	1
02/03/2020 23:00	1.6	12.5	2,097.2	1.1	8.40	1	1	1
Average/Sum#:	1.8	13.5	1,680.9	1.9	164.30 #	24 #	21 #	8 #
Minimum:	0.1	11.8	528.4	0.1	0.00	1	0	0
Maximum:	16.1	16.9	2,248.2	19.0	50.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/04/2020 00:00	1.6	12.6	2,067.0	1.1	8.30	1	1	1
02/04/2020 01:00	1.6	12.7	2,043.7	1.2	8.20	1	1	1
02/04/2020 02:00	1.6	12.7	2,047.7	1.2	8.20	1	1	1
02/04/2020 03:00	1.6	12.7	2,042.3	1.2	8.20	1	1	1
02/04/2020 04:00	1.6	12.6	2,066.5	1.1	8.30	1	1	1
02/04/2020 05:00	1.6	12.5	2,099.2	1.1	8.40	1	1	1
02/04/2020 06:00	1.5	12.2	2,145.7	1.0	8.60	1	1	1
02/04/2020 07:00	1.6	12.2	2,164.2	1.1	8.70	1	1	1
02/04/2020 08:00	1.5	12.6	2,041.1	1.1	8.20	1	1	1
02/04/2020 09:00	0.5	13.7	1,764.2	0.4	3.50	1	1	0
02/04/2020 10:00	0.5	13.7	1,764.5	0.4	3.50	1	1	0
02/04/2020 11:00	0.4	13.7	1,764.1	0.3	1.80	1	1	0
02/04/2020 12:00	0.4	13.7	1,764.6	0.3	1.80	1	1	0
02/04/2020 13:00	0.4	13.7	1,765.0	0.3	1.80	1	1	0
02/04/2020 14:00	0.4	13.7	1,765.6	0.3	1.80	1	1	0
02/04/2020 15:00	0.4	13.7	1,765.7	0.3	1.80	1	1	0
02/04/2020 16:00	0.7	13.3	1,836.9	0.5	3.70	1	1	1
02/04/2020 17:00	1.3	12.8	1,997.4	0.9	6.00	1	1	1
02/04/2020 18:00	1.6	12.3	2,119.1	1.1	8.50	1	1	1
02/04/2020 19:00	1.6	12.0	2,181.9	1.1	8.70	1	1	1
02/04/2020 20:00	1.6	12.1	2,167.2	1.1	8.70	1	1	1
02/04/2020 21:00	1.6	11.9	2,225.3	1.0	8.90	1	1	1
02/04/2020 22:00	1.6	12.3	2,108.0	1.1	8.40	1	1	1
02/04/2020 23:00	1.6	12.4	2,088.9	1.1	8.40	1	1	1
Average/Sum#:	1.2	12.8	1,991.5	0.8	152.40 #	24 #	24 #	17 #
Minimum:	0.4	11.9	1,764.1	0.3	1.80	1	1	0
Maximum:	1.6	13.7	2,225.3	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2020 00:00	1.6	12.3	2,109.0	1.1	8.40	1	1	1
02/05/2020 01:00	1.6	12.5	2,078.8	1.1	8.30	1	1	1
02/05/2020 02:00	1.6	12.6	2,047.2	1.1	8.20	1	1	1
02/05/2020 03:00	1.6	12.6	2,046.5	1.1	8.20	1	1	1
02/05/2020 04:00	1.6	12.5	2,067.8	1.1	8.30	1	1	1
02/05/2020 05:00	1.4	12.8	1,996.5	1.0	8.00	1	1	1
02/05/2020 06:00	1.2	12.7	2,015.4	0.9	6.00	1	1	1
02/05/2020 07:00	1.7	12.0	2,185.5	1.1	8.70	1	1	1
02/05/2020 08:00	1.6	12.5	2,067.4	1.1	8.30	1	1	1
02/05/2020 09:00	1.2	12.9	1,956.4	0.9	5.90	1	1	1
02/05/2020 10:00	0.4	13.6	1,617.9	0.3	1.60	1	1	0
02/05/2020 11:00	0.4	13.6	1,623.0	0.3	1.60	1	1	0
02/05/2020 12:00	0.4	13.6	1,671.3	0.3	1.70	1	1	0
02/05/2020 13:00	0.4	13.6	1,671.8	0.3	1.70	1	1	0
02/05/2020 14:00	0.4	13.7	1,597.6	0.3	1.60	1	1	0
02/05/2020 15:00	0.5	13.6	1,685.0	0.4	1.70	1	1	0
02/05/2020 16:00	0.8	13.2	1,837.1	0.6	3.70	1	1	1
02/05/2020 17:00	1.4	12.8	1,973.5	1.0	7.90	1	1	1
02/05/2020 18:00	1.6	12.0	2,168.5	1.1	8.70	1	1	1
02/05/2020 19:00	1.7	12.1	2,119.6	1.1	8.50	1	1	1
02/05/2020 20:00	1.6	12.1	2,144.6	1.1	8.60	1	1	1
02/05/2020 21:00	1.6	12.3	2,102.4	1.1	8.40	1	1	1
02/05/2020 22:00	1.6	12.2	2,114.5	1.1	8.50	1	1	1
02/05/2020 23:00	1.6	12.4	2,056.9	1.1	8.20	1	1	1
Average/Sum#:	1.2	12.8	1,956.4	0.9	150.70 #	24 #	24 #	18 #
Minimum:	0.4	12.0	1,597.6	0.3	1.60	1	1	0
Maximum:	1.7	13.7	2,185.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2020 00:00	1.5	12.6	2,026.4	1.1	8.10	1	1	1
02/06/2020 01:00	1.5	12.7	2,008.0	1.1	8.00	1	1	1
02/06/2020 02:00	1.5	12.8	2,007.0	1.1	8.00	1	1	1
02/06/2020 03:00	1.5	12.7	2,028.1	1.1	8.10	1	1	1
02/06/2020 04:00	1.4	12.7	2,018.4	1.0	8.10	1	1	1
02/06/2020 05:00	1.5	12.7	2,042.6	1.1	8.20	1	1	1
02/06/2020 06:00	1.4	12.3	2,070.9	1.0	8.30	1	1	1
02/06/2020 07:00	1.4	12.4	2,087.5	1.0	8.40	1	1	1
02/06/2020 08:00	1.1	13.0	1,940.7	0.8	5.80	1	1	1
02/06/2020 09:00	0.5	13.6	1,701.3	0.4	1.70	1	1	0
02/06/2020 10:00	0.4	13.6	1,689.3	0.3	1.70	1	1	0
02/06/2020 11:00	0.4	13.6	1,690.2	0.3	1.70	1	1	0
02/06/2020 12:00	0.4	13.6	1,598.3	0.3	1.60	1	1	0
02/06/2020 13:00	0.5	13.6	1,688.1	0.4	1.70	1	1	0
02/06/2020 14:00	0.5	13.6	1,670.8	0.4	1.70	1	1	0
02/06/2020 15:00	0.4	13.6	1,553.6	0.3	1.60	1	1	0
02/06/2020 16:00	0.4	13.6	1,572.1	0.3	1.60	1	1	1
02/06/2020 17:00	1.2	12.6	2,001.0	0.9	6.00	1	1	1
02/06/2020 18:00	1.6	12.2	2,095.8	1.1	8.40	1	1	1
02/06/2020 19:00	1.7	12.2	2,088.1	1.2	8.40	1	1	1
02/06/2020 20:00	1.6	12.2	2,105.0	1.1	8.40	1	1	1
02/06/2020 21:00	1.6	12.2	2,107.5	1.1	8.40	1	1	1
02/06/2020 22:00	1.6	12.3	2,084.1	1.1	8.30	1	1	1
02/06/2020 23:00	1.2	12.9	1,948.7	0.9	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,909.3	0.8	138.00 #	24 #	24 #	17 #
Minimum:	0.4	12.2	1,553.6	0.3	1.60	1	1	0
Maximum:	1.7	13.6	2,107.5	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2020 00:00	1.1	12.9	1,928.1	0.8	5.80	1	1	1
02/07/2020 01:00	0.5	13.6	1,705.0	0.4	1.70	1	1	0
02/07/2020 02:00	0.4	13.6	1,570.0	0.3	1.60	1	1	0
02/07/2020 03:00	0.4	13.6	1,566.2	0.3	1.60	1	1	0
02/07/2020 04:00	0.3	13.6	1,535.6	0.2	1.50	1	1	0
02/07/2020 05:00	0.4	13.6	1,566.2	0.3	1.60	1	1	1
02/07/2020 06:00	1.4	12.5	2,036.5	1.0	8.10	1	1	1
02/07/2020 07:00	1.4	12.4	2,086.5	1.0	8.30	1	1	1
02/07/2020 08:00	1.2	12.9	1,960.4	0.9	5.90	1	1	1
02/07/2020 09:00	0.5	13.6	1,654.0	0.4	1.70	1	1	0
02/07/2020 10:00	0.5	13.6	1,668.8	0.4	1.70	1	1	0
02/07/2020 11:00	0.5	13.6	1,699.5	0.4	1.70	1	1	0
02/07/2020 12:00	0.6	13.6	1,701.9	0.5	3.40	1	1	0
02/07/2020 13:00	0.6	13.6	1,699.7	0.5	3.40	1	1	0
02/07/2020 14:00	0.5	13.6	1,669.1	0.4	1.70	1	1	0
02/07/2020 15:00	0.5	13.6	1,686.0	0.4	1.70	1	1	0
02/07/2020 16:00	0.5	13.6	1,598.3	0.4	1.60	1	1	1
02/07/2020 17:00	1.4	12.5	2,017.1	1.0	8.10	1	1	1
02/07/2020 18:00	1.7	12.1	2,105.8	1.1	8.40	1	1	1
02/07/2020 19:00	1.7	12.2	2,086.5	1.2	8.30	1	1	1
02/07/2020 20:00	1.7	12.2	2,098.2	1.2	8.40	1	1	1
02/07/2020 21:00	1.6	12.2	2,097.1	1.1	8.40	1	1	1
02/07/2020 22:00	1.5	12.4	2,050.2	1.0	8.20	1	1	1
02/07/2020 23:00	4.0	14.1	1,248.0	3.5	8.10	1	0	1
Average/Sum#:	1.0	13.1	1,793.1	0.8	110.90 #	24 #	23 #	13 #
Minimum:	0.3	12.1	1,248.0	0.2	1.50	1	0	0
Maximum:	4.0	14.1	2,105.8	3.5	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/09/2020 23:00	33.3	17.3	470.6	54.6	66.22	1	0	0
Average/Sum#:	33.3	17.3	470.6	54.6	66.22 #	1 #	0 #	0 #
Minimum:	33.3	17.3	470.6	54.6	66.22	0	0	0
Maximum:	33.3	17.3	470.6	54.6	66.22	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/10/2020 00:00	26.0	15.6	706.4	28.9	75.60	1	0	0
02/10/2020 01:00	17.5	14.8	998.4	16.9	61.90	1	0	0
02/10/2020 02:00	0.2	13.7	1,443.5	0.2	1.40	1	1	0
02/10/2020 03:00	0.3	13.7	1,376.4	0.2	1.40	1	1	0
02/10/2020 04:00	0.4	13.7	1,512.6	0.3	1.50	1	1	0
02/10/2020 05:00	0.2	13.7	1,436.5	0.2	1.40	1	1	0
02/10/2020 06:00	0.5	13.7	1,700.8	0.4	3.40	1	1	0
02/10/2020 07:00	0.4	13.7	1,705.2	0.3	1.70	1	1	0
02/10/2020 08:00	0.4	13.7	1,662.0	0.3	1.70	1	1	0
02/10/2020 09:00	0.4	13.7	1,663.7	0.3	1.70	1	1	0
02/10/2020 10:00	0.4	13.7	1,645.9	0.3	1.60	1	1	0
02/10/2020 11:00	0.4	13.7	1,677.2	0.3	1.70	1	1	0
02/10/2020 12:00	0.4	13.7	1,676.1	0.3	1.70	1	1	0
02/10/2020 13:00	0.4	13.7	1,661.2	0.3	1.70	1	1	0
02/10/2020 14:00	0.4	13.7	1,658.8	0.3	1.70	1	1	0
02/10/2020 15:00	0.4	13.7	1,667.9	0.3	1.70	1	1	0
02/10/2020 16:00	0.5	13.7	1,697.8	0.4	3.40	1	1	0
02/10/2020 17:00	0.8	13.2	1,841.8	0.6	3.70	1	1	1
02/10/2020 18:00	1.2	12.5	2,055.5	0.8	6.20	1	1	1
02/10/2020 19:00	1.4	12.4	2,070.2	1.0	8.30	1	1	1
02/10/2020 20:00	1.4	12.3	2,107.7	1.0	8.40	1	1	1
02/10/2020 21:00	1.5	12.2	2,115.8	1.0	8.50	1	1	1
02/10/2020 22:00	1.4	12.3	2,088.6	1.0	8.40	1	1	1
02/10/2020 23:00	1.4	12.6	2,033.7	1.0	8.10	1	1	1
Average/Sum#:	2.4	13.5	1,675.2	2.4	216.80 #	24 #	22 #	7 #
Minimum:	0.2	12.2	706.4	0.2	1.40	1	0	0
Maximum:	26.0	15.6	2,115.8	28.9	75.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2020 00:00	1.1	13.0	1,930.1	0.8	5.80	1	1	1
02/11/2020 01:00	0.4	13.7	1,574.3	0.3	1.60	1	1	0
02/11/2020 02:00	0.3	13.7	1,475.4	0.2	1.50	1	1	0
02/11/2020 03:00	0.3	13.7	1,546.6	0.2	1.50	1	1	0
02/11/2020 04:00	0.3	13.7	1,518.7	0.2	1.50	1	1	0
02/11/2020 05:00	0.4	13.7	1,648.0	0.3	1.60	1	1	0
02/11/2020 06:00	0.5	13.7	1,649.7	0.4	3.30	1	1	0
02/11/2020 07:00	0.4	13.7	1,582.7	0.3	1.60	1	1	0
02/11/2020 08:00	0.2	13.8	1,389.4	0.2	1.40	1	1	0
02/11/2020 09:00	0.3	13.7	1,555.8	0.2	1.60	1	1	0
02/11/2020 10:00	0.3	13.7	1,609.2	0.2	1.60	1	1	0
02/11/2020 11:00	0.4	13.7	1,628.7	0.3	1.60	1	1	0
02/11/2020 12:00	0.4	13.7	1,665.8	0.3	1.70	1	1	0
02/11/2020 13:00	0.5	13.7	1,683.9	0.4	3.40	1	1	0
02/11/2020 14:00	0.4	13.7	1,660.1	0.3	1.70	1	1	0
02/11/2020 15:00	0.4	13.7	1,539.4	0.3	1.50	1	1	0
02/11/2020 16:00	0.4	13.7	1,481.3	0.3	1.50	1	1	0
02/11/2020 17:00	0.4	13.7	1,625.5	0.3	1.60	1	1	0
02/11/2020 18:00	0.8	13.1	1,842.5	0.6	3.70	1	1	1
02/11/2020 19:00	1.6	12.1	2,091.3	1.1	8.40	1	1	1
02/11/2020 20:00	1.6	12.0	2,110.7	1.1	8.40	1	1	1
02/11/2020 21:00	1.7	11.9	2,141.6	1.1	8.60	1	1	1
02/11/2020 22:00	1.7	12.0	2,120.6	1.1	8.50	1	1	1
02/11/2020 23:00	1.6	12.3	2,068.8	1.1	8.30	1	1	1
Average/Sum#:	0.7	13.3	1,714.2	0.5	81.90 #	24 #	24 #	7 #
Minimum:	0.2	11.9	1,389.4	0.2	1.40	1	1	0
Maximum:	1.7	13.8	2,141.6	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2020 00:00	1.5	12.8	1,926.8	1.1	7.70	1	1	1
02/12/2020 01:00	0.4	13.7	1,569.9	0.3	1.60	1	1	0
02/12/2020 02:00	0.3	13.7	1,548.8	0.2	1.50	1	1	0
02/12/2020 03:00	0.3	13.7	1,507.2	0.2	1.50	1	1	0
02/12/2020 04:00	0.4	13.7	1,660.3	0.3	1.70	1	1	0
02/12/2020 05:00	0.4	13.7	1,664.6	0.3	1.70	1	1	0
02/12/2020 06:00	0.4	13.7	1,623.6	0.3	1.60	1	1	0
02/12/2020 07:00	0.3	13.7	1,562.6	0.2	1.60	1	1	0
02/12/2020 08:00	0.4	13.7	1,702.2	0.3	1.70	1	1	0
02/12/2020 09:00	0.4	13.7	1,692.8	0.3	1.70	1	1	0
02/12/2020 10:00	0.4	13.7	1,679.8	0.3	1.70	1	1	0
02/12/2020 11:00	0.4	13.7	1,680.9	0.3	1.70	1	1	0
02/12/2020 12:00	0.4	13.7	1,645.0	0.3	1.60	1	1	0
02/12/2020 13:00	0.5	13.7	1,689.5	0.4	3.40	1	1	0
02/12/2020 14:00	0.4	13.7	1,630.2	0.3	1.60	1	1	0
02/12/2020 15:00	0.4	13.7	1,617.6	0.3	1.60	1	1	0
02/12/2020 16:00	0.3	13.7	1,413.7	0.2	1.40	1	1	0
02/12/2020 17:00	0.4	13.7	1,634.9	0.3	1.60	1	1	0
02/12/2020 18:00	0.5	13.7	1,707.7	0.4	3.40	1	1	1
02/12/2020 19:00	1.6	12.4	2,026.9	1.1	8.10	1	1	1
02/12/2020 20:00	1.7	12.0	2,121.7	1.1	8.50	1	1	1
02/12/2020 21:00	1.7	12.1	2,104.2	1.1	8.40	1	1	1
02/12/2020 22:00	1.7	12.1	2,099.4	1.1	8.40	1	1	1
02/12/2020 23:00	1.6	12.4	2,048.1	1.1	8.20	1	1	1
Average/Sum#:	0.7	13.4	1,731.6	0.5	81.90 #	24 #	24 #	7 #
Minimum:	0.3	12.0	1,413.7	0.2	1.40	1	1	0
Maximum:	1.7	13.7	2,121.7	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/13/2020 00:00	1.6	12.4	2,048.4	1.1	8.20	1	1	1
02/13/2020 01:00	1.6	12.6	2,017.6	1.1	8.10	1	1	1
02/13/2020 02:00	1.5	12.6	2,021.7	1.1	8.10	1	1	1
02/13/2020 03:00	1.5	12.6	2,031.1	1.1	8.10	1	1	1
02/13/2020 04:00	1.5	12.6	2,028.8	1.1	8.10	1	1	1
02/13/2020 05:00	1.6	12.6	2,037.2	1.1	8.10	1	1	1
02/13/2020 06:00	1.6	12.1	2,132.4	1.1	8.50	1	1	1
02/13/2020 07:00	1.5	12.4	2,075.9	1.0	8.30	1	1	1
02/13/2020 08:00	1.1	13.0	1,932.9	0.8	5.80	1	1	1
02/13/2020 09:00	0.5	13.6	1,665.6	0.4	1.70	1	1	0
02/13/2020 10:00	0.4	13.6	1,654.7	0.3	1.70	1	1	0
02/13/2020 11:00	0.4	13.7	1,662.2	0.3	1.70	1	1	0
02/13/2020 12:00	0.5	13.7	1,690.0	0.4	3.40	1	1	0
02/13/2020 13:00	0.5	13.7	1,624.3	0.4	3.20	1	1	0
02/13/2020 14:00	0.5	13.7	1,640.4	0.4	3.30	1	1	0
02/13/2020 15:00	0.4	13.7	1,591.0	0.3	1.60	1	1	0
02/13/2020 16:00	0.5	13.6	1,599.3	0.4	1.60	1	1	1
02/13/2020 17:00	1.4	12.5	2,006.2	1.0	8.00	1	1	1
02/13/2020 18:00	1.7	12.1	2,092.0	1.1	8.40	1	1	1
02/13/2020 19:00	1.7	12.1	2,105.6	1.1	8.40	1	1	1
02/13/2020 20:00	1.7	12.1	2,101.3	1.1	8.40	1	1	1
02/13/2020 21:00	1.6	12.1	2,103.7	1.1	8.40	1	1	1
02/13/2020 22:00	1.6	12.3	2,088.7	1.1	8.40	1	1	1
02/13/2020 23:00	1.6	12.3	2,080.6	1.1	8.30	1	1	1
Average/Sum#:	1.2	12.8	1,918.0	0.8	147.80 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,591.0	0.3	1.60	1	1	0
Maximum:	1.7	13.7	2,132.4	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2020 00:00	2.5	13.5	1,589.0	2.0	10.77	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.5	13.5	1,589.0	2.0	10.77 #	1 #	0 #	1 #
Minimum:	2.5	13.5	1,589.0	2.0	10.77	0	0	0
Maximum:	2.5	13.5	1,589.0	2.0	10.77	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/17/2020 09:00	33.7	17.3	473.6	55.2	78.80	1	0	0
02/17/2020 10:00	13.8	16.9	528.5	20.4	39.60	1	0	0
02/17/2020 11:00	18.5	16.0	660.9	22.3	54.20	1	0	0
02/17/2020 12:00	16.7	15.0	968.9	16.7	60.10	1	0	0
02/17/2020 13:00	0.1	13.7	1,393.2	0.1	0.00	1	1	0
02/17/2020 14:00	0.2	13.7	1,392.7	0.2	1.40	1	1	0
02/17/2020 15:00	0.4	13.7	1,620.5	0.3	1.60	1	1	0
02/17/2020 16:00	0.3	13.7	1,517.4	0.2	1.50	1	1	0
02/17/2020 17:00	0.4	13.7	1,693.1	0.3	1.70	1	1	0
02/17/2020 18:00	0.5	13.7	1,746.3	0.4	3.50	1	1	1
02/17/2020 19:00	1.5	12.6	2,017.8	1.1	8.10	1	1	1
02/17/2020 20:00	1.7	12.1	2,129.0	1.1	8.50	1	1	1
02/17/2020 21:00	1.7	12.1	2,118.2	1.1	8.50	1	1	1
02/17/2020 22:00	1.7	12.2	2,099.4	1.2	8.40	1	1	1
02/17/2020 23:00	1.7	12.5	2,054.0	1.2	8.20	1	1	1
Average/Sum#:	6.2	13.9	1,494.2	8.1	284.10 #	15 #	11 #	6 #
Minimum:	0.1	12.1	473.6	0.1	0.00	0	0	0
Maximum:	33.7	17.3	2,129.0	55.2	78.80	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2020 00:00	1.7	12.5	2,047.5	1.2	8.20	1	1	1
02/18/2020 01:00	1.7	12.5	2,046.5	1.2	8.20	1	1	1
02/18/2020 02:00	1.6	12.6	2,022.3	1.1	8.10	1	1	1
02/18/2020 03:00	1.7	12.5	2,046.4	1.2	8.20	1	1	1
02/18/2020 04:00	1.7	12.5	2,048.8	1.2	8.20	1	1	1
02/18/2020 05:00	1.7	12.4	2,068.8	1.2	8.30	1	1	1
02/18/2020 06:00	1.6	12.3	2,105.3	1.1	8.40	1	1	1
02/18/2020 07:00	1.6	12.3	2,104.8	1.1	8.40	1	1	1
02/18/2020 08:00	1.7	12.5	2,060.0	1.2	8.20	1	1	1
02/18/2020 09:00	1.4	12.9	1,957.3	1.0	7.80	1	1	1
02/18/2020 10:00	1.0	13.0	1,955.7	0.7	5.90	1	1	1
02/18/2020 11:00	1.0	13.0	1,953.4	0.7	5.90	1	1	1
02/18/2020 12:00	1.0	13.0	1,950.7	0.7	5.90	1	1	1
02/18/2020 13:00	0.7	13.4	1,773.7	0.6	3.50	1	1	1
02/18/2020 14:00	0.3	13.7	1,414.9	0.2	1.40	1	1	0
02/18/2020 15:00	0.3	13.7	1,503.6	0.2	1.50	1	1	1
02/18/2020 16:00	1.1	12.7	2,015.5	0.8	6.00	1	1	1
02/18/2020 17:00	1.5	12.1	2,134.8	1.0	8.50	1	1	1
02/18/2020 18:00	1.5	12.1	2,153.0	1.0	8.60	1	1	1
02/18/2020 19:00	1.6	11.9	2,196.2	1.0	8.80	1	1	1
02/18/2020 20:00	1.7	11.9	2,196.0	1.1	8.80	1	1	1
02/18/2020 21:00	1.7	12.0	2,149.6	1.1	8.60	1	1	1
02/18/2020 22:00	1.7	12.2	2,109.3	1.2	8.40	1	1	1
02/18/2020 23:00	1.6	12.5	2,053.6	1.1	8.20	1	1	1
Average/Sum#:	1.4	12.6	2,002.8	1.0	172.00 #	24 #	24 #	23 #
Minimum:	0.3	11.9	1,414.9	0.2	1.40	1	1	0
Maximum:	1.7	13.7	2,196.2	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/19/2020 00:00	1.8	11.9	2,212.6	1.2	8.90	1	1	1
02/19/2020 01:00	1.5	12.6	2,032.5	1.1	8.10	1	1	1
02/19/2020 02:00	1.6	13.0	1,942.7	1.2	7.80	1	1	1
02/19/2020 03:00	1.2	13.0	1,943.9	0.9	5.80	1	1	1
02/19/2020 04:00	1.6	12.5	2,066.0	1.1	8.30	1	1	1
02/19/2020 05:00	1.5	12.4	2,094.6	1.0	8.40	1	1	1
02/19/2020 06:00	1.5	12.2	2,100.0	1.0	8.40	1	1	1
02/19/2020 07:00	1.7	12.0	2,178.1	1.1	8.70	1	1	1
02/19/2020 08:00	1.3	12.8	1,995.8	0.9	6.00	1	1	1
02/19/2020 09:00	1.6	13.0	1,946.8	1.2	7.80	1	1	1
02/19/2020 10:00	1.1	13.0	1,947.3	0.8	5.80	1	1	1
02/19/2020 11:00	1.1	13.0	1,948.8	0.8	5.80	1	1	1
02/19/2020 12:00	1.2	13.0	1,949.5	0.9	5.80	1	1	1
02/19/2020 13:00	1.3	13.0	1,948.8	1.0	7.80	1	1	1
02/19/2020 14:00	1.3	13.0	1,945.4	1.0	7.80	1	1	1
02/19/2020 15:00	1.3	13.0	1,941.5	1.0	7.80	1	1	1
02/19/2020 16:00	1.3	12.6	2,035.5	0.9	6.10	1	1	1
02/19/2020 17:00	1.6	12.1	2,108.7	1.1	8.40	1	1	1
02/19/2020 18:00	1.7	12.1	2,113.8	1.1	8.50	1	1	1
02/19/2020 19:00	1.7	11.8	2,176.3	1.1	8.70	1	1	1
02/19/2020 20:00	1.8	11.9	2,164.0	1.2	8.70	1	1	1
02/19/2020 21:00	1.7	12.0	2,159.2	1.1	8.60	1	1	1
02/19/2020 22:00	1.6	12.4	2,051.8	1.1	8.20	1	1	1
02/19/2020 23:00	1.6	12.5	2,046.5	1.1	8.20	1	1	1
Average/Sum#:	1.5	12.5	2,043.8	1.0	184.40 #	24 #	24 #	24 #
Minimum:	1.1	11.8	1,941.5	0.8	5.80	1	1	1
Maximum:	1.8	13.0	2,212.6	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2020 00:00	1.5	12.7	2,026.1	1.1	8.10	1	1	1
02/20/2020 01:00	1.5	12.6	2,040.0	1.1	8.20	1	1	1
02/20/2020 02:00	1.5	12.6	2,042.7	1.1	8.20	1	1	1
02/20/2020 03:00	1.6	12.6	2,038.6	1.1	8.20	1	1	1
02/20/2020 04:00	1.6	12.5	2,037.9	1.1	8.20	1	1	1
02/20/2020 05:00	1.5	12.6	2,053.2	1.1	8.20	1	1	1
02/20/2020 06:00	1.6	12.5	2,070.2	1.1	8.30	1	1	1
02/20/2020 07:00	1.5	12.5	2,078.3	1.1	8.30	1	1	1
02/20/2020 08:00	1.5	12.6	2,044.8	1.1	8.20	1	1	1
02/20/2020 09:00	1.2	12.9	1,952.5	0.9	5.90	1	1	1
02/20/2020 10:00	1.0	13.0	1,949.9	0.7	5.80	1	1	1
02/20/2020 11:00	1.0	13.0	1,948.0	0.7	5.80	1	1	1
02/20/2020 12:00	1.0	12.9	1,949.6	0.7	5.80	1	1	1
02/20/2020 13:00	1.0	12.9	1,950.1	0.7	5.90	1	1	1
02/20/2020 14:00	1.2	12.8	1,963.6	0.9	5.90	1	1	1
02/20/2020 15:00	1.3	12.7	1,995.9	0.9	6.00	1	1	1
02/20/2020 16:00	1.4	12.4	2,076.7	1.0	8.30	1	1	1
02/20/2020 17:00	1.4	12.3	2,087.7	1.0	8.40	1	1	1
02/20/2020 18:00	1.4	12.3	2,089.7	1.0	8.40	1	1	1
02/20/2020 19:00	1.5	12.3	2,087.8	1.0	8.40	1	1	1
02/20/2020 20:00	1.7	12.2	2,088.0	1.2	8.40	1	1	1
02/20/2020 21:00	1.7	12.2	2,098.3	1.2	8.40	1	1	1
02/20/2020 22:00	1.7	12.2	2,086.1	1.2	8.30	1	1	1
02/20/2020 23:00	1.7	12.5	2,023.2	1.2	8.10	1	1	1
Average/Sum#:	1.4	12.6	2,032.5	1.0	181.70 #	24 #	24 #	24 #
Minimum:	1.0	12.2	1,948.0	0.7	5.80	1	1	1
Maximum:	1.7	13.0	2,098.3	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2020 00:00	1.4	12.9	1,915.5	1.0	7.70	1	1	1
02/21/2020 01:00	0.3	13.7	1,540.2	0.2	1.50	1	1	0
02/21/2020 02:00	0.3	13.7	1,484.5	0.2	1.50	1	1	0
02/21/2020 03:00	0.3	13.7	1,567.0	0.2	1.60	1	1	0
02/21/2020 04:00	0.4	13.7	1,685.5	0.3	1.70	1	1	0
02/21/2020 05:00	0.3	13.7	1,590.9	0.2	1.60	1	1	0
02/21/2020 06:00	0.5	13.7	1,688.6	0.4	3.40	1	1	0
02/21/2020 07:00	0.3	13.7	1,649.8	0.2	1.60	1	1	0
02/21/2020 08:00	0.3	13.6	1,553.8	0.2	1.60	1	1	0
02/21/2020 09:00	0.4	13.6	1,684.7	0.3	1.70	1	1	0
02/21/2020 10:00	0.3	13.7	1,625.3	0.2	1.60	1	1	0
02/21/2020 11:00	0.4	13.7	1,608.2	0.3	1.60	1	1	0
02/21/2020 12:00	0.4	13.7	1,676.5	0.3	1.70	1	1	0
02/21/2020 13:00	0.4	13.6	1,677.0	0.3	1.70	1	1	0
02/21/2020 14:00	0.5	13.6	1,697.8	0.4	1.70	1	1	0
02/21/2020 15:00	0.5	13.6	1,686.6	0.4	1.70	1	1	0
02/21/2020 16:00	0.7	13.6	1,692.8	0.6	3.40	1	1	1
02/21/2020 17:00	1.2	12.6	1,986.0	0.9	6.00	1	1	1
02/21/2020 18:00	1.4	12.2	2,097.5	0.9	6.30	1	1	1
02/21/2020 19:00	1.4	12.3	2,077.5	1.0	8.30	1	1	1
02/21/2020 20:00	1.5	12.3	2,094.5	1.0	8.40	1	1	1
02/21/2020 21:00	1.4	12.4	2,066.2	1.0	8.30	1	1	1
02/21/2020 22:00	1.5	12.3	2,094.4	1.0	8.40	1	1	1
02/21/2020 23:00	3.7	13.9	1,282.6	3.1	6.77	1	0	1
Average/Sum#:	0.8	13.3	1,738.5	0.6	89.77 #	24 #	23 #	9 #
Minimum:	0.3	12.2	1,282.6	0.2	1.50	1	0	0
Maximum:	3.7	13.9	2,097.5	3.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/24/2020 13:00	34.3	17.3	476.5	56.2	70.99	1	0	0
02/24/2020 14:00	23.3	16.1	626.2	28.6	66.40	1	0	0
02/24/2020 15:00	24.1	15.0	880.3	24.1	78.30	1	0	0
02/24/2020 16:00	0.2	13.7	1,505.3	0.2	1.50	1	1	1
02/24/2020 17:00	1.4	12.5	2,085.8	1.0	8.30	1	1	1
02/24/2020 18:00	1.6	12.0	2,167.5	1.1	8.70	1	1	1
02/24/2020 19:00	1.7	12.1	2,161.0	1.1	8.60	1	1	1
02/24/2020 20:00	1.6	12.4	2,091.2	1.1	8.40	1	1	1
02/24/2020 21:00	1.6	12.4	2,087.4	1.1	8.30	1	1	1
02/24/2020 22:00	1.3	12.9	1,964.8	1.0	7.90	1	1	1
02/24/2020 23:00	1.5	12.6	2,023.8	1.1	8.10	1	1	1
Average/Sum#:	8.4	13.5	1,642.7	10.6	275.49 #	11 #	8 #	8 #
Minimum:	0.2	12.0	476.5	0.2	1.50	0	0	0
Maximum:	34.3	17.3	2,167.5	56.2	78.30	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.4	13.7	1,562.5	0.3	1.60	1	1	0
02/25/2020 01:00	0.3	13.7	1,513.6	0.2	1.50	1	1	0
02/25/2020 02:00	0.2	13.7	1,365.0	0.2	1.40	1	1	0
02/25/2020 03:00	0.2	13.7	1,360.5	0.2	1.40	1	1	0
02/25/2020 04:00	0.3	13.7	1,473.4	0.2	1.50	1	1	1
02/25/2020 05:00	1.2	13.0	1,953.5	0.9	5.90	1	1	1
02/25/2020 06:00	1.1	12.9	1,968.3	0.8	5.90	1	1	1
02/25/2020 07:00	1.2	12.9	1,949.7	0.9	5.80	1	1	1
02/25/2020 08:00	0.3	13.7	1,389.1	0.2	1.40	1	1	0
02/25/2020 09:00	0.2	13.7	1,379.8	0.2	1.40	1	1	0
02/25/2020 10:00	0.1	13.7	1,380.4	0.1	0.00	1	1	0
02/25/2020 11:00	0.1	13.7	1,372.4	0.1	0.00	1	1	0
02/25/2020 12:00	0.1	13.7	1,376.1	0.1	0.00	1	1	0
02/25/2020 13:00	0.1	13.7	1,377.8	0.1	0.00	1	1	0
02/25/2020 14:00	0.5	13.7	1,644.3	0.4	3.30	1	1	0
02/25/2020 15:00	0.4	13.7	1,540.5	0.3	1.50	1	1	0
02/25/2020 16:00	0.5	13.7	1,634.0	0.4	3.30	1	1	0
02/25/2020 17:00	0.4	13.7	1,551.5	0.3	1.60	1	1	1
02/25/2020 18:00	1.2	12.7	1,987.1	0.9	6.00	1	1	1
02/25/2020 19:00	1.4	12.1	2,125.9	0.9	6.40	1	1	1
02/25/2020 20:00	1.5	12.0	2,156.8	1.0	8.60	1	1	1
02/25/2020 21:00	1.5	12.1	2,142.4	1.0	8.60	1	1	1
02/25/2020 22:00	1.5	12.1	2,135.7	1.0	8.50	1	1	1
02/25/2020 23:00	1.5	12.2	2,128.2	1.0	8.50	1	1	1
Average/Sum#:	0.7	13.2	1,686.2	0.5	84.10 #	24 #	24 #	11 #
Minimum:	0.1	12.0	1,360.5	0.1	0.00	1	1	0
Maximum:	1.5	13.7	2,156.8	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2020 00:00	1.4	12.5	2,065.6	1.0	8.30	1	1	1
02/26/2020 01:00	1.7	12.5	2,047.7	1.2	8.20	1	1	1
02/26/2020 02:00	1.7	12.5	2,042.5	1.2	8.20	1	1	1
02/26/2020 03:00	1.7	12.5	2,036.1	1.2	8.10	1	1	1
02/26/2020 04:00	1.5	12.6	2,031.3	1.1	8.10	1	1	1
02/26/2020 05:00	1.6	12.6	2,026.1	1.1	8.10	1	1	1
02/26/2020 06:00	1.6	12.7	2,021.5	1.2	8.10	1	1	1
02/26/2020 07:00	1.5	12.7	2,012.8	1.1	8.10	1	1	1
02/26/2020 08:00	4.6	14.1	1,229.8	4.0	8.65	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/26/2020 15:00	29.0	17.1	502.2	45.0	50.04	1	0	0
02/26/2020 16:00	8.9	14.1	1,308.9	7.7	36.60	1	0	1
02/26/2020 17:00	1.3	12.5	2,032.0	0.9	6.10	1	1	1
02/26/2020 18:00	1.5	12.4	2,042.2	1.0	8.20	1	1	1
02/26/2020 19:00	1.2	12.9	1,951.8	0.9	5.90	1	1	1
02/26/2020 20:00	1.6	12.3	2,087.3	1.1	8.30	1	1	1
02/26/2020 21:00	1.4	12.7	1,996.3	1.0	8.00	1	1	1
02/26/2020 22:00	1.3	12.9	1,959.3	1.0	7.80	1	1	1
02/26/2020 23:00	0.9	13.2	1,798.9	0.7	5.40	1	1	1
Average/Sum#:	3.6	13.0	1,844.0	4.0	210.19 #	18 #	15 #	17 #
Minimum:	0.9	12.3	502.2	0.7	5.40	0	0	0
Maximum:	29.0	17.1	2,087.3	45.0	50.04	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.4	13.6	1,508.5	0.3	1.50	1	1	0
02/27/2020 01:00	0.3	13.7	1,473.8	0.2	1.50	1	1	0
02/27/2020 02:00	0.4	13.7	1,575.0	0.3	1.60	1	1	0
02/27/2020 03:00	0.3	13.7	1,498.2	0.2	1.50	1	1	0
02/27/2020 04:00	0.5	13.6	1,761.8	0.4	1.80	1	1	0
02/27/2020 05:00	0.5	13.6	1,764.3	0.4	1.80	1	1	0
02/27/2020 06:00	0.5	13.6	1,759.8	0.4	1.80	1	1	0
02/27/2020 07:00	0.5	13.6	1,759.3	0.4	1.80	1	1	0
02/27/2020 08:00	0.5	13.6	1,761.7	0.4	1.80	1	1	0
02/27/2020 09:00	0.6	13.6	1,764.4	0.5	3.50	1	1	0
02/27/2020 10:00	0.6	13.6	1,763.8	0.5	3.50	1	1	0
02/27/2020 11:00	0.8	13.5	1,759.0	0.6	3.50	1	1	0
02/27/2020 12:00	0.9	13.6	1,741.7	0.7	5.20	1	1	0
02/27/2020 13:00	0.5	13.6	1,688.5	0.4	1.70	1	1	0
02/27/2020 14:00	0.5	13.6	1,677.6	0.4	1.70	1	1	0
02/27/2020 15:00	0.5	13.6	1,665.2	0.4	1.70	1	1	0
02/27/2020 16:00	0.8	13.1	1,836.3	0.6	3.70	1	1	1
02/27/2020 17:00	1.4	12.3	2,049.6	1.0	8.20	1	1	1
02/27/2020 18:00	1.4	12.4	2,050.0	1.0	8.20	1	1	1
02/27/2020 19:00	1.4	12.4	2,053.4	1.0	8.20	1	1	1
02/27/2020 20:00	1.5	12.3	2,087.5	1.0	8.40	1	1	1
02/27/2020 21:00	1.5	12.2	2,092.2	1.0	8.40	1	1	1
02/27/2020 22:00	1.5	12.2	2,096.2	1.0	8.40	1	1	1
02/27/2020 23:00	1.3	12.6	2,016.2	0.9	6.00	1	1	1
Average/Sum#:	0.8	13.2	1,800.2	0.6	95.40 #	24 #	24 #	8 #
Minimum:	0.3	12.2	1,473.8	0.2	1.50	1	1	0
Maximum:	1.5	13.7	2,096.2	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2020 00:00	1.0	13.0	1,925.9	0.7	5.80	1	1	1
02/28/2020 01:00	0.5	13.7	1,591.0	0.4	3.20	1	1	0
02/28/2020 02:00	0.3	13.7	1,500.7	0.2	1.50	1	1	0
02/28/2020 03:00	0.3	13.7	1,520.9	0.2	1.50	1	1	0
02/28/2020 04:00	0.3	13.7	1,513.5	0.2	1.50	1	1	0
02/28/2020 05:00	0.4	13.6	1,652.7	0.3	1.70	1	1	0
02/28/2020 06:00	0.4	13.6	1,694.8	0.3	1.70	1	1	0
02/28/2020 07:00	0.4	13.6	1,653.6	0.3	1.70	1	1	0
02/28/2020 08:00	0.3	13.6	1,552.3	0.2	1.60	1	1	0
02/28/2020 09:00	0.3	13.7	1,533.3	0.2	1.50	1	1	0
02/28/2020 10:00	0.3	13.7	1,476.4	0.2	1.50	1	1	0
02/28/2020 11:00	0.3	13.7	1,513.9	0.2	1.50	1	1	0
02/28/2020 12:00	0.4	13.7	1,574.7	0.3	1.60	1	1	0
02/28/2020 13:00	0.5	13.7	1,609.1	0.4	3.20	1	1	0
02/28/2020 14:00	0.3	13.7	1,452.9	0.2	1.50	1	1	0
02/28/2020 15:00	0.5	13.6	1,563.8	0.4	1.60	1	1	1
02/28/2020 16:00	1.2	12.5	2,014.8	0.8	6.00	1	1	1
02/28/2020 17:00	1.4	12.3	2,048.7	1.0	8.20	1	1	1
02/28/2020 18:00	1.4	12.4	2,034.8	1.0	8.10	1	1	1
02/28/2020 19:00	1.4	12.3	2,043.5	1.0	8.20	1	1	1
02/28/2020 20:00	1.4	12.5	2,026.5	1.0	8.10	1	1	1
02/28/2020 21:00	1.4	12.3	2,054.5	1.0	8.20	1	1	1
02/28/2020 22:00	1.4	12.4	2,031.8	1.0	8.10	1	1	1
02/28/2020 23:00	3.2	14.0	1,248.2	2.7	6.50	1	0	1
Average/Sum#:	0.8	13.3	1,701.3	0.6	94.00 #	24 #	23 #	10 #
Minimum:	0.3	12.3	1,248.2	0.2	1.50	1	0	0
Maximum:	3.2	14.0	2,054.5	2.7	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/03/2020 08:00	8.6	18.7	286.2	23.1	4.37	1	0	0
03/03/2020 09:00	31.5	16.9	526.7	46.5	90.10	1	0	0
03/03/2020 10:00	11.8	16.6	572.6	16.2	34.40	1	0	0
03/03/2020 11:00	22.6	15.5	722.2	24.7	65.70	1	0	0
03/03/2020 12:00	12.0	14.4	1,140.8	10.9	45.60	1	0	0
03/03/2020 13:00	0.2	13.8	1,396.8	0.2	1.40	1	1	0
03/03/2020 14:00	0.3	13.8	1,393.5	0.2	1.40	1	1	0
03/03/2020 15:00	0.4	13.8	1,559.0	0.3	1.60	1	1	0
03/03/2020 16:00	0.4	13.8	1,569.6	0.3	1.60	1	1	0
03/03/2020 17:00	0.7	13.7	1,601.7	0.6	3.20	1	1	1
03/03/2020 18:00	1.4	12.2	2,098.3	0.9	6.30	1	1	1
03/03/2020 19:00	1.6	11.9	2,162.7	1.0	8.70	1	1	1
03/03/2020 20:00	1.6	11.9	2,156.3	1.0	8.60	1	1	1
03/03/2020 21:00	1.6	11.9	2,156.0	1.0	8.60	1	1	1
03/03/2020 22:00	1.6	12.0	2,129.3	1.1	8.50	1	1	1
03/03/2020 23:00	1.5	12.2	2,104.5	1.0	8.40	1	1	1
Average/Sum#:	6.1	13.9	1,473.5	8.1	298.47 #	16 #	11 #	7 #
Minimum:	0.2	11.9	286.2	0.2	1.40	0	0	0
Maximum:	31.5	18.7	2,162.7	46.5	90.10	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2020 00:00	1.4	12.5	2,059.3	1.0	8.20	1	1	1
03/04/2020 01:00	1.4	12.5	2,049.8	1.0	8.20	1	1	1
03/04/2020 02:00	1.3	12.7	2,001.7	0.9	6.00	1	1	1
03/04/2020 03:00	1.3	12.7	1,997.8	0.9	6.00	1	1	1
03/04/2020 04:00	1.4	12.5	2,046.9	1.0	8.20	1	1	1
03/04/2020 05:00	1.4	12.6	2,044.4	1.0	8.20	1	1	1
03/04/2020 06:00	1.2	12.5	2,043.1	0.8	6.10	1	1	1
03/04/2020 07:00	1.6	12.5	2,029.1	1.1	8.10	1	1	1
03/04/2020 08:00	0.6	13.6	1,508.5	0.5	3.00	1	1	1
03/04/2020 09:00	0.3	13.7	1,379.5	0.2	1.40	1	1	0
03/04/2020 10:00	0.2	13.7	1,382.6	0.2	1.40	1	1	0
03/04/2020 11:00	0.4	13.7	1,580.0	0.3	1.60	1	1	0
03/04/2020 12:00	0.5	13.7	1,708.4	0.4	3.40	1	1	0
03/04/2020 13:00	0.4	13.7	1,539.6	0.3	1.50	1	1	0
03/04/2020 14:00	0.6	13.7	1,636.6	0.5	3.30	1	1	0
03/04/2020 15:00	0.5	13.7	1,609.1	0.4	3.20	1	1	0
03/04/2020 16:00	0.5	13.7	1,553.5	0.4	3.10	1	1	1
03/04/2020 17:00	1.2	12.5	2,030.1	0.8	6.10	1	1	1
03/04/2020 18:00	1.5	12.3	2,054.6	1.0	8.20	1	1	1
03/04/2020 19:00	1.4	12.4	2,050.6	1.0	8.20	1	1	1
03/04/2020 20:00	1.6	12.1	2,113.0	1.1	8.50	1	1	1
03/04/2020 21:00	1.6	12.1	2,121.5	1.1	8.50	1	1	1
03/04/2020 22:00	1.5	12.1	2,109.1	1.0	8.40	1	1	1
03/04/2020 23:00	1.5	12.4	2,060.4	1.0	8.20	1	1	1
Average/Sum#:	1.1	12.9	1,862.9	0.7	137.00 #	24 #	24 #	17 #
Minimum:	0.2	12.1	1,379.5	0.2	1.40	1	1	0
Maximum:	1.6	13.7	2,121.5	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2020 00:00	1.4	12.7	2,008.7	1.0	8.00	1	1	1
03/05/2020 01:00	1.5	12.7	1,998.5	1.1	8.00	1	1	1
03/05/2020 02:00	1.6	12.7	1,990.0	1.2	8.00	1	1	1
03/05/2020 03:00	1.6	12.7	1,989.3	1.2	8.00	1	1	1
03/05/2020 04:00	1.6	12.4	2,055.6	1.1	8.20	1	1	1
03/05/2020 05:00	1.6	12.4	2,052.3	1.1	8.20	1	1	1
03/05/2020 06:00	1.4	12.6	2,042.3	1.0	8.20	1	1	1
03/05/2020 07:00	1.4	12.7	1,984.6	1.0	7.90	1	1	1
03/05/2020 08:00	0.5	13.6	1,636.4	0.4	1.60	1	1	0
03/05/2020 09:00	0.6	13.6	1,704.5	0.5	3.40	1	1	0
03/05/2020 10:00	0.5	13.7	1,705.5	0.4	3.40	1	1	0
03/05/2020 11:00	0.5	13.6	1,688.6	0.4	1.70	1	1	0
03/05/2020 12:00	0.5	13.6	1,661.7	0.4	1.70	1	1	0
03/05/2020 13:00	0.6	13.6	1,698.8	0.5	3.40	1	1	0
03/05/2020 14:00	0.5	13.6	1,594.6	0.4	1.60	1	1	0
03/05/2020 15:00	0.4	13.6	1,528.7	0.3	1.50	1	1	0
03/05/2020 16:00	0.5	13.6	1,488.9	0.4	1.50	1	1	1
03/05/2020 17:00	1.3	12.5	1,990.0	0.9	6.00	1	1	1
03/05/2020 18:00	1.4	12.2	2,066.1	0.9	6.20	1	1	1
03/05/2020 19:00	1.4	12.3	2,059.4	1.0	8.20	1	1	1
03/05/2020 20:00	1.5	12.3	2,053.9	1.0	8.20	1	1	1
03/05/2020 21:00	1.5	12.3	2,075.9	1.0	8.30	1	1	1
03/05/2020 22:00	1.5	12.3	2,076.5	1.0	8.30	1	1	1
03/05/2020 23:00	1.4	12.6	1,993.9	1.0	8.00	1	1	1
Average/Sum#:	1.1	12.9	1,881.0	0.8	137.50 #	24 #	24 #	16 #
Minimum:	0.4	12.2	1,488.9	0.3	1.50	1	1	0
Maximum:	1.6	13.7	2,076.5	1.2	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2020 00:00	1.5	12.4	2,055.1	1.0	8.20	1	1	1
03/06/2020 01:00	1.5	12.4	2,057.8	1.0	8.20	1	1	1
03/06/2020 02:00	1.5	12.6	1,994.5	1.1	8.00	1	1	1
03/06/2020 03:00	1.5	12.5	2,024.2	1.1	8.10	1	1	1
03/06/2020 04:00	1.5	12.5	2,038.8	1.1	8.20	1	1	1
03/06/2020 05:00	1.4	12.4	2,056.5	1.0	8.20	1	1	1
03/06/2020 06:00	1.4	12.5	2,044.7	1.0	8.20	1	1	1
03/06/2020 07:00	1.4	12.5	2,029.0	1.0	8.10	1	1	1
03/06/2020 08:00	1.3	12.8	1,952.1	0.9	5.90	1	1	1
03/06/2020 09:00	0.5	13.6	1,636.3	0.4	1.60	1	1	0
03/06/2020 10:00	0.5	13.6	1,682.9	0.4	1.70	1	1	0
03/06/2020 11:00	0.6	13.6	1,700.5	0.5	3.40	1	1	0
03/06/2020 12:00	0.5	13.6	1,673.0	0.4	1.70	1	1	0
03/06/2020 13:00	0.6	13.6	1,694.7	0.5	3.40	1	1	0
03/06/2020 14:00	0.5	13.6	1,657.8	0.4	1.70	1	1	0
03/06/2020 15:00	0.5	13.6	1,641.2	0.4	1.60	1	1	0
03/06/2020 16:00	0.5	13.6	1,529.2	0.4	1.50	1	1	1
03/06/2020 17:00	1.2	12.5	2,007.7	0.8	6.00	1	1	1
03/06/2020 18:00	1.4	12.3	2,044.3	1.0	8.20	1	1	1
03/06/2020 19:00	1.4	12.3	2,050.9	1.0	8.20	1	1	1
03/06/2020 20:00	1.6	12.1	2,099.4	1.1	8.40	1	1	1
03/06/2020 21:00	1.7	12.0	2,120.6	1.1	8.50	1	1	1
03/06/2020 22:00	1.6	12.2	2,086.0	1.1	8.30	1	1	1
03/06/2020 23:00	1.5	12.3	2,054.7	1.0	8.20	1	1	1
Average/Sum#:	1.2	12.8	1,913.8	0.8	143.50 #	24 #	24 #	17 #
Minimum:	0.5	12.0	1,529.2	0.4	1.50	1	1	0
Maximum:	1.7	13.6	2,120.6	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2020 00:00	3.9	14.1	1,220.5	3.4	7.30	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.9	14.1	1,220.5	3.4	7.30 #	1 #	0 #	1 #
Minimum:	3.9	14.1	1,220.5	3.4	7.30	0	0	0
Maximum:	3.9	14.1	1,220.5	3.4	7.30	1	0	1
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/08/2020 20:00	29.7	17.3	468.7	48.7	60.41	1	0	0
03/08/2020 21:00	12.0	16.9	529.5	17.7	34.40	1	0	0
03/08/2020 22:00	6.5	14.5	1,159.1	6.0	25.50	1	0	0
03/08/2020 23:00	0.3	13.6	1,549.1	0.2	1.50	1	1	0
Average/Sum#:	12.1	15.6	926.6	18.2	121.81 #	4 #	1 #	0 #
Minimum:	0.3	13.6	468.7	0.2	1.50	0	0	0
Maximum:	29.7	17.3	1,549.1	48.7	60.41	1	1	0
%SI	83.33	83.33	83.33	83.33	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/09/2020 00:00	0.4	13.6	1,545.8	0.3	1.50	1	1	0
03/09/2020 01:00	0.5	13.6	1,647.7	0.4	1.60	1	1	0
03/09/2020 02:00	0.4	13.6	1,608.2	0.3	1.60	1	1	0
03/09/2020 03:00	0.3	13.6	1,503.5	0.2	1.50	1	1	0
03/09/2020 04:00	0.4	13.6	1,591.5	0.3	1.60	1	1	1
03/09/2020 05:00	1.2	12.7	2,030.9	0.9	6.10	1	1	1
03/09/2020 06:00	1.6	12.2	2,153.8	1.1	8.60	1	1	1
03/09/2020 07:00	1.6	12.2	2,138.7	1.1	8.60	1	1	1
03/09/2020 08:00	1.7	12.2	2,127.0	1.2	8.50	1	1	1
03/09/2020 09:00	0.7	13.5	1,683.7	0.6	3.40	1	1	1
03/09/2020 10:00	0.4	13.6	1,601.6	0.3	1.60	1	1	0
03/09/2020 11:00	0.4	13.6	1,571.5	0.3	1.60	1	1	0
03/09/2020 12:00	0.5	13.6	1,697.9	0.4	1.70	1	1	0
03/09/2020 13:00	0.5	13.7	1,698.6	0.4	3.40	1	1	0
03/09/2020 14:00	0.5	13.7	1,698.9	0.4	3.40	1	1	0
03/09/2020 15:00	0.5	13.7	1,672.5	0.4	3.30	1	1	0
03/09/2020 16:00	0.5	13.6	1,688.6	0.4	1.70	1	1	1
03/09/2020 17:00	1.1	12.6	2,022.0	0.8	6.10	1	1	1
03/09/2020 18:00	1.5	12.0	2,157.7	1.0	8.60	1	1	1
03/09/2020 19:00	1.5	12.0	2,162.6	1.0	8.70	1	1	1
03/09/2020 20:00	1.6	12.1	2,130.8	1.1	8.50	1	1	1
03/09/2020 21:00	1.7	12.1	2,127.5	1.1	8.50	1	1	1
03/09/2020 22:00	1.8	12.1	2,127.2	1.2	8.50	1	1	1
03/09/2020 23:00	1.8	12.1	2,125.7	1.2	8.50	1	1	1
Average/Sum#:	1.0	13.0	1,854.7	0.7	117.10 #	24 #	24 #	14 #
Minimum:	0.3	12.0	1,503.5	0.2	1.50	1	1	0
Maximum:	1.8	13.7	2,162.6	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/10/2020 00:00	1.8	12.1	2,126.8	1.2	8.50	1	1	1
03/10/2020 01:00	1.7	12.1	2,116.3	1.1	8.50	1	1	1
03/10/2020 02:00	1.7	12.2	2,105.4	1.2	8.40	1	1	1
03/10/2020 03:00	1.5	12.4	2,065.1	1.0	8.30	1	1	1
03/10/2020 04:00	1.5	12.4	2,068.2	1.0	8.30	1	1	1
03/10/2020 05:00	1.7	12.0	2,149.7	1.1	8.60	1	1	1
03/10/2020 06:00	1.7	11.8	2,202.0	1.1	8.80	1	1	1
03/10/2020 07:00	1.7	11.9	2,163.8	1.1	8.70	1	1	1
03/10/2020 08:00	1.5	12.0	2,153.5	1.0	8.60	1	1	1
03/10/2020 09:00	1.5	12.2	2,113.4	1.0	8.50	1	1	1
03/10/2020 10:00	1.4	12.3	2,090.0	1.0	8.40	1	1	1
03/10/2020 11:00	0.0	0.0	2,114.9	0.0	0.00	1	1	1
03/10/2020 12:00	1.5	12.2	2,129.0	1.0	8.50	1	1	1
03/10/2020 13:00	1.7	12.3	2,114.8	1.2	8.50	1	1	1
03/10/2020 14:00	1.7	12.2	2,124.9	1.2	8.50	1	1	1
03/10/2020 15:00	1.7	12.3	2,103.1	1.2	8.40	1	1	1
03/10/2020 16:00	1.7	12.3	2,105.2	1.2	8.40	1	1	1
03/10/2020 17:00	1.6	12.4	2,074.3	1.1	8.30	1	1	1
03/10/2020 18:00	1.7	12.1	2,156.5	1.1	8.60	1	1	1
03/10/2020 19:00	1.8	12.0	2,182.4	1.2	8.70	1	1	1
03/10/2020 20:00	1.8	12.0	2,182.0	1.2	8.70	1	1	1
03/10/2020 21:00	1.7	12.3	2,124.9	1.2	8.50	1	1	1
03/10/2020 22:00	1.7	12.4	2,121.6	1.2	8.50	1	1	1
03/10/2020 23:00	1.7	12.4	2,089.7	1.2	8.40	1	1	1
Average/Sum#:	1.7	12.2	2,124.1	1.1	195.60 #	24 #	24 #	24 #
Minimum:	1.4	11.8	2,065.1	1.0	8.30	1	1	1
Maximum:	1.8	12.4	2,202.0	1.2	8.80	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2020 00:00	1.6	12.6	2,034.8	1.1	8.10	1	1	1
03/11/2020 01:00	1.6	12.7	2,026.3	1.2	8.10	1	1	1
03/11/2020 02:00	1.6	12.6	2,046.5	1.1	8.20	1	1	1
03/11/2020 03:00	1.7	12.6	2,046.6	1.2	8.20	1	1	1
03/11/2020 04:00	1.7	12.5	2,070.4	1.2	8.30	1	1	1
03/11/2020 05:00	1.7	12.4	2,121.6	1.2	8.50	1	1	1
03/11/2020 06:00	1.6	12.0	2,191.3	1.1	8.80	1	1	1
03/11/2020 07:00	1.7	12.3	2,124.5	1.2	8.50	1	1	1
03/11/2020 08:00	1.7	12.3	2,116.3	1.2	8.50	1	1	1
03/11/2020 09:00	1.0	13.6	1,719.1	0.8	5.20	1	1	1
03/11/2020 10:00	0.7	13.8	1,649.8	0.6	3.30	1	1	0
03/11/2020 11:00	0.7	13.8	1,562.1	0.6	3.10	1	1	0
03/11/2020 12:00	0.7	13.9	1,598.0	0.6	3.20	1	1	0
03/11/2020 13:00	0.8	13.9	1,687.2	0.7	3.40	1	1	0
03/11/2020 14:00	0.8	13.9	1,653.1	0.7	3.30	1	1	0
03/11/2020 15:00	0.7	13.9	1,560.0	0.6	3.10	1	1	0
03/11/2020 16:00	0.5	14.0	1,350.6	0.4	2.70	1	1	0
03/11/2020 17:00	0.8	13.9	1,645.4	0.7	3.30	1	1	0
03/11/2020 18:00	0.9	13.8	1,706.9	0.7	5.10	1	1	1
03/11/2020 19:00	1.5	12.7	2,029.1	1.1	8.10	1	1	1
03/11/2020 20:00	1.8	12.0	2,172.6	1.2	8.70	1	1	1
03/11/2020 21:00	1.7	12.2	2,125.6	1.2	8.50	1	1	1
03/11/2020 22:00	1.7	12.5	2,072.5	1.2	8.30	1	1	1
03/11/2020 23:00	1.7	12.3	2,115.3	1.2	8.50	1	1	1
Average/Sum#:	1.3	13.0	1,892.7	1.0	153.00 #	24 #	24 #	16 #
Minimum:	0.5	12.0	1,350.6	0.4	2.70	1	1	0
Maximum:	1.8	14.0	2,191.3	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/12/2020 00:00	1.7	12.4	2,075.2	1.2	8.30	1	1	1
03/12/2020 01:00	1.7	12.6	2,044.0	1.2	8.20	1	1	1
03/12/2020 02:00	1.6	12.8	1,989.9	1.2	8.00	1	1	1
03/12/2020 03:00	1.6	12.6	2,038.8	1.1	8.20	1	1	1
03/12/2020 04:00	1.7	12.4	2,071.6	1.2	8.30	1	1	1
03/12/2020 05:00	1.6	12.4	2,081.3	1.1	8.30	1	1	1
03/12/2020 06:00	1.7	12.0	2,178.0	1.1	8.70	1	1	1
03/12/2020 07:00	1.7	12.0	2,168.8	1.1	8.70	1	1	1
03/12/2020 08:00	1.6	12.4	2,066.4	1.1	8.30	1	1	1
03/12/2020 09:00	0.7	13.8	1,667.7	0.6	3.30	1	1	0
03/12/2020 10:00	0.7	13.8	1,676.7	0.6	3.40	1	1	0
03/12/2020 11:00	0.8	13.9	1,663.4	0.7	3.30	1	1	0
03/12/2020 12:00	1.1	13.8	1,699.6	0.9	5.10	1	1	0
03/12/2020 13:00	0.8	13.9	1,587.1	0.7	3.20	1	1	0
03/12/2020 14:00	0.8	13.9	1,676.7	0.7	3.40	1	1	0
03/12/2020 15:00	1.1	13.3	1,825.9	0.9	5.50	1	1	1
03/12/2020 16:00	1.6	12.3	2,095.5	1.1	8.40	1	1	1
03/12/2020 17:00	1.8	12.0	2,146.7	1.2	8.60	1	1	1
03/12/2020 18:00	1.8	12.0	2,176.4	1.2	8.70	1	1	1
03/12/2020 19:00	1.8	11.9	2,182.9	1.2	8.70	1	1	1
03/12/2020 20:00	1.6	12.3	2,088.8	1.1	8.40	1	1	1
03/12/2020 21:00	1.6	12.1	2,115.5	1.1	8.50	1	1	1
03/12/2020 22:00	1.6	12.1	2,121.4	1.1	8.50	1	1	1
03/12/2020 23:00	1.6	12.1	2,116.5	1.1	8.50	1	1	1
Average/Sum#:	1.4	12.7	1,981.5	1.0	170.50 #	24 #	24 #	18 #
Minimum:	0.7	11.9	1,587.1	0.6	3.20	1	1	0
Maximum:	1.8	13.9	2,182.9	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2020 00:00	1.6	12.1	2,104.1	1.1	8.40	1	1	1
03/13/2020 01:00	1.6	12.1	2,105.6	1.1	8.40	1	1	1
03/13/2020 02:00	1.6	12.2	2,104.7	1.1	8.40	1	1	1
03/13/2020 03:00	1.6	12.2	2,105.0	1.1	8.40	1	1	1
03/13/2020 04:00	1.6	12.4	2,068.0	1.1	8.30	1	1	1
03/13/2020 05:00	1.6	12.1	2,127.2	1.1	8.50	1	1	1
03/13/2020 06:00	1.6	12.2	2,112.9	1.1	8.50	1	1	1
03/13/2020 07:00	1.6	12.2	2,120.9	1.1	8.50	1	1	1
03/13/2020 08:00	1.7	12.1	2,167.3	1.1	8.70	1	1	1
03/13/2020 09:00	1.0	13.6	1,722.3	0.8	5.20	1	1	1
03/13/2020 10:00	0.7	13.9	1,601.6	0.6	3.20	1	1	0
03/13/2020 11:00	0.7	13.9	1,637.0	0.6	3.30	1	1	0
03/13/2020 12:00	0.8	13.9	1,682.0	0.7	3.40	1	1	0
03/13/2020 13:00	0.8	13.9	1,634.8	0.7	3.30	1	1	0
03/13/2020 14:00	0.9	13.8	1,673.9	0.7	5.00	1	1	0
03/13/2020 15:00	0.9	13.9	1,678.5	0.8	5.00	1	1	0
03/13/2020 16:00	0.9	13.9	1,693.4	0.8	5.10	1	1	0
03/13/2020 17:00	1.2	13.3	1,816.5	0.9	5.40	1	1	1
03/13/2020 18:00	1.5	12.5	2,053.3	1.1	8.20	1	1	1
03/13/2020 19:00	1.8	12.0	2,170.0	1.2	8.70	1	1	1
03/13/2020 20:00	1.8	11.9	2,189.1	1.2	8.80	1	1	1
03/13/2020 21:00	1.7	12.2	2,137.0	1.2	8.50	1	1	1
03/13/2020 22:00	1.6	12.4	2,102.5	1.1	8.40	1	1	1
03/13/2020 23:00	1.7	12.5	2,059.6	1.2	8.20	1	1	1
Average/Sum#:	1.4	12.8	1,952.8	1.0	165.80 #	24 #	24 #	17 #
Minimum:	0.7	11.9	1,601.6	0.6	3.20	1	1	0
Maximum:	1.8	13.9	2,189.1	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/14/2020 00:00	1.7	12.3	2,114.7	1.2	8.50	1	1	1
03/14/2020 01:00	1.7	12.3	2,117.8	1.2	8.50	1	1	1
03/14/2020 02:00	1.7	12.3	2,113.1	1.2	8.50	1	1	1
03/14/2020 03:00	1.7	12.3	2,110.9	1.2	8.40	1	1	1
03/14/2020 04:00	1.6	12.6	2,046.9	1.1	8.20	1	1	1
03/14/2020 05:00	1.7	12.5	2,087.0	1.2	8.30	1	1	1
03/14/2020 06:00	1.7	12.4	2,121.3	1.2	8.50	1	1	1
03/14/2020 07:00	1.7	12.4	2,077.3	1.2	8.30	1	1	1
03/14/2020 08:00	0.8	13.9	1,760.8	0.7	3.50	1	1	0
03/14/2020 09:00	0.8	13.9	1,750.9	0.7	3.50	1	1	0
03/14/2020 10:00	0.8	13.9	1,745.9	0.7	3.50	1	1	0
03/14/2020 11:00	0.8	13.9	1,747.5	0.7	3.50	1	1	0
03/14/2020 12:00	0.8	13.9	1,748.0	0.7	3.50	1	1	0
03/14/2020 13:00	0.8	13.9	1,747.5	0.7	3.50	1	1	0
03/14/2020 14:00	0.8	13.9	1,749.9	0.7	3.50	1	1	0
03/14/2020 15:00	0.8	13.9	1,750.6	0.7	3.50	1	1	0
03/14/2020 16:00	0.8	13.9	1,755.6	0.7	3.50	1	1	0
03/14/2020 17:00	1.1	13.4	1,837.9	0.9	5.50	1	1	1
03/14/2020 18:00	1.7	12.4	2,114.7	1.2	8.50	1	1	1
03/14/2020 19:00	1.7	12.1	2,185.9	1.1	8.70	1	1	1
03/14/2020 20:00	1.7	12.2	2,153.3	1.2	8.60	1	1	1
03/14/2020 21:00	1.7	12.4	2,110.3	1.2	8.40	1	1	1
03/14/2020 22:00	1.6	12.7	2,048.7	1.2	8.20	1	1	1
03/14/2020 23:00	1.6	12.7	2,040.0	1.2	8.20	1	1	1
Average/Sum#:	1.3	13.0	1,959.9	1.0	154.80 #	24 #	24 #	15 #
Minimum:	0.8	12.1	1,745.9	0.7	3.50	1	1	0
Maximum:	1.7	13.9	2,185.9	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2020 00:00	1.7	12.6	2,080.7	1.2	8.30	1	1	1
03/15/2020 01:00	1.6	12.7	2,047.4	1.2	8.20	1	1	1
03/15/2020 02:00	1.6	12.7	2,037.8	1.2	8.20	1	1	1
03/15/2020 03:00	1.6	12.7	2,037.4	1.2	8.10	1	1	1
03/15/2020 04:00	1.6	12.7	2,047.4	1.2	8.20	1	1	1
03/15/2020 05:00	1.6	12.7	2,044.8	1.2	8.20	1	1	1
03/15/2020 06:00	1.6	12.7	2,062.7	1.2	8.30	1	1	1
03/15/2020 07:00	1.6	12.6	2,061.9	1.1	8.20	1	1	1
03/15/2020 08:00	1.5	12.7	2,017.9	1.1	8.10	1	1	1
03/15/2020 09:00	0.8	13.8	1,752.8	0.7	3.50	1	1	0
03/15/2020 10:00	0.8	13.8	1,758.3	0.7	3.50	1	1	0
03/15/2020 11:00	0.8	13.8	1,746.1	0.7	3.50	1	1	0
03/15/2020 12:00	0.8	13.8	1,747.4	0.7	3.50	1	1	0
03/15/2020 13:00	0.8	13.9	1,751.7	0.7	3.50	1	1	0
03/15/2020 14:00	0.6	13.9	1,592.7	0.5	3.20	1	1	0
03/15/2020 15:00	0.6	13.9	1,522.6	0.5	3.00	1	1	0
03/15/2020 16:00	0.6	13.9	1,520.6	0.5	3.00	1	1	0
03/15/2020 17:00	1.0	13.4	1,831.2	0.8	5.50	1	1	1
03/15/2020 18:00	1.7	12.1	2,184.0	1.1	8.70	1	1	1
03/15/2020 19:00	1.7	11.9	2,221.3	1.1	8.90	1	1	1
03/15/2020 20:00	1.7	12.0	2,211.2	1.1	8.80	1	1	1
03/15/2020 21:00	1.7	12.1	2,199.6	1.1	8.80	1	1	1
03/15/2020 22:00	1.7	12.5	2,105.6	1.2	8.40	1	1	1
03/15/2020 23:00	1.7	12.5	2,108.6	1.2	8.40	1	1	1
Average/Sum#:	1.3	13.0	1,945.5	1.0	158.00 #	24 #	24 #	16 #
Minimum:	0.6	11.9	1,520.6	0.5	3.00	1	1	0
Maximum:	1.7	13.9	2,221.3	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2020 00:00	1.7	12.4	2,114.4	1.2	8.50	1	1	1
03/16/2020 01:00	1.7	12.5	2,101.3	1.2	8.40	1	1	1
03/16/2020 02:00	1.7	12.4	2,115.6	1.2	8.50	1	1	1
03/16/2020 03:00	1.7	12.5	2,112.4	1.2	8.40	1	1	1
03/16/2020 04:00	1.7	12.3	2,164.5	1.2	8.70	1	1	1
03/16/2020 05:00	1.7	12.2	2,182.4	1.2	8.70	1	1	1
03/16/2020 06:00	1.5	12.0	2,221.5	1.0	8.90	1	1	1
03/16/2020 07:00	1.6	12.4	2,129.1	1.1	8.50	1	1	1
03/16/2020 08:00	1.7	12.4	2,122.0	1.2	8.50	1	1	1
03/16/2020 09:00	1.7	12.4	2,110.6	1.2	8.40	1	1	1
03/16/2020 10:00	1.7	12.4	2,110.4	1.2	8.40	1	1	1
03/16/2020 11:00	1.7	12.4	2,121.0	1.2	8.50	1	1	1
03/16/2020 12:00	1.7	12.4	2,106.5	1.2	8.40	1	1	1
03/16/2020 13:00	1.6	12.5	2,081.9	1.1	8.30	1	1	1
03/16/2020 14:00	1.7	12.6	2,066.6	1.2	8.30	1	1	1
03/16/2020 15:00	1.6	12.7	2,038.7	1.2	8.20	1	1	1
03/16/2020 16:00	1.6	12.7	2,041.4	1.2	8.20	1	1	1
03/16/2020 17:00	1.6	12.6	2,052.2	1.1	8.20	1	1	1
03/16/2020 18:00	1.8	12.0	2,198.0	1.2	8.80	1	1	1
03/16/2020 19:00	1.8	12.0	2,204.5	1.2	8.80	1	1	1
03/16/2020 20:00	1.7	12.2	2,161.9	1.2	8.60	1	1	1
03/16/2020 21:00	1.8	12.1	2,168.2	1.2	8.70	1	1	1
03/16/2020 22:00	1.7	12.4	2,118.9	1.2	8.50	1	1	1
03/16/2020 23:00	1.7	12.4	2,115.2	1.2	8.50	1	1	1
Average/Sum#:	1.7	12.4	2,123.3	1.2	203.90 #	24 #	24 #	24 #
Minimum:	1.5	12.0	2,038.7	1.0	8.20	1	1	1
Maximum:	1.8	12.7	2,221.5	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2020 00:00	1.7	12.5	2,100.7	1.2	8.40	1	1	1
03/17/2020 01:00	1.6	12.5	2,090.2	1.1	8.40	1	1	1
03/17/2020 02:00	1.6	12.8	2,036.4	1.2	8.10	1	1	1
03/17/2020 03:00	1.6	12.7	2,062.1	1.2	8.20	1	1	1
03/17/2020 04:00	1.6	12.8	2,034.1	1.2	8.10	1	1	1
03/17/2020 05:00	1.7	12.5	2,113.7	1.2	8.50	1	1	1
03/17/2020 06:00	1.6	12.3	2,157.3	1.1	8.60	1	1	1
03/17/2020 07:00	1.5	12.8	2,037.5	1.1	8.20	1	1	1
03/17/2020 08:00	1.3	13.2	1,928.1	1.0	7.70	1	1	1
03/17/2020 09:00	0.9	13.8	1,757.0	0.7	5.30	1	1	0
03/17/2020 10:00	0.8	13.8	1,758.6	0.7	3.50	1	1	0
03/17/2020 11:00	0.8	13.8	1,761.8	0.7	3.50	1	1	0
03/17/2020 12:00	0.8	13.8	1,763.8	0.7	3.50	1	1	0
03/17/2020 13:00	0.8	13.8	1,760.2	0.7	3.50	1	1	0
03/17/2020 14:00	0.8	13.8	1,759.6	0.7	3.50	1	1	0
03/17/2020 15:00	0.8	13.8	1,758.8	0.7	3.50	1	1	0
03/17/2020 16:00	0.8	13.8	1,760.9	0.7	3.50	1	1	1
03/17/2020 17:00	1.4	12.8	2,023.9	1.0	8.10	1	1	1
03/17/2020 18:00	1.7	12.4	2,115.6	1.2	8.50	1	1	1
03/17/2020 19:00	1.7	12.3	2,125.0	1.2	8.50	1	1	1
03/17/2020 20:00	1.6	12.6	2,070.6	1.1	8.30	1	1	1
03/17/2020 21:00	1.7	12.6	2,073.7	1.2	8.30	1	1	1
03/17/2020 22:00	1.7	12.5	2,073.6	1.2	8.30	1	1	1
03/17/2020 23:00	1.6	12.7	2,040.2	1.2	8.20	1	1	1
Average/Sum#:	1.3	13.0	1,965.1	1.0	162.20 #	24 #	24 #	17 #
Minimum:	0.8	12.3	1,757.0	0.7	3.50	1	1	0
Maximum:	1.7	13.8	2,157.3	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2020 00:00	1.6	12.7	2,032.6	1.2	8.10	1	1	1
03/18/2020 01:00	1.6	12.8	2,029.6	1.2	8.10	1	1	1
03/18/2020 02:00	1.6	12.8	2,030.8	1.2	8.10	1	1	1
03/18/2020 03:00	1.6	12.7	2,041.1	1.2	8.20	1	1	1
03/18/2020 04:00	1.6	12.8	2,031.3	1.2	8.10	1	1	1
03/18/2020 05:00	1.5	12.8	2,006.4	1.1	8.00	1	1	1
03/18/2020 06:00	1.5	12.4	2,091.5	1.0	8.40	1	1	1
03/18/2020 07:00	1.6	12.5	2,067.0	1.1	8.30	1	1	1
03/18/2020 08:00	1.6	12.7	2,010.8	1.2	8.00	1	1	1
03/18/2020 09:00	0.7	13.8	1,654.6	0.6	3.30	1	1	0
03/18/2020 10:00	0.7	13.8	1,630.1	0.6	3.30	1	1	0
03/18/2020 11:00	0.6	13.8	1,615.1	0.5	3.20	1	1	0
03/18/2020 12:00	0.6	13.8	1,640.0	0.5	3.30	1	1	0
03/18/2020 13:00	0.6	13.8	1,616.6	0.5	3.20	1	1	0
03/18/2020 14:00	0.7	13.8	1,650.2	0.6	3.30	1	1	0
03/18/2020 15:00	0.7	13.8	1,632.9	0.6	3.30	1	1	0
03/18/2020 16:00	0.7	13.8	1,681.8	0.6	3.40	1	1	0
03/18/2020 17:00	0.7	13.8	1,563.7	0.6	3.10	1	1	0
03/18/2020 18:00	1.3	12.9	1,992.5	1.0	8.00	1	1	1
03/18/2020 19:00	1.6	12.8	2,022.6	1.2	8.10	1	1	1
03/18/2020 20:00	1.6	12.6	2,066.1	1.1	8.30	1	1	1
03/18/2020 21:00	1.7	12.7	2,051.9	1.2	10.30	1	1	1
03/18/2020 22:00	1.7	12.7	2,053.4	1.2	10.30	1	1	1
03/18/2020 23:00	1.6	12.8	2,015.8	1.2	8.10	1	1	1
Average/Sum#:	1.2	13.1	1,884.5	0.9	155.80 #	24 #	24 #	15 #
Minimum:	0.6	12.4	1,563.7	0.5	3.10	1	1	0
Maximum:	1.7	13.8	2,091.5	1.2	10.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/19/2020 00:00	1.3	13.2	1,941.1	1.0	7.80	1	1	1
03/19/2020 01:00	1.2	13.2	1,941.8	0.9	5.80	1	1	1
03/19/2020 02:00	1.2	13.2	1,948.4	0.9	5.80	1	1	1
03/19/2020 03:00	1.2	13.2	1,948.8	0.9	5.80	1	1	1
03/19/2020 04:00	1.3	13.1	1,980.5	1.0	7.90	1	1	1
03/19/2020 05:00	1.4	13.0	1,989.0	1.0	8.00	1	1	1
03/19/2020 06:00	1.4	12.6	2,103.3	1.0	8.40	1	1	1
03/19/2020 07:00	1.6	12.6	2,100.4	1.1	8.40	1	1	1
03/19/2020 08:00	1.5	12.9	1,998.8	1.1	8.00	1	1	1
03/19/2020 09:00	0.7	13.8	1,554.5	0.6	3.10	1	1	0
03/19/2020 10:00	0.6	13.8	1,593.5	0.5	3.20	1	1	0
03/19/2020 11:00	0.6	13.9	1,473.0	0.5	2.90	1	1	0
03/19/2020 12:00	0.6	13.9	1,531.7	0.5	3.10	1	1	0
03/19/2020 13:00	0.5	13.9	1,374.0	0.4	2.70	1	1	0
03/19/2020 14:00	0.5	13.9	1,299.8	0.4	2.60	1	1	0
03/19/2020 15:00	0.7	13.9	1,566.5	0.6	3.10	1	1	0
03/19/2020 16:00	0.7	13.9	1,539.2	0.6	3.10	1	1	1
03/19/2020 17:00	1.6	12.7	2,018.0	1.2	8.10	1	1	1
03/19/2020 18:00	1.6	12.5	2,063.4	1.1	8.30	1	1	1
03/19/2020 19:00	1.6	12.3	2,109.3	1.1	8.40	1	1	1
03/19/2020 20:00	1.7	12.4	2,112.9	1.2	8.50	1	1	1
03/19/2020 21:00	1.7	12.4	2,093.9	1.2	8.40	1	1	1
03/19/2020 22:00	1.7	12.6	2,081.3	1.2	8.30	1	1	1
03/19/2020 23:00	1.6	12.8	2,035.8	1.2	8.10	1	1	1
Average/Sum#:	1.2	13.2	1,850.0	0.9	147.80 #	24 #	24 #	17 #
Minimum:	0.5	12.3	1,299.8	0.4	2.60	1	1	0
Maximum:	1.7	13.9	2,112.9	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2020 00:00	1.6	12.9	2,031.3	1.2	8.10	1	1	1
03/20/2020 01:00	1.6	12.9	2,032.7	1.2	8.10	1	1	1
03/20/2020 02:00	1.6	12.8	2,030.9	1.2	8.10	1	1	1
03/20/2020 03:00	1.6	12.9	2,029.7	1.2	8.10	1	1	1
03/20/2020 04:00	1.6	12.9	2,029.8	1.2	8.10	1	1	1
03/20/2020 05:00	1.4	13.1	1,983.2	1.1	7.90	1	1	1
03/20/2020 06:00	1.4	12.9	2,049.1	1.0	8.20	1	1	1
03/20/2020 07:00	1.3	13.2	1,928.7	1.0	7.70	1	1	1
03/20/2020 08:00	0.7	13.8	1,617.2	0.6	3.20	1	1	0
03/20/2020 09:00	0.5	13.9	1,381.3	0.4	2.80	1	1	0
03/20/2020 10:00	0.7	13.8	1,659.9	0.6	3.30	1	1	0
03/20/2020 11:00	0.6	13.9	1,557.8	0.5	3.10	1	1	0
03/20/2020 12:00	0.6	13.9	1,527.2	0.5	3.10	1	1	0
03/20/2020 13:00	0.7	13.9	1,644.7	0.6	3.30	1	1	0
03/20/2020 14:00	0.6	13.9	1,531.9	0.5	3.10	1	1	0
03/20/2020 15:00	0.7	13.9	1,581.6	0.6	3.20	1	1	1
03/20/2020 16:00	1.6	12.8	2,006.0	1.2	8.00	1	1	1
03/20/2020 17:00	1.6	12.6	2,042.3	1.1	8.20	1	1	1
03/20/2020 18:00	1.6	12.6	2,042.8	1.1	8.20	1	1	1
03/20/2020 19:00	1.6	12.6	2,055.5	1.1	8.20	1	1	1
03/20/2020 20:00	1.7	12.5	2,078.7	1.2	8.30	1	1	1
03/20/2020 21:00	1.7	12.4	2,094.3	1.2	8.40	1	1	1
03/20/2020 22:00	1.6	12.5	2,073.4	1.1	8.30	1	1	1
03/20/2020 23:00	1.6	12.7	2,037.1	1.2	8.10	1	1	1
Average/Sum#:	1.3	13.1	1,877.0	0.9	155.10 #	24 #	24 #	17 #
Minimum:	0.5	12.4	1,381.3	0.4	2.80	1	1	0
Maximum:	1.7	13.9	2,094.3	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2020 00:00	1.6	12.7	2,070.8	1.2	8.30	1	1	1
03/21/2020 01:00	1.7	12.6	2,091.2	1.2	8.40	1	1	1
03/21/2020 02:00	1.6	12.5	2,085.7	1.1	8.30	1	1	1
03/21/2020 03:00	1.7	12.5	2,094.3	1.2	8.40	1	1	1
03/21/2020 04:00	1.6	12.6	2,064.0	1.1	8.30	1	1	1
03/21/2020 05:00	1.6	12.6	2,055.9	1.1	8.20	1	1	1
03/21/2020 06:00	1.1	13.1	2,002.1	0.8	6.00	1	1	1
03/21/2020 07:00	3.6	14.5	1,201.0	3.3	6.77	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.8	12.9	1,958.1	1.4	62.67 #	8 #	7 #	8 #
Minimum:	1.1	12.5	1,201.0	0.8	6.00	0	0	0
Maximum:	3.6	14.5	2,094.3	3.3	8.40	1	1	1
%SI	66.67	66.67	66.67	66.67	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/22/2020 17:00	33.4	17.6	464.8	59.7	74.68	1	0	0
03/22/2020 18:00	12.1	17.1	521.9	18.8	36.00	1	0	0
03/22/2020 19:00	10.8	15.5	920.8	11.8	39.60	1	0	0
03/22/2020 20:00	0.5	13.9	1,478.7	0.4	3.00	1	1	0
03/22/2020 21:00	0.5	13.9	1,416.5	0.4	2.80	1	1	0
03/22/2020 22:00	0.6	13.9	1,439.7	0.5	2.90	1	1	0
03/22/2020 23:00	0.6	13.9	1,477.7	0.5	3.00	1	1	0
Average/Sum#:	8.4	15.1	1,102.9	13.2	161.98 #	7 #	4 #	0 #
Minimum:	0.5	13.9	464.8	0.4	2.80	0	0	0
Maximum:	33.4	17.6	1,478.7	59.7	74.68	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.5	13.9	1,367.8	0.4	2.70	1	1	0
03/23/2020 01:00	0.5	13.9	1,351.3	0.4	2.70	1	1	0
03/23/2020 02:00	6.0	16.6	343.8	8.2	1.75	1	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/23/2020 17:00	32.4	17.6	462.2	57.9	68.88	1	0	0
03/23/2020 18:00	11.3	17.1	521.7	17.5	33.90	1	0	0
03/23/2020 19:00	13.0	15.6	864.1	14.5	45.80	1	0	0
03/23/2020 20:00	0.5	13.9	1,551.4	0.4	3.10	1	1	0
03/23/2020 21:00	0.7	13.9	1,538.5	0.6	3.10	1	1	0
03/23/2020 22:00	0.6	13.9	1,547.8	0.5	3.10	1	1	0
03/23/2020 23:00	0.7	13.8	1,648.1	0.6	3.30	1	1	0
Average/Sum#:	6.6	15.0	1,119.7	10.1	168.33 #	10 #	6 #	0 #
Minimum:	0.5	13.8	343.8	0.4	1.75	0	0	0
Maximum:	32.4	17.6	1,648.1	57.9	68.88	1	1	0
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/24/2020 00:00	0.5	13.9	1,432.3	0.4	2.90	1	1	0
03/24/2020 01:00	0.5	13.9	1,379.4	0.4	2.80	1	1	0
03/24/2020 02:00	0.6	13.8	1,580.7	0.5	3.20	1	1	0
03/24/2020 03:00	0.6	13.8	1,524.7	0.5	3.00	1	1	0
03/24/2020 04:00	0.8	13.8	1,725.2	0.7	3.50	1	1	0
03/24/2020 05:00	0.8	13.8	1,700.6	0.7	3.40	1	1	0
03/24/2020 06:00	0.7	13.8	1,686.9	0.6	3.40	1	1	0
03/24/2020 07:00	0.7	13.8	1,701.5	0.6	3.40	1	1	0
03/24/2020 08:00	0.6	13.8	1,575.3	0.5	3.20	1	1	0
03/24/2020 09:00	0.7	13.8	1,681.6	0.6	3.40	1	1	0
03/24/2020 10:00	0.7	13.8	1,701.8	0.6	3.40	1	1	0
03/24/2020 11:00	0.6	13.8	1,614.3	0.5	3.20	1	1	0
03/24/2020 12:00	0.7	13.8	1,648.1	0.6	3.30	1	1	0
03/24/2020 13:00	0.6	13.9	1,548.1	0.5	3.10	1	1	0
03/24/2020 14:00	0.6	13.9	1,570.7	0.5	3.10	1	1	0
03/24/2020 15:00	0.6	13.9	1,586.9	0.5	3.20	1	1	0
03/24/2020 16:00	0.6	13.9	1,604.7	0.5	3.20	1	1	1
03/24/2020 17:00	1.5	12.7	2,020.6	1.1	8.10	1	1	1
03/24/2020 18:00	1.6	12.9	1,996.4	1.2	8.00	1	1	1
03/24/2020 19:00	1.6	12.8	2,019.1	1.2	8.10	1	1	1
03/24/2020 20:00	1.7	12.4	2,110.1	1.2	8.40	1	1	1
03/24/2020 21:00	1.6	12.7	2,046.7	1.2	8.20	1	1	1
03/24/2020 22:00	1.6	12.8	2,047.3	1.2	8.20	1	1	1
03/24/2020 23:00	3.9	14.3	1,244.1	3.5	7.78	1	0	1
Average/Sum#:	1.0	13.6	1,697.8	0.8	111.48 #	24 #	23 #	8 #
Minimum:	0.5	12.4	1,244.1	0.4	2.80	1	0	0
Maximum:	3.9	14.3	2,110.1	3.5	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/27/2020 17:00	32.4	17.5	483.2	56.2	93.00	1	0	0
03/27/2020 18:00	10.2	17.2	524.0	16.3	31.40	1	0	0
03/27/2020 19:00	15.9	15.4	882.5	17.1	55.60	1	0	0
03/27/2020 20:00	0.5	13.9	1,598.1	0.4	3.20	1	1	0
03/27/2020 21:00	0.6	13.9	1,427.6	0.5	2.90	1	1	0
03/27/2020 22:00	0.5	13.9	1,428.1	0.4	2.90	1	1	0
03/27/2020 23:00	0.7	13.8	1,683.7	0.6	3.40	1	1	0
Average/Sum#:	8.7	15.1	1,146.7	13.1	192.40 #	7 #	4 #	0 #
Minimum:	0.5	13.8	483.2	0.4	2.90	0	0	0
Maximum:	32.4	17.5	1,683.7	56.2	93.00	1	1	0
%SI	70.83	70.83	70.83	70.83	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2020 00:00	0.6	13.9	1,514.3	0.5	3.00	1	1	0
03/28/2020 01:00	0.7	13.8	1,683.8	0.6	3.40	1	1	0
03/28/2020 02:00	0.7	13.8	1,693.4	0.6	3.40	1	1	0
03/28/2020 03:00	0.7	13.8	1,696.4	0.6	3.40	1	1	0
03/28/2020 04:00	0.7	13.8	1,676.9	0.6	3.40	1	1	0
03/28/2020 05:00	0.7	13.8	1,678.7	0.6	3.40	1	1	0
03/28/2020 06:00	0.6	13.8	1,559.6	0.5	3.10	1	1	0
03/28/2020 07:00	0.6	13.8	1,527.0	0.5	3.10	1	1	0
03/28/2020 08:00	0.7	13.8	1,639.4	0.6	3.30	1	1	0
03/28/2020 09:00	0.7	13.8	1,665.2	0.6	3.30	1	1	0
03/28/2020 10:00	0.7	13.8	1,692.7	0.6	3.40	1	1	0
03/28/2020 11:00	0.7	13.8	1,698.4	0.6	3.40	1	1	0
03/28/2020 12:00	0.7	13.8	1,687.9	0.6	3.40	1	1	0
03/28/2020 13:00	0.7	13.8	1,691.7	0.6	3.40	1	1	0
03/28/2020 14:00	0.7	13.8	1,670.2	0.6	3.30	1	1	0
03/28/2020 15:00	0.7	13.9	1,670.5	0.6	3.30	1	1	0
03/28/2020 16:00	0.8	13.8	1,698.8	0.7	3.40	1	1	0
03/28/2020 17:00	1.1	13.3	1,846.2	0.9	5.50	1	1	1
03/28/2020 18:00	1.7	12.4	2,114.3	1.2	8.50	1	1	1
03/28/2020 19:00	1.7	12.5	2,080.3	1.2	8.30	1	1	1
03/28/2020 20:00	1.7	12.3	2,117.6	1.2	8.50	1	1	1
03/28/2020 21:00	1.7	12.6	2,064.6	1.2	8.30	1	1	1
03/28/2020 22:00	1.7	12.6	2,055.4	1.2	8.20	1	1	1
03/28/2020 23:00	1.5	12.9	1,968.9	1.1	7.90	1	1	1
Average/Sum#:	1.0	13.5	1,766.3	0.8	111.60 #	24 #	24 #	7 #
Minimum:	0.6	12.3	1,514.3	0.5	3.00	1	1	0
Maximum:	1.7	13.9	2,117.6	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.7	13.8	1,646.7	0.6	3.30	1	1	0
03/29/2020 01:00	0.6	13.8	1,606.5	0.5	3.20	1	1	0
03/29/2020 02:00	0.6	13.8	1,615.4	0.5	3.20	1	1	0
03/29/2020 03:00	0.6	13.8	1,564.6	0.5	3.10	1	1	0
03/29/2020 04:00	0.7	13.8	1,699.9	0.6	3.40	1	1	0
03/29/2020 05:00	0.7	13.8	1,615.7	0.6	3.20	1	1	0
03/29/2020 06:00	0.6	13.8	1,593.2	0.5	3.20	1	1	0
03/29/2020 07:00	0.6	13.8	1,618.2	0.5	3.20	1	1	0
03/29/2020 08:00	0.6	13.8	1,603.0	0.5	3.20	1	1	0
03/29/2020 09:00	0.7	13.8	1,679.2	0.6	3.40	1	1	0
03/29/2020 10:00	0.7	13.8	1,702.6	0.6	3.40	1	1	0
03/29/2020 11:00	0.7	13.8	1,679.4	0.6	3.40	1	1	0
03/29/2020 12:00	0.7	13.9	1,571.1	0.6	3.10	1	1	0
03/29/2020 13:00	0.7	13.8	1,614.5	0.6	3.20	1	1	0
03/29/2020 14:00	0.7	13.9	1,597.8	0.6	3.20	1	1	0
03/29/2020 15:00	0.7	13.9	1,595.7	0.6	3.20	1	1	0
03/29/2020 16:00	0.8	13.9	1,652.6	0.7	3.30	1	1	0
03/29/2020 17:00	0.7	13.8	1,561.9	0.6	3.10	1	1	1
03/29/2020 18:00	1.5	12.6	2,026.3	1.1	8.10	1	1	1
03/29/2020 19:00	1.7	12.3	2,096.9	1.2	8.40	1	1	1
03/29/2020 20:00	1.7	12.4	2,079.0	1.2	8.30	1	1	1
03/29/2020 21:00	1.7	12.4	2,074.3	1.2	8.30	1	1	1
03/29/2020 22:00	1.5	13.0	1,951.3	1.1	7.80	1	1	1
03/29/2020 23:00	1.5	12.9	1,958.5	1.1	7.80	1	1	1
Average/Sum#:	0.9	13.5	1,725.2	0.7	107.00 #	24 #	24 #	7 #
Minimum:	0.6	12.3	1,561.9	0.5	3.10	1	1	0
Maximum:	1.7	13.9	2,096.9	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2020 00:00	0.8	13.8	1,687.9	0.7	3.40	1	1	0
03/30/2020 01:00	0.7	13.8	1,688.9	0.6	3.40	1	1	0
03/30/2020 02:00	0.7	13.8	1,677.1	0.6	3.40	1	1	0
03/30/2020 03:00	0.7	13.8	1,649.8	0.6	3.30	1	1	0
03/30/2020 04:00	0.6	13.8	1,626.3	0.5	3.30	1	1	0
03/30/2020 05:00	0.7	13.8	1,677.8	0.6	3.40	1	1	0
03/30/2020 06:00	0.7	13.8	1,686.9	0.6	3.40	1	1	0
03/30/2020 07:00	0.6	13.8	1,663.8	0.5	3.30	1	1	0
03/30/2020 08:00	0.6	13.8	1,640.7	0.5	3.30	1	1	0
03/30/2020 09:00	0.7	13.8	1,664.4	0.6	3.30	1	1	0
03/30/2020 10:00	0.7	13.9	1,666.9	0.6	3.30	1	1	0
03/30/2020 11:00	0.7	13.9	1,641.2	0.6	3.30	1	1	0
03/30/2020 12:00	0.7	13.9	1,606.7	0.6	3.20	1	1	0
03/30/2020 13:00	0.7	13.9	1,595.8	0.6	3.20	1	1	0
03/30/2020 14:00	0.8	13.9	1,651.7	0.7	3.30	1	1	0
03/30/2020 15:00	0.7	13.9	1,613.2	0.6	3.20	1	1	0
03/30/2020 16:00	0.8	13.9	1,663.6	0.7	3.30	1	1	0
03/30/2020 17:00	0.7	13.9	1,657.4	0.6	3.30	1	1	1
03/30/2020 18:00	1.5	12.7	2,003.2	1.1	8.00	1	1	1
03/30/2020 19:00	1.7	12.5	2,049.4	1.2	8.20	1	1	1
03/30/2020 20:00	1.7	12.3	2,103.5	1.2	8.40	1	1	1
03/30/2020 21:00	1.7	12.3	2,103.4	1.2	8.40	1	1	1
03/30/2020 22:00	1.6	12.4	2,089.8	1.1	8.40	1	1	1
03/30/2020 23:00	1.6	12.7	2,025.9	1.2	8.10	1	1	1
Average/Sum#:	0.9	13.5	1,755.6	0.7	109.10 #	24 #	24 #	7 #
Minimum:	0.6	12.3	1,595.8	0.5	3.20	1	1	0
Maximum:	1.7	13.9	2,103.5	1.2	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2020 00:00	1.6	12.6	2,033.6	1.1	8.10	1	1	1
03/31/2020 01:00	1.6	12.6	2,033.7	1.1	8.10	1	1	1
03/31/2020 02:00	1.6	12.7	2,035.1	1.2	8.10	1	1	1
03/31/2020 03:00	1.6	12.7	2,032.8	1.2	8.10	1	1	1
03/31/2020 04:00	1.6	12.8	2,017.7	1.2	8.10	1	1	1
03/31/2020 05:00	1.4	13.1	1,948.6	1.1	7.80	1	1	1
03/31/2020 06:00	1.5	12.7	2,032.9	1.1	8.10	1	1	1
03/31/2020 07:00	3.6	14.3	1,217.9	3.2	7.30	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
03/31/2020 18:00	23.5	17.5	469.7	40.8	61.34	1	0	0
03/31/2020 19:00	15.9	15.2	919.4	16.5	56.10	1	0	0
03/31/2020 20:00	0.4	13.9	1,430.6	0.3	1.40	1	1	0
03/31/2020 21:00	0.5	13.9	1,349.9	0.4	2.70	1	1	0
03/31/2020 22:00	0.5	13.9	1,359.3	0.4	2.70	1	1	0
03/31/2020 23:00	0.6	13.9	1,510.0	0.5	3.00	1	1	0
Average/Sum#:	4.0	13.7	1,599.4	5.0	190.94 #	14 #	11 #	8 #
Minimum:	0.4	12.6	469.7	0.3	1.40	0	0	0
Maximum:	23.5	17.5	2,035.1	40.8	61.34	1	1	1
%SI	41.67	41.67	41.67	41.67	41.67	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/01/2020 00:00	0.4	12.6	2,047.4	0.3	1.3	1	1	1
01/01/2020 01:00	0.3	12.7	2,032.6	0.3	1.0	1	1	1
01/01/2020 02:00	7.2	14.6	1,132.0	0.0	7.4	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.6	13.3	1,737.3	0.3	9.7 #	3 #	2 #	3 #
Minimum:	0.3	12.6	1,132.0	0.3	1.0	0	0	0
Maximum:	7.2	14.6	2,047.4	0.3	7.4	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/02/2020 07:00	109.3	18.2	375.4	0.0	56.2	1	1	0
01/02/2020 08:00	21.4	15.8	794.9	0.0	44.1	1	1	0
01/02/2020 09:00	0.0	13.9	1,520.1	0.0	0.0	1	1	0
01/02/2020 10:00	0.0	13.9	1,653.2	0.0	0.0	1	1	0
01/02/2020 11:00	0.0	13.9	1,669.7	0.0	0.0	1	1	0
01/02/2020 12:00	0.0	13.9	1,615.8	0.0	0.0	1	1	0
01/02/2020 13:00	0.0	13.9	1,639.0	0.0	0.0	1	1	0
01/02/2020 14:00	0.0	13.9	1,625.1	0.0	0.0	1	1	0
01/02/2020 15:00	0.0	13.9	1,587.2	0.0	0.0	1	1	1
01/02/2020 16:00	0.3	12.6	2,022.4	0.1	1.0	1	1	1
01/02/2020 17:00	0.3	12.4	2,057.7	0.1	1.0	1	1	1
01/02/2020 18:00	0.3	12.3	2,101.3	0.2	1.0	1	1	1
01/02/2020 19:00	0.2	12.3	2,102.5	0.2	0.6	1	1	1
01/02/2020 20:00	0.3	12.3	2,108.2	0.2	1.0	1	1	1
01/02/2020 21:00	0.2	12.1	2,127.6	0.1	0.6	1	1	1
01/02/2020 22:00	0.2	12.2	2,114.6	0.1	0.6	1	1	1
01/02/2020 23:00	0.2	12.6	2,062.2	0.1	0.7	1	1	1
Average/Sum#:	7.8	13.5	1,716.3	0.1	106.8 #	17 #	20 #	9 #
Minimum:	0.0	12.1	375.4	0.0	0.0	0	0	0
Maximum:	109.3	18.2	2,127.6	0.2	56.2	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2020 00:00	0.2	12.7	2,043.7	0.1	0.7	1	1	1
01/03/2020 01:00	0.2	12.6	2,040.5	0.1	0.6	1	1	1
01/03/2020 02:00	0.2	12.7	2,034.5	0.1	0.7	1	1	1
01/03/2020 03:00	0.2	12.7	2,046.3	0.1	0.7	1	1	1
01/03/2020 04:00	0.2	12.7	2,048.4	0.1	0.7	1	1	1
01/03/2020 05:00	0.3	12.7	2,037.6	0.1	1.0	1	1	1
01/03/2020 06:00	0.3	12.8	2,018.8	0.2	1.0	1	1	1
01/03/2020 07:00	0.3	12.8	2,033.2	0.2	1.0	1	1	1
01/03/2020 08:00	0.3	13.3	1,883.8	0.2	1.0	1	1	1
01/03/2020 09:00	0.0	13.9	1,521.2	0.1	0.0	1	1	0
01/03/2020 10:00	0.0	13.9	1,546.6	0.1	0.0	1	1	0
01/03/2020 11:00	0.0	13.9	1,592.3	0.0	0.0	1	1	0
01/03/2020 12:00	0.0	13.9	1,674.7	0.0	0.0	1	1	0
01/03/2020 13:00	0.0	13.9	1,653.4	0.0	0.0	1	1	0
01/03/2020 14:00	0.0	13.9	1,540.0	0.0	0.0	1	1	0
01/03/2020 15:00	0.0	13.9	1,574.9	0.0	0.0	1	1	0
01/03/2020 16:00	0.3	13.0	1,947.1	0.1	1.0	1	1	1
01/03/2020 17:00	0.3	12.7	2,027.7	0.1	1.0	1	1	1
01/03/2020 18:00	0.3	12.6	2,057.3	0.0	1.0	1	1	1
01/03/2020 19:00	0.3	12.6	2,044.2	0.2	1.0	1	1	1
01/03/2020 20:00	0.3	12.6	2,062.8	0.2	1.0	1	1	1
01/03/2020 21:00	0.3	12.3	2,116.1	0.2	1.0	1	1	1
01/03/2020 22:00	0.3	12.4	2,118.5	0.2	1.0	1	1	1
01/03/2020 23:00	3.1	13.2	1,678.7	0.0	8.9	1	0	1
Average/Sum#:	0.3	13.1	1,889.3	0.1	23.3 #	24 #	23 #	17 #
Minimum:	0.0	12.3	1,521.2	0.0	0.0	1	0	0
Maximum:	3.1	13.9	2,118.5	0.2	8.9	1	1	1
%SI	0.00	0.00	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/04/2020 00:00	9.0	19.4	0.2	0.0	0.0	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	9.0	19.4	0.2	0.0	0.0 #	1 #	0 #	0 #
Minimum:	9.0	19.4	0.2	0.0	0.0	0	0	0
Maximum:	9.0	19.4	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 07:00	113.2	19.5	212.8	0.0	29.5	1	1	0
01/06/2020 08:00	39.5	16.6	601.7	0.0	73.0	1	1	0
01/06/2020 09:00	2.7	14.1	1,529.5	0.0	8.0	1	1	0
01/06/2020 10:00	0.0	13.9	1,546.4	0.0	0.0	1	1	0
01/06/2020 11:00	0.0	13.9	1,643.7	0.0	0.0	1	1	0
01/06/2020 12:00	0.0	13.9	1,574.9	0.0	0.0	1	1	0
01/06/2020 13:00	0.0	13.9	1,627.9	0.0	0.0	1	1	0
01/06/2020 14:00	0.0	13.9	1,558.1	0.0	0.0	1	1	0
01/06/2020 15:00	0.0	13.9	1,543.6	0.0	0.0	1	1	1
01/06/2020 16:00	0.4	12.8	2,021.8	0.1	1.3	1	1	1
01/06/2020 17:00	0.2	12.6	2,054.0	0.1	0.7	1	1	1
01/06/2020 18:00	0.1	12.7	2,048.2	0.2	0.3	1	1	1
01/06/2020 19:00	0.1	12.8	2,036.6	0.1	0.3	1	1	1
01/06/2020 20:00	0.1	12.8	2,030.5	0.1	0.3	1	1	1
01/06/2020 21:00	0.1	12.8	2,035.0	0.1	0.3	1	1	1
01/06/2020 22:00	0.1	12.7	2,058.6	0.1	0.3	1	1	1
01/06/2020 23:00	0.1	13.0	2,018.3	0.1	0.3	1	1	1
Average/Sum#:	9.2	13.9	1,655.4	0.1	114.3 #	17 #	17 #	9 #
Minimum:	0.0	12.6	212.8	0.0	0.0	0	0	0
Maximum:	113.2	19.5	2,058.6	0.2	73.0	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2020 00:00	0.1	12.8	2,038.3	0.1	0.3	1	1	1
01/07/2020 01:00	0.1	13.0	2,021.6	0.1	0.3	1	1	1
01/07/2020 02:00	0.2	13.0	2,010.9	0.1	0.7	1	1	1
01/07/2020 03:00	0.2	13.0	2,009.9	0.1	0.7	1	1	1
01/07/2020 04:00	0.2	12.9	2,029.6	0.1	0.7	1	1	1
01/07/2020 05:00	0.2	12.9	2,035.9	0.1	0.7	1	1	1
01/07/2020 06:00	0.2	12.9	2,035.6	0.1	0.7	1	1	1
01/07/2020 07:00	0.2	12.7	2,081.0	0.1	0.7	1	1	1
01/07/2020 08:00	0.3	13.3	1,926.0	0.1	1.0	1	1	1
01/07/2020 09:00	0.0	13.8	1,715.4	0.1	0.0	1	1	0
01/07/2020 10:00	0.0	13.8	1,617.3	0.1	0.0	1	1	0
01/07/2020 11:00	0.0	13.8	1,604.8	0.0	0.0	1	1	0
01/07/2020 12:00	0.0	13.8	1,671.1	0.0	0.0	1	1	0
01/07/2020 13:00	0.0	13.8	1,640.1	0.0	0.0	1	1	0
01/07/2020 14:00	0.0	13.8	1,586.1	0.0	0.0	1	1	0
01/07/2020 15:00	0.0	13.8	1,565.3	0.0	0.0	1	1	1
01/07/2020 16:00	0.5	12.9	2,010.7	0.1	1.7	1	1	1
01/07/2020 17:00	0.4	12.8	2,037.7	0.2	1.3	1	1	1
01/07/2020 18:00	0.3	12.8	2,035.5	0.3	1.0	1	1	1
01/07/2020 19:00	0.3	12.8	2,024.5	0.2	1.0	1	1	1
01/07/2020 20:00	0.4	12.7	2,058.3	0.2	1.3	1	1	1
01/07/2020 21:00	0.4	12.6	2,076.5	0.3	1.3	1	1	1
01/07/2020 22:00	5.7	14.2	1,263.2	0.0	6.8	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.2	1,873.7	0.1	20.2 #	23 #	22 #	17 #
Minimum:	0.0	12.6	1,263.2	0.0	0.0	0	0	0
Maximum:	5.7	14.2	2,081.0	0.3	6.8	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/09/2020 02:00	113.6	18.2	381.2	0.0	59.3	1	1	0
01/09/2020 03:00	19.3	15.4	916.2	0.0	42.5	1	1	0
01/09/2020 04:00	0.0	13.8	1,685.2	0.0	0.0	1	1	0
01/09/2020 05:00	0.0	13.8	1,628.3	0.0	0.0	1	1	0
01/09/2020 06:00	0.0	13.9	1,386.6	0.0	0.0	1	1	0
01/09/2020 07:00	0.0	13.8	1,483.0	0.0	0.0	1	1	0
01/09/2020 08:00	0.0	13.8	1,623.6	0.0	0.0	1	1	0
01/09/2020 09:00	0.0	13.8	1,697.4	0.0	0.0	1	1	0
01/09/2020 10:00	0.0	13.8	1,573.0	0.0	0.0	1	1	0
01/09/2020 11:00	0.0	13.8	1,668.1	0.0	0.0	1	1	0
01/09/2020 12:00	0.0	13.8	1,636.1	0.0	0.0	1	1	0
01/09/2020 13:00	0.0	13.9	1,677.5	0.0	0.0	1	1	0
01/09/2020 14:00	0.0	13.9	1,605.1	0.0	0.0	1	1	0
01/09/2020 15:00	0.0	13.9	1,560.0	0.0	0.0	1	1	1
01/09/2020 16:00	0.4	12.7	2,038.7	0.1	1.3	1	1	1
01/09/2020 17:00	0.3	12.4	2,100.4	0.2	1.0	1	1	1
01/09/2020 18:00	0.3	12.2	2,144.2	0.2	1.0	1	1	1
01/09/2020 19:00	0.3	12.2	2,135.9	0.2	1.0	1	1	1
01/09/2020 20:00	0.3	12.2	2,140.8	0.2	1.0	1	1	1
01/09/2020 21:00	0.3	12.3	2,113.8	0.2	1.0	1	1	1
01/09/2020 22:00	0.3	12.3	2,128.4	0.2	1.0	1	1	1
01/09/2020 23:00	0.3	12.3	2,125.5	0.2	1.0	1	1	1
Average/Sum#:	6.2	13.6	1,702.2	0.1	110.1 #	22 #	24 #	9 #
Minimum:	0.0	12.2	381.2	0.0	0.0	0	1	0
Maximum:	113.6	18.2	2,144.2	0.2	59.3	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2020 00:00	0.2	12.5	2,074.3	0.2	0.7	1	1	1
01/10/2020 01:00	0.2	12.7	2,055.4	0.1	0.7	1	1	1
01/10/2020 02:00	0.3	12.4	2,119.4	0.1	1.0	1	1	1
01/10/2020 03:00	0.3	12.3	2,124.4	0.2	1.0	1	1	1
01/10/2020 04:00	0.2	12.7	2,044.1	0.2	0.7	1	1	1
01/10/2020 05:00	0.3	12.7	2,061.3	0.2	1.0	1	1	1
01/10/2020 06:00	0.4	12.5	2,141.0	0.2	1.3	1	1	1
01/10/2020 07:00	0.3	12.1	2,203.0	0.2	1.0	1	1	1
01/10/2020 08:00	0.2	12.7	2,076.8	0.2	0.7	1	1	1
01/10/2020 09:00	0.3	13.3	1,914.2	0.2	1.0	1	1	1
01/10/2020 10:00	0.0	13.9	1,696.9	0.1	0.0	1	1	0
01/10/2020 11:00	0.0	13.8	1,656.6	0.1	0.0	1	1	0
01/10/2020 12:00	0.0	13.8	1,630.8	0.0	0.0	1	1	0
01/10/2020 13:00	0.0	13.8	1,675.0	0.0	0.0	1	1	0
01/10/2020 14:00	0.0	13.9	1,533.2	0.0	0.0	1	1	0
01/10/2020 15:00	0.0	13.8	1,540.9	0.0	0.0	1	1	1
01/10/2020 16:00	0.4	12.8	2,034.1	0.1	1.3	1	1	1
01/10/2020 17:00	0.4	12.5	2,084.9	0.2	1.3	1	1	1
01/10/2020 18:00	0.4	12.4	2,117.8	0.3	1.3	1	1	1
01/10/2020 19:00	0.3	12.5	2,094.9	0.3	1.0	1	1	1
01/10/2020 20:00	0.3	12.6	2,082.0	0.2	1.0	1	1	1
01/10/2020 21:00	0.3	12.6	2,069.1	0.2	1.0	1	1	1
01/10/2020 22:00	0.3	12.7	2,038.2	0.2	1.0	1	1	1
01/10/2020 23:00	0.3	12.8	2,021.5	0.2	1.0	1	1	1
Average/Sum#:	0.2	12.9	1,962.1	0.2	18.0 #	24 #	24 #	19 #
Minimum:	0.0	12.1	1,533.2	0.0	0.0	1	1	0
Maximum:	0.4	13.9	2,203.0	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/11/2020 00:00	0.3	12.8	2,034.9	0.2	1.0	1	1	1
01/11/2020 01:00	0.3	12.8	2,029.7	0.2	1.0	1	1	1
01/11/2020 02:00	0.3	12.8	2,037.5	0.2	1.0	1	1	1
01/11/2020 03:00	0.3	12.9	2,038.0	0.2	1.0	1	1	1
01/11/2020 04:00	0.3	12.8	2,045.4	0.2	1.0	1	1	1
01/11/2020 05:00	0.3	12.8	2,033.9	0.2	1.0	1	1	1
01/11/2020 06:00	0.3	12.8	2,036.6	0.2	1.0	1	1	1
01/11/2020 07:00	0.3	12.8	2,042.0	0.2	1.0	1	1	1
01/11/2020 08:00	5.5	14.2	1,290.8	0.0	7.3	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.9	13.0	1,954.3	0.2	15.3 #	9 #	8 #	9 #
Minimum:	0.3	12.8	1,290.8	0.2	1.0	0	0	0
Maximum:	5.5	14.2	2,045.4	0.2	7.3	1	1	1
%SI	62.50	62.50	62.50	66.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/13/2020 03:00	131.4	18.8	311.8	0.0	51.5	1	1	0
01/13/2020 04:00	33.9	16.7	590.4	0.0	62.9	1	1	0
01/13/2020 05:00	34.2	15.4	811.9	0.0	66.7	1	1	0
01/13/2020 06:00	0.0	13.8	1,629.4	0.0	0.0	1	1	0
01/13/2020 07:00	0.0	13.8	1,613.3	0.0	0.0	1	1	0
01/13/2020 08:00	0.0	13.8	1,540.0	0.0	0.0	1	1	0
01/13/2020 09:00	0.0	13.8	1,661.0	0.0	0.0	1	1	0
01/13/2020 10:00	0.0	13.8	1,591.1	0.0	0.0	1	1	0
01/13/2020 11:00	0.0	13.8	1,520.2	0.0	0.0	1	1	0
01/13/2020 12:00	0.0	13.8	1,612.6	0.0	0.0	1	1	0
01/13/2020 13:00	0.0	13.8	1,689.3	0.0	0.0	1	1	0
01/13/2020 14:00	0.0	13.9	1,571.8	0.0	0.0	1	1	0
01/13/2020 15:00	0.0	13.8	1,547.6	0.0	0.0	1	1	1
01/13/2020 16:00	0.6	12.7	2,028.5	0.1	2.0	1	1	1
01/13/2020 17:00	0.6	12.0	2,152.7	0.3	1.9	1	1	1
01/13/2020 18:00	0.5	11.9	2,171.5	0.4	1.6	1	1	1
01/13/2020 19:00	0.5	12.0	2,158.4	0.3	1.6	1	1	1
01/13/2020 20:00	0.5	12.0	2,145.6	0.3	1.6	1	1	1
01/13/2020 21:00	0.5	12.3	2,091.7	0.3	1.6	1	1	1
01/13/2020 22:00	0.5	12.4	2,057.4	0.3	1.6	1	1	1
01/13/2020 23:00	0.5	12.5	2,041.2	0.3	1.6	1	1	1
Average/Sum#:	9.7	13.7	1,644.6	0.2	194.6 #	21 #	22 #	9 #
Minimum:	0.0	11.9	311.8	0.0	0.0	0	0	0
Maximum:	131.4	18.8	2,171.5	0.4	66.7	1	1	1
%SI	12.50	12.50	12.50	37.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2020 00:00	0.5	12.5	2,050.6	0.4	1.6	1	1	1
01/14/2020 01:00	0.5	12.5	2,039.4	0.4	1.6	1	1	1
01/14/2020 02:00	0.5	12.5	2,043.5	0.4	1.6	1	1	1
01/14/2020 03:00	0.5	12.5	2,041.6	0.4	1.6	1	1	1
01/14/2020 04:00	0.5	12.6	2,042.3	0.4	1.6	1	1	1
01/14/2020 05:00	0.6	12.4	2,072.5	0.4	1.9	1	1	1
01/14/2020 06:00	0.6	12.3	2,112.3	0.4	1.9	1	1	1
01/14/2020 07:00	0.5	12.0	2,182.9	0.4	1.6	1	1	1
01/14/2020 08:00	0.5	12.6	2,051.7	0.4	1.6	1	1	1
01/14/2020 09:00	0.5	12.6	1,990.6	0.4	1.6	1	1	1
01/14/2020 10:00	0.0	13.8	1,676.4	0.3	0.0	1	1	0
01/14/2020 11:00	0.0	13.8	1,689.2	0.1	0.0	1	1	0
01/14/2020 12:00	0.0	13.8	1,659.1	0.0	0.0	1	1	0
01/14/2020 13:00	0.0	13.8	1,681.2	0.0	0.0	1	1	0
01/14/2020 14:00	0.0	0.0	1,625.9	0.0	0.0	1	1	0
01/14/2020 15:00	0.0	13.8	1,533.7	0.0	0.0	1	1	0
01/14/2020 16:00	0.1	13.8	1,548.7	0.0	0.3	1	1	1
01/14/2020 17:00	0.7	12.8	2,001.0	0.2	2.3	1	1	1
01/14/2020 18:00	0.6	12.6	2,044.7	0.3	2.0	1	1	1
01/14/2020 19:00	0.5	12.6	2,053.8	0.4	1.6	1	1	1
01/14/2020 20:00	0.6	12.4	2,093.2	0.4	2.0	1	1	1
01/14/2020 21:00	0.6	12.5	2,076.4	0.4	2.0	1	1	1
01/14/2020 22:00	0.5	12.7	2,043.8	0.4	1.6	1	1	1
01/14/2020 23:00	0.6	13.0	1,985.9	0.4	2.0	1	1	1
Average/Sum#:	0.4	12.9	1,930.9	0.3	30.4 #	24 #	24 #	18 #
Minimum:	0.0	12.0	1,533.7	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,182.9	0.4	2.3	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/15/2020 00:00	0.5	12.8	2,036.4	0.4	1.7	1	1	1
01/15/2020 01:00	0.5	12.7	2,039.9	0.4	1.6	1	1	1
01/15/2020 02:00	0.5	12.7	2,042.7	0.4	1.6	1	1	1
01/15/2020 03:00	0.5	12.8	2,039.6	0.4	1.7	1	1	1
01/15/2020 04:00	0.5	12.8	2,041.3	0.4	1.7	1	1	1
01/15/2020 05:00	0.6	12.6	2,068.0	0.4	2.0	1	1	1
01/15/2020 06:00	0.6	12.2	2,180.0	0.4	2.0	1	1	1
01/15/2020 07:00	0.6	11.7	2,289.4	0.4	2.0	1	1	1
01/15/2020 08:00	0.5	12.7	2,038.9	0.4	1.6	1	1	1
01/15/2020 09:00	0.0	13.8	1,610.9	0.3	0.0	1	1	0
01/15/2020 10:00	0.0	13.8	1,652.5	0.1	0.0	1	1	0
01/15/2020 11:00	0.0	13.8	1,668.7	0.0	0.0	1	1	0
01/15/2020 12:00	0.0	13.8	1,627.7	0.0	0.0	1	1	0
01/15/2020 13:00	0.0	13.8	1,672.1	0.0	0.0	1	1	0
01/15/2020 14:00	0.0	13.8	1,687.2	0.0	0.0	1	1	0
01/15/2020 15:00	0.0	13.8	1,590.5	0.0	0.0	1	1	1
01/15/2020 16:00	0.7	12.5	2,055.4	0.2	2.3	1	1	1
01/15/2020 17:00	0.6	12.0	2,157.4	0.3	1.9	1	1	1
01/15/2020 18:00	0.6	12.2	2,131.7	0.4	1.9	1	1	1
01/15/2020 19:00	0.6	11.9	2,194.2	0.4	1.9	1	1	1
01/15/2020 20:00	0.5	11.9	2,187.8	0.4	1.6	1	1	1
01/15/2020 21:00	0.5	11.9	2,172.1	0.3	1.6	1	1	1
01/15/2020 22:00	0.5	12.3	2,091.6	0.3	1.6	1	1	1
01/15/2020 23:00	0.5	12.5	2,055.1	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,972.1	0.3	30.3 #	24 #	24 #	18 #
Minimum:	0.0	11.7	1,590.5	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,289.4	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/16/2020 00:00	0.5	12.6	2,039.7	0.4	1.6	1	1	1
01/16/2020 01:00	0.6	12.5	2,042.3	0.4	1.9	1	1	1
01/16/2020 02:00	0.6	12.5	2,045.3	0.4	1.9	1	1	1
01/16/2020 03:00	0.6	12.5	2,047.5	0.4	1.9	1	1	1
01/16/2020 04:00	0.6	12.5	2,050.7	0.4	1.9	1	1	1
01/16/2020 05:00	0.6	12.4	2,046.7	0.4	1.9	1	1	1
01/16/2020 06:00	0.6	12.3	2,078.5	0.4	1.9	1	1	1
01/16/2020 07:00	0.6	11.9	2,169.9	0.4	1.9	1	1	1
01/16/2020 08:00	0.6	12.3	2,071.2	0.4	1.9	1	1	1
01/16/2020 09:00	0.6	12.8	1,966.5	0.4	1.9	1	1	1
01/16/2020 10:00	0.0	13.8	1,659.5	0.3	0.0	1	1	0
01/16/2020 11:00	0.0	13.8	1,574.7	0.1	0.0	1	1	0
01/16/2020 12:00	0.0	13.8	1,521.4	0.0	0.0	1	1	0
01/16/2020 13:00	0.0	13.8	1,656.8	0.0	0.0	1	1	0
01/16/2020 14:00	0.0	13.8	1,596.4	0.0	0.0	1	1	0
01/16/2020 15:00	0.0	13.8	1,727.3	0.0	0.0	1	1	1
01/16/2020 16:00	0.6	12.6	2,024.8	0.1	1.9	1	1	1
01/16/2020 17:00	0.6	12.5	2,037.7	0.3	1.9	1	1	1
01/16/2020 18:00	0.5	12.6	2,033.0	0.4	1.6	1	1	1
01/16/2020 19:00	0.5	12.6	2,049.0	0.4	1.6	1	1	1
01/16/2020 20:00	0.6	12.4	2,094.1	0.4	2.0	1	1	1
01/16/2020 21:00	0.6	12.4	2,099.0	0.4	2.0	1	1	1
01/16/2020 22:00	0.5	12.7	2,031.1	0.4	1.6	1	1	1
01/16/2020 23:00	0.5	12.7	2,037.4	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,945.9	0.3	32.9 #	24 #	24 #	19 #
Minimum:	0.0	11.9	1,521.4	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,169.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2020 00:00	0.5	12.7	2,045.2	0.4	1.6	1	1	1
01/17/2020 01:00	0.5	12.8	2,017.8	0.4	1.6	1	1	1
01/17/2020 02:00	0.5	12.8	2,041.4	0.4	1.7	1	1	1
01/17/2020 03:00	0.5	12.9	2,037.3	0.4	1.7	1	1	1
01/17/2020 04:00	0.5	12.8	2,050.8	0.4	1.7	1	1	1
01/17/2020 05:00	0.6	12.7	2,065.2	0.4	2.0	1	1	1
01/17/2020 06:00	0.6	12.1	2,208.2	0.4	2.0	1	1	1
01/17/2020 07:00	0.6	11.7	2,284.1	0.4	2.0	1	1	1
01/17/2020 08:00	0.5	12.7	2,060.1	0.4	1.7	1	1	1
01/17/2020 09:00	0.5	13.0	1,966.5	0.4	1.6	1	1	1
01/17/2020 10:00	0.0	13.8	1,682.9	0.3	0.0	1	1	0
01/17/2020 11:00	0.0	13.8	1,633.2	0.1	0.0	1	1	0
01/17/2020 12:00	0.0	13.8	1,664.0	0.0	0.0	1	1	0
01/17/2020 13:00	0.0	13.8	1,649.5	0.0	0.0	1	1	0
01/17/2020 14:00	0.0	13.8	1,623.2	0.0	0.0	1	1	0
01/17/2020 15:00	0.0	13.8	1,507.0	0.0	0.0	1	1	1
01/17/2020 16:00	0.6	12.8	2,003.8	0.1	2.0	1	1	1
01/17/2020 17:00	0.5	13.0	1,958.6	0.3	1.6	1	1	1
01/17/2020 18:00	0.5	13.0	1,967.6	0.4	1.6	1	1	1
01/17/2020 19:00	0.6	12.5	2,094.8	0.4	2.0	1	1	1
01/17/2020 20:00	0.6	12.3	2,127.6	0.4	2.0	1	1	1
01/17/2020 21:00	0.5	12.4	2,118.9	0.4	1.6	1	1	1
01/17/2020 22:00	0.5	12.5	2,096.4	0.4	1.6	1	1	1
01/17/2020 23:00	0.5	12.6	2,074.6	0.4	1.7	1	1	1
Average/Sum#:	0.4	12.9	1,957.4	0.3	31.7 #	24 #	24 #	19 #
Minimum:	0.0	11.7	1,507.0	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,284.1	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2020 00:00	0.5	12.7	2,054.8	0.4	1.7	1	1	1
01/18/2020 01:00	0.5	12.6	2,064.2	0.4	1.6	1	1	1
01/18/2020 02:00	0.4	12.8	2,036.9	0.4	1.3	1	1	1
01/18/2020 03:00	0.5	12.8	2,038.0	0.4	1.7	1	1	1
01/18/2020 04:00	0.4	12.8	2,038.1	0.3	1.3	1	1	1
01/18/2020 05:00	0.5	12.8	2,037.8	0.4	1.7	1	1	1
01/18/2020 06:00	0.5	12.8	2,044.1	0.4	1.7	1	1	1
01/18/2020 07:00	0.5	12.8	2,038.4	0.4	1.7	1	1	1
01/18/2020 08:00	0.5	13.1	1,983.9	0.4	1.7	1	1	1
01/18/2020 09:00	0.0	13.8	1,679.4	0.3	0.0	1	1	0
01/18/2020 10:00	0.0	13.8	1,635.0	0.1	0.0	1	1	0
01/18/2020 11:00	0.0	13.8	1,611.4	0.0	0.0	1	1	0
01/18/2020 12:00	0.0	13.8	1,628.4	0.0	0.0	1	1	0
01/18/2020 13:00	0.0	13.8	1,651.5	0.0	0.0	1	1	0
01/18/2020 14:00	0.0	13.8	1,617.0	0.0	0.0	1	1	0
01/18/2020 15:00	0.0	13.8	1,600.9	0.0	0.0	1	1	1
01/18/2020 16:00	0.6	12.8	2,012.6	0.1	2.0	1	1	1
01/18/2020 17:00	0.5	12.7	2,041.7	0.3	1.6	1	1	1
01/18/2020 18:00	0.5	13.0	1,957.5	0.4	1.6	1	1	1
01/18/2020 19:00	0.5	12.6	2,060.8	0.4	1.6	1	1	1
01/18/2020 20:00	0.5	12.3	2,119.2	0.4	1.6	1	1	1
01/18/2020 21:00	0.5	12.3	2,127.2	0.3	1.6	1	1	1
01/18/2020 22:00	0.5	12.2	2,140.7	0.3	1.6	1	1	1
01/18/2020 23:00	0.5	12.3	2,115.9	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.0	1,930.6	0.3	27.6 #	24 #	24 #	18 #
Minimum:	0.0	12.2	1,600.9	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,140.7	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/19/2020 00:00	0.5	12.5	2,029.0	0.3	1.6	1	1	1
01/19/2020 01:00	0.0	13.8	1,700.3	0.2	0.0	1	1	0
01/19/2020 02:00	0.0	13.8	1,552.0	0.1	0.0	1	1	0
01/19/2020 03:00	0.0	13.8	1,628.7	0.0	0.0	1	1	0
01/19/2020 04:00	0.0	13.8	1,620.8	0.0	0.0	1	1	0
01/19/2020 05:00	0.0	13.8	1,673.3	0.0	0.0	1	1	0
01/19/2020 06:00	0.0	13.8	1,692.8	0.0	0.0	1	1	0
01/19/2020 07:00	0.0	13.8	1,601.4	0.0	0.0	1	1	0
01/19/2020 08:00	0.0	13.8	1,555.3	0.0	0.0	1	1	0
01/19/2020 09:00	0.0	13.8	1,616.4	0.0	0.0	1	1	0
01/19/2020 10:00	0.0	13.8	1,565.8	0.0	0.0	1	1	0
01/19/2020 11:00	0.0	13.8	1,639.9	0.0	0.0	1	1	0
01/19/2020 12:00	0.0	13.8	1,658.6	0.0	0.0	1	1	0
01/19/2020 13:00	0.0	13.8	1,671.7	0.0	0.0	1	1	0
01/19/2020 14:00	0.0	13.8	1,582.0	0.0	0.0	1	1	0
01/19/2020 15:00	0.0	13.8	1,620.0	0.0	0.0	1	1	0
01/19/2020 16:00	0.0	13.8	1,614.5	0.0	0.0	1	1	1
01/19/2020 17:00	0.7	12.8	2,011.7	0.2	2.3	1	1	1
01/19/2020 18:00	0.6	12.6	2,046.3	0.3	2.0	1	1	1
01/19/2020 19:00	0.6	12.6	2,039.5	0.4	1.9	1	1	1
01/19/2020 20:00	0.6	12.3	2,105.5	0.4	1.9	1	1	1
01/19/2020 21:00	0.6	12.2	2,133.5	0.4	1.9	1	1	1
01/19/2020 22:00	0.6	12.2	2,130.1	0.4	1.9	1	1	1
01/19/2020 23:00	0.6	12.3	2,118.5	0.4	2.0	1	1	1
Average/Sum#:	0.2	13.3	1,775.3	0.1	15.5 #	24 #	24 #	9 #
Minimum:	0.0	12.2	1,552.0	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,133.5	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/20/2020 00:00	0.6	12.4	2,084.3	0.4	1.9	1	1	1
01/20/2020 01:00	0.6	12.6	2,047.3	0.4	2.0	1	1	1
01/20/2020 02:00	0.5	12.7	2,030.2	0.4	1.6	1	1	1
01/20/2020 03:00	0.5	12.7	2,036.9	0.4	1.6	1	1	1
01/20/2020 04:00	0.5	12.6	2,041.2	0.4	1.6	1	1	1
01/20/2020 05:00	0.6	12.5	2,053.5	0.4	1.9	1	1	1
01/20/2020 06:00	0.6	12.6	2,061.1	0.4	2.0	1	1	1
01/20/2020 07:00	0.6	12.3	2,123.4	0.4	2.0	1	1	1
01/20/2020 08:00	0.6	12.2	2,143.1	0.4	2.0	1	1	1
01/20/2020 09:00	0.5	12.2	2,121.3	0.4	1.6	1	1	1
01/20/2020 10:00	0.6	12.1	2,143.4	0.4	1.9	1	1	1
01/20/2020 11:00	0.5	12.2	2,117.0	0.3	1.6	1	1	1
01/20/2020 12:00	0.5	12.0	2,138.3	0.3	1.6	1	1	1
01/20/2020 13:00	0.5	12.1	2,132.1	0.3	1.6	1	1	1
01/20/2020 14:00	0.5	11.9	2,153.9	0.3	1.6	1	1	1
01/20/2020 15:00	0.5	12.1	2,116.9	0.3	1.6	1	1	1
01/20/2020 16:00	0.5	12.3	2,073.6	0.3	1.6	1	1	1
01/20/2020 17:00	0.6	12.1	2,126.3	0.3	1.9	1	1	1
01/20/2020 18:00	0.6	12.1	2,121.6	0.4	1.9	1	1	1
01/20/2020 19:00	0.6	12.2	2,120.1	0.4	1.9	1	1	1
01/20/2020 20:00	0.6	12.2	2,118.1	0.4	1.9	1	1	1
01/20/2020 21:00	0.6	12.2	2,118.3	0.4	1.9	1	1	1
01/20/2020 22:00	0.6	12.3	2,102.6	0.4	1.9	1	1	1
01/20/2020 23:00	0.6	12.4	2,071.0	0.4	1.9	1	1	1
Average/Sum#:	0.6	12.3	2,099.8	0.4	43.0 #	24 #	24 #	24 #
Minimum:	0.5	11.9	2,030.2	0.3	1.6	1	1	1
Maximum:	0.6	12.7	2,153.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/21/2020 00:00	0.5	12.6	2,045.0	0.4	1.6	1	1	1
01/21/2020 01:00	0.6	12.6	2,036.2	0.4	1.9	1	1	1
01/21/2020 02:00	0.6	12.6	2,041.0	0.4	1.9	1	1	1
01/21/2020 03:00	0.6	12.6	2,033.9	0.4	1.9	1	1	1
01/21/2020 04:00	0.6	12.6	2,038.6	0.4	1.9	1	1	1
01/21/2020 05:00	0.6	12.6	2,041.2	0.4	1.9	1	1	1
01/21/2020 06:00	0.6	12.7	2,010.3	0.4	1.9	1	1	1
01/21/2020 07:00	0.6	12.3	2,093.8	0.4	1.9	1	1	1
01/21/2020 08:00	0.6	12.5	2,059.5	0.4	1.9	1	1	1
01/21/2020 09:00	0.6	12.8	1,969.7	0.4	1.9	1	1	1
01/21/2020 10:00	0.0	13.8	1,674.5	0.3	0.0	1	1	0
01/21/2020 11:00	0.0	13.8	1,685.4	0.1	0.0	1	1	0
01/21/2020 12:00	0.0	13.8	1,650.7	0.0	0.0	1	1	0
01/21/2020 13:00	0.0	13.8	1,622.5	0.0	0.0	1	1	0
01/21/2020 14:00	0.0	13.8	1,632.0	0.0	0.0	1	1	0
01/21/2020 15:00	0.0	13.8	1,552.1	0.0	0.0	1	1	1
01/21/2020 16:00	0.7	12.5	2,028.0	0.2	2.2	1	1	1
01/21/2020 17:00	0.6	12.4	2,054.3	0.3	1.9	1	1	1
01/21/2020 18:00	0.6	12.4	2,048.2	0.4	1.9	1	1	1
01/21/2020 19:00	0.6	12.4	2,043.8	0.4	1.9	1	1	1
01/21/2020 20:00	0.5	12.4	2,039.7	0.4	1.6	1	1	1
01/21/2020 21:00	0.5	12.5	2,036.1	0.4	1.6	1	1	1
01/21/2020 22:00	0.6	12.3	2,072.6	0.4	1.9	1	1	1
01/21/2020 23:00	0.5	12.5	2,044.7	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,939.7	0.3	33.3 #	24 #	24 #	19 #
Minimum:	0.0	12.3	1,552.1	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,093.8	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/22/2020 00:00	0.4	13.1	1,828.3	0.4	1.2	1	1	1
01/22/2020 01:00	0.0	13.8	1,303.7	0.2	0.0	1	1	0
01/22/2020 02:00	0.0	13.8	1,365.4	0.1	0.0	1	1	0
01/22/2020 03:00	0.0	13.8	1,330.9	0.0	0.0	1	1	0
01/22/2020 04:00	0.0	13.7	1,515.3	0.0	0.0	1	1	0
01/22/2020 05:00	0.0	13.7	1,451.4	0.0	0.0	1	1	0
01/22/2020 06:00	0.0	13.7	1,585.6	0.0	0.0	1	1	0
01/22/2020 07:00	0.0	13.7	1,640.0	0.0	0.0	1	1	0
01/22/2020 08:00	0.0	13.8	1,483.2	0.0	0.0	1	1	0
01/22/2020 09:00	0.0	13.7	1,584.1	0.0	0.0	1	1	0
01/22/2020 10:00	0.0	13.7	1,613.9	0.0	0.0	1	1	0
01/22/2020 11:00	0.0	13.7	1,695.4	0.0	0.0	1	1	0
01/22/2020 12:00	0.0	13.8	1,694.9	0.0	0.0	1	1	0
01/22/2020 13:00	0.0	13.8	1,653.4	0.0	0.0	1	1	0
01/22/2020 14:00	0.0	13.8	1,632.4	0.0	0.0	1	1	0
01/22/2020 15:00	0.0	13.8	1,599.2	0.0	0.0	1	1	1
01/22/2020 16:00	0.6	12.6	2,029.5	0.1	1.9	1	1	1
01/22/2020 17:00	0.5	12.6	2,008.8	0.3	1.6	1	1	1
01/22/2020 18:00	0.6	12.1	2,126.3	0.4	1.9	1	1	1
01/22/2020 19:00	0.5	12.2	2,119.6	0.4	1.6	1	1	1
01/22/2020 20:00	0.5	12.5	2,049.9	0.4	1.6	1	1	1
01/22/2020 21:00	0.5	12.6	2,042.0	0.4	1.6	1	1	1
01/22/2020 22:00	0.5	12.6	2,048.9	0.4	1.6	1	1	1
01/22/2020 23:00	0.6	13.0	1,953.5	0.4	2.0	1	1	1
Average/Sum#:	0.2	13.3	1,723.2	0.1	15.0 #	24 #	24 #	10 #
Minimum:	0.0	12.1	1,303.7	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,126.3	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/23/2020 00:00	0.6	12.3	2,098.2	0.4	1.9	1	1	1
01/23/2020 01:00	0.6	12.3	2,098.0	0.4	1.9	1	1	1
01/23/2020 02:00	0.5	12.6	2,046.4	0.4	1.6	1	1	1
01/23/2020 03:00	0.5	12.6	2,046.2	0.4	1.6	1	1	1
01/23/2020 04:00	0.6	12.2	2,121.4	0.4	1.9	1	1	1
01/23/2020 05:00	0.5	12.6	2,062.0	0.4	1.6	1	1	1
01/23/2020 06:00	0.6	12.2	2,157.5	0.4	2.0	1	1	1
01/23/2020 07:00	0.5	12.4	2,113.5	0.4	1.6	1	1	1
01/23/2020 08:00	0.5	13.0	1,940.1	0.4	1.6	1	1	1
01/23/2020 09:00	0.0	13.7	1,671.7	0.2	0.0	1	1	0
01/23/2020 10:00	0.0	13.8	1,547.6	0.1	0.0	1	1	0
01/23/2020 11:00	0.0	13.8	1,603.8	0.0	0.0	1	1	0
01/23/2020 12:00	0.0	13.8	1,630.2	0.0	0.0	1	1	0
01/23/2020 13:00	0.0	13.8	1,660.7	0.0	0.0	1	1	0
01/23/2020 14:00	0.0	13.8	1,649.9	0.0	0.0	1	1	0
01/23/2020 15:00	0.0	13.8	1,616.6	0.0	0.0	1	1	0
01/23/2020 16:00	0.0	13.8	1,496.6	0.0	0.0	1	1	0
01/23/2020 17:00	0.5	12.9	1,919.5	0.1	1.6	1	1	1
01/23/2020 18:00	0.6	12.1	2,126.8	0.3	1.9	1	1	1
01/23/2020 19:00	0.6	12.1	2,124.2	0.4	1.9	1	1	1
01/23/2020 20:00	0.5	12.1	2,120.9	0.4	1.6	1	1	1
01/23/2020 21:00	0.5	12.2	2,108.3	0.3	1.6	1	1	1
01/23/2020 22:00	0.5	12.4	2,070.6	0.3	1.6	1	1	1
01/23/2020 23:00	0.6	13.0	1,934.3	0.3	1.9	1	1	1
Average/Sum#:	0.4	12.9	1,915.2	0.3	27.8 #	24 #	24 #	16 #
Minimum:	0.0	12.1	1,496.6	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,157.5	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2020 00:00	0.6	13.1	1,913.9	0.4	1.9	1	1	1
01/24/2020 01:00	0.0	13.7	1,630.9	0.3	0.0	1	1	0
01/24/2020 02:00	0.0	13.7	1,659.8	0.2	0.0	1	1	0
01/24/2020 03:00	0.0	13.7	1,693.1	0.0	0.0	1	1	0
01/24/2020 04:00	0.0	13.7	1,694.3	0.0	0.0	1	1	0
01/24/2020 05:00	0.0	13.7	1,593.1	0.0	0.0	1	1	0
01/24/2020 06:00	0.0	13.7	1,652.2	0.0	0.0	1	1	0
01/24/2020 07:00	0.0	13.7	1,647.7	0.0	0.0	1	1	0
01/24/2020 08:00	0.0	13.7	1,589.3	0.0	0.0	1	1	0
01/24/2020 09:00	0.0	13.7	1,661.4	0.0	0.0	1	1	0
01/24/2020 10:00	0.0	13.8	1,470.8	0.0	0.0	1	1	0
01/24/2020 11:00	0.0	13.7	1,653.5	0.0	0.0	1	1	0
01/24/2020 12:00	0.0	13.7	1,624.2	0.0	0.0	1	1	0
01/24/2020 13:00	0.0	13.7	1,666.2	0.0	0.0	1	1	0
01/24/2020 14:00	0.0	13.7	1,642.4	0.0	0.0	1	1	0
01/24/2020 15:00	0.0	13.8	1,548.8	0.0	0.0	1	1	0
01/24/2020 16:00	0.0	13.8	1,579.7	0.0	0.0	1	1	1
01/24/2020 17:00	0.7	12.6	2,030.5	0.2	2.3	1	1	1
01/24/2020 18:00	0.6	12.1	2,121.2	0.3	1.9	1	1	1
01/24/2020 19:00	0.6	12.1	2,117.7	0.4	1.9	1	1	1
01/24/2020 20:00	0.6	12.1	2,112.0	0.4	1.9	1	1	1
01/24/2020 21:00	0.5	12.3	2,083.6	0.4	1.6	1	1	1
01/24/2020 22:00	0.5	12.4	2,050.7	0.3	1.6	1	1	1
01/24/2020 23:00	5.9	14.0	1,267.4	0.0	7.2	1	0	1
Average/Sum#:	0.4	13.3	1,737.7	0.1	20.3 #	24 #	23 #	9 #
Minimum:	0.0	12.1	1,267.4	0.0	0.0	1	0	0
Maximum:	5.9	14.0	2,121.2	0.4	7.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	3 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/28/2020 03:00	79.4	17.6	453.6	0.0	89.3	1	1	0
01/28/2020 04:00	14.3	15.1	1,005.9	0.0	32.8	1	1	0
01/28/2020 05:00	0.0	13.7	1,596.0	0.0	0.0	1	1	0
01/28/2020 06:00	0.0	13.7	1,696.1	0.0	0.0	1	1	0
01/28/2020 07:00	0.0	13.8	1,604.8	0.0	0.0	1	1	0
01/28/2020 08:00	0.0	13.7	1,666.6	0.0	0.0	1	1	0
01/28/2020 09:00	0.0	13.7	1,679.4	0.0	0.0	1	1	0
01/28/2020 10:00	0.0	13.8	1,528.8	0.0	0.0	1	1	0
01/28/2020 11:00	0.0	13.7	1,609.3	0.0	0.0	1	1	0
01/28/2020 12:00	0.0	13.8	1,598.1	0.0	0.0	1	1	0
01/28/2020 13:00	0.0	13.8	1,655.0	0.0	0.0	1	1	0
01/28/2020 14:00	0.0	13.7	1,569.9	0.0	0.0	1	1	0
01/28/2020 15:00	0.0	13.8	1,559.2	0.0	0.0	1	1	0
01/28/2020 16:00	0.0	13.7	1,566.5	0.0	0.0	1	1	1
01/28/2020 17:00	0.7	12.6	2,021.2	0.2	2.3	1	1	1
01/28/2020 18:00	0.6	12.3	2,063.4	0.3	1.9	1	1	1
01/28/2020 19:00	0.5	12.3	2,085.0	0.4	1.6	1	1	1
01/28/2020 20:00	0.6	12.1	2,116.2	0.4	1.9	1	1	1
01/28/2020 21:00	0.5	12.1	2,119.1	0.3	1.6	1	1	1
01/28/2020 22:00	5.7	14.0	1,276.7	0.0	7.2	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.1	13.7	1,623.5	0.1	138.6 #	20 #	22 #	7 #
Minimum:	0.0	12.1	453.6	0.0	0.0	0	0	0
Maximum:	79.4	17.6	2,119.1	0.4	89.3	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	4 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/30/2020 02:00	51.3	17.5	460.1	0.0	61.4	1	1	0
01/30/2020 03:00	13.0	14.6	1,102.0	0.0	30.0	1	1	0
01/30/2020 04:00	0.0	13.7	1,635.4	0.0	0.0	1	1	0
01/30/2020 05:00	0.0	13.8	1,383.8	0.0	0.0	1	1	0
01/30/2020 06:00	0.4	13.2	1,845.9	0.1	1.3	1	1	1
01/30/2020 07:00	0.6	12.5	2,084.1	0.2	2.0	1	1	1
01/30/2020 08:00	0.6	13.0	1,925.2	0.4	1.9	1	1	1
01/30/2020 09:00	0.0	13.7	1,626.9	0.3	0.0	1	1	0
01/30/2020 10:00	0.0	13.8	1,629.6	0.1	0.0	1	1	0
01/30/2020 11:00	0.0	13.8	1,681.9	0.0	0.0	1	1	0
01/30/2020 12:00	0.0	13.8	1,494.1	0.0	0.0	1	1	0
01/30/2020 13:00	0.0	13.8	1,650.4	0.0	0.0	1	1	0
01/30/2020 14:00	0.0	13.8	1,550.0	0.0	0.0	1	1	0
01/30/2020 15:00	0.0	13.8	1,630.1	0.0	0.0	1	1	0
01/30/2020 16:00	0.0	13.8	1,511.7	0.0	0.0	1	1	0
01/30/2020 17:00	0.0	13.8	1,632.9	0.0	0.0	1	1	0
01/30/2020 18:00	0.0	13.8	1,708.9	0.0	0.0	1	1	1
01/30/2020 19:00	0.6	12.4	2,039.3	0.1	1.9	1	1	1
01/30/2020 20:00	0.5	11.9	2,143.9	0.2	1.6	1	1	1
01/30/2020 21:00	0.5	12.0	2,125.4	0.3	1.6	1	1	1
01/30/2020 22:00	0.5	12.3	2,073.7	0.3	1.6	1	1	1
01/30/2020 23:00	0.1	13.3	1,751.3	0.2	0.3	1	1	1
Average/Sum#:	3.1	13.6	1,667.6	0.1	103.6 #	22 #	24 #	9 #
Minimum:	0.0	11.9	460.1	0.0	0.0	0	1	0
Maximum:	51.3	17.5	2,143.9	0.4	61.4	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
01/31/2020 00:00	4.4	14.4	1,058.6	0.0	6.4	1	1	0
01/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
01/31/2020 05:00	21.2	16.7	519.4	0.0	24.2	1	1	0
01/31/2020 06:00	12.7	14.3	1,278.2	0.0	32.5	1	1	0
01/31/2020 07:00	0.0	13.7	1,591.9	0.0	0.0	1	1	0
01/31/2020 08:00	0.0	13.8	1,524.1	0.0	0.0	1	1	0
01/31/2020 09:00	0.0	13.8	1,617.4	0.0	0.0	1	1	0
01/31/2020 10:00	0.0	13.7	1,627.0	0.0	0.0	1	1	0
01/31/2020 11:00	0.0	13.8	1,637.6	0.0	0.0	1	1	0
01/31/2020 12:00	0.0	13.8	1,615.7	0.0	0.0	1	1	0
01/31/2020 13:00	0.0	13.8	1,692.2	0.0	0.0	1	1	0
01/31/2020 14:00	0.0	13.8	1,678.2	0.0	0.0	1	1	0
01/31/2020 15:00	0.0	13.8	1,662.5	0.0	0.0	1	1	0
01/31/2020 16:00	0.0	13.8	1,481.5	0.0	0.0	1	1	0
01/31/2020 17:00	0.0	13.8	1,672.6	0.0	0.0	1	1	0
01/31/2020 18:00	0.3	13.2	1,826.3	0.1	0.9	1	1	1
01/31/2020 19:00	0.6	12.6	2,009.4	0.2	1.9	1	1	1
01/31/2020 20:00	0.6	12.1	2,101.7	0.3	1.9	1	1	1
01/31/2020 21:00	0.6	12.1	2,103.7	0.4	1.9	1	1	1
01/31/2020 22:00	0.6	12.2	2,095.8	0.4	1.9	1	1	1
01/31/2020 23:00	6.1	14.0	1,284.9	0.0	7.5	1	0	1
Average/Sum#:	2.4	13.7	1,603.9	0.1	79.1 #	20 #	23 #	6 #
Minimum:	0.0	12.1	519.4	0.0	0.0	0	0	0
Maximum:	21.2	16.7	2,103.7	0.4	32.5	1	1	1
%SI	16.67	16.67	16.67	41.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/03/2020 03:00	103.8	19.8	175.5	0.0	28.4	1	1	0
02/03/2020 04:00	37.6	16.9	563.0	0.0	69.9	1	1	0
02/03/2020 05:00	8.8	14.2	1,373.4	0.0	23.8	1	1	0
02/03/2020 06:00	0.0	13.8	1,701.3	0.0	0.0	1	1	0
02/03/2020 07:00	0.0	13.8	1,615.6	0.0	0.0	1	1	0
02/03/2020 08:00	0.0	13.8	1,549.0	0.0	0.0	1	1	0
02/03/2020 09:00	0.0	13.8	1,477.8	0.0	0.0	1	1	0
02/03/2020 10:00	0.0	13.8	1,561.3	0.0	0.0	1	1	0
02/03/2020 11:00	0.0	13.8	1,694.0	0.0	0.0	1	1	0
02/03/2020 12:00	0.0	13.8	1,656.3	0.0	0.0	1	1	0
02/03/2020 13:00	0.0	13.8	1,641.1	0.0	0.0	1	1	0
02/03/2020 14:00	0.0	13.8	1,563.8	0.0	0.0	1	1	0
02/03/2020 15:00	0.0	13.8	1,654.5	0.0	0.0	1	1	0
02/03/2020 16:00	0.0	13.8	1,584.6	0.0	0.0	1	1	1
02/03/2020 17:00	0.6	12.6	2,058.6	0.1	2.0	1	1	1
02/03/2020 18:00	0.6	11.8	2,248.7	0.3	2.0	1	1	1
02/03/2020 19:00	0.5	11.5	2,287.2	0.4	1.6	1	1	1
02/03/2020 20:00	0.5	11.5	2,293.3	0.3	1.6	1	1	1
02/03/2020 21:00	0.5	12.2	2,154.0	0.3	1.6	1	1	1
02/03/2020 22:00	0.5	12.3	2,142.6	0.3	1.6	1	1	1
02/03/2020 23:00	0.5	12.5	2,108.8	0.3	1.7	1	1	1
Average/Sum#:	7.3	13.7	1,671.6	0.1	134.2 #	21 #	21 #	8 #
Minimum:	0.0	11.5	175.5	0.0	0.0	0	0	0
Maximum:	103.8	19.8	2,293.3	0.4	69.9	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2020 00:00	0.5	12.6	2,075.7	0.4	1.7	1	1	1
02/04/2020 01:00	0.4	12.8	2,052.1	0.4	1.3	1	1	1
02/04/2020 02:00	0.5	12.8	2,058.0	0.4	1.7	1	1	1
02/04/2020 03:00	0.5	12.8	2,051.7	0.4	1.7	1	1	1
02/04/2020 04:00	0.5	12.7	2,078.4	0.4	1.7	1	1	1
02/04/2020 05:00	0.6	12.3	2,113.3	0.4	1.9	1	1	1
02/04/2020 06:00	0.5	12.3	2,167.2	0.4	1.7	1	1	1
02/04/2020 07:00	0.5	12.1	2,188.3	0.3	1.6	1	1	1
02/04/2020 08:00	0.4	12.7	2,047.2	0.3	1.3	1	1	1
02/04/2020 09:00	0.0	13.8	1,755.6	0.2	0.0	1	1	0
02/04/2020 10:00	0.0	13.8	1,756.3	0.1	0.0	1	1	0
02/04/2020 11:00	0.0	13.8	1,754.5	0.0	0.0	1	1	0
02/04/2020 12:00	0.0	13.9	1,754.6	0.0	0.0	1	1	0
02/04/2020 13:00	0.0	13.9	1,755.0	0.0	0.0	1	1	0
02/04/2020 14:00	0.0	13.9	1,756.1	0.0	0.0	1	1	0
02/04/2020 15:00	0.0	13.9	1,755.5	0.0	0.0	1	1	0
02/04/2020 16:00	0.2	13.4	1,829.6	0.1	0.6	1	1	1
02/04/2020 17:00	0.5	12.8	2,010.6	0.2	1.6	1	1	1
02/04/2020 18:00	0.6	12.3	2,123.7	0.3	2.0	1	1	1
02/04/2020 19:00	0.5	11.9	2,202.7	0.4	1.6	1	1	1
02/04/2020 20:00	0.5	12.0	2,185.9	0.3	1.6	1	1	1
02/04/2020 21:00	0.5	11.7	2,262.8	0.3	1.6	1	1	1
02/04/2020 22:00	0.5	12.3	2,113.8	0.3	1.6	1	1	1
02/04/2020 23:00	0.5	12.4	2,093.8	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,997.6	0.2	26.8 #	24 #	24 #	17 #
Minimum:	0.0	11.7	1,754.5	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,262.8	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/05/2020 00:00	0.5	12.3	2,119.0	0.3	1.6	1	1	1
02/05/2020 01:00	0.5	12.5	2,085.4	0.3	1.6	1	1	1
02/05/2020 02:00	0.5	12.6	2,050.6	0.4	1.6	1	1	1
02/05/2020 03:00	0.5	12.6	2,048.4	0.4	1.6	1	1	1
02/05/2020 04:00	0.5	12.5	2,072.3	0.4	1.6	1	1	1
02/05/2020 05:00	0.6	12.9	1,990.5	0.4	2.0	1	1	1
02/05/2020 06:00	0.5	12.8	2,014.3	0.4	1.6	1	1	1
02/05/2020 07:00	0.5	11.9	2,208.8	0.4	1.6	1	1	1
02/05/2020 08:00	0.5	12.6	2,071.9	0.4	1.6	1	1	1
02/05/2020 09:00	0.5	13.0	1,945.8	0.4	1.6	1	1	1
02/05/2020 10:00	0.0	13.8	1,605.6	0.3	0.0	1	1	0
02/05/2020 11:00	0.0	13.8	1,608.1	0.1	0.0	1	1	0
02/05/2020 12:00	0.0	13.8	1,655.7	0.0	0.0	1	1	0
02/05/2020 13:00	0.0	13.8	1,663.4	0.0	0.0	1	1	0
02/05/2020 14:00	0.0	13.8	1,589.9	0.0	0.0	1	1	0
02/05/2020 15:00	0.0	13.8	1,673.9	0.0	0.0	1	1	0
02/05/2020 16:00	0.3	13.3	1,828.9	0.1	1.0	1	1	1
02/05/2020 17:00	0.6	12.8	1,971.3	0.2	1.9	1	1	1
02/05/2020 18:00	0.6	11.8	2,189.5	0.3	1.9	1	1	1
02/05/2020 19:00	0.6	12.1	2,132.6	0.4	1.9	1	1	1
02/05/2020 20:00	0.5	11.9	2,164.6	0.4	1.6	1	1	1
02/05/2020 21:00	0.6	12.2	2,106.4	0.4	1.9	1	1	1
02/05/2020 22:00	0.6	12.1	2,121.1	0.4	1.9	1	1	1
02/05/2020 23:00	0.6	12.4	2,057.4	0.4	1.9	1	1	1
Average/Sum#:	0.4	12.8	1,957.3	0.3	30.4 #	24 #	24 #	18 #
Minimum:	0.0	11.8	1,589.9	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,208.8	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/06/2020 00:00	0.6	12.6	2,029.0	0.4	1.9	1	1	1
02/06/2020 01:00	0.5	12.8	2,007.6	0.4	1.6	1	1	1
02/06/2020 02:00	0.5	12.8	2,003.9	0.4	1.6	1	1	1
02/06/2020 03:00	0.6	12.7	2,029.9	0.4	2.0	1	1	1
02/06/2020 04:00	0.5	12.8	2,015.7	0.4	1.6	1	1	1
02/06/2020 05:00	0.6	12.6	2,041.7	0.4	1.9	1	1	1
02/06/2020 06:00	0.7	12.5	2,074.6	0.4	2.3	1	1	1
02/06/2020 07:00	0.6	12.4	2,096.5	0.4	2.0	1	1	1
02/06/2020 08:00	0.5	13.2	1,923.0	0.4	1.6	1	1	1
02/06/2020 09:00	0.0	13.8	1,694.5	0.3	0.0	1	1	0
02/06/2020 10:00	0.0	13.8	1,681.5	0.1	0.0	1	1	0
02/06/2020 11:00	0.0	13.8	1,675.7	0.0	0.0	1	1	0
02/06/2020 12:00	0.0	13.8	1,589.7	0.0	0.0	1	1	0
02/06/2020 13:00	0.0	13.8	1,682.7	0.0	0.0	1	1	0
02/06/2020 14:00	0.0	13.8	1,658.3	0.0	0.0	1	1	0
02/06/2020 15:00	0.0	13.8	1,545.8	0.0	0.0	1	1	0
02/06/2020 16:00	0.0	13.8	1,563.9	0.0	0.0	1	1	1
02/06/2020 17:00	0.7	12.6	1,999.3	0.2	2.2	1	1	1
02/06/2020 18:00	0.7	12.1	2,104.1	0.3	2.2	1	1	1
02/06/2020 19:00	0.6	12.1	2,091.6	0.5	1.9	1	1	1
02/06/2020 20:00	0.6	12.2	2,114.7	0.4	1.9	1	1	1
02/06/2020 21:00	0.6	12.1	2,117.5	0.4	1.9	1	1	1
02/06/2020 22:00	0.6	12.2	2,093.6	0.4	1.9	1	1	1
02/06/2020 23:00	0.6	13.0	1,932.7	0.4	1.9	1	1	1
Average/Sum#:	0.4	13.0	1,907.0	0.3	30.4 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,545.8	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,117.5	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2020 00:00	0.6	13.1	1,911.3	0.4	1.9	1	1	1
02/07/2020 01:00	0.0	13.8	1,698.1	0.3	0.0	1	1	0
02/07/2020 02:00	0.0	13.8	1,561.1	0.2	0.0	1	1	0
02/07/2020 03:00	0.0	13.8	1,557.0	0.0	0.0	1	1	0
02/07/2020 04:00	0.0	13.8	1,526.6	0.0	0.0	1	1	0
02/07/2020 05:00	0.1	13.7	1,557.5	0.0	0.3	1	1	1
02/07/2020 06:00	0.8	12.7	2,025.3	0.2	2.6	1	1	1
02/07/2020 07:00	0.7	12.5	2,081.2	0.4	2.3	1	1	1
02/07/2020 08:00	0.6	13.0	1,939.4	0.5	1.9	1	1	1
02/07/2020 09:00	0.0	13.8	1,649.6	0.3	0.0	1	1	0
02/07/2020 10:00	0.0	13.8	1,660.6	0.1	0.0	1	1	0
02/07/2020 11:00	0.0	13.8	1,682.7	0.0	0.0	1	1	0
02/07/2020 12:00	0.0	13.8	1,685.2	0.0	0.0	1	1	0
02/07/2020 13:00	0.0	13.8	1,688.1	0.0	0.0	1	1	0
02/07/2020 14:00	0.0	13.8	1,660.8	0.0	0.0	1	1	0
02/07/2020 15:00	0.0	13.8	1,677.3	0.0	0.0	1	1	0
02/07/2020 16:00	0.0	13.8	1,588.9	0.0	0.0	1	1	1
02/07/2020 17:00	0.7	12.5	2,010.9	0.2	2.2	1	1	1
02/07/2020 18:00	0.6	12.0	2,112.5	0.3	1.9	1	1	1
02/07/2020 19:00	0.6	12.1	2,091.3	0.4	1.9	1	1	1
02/07/2020 20:00	0.6	12.1	2,106.1	0.4	1.9	1	1	1
02/07/2020 21:00	0.6	12.1	2,106.4	0.4	1.9	1	1	1
02/07/2020 22:00	0.6	12.4	2,051.2	0.4	1.9	1	1	1
02/07/2020 23:00	6.1	13.9	1,282.5	0.0	7.1	1	0	1
Average/Sum#:	0.5	13.2	1,788.0	0.2	27.8 #	24 #	23 #	13 #
Minimum:	0.0	12.0	1,282.5	0.0	0.0	1	0	0
Maximum:	6.1	13.9	2,112.5	0.5	7.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/10/2020 03:00	54.3	17.6	463.3	0.0	70.5	1	1	0
02/10/2020 04:00	30.0	15.7	707.0	0.0	53.9	1	1	0
02/10/2020 05:00	11.9	14.4	1,158.6	0.0	28.0	1	1	0
02/10/2020 06:00	0.0	13.8	1,696.7	0.0	0.0	1	1	0
02/10/2020 07:00	0.0	13.8	1,698.9	0.0	0.0	1	1	0
02/10/2020 08:00	0.0	13.9	1,651.9	0.0	0.0	1	1	0
02/10/2020 09:00	0.0	13.9	1,650.7	0.0	0.0	1	1	0
02/10/2020 10:00	0.0	13.9	1,636.9	0.0	0.0	1	1	0
02/10/2020 11:00	0.0	13.9	1,668.8	0.0	0.0	1	1	0
02/10/2020 12:00	0.0	13.9	1,666.9	0.0	0.0	1	1	0
02/10/2020 13:00	0.0	13.9	1,654.2	0.0	0.0	1	1	0
02/10/2020 14:00	0.0	13.9	1,648.3	0.0	0.0	1	1	0
02/10/2020 15:00	0.0	13.9	1,655.4	0.0	0.0	1	1	0
02/10/2020 16:00	0.0	13.9	1,685.7	0.0	0.0	1	1	0
02/10/2020 17:00	0.3	13.3	1,836.0	0.1	1.0	1	1	1
02/10/2020 18:00	0.6	12.5	2,049.4	0.2	1.9	1	1	1
02/10/2020 19:00	0.6	12.4	2,065.7	0.3	1.9	1	1	1
02/10/2020 20:00	0.6	12.2	2,109.4	0.4	1.9	1	1	1
02/10/2020 21:00	0.6	12.2	2,121.9	0.4	1.9	1	1	1
02/10/2020 22:00	0.6	12.3	2,101.9	0.4	1.9	1	1	1
02/10/2020 23:00	0.6	12.6	2,039.4	0.4	1.9	1	1	1
Average/Sum#:	4.8	13.7	1,665.1	0.1	164.8 #	21 #	22 #	7 #
Minimum:	0.0	12.2	463.3	0.0	0.0	0	0	0
Maximum:	54.3	17.6	2,121.9	0.4	70.5	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/11/2020 00:00	0.6	13.1	1,916.2	0.4	1.9	1	1	1
02/11/2020 01:00	0.0	13.8	1,566.8	0.3	0.0	1	1	0
02/11/2020 02:00	0.0	13.9	1,463.8	0.2	0.0	1	1	0
02/11/2020 03:00	0.0	13.9	1,532.0	0.0	0.0	1	1	0
02/11/2020 04:00	0.0	13.8	1,506.6	0.0	0.0	1	1	0
02/11/2020 05:00	0.0	13.8	1,635.4	0.0	0.0	1	1	0
02/11/2020 06:00	0.0	13.8	1,637.0	0.0	0.0	1	1	0
02/11/2020 07:00	0.0	13.8	1,569.1	0.0	0.0	1	1	0
02/11/2020 08:00	0.0	13.9	1,379.6	0.0	0.0	1	1	0
02/11/2020 09:00	0.0	13.9	1,549.0	0.0	0.0	1	1	0
02/11/2020 10:00	0.0	13.9	1,601.2	0.0	0.0	1	1	0
02/11/2020 11:00	0.0	13.9	1,621.6	0.0	0.0	1	1	0
02/11/2020 12:00	0.0	13.9	1,661.6	0.0	0.0	1	1	0
02/11/2020 13:00	0.0	13.9	1,679.3	0.0	0.0	1	1	0
02/11/2020 14:00	0.0	13.9	1,648.6	0.0	0.0	1	1	0
02/11/2020 15:00	0.0	13.9	1,530.3	0.0	0.0	1	1	0
02/11/2020 16:00	0.0	13.9	1,473.9	0.0	0.0	1	1	0
02/11/2020 17:00	0.0	13.9	1,623.8	0.0	0.0	1	1	0
02/11/2020 18:00	0.3	13.2	1,849.1	0.1	1.0	1	1	1
02/11/2020 19:00	0.6	11.9	2,163.5	0.2	1.9	1	1	1
02/11/2020 20:00	0.6	11.8	2,180.5	0.3	1.9	1	1	1
02/11/2020 21:00	0.5	11.7	2,176.4	0.4	1.6	1	1	1
02/11/2020 22:00	0.5	11.8	2,149.9	0.3	1.6	1	1	1
02/11/2020 23:00	0.5	12.1	2,086.9	0.3	1.6	1	1	1
Average/Sum#:	0.2	13.4	1,716.8	0.1	11.5 #	24 #	24 #	7 #
Minimum:	0.0	11.7	1,379.6	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,180.5	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/12/2020 00:00	0.4	12.8	1,923.8	0.3	1.3	1	1	1
02/12/2020 01:00	0.0	13.9	1,562.3	0.2	0.0	1	1	0
02/12/2020 02:00	0.0	13.8	1,541.9	0.1	0.0	1	1	0
02/12/2020 03:00	0.0	13.8	1,500.9	0.0	0.0	1	1	0
02/12/2020 04:00	0.0	13.8	1,647.0	0.0	0.0	1	1	0
02/12/2020 05:00	0.0	13.8	1,648.5	0.0	0.0	1	1	0
02/12/2020 06:00	0.0	13.8	1,613.5	0.0	0.0	1	1	0
02/12/2020 07:00	0.0	13.8	1,553.4	0.0	0.0	1	1	0
02/12/2020 08:00	0.0	13.8	1,690.5	0.0	0.0	1	1	0
02/12/2020 09:00	0.0	13.8	1,677.1	0.0	0.0	1	1	0
02/12/2020 10:00	0.0	13.8	1,668.5	0.0	0.0	1	1	0
02/12/2020 11:00	0.0	13.9	1,671.9	0.0	0.0	1	1	0
02/12/2020 12:00	0.0	13.9	1,636.8	0.0	0.0	1	1	0
02/12/2020 13:00	0.0	13.9	1,680.8	0.0	0.0	1	1	0
02/12/2020 14:00	0.0	13.9	1,619.0	0.0	0.0	1	1	0
02/12/2020 15:00	0.0	13.9	1,613.1	0.0	0.0	1	1	0
02/12/2020 16:00	0.0	13.9	1,405.6	0.0	0.0	1	1	0
02/12/2020 17:00	0.0	13.9	1,628.4	0.0	0.0	1	1	0
02/12/2020 18:00	0.0	13.9	1,699.1	0.0	0.0	1	1	1
02/12/2020 19:00	0.7	12.4	2,057.1	0.2	2.2	1	1	1
02/12/2020 20:00	0.6	11.7	2,196.0	0.3	1.9	1	1	1
02/12/2020 21:00	0.6	11.9	2,156.1	0.4	1.9	1	1	1
02/12/2020 22:00	0.6	12.0	2,142.0	0.4	1.9	1	1	1
02/12/2020 23:00	0.6	12.3	2,077.8	0.4	1.9	1	1	1
Average/Sum#:	0.1	13.4	1,733.8	0.1	11.1 #	24 #	24 #	7 #
Minimum:	0.0	11.7	1,405.6	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,196.0	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/13/2020 00:00	0.6	12.3	2,060.0	0.4	1.9	1	1	1
02/13/2020 01:00	0.6	12.5	2,025.5	0.4	1.9	1	1	1
02/13/2020 02:00	0.6	12.6	2,033.8	0.4	1.9	1	1	1
02/13/2020 03:00	0.6	12.5	2,037.4	0.4	1.9	1	1	1
02/13/2020 04:00	0.6	12.5	2,035.8	0.4	1.9	1	1	1
02/13/2020 05:00	0.7	12.5	2,044.6	0.4	2.3	1	1	1
02/13/2020 06:00	0.7	12.1	2,157.5	0.5	2.3	1	1	1
02/13/2020 07:00	0.6	12.3	2,088.9	0.5	1.9	1	1	1
02/13/2020 08:00	0.6	13.1	1,917.0	0.5	1.9	1	1	1
02/13/2020 09:00	0.0	13.8	1,657.3	0.3	0.0	1	1	0
02/13/2020 10:00	0.0	13.8	1,643.1	0.2	0.0	1	1	0
02/13/2020 11:00	0.0	13.8	1,649.8	0.0	0.0	1	1	0
02/13/2020 12:00	0.0	13.8	1,677.2	0.0	0.0	1	1	0
02/13/2020 13:00	0.0	13.8	1,616.3	0.0	0.0	1	1	0
02/13/2020 14:00	0.0	13.8	1,632.9	0.0	0.0	1	1	0
02/13/2020 15:00	0.0	13.8	1,583.2	0.0	0.0	1	1	0
02/13/2020 16:00	0.0	13.8	1,593.6	0.0	0.0	1	1	1
02/13/2020 17:00	0.8	12.4	2,045.2	0.2	2.5	1	1	1
02/13/2020 18:00	0.7	12.0	2,137.4	0.4	2.2	1	1	1
02/13/2020 19:00	0.7	11.9	2,154.5	0.5	2.2	1	1	1
02/13/2020 20:00	0.7	11.9	2,146.4	0.5	2.2	1	1	1
02/13/2020 21:00	0.7	12.0	2,143.3	0.5	2.2	1	1	1
02/13/2020 22:00	0.7	12.2	2,111.2	0.5	2.2	1	1	1
02/13/2020 23:00	0.6	12.2	2,101.8	0.5	1.9	1	1	1
Average/Sum#:	0.4	12.8	1,928.9	0.3	33.3 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,583.2	0.0	0.0	1	1	0
Maximum:	0.8	13.8	2,157.5	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/14/2020 00:00	3.6	13.6	1,577.0	0.0	10.0	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.6	13.6	1,577.0	0.0	10.0 #	1 #	0 #	1 #
Minimum:	3.6	13.6	1,577.0	0.0	10.0	0	0	0
Maximum:	3.6	13.6	1,577.0	0.0	10.0	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/17/2020 15:00	42.2	17.3	476.4	0.0	70.1	1	1	0
02/17/2020 16:00	13.3	14.8	1,059.7	0.0	30.5	1	1	0
02/17/2020 17:00	0.0	13.8	1,688.1	0.0	0.0	1	1	0
02/17/2020 18:00	0.0	13.8	1,736.9	0.0	0.0	1	1	1
02/17/2020 19:00	0.6	12.8	2,027.7	0.1	2.0	1	1	1
02/17/2020 20:00	0.6	11.9	2,156.5	0.3	1.9	1	1	1
02/17/2020 21:00	0.6	12.0	2,146.0	0.4	1.9	1	1	1
02/17/2020 22:00	0.5	12.1	2,124.4	0.4	1.6	1	1	1
02/17/2020 23:00	0.5	12.4	2,071.6	0.3	1.6	1	1	1
Average/Sum#:	6.5	13.4	1,720.8	0.3	109.6 #	9 #	11 #	6 #
Minimum:	0.0	11.9	476.4	0.1	0.0	0	0	0
Maximum:	42.2	17.3	2,156.5	0.4	70.1	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2020 00:00	0.5	12.4	2,066.5	0.3	1.6	1	1	1
02/18/2020 01:00	0.6	12.4	2,066.8	0.3	1.9	1	1	1
02/18/2020 02:00	0.5	12.6	2,040.1	0.4	1.6	1	1	1
02/18/2020 03:00	0.6	12.5	2,066.0	0.4	1.9	1	1	1
02/18/2020 04:00	0.6	12.5	2,068.7	0.4	2.0	1	1	1
02/18/2020 05:00	0.6	12.3	2,092.3	0.4	1.9	1	1	1
02/18/2020 06:00	0.6	12.2	2,133.3	0.4	1.9	1	1	1
02/18/2020 07:00	0.6	12.2	2,122.7	0.4	1.9	1	1	1
02/18/2020 08:00	0.5	12.4	2,064.2	0.4	1.6	1	1	1
02/18/2020 09:00	0.5	13.0	1,941.2	0.4	1.6	1	1	1
02/18/2020 10:00	0.7	13.1	1,937.3	0.4	2.3	1	1	1
02/18/2020 11:00	0.7	13.1	1,939.2	0.5	2.3	1	1	1
02/18/2020 12:00	0.7	13.0	1,938.0	0.5	2.3	1	1	1
02/18/2020 13:00	0.1	13.5	1,762.5	0.4	0.3	1	1	1
02/18/2020 14:00	0.0	13.8	1,407.4	0.2	0.0	1	1	0
02/18/2020 15:00	0.0	13.8	1,496.5	0.0	0.0	1	1	1
02/18/2020 16:00	0.7	12.7	2,010.6	0.2	2.3	1	1	1
02/18/2020 17:00	0.7	12.0	2,148.3	0.3	2.2	1	1	1
02/18/2020 18:00	0.6	11.9	2,168.1	0.5	1.9	1	1	1
02/18/2020 19:00	0.6	11.7	2,225.2	0.4	1.9	1	1	1
02/18/2020 20:00	0.6	11.6	2,244.2	0.4	1.9	1	1	1
02/18/2020 21:00	0.5	11.8	2,171.7	0.4	1.6	1	1	1
02/18/2020 22:00	0.5	12.0	2,124.2	0.3	1.6	1	1	1
02/18/2020 23:00	0.5	12.4	2,064.9	0.3	1.6	1	1	1
Average/Sum#:	0.5	12.5	2,012.5	0.4	40.1 #	24 #	24 #	23 #
Minimum:	0.0	11.6	1,407.4	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,244.2	0.5	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2020 00:00	0.6	11.7	2,249.6	0.3	1.9	1	1	1
02/19/2020 01:00	0.5	12.6	2,031.7	0.4	1.6	1	1	1
02/19/2020 02:00	0.5	13.1	1,922.5	0.4	1.6	1	1	1
02/19/2020 03:00	0.6	13.1	1,928.7	0.4	2.0	1	1	1
02/19/2020 04:00	0.6	12.4	2,077.8	0.4	1.9	1	1	1
02/19/2020 05:00	0.7	12.4	2,109.0	0.5	2.3	1	1	1
02/19/2020 06:00	0.6	12.3	2,116.3	0.4	1.9	1	1	1
02/19/2020 07:00	0.6	11.8	2,208.7	0.4	1.9	1	1	1
02/19/2020 08:00	0.5	12.8	1,979.8	0.4	1.6	1	1	1
02/19/2020 09:00	0.6	13.0	1,893.9	0.4	1.9	1	1	1
02/19/2020 10:00	0.9	13.1	1,904.0	0.5	2.9	1	1	1
02/19/2020 11:00	1.0	13.1	1,905.4	0.6	3.2	1	1	1
02/19/2020 12:00	1.0	13.1	1,902.5	0.8	3.2	1	1	1
02/19/2020 13:00	1.0	13.0	1,911.6	0.8	3.2	1	1	1
02/19/2020 14:00	0.9	13.0	1,914.0	0.7	2.9	1	1	1
02/19/2020 15:00	0.9	13.0	1,909.1	0.7	2.9	1	1	1
02/19/2020 16:00	0.7	12.5	2,010.2	0.6	2.2	1	1	1
02/19/2020 17:00	0.6	11.9	2,143.0	0.5	1.9	1	1	1
02/19/2020 18:00	0.6	11.8	2,145.6	0.4	1.9	1	1	1
02/19/2020 19:00	0.6	11.5	2,223.4	0.4	1.9	1	1	1
02/19/2020 20:00	0.6	11.6	2,201.3	0.4	1.9	1	1	1
02/19/2020 21:00	0.6	11.6	2,192.1	0.4	1.9	1	1	1
02/19/2020 22:00	0.6	12.3	2,054.7	0.4	1.9	1	1	1
02/19/2020 23:00	0.6	12.5	2,018.0	0.4	1.9	1	1	1
Average/Sum#:	0.7	12.5	2,039.7	0.5	52.4 #	24 #	24 #	24 #
Minimum:	0.5	11.5	1,893.9	0.3	1.6	1	1	1
Maximum:	1.0	13.1	2,249.6	0.8	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/20/2020 00:00	0.5	12.7	1,994.1	0.4	1.6	1	1	1
02/20/2020 01:00	0.6	12.6	2,011.8	0.4	1.9	1	1	1
02/20/2020 02:00	0.6	12.5	2,012.7	0.4	1.9	1	1	1
02/20/2020 03:00	0.6	12.5	2,011.7	0.4	1.9	1	1	1
02/20/2020 04:00	0.6	12.5	2,011.9	0.4	1.9	1	1	1
02/20/2020 05:00	0.6	12.5	2,026.7	0.4	1.9	1	1	1
02/20/2020 06:00	0.7	12.4	2,046.5	0.4	2.2	1	1	1
02/20/2020 07:00	0.6	12.4	2,052.1	0.4	1.9	1	1	1
02/20/2020 08:00	0.6	12.5	2,022.8	0.4	1.9	1	1	1
02/20/2020 09:00	0.5	13.0	1,907.2	0.4	1.6	1	1	1
02/20/2020 10:00	0.6	13.0	1,906.6	0.4	1.9	1	1	1
02/20/2020 11:00	0.6	13.0	1,906.0	0.4	1.9	1	1	1
02/20/2020 12:00	0.6	13.0	1,908.2	0.4	1.9	1	1	1
02/20/2020 13:00	0.6	13.0	1,907.3	0.4	1.9	1	1	1
02/20/2020 14:00	0.6	12.9	1,924.7	0.4	1.9	1	1	1
02/20/2020 15:00	0.6	12.7	1,969.4	0.4	1.9	1	1	1
02/20/2020 16:00	0.6	12.3	2,056.7	0.4	1.9	1	1	1
02/20/2020 17:00	0.6	12.2	2,066.3	0.4	1.9	1	1	1
02/20/2020 18:00	0.7	12.2	2,068.5	0.4	2.2	1	1	1
02/20/2020 19:00	0.7	12.1	2,089.9	0.5	2.2	1	1	1
02/20/2020 20:00	0.7	12.0	2,112.5	0.5	2.2	1	1	1
02/20/2020 21:00	0.6	12.0	2,127.1	0.5	1.9	1	1	1
02/20/2020 22:00	0.6	12.0	2,114.6	0.4	1.9	1	1	1
02/20/2020 23:00	0.6	12.4	2,042.5	0.4	1.9	1	1	1
Average/Sum#:	0.6	12.5	2,012.4	0.4	46.2 #	24 #	24 #	24 #
Minimum:	0.5	12.0	1,906.0	0.4	1.6	1	1	1
Maximum:	0.7	13.0	2,127.1	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2020 00:00	0.5	12.9	1,885.5	0.4	1.6	1	1	1
02/21/2020 01:00	0.0	13.8	1,507.6	0.3	0.0	1	1	0
02/21/2020 02:00	0.0	13.8	1,450.8	0.1	0.0	1	1	0
02/21/2020 03:00	0.0	13.8	1,534.4	0.0	0.0	1	1	0
02/21/2020 04:00	0.0	13.8	1,650.6	0.0	0.0	1	1	0
02/21/2020 05:00	0.0	13.8	1,556.8	0.0	0.0	1	1	0
02/21/2020 06:00	0.0	13.8	1,647.8	0.0	0.0	1	1	0
02/21/2020 07:00	0.0	13.7	1,610.7	0.0	0.0	1	1	0
02/21/2020 08:00	0.0	13.7	1,520.8	0.0	0.0	1	1	0
02/21/2020 09:00	0.0	13.7	1,643.6	0.0	0.0	1	1	0
02/21/2020 10:00	0.0	13.8	1,590.4	0.0	0.0	1	1	0
02/21/2020 11:00	0.0	13.8	1,579.0	0.0	0.0	1	1	0
02/21/2020 12:00	0.0	13.7	1,644.4	0.0	0.0	1	1	0
02/21/2020 13:00	0.0	13.7	1,642.8	0.0	0.0	1	1	0
02/21/2020 14:00	0.0	13.7	1,666.4	0.0	0.0	1	1	0
02/21/2020 15:00	0.0	13.7	1,654.8	0.0	0.0	1	1	0
02/21/2020 16:00	0.0	13.7	1,665.5	0.0	0.0	1	1	1
02/21/2020 17:00	0.7	12.6	1,969.1	0.2	2.2	1	1	1
02/21/2020 18:00	0.7	12.0	2,074.9	0.3	2.2	1	1	1
02/21/2020 19:00	0.6	12.2	2,045.6	0.5	1.9	1	1	1
02/21/2020 20:00	0.6	12.1	2,057.5	0.4	1.9	1	1	1
02/21/2020 21:00	0.6	12.3	2,033.5	0.4	1.9	1	1	1
02/21/2020 22:00	0.6	12.1	2,065.4	0.4	1.9	1	1	1
02/21/2020 23:00	6.6	13.9	1,250.8	0.0	7.5	1	0	1
Average/Sum#:	0.5	13.3	1,706.2	0.1	21.1 #	24 #	23 #	9 #
Minimum:	0.0	12.0	1,250.8	0.0	0.0	1	0	0
Maximum:	6.6	13.9	2,074.9	0.5	7.5	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	8 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/25/2020 14:00	55.2	17.4	455.6	0.0	63.6	1	1	0
02/25/2020 15:00	19.1	15.3	804.4	0.0	36.2	1	1	0
02/25/2020 16:00	0.0	13.8	1,602.6	0.0	0.0	1	1	0
02/25/2020 17:00	0.0	13.8	1,522.9	0.0	0.0	1	1	1
02/25/2020 18:00	0.6	12.7	1,961.2	0.1	1.9	1	1	1
02/25/2020 19:00	0.6	11.9	2,107.0	0.3	1.9	1	1	1
02/25/2020 20:00	0.6	11.8	2,141.5	0.4	1.9	1	1	1
02/25/2020 21:00	0.6	11.9	2,122.5	0.4	1.9	1	1	1
02/25/2020 22:00	0.6	11.9	2,115.1	0.4	1.9	1	1	1
02/25/2020 23:00	0.6	12.0	2,106.7	0.4	1.9	1	1	1
Average/Sum#:	7.8	13.3	1,694.0	0.3	111.2 #	10 #	24 #	7 #
Minimum:	0.0	11.8	455.6	0.1	0.0	0	1	0
Maximum:	55.2	17.4	2,141.5	0.4	63.6	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2020 00:00	0.6	12.4	2,020.7	0.4	1.9	1	1	1
02/26/2020 01:00	0.6	12.3	2,021.8	0.4	1.9	1	1	1
02/26/2020 02:00	0.6	12.3	2,020.8	0.4	1.9	1	1	1
02/26/2020 03:00	0.6	12.4	2,016.4	0.4	1.9	1	1	1
02/26/2020 04:00	0.6	12.5	2,013.9	0.4	1.9	1	1	1
02/26/2020 05:00	0.6	12.5	2,005.6	0.4	1.9	1	1	1
02/26/2020 06:00	0.6	12.6	2,000.6	0.4	1.9	1	1	1
02/26/2020 07:00	0.5	12.7	1,987.0	0.4	1.6	1	1	1
02/26/2020 08:00	6.2	14.2	1,195.8	0.0	6.9	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.2	12.7	1,920.3	0.4	21.8 #	9 #	15 #	9 #
Minimum:	0.5	12.3	1,195.8	0.4	1.6	0	0	0
Maximum:	6.2	14.2	2,021.8	0.4	6.9	1	1	1
%SI	62.50	62.50	62.50	66.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
02/27/2020 02:00	38.8	17.8	412.9	0.0	37.6	1	1	0
02/27/2020 03:00	20.8	15.0	954.0	0.0	44.4	1	1	0
02/27/2020 04:00	0.0	13.7	1,724.7	0.0	0.0	1	1	0
02/27/2020 05:00	0.0	13.7	1,726.4	0.0	0.0	1	1	0
02/27/2020 06:00	0.0	13.7	1,720.7	0.0	0.0	1	1	0
02/27/2020 07:00	0.0	13.7	1,725.1	0.0	0.0	1	1	0
02/27/2020 08:00	0.0	13.7	1,722.2	0.0	0.0	1	1	0
02/27/2020 09:00	0.0	13.7	1,726.6	0.0	0.0	1	1	0
02/27/2020 10:00	0.0	13.7	1,727.3	0.0	0.0	1	1	0
02/27/2020 11:00	0.0	13.7	1,723.8	0.0	0.0	1	1	0
02/27/2020 12:00	0.0	13.7	1,706.6	0.0	0.0	1	1	0
02/27/2020 13:00	0.0	13.7	1,656.0	0.0	0.0	1	1	0
02/27/2020 14:00	0.0	13.7	1,645.9	0.0	0.0	1	1	0
02/27/2020 15:00	0.0	13.7	1,633.4	0.0	0.0	1	1	0
02/27/2020 16:00	0.4	13.1	1,809.7	0.1	1.2	1	1	1
02/27/2020 17:00	0.7	12.2	2,033.9	0.3	2.2	1	1	1
02/27/2020 18:00	0.7	12.2	2,035.4	0.4	2.2	1	1	1
02/27/2020 19:00	0.7	12.2	2,038.8	0.5	2.2	1	1	1
02/27/2020 20:00	0.7	12.1	2,078.5	0.5	2.2	1	1	1
02/27/2020 21:00	0.7	12.0	2,080.8	0.5	2.2	1	1	1
02/27/2020 22:00	0.7	12.0	2,085.8	0.5	2.2	1	1	1
02/27/2020 23:00	0.6	12.5	1,993.6	0.5	1.9	1	1	1
Average/Sum#:	2.9	13.4	1,725.6	0.2	98.3 #	22 #	24 #	8 #
Minimum:	0.0	12.0	412.9	0.0	0.0	0	1	0
Maximum:	38.8	17.8	2,085.8	0.5	44.4	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/28/2020 00:00	0.6	13.0	1,887.0	0.4	1.9	1	1	1
02/28/2020 01:00	0.0	13.7	1,557.1	0.3	0.0	1	1	0
02/28/2020 02:00	0.0	13.7	1,468.7	0.1	0.0	1	1	0
02/28/2020 03:00	0.0	13.7	1,493.7	0.0	0.0	1	1	0
02/28/2020 04:00	0.0	13.7	1,487.3	0.0	0.0	1	1	0
02/28/2020 05:00	0.0	13.7	1,616.7	0.0	0.0	1	1	0
02/28/2020 06:00	0.0	13.7	1,654.1	0.0	0.0	1	1	0
02/28/2020 07:00	0.0	13.7	1,614.9	0.0	0.0	1	1	0
02/28/2020 08:00	0.0	13.7	1,520.5	0.0	0.0	1	1	0
02/28/2020 09:00	0.0	13.7	1,506.4	0.0	0.0	1	1	0
02/28/2020 10:00	0.0	13.8	1,450.9	0.0	0.0	1	1	0
02/28/2020 11:00	0.0	13.8	1,484.2	0.0	0.0	1	1	0
02/28/2020 12:00	0.0	13.8	1,544.1	0.0	0.0	1	1	0
02/28/2020 13:00	0.0	13.8	1,577.6	0.0	0.0	1	1	0
02/28/2020 14:00	0.0	13.8	1,423.0	0.0	0.0	1	1	0
02/28/2020 15:00	0.0	13.7	1,534.4	0.0	0.0	1	1	1
02/28/2020 16:00	0.8	12.3	1,998.1	0.2	2.5	1	1	1
02/28/2020 17:00	0.8	12.1	2,028.7	0.3	2.4	1	1	1
02/28/2020 18:00	0.7	12.2	2,014.6	0.5	2.1	1	1	1
02/28/2020 19:00	0.8	12.2	2,024.8	0.5	2.5	1	1	1
02/28/2020 20:00	0.7	12.3	2,006.3	0.5	2.2	1	1	1
02/28/2020 21:00	0.8	12.2	2,038.9	0.5	2.5	1	1	1
02/28/2020 22:00	0.7	12.3	2,014.9	0.5	2.2	1	1	1
02/28/2020 23:00	6.4	14.0	1,212.1	0.0	7.7	1	0	1
Average/Sum#:	0.5	13.3	1,673.3	0.2	26.0 #	24 #	23 #	10 #
Minimum:	0.0	12.1	1,212.1	0.0	0.0	1	0	0
Maximum:	6.4	14.0	2,038.9	0.5	7.7	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/03/2020 15:00	54.7	17.5	437.3	0.0	58.5	1	1	0
03/03/2020 16:00	14.6	15.4	820.8	0.0	28.8	1	1	0
03/03/2020 17:00	0.0	13.7	1,578.6	0.0	0.0	1	1	1
03/03/2020 18:00	0.6	12.0	2,074.2	0.0	1.8	1	1	1
03/03/2020 19:00	0.6	11.6	2,145.8	0.3	1.8	1	1	1
03/03/2020 20:00	0.6	11.6	2,146.2	0.4	1.8	1	1	1
03/03/2020 21:00	0.5	11.6	2,149.4	0.4	1.5	1	1	1
03/03/2020 22:00	0.5	11.8	2,115.9	0.3	1.5	1	1	1
03/03/2020 23:00	0.6	12.0	2,083.0	0.3	1.9	1	1	1
Average/Sum#:	8.1	13.0	1,727.9	0.3	97.6 #	9 #	11 #	7 #
Minimum:	0.0	11.6	437.3	0.3	0.0	0	0	0
Maximum:	54.7	17.5	2,149.4	0.4	58.5	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/04/2020 00:00	0.6	12.3	2,029.8	0.4	1.9	1	1	1
03/04/2020 01:00	0.6	12.3	2,018.3	0.4	1.9	1	1	1
03/04/2020 02:00	0.5	12.6	1,967.9	0.4	1.6	1	1	1
03/04/2020 03:00	0.5	12.7	1,963.5	0.4	1.6	1	1	1
03/04/2020 04:00	0.6	12.4	2,016.0	0.4	1.9	1	1	1
03/04/2020 05:00	0.6	12.4	2,014.7	0.4	1.9	1	1	1
03/04/2020 06:00	0.6	12.4	2,013.8	0.4	1.9	1	1	1
03/04/2020 07:00	0.6	12.4	2,002.8	0.4	1.9	1	1	1
03/04/2020 08:00	0.0	13.7	1,479.7	0.3	0.0	1	1	1
03/04/2020 09:00	0.0	13.8	1,353.7	0.1	0.0	1	1	0
03/04/2020 10:00	0.0	13.8	1,354.8	0.0	0.0	1	1	0
03/04/2020 11:00	0.0	13.8	1,549.6	0.0	0.0	1	1	0
03/04/2020 12:00	0.0	13.8	1,675.0	0.0	0.0	1	1	0
03/04/2020 13:00	0.0	13.8	1,511.4	0.0	0.0	1	1	0
03/04/2020 14:00	0.0	13.8	1,600.8	0.0	0.0	1	1	0
03/04/2020 15:00	0.0	13.8	1,577.7	0.0	0.0	1	1	0
03/04/2020 16:00	0.0	13.8	1,521.5	0.0	0.0	1	1	1
03/04/2020 17:00	0.7	12.3	2,009.6	0.2	2.2	1	1	1
03/04/2020 18:00	0.7	12.2	2,034.2	0.3	2.2	1	1	1
03/04/2020 19:00	0.7	12.2	2,030.5	0.5	2.2	1	1	1
03/04/2020 20:00	0.7	11.9	2,101.7	0.5	2.2	1	1	1
03/04/2020 21:00	0.7	11.8	2,112.9	0.5	2.1	1	1	1
03/04/2020 22:00	0.6	11.9	2,098.3	0.5	1.8	1	1	1
03/04/2020 23:00	0.6	12.2	2,041.8	0.4	1.9	1	1	1
Average/Sum#:	0.4	12.8	1,836.7	0.3	29.2 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,353.7	0.0	0.0	1	1	0
Maximum:	0.7	13.8	2,112.9	0.5	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2020 00:00	0.6	12.6	1,966.1	0.4	1.9	1	1	1
03/05/2020 01:00	0.6	12.6	1,952.8	0.4	1.9	1	1	1
03/05/2020 02:00	0.6	12.6	1,960.2	0.4	1.9	1	1	1
03/05/2020 03:00	0.6	12.6	1,960.5	0.4	1.9	1	1	1
03/05/2020 04:00	0.7	12.2	2,034.1	0.4	2.2	1	1	1
03/05/2020 05:00	0.7	12.2	2,034.5	0.5	2.2	1	1	1
03/05/2020 06:00	0.7	12.3	2,021.4	0.5	2.2	1	1	1
03/05/2020 07:00	0.6	12.6	1,959.5	0.5	1.9	1	1	1
03/05/2020 08:00	0.0	13.7	1,597.3	0.3	0.0	1	1	0
03/05/2020 09:00	0.0	13.7	1,662.5	0.1	0.0	1	1	0
03/05/2020 10:00	0.0	13.7	1,668.7	0.0	0.0	1	1	0
03/05/2020 11:00	0.0	13.7	1,657.3	0.0	0.0	1	1	0
03/05/2020 12:00	0.0	13.7	1,630.3	0.0	0.0	1	1	0
03/05/2020 13:00	0.0	13.7	1,666.1	0.0	0.0	1	1	0
03/05/2020 14:00	0.0	13.6	1,563.5	0.0	0.0	1	1	0
03/05/2020 15:00	0.0	13.7	1,497.7	0.0	0.0	1	1	0
03/05/2020 16:00	0.1	13.7	1,458.4	0.0	0.3	1	1	1
03/05/2020 17:00	0.8	12.3	1,979.7	0.2	2.4	1	1	1
03/05/2020 18:00	0.7	12.0	2,041.5	0.4	2.1	1	1	1
03/05/2020 19:00	0.7	12.1	2,040.7	0.5	2.1	1	1	1
03/05/2020 20:00	0.7	12.2	2,029.4	0.5	2.2	1	1	1
03/05/2020 21:00	0.7	12.1	2,059.0	0.5	2.2	1	1	1
03/05/2020 22:00	0.7	12.1	2,058.2	0.5	2.2	1	1	1
03/05/2020 23:00	0.7	12.5	1,965.0	0.5	2.2	1	1	1
Average/Sum#:	0.4	12.8	1,852.7	0.3	31.8 #	24 #	24 #	16 #
Minimum:	0.0	12.0	1,458.4	0.0	0.0	1	1	0
Maximum:	0.8	13.7	2,059.0	0.5	2.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/06/2020 00:00	0.8	12.2	2,036.4	0.5	2.5	1	1	1
03/06/2020 01:00	0.7	12.2	2,039.3	0.5	2.2	1	1	1
03/06/2020 02:00	0.7	12.5	1,968.2	0.5	2.2	1	1	1
03/06/2020 03:00	0.7	12.4	2,000.8	0.5	2.2	1	1	1
03/06/2020 04:00	0.8	12.3	2,013.8	0.5	2.5	1	1	1
03/06/2020 05:00	0.8	12.2	2,032.9	0.5	2.5	1	1	1
03/06/2020 06:00	0.8	12.3	2,023.9	0.5	2.5	1	1	1
03/06/2020 07:00	0.7	12.4	2,004.9	0.5	2.2	1	1	1
03/06/2020 08:00	0.7	12.7	1,919.4	0.5	2.2	1	1	1
03/06/2020 09:00	0.0	13.7	1,604.2	0.3	0.0	1	1	0
03/06/2020 10:00	0.0	13.7	1,647.6	0.2	0.0	1	1	0
03/06/2020 11:00	0.0	13.7	1,663.3	0.0	0.0	1	1	0
03/06/2020 12:00	0.5	13.7	1,633.4	0.1	1.5	1	1	0
03/06/2020 13:00	0.0	13.7	1,655.1	0.1	0.0	1	1	0
03/06/2020 14:00	0.0	13.7	1,619.0	0.1	0.0	1	1	0
03/06/2020 15:00	0.0	13.7	1,601.2	0.0	0.0	1	1	0
03/06/2020 16:00	0.0	13.7	1,497.5	0.0	0.0	1	1	1
03/06/2020 17:00	0.8	12.4	1,977.0	0.2	2.5	1	1	1
03/06/2020 18:00	0.7	12.2	2,017.0	0.4	2.1	1	1	1
03/06/2020 19:00	0.7	12.2	2,021.3	0.5	2.1	1	1	1
03/06/2020 20:00	0.7	11.9	2,080.6	0.5	2.1	1	1	1
03/06/2020 21:00	0.6	11.8	2,105.2	0.5	1.8	1	1	1
03/06/2020 22:00	0.6	12.0	2,069.3	0.4	1.8	1	1	1
03/06/2020 23:00	0.7	12.1	2,033.4	0.4	2.1	1	1	1
Average/Sum#:	0.5	12.7	1,886.0	0.3	37.0 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,497.5	0.0	0.0	1	1	0
Maximum:	0.8	13.7	2,105.2	0.5	2.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/07/2020 00:00	6.6	13.9	1,233.3	0.0	7.4	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.6	13.9	1,233.3	0.0	7.4 #	1 #	0 #	1 #
Minimum:	6.6	13.9	1,233.3	0.0	7.4	0	0	0
Maximum:	6.6	13.9	1,233.3	0.0	7.4	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	1 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/09/2020 01:00	126.7	18.6	326.1	0.0	47.4	1	1	0
03/09/2020 02:00	35.6	16.3	622.9	0.0	63.7	1	1	0
03/09/2020 03:00	0.4	13.7	1,466.3	0.0	1.1	1	1	0
03/09/2020 04:00	0.0	13.7	1,559.0	0.0	0.0	1	1	1
03/09/2020 05:00	0.5	12.6	1,997.4	0.0	1.6	1	1	1
03/09/2020 06:00	0.5	12.0	2,130.1	0.2	1.6	1	1	1
03/09/2020 07:00	0.4	12.0	2,111.7	0.3	1.3	1	1	1
03/09/2020 08:00	0.4	12.0	2,100.6	0.3	1.2	1	1	1
03/09/2020 09:00	0.0	13.5	1,646.5	0.2	0.0	1	1	1
03/09/2020 10:00	0.0	13.7	1,567.7	0.1	0.0	1	1	0
03/09/2020 11:00	0.0	13.7	1,541.6	0.0	0.0	1	1	0
03/09/2020 12:00	0.0	13.7	1,665.3	0.0	0.0	1	1	0
03/09/2020 13:00	0.0	13.7	1,668.1	0.0	0.0	1	1	0
03/09/2020 14:00	0.0	13.7	1,664.9	0.0	0.0	1	1	0
03/09/2020 15:00	0.0	13.7	1,639.8	0.0	0.0	1	1	0
03/09/2020 16:00	0.0	13.7	1,657.1	0.0	0.0	1	1	1
03/09/2020 17:00	0.7	12.4	1,999.7	0.2	2.2	1	1	1
03/09/2020 18:00	0.7	11.7	2,141.2	0.3	2.2	1	1	1
03/09/2020 19:00	0.7	11.7	2,146.6	0.4	2.2	1	1	1
03/09/2020 20:00	0.6	11.9	2,111.3	0.4	1.9	1	1	1
03/09/2020 21:00	0.6	11.8	2,114.6	0.4	1.8	1	1	1
03/09/2020 22:00	0.6	11.8	2,114.0	0.4	1.8	1	1	1
03/09/2020 23:00	0.6	11.8	2,113.7	0.4	1.8	1	1	1
Average/Sum#:	7.3	13.2	1,743.7	0.2	131.8 #	23 #	24 #	14 #
Minimum:	0.0	11.7	326.1	0.0	0.0	0	1	0
Maximum:	126.7	18.6	2,146.6	0.4	63.7	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2020 00:00	0.6	11.8	2,115.8	0.4	1.8	1	1	1
03/10/2020 01:00	0.6	11.9	2,105.0	0.4	1.9	1	1	1
03/10/2020 02:00	0.6	11.9	2,094.0	0.4	1.8	1	1	1
03/10/2020 03:00	0.6	12.2	2,048.8	0.4	1.9	1	1	1
03/10/2020 04:00	0.6	12.2	2,051.9	0.4	1.9	1	1	1
03/10/2020 05:00	0.7	11.6	2,145.4	0.4	2.1	1	1	1
03/10/2020 06:00	0.6	11.4	2,215.2	0.4	1.8	1	1	1
03/10/2020 07:00	0.6	11.5	2,176.7	0.4	1.8	1	1	1
03/10/2020 08:00	0.0	0.0	2,150.2	0.0	0.0	1	1	1
03/10/2020 09:00	0.5	12.3	2,099.1	0.0	1.6	1	1	1
03/10/2020 10:00	0.4	12.4	2,063.7	0.0	1.3	1	1	1
03/10/2020 11:00	0.4	12.2	2,093.0	0.3	1.3	1	1	1
03/10/2020 12:00	0.4	12.1	2,114.6	0.3	1.3	1	1	1
03/10/2020 13:00	0.4	12.1	2,099.9	0.3	1.3	1	1	1
03/10/2020 14:00	0.3	12.0	2,114.1	0.3	0.9	1	1	1
03/10/2020 15:00	0.3	12.2	2,089.1	0.2	1.0	1	1	1
03/10/2020 16:00	0.3	12.1	2,090.0	0.2	0.9	1	1	1
03/10/2020 17:00	0.3	12.3	2,060.3	0.2	0.9	1	1	1
03/10/2020 18:00	0.3	11.8	2,159.1	0.2	0.9	1	1	1
03/10/2020 19:00	0.3	11.6	2,194.4	0.2	0.9	1	1	1
03/10/2020 20:00	0.3	11.7	2,192.6	0.2	0.9	1	1	1
03/10/2020 21:00	0.3	12.0	2,115.1	0.2	0.9	1	1	1
03/10/2020 22:00	0.3	12.2	2,099.5	0.2	1.0	1	1	1
03/10/2020 23:00	0.3	12.2	2,072.5	0.2	0.9	1	1	1
Average/Sum#:	0.4	12.0	2,115.0	0.3	31.0 #	24 #	24 #	24 #
Minimum:	0.3	11.4	2,048.8	0.2	0.9	1	1	1
Maximum:	0.7	12.4	2,215.2	0.4	2.1	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/11/2020 00:00	0.3	12.6	2,007.3	0.2	1.0	1	1	1
03/11/2020 01:00	0.4	12.6	2,001.4	0.2	1.3	1	1	1
03/11/2020 02:00	0.4	12.5	2,014.6	0.3	1.3	1	1	1
03/11/2020 03:00	0.5	12.5	2,017.7	0.3	1.6	1	1	1
03/11/2020 04:00	0.5	12.5	2,046.2	0.4	1.6	1	1	1
03/11/2020 05:00	0.5	12.0	2,104.5	0.4	1.6	1	1	1
03/11/2020 06:00	0.4	11.7	2,189.2	0.3	1.3	1	1	1
03/11/2020 07:00	0.4	12.2	2,105.0	0.3	1.3	1	1	1
03/11/2020 08:00	0.4	12.2	2,099.4	0.3	1.3	1	1	1
03/11/2020 09:00	0.0	13.7	1,684.2	0.2	0.0	1	1	1
03/11/2020 10:00	0.0	13.9	1,618.7	0.1	0.0	1	1	0
03/11/2020 11:00	0.0	13.9	1,533.3	0.0	0.0	1	1	0
03/11/2020 12:00	0.0	14.0	1,567.8	0.0	0.0	1	1	0
03/11/2020 13:00	0.0	14.0	1,654.9	0.0	0.0	1	1	0
03/11/2020 14:00	0.0	14.0	1,621.7	0.0	0.0	1	1	0
03/11/2020 15:00	0.0	14.0	1,529.6	0.0	0.0	1	1	0
03/11/2020 16:00	0.0	14.1	1,323.4	0.0	0.0	1	1	0
03/11/2020 17:00	0.0	14.0	1,609.1	0.0	0.0	1	1	0
03/11/2020 18:00	0.0	13.9	1,675.6	0.0	0.0	1	1	1
03/11/2020 19:00	0.6	12.6	2,002.8	0.1	1.9	1	1	1
03/11/2020 20:00	0.5	11.7	2,170.1	0.2	1.6	1	1	1
03/11/2020 21:00	0.5	12.0	2,114.6	0.3	1.6	1	1	1
03/11/2020 22:00	0.5	12.3	2,054.4	0.3	1.6	1	1	1
03/11/2020 23:00	0.5	12.2	2,098.7	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.0	1,868.5	0.2	20.6 #	24 #	24 #	16 #
Minimum:	0.0	11.7	1,323.4	0.0	0.0	1	1	0
Maximum:	0.6	14.1	2,189.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/12/2020 00:00	0.4	12.3	2,055.5	0.3	1.3	1	1	1
03/12/2020 01:00	0.4	12.5	2,022.4	0.3	1.3	1	1	1
03/12/2020 02:00	0.4	12.7	1,963.5	0.3	1.3	1	1	1
03/12/2020 03:00	0.4	12.5	2,018.6	0.3	1.3	1	1	1
03/12/2020 04:00	0.4	12.3	2,056.9	0.3	1.3	1	1	1
03/12/2020 05:00	0.4	12.0	2,072.2	0.3	1.2	1	1	1
03/12/2020 06:00	0.4	11.6	2,194.7	0.3	1.2	1	1	1
03/12/2020 07:00	0.4	11.8	2,182.0	0.3	1.3	1	1	1
03/12/2020 08:00	0.3	12.2	2,052.2	0.3	0.9	1	1	1
03/12/2020 09:00	0.0	13.9	1,636.4	0.2	0.0	1	1	0
03/12/2020 10:00	0.0	13.9	1,646.8	0.1	0.0	1	1	0
03/12/2020 11:00	0.0	14.0	1,630.8	0.0	0.0	1	1	0
03/12/2020 12:00	0.0	14.0	1,664.1	0.0	0.0	1	1	0
03/12/2020 13:00	0.0	14.0	1,557.2	0.0	0.0	1	1	0
03/12/2020 14:00	0.0	13.9	1,643.3	0.0	0.0	1	1	0
03/12/2020 15:00	0.1	13.3	1,804.7	0.0	0.3	1	1	1
03/12/2020 16:00	0.4	12.1	2,081.5	0.1	1.2	1	1	1
03/12/2020 17:00	0.4	11.8	2,146.6	0.2	1.2	1	1	1
03/12/2020 18:00	0.3	11.6	2,186.7	0.3	0.9	1	1	1
03/12/2020 19:00	0.3	11.6	2,196.4	0.2	0.9	1	1	1
03/12/2020 20:00	0.3	12.2	2,077.6	0.2	0.9	1	1	1
03/12/2020 21:00	0.3	11.7	2,170.3	0.2	0.9	1	1	1
03/12/2020 22:00	0.3	11.6	2,190.6	0.2	0.9	1	1	1
03/12/2020 23:00	0.3	11.7	2,182.4	0.2	0.9	1	1	1
Average/Sum#:	0.3	12.6	1,976.4	0.2	19.2 #	24 #	24 #	18 #
Minimum:	0.0	11.6	1,557.2	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,196.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/13/2020 00:00	0.3	11.7	2,175.0	0.2	0.9	1	1	1
03/13/2020 01:00	0.4	11.8	2,173.7	0.2	1.3	1	1	1
03/13/2020 02:00	0.4	11.8	2,161.9	0.3	1.3	1	1	1
03/13/2020 03:00	0.4	11.8	2,157.8	0.3	1.3	1	1	1
03/13/2020 04:00	0.4	12.1	2,111.2	0.3	1.3	1	1	1
03/13/2020 05:00	0.4	11.6	2,189.2	0.3	1.2	1	1	1
03/13/2020 06:00	0.4	11.8	2,165.8	0.3	1.3	1	1	1
03/13/2020 07:00	0.4	12.0	2,142.1	0.3	1.3	1	1	1
03/13/2020 08:00	0.4	11.9	2,148.7	0.3	1.3	1	1	1
03/13/2020 09:00	0.0	13.6	1,689.9	0.2	0.0	1	1	1
03/13/2020 10:00	0.0	14.0	1,572.2	0.1	0.0	1	1	0
03/13/2020 11:00	0.0	14.0	1,606.7	0.0	0.0	1	1	0
03/13/2020 12:00	0.0	14.0	1,652.9	0.0	0.0	1	1	0
03/13/2020 13:00	0.0	14.0	1,603.7	0.0	0.0	1	1	0
03/13/2020 14:00	0.0	13.9	1,638.9	0.0	0.0	1	1	0
03/13/2020 15:00	0.0	14.0	1,645.5	0.0	0.0	1	1	0
03/13/2020 16:00	0.0	14.0	1,660.3	0.0	0.0	1	1	0
03/13/2020 17:00	0.2	13.3	1,791.3	0.1	0.6	1	1	1
03/13/2020 18:00	0.5	12.4	2,029.0	0.2	1.6	1	1	1
03/13/2020 19:00	0.4	11.7	2,173.5	0.3	1.2	1	1	1
03/13/2020 20:00	0.4	11.6	2,194.0	0.3	1.2	1	1	1
03/13/2020 21:00	0.4	12.0	2,125.1	0.3	1.3	1	1	1
03/13/2020 22:00	0.4	12.2	2,082.7	0.3	1.3	1	1	1
03/13/2020 23:00	0.4	12.4	2,035.7	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.7	1,955.3	0.2	19.7 #	24 #	24 #	17 #
Minimum:	0.0	11.6	1,572.2	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,194.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2020 00:00	0.4	12.1	2,102.7	0.3	1.3	1	1	1
03/14/2020 01:00	0.4	12.0	2,111.9	0.3	1.3	1	1	1
03/14/2020 02:00	0.4	12.1	2,104.4	0.3	1.3	1	1	1
03/14/2020 03:00	0.4	12.1	2,099.9	0.3	1.3	1	1	1
03/14/2020 04:00	0.4	12.5	2,028.5	0.3	1.3	1	1	1
03/14/2020 05:00	0.5	12.2	2,071.7	0.3	1.6	1	1	1
03/14/2020 06:00	0.5	12.1	2,112.3	0.3	1.6	1	1	1
03/14/2020 07:00	0.4	12.3	2,065.5	0.3	1.3	1	1	1
03/14/2020 08:00	0.0	14.0	1,723.4	0.2	0.0	1	1	0
03/14/2020 09:00	0.0	14.0	1,717.0	0.1	0.0	1	1	0
03/14/2020 10:00	0.0	14.0	1,713.7	0.0	0.0	1	1	0
03/14/2020 11:00	0.0	14.0	1,714.1	0.0	0.0	1	1	0
03/14/2020 12:00	0.0	14.0	1,712.4	0.0	0.0	1	1	0
03/14/2020 13:00	0.0	14.0	1,708.3	0.0	0.0	1	1	0
03/14/2020 14:00	0.0	14.0	1,711.3	0.0	0.0	1	1	0
03/14/2020 15:00	0.0	14.0	1,711.1	0.0	0.0	1	1	0
03/14/2020 16:00	0.0	14.0	1,718.1	0.0	0.0	1	1	0
03/14/2020 17:00	0.1	13.4	1,802.0	0.0	0.3	1	1	1
03/14/2020 18:00	0.5	12.3	2,088.0	0.1	1.6	1	1	1
03/14/2020 19:00	0.4	11.8	2,175.9	0.2	1.3	1	1	1
03/14/2020 20:00	0.4	12.0	2,141.1	0.3	1.3	1	1	1
03/14/2020 21:00	0.5	12.3	2,094.0	0.3	1.6	1	1	1
03/14/2020 22:00	0.4	12.6	2,021.6	0.3	1.3	1	1	1
03/14/2020 23:00	0.4	12.7	2,012.5	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,935.9	0.2	19.7 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,708.3	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,175.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/15/2020 00:00	0.5	12.4	2,063.4	0.3	1.6	1	1	1
03/15/2020 01:00	0.4	12.6	2,026.4	0.3	1.3	1	1	1
03/15/2020 02:00	0.4	12.7	2,015.0	0.3	1.3	1	1	1
03/15/2020 03:00	0.4	12.7	2,015.7	0.3	1.3	1	1	1
03/15/2020 04:00	0.5	12.6	2,028.1	0.3	1.6	1	1	1
03/15/2020 05:00	0.5	12.7	2,025.5	0.4	1.6	1	1	1
03/15/2020 06:00	0.5	12.5	2,046.5	0.4	1.6	1	1	1
03/15/2020 07:00	0.4	12.5	2,044.5	0.4	1.3	1	1	1
03/15/2020 08:00	0.4	12.6	1,997.9	0.3	1.3	1	1	1
03/15/2020 09:00	0.0	13.9	1,719.8	0.2	0.0	1	1	0
03/15/2020 10:00	0.0	13.9	1,724.4	0.1	0.0	1	1	0
03/15/2020 11:00	0.0	13.9	1,714.7	0.0	0.0	1	1	0
03/15/2020 12:00	0.0	14.0	1,715.4	0.0	0.0	1	1	0
03/15/2020 13:00	0.0	14.0	1,717.8	0.0	0.0	1	1	0
03/15/2020 14:00	0.0	14.0	1,557.9	0.0	0.0	1	1	0
03/15/2020 15:00	0.0	14.0	1,492.1	0.0	0.0	1	1	0
03/15/2020 16:00	0.0	14.0	1,488.3	0.0	0.0	1	1	0
03/15/2020 17:00	0.1	13.5	1,794.4	0.0	0.3	1	1	1
03/15/2020 18:00	0.5	11.9	2,170.7	0.1	1.6	1	1	1
03/15/2020 19:00	0.4	11.7	2,218.3	0.2	1.3	1	1	1
03/15/2020 20:00	0.4	11.7	2,201.8	0.3	1.3	1	1	1
03/15/2020 21:00	0.4	11.8	2,198.1	0.3	1.3	1	1	1
03/15/2020 22:00	0.4	12.4	2,081.0	0.3	1.3	1	1	1
03/15/2020 23:00	0.4	12.4	2,089.1	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,922.8	0.2	21.3 #	24 #	24 #	16 #
Minimum:	0.0	11.7	1,488.3	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,218.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2020 00:00	0.5	12.3	2,100.3	0.3	1.6	1	1	1
03/16/2020 01:00	0.5	12.4	2,086.3	0.3	1.6	1	1	1
03/16/2020 02:00	0.5	12.3	2,100.7	0.3	1.6	1	1	1
03/16/2020 03:00	0.5	12.4	2,093.7	0.3	1.6	1	1	1
03/16/2020 04:00	0.5	12.1	2,159.1	0.3	1.6	1	1	1
03/16/2020 05:00	0.5	11.9	2,181.7	0.3	1.6	1	1	1
03/16/2020 06:00	0.4	11.7	2,231.6	0.3	1.3	1	1	1
03/16/2020 07:00	0.4	12.3	2,121.9	0.3	1.3	1	1	1
03/16/2020 08:00	0.4	12.3	2,108.2	0.3	1.3	1	1	1
03/16/2020 09:00	0.4	12.3	2,097.4	0.3	1.3	1	1	1
03/16/2020 10:00	0.4	12.3	2,097.8	0.3	1.3	1	1	1
03/16/2020 11:00	0.4	12.2	2,110.7	0.3	1.3	1	1	1
03/16/2020 12:00	0.4	12.3	2,092.9	0.3	1.3	1	1	1
03/16/2020 13:00	0.4	12.4	2,061.4	0.3	1.3	1	1	1
03/16/2020 14:00	0.4	12.4	2,042.2	0.3	1.3	1	1	1
03/16/2020 15:00	0.4	12.6	2,008.7	0.3	1.3	1	1	1
03/16/2020 16:00	0.4	12.6	2,007.2	0.3	1.3	1	1	1
03/16/2020 17:00	0.4	12.6	2,019.2	0.3	1.3	1	1	1
03/16/2020 18:00	0.4	11.8	2,196.5	0.3	1.3	1	1	1
03/16/2020 19:00	0.4	11.7	2,201.6	0.3	1.3	1	1	1
03/16/2020 20:00	0.4	12.0	2,146.1	0.3	1.3	1	1	1
03/16/2020 21:00	0.5	11.9	2,161.9	0.3	1.6	1	1	1
03/16/2020 22:00	0.5	12.2	2,094.0	0.3	1.6	1	1	1
03/16/2020 23:00	0.5	12.2	2,094.6	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.2	2,109.0	0.3	33.9 #	24 #	24 #	24 #
Minimum:	0.4	11.7	2,007.2	0.3	1.3	1	1	1
Maximum:	0.5	12.6	2,231.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2020 00:00	0.5	12.3	2,079.2	0.3	1.6	1	1	1
03/17/2020 01:00	0.5	12.4	2,072.9	0.3	1.6	1	1	1
03/17/2020 02:00	0.4	12.7	2,012.9	0.3	1.3	1	1	1
03/17/2020 03:00	0.4	12.6	2,042.0	0.3	1.3	1	1	1
03/17/2020 04:00	0.4	12.7	2,006.1	0.3	1.3	1	1	1
03/17/2020 05:00	0.6	12.2	2,092.2	0.3	1.9	1	1	1
03/17/2020 06:00	0.5	12.1	2,149.1	0.3	1.6	1	1	1
03/17/2020 07:00	0.4	12.8	2,007.9	0.3	1.3	1	1	1
03/17/2020 08:00	0.4	13.2	1,880.6	0.3	1.3	1	1	1
03/17/2020 09:00	0.0	13.9	1,710.7	0.2	0.0	1	1	0
03/17/2020 10:00	0.0	13.9	1,721.0	0.1	0.0	1	1	0
03/17/2020 11:00	0.0	13.9	1,724.1	0.0	0.0	1	1	0
03/17/2020 12:00	0.0	13.9	1,724.9	0.0	0.0	1	1	0
03/17/2020 13:00	0.1	13.9	1,723.7	0.0	0.3	1	1	0
03/17/2020 14:00	0.0	13.9	1,722.0	0.0	0.0	1	1	0
03/17/2020 15:00	0.0	13.9	1,721.6	0.0	0.0	1	1	0
03/17/2020 16:00	0.0	13.9	1,725.8	0.0	0.0	1	1	1
03/17/2020 17:00	0.5	12.8	1,979.8	0.1	1.6	1	1	1
03/17/2020 18:00	0.5	12.3	2,081.9	0.2	1.6	1	1	1
03/17/2020 19:00	0.5	12.2	2,094.9	0.3	1.6	1	1	1
03/17/2020 20:00	0.4	12.5	2,036.4	0.3	1.3	1	1	1
03/17/2020 21:00	0.5	12.5	2,042.4	0.3	1.6	1	1	1
03/17/2020 22:00	0.5	12.5	2,043.6	0.4	1.6	1	1	1
03/17/2020 23:00	0.4	12.7	2,004.9	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.0	1,933.4	0.2	24.1 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,710.7	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,149.1	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/18/2020 00:00	0.4	12.7	2,002.2	0.3	1.3	1	1	1
03/18/2020 01:00	0.4	12.7	2,002.4	0.3	1.3	1	1	1
03/18/2020 02:00	0.4	12.7	2,003.2	0.3	1.3	1	1	1
03/18/2020 03:00	0.4	12.7	2,007.3	0.3	1.3	1	1	1
03/18/2020 04:00	0.4	12.7	1,998.3	0.3	1.3	1	1	1
03/18/2020 05:00	0.5	12.5	1,998.7	0.3	1.6	1	1	1
03/18/2020 06:00	0.5	12.2	2,097.3	0.3	1.6	1	1	1
03/18/2020 07:00	0.5	12.4	2,064.0	0.3	1.6	1	1	1
03/18/2020 08:00	0.4	12.6	1,998.1	0.3	1.3	1	1	1
03/18/2020 09:00	0.0	13.9	1,621.1	0.2	0.0	1	1	0
03/18/2020 10:00	0.0	13.9	1,599.2	0.1	0.0	1	1	0
03/18/2020 11:00	0.0	13.9	1,585.1	0.0	0.0	1	1	0
03/18/2020 12:00	0.0	13.9	1,608.1	0.0	0.0	1	1	0
03/18/2020 13:00	0.0	13.9	1,586.3	0.0	0.0	1	1	0
03/18/2020 14:00	0.0	13.9	1,620.8	0.0	0.0	1	1	0
03/18/2020 15:00	0.0	13.9	1,598.7	0.0	0.0	1	1	0
03/18/2020 16:00	0.0	13.9	1,652.3	0.0	0.0	1	1	0
03/18/2020 17:00	0.0	13.9	1,533.8	0.0	0.0	1	1	0
03/18/2020 18:00	0.4	12.8	1,954.4	0.1	1.3	1	1	1
03/18/2020 19:00	0.4	12.7	1,983.7	0.2	1.3	1	1	1
03/18/2020 20:00	0.5	12.5	2,035.7	0.3	1.6	1	1	1
03/18/2020 21:00	0.5	12.6	2,018.3	0.4	1.6	1	1	1
03/18/2020 22:00	0.5	12.6	2,020.3	0.4	1.6	1	1	1
03/18/2020 23:00	0.4	12.8	1,977.1	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,856.9	0.2	21.3 #	24 #	24 #	15 #
Minimum:	0.0	12.2	1,533.8	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,097.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/19/2020 00:00	0.4	13.2	1,891.9	0.3	1.3	1	1	1
03/19/2020 01:00	0.4	13.2	1,891.7	0.3	1.3	1	1	1
03/19/2020 02:00	0.5	13.3	1,899.4	0.3	1.7	1	1	1
03/19/2020 03:00	0.5	13.1	1,943.5	0.4	1.6	1	1	1
03/19/2020 04:00	0.6	12.4	2,084.9	0.4	1.9	1	1	1
03/19/2020 05:00	0.5	13.0	1,951.0	0.4	1.6	1	1	1
03/19/2020 06:00	0.6	12.5	2,074.9	0.4	2.0	1	1	1
03/19/2020 07:00	0.5	12.5	2,077.5	0.4	1.6	1	1	1
03/19/2020 08:00	0.4	12.8	1,964.4	0.4	1.3	1	1	1
03/19/2020 09:00	0.0	13.9	1,521.8	0.2	0.0	1	1	0
03/19/2020 10:00	0.0	13.9	1,558.8	0.1	0.0	1	1	0
03/19/2020 11:00	0.0	14.0	1,441.0	0.0	0.0	1	1	0
03/19/2020 12:00	0.0	13.9	1,500.2	0.0	0.0	1	1	0
03/19/2020 13:00	0.0	14.0	1,347.7	0.0	0.0	1	1	0
03/19/2020 14:00	0.0	14.0	1,276.5	0.0	0.0	1	1	0
03/19/2020 15:00	0.0	14.0	1,536.0	0.0	0.0	1	1	0
03/19/2020 16:00	0.0	14.0	1,510.6	0.0	0.0	1	1	1
03/19/2020 17:00	0.5	12.7	1,985.8	0.1	1.6	1	1	1
03/19/2020 18:00	0.5	12.4	2,035.6	0.2	1.6	1	1	1
03/19/2020 19:00	0.5	12.2	2,088.6	0.3	1.6	1	1	1
03/19/2020 20:00	0.5	12.2	2,091.7	0.3	1.6	1	1	1
03/19/2020 21:00	0.5	12.3	2,068.3	0.3	1.6	1	1	1
03/19/2020 22:00	0.5	12.4	2,059.9	0.3	1.6	1	1	1
03/19/2020 23:00	0.4	12.7	2,009.8	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,825.5	0.2	25.2 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,276.5	0.0	0.0	1	1	0
Maximum:	0.6	14.0	2,091.7	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/20/2020 00:00	0.4	12.8	2,003.8	0.3	1.3	1	1	1
03/20/2020 01:00	0.4	12.8	2,007.0	0.3	1.3	1	1	1
03/20/2020 02:00	0.4	12.8	2,005.1	0.3	1.3	1	1	1
03/20/2020 03:00	0.4	12.8	2,003.8	0.3	1.3	1	1	1
03/20/2020 04:00	0.4	12.8	2,004.6	0.3	1.3	1	1	1
03/20/2020 05:00	0.4	13.1	1,942.3	0.3	1.3	1	1	1
03/20/2020 06:00	0.5	12.8	2,026.8	0.3	1.7	1	1	1
03/20/2020 07:00	0.4	13.3	1,883.0	0.3	1.3	1	1	1
03/20/2020 08:00	0.0	13.9	1,590.6	0.2	0.0	1	1	0
03/20/2020 09:00	0.0	14.0	1,350.6	0.1	0.0	1	1	0
03/20/2020 10:00	0.0	13.9	1,620.5	0.0	0.0	1	1	0
03/20/2020 11:00	0.0	13.9	1,525.4	0.0	0.0	1	1	0
03/20/2020 12:00	0.0	14.0	1,499.9	0.0	0.0	1	1	0
03/20/2020 13:00	0.0	14.0	1,613.8	0.0	0.0	1	1	0
03/20/2020 14:00	0.0	14.0	1,503.6	0.0	0.0	1	1	0
03/20/2020 15:00	0.0	13.9	1,551.6	0.0	0.0	1	1	1
03/20/2020 16:00	0.5	12.7	1,980.0	0.1	1.6	1	1	1
03/20/2020 17:00	0.5	12.5	2,019.0	0.3	1.6	1	1	1
03/20/2020 18:00	0.5	12.5	2,021.3	0.4	1.6	1	1	1
03/20/2020 19:00	0.5	12.4	2,030.2	0.4	1.6	1	1	1
03/20/2020 20:00	0.5	12.4	2,054.4	0.3	1.6	1	1	1
03/20/2020 21:00	0.5	12.3	2,070.3	0.3	1.6	1	1	1
03/20/2020 22:00	0.4	12.4	2,050.9	0.3	1.3	1	1	1
03/20/2020 23:00	0.4	12.6	2,011.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,848.8	0.2	23.0 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,350.6	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,070.3	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2020 00:00	0.5	12.5	2,052.2	0.3	1.6	1	1	1
03/21/2020 01:00	0.5	12.5	2,073.5	0.4	1.6	1	1	1
03/21/2020 02:00	0.5	12.4	2,066.3	0.4	1.6	1	1	1
03/21/2020 03:00	0.5	12.4	2,073.9	0.3	1.6	1	1	1
03/21/2020 04:00	0.4	12.5	2,042.9	0.3	1.3	1	1	1
03/21/2020 05:00	0.5	12.5	2,034.4	0.3	1.6	1	1	1
03/21/2020 06:00	0.4	12.8	1,971.8	0.3	1.3	1	1	1
03/21/2020 07:00	6.1	14.5	1,168.2	0.0	6.9	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.2	12.8	1,935.4	0.3	17.5 #	8 #	7 #	8 #
Minimum:	0.4	12.4	1,168.2	0.3	1.3	0	0	0
Maximum:	6.1	14.5	2,073.9	0.4	6.9	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	4 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	6 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/24/2020 02:00	64.6	17.7	451.6	0.0	86.7	1	1	0
03/24/2020 03:00	20.3	15.7	832.3	0.0	42.9	1	1	0
03/24/2020 04:00	0.0	13.8	1,694.2	0.0	0.0	1	1	0
03/24/2020 05:00	0.0	13.9	1,566.4	0.0	0.0	1	1	0
03/24/2020 06:00	0.0	13.9	1,657.2	0.0	0.0	1	1	0
03/24/2020 07:00	0.0	13.9	1,667.4	0.0	0.0	1	1	0
03/24/2020 08:00	0.0	13.9	1,546.4	0.0	0.0	1	1	0
03/24/2020 09:00	0.0	13.9	1,651.1	0.0	0.0	1	1	0
03/24/2020 10:00	0.0	13.9	1,671.1	0.0	0.0	1	1	0
03/24/2020 11:00	0.0	13.9	1,583.5	0.0	0.0	1	1	0
03/24/2020 12:00	0.0	13.9	1,611.7	0.0	0.0	1	1	0
03/24/2020 13:00	0.0	13.9	1,514.7	0.0	0.0	1	1	0
03/24/2020 14:00	0.0	13.9	1,536.0	0.0	0.0	1	1	0
03/24/2020 15:00	0.0	14.0	1,551.9	0.0	0.0	1	1	0
03/24/2020 16:00	0.0	14.0	1,568.9	0.0	0.0	1	1	1
03/24/2020 17:00	0.5	12.7	1,992.1	0.1	1.6	1	1	1
03/24/2020 18:00	0.4	12.8	1,959.9	0.2	1.3	1	1	1
03/24/2020 19:00	0.4	12.8	1,983.3	0.3	1.3	1	1	1
03/24/2020 20:00	0.5	12.3	2,086.5	0.3	1.6	1	1	1
03/24/2020 21:00	0.4	12.6	2,017.5	0.3	1.3	1	1	1
03/24/2020 22:00	0.5	12.7	2,027.9	0.3	1.6	1	1	1
03/24/2020 23:00	5.8	14.4	1,214.5	0.0	6.9	1	0	1
Average/Sum#:	4.2	13.8	1,608.5	0.1	145.2 #	22 #	23 #	8 #
Minimum:	0.0	12.3	451.6	0.0	0.0	0	0	0
Maximum:	64.6	17.7	2,086.5	0.3	86.7	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/27/2020 23:00	52.0	17.5	469.6	0.0	88.3	1	1	0
Average/Sum#:	52.0	17.5	469.6	0.0	88.3 #	1 #	4 #	0 #
Minimum:	52.0	17.5	469.6	0.0	88.3	0	0	0
Maximum:	52.0	17.5	469.6	0.0	88.3	1	1	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/28/2020 00:00	17.6	15.1	1,005.4	0.0	40.3	1	1	0
03/28/2020 01:00	0.0	13.9	1,654.1	0.0	0.0	1	1	0
03/28/2020 02:00	0.0	13.9	1,663.3	0.0	0.0	1	1	0
03/28/2020 03:00	0.0	13.9	1,665.2	0.0	0.0	1	1	0
03/28/2020 04:00	0.0	13.9	1,645.2	0.0	0.0	1	1	0
03/28/2020 05:00	0.0	13.9	1,647.5	0.0	0.0	1	1	0
03/28/2020 06:00	0.0	13.9	1,526.6	0.0	0.0	1	1	0
03/28/2020 07:00	0.0	13.9	1,495.6	0.0	0.0	1	1	0
03/28/2020 08:00	0.0	13.9	1,607.9	0.0	0.0	1	1	0
03/28/2020 09:00	0.0	13.9	1,631.6	0.0	0.0	1	1	0
03/28/2020 10:00	0.0	13.9	1,653.8	0.0	0.0	1	1	0
03/28/2020 11:00	0.0	13.9	1,661.3	0.0	0.0	1	1	0
03/28/2020 12:00	0.0	13.9	1,651.0	0.0	0.0	1	1	0
03/28/2020 13:00	0.0	13.9	1,652.2	0.0	0.0	1	1	0
03/28/2020 14:00	0.0	13.9	1,631.6	0.0	0.0	1	1	0
03/28/2020 15:00	0.0	13.9	1,632.4	0.0	0.0	1	1	0
03/28/2020 16:00	0.0	13.9	1,661.3	0.0	0.0	1	1	0
03/28/2020 17:00	0.1	13.4	1,797.9	0.0	0.3	1	1	1
03/28/2020 18:00	0.3	12.2	2,079.6	0.1	0.9	1	1	1
03/28/2020 19:00	0.3	12.4	2,047.3	0.2	1.0	1	1	1
03/28/2020 20:00	0.2	12.2	2,089.1	0.2	0.6	1	1	1
03/28/2020 21:00	0.3	12.5	2,034.5	0.2	1.0	1	1	1
03/28/2020 22:00	0.3	12.5	2,026.8	0.2	1.0	1	1	1
03/28/2020 23:00	0.2	12.9	1,933.9	0.2	0.6	1	1	1
Average/Sum#:	0.8	13.6	1,712.3	0.1	45.7 #	24 #	24 #	7 #
Minimum:	0.0	12.2	1,005.4	0.0	0.0	1	1	0
Maximum:	17.6	15.1	2,089.1	0.2	40.3	1	1	1
%SI	0.00	0.00	0.00	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.0	13.9	1,613.0	0.1	0.0	1	1	0
03/29/2020 01:00	0.0	13.9	1,574.2	0.0	0.0	1	1	0
03/29/2020 02:00	0.0	13.9	1,580.4	0.0	0.0	1	1	0
03/29/2020 03:00	0.0	13.9	1,531.6	0.0	0.0	1	1	0
03/29/2020 04:00	0.0	13.9	1,659.1	0.0	0.0	1	1	0
03/29/2020 05:00	0.0	13.9	1,580.5	0.0	0.0	1	1	0
03/29/2020 06:00	0.0	13.9	1,562.2	0.0	0.0	1	1	0
03/29/2020 07:00	0.0	13.9	1,584.7	0.0	0.0	1	1	0
03/29/2020 08:00	0.0	13.9	1,568.1	0.0	0.0	1	1	0
03/29/2020 09:00	0.0	13.9	1,638.2	0.0	0.0	1	1	0
03/29/2020 10:00	0.0	13.9	1,662.6	0.0	0.0	1	1	0
03/29/2020 11:00	0.0	13.9	1,644.1	0.0	0.0	1	1	0
03/29/2020 12:00	0.0	13.9	1,537.1	0.0	0.0	1	1	0
03/29/2020 13:00	0.0	13.9	1,578.6	0.0	0.0	1	1	0
03/29/2020 14:00	0.0	13.9	1,568.1	0.0	0.0	1	1	0
03/29/2020 15:00	0.0	14.0	1,565.1	0.0	0.0	1	1	0
03/29/2020 16:00	0.0	13.9	1,619.2	0.0	0.0	1	1	0
03/29/2020 17:00	0.0	13.9	1,532.7	0.0	0.0	1	1	1
03/29/2020 18:00	0.4	12.6	2,010.5	0.1	1.3	1	1	1
03/29/2020 19:00	0.2	12.1	2,091.9	0.1	0.6	1	1	1
03/29/2020 20:00	0.2	12.2	2,068.0	0.2	0.6	1	1	1
03/29/2020 21:00	0.2	12.3	2,060.4	0.1	0.6	1	1	1
03/29/2020 22:00	0.2	13.0	1,913.3	0.1	0.6	1	1	1
03/29/2020 23:00	0.2	12.9	1,927.1	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.6	1,694.6	0.0	4.3 #	24 #	24 #	7 #
Minimum:	0.0	12.1	1,531.6	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,091.9	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2020 00:00	0.0	13.9	1,653.5	0.1	0.0	1	1	0
03/30/2020 01:00	0.0	13.9	1,654.5	0.0	0.0	1	1	0
03/30/2020 02:00	0.0	13.9	1,643.8	0.0	0.0	1	1	0
03/30/2020 03:00	0.0	13.9	1,614.2	0.0	0.0	1	1	0
03/30/2020 04:00	0.0	13.9	1,590.6	0.0	0.0	1	1	0
03/30/2020 05:00	0.0	13.9	1,641.7	0.0	0.0	1	1	0
03/30/2020 06:00	0.0	13.9	1,654.8	0.0	0.0	1	1	0
03/30/2020 07:00	0.0	13.9	1,632.0	0.0	0.0	1	1	0
03/30/2020 08:00	0.0	13.9	1,608.7	0.0	0.0	1	1	0
03/30/2020 09:00	0.0	13.9	1,628.0	0.0	0.0	1	1	0
03/30/2020 10:00	0.0	13.9	1,630.2	0.0	0.0	1	1	0
03/30/2020 11:00	0.0	13.9	1,607.6	0.0	0.0	1	1	0
03/30/2020 12:00	0.0	13.9	1,576.3	0.0	0.0	1	1	0
03/30/2020 13:00	0.0	13.9	1,565.2	0.0	0.0	1	1	0
03/30/2020 14:00	0.0	13.9	1,619.3	0.0	0.0	1	1	0
03/30/2020 15:00	0.0	13.9	1,582.7	0.0	0.0	1	1	0
03/30/2020 16:00	0.0	13.9	1,630.2	0.0	0.0	1	1	0
03/30/2020 17:00	0.0	13.9	1,623.8	0.0	0.0	1	1	1
03/30/2020 18:00	0.5	12.7	1,980.9	0.1	1.6	1	1	1
03/30/2020 19:00	0.5	12.4	2,035.9	0.2	1.6	1	1	1
03/30/2020 20:00	0.5	12.0	2,109.7	0.3	1.6	1	1	1
03/30/2020 21:00	0.4	12.0	2,111.8	0.3	1.3	1	1	1
03/30/2020 22:00	0.4	12.2	2,089.0	0.3	1.3	1	1	1
03/30/2020 23:00	0.4	12.6	2,001.1	0.3	1.3	1	1	1
Average/Sum#:	0.1	13.5	1,728.6	0.1	8.7 #	24 #	24 #	7 #
Minimum:	0.0	12.0	1,565.2	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,111.8	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2020 00:00	0.4	12.5	2,015.0	0.3	1.3	1	1	1
03/31/2020 01:00	0.4	12.5	2,017.2	0.3	1.3	1	1	1
03/31/2020 02:00	0.4	12.6	2,015.0	0.3	1.3	1	1	1
03/31/2020 03:00	0.4	12.6	2,012.6	0.3	1.3	1	1	1
03/31/2020 04:00	0.4	12.7	1,995.7	0.3	1.3	1	1	1
03/31/2020 05:00	0.4	13.1	1,907.7	0.3	1.3	1	1	1
03/31/2020 06:00	0.5	12.6	2,013.5	0.3	1.6	1	1	1
03/31/2020 07:00	6.2	14.2	1,224.0	0.0	7.2	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
03/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	1.1	12.9	1,900.1	0.3	16.6 #	8 #	11 #	8 #
Minimum:	0.4	12.5	1,224.0	0.3	1.3	0	0	0
Maximum:	6.2	14.2	2,017.2	0.3	7.2	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/01/2020 00:00	0.0	12.6	2,035.3	0.0	0.0	1	1	1
01/01/2020 01:00	0.0	12.6	2,026.0	0.0	0.0	1	1	1
01/01/2020 02:00	6.1	14.4	1,144.9	0.0	6.1	1	0	1
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.0	13.2	1,735.4	0.0	6.1 #	3 #	2 #	3 #
Minimum:	0.0	12.6	1,144.9	0.0	0.0	0	0	0
Maximum:	6.1	14.4	2,035.3	0.0	6.1	1	1	1
%SI	87.50	87.50	87.50	91.67	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/02/2020 01:00	55.4	17.4	462.5	0.0	60.9	1	0	0
01/02/2020 02:00	27.3	15.6	700.4	0.0	47.6	1	0	0
01/02/2020 03:00	23.5	14.8	966.5	0.0	49.2	1	0	0
01/02/2020 04:00	0.0	13.6	1,542.2	0.0	0.0	1	1	0
01/02/2020 05:00	0.0	13.1	1,864.2	0.0	0.0	1	1	1
01/02/2020 06:00	0.0	12.1	2,117.0	0.0	0.0	1	1	1
01/02/2020 07:00	0.0	13.6	1,755.7	0.0	0.0	1	1	0
01/02/2020 08:00	0.0	13.6	1,537.2	0.0	0.0	1	1	0
01/02/2020 09:00	0.0	13.6	1,524.6	0.0	0.0	1	1	0
01/02/2020 10:00	0.0	13.6	1,660.3	0.0	0.0	1	1	0
01/02/2020 11:00	0.0	13.7	1,680.4	0.0	0.0	1	1	0
01/02/2020 12:00	0.0	13.7	1,626.2	0.0	0.0	1	1	0
01/02/2020 13:00	0.0	13.7	1,646.2	0.0	0.0	1	1	0
01/02/2020 14:00	0.0	13.7	1,633.3	0.0	0.0	1	1	0
01/02/2020 15:00	0.0	13.6	1,594.6	0.0	0.0	1	1	1
01/02/2020 16:00	0.0	12.5	2,015.8	0.0	0.0	1	1	1
01/02/2020 17:00	0.0	12.4	2,045.9	0.0	0.0	1	1	1
01/02/2020 18:00	0.0	12.3	2,077.0	0.0	0.0	1	1	1
01/02/2020 19:00	0.0	12.3	2,082.2	0.0	0.0	1	1	1
01/02/2020 20:00	0.0	12.3	2,082.4	0.0	0.0	1	1	1
01/02/2020 21:00	0.0	12.2	2,092.7	0.0	0.0	1	1	1
01/02/2020 22:00	0.0	12.2	2,080.3	0.0	0.0	1	1	1
01/02/2020 23:00	0.0	12.5	2,048.2	0.0	0.0	1	1	1
Average/Sum#:	4.6	13.4	1,688.5	0.0	157.7 #	23 #	20 #	11 #
Minimum:	0.0	12.1	462.5	0.0	0.0	0	0	0
Maximum:	55.4	17.4	2,117.0	0.0	60.9	1	1	1
%SI	4.17	4.17	4.17	25.00	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2020 00:00	0.0	12.6	2,035.4	0.0	0.0	1	1	1
01/03/2020 01:00	0.0	12.5	2,028.9	0.0	0.0	1	1	1
01/03/2020 02:00	0.0	12.7	2,024.1	0.0	0.0	1	1	1
01/03/2020 03:00	0.0	12.6	2,037.3	0.0	0.0	1	1	1
01/03/2020 04:00	0.0	12.6	2,037.7	0.0	0.0	1	1	1
01/03/2020 05:00	0.0	12.6	2,030.5	0.0	0.0	1	1	1
01/03/2020 06:00	0.0	12.7	2,017.3	0.0	0.0	1	1	1
01/03/2020 07:00	0.0	12.7	2,027.9	0.0	0.0	1	1	1
01/03/2020 08:00	0.0	13.1	1,904.9	0.0	0.0	1	1	1
01/03/2020 09:00	0.0	13.7	1,532.8	0.0	0.0	1	1	0
01/03/2020 10:00	0.0	13.6	1,557.2	0.0	0.0	1	1	0
01/03/2020 11:00	0.0	13.6	1,606.4	0.0	0.0	1	1	0
01/03/2020 12:00	0.0	13.6	1,690.7	0.0	0.0	1	1	0
01/03/2020 13:00	0.0	13.6	1,668.8	0.0	0.0	1	1	0
01/03/2020 14:00	0.0	13.7	1,545.8	0.0	0.0	1	1	0
01/03/2020 15:00	0.0	13.7	1,581.2	0.0	0.0	1	1	0
01/03/2020 16:00	0.0	12.8	1,952.8	0.0	0.0	1	1	1
01/03/2020 17:00	0.0	12.5	2,034.8	0.0	0.0	1	1	1
01/03/2020 18:00	0.0	12.5	2,056.3	0.0	0.0	1	1	1
01/03/2020 19:00	0.0	12.5	2,041.2	0.0	0.0	1	1	1
01/03/2020 20:00	0.0	12.5	2,053.0	0.0	0.0	1	1	1
01/03/2020 21:00	0.0	12.3	2,095.6	0.0	0.0	1	1	1
01/03/2020 22:00	0.0	12.4	2,098.3	0.0	0.0	1	1	1
01/03/2020 23:00	2.3	13.1	1,674.2	0.0	6.5	1	0	1
Average/Sum#:	0.1	12.9	1,888.9	0.0	6.5 #	24 #	23 #	17 #
Minimum:	0.0	12.3	1,532.8	0.0	0.0	1	0	0
Maximum:	2.3	13.7	2,098.3	0.0	6.5	1	1	1
%SI	0.00	0.00	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/04/2020 00:00	7.2	19.1	0.2	0.0	0.0	1	0	0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.2	19.1	0.2	0.0	0.0 #	1 #	0 #	0 #
Minimum:	7.2	19.1	0.2	0.0	0.0	0	0	0
Maximum:	7.2	19.1	0.2	0.0	0.0	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/06/2020 04:00	86.6	17.6	443.8	0.0	72.3	1	0	0
01/06/2020 05:00	17.5	16.5	601.7	0.0	31.6	1	0	0
01/06/2020 06:00	26.4	15.2	842.6	0.0	51.5	1	0	0
01/06/2020 07:00	0.0	13.7	1,588.4	0.0	0.0	1	1	0
01/06/2020 08:00	0.0	13.6	1,755.9	0.0	0.0	1	1	0
01/06/2020 09:00	0.0	13.6	1,667.1	0.0	0.0	1	1	0
01/06/2020 10:00	0.0	13.7	1,555.8	0.0	0.0	1	1	0
01/06/2020 11:00	0.0	13.7	1,654.8	0.0	0.0	1	1	0
01/06/2020 12:00	0.0	13.7	1,583.5	0.0	0.0	1	1	0
01/06/2020 13:00	0.0	13.7	1,638.7	0.0	0.0	1	1	0
01/06/2020 14:00	0.0	13.7	1,567.1	0.0	0.0	1	1	0
01/06/2020 15:00	0.0	13.6	1,552.6	0.0	0.0	1	1	1
01/06/2020 16:00	0.0	12.7	2,014.8	0.0	0.0	1	1	1
01/06/2020 17:00	0.0	12.5	2,053.4	0.0	0.0	1	1	1
01/06/2020 18:00	0.0	12.6	2,049.6	0.0	0.0	1	1	1
01/06/2020 19:00	0.0	12.6	2,036.0	0.0	0.0	1	1	1
01/06/2020 20:00	0.0	12.7	2,031.6	0.0	0.0	1	1	1
01/06/2020 21:00	0.0	12.7	2,034.9	0.0	0.0	1	1	1
01/06/2020 22:00	0.0	12.6	2,052.9	0.0	0.0	1	1	1
01/06/2020 23:00	0.0	12.8	2,017.5	0.0	0.0	1	1	1
Average/Sum#:	6.5	13.7	1,637.1	0.0	155.4 #	20 #	17 #	9 #
Minimum:	0.0	12.5	443.8	0.0	0.0	0	0	0
Maximum:	86.6	17.6	2,053.4	0.0	72.3	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/07/2020 00:00	0.0	12.7	2,036.3	0.0	0.0	1	1	1
01/07/2020 01:00	0.0	12.8	2,016.4	0.0	0.0	1	1	1
01/07/2020 02:00	0.0	12.8	2,008.2	0.0	0.0	1	1	1
01/07/2020 03:00	0.0	12.8	2,009.9	0.0	0.0	1	1	1
01/07/2020 04:00	0.0	12.8	2,025.5	0.0	0.0	1	1	1
01/07/2020 05:00	0.0	12.8	2,028.6	0.0	0.0	1	1	1
01/07/2020 06:00	0.0	12.7	2,031.0	0.0	0.0	1	1	1
01/07/2020 07:00	0.0	12.6	2,070.4	0.0	0.0	1	1	1
01/07/2020 08:00	0.0	13.1	1,960.5	0.0	0.0	1	1	1
01/07/2020 09:00	0.0	13.6	1,723.4	0.0	0.0	1	1	0
01/07/2020 10:00	0.0	13.6	1,625.3	0.0	0.0	1	1	0
01/07/2020 11:00	0.0	13.6	1,614.8	0.0	0.0	1	1	0
01/07/2020 12:00	0.0	13.6	1,677.6	0.0	0.0	1	1	0
01/07/2020 13:00	0.0	13.6	1,645.7	0.0	0.0	1	1	0
01/07/2020 14:00	0.0	13.6	1,593.5	0.0	0.0	1	1	0
01/07/2020 15:00	0.0	13.6	1,573.8	0.0	0.0	1	1	1
01/07/2020 16:00	0.0	12.7	2,015.1	0.0	0.0	1	1	1
01/07/2020 17:00	0.0	12.6	2,038.8	0.0	0.0	1	1	1
01/07/2020 18:00	0.0	12.6	2,036.1	0.0	0.0	1	1	1
01/07/2020 19:00	0.0	12.7	2,025.4	0.0	0.0	1	1	1
01/07/2020 20:00	0.0	12.6	2,056.1	0.0	0.0	1	1	1
01/07/2020 21:00	0.0	12.5	2,064.1	0.0	0.0	1	1	1
01/07/2020 22:00	4.7	14.1	1,265.4	0.0	5.6	1	0	1
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.0	1,875.7	0.0	5.6 #	23 #	22 #	17 #
Minimum:	0.0	12.5	1,265.4	0.0	0.0	0	0	0
Maximum:	4.7	14.1	2,070.4	0.0	5.6	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/08/2020 21:00	64.0	17.4	466.5	0.0	78.9	1	0	0
01/08/2020 22:00	12.2	16.9	529.7	0.0	21.3	1	0	0
01/08/2020 23:00	15.3	15.4	867.5	0.0	31.9	1	0	0
Average/Sum#:	30.5	16.6	621.2	0.0	132.1 #	3 #	0 #	0 #
Minimum:	12.2	15.4	466.5	0.0	21.3	0	0	0
Maximum:	64.0	17.4	867.5	0.0	78.9	1	0	0
%SI	87.50	87.50	87.50	100.00	87.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2020 00:00	0.0	13.6	1,483.0	0.0	0.0	1	1	0
01/09/2020 01:00	0.0	13.7	1,373.4	0.0	0.0	1	1	0
01/09/2020 02:00	0.0	13.6	1,675.7	0.0	0.0	1	1	0
01/09/2020 03:00	0.0	13.6	1,512.9	0.0	0.0	1	1	0
01/09/2020 04:00	0.0	13.6	1,694.8	0.0	0.0	1	1	0
01/09/2020 05:00	0.0	13.6	1,634.8	0.0	0.0	1	1	0
01/09/2020 06:00	0.0	13.6	1,397.1	0.0	0.0	1	1	0
01/09/2020 07:00	0.0	13.6	1,491.7	0.0	0.0	1	1	0
01/09/2020 08:00	0.0	13.6	1,629.8	0.0	0.0	1	1	0
01/09/2020 09:00	0.0	13.6	1,707.6	0.0	0.0	1	1	0
01/09/2020 10:00	0.0	13.6	1,578.3	0.0	0.0	1	1	0
01/09/2020 11:00	0.0	13.6	1,674.2	0.0	0.0	1	1	0
01/09/2020 12:00	0.0	13.6	1,645.8	0.0	0.0	1	1	0
01/09/2020 13:00	0.0	13.6	1,690.6	0.0	0.0	1	1	0
01/09/2020 14:00	0.0	13.6	1,614.5	0.0	0.0	1	1	0
01/09/2020 15:00	0.0	13.6	1,567.8	0.0	0.0	1	1	0
01/09/2020 16:00	0.0	12.6	2,007.7	0.0	0.0	1	1	1
01/09/2020 17:00	0.0	12.4	2,076.0	0.0	0.0	1	1	1
01/09/2020 18:00	0.0	12.3	2,116.7	0.0	0.0	1	1	1
01/09/2020 19:00	0.0	12.2	2,110.6	0.0	0.0	1	1	1
01/09/2020 20:00	0.0	12.2	2,113.0	0.0	0.0	1	1	1
01/09/2020 21:00	0.0	12.3	2,094.0	0.0	0.0	1	1	1
01/09/2020 22:00	0.0	12.3	2,103.8	0.0	0.0	1	1	1
01/09/2020 23:00	0.0	12.3	2,100.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,753.9	0.0	0.0 #	24 #	24 #	8 #
Minimum:	0.0	12.2	1,373.4	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,116.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/10/2020 00:00	0.0	12.5	2,060.6	0.0	0.0	1	1	1
01/10/2020 01:00	0.0	12.6	2,043.4	0.0	0.0	1	1	1
01/10/2020 02:00	0.0	12.4	2,094.0	0.0	0.0	1	1	1
01/10/2020 03:00	0.0	12.4	2,097.6	0.0	0.0	1	1	1
01/10/2020 04:00	0.0	12.6	2,032.0	0.0	0.0	1	1	1
01/10/2020 05:00	0.0	12.6	2,049.4	0.0	0.0	1	1	1
01/10/2020 06:00	0.0	12.3	2,118.6	0.0	0.0	1	1	1
01/10/2020 07:00	0.0	12.2	2,158.0	0.0	0.0	1	1	1
01/10/2020 08:00	0.0	12.6	2,069.5	0.0	0.0	1	1	1
01/10/2020 09:00	0.0	13.0	1,935.5	0.0	0.0	1	1	1
01/10/2020 10:00	0.0	13.6	1,703.7	0.0	0.0	1	1	0
01/10/2020 11:00	0.0	13.6	1,668.0	0.0	0.0	1	1	0
01/10/2020 12:00	0.0	13.6	1,639.3	0.0	0.0	1	1	0
01/10/2020 13:00	0.0	13.6	1,680.8	0.0	0.0	1	1	0
01/10/2020 14:00	0.0	13.6	1,544.2	0.0	0.0	1	1	0
01/10/2020 15:00	0.0	13.6	1,552.5	0.0	0.0	1	1	1
01/10/2020 16:00	0.0	12.7	2,036.5	0.0	0.0	1	1	1
01/10/2020 17:00	0.0	12.4	2,082.9	0.0	0.0	1	1	1
01/10/2020 18:00	0.0	12.3	2,108.5	0.0	0.0	1	1	1
01/10/2020 19:00	0.0	12.4	2,088.6	0.0	0.0	1	1	1
01/10/2020 20:00	0.0	12.5	2,079.1	0.0	0.0	1	1	1
01/10/2020 21:00	0.0	12.5	2,066.4	0.0	0.0	1	1	1
01/10/2020 22:00	0.0	12.6	2,037.4	0.0	0.0	1	1	1
01/10/2020 23:00	0.0	12.7	2,023.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,957.1	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.2	1,544.2	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,158.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/11/2020 00:00	0.0	12.7	2,028.9	0.0	0.0	1	1	1
01/11/2020 01:00	0.0	12.7	2,023.8	0.0	0.0	1	1	1
01/11/2020 02:00	0.0	12.7	2,028.4	0.0	0.0	1	1	1
01/11/2020 03:00	0.0	12.7	2,027.7	0.0	0.0	1	1	1
01/11/2020 04:00	0.0	12.7	2,034.1	0.0	0.0	1	1	1
01/11/2020 05:00	0.0	12.7	2,026.6	0.0	0.0	1	1	1
01/11/2020 06:00	0.0	12.7	2,030.0	0.0	0.0	1	1	1
01/11/2020 07:00	0.0	12.7	2,032.9	0.0	0.0	1	1	1
01/11/2020 08:00	4.3	14.0	1,305.5	0.0	5.6	1	0	1
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	12.8	1,948.7	0.0	5.6 #	9 #	8 #	9 #
Minimum:	0.0	12.7	1,305.5	0.0	0.0	0	0	0
Maximum:	4.3	14.0	2,034.1	0.0	5.6	1	1	1
%SI	62.50	62.50	62.50	66.67	62.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/12/2020 23:00	93.2	17.6	441.6	0.0	74.1	1	0	0
Average/Sum#:	93.2	17.6	441.6	0.0	74.1 #	1 #	0 #	0 #
Minimum:	93.2	17.6	441.6	0.0	74.1	0	0	0
Maximum:	93.2	17.6	441.6	0.0	74.1	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/13/2020 00:00	25.4	16.0	661.7	0.0	45.3	1	0	0
01/13/2020 01:00	22.7	14.8	987.5	0.0	48.5	1	0	0
01/13/2020 02:00	0.0	13.6	1,448.4	0.0	0.0	1	1	0
01/13/2020 03:00	0.0	13.6	1,451.3	0.0	0.0	1	1	0
01/13/2020 04:00	0.0	13.6	1,670.8	0.0	0.0	1	1	0
01/13/2020 05:00	0.0	13.6	1,668.2	0.0	0.0	1	1	0
01/13/2020 06:00	0.0	13.6	1,646.5	0.0	0.0	1	1	0
01/13/2020 07:00	0.0	13.6	1,631.2	0.0	0.0	1	1	0
01/13/2020 08:00	0.0	13.6	1,555.4	0.0	0.0	1	1	0
01/13/2020 09:00	0.0	13.6	1,679.3	0.0	0.0	1	1	0
01/13/2020 10:00	0.0	13.6	1,602.4	0.0	0.0	1	1	0
01/13/2020 11:00	0.0	13.6	1,526.5	0.0	0.0	1	1	0
01/13/2020 12:00	0.0	13.6	1,619.3	0.0	0.0	1	1	0
01/13/2020 13:00	0.0	13.6	1,695.9	0.0	0.0	1	1	0
01/13/2020 14:00	0.0	13.6	1,584.8	0.0	0.0	1	1	0
01/13/2020 15:00	0.0	13.6	1,558.6	0.0	0.0	1	1	1
01/13/2020 16:00	0.0	12.6	2,023.2	0.0	0.0	1	1	1
01/13/2020 17:00	0.0	12.1	2,141.0	0.0	0.0	1	1	1
01/13/2020 18:00	0.0	12.0	2,154.5	0.0	0.0	1	1	1
01/13/2020 19:00	0.0	12.0	2,143.7	0.0	0.0	1	1	1
01/13/2020 20:00	0.0	12.1	2,133.0	0.0	0.0	1	1	1
01/13/2020 21:00	0.0	12.3	2,088.1	0.0	0.0	1	1	1
01/13/2020 22:00	0.0	12.4	2,057.2	0.0	0.0	1	1	1
01/13/2020 23:00	0.0	12.5	2,041.9	0.0	0.0	1	1	1
Average/Sum#:	2.0	13.3	1,698.8	0.0	93.8 #	24 #	22 #	9 #
Minimum:	0.0	12.0	661.7	0.0	0.0	1	0	0
Maximum:	25.4	16.0	2,154.5	0.0	48.5	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/14/2020 00:00	0.0	12.5	2,051.1	0.0	0.0	1	1	1
01/14/2020 01:00	0.0	12.5	2,039.4	0.0	0.0	1	1	1
01/14/2020 02:00	0.0	12.5	2,041.0	0.0	0.0	1	1	1
01/14/2020 03:00	0.0	12.5	2,038.9	0.0	0.0	1	1	1
01/14/2020 04:00	0.0	12.6	2,040.0	0.0	0.0	1	1	1
01/14/2020 05:00	0.0	12.5	2,066.2	0.0	0.0	1	1	1
01/14/2020 06:00	0.0	12.3	2,101.0	0.0	0.0	1	1	1
01/14/2020 07:00	0.0	12.1	2,160.1	0.0	0.0	1	1	1
01/14/2020 08:00	0.0	12.6	2,045.8	0.0	0.0	1	1	1
01/14/2020 09:00	0.0	12.7	1,989.4	0.0	0.0	1	1	1
01/14/2020 10:00	0.0	0.0	1,683.1	0.0	0.0	1	1	0
01/14/2020 11:00	0.0	13.6	1,700.2	0.0	0.0	1	1	0
01/14/2020 12:00	0.0	13.6	1,666.5	0.0	0.0	1	1	0
01/14/2020 13:00	0.0	0.0	1,688.7	0.0	0.0	1	1	0
01/14/2020 14:00	0.0	0.0	1,630.2	0.0	0.0	1	1	0
01/14/2020 15:00	0.0	13.6	1,542.0	0.0	0.0	1	1	0
01/14/2020 16:00	0.0	13.6	1,559.5	0.0	0.0	1	1	1
01/14/2020 17:00	0.0	12.7	2,008.7	0.0	0.0	1	1	1
01/14/2020 18:00	0.0	12.6	2,045.2	0.0	0.0	1	1	1
01/14/2020 19:00	0.0	12.6	2,051.3	0.0	0.0	1	1	1
01/14/2020 20:00	0.0	12.4	2,087.9	0.0	0.0	1	1	1
01/14/2020 21:00	0.0	12.5	2,074.8	0.0	0.0	1	1	1
01/14/2020 22:00	0.0	12.6	2,045.6	0.0	0.0	1	1	1
01/14/2020 23:00	0.0	12.9	1,998.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,931.4	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.1	1,542.0	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,160.1	0.0	0.0	1	1	1
%SI	12.50	12.50	0.00	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/15/2020 00:00	0.0	12.7	2,039.3	0.0	0.0	1	1	1
01/15/2020 01:00	0.0	12.7	2,043.2	0.0	0.0	1	1	1
01/15/2020 02:00	0.0	12.7	2,042.0	0.0	0.0	1	1	1
01/15/2020 03:00	0.0	12.7	2,045.1	0.0	0.0	1	1	1
01/15/2020 04:00	0.0	12.7	2,043.0	0.0	0.0	1	1	1
01/15/2020 05:00	0.0	12.6	2,070.1	0.0	0.0	1	1	1
01/15/2020 06:00	0.0	12.1	2,164.6	0.0	0.0	1	1	1
01/15/2020 07:00	0.0	11.9	2,252.3	0.0	0.0	1	1	1
01/15/2020 08:00	0.0	12.6	2,048.1	0.0	0.0	1	1	1
01/15/2020 09:00	0.0	13.6	1,620.5	0.0	0.0	1	1	0
01/15/2020 10:00	0.0	13.6	1,658.9	0.0	0.0	1	1	0
01/15/2020 11:00	0.0	13.6	1,676.0	0.0	0.0	1	1	0
01/15/2020 12:00	0.0	13.6	1,635.8	0.0	0.0	1	1	0
01/15/2020 13:00	0.0	13.6	1,681.8	0.0	0.0	1	1	0
01/15/2020 14:00	0.0	13.6	1,696.5	0.0	0.0	1	1	0
01/15/2020 15:00	0.0	13.6	1,600.5	0.0	0.0	1	1	1
01/15/2020 16:00	0.0	12.5	2,069.1	0.0	0.0	1	1	1
01/15/2020 17:00	0.0	12.0	2,163.9	0.0	0.0	1	1	1
01/15/2020 18:00	0.0	12.1	2,140.1	0.0	0.0	1	1	1
01/15/2020 19:00	0.0	11.9	2,194.1	0.0	0.0	1	1	1
01/15/2020 20:00	0.0	11.9	2,188.0	0.0	0.0	1	1	1
01/15/2020 21:00	0.0	12.0	2,172.6	0.0	0.0	1	1	1
01/15/2020 22:00	0.0	12.3	2,093.7	0.0	0.0	1	1	1
01/15/2020 23:00	0.0	12.5	2,055.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,974.8	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,600.5	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,252.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2020 00:00	0.0	12.5	2,039.7	0.0	0.0	1	1	1
01/16/2020 01:00	0.0	12.5	2,046.8	0.0	0.0	1	1	1
01/16/2020 02:00	0.0	12.5	2,051.3	0.0	0.0	1	1	1
01/16/2020 03:00	0.0	12.5	2,054.4	0.0	0.0	1	1	1
01/16/2020 04:00	0.0	12.5	2,058.2	0.0	0.0	1	1	1
01/16/2020 05:00	0.0	12.5	2,056.4	0.0	0.0	1	1	1
01/16/2020 06:00	0.0	12.3	2,095.9	0.0	0.0	1	1	1
01/16/2020 07:00	0.0	11.9	2,179.2	0.0	0.0	1	1	1
01/16/2020 08:00	0.0	12.4	2,073.8	0.0	0.0	1	1	1
01/16/2020 09:00	0.0	12.7	1,978.0	0.0	0.0	1	1	1
01/16/2020 10:00	0.0	13.6	1,670.4	0.0	0.0	1	1	0
01/16/2020 11:00	0.0	13.6	1,582.6	0.0	0.0	1	1	0
01/16/2020 12:00	0.0	13.6	1,529.2	0.0	0.0	1	1	0
01/16/2020 13:00	0.0	13.6	1,663.4	0.0	0.0	1	1	0
01/16/2020 14:00	0.0	13.6	1,602.9	0.0	0.0	1	1	0
01/16/2020 15:00	0.0	13.6	1,736.8	0.0	0.0	1	1	1
01/16/2020 16:00	0.0	12.6	2,021.4	0.0	0.0	1	1	1
01/16/2020 17:00	0.0	12.5	2,045.6	0.0	0.0	1	1	1
01/16/2020 18:00	0.0	12.5	2,039.3	0.0	0.0	1	1	1
01/16/2020 19:00	0.0	12.5	2,049.6	0.0	0.0	1	1	1
01/16/2020 20:00	0.0	12.4	2,086.3	0.0	0.0	1	1	1
01/16/2020 21:00	0.0	12.4	2,091.1	0.0	0.0	1	1	1
01/16/2020 22:00	0.0	12.7	2,030.5	0.0	0.0	1	1	1
01/16/2020 23:00	0.0	12.7	2,037.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,950.9	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.9	1,529.2	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,179.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2020 00:00	0.0	12.7	2,045.2	0.0	0.0	1	1	1
01/17/2020 01:00	0.0	12.8	2,021.3	0.0	0.0	1	1	1
01/17/2020 02:00	0.0	12.7	2,042.7	0.0	0.0	1	1	1
01/17/2020 03:00	0.0	12.8	2,041.2	0.0	0.0	1	1	1
01/17/2020 04:00	0.0	12.7	2,050.0	0.0	0.0	1	1	1
01/17/2020 05:00	0.0	12.7	2,064.2	0.0	0.0	1	1	1
01/17/2020 06:00	0.0	12.0	2,193.2	0.0	0.0	1	1	1
01/17/2020 07:00	0.0	11.9	2,248.6	0.0	0.0	1	1	1
01/17/2020 08:00	0.0	12.7	2,057.1	0.0	0.0	1	1	1
01/17/2020 09:00	0.0	12.9	1,983.8	0.0	0.0	1	1	1
01/17/2020 10:00	0.0	13.6	1,692.8	0.0	0.0	1	1	0
01/17/2020 11:00	0.0	13.6	1,637.7	0.0	0.0	1	1	0
01/17/2020 12:00	0.0	13.6	1,669.2	0.0	0.0	1	1	0
01/17/2020 13:00	0.0	13.6	1,656.5	0.0	0.0	1	1	0
01/17/2020 14:00	0.0	13.6	1,632.7	0.0	0.0	1	1	0
01/17/2020 15:00	0.0	13.6	1,517.8	0.0	0.0	1	1	1
01/17/2020 16:00	0.0	12.7	2,010.2	0.0	0.0	1	1	1
01/17/2020 17:00	0.0	12.8	1,972.3	0.0	0.0	1	1	1
01/17/2020 18:00	0.0	12.9	1,979.7	0.0	0.0	1	1	1
01/17/2020 19:00	0.0	12.4	2,087.5	0.0	0.0	1	1	1
01/17/2020 20:00	0.0	12.3	2,116.9	0.0	0.0	1	1	1
01/17/2020 21:00	0.0	12.4	2,106.8	0.0	0.0	1	1	1
01/17/2020 22:00	0.0	12.4	2,086.2	0.0	0.0	1	1	1
01/17/2020 23:00	0.0	12.6	2,065.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,957.5	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.9	1,517.8	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,248.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/18/2020 00:00	0.0	12.6	2,047.8	0.0	0.0	1	1	1
01/18/2020 01:00	0.0	12.6	2,060.0	0.0	0.0	1	1	1
01/18/2020 02:00	0.0	12.7	2,031.0	0.0	0.0	1	1	1
01/18/2020 03:00	0.0	12.7	2,033.6	0.0	0.0	1	1	1
01/18/2020 04:00	0.0	12.7	2,034.3	0.0	0.0	1	1	1
01/18/2020 05:00	0.0	12.7	2,033.7	0.0	0.0	1	1	1
01/18/2020 06:00	0.0	12.7	2,035.8	0.0	0.0	1	1	1
01/18/2020 07:00	0.0	12.7	2,032.1	0.0	0.0	1	1	1
01/18/2020 08:00	0.0	13.0	2,008.0	0.0	0.0	1	1	1
01/18/2020 09:00	0.0	13.6	1,685.4	0.0	0.0	1	1	1
01/18/2020 10:00	0.0	13.6	1,636.9	0.0	0.0	1	1	0
01/18/2020 11:00	0.0	13.6	1,616.7	0.0	0.0	1	1	0
01/18/2020 12:00	0.0	13.6	1,634.4	0.0	0.0	1	1	0
01/18/2020 13:00	0.0	13.6	1,663.8	0.0	0.0	1	1	0
01/18/2020 14:00	0.0	13.6	1,631.3	0.0	0.0	1	1	0
01/18/2020 15:00	0.0	13.6	1,611.6	0.0	0.0	1	1	1
01/18/2020 16:00	0.0	12.7	2,018.3	0.0	0.0	1	1	1
01/18/2020 17:00	0.0	12.6	2,041.6	0.0	0.0	1	1	1
01/18/2020 18:00	0.0	12.9	1,972.5	0.0	0.0	1	1	1
01/18/2020 19:00	0.0	12.5	2,060.4	0.0	0.0	1	1	1
01/18/2020 20:00	0.0	12.3	2,113.0	0.0	0.0	1	1	1
01/18/2020 21:00	0.0	12.3	2,118.6	0.0	0.0	1	1	1
01/18/2020 22:00	0.0	12.2	2,128.9	0.0	0.0	1	1	1
01/18/2020 23:00	0.0	12.3	2,107.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,931.6	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.2	1,611.6	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,128.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/19/2020 00:00	0.0	12.5	2,026.4	0.0	0.0	1	1	1
01/19/2020 01:00	0.0	13.6	1,708.0	0.0	0.0	1	1	0
01/19/2020 02:00	0.0	13.6	1,559.6	0.0	0.0	1	1	0
01/19/2020 03:00	0.0	13.6	1,637.5	0.0	0.0	1	1	0
01/19/2020 04:00	0.0	13.6	1,630.0	0.0	0.0	1	1	0
01/19/2020 05:00	0.0	13.6	1,678.4	0.0	0.0	1	1	0
01/19/2020 06:00	0.0	13.6	1,699.9	0.0	0.0	1	1	0
01/19/2020 07:00	0.0	13.6	1,603.0	0.0	0.0	1	1	0
01/19/2020 08:00	0.0	13.6	1,563.8	0.0	0.0	1	1	0
01/19/2020 09:00	0.0	13.6	1,632.9	0.0	0.0	1	1	0
01/19/2020 10:00	0.0	13.6	1,576.8	0.0	0.0	1	1	0
01/19/2020 11:00	0.0	13.6	1,649.1	0.0	0.0	1	1	0
01/19/2020 12:00	0.0	13.6	1,668.4	0.0	0.0	1	1	0
01/19/2020 13:00	0.0	13.6	1,686.3	0.0	0.0	1	1	0
01/19/2020 14:00	0.0	13.6	1,595.7	0.0	0.0	1	1	0
01/19/2020 15:00	0.0	13.6	1,628.8	0.0	0.0	1	1	0
01/19/2020 16:00	0.0	13.6	1,623.0	0.0	0.0	1	1	1
01/19/2020 17:00	0.0	12.7	2,015.6	0.0	0.0	1	1	1
01/19/2020 18:00	0.0	12.5	2,047.9	0.0	0.0	1	1	1
01/19/2020 19:00	0.0	12.6	2,041.9	0.0	0.0	1	1	1
01/19/2020 20:00	0.0	12.3	2,102.5	0.0	0.0	1	1	1
01/19/2020 21:00	0.0	12.2	2,125.7	0.0	0.0	1	1	1
01/19/2020 22:00	0.0	12.2	2,120.0	0.0	0.0	1	1	1
01/19/2020 23:00	0.0	12.3	2,111.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,780.5	0.0	0.0 #	24 #	24 #	9 #
Minimum:	0.0	12.2	1,559.6	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,125.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2020 00:00	0.0	12.4	2,079.7	0.0	0.0	1	1	1
01/20/2020 01:00	0.0	12.6	2,045.1	0.0	0.0	1	1	1
01/20/2020 02:00	0.0	12.6	2,027.0	0.0	0.0	1	1	1
01/20/2020 03:00	0.0	12.6	2,033.0	0.0	0.0	1	1	1
01/20/2020 04:00	0.0	12.6	2,037.0	0.0	0.0	1	1	1
01/20/2020 05:00	0.0	12.5	2,048.2	0.0	0.0	1	1	1
01/20/2020 06:00	0.0	12.5	2,054.6	0.0	0.0	1	1	1
01/20/2020 07:00	0.0	12.3	2,111.4	0.0	0.0	1	1	1
01/20/2020 08:00	0.0	12.2	2,128.5	0.0	0.0	1	1	1
01/20/2020 09:00	0.0	12.2	2,108.7	0.0	0.0	1	1	1
01/20/2020 10:00	0.0	12.2	2,124.2	0.0	0.0	1	1	1
01/20/2020 11:00	0.0	12.2	2,103.7	0.0	0.0	1	1	1
01/20/2020 12:00	0.0	12.1	2,117.8	0.0	0.0	1	1	1
01/20/2020 13:00	0.0	12.2	2,112.3	0.0	0.0	1	1	1
01/20/2020 14:00	0.0	12.1	2,131.1	0.0	0.0	1	1	1
01/20/2020 15:00	0.0	12.2	2,101.1	0.0	0.0	1	1	1
01/20/2020 16:00	0.0	12.4	2,065.6	0.0	0.0	1	1	1
01/20/2020 17:00	0.0	12.2	2,111.9	0.0	0.0	1	1	1
01/20/2020 18:00	0.0	12.2	2,113.8	0.0	0.0	1	1	1
01/20/2020 19:00	0.0	12.2	2,109.9	0.0	0.0	1	1	1
01/20/2020 20:00	0.0	12.2	2,109.6	0.0	0.0	1	1	1
01/20/2020 21:00	0.0	12.3	2,104.2	0.0	0.0	1	1	1
01/20/2020 22:00	0.0	12.3	2,090.5	0.0	0.0	1	1	1
01/20/2020 23:00	0.0	12.4	2,065.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.3	2,088.9	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.1	2,027.0	0.0	0.0	1	1	1
Maximum:	0.0	12.6	2,131.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2020 00:00	0.0	12.5	2,039.9	0.0	0.0	1	1	1
01/21/2020 01:00	0.0	12.6	2,032.9	0.0	0.0	1	1	1
01/21/2020 02:00	0.0	12.6	2,037.9	0.0	0.0	1	1	1
01/21/2020 03:00	0.0	12.5	2,039.8	0.0	0.0	1	1	1
01/21/2020 04:00	0.0	12.5	2,036.1	0.0	0.0	1	1	1
01/21/2020 05:00	0.0	12.5	2,037.0	0.0	0.0	1	1	1
01/21/2020 06:00	0.0	12.6	2,010.2	0.0	0.0	1	1	1
01/21/2020 07:00	0.0	12.3	2,085.0	0.0	0.0	1	1	1
01/21/2020 08:00	0.0	12.5	2,053.1	0.0	0.0	1	1	1
01/21/2020 09:00	0.0	12.7	1,982.7	0.0	0.0	1	1	1
01/21/2020 10:00	0.0	13.5	1,681.4	0.0	0.0	1	1	1
01/21/2020 11:00	0.0	13.6	1,692.8	0.0	0.0	1	1	0
01/21/2020 12:00	0.0	13.6	1,659.1	0.0	0.0	1	1	0
01/21/2020 13:00	0.0	13.6	1,630.8	0.0	0.0	1	1	0
01/21/2020 14:00	0.0	13.6	1,640.3	0.0	0.0	1	1	0
01/21/2020 15:00	0.0	13.6	1,563.7	0.0	0.0	1	1	1
01/21/2020 16:00	0.0	12.5	2,034.2	0.0	0.0	1	1	1
01/21/2020 17:00	0.0	12.4	2,056.2	0.0	0.0	1	1	1
01/21/2020 18:00	0.0	12.4	2,048.2	0.0	0.0	1	1	1
01/21/2020 19:00	0.0	12.4	2,044.8	0.0	0.0	1	1	1
01/21/2020 20:00	0.0	12.4	2,039.9	0.0	0.0	1	1	1
01/21/2020 21:00	0.0	12.5	2,034.2	0.0	0.0	1	1	1
01/21/2020 22:00	0.0	12.3	2,070.4	0.0	0.0	1	1	1
01/21/2020 23:00	0.0	12.5	2,044.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,941.5	0.0	0.0 #	24 #	24 #	20 #
Minimum:	0.0	12.3	1,563.7	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,085.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/22/2020 00:00	0.0	13.0	1,841.4	0.0	0.0	1	1	1
01/22/2020 01:00	0.0	13.6	1,309.8	0.0	0.0	1	1	0
01/22/2020 02:00	0.0	13.6	1,381.3	0.0	0.0	1	1	0
01/22/2020 03:00	0.0	13.6	1,345.7	0.0	0.0	1	1	0
01/22/2020 04:00	0.0	13.6	1,527.5	0.0	0.0	1	1	0
01/22/2020 05:00	0.0	13.6	1,463.0	0.0	0.0	1	1	0
01/22/2020 06:00	0.0	13.6	1,596.4	0.0	0.0	1	1	0
01/22/2020 07:00	0.0	13.6	1,646.4	0.0	0.0	1	1	0
01/22/2020 08:00	0.0	13.6	1,493.5	0.0	0.0	1	1	0
01/22/2020 09:00	0.0	13.6	1,595.0	0.0	0.0	1	1	0
01/22/2020 10:00	0.0	13.6	1,624.5	0.0	0.0	1	1	0
01/22/2020 11:00	0.0	13.6	1,705.1	0.0	0.0	1	1	0
01/22/2020 12:00	0.0	13.6	1,710.3	0.0	0.0	1	1	0
01/22/2020 13:00	0.0	13.6	1,669.7	0.0	0.0	1	1	0
01/22/2020 14:00	0.0	13.6	1,640.8	0.0	0.0	1	1	0
01/22/2020 15:00	0.0	13.6	1,608.1	0.0	0.0	1	1	1
01/22/2020 16:00	0.0	12.6	2,032.9	0.0	0.0	1	1	1
01/22/2020 17:00	0.0	12.6	2,017.9	0.0	0.0	1	1	1
01/22/2020 18:00	0.0	12.2	2,121.4	0.0	0.0	1	1	1
01/22/2020 19:00	0.0	12.2	2,114.1	0.0	0.0	1	1	1
01/22/2020 20:00	0.0	12.5	2,048.7	0.0	0.0	1	1	1
01/22/2020 21:00	0.0	12.6	2,040.8	0.0	0.0	1	1	1
01/22/2020 22:00	0.0	12.5	2,045.9	0.0	0.0	1	1	1
01/22/2020 23:00	0.0	12.9	1,969.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,731.2	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	12.2	1,309.8	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,121.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2020 00:00	0.0	12.4	2,093.9	0.0	0.0	1	1	1
01/23/2020 01:00	0.0	12.3	2,092.7	0.0	0.0	1	1	1
01/23/2020 02:00	0.0	12.5	2,044.9	0.0	0.0	1	1	1
01/23/2020 03:00	0.0	12.6	2,042.8	0.0	0.0	1	1	1
01/23/2020 04:00	0.0	12.3	2,107.6	0.0	0.0	1	1	1
01/23/2020 05:00	0.0	12.6	2,053.0	0.0	0.0	1	1	1
01/23/2020 06:00	0.0	12.2	2,134.5	0.0	0.0	1	1	1
01/23/2020 07:00	0.0	12.4	2,097.9	0.0	0.0	1	1	1
01/23/2020 08:00	0.0	12.9	1,950.8	0.0	0.0	1	1	1
01/23/2020 09:00	0.0	13.6	1,683.4	0.0	0.0	1	1	0
01/23/2020 10:00	0.0	13.6	1,559.2	0.0	0.0	1	1	0
01/23/2020 11:00	0.0	13.6	1,615.7	0.0	0.0	1	1	0
01/23/2020 12:00	0.0	13.6	1,642.0	0.0	0.0	1	1	0
01/23/2020 13:00	0.0	13.6	1,672.7	0.0	0.0	1	1	0
01/23/2020 14:00	0.0	13.6	1,662.7	0.0	0.0	1	1	0
01/23/2020 15:00	0.0	13.6	1,631.3	0.0	0.0	1	1	0
01/23/2020 16:00	0.0	13.6	1,505.8	0.0	0.0	1	1	0
01/23/2020 17:00	0.0	12.9	1,927.7	0.0	0.0	1	1	1
01/23/2020 18:00	0.0	12.1	2,123.8	0.0	0.0	1	1	1
01/23/2020 19:00	0.0	12.1	2,119.7	0.0	0.0	1	1	1
01/23/2020 20:00	0.0	12.2	2,116.2	0.0	0.0	1	1	1
01/23/2020 21:00	0.0	12.2	2,102.1	0.0	0.0	1	1	1
01/23/2020 22:00	0.0	12.4	2,066.4	0.0	0.0	1	1	1
01/23/2020 23:00	0.0	12.9	1,955.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,916.8	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.1	1,505.8	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,134.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/24/2020 00:00	0.0	12.9	1,936.9	0.0	0.0	1	1	1
01/24/2020 01:00	0.0	13.6	1,646.8	0.0	0.0	1	1	0
01/24/2020 02:00	0.0	13.6	1,665.5	0.0	0.0	1	1	0
01/24/2020 03:00	0.0	13.6	1,699.4	0.0	0.0	1	1	0
01/24/2020 04:00	0.0	13.6	1,701.8	0.0	0.0	1	1	0
01/24/2020 05:00	0.0	13.6	1,600.3	0.0	0.0	1	1	0
01/24/2020 06:00	0.0	13.6	1,657.8	0.0	0.0	1	1	0
01/24/2020 07:00	0.0	13.6	1,654.5	0.0	0.0	1	1	0
01/24/2020 08:00	0.0	13.6	1,597.3	0.0	0.0	1	1	0
01/24/2020 09:00	0.0	13.6	1,669.6	0.0	0.0	1	1	0
01/24/2020 10:00	0.0	13.6	1,482.9	0.0	0.0	1	1	0
01/24/2020 11:00	0.0	13.6	1,665.0	0.0	0.0	1	1	0
01/24/2020 12:00	0.0	13.6	1,639.1	0.0	0.0	1	1	0
01/24/2020 13:00	0.0	13.6	1,681.7	0.0	0.0	1	1	0
01/24/2020 14:00	0.0	13.6	1,653.2	0.0	0.0	1	1	0
01/24/2020 15:00	0.0	13.6	1,557.3	0.0	0.0	1	1	0
01/24/2020 16:00	0.0	13.6	1,589.3	0.0	0.0	1	1	1
01/24/2020 17:00	0.0	12.5	2,029.3	0.0	0.0	1	1	1
01/24/2020 18:00	0.0	12.2	2,115.6	0.0	0.0	1	1	1
01/24/2020 19:00	0.0	12.2	2,112.0	0.0	0.0	1	1	1
01/24/2020 20:00	0.0	12.2	2,104.4	0.0	0.0	1	1	1
01/24/2020 21:00	0.0	12.3	2,077.7	0.0	0.0	1	1	1
01/24/2020 22:00	0.0	12.5	2,048.2	0.0	0.0	1	1	1
01/24/2020 23:00	4.4	13.9	1,278.7	0.0	5.3	1	0	1
Average/Sum#:	0.2	13.3	1,744.3	0.0	5.3 #	24 #	23 #	9 #
Minimum:	0.0	12.2	1,278.7	0.0	0.0	1	0	0
Maximum:	4.4	13.9	2,115.6	0.0	5.3	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/27/2020 18:00	62.5	17.3	476.2	0.0	87.4	1	0	0
01/27/2020 19:00	11.5	16.8	534.7	0.0	19.8	1	0	0
01/27/2020 20:00	27.7	15.3	882.3	0.0	57.6	1	0	0
01/27/2020 21:00	0.0	13.6	1,433.6	0.0	0.0	1	1	0
01/27/2020 22:00	0.0	13.7	1,367.5	0.0	0.0	1	1	0
01/27/2020 23:00	0.0	13.7	1,370.1	0.0	0.0	1	1	0
Average/Sum#:	17.0	15.1	1,010.7	0.0	164.8 #	6 #	3 #	0 #
Minimum:	0.0	13.6	476.2	0.0	0.0	0	0	0
Maximum:	62.5	17.3	1,433.6	0.0	87.4	1	1	0
%SI	75.00	75.00	75.00	95.83	75.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2020 00:00	0.0	13.7	1,367.3	0.0	0.0	1	1	0
01/28/2020 01:00	0.0	13.6	1,362.7	0.0	0.0	1	1	0
01/28/2020 02:00	0.0	13.6	1,362.1	0.0	0.0	1	1	0
01/28/2020 03:00	0.0	13.6	1,634.5	0.0	0.0	1	1	0
01/28/2020 04:00	0.0	13.6	1,495.1	0.0	0.0	1	1	0
01/28/2020 05:00	0.0	13.6	1,602.4	0.0	0.0	1	1	0
01/28/2020 06:00	0.0	13.6	1,703.4	0.0	0.0	1	1	0
01/28/2020 07:00	0.0	13.6	1,611.7	0.0	0.0	1	1	0
01/28/2020 08:00	0.0	13.6	1,672.8	0.0	0.0	1	1	0
01/28/2020 09:00	0.0	13.6	1,687.1	0.0	0.0	1	1	0
01/28/2020 10:00	0.0	13.6	1,538.9	0.0	0.0	1	1	0
01/28/2020 11:00	0.0	13.6	1,621.0	0.0	0.0	1	1	0
01/28/2020 12:00	0.0	13.6	1,613.2	0.0	0.0	1	1	0
01/28/2020 13:00	0.0	13.6	1,671.5	0.0	0.0	1	1	0
01/28/2020 14:00	0.0	13.6	1,580.4	0.0	0.0	1	1	0
01/28/2020 15:00	0.0	13.6	1,569.9	0.0	0.0	1	1	0
01/28/2020 16:00	0.0	13.6	1,573.9	0.0	0.0	1	1	1
01/28/2020 17:00	0.0	12.6	2,024.2	0.0	0.0	1	1	1
01/28/2020 18:00	0.0	12.4	2,066.7	0.0	0.0	1	1	1
01/28/2020 19:00	0.0	12.3	2,086.3	0.0	0.0	1	1	1
01/28/2020 20:00	0.0	12.2	2,113.2	0.0	0.0	1	1	1
01/28/2020 21:00	0.0	12.2	2,112.7	0.0	0.0	1	1	1
01/28/2020 22:00	4.2	13.9	1,290.1	0.0	5.3	1	0	1
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.3	1,667.9	0.0	5.3 #	23 #	22 #	7 #
Minimum:	0.0	12.2	1,290.1	0.0	0.0	0	0	0
Maximum:	4.2	13.9	2,113.2	0.0	5.3	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
01/29/2020 17:00	31.8	17.3	460.5	0.0	37.6	1	0	0
01/29/2020 18:00	21.4	15.9	657.2	0.0	37.1	1	0	0
01/29/2020 19:00	10.4	14.2	1,327.0	0.0	27.2	1	0	0
01/29/2020 20:00	0.0	13.0	1,853.0	0.0	0.0	1	1	1
01/29/2020 21:00	0.0	11.8	2,158.1	0.0	0.0	1	1	1
01/29/2020 22:00	0.0	13.3	1,632.5	0.0	0.0	1	1	1
01/29/2020 23:00	0.0	13.7	1,528.4	0.0	0.0	1	1	0
Average/Sum#:	9.1	14.2	1,373.8	0.0	101.9 #	7 #	4 #	3 #
Minimum:	0.0	11.8	460.5	0.0	0.0	0	0	0
Maximum:	31.8	17.3	2,158.1	0.0	37.6	1	1	1
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2020 00:00	0.0	13.6	1,552.4	0.0	0.0	1	1	0
01/30/2020 01:00	0.0	13.6	1,556.1	0.0	0.0	1	1	0
01/30/2020 02:00	0.0	13.6	1,692.0	0.0	0.0	1	1	0
01/30/2020 03:00	0.0	13.6	1,472.5	0.0	0.0	1	1	0
01/30/2020 04:00	0.0	13.6	1,642.6	0.0	0.0	1	1	0
01/30/2020 05:00	0.0	13.6	1,391.3	0.0	0.0	1	1	0
01/30/2020 06:00	0.0	12.9	1,859.5	0.0	0.0	1	1	1
01/30/2020 07:00	0.0	12.4	2,091.1	0.0	0.0	1	1	1
01/30/2020 08:00	0.0	12.9	1,946.8	0.0	0.0	1	1	1
01/30/2020 09:00	0.0	13.6	1,635.6	0.0	0.0	1	1	0
01/30/2020 10:00	0.0	13.6	1,643.1	0.0	0.0	1	1	0
01/30/2020 11:00	0.0	13.6	1,694.3	0.0	0.0	1	1	0
01/30/2020 12:00	0.0	13.6	1,499.8	0.0	0.0	1	1	0
01/30/2020 13:00	0.0	13.6	1,657.3	0.0	0.0	1	1	0
01/30/2020 14:00	0.0	13.6	1,554.7	0.0	0.0	1	1	0
01/30/2020 15:00	0.0	13.6	1,633.8	0.0	0.0	1	1	0
01/30/2020 16:00	0.0	13.6	1,516.4	0.0	0.0	1	1	0
01/30/2020 17:00	0.0	13.6	1,642.3	0.0	0.0	1	1	0
01/30/2020 18:00	0.0	13.6	1,718.5	0.0	0.0	1	1	1
01/30/2020 19:00	0.0	12.4	2,025.8	0.0	0.0	1	1	1
01/30/2020 20:00	0.0	12.0	2,117.0	0.0	0.0	1	1	1
01/30/2020 21:00	0.0	12.1	2,100.4	0.0	0.0	1	1	1
01/30/2020 22:00	0.0	12.3	2,053.8	0.0	0.0	1	1	1
01/30/2020 23:00	0.0	13.2	1,755.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,727.2	0.0	0.0 #	24 #	24 #	9 #
Minimum:	0.0	12.0	1,391.3	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,117.0	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
01/31/2020 00:00	0.0	13.7	1,427.0	0.0	0.0	1	1	0
01/31/2020 01:00	0.0	13.7	1,387.7	0.0	0.0	1	1	0
01/31/2020 02:00	0.0	13.7	1,385.5	0.0	0.0	1	1	0
01/31/2020 03:00	0.0	13.6	1,396.6	0.0	0.0	1	1	0
01/31/2020 04:00	0.0	13.6	1,463.0	0.0	0.0	1	1	0
01/31/2020 05:00	0.0	13.6	1,703.6	0.0	0.0	1	1	0
01/31/2020 06:00	0.0	13.6	1,548.2	0.0	0.0	1	1	0
01/31/2020 07:00	0.0	13.6	1,599.8	0.0	0.0	1	1	0
01/31/2020 08:00	0.0	13.6	1,532.8	0.0	0.0	1	1	0
01/31/2020 09:00	0.0	13.6	1,630.4	0.0	0.0	1	1	0
01/31/2020 10:00	0.0	13.6	1,643.8	0.0	0.0	1	1	0
01/31/2020 11:00	0.0	13.6	1,650.4	0.0	0.0	1	1	0
01/31/2020 12:00	0.0	13.6	1,623.4	0.0	0.0	1	1	0
01/31/2020 13:00	0.0	13.6	1,697.8	0.0	0.0	1	1	0
01/31/2020 14:00	0.0	13.6	1,685.6	0.0	0.0	1	1	0
01/31/2020 15:00	0.0	13.6	1,670.4	0.0	0.0	1	1	0
01/31/2020 16:00	0.0	13.7	1,488.7	0.0	0.0	1	1	0
01/31/2020 17:00	0.0	13.6	1,679.8	0.0	0.0	1	1	0
01/31/2020 18:00	0.0	13.1	1,828.9	0.0	0.0	1	1	1
01/31/2020 19:00	0.0	12.5	2,014.8	0.0	0.0	1	1	1
01/31/2020 20:00	0.0	12.2	2,098.2	0.0	0.0	1	1	1
01/31/2020 21:00	0.0	12.2	2,099.3	0.0	0.0	1	1	1
01/31/2020 22:00	0.0	12.2	2,092.4	0.0	0.0	1	1	1
01/31/2020 23:00	4.6	14.0	1,276.7	0.0	5.8	1	0	1
Average/Sum#:	0.2	13.4	1,651.0	0.0	5.8 #	24 #	23 #	6 #
Minimum:	0.0	12.2	1,276.7	0.0	0.0	1	0	0
Maximum:	4.6	14.0	2,099.3	0.0	5.8	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/02/2020 23:00	53.7	17.3	477.5	0.0	73.4	1	0	0
Average/Sum#:	53.7	17.3	477.5	0.0	73.4 #	1 #	0 #	0 #
Minimum:	53.7	17.3	477.5	0.0	73.4	0	0	0
Maximum:	53.7	17.3	477.5	0.0	73.4	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/03/2020 00:00	10.3	16.9	528.4	0.0	18.0	1	0	0
02/03/2020 01:00	31.1	15.9	715.4	0.0	58.8	1	0	0
02/03/2020 02:00	0.0	13.7	1,442.4	0.0	0.0	1	0	0
02/03/2020 03:00	0.0	13.7	1,465.0	0.0	0.0	1	1	0
02/03/2020 04:00	0.0	13.6	1,708.3	0.0	0.0	1	1	0
02/03/2020 05:00	0.0	13.7	1,559.5	0.0	0.0	1	1	0
02/03/2020 06:00	0.0	13.6	1,710.4	0.0	0.0	1	1	0
02/03/2020 07:00	0.0	13.6	1,622.5	0.0	0.0	1	1	0
02/03/2020 08:00	0.0	13.7	1,552.9	0.0	0.0	1	1	0
02/03/2020 09:00	0.0	13.7	1,483.7	0.0	0.0	1	1	0
02/03/2020 10:00	0.0	13.7	1,566.7	0.0	0.0	1	1	0
02/03/2020 11:00	0.0	13.7	1,701.3	0.0	0.0	1	1	0
02/03/2020 12:00	0.0	13.7	1,664.6	0.0	0.0	1	1	0
02/03/2020 13:00	0.0	13.7	1,651.6	0.0	0.0	1	1	0
02/03/2020 14:00	0.0	13.7	1,575.5	0.0	0.0	1	1	0
02/03/2020 15:00	0.0	13.7	1,666.2	0.0	0.0	1	1	0
02/03/2020 16:00	0.0	13.7	1,593.4	0.0	0.0	1	1	1
02/03/2020 17:00	0.0	12.6	2,059.2	0.0	0.0	1	1	1
02/03/2020 18:00	0.0	11.9	2,216.8	0.0	0.0	1	1	1
02/03/2020 19:00	0.0	11.8	2,245.3	0.0	0.0	1	1	1
02/03/2020 20:00	0.0	11.8	2,248.2	0.0	0.0	1	1	1
02/03/2020 21:00	0.0	12.3	2,139.4	0.0	0.0	1	1	1
02/03/2020 22:00	0.0	12.3	2,127.7	0.0	0.0	1	1	1
02/03/2020 23:00	0.0	12.5	2,097.2	0.0	0.0	1	1	1
Average/Sum#:	1.7	13.5	1,680.9	0.0	76.8 #	24 #	21 #	8 #
Minimum:	0.0	11.8	528.4	0.0	0.0	1	0	0
Maximum:	31.1	16.9	2,248.2	0.0	58.8	1	1	1
%SI	0.00	0.00	0.00	20.83	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/04/2020 00:00	0.0	12.6	2,067.0	0.0	0.0	1	1	1
02/04/2020 01:00	0.0	12.7	2,043.7	0.0	0.0	1	1	1
02/04/2020 02:00	0.0	12.7	2,047.7	0.0	0.0	1	1	1
02/04/2020 03:00	0.0	12.7	2,042.3	0.0	0.0	1	1	1
02/04/2020 04:00	0.0	12.6	2,066.5	0.0	0.0	1	1	1
02/04/2020 05:00	0.0	12.5	2,099.2	0.0	0.0	1	1	1
02/04/2020 06:00	0.0	12.2	2,145.7	0.0	0.0	1	1	1
02/04/2020 07:00	0.0	12.2	2,164.2	0.0	0.0	1	1	1
02/04/2020 08:00	0.0	12.6	2,041.1	0.0	0.0	1	1	1
02/04/2020 09:00	0.0	13.7	1,764.2	0.0	0.0	1	1	0
02/04/2020 10:00	0.0	13.7	1,764.5	0.0	0.0	1	1	0
02/04/2020 11:00	0.0	13.7	1,764.1	0.0	0.0	1	1	0
02/04/2020 12:00	0.0	13.7	1,764.6	0.0	0.0	1	1	0
02/04/2020 13:00	0.0	13.7	1,765.0	0.0	0.0	1	1	0
02/04/2020 14:00	0.0	13.7	1,765.6	0.0	0.0	1	1	0
02/04/2020 15:00	0.0	13.7	1,765.7	0.0	0.0	1	1	0
02/04/2020 16:00	0.0	13.3	1,836.9	0.0	0.0	1	1	1
02/04/2020 17:00	0.0	12.8	1,997.4	0.0	0.0	1	1	1
02/04/2020 18:00	0.0	12.3	2,119.1	0.0	0.0	1	1	1
02/04/2020 19:00	0.0	12.0	2,181.9	0.0	0.0	1	1	1
02/04/2020 20:00	0.0	12.1	2,167.2	0.0	0.0	1	1	1
02/04/2020 21:00	0.0	11.9	2,225.3	0.0	0.0	1	1	1
02/04/2020 22:00	0.0	12.3	2,108.0	0.0	0.0	1	1	1
02/04/2020 23:00	0.0	12.4	2,088.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,991.5	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,764.1	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,225.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/05/2020 00:00	0.0	12.3	2,109.0	0.0	0.0	1	1	1
02/05/2020 01:00	0.0	12.5	2,078.8	0.0	0.0	1	1	1
02/05/2020 02:00	0.0	12.6	2,047.2	0.0	0.0	1	1	1
02/05/2020 03:00	0.0	12.6	2,046.5	0.0	0.0	1	1	1
02/05/2020 04:00	0.0	12.5	2,067.8	0.0	0.0	1	1	1
02/05/2020 05:00	0.0	12.8	1,996.5	0.0	0.0	1	1	1
02/05/2020 06:00	0.0	12.7	2,015.4	0.0	0.0	1	1	1
02/05/2020 07:00	0.0	12.0	2,185.5	0.0	0.0	1	1	1
02/05/2020 08:00	0.0	12.5	2,067.4	0.0	0.0	1	1	1
02/05/2020 09:00	0.0	12.9	1,956.4	0.0	0.0	1	1	1
02/05/2020 10:00	0.0	13.6	1,617.9	0.0	0.0	1	1	0
02/05/2020 11:00	0.0	13.6	1,623.0	0.0	0.0	1	1	0
02/05/2020 12:00	0.0	13.6	1,671.3	0.0	0.0	1	1	0
02/05/2020 13:00	0.0	13.6	1,671.8	0.0	0.0	1	1	0
02/05/2020 14:00	0.0	13.7	1,597.6	0.0	0.0	1	1	0
02/05/2020 15:00	0.0	13.6	1,685.0	0.0	0.0	1	1	0
02/05/2020 16:00	0.0	13.2	1,837.1	0.0	0.0	1	1	1
02/05/2020 17:00	0.0	12.8	1,973.5	0.0	0.0	1	1	1
02/05/2020 18:00	0.0	12.0	2,168.5	0.0	0.0	1	1	1
02/05/2020 19:00	0.0	12.1	2,119.6	0.0	0.0	1	1	1
02/05/2020 20:00	0.0	12.1	2,144.6	0.0	0.0	1	1	1
02/05/2020 21:00	0.0	12.3	2,102.4	0.0	0.0	1	1	1
02/05/2020 22:00	0.0	12.2	2,114.5	0.0	0.0	1	1	1
02/05/2020 23:00	0.0	12.4	2,056.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,956.4	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.0	1,597.6	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,185.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/06/2020 00:00	0.0	12.6	2,026.4	0.0	0.0	1	1	1
02/06/2020 01:00	0.0	12.7	2,008.0	0.0	0.0	1	1	1
02/06/2020 02:00	0.0	12.8	2,007.0	0.0	0.0	1	1	1
02/06/2020 03:00	0.0	12.7	2,028.1	0.0	0.0	1	1	1
02/06/2020 04:00	0.0	12.7	2,018.4	0.0	0.0	1	1	1
02/06/2020 05:00	0.0	12.7	2,042.6	0.0	0.0	1	1	1
02/06/2020 06:00	0.0	12.3	2,070.9	0.0	0.0	1	1	1
02/06/2020 07:00	0.0	12.4	2,087.5	0.0	0.0	1	1	1
02/06/2020 08:00	0.0	13.0	1,940.7	0.0	0.0	1	1	1
02/06/2020 09:00	0.0	13.6	1,701.3	0.0	0.0	1	1	0
02/06/2020 10:00	0.0	13.6	1,689.3	0.0	0.0	1	1	0
02/06/2020 11:00	0.0	13.6	1,690.2	0.0	0.0	1	1	0
02/06/2020 12:00	0.0	13.6	1,598.3	0.0	0.0	1	1	0
02/06/2020 13:00	0.0	13.6	1,688.1	0.0	0.0	1	1	0
02/06/2020 14:00	0.0	13.6	1,670.8	0.0	0.0	1	1	0
02/06/2020 15:00	0.0	13.6	1,553.6	0.0	0.0	1	1	0
02/06/2020 16:00	0.0	13.6	1,572.1	0.0	0.0	1	1	1
02/06/2020 17:00	0.0	12.6	2,001.0	0.0	0.0	1	1	1
02/06/2020 18:00	0.0	12.2	2,095.8	0.0	0.0	1	1	1
02/06/2020 19:00	0.0	12.2	2,088.1	0.0	0.0	1	1	1
02/06/2020 20:00	0.0	12.2	2,105.0	0.0	0.0	1	1	1
02/06/2020 21:00	0.0	12.2	2,107.5	0.0	0.0	1	1	1
02/06/2020 22:00	0.0	12.3	2,084.1	0.0	0.0	1	1	1
02/06/2020 23:00	0.0	12.9	1,948.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,909.3	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.2	1,553.6	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,107.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/07/2020 00:00	0.0	12.9	1,928.1	0.0	0.0	1	1	1
02/07/2020 01:00	0.0	13.6	1,705.0	0.0	0.0	1	1	0
02/07/2020 02:00	0.0	13.6	1,570.0	0.0	0.0	1	1	0
02/07/2020 03:00	0.0	13.6	1,566.2	0.0	0.0	1	1	0
02/07/2020 04:00	0.0	13.6	1,535.6	0.0	0.0	1	1	0
02/07/2020 05:00	0.0	13.6	1,566.2	0.0	0.0	1	1	1
02/07/2020 06:00	0.0	12.5	2,036.5	0.0	0.0	1	1	1
02/07/2020 07:00	0.0	12.4	2,086.5	0.0	0.0	1	1	1
02/07/2020 08:00	0.0	12.9	1,960.4	0.0	0.0	1	1	1
02/07/2020 09:00	0.0	13.6	1,654.0	0.0	0.0	1	1	0
02/07/2020 10:00	0.0	13.6	1,668.8	0.0	0.0	1	1	0
02/07/2020 11:00	0.0	13.6	1,699.5	0.0	0.0	1	1	0
02/07/2020 12:00	0.0	13.6	1,701.9	0.0	0.0	1	1	0
02/07/2020 13:00	0.0	13.6	1,699.7	0.0	0.0	1	1	0
02/07/2020 14:00	0.0	13.6	1,669.1	0.0	0.0	1	1	0
02/07/2020 15:00	0.0	13.6	1,686.0	0.0	0.0	1	1	0
02/07/2020 16:00	0.0	13.6	1,598.3	0.0	0.0	1	1	1
02/07/2020 17:00	0.0	12.5	2,017.1	0.0	0.0	1	1	1
02/07/2020 18:00	0.0	12.1	2,105.8	0.0	0.0	1	1	1
02/07/2020 19:00	0.0	12.2	2,086.5	0.0	0.0	1	1	1
02/07/2020 20:00	0.0	12.2	2,098.2	0.0	0.0	1	1	1
02/07/2020 21:00	0.0	12.2	2,097.1	0.0	0.0	1	1	1
02/07/2020 22:00	0.0	12.4	2,050.2	0.0	0.0	1	1	1
02/07/2020 23:00	5.0	14.1	1,248.0	0.0	6.1	1	0	1
Average/Sum#:	0.2	13.1	1,793.1	0.0	6.1 #	24 #	23 #	13 #
Minimum:	0.0	12.1	1,248.0	0.0	0.0	1	0	0
Maximum:	5.0	14.1	2,105.8	0.0	6.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/09/2020 23:00	55.9	17.3	470.6	0.0	67.6	1	0	0
Average/Sum#:	55.9	17.3	470.6	0.0	67.6 #	1 #	0 #	0 #
Minimum:	55.9	17.3	470.6	0.0	67.6	0	0	0
Maximum:	55.9	17.3	470.6	0.0	67.6	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2020 00:00	27.1	15.6	706.4	0.0	47.7	1	0	0
02/10/2020 01:00	21.2	14.8	998.4	0.0	45.8	1	0	0
02/10/2020 02:00	0.0	13.7	1,443.5	0.0	0.0	1	1	0
02/10/2020 03:00	0.0	13.7	1,376.4	0.0	0.0	1	1	0
02/10/2020 04:00	0.0	13.7	1,512.6	0.0	0.0	1	1	0
02/10/2020 05:00	0.0	13.7	1,436.5	0.0	0.0	1	1	0
02/10/2020 06:00	0.0	13.7	1,700.8	0.0	0.0	1	1	0
02/10/2020 07:00	0.0	13.7	1,705.2	0.0	0.0	1	1	0
02/10/2020 08:00	0.0	13.7	1,662.0	0.0	0.0	1	1	0
02/10/2020 09:00	0.0	13.7	1,663.7	0.0	0.0	1	1	0
02/10/2020 10:00	0.0	13.7	1,645.9	0.0	0.0	1	1	0
02/10/2020 11:00	0.0	13.7	1,677.2	0.0	0.0	1	1	0
02/10/2020 12:00	0.0	13.7	1,676.1	0.0	0.0	1	1	0
02/10/2020 13:00	0.0	13.7	1,661.2	0.0	0.0	1	1	0
02/10/2020 14:00	0.0	13.7	1,658.8	0.0	0.0	1	1	0
02/10/2020 15:00	0.0	13.7	1,667.9	0.0	0.0	1	1	0
02/10/2020 16:00	0.0	13.7	1,697.8	0.0	0.0	1	1	0
02/10/2020 17:00	0.0	13.2	1,841.8	0.0	0.0	1	1	1
02/10/2020 18:00	0.0	12.5	2,055.5	0.0	0.0	1	1	1
02/10/2020 19:00	0.0	12.4	2,070.2	0.0	0.0	1	1	1
02/10/2020 20:00	0.0	12.3	2,107.7	0.0	0.0	1	1	1
02/10/2020 21:00	0.0	12.2	2,115.8	0.0	0.0	1	1	1
02/10/2020 22:00	0.0	12.3	2,088.6	0.0	0.0	1	1	1
02/10/2020 23:00	0.0	12.6	2,033.7	0.0	0.0	1	1	1
Average/Sum#:	2.0	13.5	1,675.2	0.0	93.5 #	24 #	22 #	7 #
Minimum:	0.0	12.2	706.4	0.0	0.0	1	0	0
Maximum:	27.1	15.6	2,115.8	0.0	47.7	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/11/2020 00:00	0.0	13.0	1,930.1	0.0	0.0	1	1	1
02/11/2020 01:00	0.0	13.7	1,574.3	0.0	0.0	1	1	0
02/11/2020 02:00	0.0	13.7	1,475.4	0.0	0.0	1	1	0
02/11/2020 03:00	0.0	13.7	1,546.6	0.0	0.0	1	1	0
02/11/2020 04:00	0.0	13.7	1,518.7	0.0	0.0	1	1	0
02/11/2020 05:00	0.0	13.7	1,648.0	0.0	0.0	1	1	0
02/11/2020 06:00	0.0	13.7	1,649.7	0.0	0.0	1	1	0
02/11/2020 07:00	0.0	13.7	1,582.7	0.0	0.0	1	1	0
02/11/2020 08:00	0.0	13.8	1,389.4	0.0	0.0	1	1	0
02/11/2020 09:00	0.0	13.7	1,555.8	0.0	0.0	1	1	0
02/11/2020 10:00	0.0	13.7	1,609.2	0.0	0.0	1	1	0
02/11/2020 11:00	0.0	13.7	1,628.7	0.0	0.0	1	1	0
02/11/2020 12:00	0.0	13.7	1,665.8	0.0	0.0	1	1	0
02/11/2020 13:00	0.0	13.7	1,683.9	0.0	0.0	1	1	0
02/11/2020 14:00	0.0	13.7	1,660.1	0.0	0.0	1	1	0
02/11/2020 15:00	0.0	13.7	1,539.4	0.0	0.0	1	1	0
02/11/2020 16:00	0.0	13.7	1,481.3	0.0	0.0	1	1	0
02/11/2020 17:00	0.0	13.7	1,625.5	0.0	0.0	1	1	0
02/11/2020 18:00	0.0	13.1	1,842.5	0.0	0.0	1	1	1
02/11/2020 19:00	0.0	12.1	2,091.3	0.0	0.0	1	1	1
02/11/2020 20:00	0.0	12.0	2,110.7	0.0	0.0	1	1	1
02/11/2020 21:00	0.0	11.9	2,141.6	0.0	0.0	1	1	1
02/11/2020 22:00	0.0	12.0	2,120.6	0.0	0.0	1	1	1
02/11/2020 23:00	0.0	12.3	2,068.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,714.2	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	11.9	1,389.4	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,141.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/12/2020 00:00	0.0	12.8	1,926.8	0.0	0.0	1	1	1
02/12/2020 01:00	0.0	13.7	1,569.9	0.0	0.0	1	1	0
02/12/2020 02:00	0.0	13.7	1,548.8	0.0	0.0	1	1	0
02/12/2020 03:00	0.0	13.7	1,507.2	0.0	0.0	1	1	0
02/12/2020 04:00	0.0	13.7	1,660.3	0.0	0.0	1	1	0
02/12/2020 05:00	0.0	13.7	1,664.6	0.0	0.0	1	1	0
02/12/2020 06:00	0.0	13.7	1,623.6	0.0	0.0	1	1	0
02/12/2020 07:00	0.0	13.7	1,562.6	0.0	0.0	1	1	0
02/12/2020 08:00	0.0	13.7	1,702.2	0.0	0.0	1	1	0
02/12/2020 09:00	0.0	13.7	1,692.8	0.0	0.0	1	1	0
02/12/2020 10:00	0.0	13.7	1,679.8	0.0	0.0	1	1	0
02/12/2020 11:00	0.0	13.7	1,680.9	0.0	0.0	1	1	0
02/12/2020 12:00	0.0	13.7	1,645.0	0.0	0.0	1	1	0
02/12/2020 13:00	0.0	13.7	1,689.5	0.0	0.0	1	1	0
02/12/2020 14:00	0.0	13.7	1,630.2	0.0	0.0	1	1	0
02/12/2020 15:00	0.0	13.7	1,617.6	0.0	0.0	1	1	0
02/12/2020 16:00	0.0	13.7	1,413.7	0.0	0.0	1	1	0
02/12/2020 17:00	0.0	13.7	1,634.9	0.0	0.0	1	1	0
02/12/2020 18:00	0.0	13.7	1,707.7	0.0	0.0	1	1	1
02/12/2020 19:00	0.0	12.4	2,026.9	0.0	0.0	1	1	1
02/12/2020 20:00	0.0	12.0	2,121.7	0.0	0.0	1	1	1
02/12/2020 21:00	0.0	12.1	2,104.2	0.0	0.0	1	1	1
02/12/2020 22:00	0.0	12.1	2,099.4	0.0	0.0	1	1	1
02/12/2020 23:00	0.0	12.4	2,048.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.4	1,731.6	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.0	1,413.7	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,121.7	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2020 00:00	0.0	12.4	2,048.4	0.0	0.0	1	1	1
02/13/2020 01:00	0.0	12.6	2,017.6	0.0	0.0	1	1	1
02/13/2020 02:00	0.0	12.6	2,021.7	0.0	0.0	1	1	1
02/13/2020 03:00	0.0	12.6	2,031.1	0.0	0.0	1	1	1
02/13/2020 04:00	0.0	12.6	2,028.8	0.0	0.0	1	1	1
02/13/2020 05:00	0.0	12.6	2,037.2	0.0	0.0	1	1	1
02/13/2020 06:00	0.0	12.1	2,132.4	0.0	0.0	1	1	1
02/13/2020 07:00	0.0	12.4	2,075.9	0.0	0.0	1	1	1
02/13/2020 08:00	0.0	13.0	1,932.9	0.0	0.0	1	1	1
02/13/2020 09:00	0.0	13.6	1,665.6	0.0	0.0	1	1	0
02/13/2020 10:00	0.0	13.6	1,654.7	0.0	0.0	1	1	0
02/13/2020 11:00	0.0	13.7	1,662.2	0.0	0.0	1	1	0
02/13/2020 12:00	0.0	13.7	1,690.0	0.0	0.0	1	1	0
02/13/2020 13:00	0.0	13.7	1,624.3	0.0	0.0	1	1	0
02/13/2020 14:00	0.0	13.7	1,640.4	0.0	0.0	1	1	0
02/13/2020 15:00	0.0	13.7	1,591.0	0.0	0.0	1	1	0
02/13/2020 16:00	0.0	13.6	1,599.3	0.0	0.0	1	1	1
02/13/2020 17:00	0.0	12.5	2,006.2	0.0	0.0	1	1	1
02/13/2020 18:00	0.0	12.1	2,092.0	0.0	0.0	1	1	1
02/13/2020 19:00	0.0	12.1	2,105.6	0.0	0.0	1	1	1
02/13/2020 20:00	0.0	12.1	2,101.3	0.0	0.0	1	1	1
02/13/2020 21:00	0.0	12.1	2,103.7	0.0	0.0	1	1	1
02/13/2020 22:00	0.0	12.3	2,088.7	0.0	0.0	1	1	1
02/13/2020 23:00	0.0	12.3	2,080.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,918.0	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,591.0	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,132.4	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/14/2020 00:00	2.2	13.5	1,589.0	0.0	6.0	1	0	1
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	2.2	13.5	1,589.0	0.0	6.0 #	1 #	0 #	1 #
Minimum:	2.2	13.5	1,589.0	0.0	6.0	0	0	0
Maximum:	2.2	13.5	1,589.0	0.0	6.0	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/17/2020 09:00	49.9	17.3	473.6	0.0	71.1	1	0	0
02/17/2020 10:00	8.5	16.9	528.5	0.0	14.8	1	0	0
02/17/2020 11:00	24.3	16.0	660.9	0.0	43.3	1	0	0
02/17/2020 12:00	27.7	15.0	968.9	0.0	60.1	1	0	0
02/17/2020 13:00	0.0	13.7	1,393.2	0.0	0.0	1	1	0
02/17/2020 14:00	0.0	13.7	1,392.7	0.0	0.0	1	1	0
02/17/2020 15:00	0.0	13.7	1,620.5	0.0	0.0	1	1	0
02/17/2020 16:00	0.0	13.7	1,517.4	0.0	0.0	1	1	0
02/17/2020 17:00	0.0	13.7	1,693.1	0.0	0.0	1	1	0
02/17/2020 18:00	0.0	13.7	1,746.3	0.0	0.0	1	1	1
02/17/2020 19:00	0.0	12.6	2,017.8	0.0	0.0	1	1	1
02/17/2020 20:00	0.0	12.1	2,129.0	0.0	0.0	1	1	1
02/17/2020 21:00	0.0	12.1	2,118.2	0.0	0.0	1	1	1
02/17/2020 22:00	0.0	12.2	2,099.4	0.0	0.0	1	1	1
02/17/2020 23:00	0.0	12.5	2,054.0	0.0	0.0	1	1	1
Average/Sum#:	7.4	13.9	1,494.2	0.0	189.3 #	15 #	11 #	6 #
Minimum:	0.0	12.1	473.6	0.0	0.0	0	0	0
Maximum:	49.9	17.3	2,129.0	0.0	71.1	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/18/2020 00:00	0.0	12.5	2,047.5	0.0	0.0	1	1	1
02/18/2020 01:00	0.0	12.5	2,046.5	0.0	0.0	1	1	1
02/18/2020 02:00	0.0	12.6	2,022.3	0.0	0.0	1	1	1
02/18/2020 03:00	0.0	12.5	2,046.4	0.0	0.0	1	1	1
02/18/2020 04:00	0.0	12.5	2,048.8	0.0	0.0	1	1	1
02/18/2020 05:00	0.0	12.4	2,068.8	0.0	0.0	1	1	1
02/18/2020 06:00	0.0	12.3	2,105.3	0.0	0.0	1	1	1
02/18/2020 07:00	0.0	12.3	2,104.8	0.0	0.0	1	1	1
02/18/2020 08:00	0.0	12.5	2,060.0	0.0	0.0	1	1	1
02/18/2020 09:00	0.0	12.9	1,957.3	0.0	0.0	1	1	1
02/18/2020 10:00	0.0	13.0	1,955.7	0.0	0.0	1	1	1
02/18/2020 11:00	0.0	13.0	1,953.4	0.0	0.0	1	1	1
02/18/2020 12:00	0.0	13.0	1,950.7	0.0	0.0	1	1	1
02/18/2020 13:00	0.0	13.4	1,773.7	0.0	0.0	1	1	1
02/18/2020 14:00	0.0	13.7	1,414.9	0.0	0.0	1	1	0
02/18/2020 15:00	0.0	13.7	1,503.6	0.0	0.0	1	1	1
02/18/2020 16:00	0.0	12.7	2,015.5	0.0	0.0	1	1	1
02/18/2020 17:00	0.0	12.1	2,134.8	0.0	0.0	1	1	1
02/18/2020 18:00	0.0	12.1	2,153.0	0.0	0.0	1	1	1
02/18/2020 19:00	0.0	11.9	2,196.2	0.0	0.0	1	1	1
02/18/2020 20:00	0.0	11.9	2,196.0	0.0	0.0	1	1	1
02/18/2020 21:00	0.0	12.0	2,149.6	0.0	0.0	1	1	1
02/18/2020 22:00	0.0	12.2	2,109.3	0.0	0.0	1	1	1
02/18/2020 23:00	0.0	12.5	2,053.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,002.8	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.9	1,414.9	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,196.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2020 00:00	0.0	11.9	2,212.6	0.0	0.0	1	1	1
02/19/2020 01:00	0.0	12.6	2,032.5	0.0	0.0	1	1	1
02/19/2020 02:00	0.0	13.0	1,942.7	0.0	0.0	1	1	1
02/19/2020 03:00	0.0	13.0	1,943.9	0.0	0.0	1	1	1
02/19/2020 04:00	0.0	12.5	2,066.0	0.0	0.0	1	1	1
02/19/2020 05:00	0.0	12.4	2,094.6	0.0	0.0	1	1	1
02/19/2020 06:00	0.0	12.2	2,100.0	0.0	0.0	1	1	1
02/19/2020 07:00	0.0	12.0	2,178.1	0.0	0.0	1	1	1
02/19/2020 08:00	0.0	12.8	1,995.8	0.0	0.0	1	1	1
02/19/2020 09:00	0.0	13.0	1,946.8	0.0	0.0	1	1	1
02/19/2020 10:00	0.0	13.0	1,947.3	0.0	0.0	1	1	1
02/19/2020 11:00	0.0	13.0	1,948.8	0.0	0.0	1	1	1
02/19/2020 12:00	0.0	13.0	1,949.5	0.0	0.0	1	1	1
02/19/2020 13:00	0.0	13.0	1,948.8	0.0	0.0	1	1	1
02/19/2020 14:00	0.0	13.0	1,945.4	0.0	0.0	1	1	1
02/19/2020 15:00	0.0	13.0	1,941.5	0.0	0.0	1	1	1
02/19/2020 16:00	0.0	12.6	2,035.5	0.0	0.0	1	1	1
02/19/2020 17:00	0.0	12.1	2,108.7	0.0	0.0	1	1	1
02/19/2020 18:00	0.0	12.1	2,113.8	0.0	0.0	1	1	1
02/19/2020 19:00	0.0	11.8	2,176.3	0.0	0.0	1	1	1
02/19/2020 20:00	0.0	11.9	2,164.0	0.0	0.0	1	1	1
02/19/2020 21:00	0.0	12.0	2,159.2	0.0	0.0	1	1	1
02/19/2020 22:00	0.0	12.4	2,051.8	0.0	0.0	1	1	1
02/19/2020 23:00	0.0	12.5	2,046.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,043.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,941.5	0.0	0.0	1	1	1
Maximum:	0.0	13.0	2,212.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/20/2020 00:00	0.0	12.7	2,026.1	0.0	0.0	1	1	1
02/20/2020 01:00	0.0	12.6	2,040.0	0.0	0.0	1	1	1
02/20/2020 02:00	0.0	12.6	2,042.7	0.0	0.0	1	1	1
02/20/2020 03:00	0.0	12.6	2,038.6	0.0	0.0	1	1	1
02/20/2020 04:00	0.0	12.5	2,037.9	0.0	0.0	1	1	1
02/20/2020 05:00	0.0	12.6	2,053.2	0.0	0.0	1	1	1
02/20/2020 06:00	0.0	12.5	2,070.2	0.0	0.0	1	1	1
02/20/2020 07:00	0.0	12.5	2,078.3	0.0	0.0	1	1	1
02/20/2020 08:00	0.0	12.6	2,044.8	0.0	0.0	1	1	1
02/20/2020 09:00	0.0	12.9	1,952.5	0.0	0.0	1	1	1
02/20/2020 10:00	0.0	13.0	1,949.9	0.0	0.0	1	1	1
02/20/2020 11:00	0.0	13.0	1,948.0	0.0	0.0	1	1	1
02/20/2020 12:00	0.0	12.9	1,949.6	0.0	0.0	1	1	1
02/20/2020 13:00	0.0	12.9	1,950.1	0.0	0.0	1	1	1
02/20/2020 14:00	0.0	12.8	1,963.6	0.0	0.0	1	1	1
02/20/2020 15:00	0.0	12.7	1,995.9	0.0	0.0	1	1	1
02/20/2020 16:00	0.0	12.4	2,076.7	0.0	0.0	1	1	1
02/20/2020 17:00	0.0	12.3	2,087.7	0.0	0.0	1	1	1
02/20/2020 18:00	0.0	12.3	2,089.7	0.0	0.0	1	1	1
02/20/2020 19:00	0.0	12.3	2,087.8	0.0	0.0	1	1	1
02/20/2020 20:00	0.0	12.2	2,088.0	0.0	0.0	1	1	1
02/20/2020 21:00	0.0	12.2	2,098.3	0.0	0.0	1	1	1
02/20/2020 22:00	0.0	12.2	2,086.1	0.0	0.0	1	1	1
02/20/2020 23:00	0.0	12.5	2,023.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	2,032.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.2	1,948.0	0.0	0.0	1	1	1
Maximum:	0.0	13.0	2,098.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/21/2020 00:00	0.0	12.9	1,915.5	0.0	0.0	1	1	1
02/21/2020 01:00	0.0	13.7	1,540.2	0.0	0.0	1	1	0
02/21/2020 02:00	0.0	13.7	1,484.5	0.0	0.0	1	1	0
02/21/2020 03:00	0.0	13.7	1,567.0	0.0	0.0	1	1	0
02/21/2020 04:00	0.0	13.7	1,685.5	0.0	0.0	1	1	0
02/21/2020 05:00	0.0	13.7	1,590.9	0.0	0.0	1	1	0
02/21/2020 06:00	0.0	13.7	1,688.6	0.0	0.0	1	1	0
02/21/2020 07:00	0.0	13.7	1,649.8	0.0	0.0	1	1	0
02/21/2020 08:00	0.0	13.6	1,553.8	0.0	0.0	1	1	0
02/21/2020 09:00	0.0	13.6	1,684.7	0.0	0.0	1	1	0
02/21/2020 10:00	0.0	13.7	1,625.3	0.0	0.0	1	1	0
02/21/2020 11:00	0.0	13.7	1,608.2	0.0	0.0	1	1	0
02/21/2020 12:00	0.0	13.7	1,676.5	0.0	0.0	1	1	0
02/21/2020 13:00	0.0	13.6	1,677.0	0.0	0.0	1	1	0
02/21/2020 14:00	0.0	13.6	1,697.8	0.0	0.0	1	1	0
02/21/2020 15:00	0.0	13.6	1,686.6	0.0	0.0	1	1	0
02/21/2020 16:00	0.0	13.6	1,692.8	0.0	0.0	1	1	1
02/21/2020 17:00	0.0	12.6	1,986.0	0.0	0.0	1	1	1
02/21/2020 18:00	0.0	12.2	2,097.5	0.0	0.0	1	1	1
02/21/2020 19:00	0.0	12.3	2,077.5	0.0	0.0	1	1	1
02/21/2020 20:00	0.0	12.3	2,094.5	0.0	0.0	1	1	1
02/21/2020 21:00	0.0	12.4	2,066.2	0.0	0.0	1	1	1
02/21/2020 22:00	0.0	12.3	2,094.4	0.0	0.0	1	1	1
02/21/2020 23:00	4.4	13.9	1,282.6	0.0	5.1	1	0	1
Average/Sum#:	0.2	13.3	1,738.5	0.0	5.1 #	24 #	23 #	9 #
Minimum:	0.0	12.2	1,282.6	0.0	0.0	1	0	0
Maximum:	4.4	13.9	2,097.5	0.0	5.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/24/2020 13:00	56.7	17.3	476.5	0.0	71.4	1	0	0
02/24/2020 14:00	15.3	16.1	626.2	0.0	26.4	1	0	0
02/24/2020 15:00	20.0	15.0	880.3	0.0	39.4	1	0	0
02/24/2020 16:00	0.0	13.7	1,505.3	0.0	0.0	1	1	1
02/24/2020 17:00	0.0	12.5	2,085.8	0.0	0.0	1	1	1
02/24/2020 18:00	0.0	12.0	2,167.5	0.0	0.0	1	1	1
02/24/2020 19:00	0.0	12.1	2,161.0	0.0	0.0	1	1	1
02/24/2020 20:00	0.0	12.4	2,091.2	0.0	0.0	1	1	1
02/24/2020 21:00	0.0	12.4	2,087.4	0.0	0.0	1	1	1
02/24/2020 22:00	0.0	12.9	1,964.8	0.0	0.0	1	1	1
02/24/2020 23:00	0.0	12.6	2,023.8	0.0	0.0	1	1	1
Average/Sum#:	8.4	13.5	1,642.7	0.0	137.2 #	11 #	8 #	8 #
Minimum:	0.0	12.0	476.5	0.0	0.0	0	0	0
Maximum:	56.7	17.3	2,167.5	0.0	71.4	1	1	1
%SI	54.17	54.17	54.17	75.00	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/25/2020 00:00	0.0	13.7	1,562.5	0.0	0.0	1	1	0
02/25/2020 01:00	0.0	13.7	1,513.6	0.0	0.0	1	1	0
02/25/2020 02:00	0.0	13.7	1,365.0	0.0	0.0	1	1	0
02/25/2020 03:00	0.0	13.7	1,360.5	0.0	0.0	1	1	0
02/25/2020 04:00	0.0	13.7	1,473.4	0.0	0.0	1	1	1
02/25/2020 05:00	0.0	13.0	1,953.5	0.0	0.0	1	1	1
02/25/2020 06:00	0.0	12.9	1,968.3	0.0	0.0	1	1	1
02/25/2020 07:00	0.0	12.9	1,949.7	0.0	0.0	1	1	1
02/25/2020 08:00	0.0	13.7	1,389.1	0.0	0.0	1	1	0
02/25/2020 09:00	0.0	13.7	1,379.8	0.0	0.0	1	1	0
02/25/2020 10:00	0.0	13.7	1,380.4	0.0	0.0	1	1	0
02/25/2020 11:00	0.0	13.7	1,372.4	0.0	0.0	1	1	0
02/25/2020 12:00	0.0	13.7	1,376.1	0.0	0.0	1	1	0
02/25/2020 13:00	0.0	13.7	1,377.8	0.0	0.0	1	1	0
02/25/2020 14:00	0.0	13.7	1,644.3	0.0	0.0	1	1	0
02/25/2020 15:00	0.0	13.7	1,540.5	0.0	0.0	1	1	0
02/25/2020 16:00	0.0	13.7	1,634.0	0.0	0.0	1	1	0
02/25/2020 17:00	0.0	13.7	1,551.5	0.0	0.0	1	1	1
02/25/2020 18:00	0.0	12.7	1,987.1	0.0	0.0	1	1	1
02/25/2020 19:00	0.0	12.1	2,125.9	0.0	0.0	1	1	1
02/25/2020 20:00	0.0	12.0	2,156.8	0.0	0.0	1	1	1
02/25/2020 21:00	0.0	12.1	2,142.4	0.0	0.0	1	1	1
02/25/2020 22:00	0.0	12.1	2,135.7	0.0	0.0	1	1	1
02/25/2020 23:00	0.0	12.2	2,128.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,686.2	0.0	0.0 #	24 #	24 #	11 #
Minimum:	0.0	12.0	1,360.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,156.8	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/26/2020 00:00	0.0	12.5	2,065.6	0.0	0.0	1	1	1
02/26/2020 01:00	0.0	12.5	2,047.7	0.0	0.0	1	1	1
02/26/2020 02:00	0.0	12.5	2,042.5	0.0	0.0	1	1	1
02/26/2020 03:00	0.0	12.5	2,036.1	0.0	0.0	1	1	1
02/26/2020 04:00	0.0	12.6	2,031.3	0.0	0.0	1	1	1
02/26/2020 05:00	0.0	12.6	2,026.1	0.0	0.0	1	1	1
02/26/2020 06:00	0.0	12.7	2,021.5	0.0	0.0	1	1	1
02/26/2020 07:00	0.0	12.7	2,012.8	0.0	0.0	1	1	1
02/26/2020 08:00	4.6	14.1	1,229.8	0.0	5.2	1	0	1
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/26/2020 15:00	15.4	17.1	502.2	0.0	16.1	1	0	0
02/26/2020 16:00	7.0	14.1	1,308.9	0.0	17.8	1	0	1
02/26/2020 17:00	0.0	12.5	2,032.0	0.0	0.0	1	1	1
02/26/2020 18:00	0.0	12.4	2,042.2	0.0	0.0	1	1	1
02/26/2020 19:00	0.0	12.9	1,951.8	0.0	0.0	1	1	1
02/26/2020 20:00	0.0	12.3	2,087.3	0.0	0.0	1	1	1
02/26/2020 21:00	0.0	12.7	1,996.3	0.0	0.0	1	1	1
02/26/2020 22:00	0.0	12.9	1,959.3	0.0	0.0	1	1	1
02/26/2020 23:00	0.0	13.2	1,798.9	0.0	0.0	1	1	1
Average/Sum#:	1.5	13.0	1,844.0	0.0	39.1 #	18 #	15 #	17 #
Minimum:	0.0	12.3	502.2	0.0	0.0	0	0	0
Maximum:	15.4	17.1	2,087.3	0.0	17.8	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/27/2020 00:00	0.0	13.6	1,508.5	0.0	0.0	1	1	0
02/27/2020 01:00	0.0	13.7	1,473.8	0.0	0.0	1	1	0
02/27/2020 02:00	0.0	13.7	1,575.0	0.0	0.0	1	1	0
02/27/2020 03:00	0.0	13.7	1,498.2	0.0	0.0	1	1	0
02/27/2020 04:00	0.0	13.6	1,761.8	0.0	0.0	1	1	0
02/27/2020 05:00	0.0	13.6	1,764.3	0.0	0.0	1	1	0
02/27/2020 06:00	0.0	13.6	1,759.8	0.0	0.0	1	1	0
02/27/2020 07:00	0.0	13.6	1,759.3	0.0	0.0	1	1	0
02/27/2020 08:00	0.0	13.6	1,761.7	0.0	0.0	1	1	0
02/27/2020 09:00	0.0	13.6	1,764.4	0.0	0.0	1	1	0
02/27/2020 10:00	0.0	13.6	1,763.8	0.0	0.0	1	1	0
02/27/2020 11:00	0.0	13.5	1,759.0	0.0	0.0	1	1	0
02/27/2020 12:00	0.0	13.6	1,741.7	0.0	0.0	1	1	0
02/27/2020 13:00	0.0	13.6	1,688.5	0.0	0.0	1	1	0
02/27/2020 14:00	0.0	13.6	1,677.6	0.0	0.0	1	1	0
02/27/2020 15:00	0.0	13.6	1,665.2	0.0	0.0	1	1	0
02/27/2020 16:00	0.0	13.1	1,836.3	0.0	0.0	1	1	1
02/27/2020 17:00	0.0	12.3	2,049.6	0.0	0.0	1	1	1
02/27/2020 18:00	0.0	12.4	2,050.0	0.0	0.0	1	1	1
02/27/2020 19:00	0.0	12.4	2,053.4	0.0	0.0	1	1	1
02/27/2020 20:00	0.0	12.3	2,087.5	0.0	0.0	1	1	1
02/27/2020 21:00	0.0	12.2	2,092.2	0.0	0.0	1	1	1
02/27/2020 22:00	0.0	12.2	2,096.2	0.0	0.0	1	1	1
02/27/2020 23:00	0.0	12.6	2,016.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,800.2	0.0	0.0 #	24 #	24 #	8 #
Minimum:	0.0	12.2	1,473.8	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,096.2	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/28/2020 00:00	0.0	13.0	1,925.9	0.0	0.0	1	1	1
02/28/2020 01:00	0.0	13.7	1,591.0	0.0	0.0	1	1	0
02/28/2020 02:00	0.0	13.7	1,500.7	0.0	0.0	1	1	0
02/28/2020 03:00	0.0	13.7	1,520.9	0.0	0.0	1	1	0
02/28/2020 04:00	0.0	13.7	1,513.5	0.0	0.0	1	1	0
02/28/2020 05:00	0.0	13.6	1,652.7	0.0	0.0	1	1	0
02/28/2020 06:00	0.0	13.6	1,694.8	0.0	0.0	1	1	0
02/28/2020 07:00	0.0	13.6	1,653.6	0.0	0.0	1	1	0
02/28/2020 08:00	0.0	13.6	1,552.3	0.0	0.0	1	1	0
02/28/2020 09:00	0.0	13.7	1,533.3	0.0	0.0	1	1	0
02/28/2020 10:00	0.0	13.7	1,476.4	0.0	0.0	1	1	0
02/28/2020 11:00	0.0	13.7	1,513.9	0.0	0.0	1	1	0
02/28/2020 12:00	0.0	13.7	1,574.7	0.0	0.0	1	1	0
02/28/2020 13:00	0.0	13.7	1,609.1	0.0	0.0	1	1	0
02/28/2020 14:00	0.0	13.7	1,452.9	0.0	0.0	1	1	0
02/28/2020 15:00	0.0	13.6	1,563.8	0.0	0.0	1	1	1
02/28/2020 16:00	0.0	12.5	2,014.8	0.0	0.0	1	1	1
02/28/2020 17:00	0.0	12.3	2,048.7	0.0	0.0	1	1	1
02/28/2020 18:00	0.0	12.4	2,034.8	0.0	0.0	1	1	1
02/28/2020 19:00	0.0	12.3	2,043.5	0.0	0.0	1	1	1
02/28/2020 20:00	0.0	12.5	2,026.5	0.0	0.0	1	1	1
02/28/2020 21:00	0.0	12.3	2,054.5	0.0	0.0	1	1	1
02/28/2020 22:00	0.0	12.4	2,031.8	0.0	0.0	1	1	1
02/28/2020 23:00	4.6	14.0	1,248.2	0.0	5.7	1	0	1
Average/Sum#:	0.2	13.3	1,701.3	0.0	5.7 #	24 #	23 #	10 #
Minimum:	0.0	12.3	1,248.2	0.0	0.0	1	0	0
Maximum:	4.6	14.0	2,054.5	0.0	5.7	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/03/2020 08:00	121.3	18.7	286.2	0.0	37.5	1	0	0
03/03/2020 09:00	26.7	16.9	526.7	0.0	46.4	1	0	0
03/03/2020 10:00	12.9	16.6	572.6	0.0	22.7	1	0	0
03/03/2020 11:00	34.4	15.5	722.2	0.0	60.8	1	0	0
03/03/2020 12:00	11.4	14.4	1,140.8	0.0	26.4	1	0	0
03/03/2020 13:00	0.0	13.8	1,396.8	0.0	0.0	1	1	0
03/03/2020 14:00	0.0	13.8	1,393.5	0.0	0.0	1	1	0
03/03/2020 15:00	0.0	13.8	1,559.0	0.0	0.0	1	1	0
03/03/2020 16:00	0.0	13.8	1,569.6	0.0	0.0	1	1	0
03/03/2020 17:00	0.0	13.7	1,601.7	0.0	0.0	1	1	1
03/03/2020 18:00	0.0	12.2	2,098.3	0.0	0.0	1	1	1
03/03/2020 19:00	0.0	11.9	2,162.7	0.0	0.0	1	1	1
03/03/2020 20:00	0.0	11.9	2,156.3	0.0	0.0	1	1	1
03/03/2020 21:00	0.0	11.9	2,156.0	0.0	0.0	1	1	1
03/03/2020 22:00	0.0	12.0	2,129.3	0.0	0.0	1	1	1
03/03/2020 23:00	0.0	12.2	2,104.5	0.0	0.0	1	1	1
Average/Sum#:	12.9	13.9	1,473.5	0.0	193.8 #	16 #	11 #	7 #
Minimum:	0.0	11.9	286.2	0.0	0.0	0	0	0
Maximum:	121.3	18.7	2,162.7	0.0	60.8	1	1	1
%SI	33.33	33.33	33.33	62.50	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/04/2020 00:00	0.0	12.5	2,059.3	0.0	0.0	1	1	1
03/04/2020 01:00	0.0	12.5	2,049.8	0.0	0.0	1	1	1
03/04/2020 02:00	0.0	12.7	2,001.7	0.0	0.0	1	1	1
03/04/2020 03:00	0.0	12.7	1,997.8	0.0	0.0	1	1	1
03/04/2020 04:00	0.0	12.5	2,046.9	0.0	0.0	1	1	1
03/04/2020 05:00	0.0	12.6	2,044.4	0.0	0.0	1	1	1
03/04/2020 06:00	0.0	12.5	2,043.1	0.0	0.0	1	1	1
03/04/2020 07:00	0.0	12.5	2,029.1	0.0	0.0	1	1	1
03/04/2020 08:00	0.0	13.6	1,508.5	0.0	0.0	1	1	1
03/04/2020 09:00	0.0	13.7	1,379.5	0.0	0.0	1	1	0
03/04/2020 10:00	0.0	13.7	1,382.6	0.0	0.0	1	1	0
03/04/2020 11:00	0.0	13.7	1,580.0	0.0	0.0	1	1	0
03/04/2020 12:00	0.0	13.7	1,708.4	0.0	0.0	1	1	0
03/04/2020 13:00	0.0	13.7	1,539.6	0.0	0.0	1	1	0
03/04/2020 14:00	0.0	13.7	1,636.6	0.0	0.0	1	1	0
03/04/2020 15:00	0.0	13.7	1,609.1	0.0	0.0	1	1	0
03/04/2020 16:00	0.0	13.7	1,553.5	0.0	0.0	1	1	1
03/04/2020 17:00	0.0	12.5	2,030.1	0.0	0.0	1	1	1
03/04/2020 18:00	0.0	12.3	2,054.6	0.0	0.0	1	1	1
03/04/2020 19:00	0.0	12.4	2,050.6	0.0	0.0	1	1	1
03/04/2020 20:00	0.0	12.1	2,113.0	0.0	0.0	1	1	1
03/04/2020 21:00	0.0	12.1	2,121.5	0.0	0.0	1	1	1
03/04/2020 22:00	0.0	12.1	2,109.1	0.0	0.0	1	1	1
03/04/2020 23:00	0.0	12.4	2,060.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,862.9	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,379.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,121.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/05/2020 00:00	0.0	12.7	2,008.7	0.0	0.0	1	1	1
03/05/2020 01:00	0.0	12.7	1,998.5	0.0	0.0	1	1	1
03/05/2020 02:00	0.0	12.7	1,990.0	0.0	0.0	1	1	1
03/05/2020 03:00	0.0	12.7	1,989.3	0.0	0.0	1	1	1
03/05/2020 04:00	0.0	12.4	2,055.6	0.0	0.0	1	1	1
03/05/2020 05:00	0.0	12.4	2,052.3	0.0	0.0	1	1	1
03/05/2020 06:00	0.0	12.6	2,042.3	0.0	0.0	1	1	1
03/05/2020 07:00	0.0	12.7	1,984.6	0.0	0.0	1	1	1
03/05/2020 08:00	0.0	13.6	1,636.4	0.0	0.0	1	1	0
03/05/2020 09:00	0.0	13.6	1,704.5	0.0	0.0	1	1	0
03/05/2020 10:00	0.0	13.7	1,705.5	0.0	0.0	1	1	0
03/05/2020 11:00	0.0	13.6	1,688.6	0.0	0.0	1	1	0
03/05/2020 12:00	0.0	13.6	1,661.7	0.0	0.0	1	1	0
03/05/2020 13:00	0.0	13.6	1,698.8	0.0	0.0	1	1	0
03/05/2020 14:00	0.0	13.6	1,594.6	0.0	0.0	1	1	0
03/05/2020 15:00	0.0	13.6	1,528.7	0.0	0.0	1	1	0
03/05/2020 16:00	0.0	13.6	1,488.9	0.0	0.0	1	1	1
03/05/2020 17:00	0.0	12.5	1,990.0	0.0	0.0	1	1	1
03/05/2020 18:00	0.0	12.2	2,066.1	0.0	0.0	1	1	1
03/05/2020 19:00	0.0	12.3	2,059.4	0.0	0.0	1	1	1
03/05/2020 20:00	0.0	12.3	2,053.9	0.0	0.0	1	1	1
03/05/2020 21:00	0.0	12.3	2,075.9	0.0	0.0	1	1	1
03/05/2020 22:00	0.0	12.3	2,076.5	0.0	0.0	1	1	1
03/05/2020 23:00	0.0	12.6	1,993.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,881.0	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.2	1,488.9	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,076.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/06/2020 00:00	0.0	12.4	2,055.1	0.0	0.0	1	1	1
03/06/2020 01:00	0.0	12.4	2,057.8	0.0	0.0	1	1	1
03/06/2020 02:00	0.0	12.6	1,994.5	0.0	0.0	1	1	1
03/06/2020 03:00	0.0	12.5	2,024.2	0.0	0.0	1	1	1
03/06/2020 04:00	0.0	12.5	2,038.8	0.0	0.0	1	1	1
03/06/2020 05:00	0.0	12.4	2,056.5	0.0	0.0	1	1	1
03/06/2020 06:00	0.0	12.5	2,044.7	0.0	0.0	1	1	1
03/06/2020 07:00	0.0	12.5	2,029.0	0.0	0.0	1	1	1
03/06/2020 08:00	0.0	12.8	1,952.1	0.0	0.0	1	1	1
03/06/2020 09:00	0.0	13.6	1,636.3	0.0	0.0	1	1	0
03/06/2020 10:00	0.0	13.6	1,682.9	0.0	0.0	1	1	0
03/06/2020 11:00	0.0	13.6	1,700.5	0.0	0.0	1	1	0
03/06/2020 12:00	0.0	13.6	1,673.0	0.0	0.0	1	1	0
03/06/2020 13:00	0.0	13.6	1,694.7	0.0	0.0	1	1	0
03/06/2020 14:00	0.0	13.6	1,657.8	0.0	0.0	1	1	0
03/06/2020 15:00	0.0	13.6	1,641.2	0.0	0.0	1	1	0
03/06/2020 16:00	0.0	13.6	1,529.2	0.0	0.0	1	1	1
03/06/2020 17:00	0.0	12.5	2,007.7	0.0	0.0	1	1	1
03/06/2020 18:00	0.0	12.3	2,044.3	0.0	0.0	1	1	1
03/06/2020 19:00	0.0	12.3	2,050.9	0.0	0.0	1	1	1
03/06/2020 20:00	0.0	12.1	2,099.4	0.0	0.0	1	1	1
03/06/2020 21:00	0.0	12.0	2,120.6	0.0	0.0	1	1	1
03/06/2020 22:00	0.0	12.2	2,086.0	0.0	0.0	1	1	1
03/06/2020 23:00	0.0	12.3	2,054.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,913.8	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.0	1,529.2	0.0	0.0	1	1	0
Maximum:	0.0	13.6	2,120.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/07/2020 00:00	5.3	14.1	1,220.5	0.0	6.3	1	0	1
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.3	14.1	1,220.5	0.0	6.3 #	1 #	0 #	1 #
Minimum:	5.3	14.1	1,220.5	0.0	6.3	0	0	0
Maximum:	5.3	14.1	1,220.5	0.0	6.3	1	0	1
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/08/2020 20:00	61.2	17.3	468.7	0.0	75.7	1	0	0
03/08/2020 21:00	11.9	16.9	529.5	0.0	20.8	1	0	0
03/08/2020 22:00	10.8	14.5	1,159.1	0.0	25.8	1	0	0
03/08/2020 23:00	0.0	13.6	1,549.1	0.0	0.0	1	1	0
Average/Sum#:	21.0	15.6	926.6	0.0	122.3 #	4 #	1 #	0 #
Minimum:	0.0	13.6	468.7	0.0	0.0	0	0	0
Maximum:	61.2	17.3	1,549.1	0.0	75.7	1	1	0
%SI	83.33	83.33	83.33	100.00	83.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2020 00:00	0.0	13.6	1,545.8	0.0	0.0	1	1	0
03/09/2020 01:00	0.0	13.6	1,647.7	0.0	0.0	1	1	0
03/09/2020 02:00	0.0	13.6	1,608.2	0.0	0.0	1	1	0
03/09/2020 03:00	0.0	13.6	1,503.5	0.0	0.0	1	1	0
03/09/2020 04:00	0.0	13.6	1,591.5	0.0	0.0	1	1	1
03/09/2020 05:00	0.0	12.7	2,030.9	0.0	0.0	1	1	1
03/09/2020 06:00	0.0	12.2	2,153.8	0.0	0.0	1	1	1
03/09/2020 07:00	0.0	12.2	2,138.7	0.0	0.0	1	1	1
03/09/2020 08:00	0.0	12.2	2,127.0	0.0	0.0	1	1	1
03/09/2020 09:00	0.0	13.5	1,683.7	0.0	0.0	1	1	1
03/09/2020 10:00	0.0	13.6	1,601.6	0.0	0.0	1	1	0
03/09/2020 11:00	0.0	13.6	1,571.5	0.0	0.0	1	1	0
03/09/2020 12:00	0.0	13.6	1,697.9	0.0	0.0	1	1	0
03/09/2020 13:00	0.0	13.7	1,698.6	0.0	0.0	1	1	0
03/09/2020 14:00	0.0	13.7	1,698.9	0.0	0.0	1	1	0
03/09/2020 15:00	0.0	13.7	1,672.5	0.0	0.0	1	1	0
03/09/2020 16:00	0.0	13.6	1,688.6	0.0	0.0	1	1	1
03/09/2020 17:00	0.0	12.6	2,022.0	0.0	0.0	1	1	1
03/09/2020 18:00	0.0	12.0	2,157.7	0.0	0.0	1	1	1
03/09/2020 19:00	0.0	12.0	2,162.6	0.0	0.0	1	1	1
03/09/2020 20:00	0.0	12.1	2,130.8	0.0	0.0	1	1	1
03/09/2020 21:00	0.0	12.1	2,127.5	0.0	0.0	1	1	1
03/09/2020 22:00	0.0	12.1	2,127.2	0.0	0.0	1	1	1
03/09/2020 23:00	0.0	12.1	2,125.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,854.7	0.0	0.0 #	24 #	24 #	14 #
Minimum:	0.0	12.0	1,503.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,162.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2020 00:00	0.0	12.1	2,126.8	0.0	0.0	1	1	1
03/10/2020 01:00	0.0	12.1	2,116.3	0.0	0.0	1	1	1
03/10/2020 02:00	0.0	12.2	2,105.4	0.0	0.0	1	1	1
03/10/2020 03:00	0.0	12.4	2,065.1	0.0	0.0	1	1	1
03/10/2020 04:00	0.0	12.4	2,068.2	0.0	0.0	1	1	1
03/10/2020 05:00	0.0	12.0	2,149.7	0.0	0.0	1	1	1
03/10/2020 06:00	0.0	11.8	2,202.0	0.0	0.0	1	1	1
03/10/2020 07:00	0.0	11.9	2,163.8	0.0	0.0	1	1	1
03/10/2020 08:00	0.0	12.0	2,153.5	0.0	0.0	1	1	1
03/10/2020 09:00	0.0	12.2	2,113.4	0.0	0.0	1	1	1
03/10/2020 10:00	0.0	12.3	2,090.0	0.0	0.0	1	1	1
03/10/2020 11:00	0.0	0.0	2,114.9	0.0	0.0	1	1	1
03/10/2020 12:00	0.0	12.2	2,129.0	0.0	0.0	1	1	1
03/10/2020 13:00	0.0	12.3	2,114.8	0.0	0.0	1	1	1
03/10/2020 14:00	0.0	12.2	2,124.9	0.0	0.0	1	1	1
03/10/2020 15:00	0.0	12.3	2,103.1	0.0	0.0	1	1	1
03/10/2020 16:00	0.0	12.3	2,105.2	0.0	0.0	1	1	1
03/10/2020 17:00	0.0	12.4	2,074.3	0.0	0.0	1	1	1
03/10/2020 18:00	0.0	12.1	2,156.5	0.0	0.0	1	1	1
03/10/2020 19:00	0.0	12.0	2,182.4	0.0	0.0	1	1	1
03/10/2020 20:00	0.0	12.0	2,182.0	0.0	0.0	1	1	1
03/10/2020 21:00	0.0	12.3	2,124.9	0.0	0.0	1	1	1
03/10/2020 22:00	0.0	12.4	2,121.6	0.0	0.0	1	1	1
03/10/2020 23:00	0.0	12.4	2,089.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,124.1	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	2,065.1	0.0	0.0	1	1	1
Maximum:	0.0	12.4	2,202.0	0.0	0.0	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/11/2020 00:00	0.0	12.6	2,034.8	0.0	0.0	1	1	1
03/11/2020 01:00	0.0	12.7	2,026.3	0.0	0.0	1	1	1
03/11/2020 02:00	0.0	12.6	2,046.5	0.0	0.0	1	1	1
03/11/2020 03:00	0.0	12.6	2,046.6	0.0	0.0	1	1	1
03/11/2020 04:00	0.0	12.5	2,070.4	0.0	0.0	1	1	1
03/11/2020 05:00	0.0	12.4	2,121.6	0.0	0.0	1	1	1
03/11/2020 06:00	0.0	12.0	2,191.3	0.0	0.0	1	1	1
03/11/2020 07:00	0.0	12.3	2,124.5	0.0	0.0	1	1	1
03/11/2020 08:00	0.0	12.3	2,116.3	0.0	0.0	1	1	1
03/11/2020 09:00	0.0	13.6	1,719.1	0.0	0.0	1	1	1
03/11/2020 10:00	0.0	13.8	1,649.8	0.0	0.0	1	1	0
03/11/2020 11:00	0.0	13.8	1,562.1	0.0	0.0	1	1	0
03/11/2020 12:00	0.0	13.9	1,598.0	0.0	0.0	1	1	0
03/11/2020 13:00	0.0	13.9	1,687.2	0.0	0.0	1	1	0
03/11/2020 14:00	0.0	13.9	1,653.1	0.0	0.0	1	1	0
03/11/2020 15:00	0.0	13.9	1,560.0	0.0	0.0	1	1	0
03/11/2020 16:00	0.0	14.0	1,350.6	0.0	0.0	1	1	0
03/11/2020 17:00	0.0	13.9	1,645.4	0.0	0.0	1	1	0
03/11/2020 18:00	0.0	13.8	1,706.9	0.0	0.0	1	1	1
03/11/2020 19:00	0.0	12.7	2,029.1	0.0	0.0	1	1	1
03/11/2020 20:00	0.0	12.0	2,172.6	0.0	0.0	1	1	1
03/11/2020 21:00	0.0	12.2	2,125.6	0.0	0.0	1	1	1
03/11/2020 22:00	0.0	12.5	2,072.5	0.0	0.0	1	1	1
03/11/2020 23:00	0.0	12.3	2,115.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,892.7	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.0	1,350.6	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,191.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2020 00:00	0.0	12.4	2,075.2	0.0	0.0	1	1	1
03/12/2020 01:00	0.0	12.6	2,044.0	0.0	0.0	1	1	1
03/12/2020 02:00	0.0	12.8	1,989.9	0.0	0.0	1	1	1
03/12/2020 03:00	0.0	12.6	2,038.8	0.0	0.0	1	1	1
03/12/2020 04:00	0.0	12.4	2,071.6	0.0	0.0	1	1	1
03/12/2020 05:00	0.0	12.4	2,081.3	0.0	0.0	1	1	1
03/12/2020 06:00	0.0	12.0	2,178.0	0.0	0.0	1	1	1
03/12/2020 07:00	0.0	12.0	2,168.8	0.0	0.0	1	1	1
03/12/2020 08:00	0.0	12.4	2,066.4	0.0	0.0	1	1	1
03/12/2020 09:00	0.0	13.8	1,667.7	0.0	0.0	1	1	0
03/12/2020 10:00	0.0	13.8	1,676.7	0.0	0.0	1	1	0
03/12/2020 11:00	0.0	13.9	1,663.4	0.0	0.0	1	1	0
03/12/2020 12:00	0.0	13.8	1,699.6	0.0	0.0	1	1	0
03/12/2020 13:00	0.0	13.9	1,587.1	0.0	0.0	1	1	0
03/12/2020 14:00	0.0	13.9	1,676.7	0.0	0.0	1	1	0
03/12/2020 15:00	0.0	13.3	1,825.9	0.0	0.0	1	1	1
03/12/2020 16:00	0.0	12.3	2,095.5	0.0	0.0	1	1	1
03/12/2020 17:00	0.0	12.0	2,146.7	0.0	0.0	1	1	1
03/12/2020 18:00	0.0	12.0	2,176.4	0.0	0.0	1	1	1
03/12/2020 19:00	0.0	11.9	2,182.9	0.0	0.0	1	1	1
03/12/2020 20:00	0.0	12.3	2,088.8	0.0	0.0	1	1	1
03/12/2020 21:00	0.0	12.1	2,115.5	0.0	0.0	1	1	1
03/12/2020 22:00	0.0	12.1	2,121.4	0.0	0.0	1	1	1
03/12/2020 23:00	0.0	12.1	2,116.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,981.5	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,587.1	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,182.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/13/2020 00:00	0.0	12.1	2,104.1	0.0	0.0	1	1	1
03/13/2020 01:00	0.0	12.1	2,105.6	0.0	0.0	1	1	1
03/13/2020 02:00	0.0	12.2	2,104.7	0.0	0.0	1	1	1
03/13/2020 03:00	0.0	12.2	2,105.0	0.0	0.0	1	1	1
03/13/2020 04:00	0.0	12.4	2,068.0	0.0	0.0	1	1	1
03/13/2020 05:00	0.0	12.1	2,127.2	0.0	0.0	1	1	1
03/13/2020 06:00	0.0	12.2	2,112.9	0.0	0.0	1	1	1
03/13/2020 07:00	0.0	12.2	2,120.9	0.0	0.0	1	1	1
03/13/2020 08:00	0.0	12.1	2,167.3	0.0	0.0	1	1	1
03/13/2020 09:00	0.0	13.6	1,722.3	0.0	0.0	1	1	1
03/13/2020 10:00	0.0	13.9	1,601.6	0.0	0.0	1	1	0
03/13/2020 11:00	0.0	13.9	1,637.0	0.0	0.0	1	1	0
03/13/2020 12:00	0.0	13.9	1,682.0	0.0	0.0	1	1	0
03/13/2020 13:00	0.0	13.9	1,634.8	0.0	0.0	1	1	0
03/13/2020 14:00	0.0	13.8	1,673.9	0.0	0.0	1	1	0
03/13/2020 15:00	0.0	13.9	1,678.5	0.0	0.0	1	1	0
03/13/2020 16:00	0.0	13.9	1,693.4	0.0	0.0	1	1	0
03/13/2020 17:00	0.0	13.3	1,816.5	0.0	0.0	1	1	1
03/13/2020 18:00	0.0	12.5	2,053.3	0.0	0.0	1	1	1
03/13/2020 19:00	0.0	12.0	2,170.0	0.0	0.0	1	1	1
03/13/2020 20:00	0.0	11.9	2,189.1	0.0	0.0	1	1	1
03/13/2020 21:00	0.0	12.2	2,137.0	0.0	0.0	1	1	1
03/13/2020 22:00	0.0	12.4	2,102.5	0.0	0.0	1	1	1
03/13/2020 23:00	0.0	12.5	2,059.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,952.8	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	11.9	1,601.6	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,189.1	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2020 00:00	0.0	12.3	2,114.7	0.0	0.0	1	1	1
03/14/2020 01:00	0.0	12.3	2,117.8	0.0	0.0	1	1	1
03/14/2020 02:00	0.0	12.3	2,113.1	0.0	0.0	1	1	1
03/14/2020 03:00	0.0	12.3	2,110.9	0.0	0.0	1	1	1
03/14/2020 04:00	0.0	12.6	2,046.9	0.0	0.0	1	1	1
03/14/2020 05:00	0.0	12.5	2,087.0	0.0	0.0	1	1	1
03/14/2020 06:00	0.0	12.4	2,121.3	0.0	0.0	1	1	1
03/14/2020 07:00	0.0	12.4	2,077.3	0.0	0.0	1	1	1
03/14/2020 08:00	0.0	13.9	1,760.8	0.0	0.0	1	1	0
03/14/2020 09:00	0.0	13.9	1,750.9	0.0	0.0	1	1	0
03/14/2020 10:00	0.0	13.9	1,745.9	0.0	0.0	1	1	0
03/14/2020 11:00	0.0	13.9	1,747.5	0.0	0.0	1	1	0
03/14/2020 12:00	0.0	13.9	1,748.0	0.0	0.0	1	1	0
03/14/2020 13:00	0.0	13.9	1,747.5	0.0	0.0	1	1	0
03/14/2020 14:00	0.0	13.9	1,749.9	0.0	0.0	1	1	0
03/14/2020 15:00	0.0	13.9	1,750.6	0.0	0.0	1	1	0
03/14/2020 16:00	0.0	13.9	1,755.6	0.0	0.0	1	1	0
03/14/2020 17:00	0.0	13.4	1,837.9	0.0	0.0	1	1	1
03/14/2020 18:00	0.0	12.4	2,114.7	0.0	0.0	1	1	1
03/14/2020 19:00	0.0	12.1	2,185.9	0.0	0.0	1	1	1
03/14/2020 20:00	0.0	12.2	2,153.3	0.0	0.0	1	1	1
03/14/2020 21:00	0.0	12.4	2,110.3	0.0	0.0	1	1	1
03/14/2020 22:00	0.0	12.7	2,048.7	0.0	0.0	1	1	1
03/14/2020 23:00	0.0	12.7	2,040.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,959.9	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	12.1	1,745.9	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,185.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/15/2020 00:00	0.0	12.6	2,080.7	0.0	0.0	1	1	1
03/15/2020 01:00	0.0	12.7	2,047.4	0.0	0.0	1	1	1
03/15/2020 02:00	0.0	12.7	2,037.8	0.0	0.0	1	1	1
03/15/2020 03:00	0.0	12.7	2,037.4	0.0	0.0	1	1	1
03/15/2020 04:00	0.0	12.7	2,047.4	0.0	0.0	1	1	1
03/15/2020 05:00	0.0	12.7	2,044.8	0.0	0.0	1	1	1
03/15/2020 06:00	0.0	12.7	2,062.7	0.0	0.0	1	1	1
03/15/2020 07:00	0.0	12.6	2,061.9	0.0	0.0	1	1	1
03/15/2020 08:00	0.0	12.7	2,017.9	0.0	0.0	1	1	1
03/15/2020 09:00	0.0	13.8	1,752.8	0.0	0.0	1	1	0
03/15/2020 10:00	0.0	13.8	1,758.3	0.0	0.0	1	1	0
03/15/2020 11:00	0.0	13.8	1,746.1	0.0	0.0	1	1	0
03/15/2020 12:00	0.0	13.8	1,747.4	0.0	0.0	1	1	0
03/15/2020 13:00	0.0	13.9	1,751.7	0.0	0.0	1	1	0
03/15/2020 14:00	0.0	13.9	1,592.7	0.0	0.0	1	1	0
03/15/2020 15:00	0.0	13.9	1,522.6	0.0	0.0	1	1	0
03/15/2020 16:00	0.0	13.9	1,520.6	0.0	0.0	1	1	0
03/15/2020 17:00	0.0	13.4	1,831.2	0.0	0.0	1	1	1
03/15/2020 18:00	0.0	12.1	2,184.0	0.0	0.0	1	1	1
03/15/2020 19:00	0.0	11.9	2,221.3	0.0	0.0	1	1	1
03/15/2020 20:00	0.0	12.0	2,211.2	0.0	0.0	1	1	1
03/15/2020 21:00	0.0	12.1	2,199.6	0.0	0.0	1	1	1
03/15/2020 22:00	0.0	12.5	2,105.6	0.0	0.0	1	1	1
03/15/2020 23:00	0.0	12.5	2,108.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,945.5	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	11.9	1,520.6	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,221.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/16/2020 00:00	0.0	12.4	2,114.4	0.0	0.0	1	1	1
03/16/2020 01:00	0.0	12.5	2,101.3	0.0	0.0	1	1	1
03/16/2020 02:00	0.0	12.4	2,115.6	0.0	0.0	1	1	1
03/16/2020 03:00	0.0	12.5	2,112.4	0.0	0.0	1	1	1
03/16/2020 04:00	0.0	12.3	2,164.5	0.0	0.0	1	1	1
03/16/2020 05:00	0.0	12.2	2,182.4	0.0	0.0	1	1	1
03/16/2020 06:00	0.0	12.0	2,221.5	0.0	0.0	1	1	1
03/16/2020 07:00	0.0	12.4	2,129.1	0.0	0.0	1	1	1
03/16/2020 08:00	0.0	12.4	2,122.0	0.0	0.0	1	1	1
03/16/2020 09:00	0.0	12.4	2,110.6	0.0	0.0	1	1	1
03/16/2020 10:00	0.0	12.4	2,110.4	0.0	0.0	1	1	1
03/16/2020 11:00	0.0	12.4	2,121.0	0.0	0.0	1	1	1
03/16/2020 12:00	0.0	12.4	2,106.5	0.0	0.0	1	1	1
03/16/2020 13:00	0.0	12.5	2,081.9	0.0	0.0	1	1	1
03/16/2020 14:00	0.0	12.6	2,066.6	0.0	0.0	1	1	1
03/16/2020 15:00	0.0	12.7	2,038.7	0.0	0.0	1	1	1
03/16/2020 16:00	0.0	12.7	2,041.4	0.0	0.0	1	1	1
03/16/2020 17:00	0.0	12.6	2,052.2	0.0	0.0	1	1	1
03/16/2020 18:00	0.0	12.0	2,198.0	0.0	0.0	1	1	1
03/16/2020 19:00	0.0	12.0	2,204.5	0.0	0.0	1	1	1
03/16/2020 20:00	0.0	12.2	2,161.9	0.0	0.0	1	1	1
03/16/2020 21:00	0.0	12.1	2,168.2	0.0	0.0	1	1	1
03/16/2020 22:00	0.0	12.4	2,118.9	0.0	0.0	1	1	1
03/16/2020 23:00	0.0	12.4	2,115.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,123.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	12.0	2,038.7	0.0	0.0	1	1	1
Maximum:	0.0	12.7	2,221.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/17/2020 00:00	0.0	12.5	2,100.7	0.0	0.0	1	1	1
03/17/2020 01:00	0.0	12.5	2,090.2	0.0	0.0	1	1	1
03/17/2020 02:00	0.0	12.8	2,036.4	0.0	0.0	1	1	1
03/17/2020 03:00	0.0	12.7	2,062.1	0.0	0.0	1	1	1
03/17/2020 04:00	0.0	12.8	2,034.1	0.0	0.0	1	1	1
03/17/2020 05:00	0.0	12.5	2,113.7	0.0	0.0	1	1	1
03/17/2020 06:00	0.0	12.3	2,157.3	0.0	0.0	1	1	1
03/17/2020 07:00	0.0	12.8	2,037.5	0.0	0.0	1	1	1
03/17/2020 08:00	0.0	13.2	1,928.1	0.0	0.0	1	1	1
03/17/2020 09:00	0.0	13.8	1,757.0	0.0	0.0	1	1	0
03/17/2020 10:00	0.0	13.8	1,758.6	0.0	0.0	1	1	0
03/17/2020 11:00	0.0	13.8	1,761.8	0.0	0.0	1	1	0
03/17/2020 12:00	0.0	13.8	1,763.8	0.0	0.0	1	1	0
03/17/2020 13:00	0.0	13.8	1,760.2	0.0	0.0	1	1	0
03/17/2020 14:00	0.0	13.8	1,759.6	0.0	0.0	1	1	0
03/17/2020 15:00	0.0	13.8	1,758.8	0.0	0.0	1	1	0
03/17/2020 16:00	0.0	13.8	1,760.9	0.0	0.0	1	1	1
03/17/2020 17:00	0.0	12.8	2,023.9	0.0	0.0	1	1	1
03/17/2020 18:00	0.0	12.4	2,115.6	0.0	0.0	1	1	1
03/17/2020 19:00	0.0	12.3	2,125.0	0.0	0.0	1	1	1
03/17/2020 20:00	0.0	12.6	2,070.6	0.0	0.0	1	1	1
03/17/2020 21:00	0.0	12.6	2,073.7	0.0	0.0	1	1	1
03/17/2020 22:00	0.0	12.5	2,073.6	0.0	0.0	1	1	1
03/17/2020 23:00	0.0	12.7	2,040.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,965.1	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,757.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,157.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/18/2020 00:00	0.0	12.7	2,032.6	0.0	0.0	1	1	1
03/18/2020 01:00	0.0	12.8	2,029.6	0.0	0.0	1	1	1
03/18/2020 02:00	0.0	12.8	2,030.8	0.0	0.0	1	1	1
03/18/2020 03:00	0.0	12.7	2,041.1	0.0	0.0	1	1	1
03/18/2020 04:00	0.0	12.8	2,031.3	0.0	0.0	1	1	1
03/18/2020 05:00	0.0	12.8	2,006.4	0.0	0.0	1	1	1
03/18/2020 06:00	0.0	12.4	2,091.5	0.0	0.0	1	1	1
03/18/2020 07:00	0.0	12.5	2,067.0	0.0	0.0	1	1	1
03/18/2020 08:00	0.0	12.7	2,010.8	0.0	0.0	1	1	1
03/18/2020 09:00	0.0	13.8	1,654.6	0.0	0.0	1	1	0
03/18/2020 10:00	0.0	13.8	1,630.1	0.0	0.0	1	1	0
03/18/2020 11:00	0.0	13.8	1,615.1	0.0	0.0	1	1	0
03/18/2020 12:00	0.0	13.8	1,640.0	0.0	0.0	1	1	0
03/18/2020 13:00	0.0	13.8	1,616.6	0.0	0.0	1	1	0
03/18/2020 14:00	0.0	13.8	1,650.2	0.0	0.0	1	1	0
03/18/2020 15:00	0.0	13.8	1,632.9	0.0	0.0	1	1	0
03/18/2020 16:00	0.0	13.8	1,681.8	0.0	0.0	1	1	0
03/18/2020 17:00	0.0	13.8	1,563.7	0.0	0.0	1	1	0
03/18/2020 18:00	0.0	12.9	1,992.5	0.0	0.0	1	1	1
03/18/2020 19:00	0.0	12.8	2,022.6	0.0	0.0	1	1	1
03/18/2020 20:00	0.0	12.6	2,066.1	0.0	0.0	1	1	1
03/18/2020 21:00	0.0	12.7	2,051.9	0.0	0.0	1	1	1
03/18/2020 22:00	0.0	12.7	2,053.4	0.0	0.0	1	1	1
03/18/2020 23:00	0.0	12.8	2,015.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,884.5	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	12.4	1,563.7	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,091.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2020 00:00	0.0	13.2	1,941.1	0.0	0.0	1	1	1
03/19/2020 01:00	0.0	13.2	1,941.8	0.0	0.0	1	1	1
03/19/2020 02:00	0.0	13.2	1,948.4	0.0	0.0	1	1	1
03/19/2020 03:00	0.0	13.2	1,948.8	0.0	0.0	1	1	1
03/19/2020 04:00	0.0	13.1	1,980.5	0.0	0.0	1	1	1
03/19/2020 05:00	0.0	13.0	1,989.0	0.0	0.0	1	1	1
03/19/2020 06:00	0.0	12.6	2,103.3	0.0	0.0	1	1	1
03/19/2020 07:00	0.0	12.6	2,100.4	0.0	0.0	1	1	1
03/19/2020 08:00	0.0	12.9	1,998.8	0.0	0.0	1	1	1
03/19/2020 09:00	0.0	13.8	1,554.5	0.0	0.0	1	1	0
03/19/2020 10:00	0.0	13.8	1,593.5	0.0	0.0	1	1	0
03/19/2020 11:00	0.0	13.9	1,473.0	0.0	0.0	1	1	0
03/19/2020 12:00	0.0	13.9	1,531.7	0.0	0.0	1	1	0
03/19/2020 13:00	0.0	13.9	1,374.0	0.0	0.0	1	1	0
03/19/2020 14:00	0.0	13.9	1,299.8	0.0	0.0	1	1	0
03/19/2020 15:00	0.0	13.9	1,566.5	0.0	0.0	1	1	0
03/19/2020 16:00	0.0	13.9	1,539.2	0.0	0.0	1	1	1
03/19/2020 17:00	0.0	12.7	2,018.0	0.0	0.0	1	1	1
03/19/2020 18:00	0.0	12.5	2,063.4	0.0	0.0	1	1	1
03/19/2020 19:00	0.0	12.3	2,109.3	0.0	0.0	1	1	1
03/19/2020 20:00	0.0	12.4	2,112.9	0.0	0.0	1	1	1
03/19/2020 21:00	0.0	12.4	2,093.9	0.0	0.0	1	1	1
03/19/2020 22:00	0.0	12.6	2,081.3	0.0	0.0	1	1	1
03/19/2020 23:00	0.0	12.8	2,035.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.2	1,850.0	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.3	1,299.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,112.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/20/2020 00:00	0.0	12.9	2,031.3	0.0	0.0	1	1	1
03/20/2020 01:00	0.0	12.9	2,032.7	0.0	0.0	1	1	1
03/20/2020 02:00	0.0	12.8	2,030.9	0.0	0.0	1	1	1
03/20/2020 03:00	0.0	12.9	2,029.7	0.0	0.0	1	1	1
03/20/2020 04:00	0.0	12.9	2,029.8	0.0	0.0	1	1	1
03/20/2020 05:00	0.0	13.1	1,983.2	0.0	0.0	1	1	1
03/20/2020 06:00	0.0	12.9	2,049.1	0.0	0.0	1	1	1
03/20/2020 07:00	0.0	13.2	1,928.7	0.0	0.0	1	1	1
03/20/2020 08:00	0.0	13.8	1,617.2	0.0	0.0	1	1	0
03/20/2020 09:00	0.0	13.9	1,381.3	0.0	0.0	1	1	0
03/20/2020 10:00	0.0	13.8	1,659.9	0.0	0.0	1	1	0
03/20/2020 11:00	0.0	13.9	1,557.8	0.0	0.0	1	1	0
03/20/2020 12:00	0.0	13.9	1,527.2	0.0	0.0	1	1	0
03/20/2020 13:00	0.0	13.9	1,644.7	0.0	0.0	1	1	0
03/20/2020 14:00	0.0	13.9	1,531.9	0.0	0.0	1	1	0
03/20/2020 15:00	0.0	13.9	1,581.6	0.0	0.0	1	1	1
03/20/2020 16:00	0.0	12.8	2,006.0	0.0	0.0	1	1	1
03/20/2020 17:00	0.0	12.6	2,042.3	0.0	0.0	1	1	1
03/20/2020 18:00	0.0	12.6	2,042.8	0.0	0.0	1	1	1
03/20/2020 19:00	0.0	12.6	2,055.5	0.0	0.0	1	1	1
03/20/2020 20:00	0.0	12.5	2,078.7	0.0	0.0	1	1	1
03/20/2020 21:00	0.0	12.4	2,094.3	0.0	0.0	1	1	1
03/20/2020 22:00	0.0	12.5	2,073.4	0.0	0.0	1	1	1
03/20/2020 23:00	0.0	12.7	2,037.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,877.0	0.0	0.0 #	24 #	24 #	17 #
Minimum:	0.0	12.4	1,381.3	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,094.3	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/21/2020 00:00	0.0	12.7	2,070.8	0.0	0.0	1	1	1
03/21/2020 01:00	0.0	12.6	2,091.2	0.0	0.0	1	1	1
03/21/2020 02:00	0.0	12.5	2,085.7	0.0	0.0	1	1	1
03/21/2020 03:00	0.0	12.5	2,094.3	0.0	0.0	1	1	1
03/21/2020 04:00	0.0	12.6	2,064.0	0.0	0.0	1	1	1
03/21/2020 05:00	0.0	12.6	2,055.9	0.0	0.0	1	1	1
03/21/2020 06:00	0.0	13.1	2,002.1	0.0	0.0	1	1	1
03/21/2020 07:00	4.9	14.5	1,201.0	0.0	5.7	1	0	1
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	12.9	1,958.1	0.0	5.7 #	8 #	7 #	8 #
Minimum:	0.0	12.5	1,201.0	0.0	0.0	0	0	0
Maximum:	4.9	14.5	2,094.3	0.0	5.7	1	1	1
%SI	66.67	66.67	66.67	70.83	66.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/22/2020 17:00	45.6	17.6	464.8	0.0	61.9	1	0	0
03/22/2020 18:00	9.3	17.1	521.9	0.0	16.9	1	0	0
03/22/2020 19:00	13.4	15.5	920.8	0.0	30.2	1	0	0
03/22/2020 20:00	0.0	13.9	1,478.7	0.0	0.0	1	1	0
03/22/2020 21:00	0.0	13.9	1,416.5	0.0	0.0	1	1	0
03/22/2020 22:00	0.0	13.9	1,439.7	0.0	0.0	1	1	0
03/22/2020 23:00	0.0	13.9	1,477.7	0.0	0.0	1	1	0
Average/Sum#:	9.8	15.1	1,102.9	0.0	109.0 #	7 #	4 #	0 #
Minimum:	0.0	13.9	464.8	0.0	0.0	0	0	0
Maximum:	45.6	17.6	1,478.7	0.0	61.9	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/23/2020 00:00	0.0	13.9	1,367.8	0.0	0.0	1	1	0
03/23/2020 01:00	0.0	13.9	1,351.3	0.0	0.0	1	1	0
03/23/2020 02:00	13.3	16.6	343.8	0.0	2.4	1	0	0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/23/2020 17:00	29.2	17.6	462.2	0.0	37.8	1	0	0
03/23/2020 18:00	10.7	17.1	521.7	0.0	19.4	1	0	0
03/23/2020 19:00	17.4	15.6	864.1	0.0	37.5	1	0	0
03/23/2020 20:00	0.0	13.9	1,551.4	0.0	0.0	1	1	0
03/23/2020 21:00	0.0	13.9	1,538.5	0.0	0.0	1	1	0
03/23/2020 22:00	0.0	13.9	1,547.8	0.0	0.0	1	1	0
03/23/2020 23:00	0.0	13.8	1,648.1	0.0	0.0	1	1	0
Average/Sum#:	7.1	15.0	1,119.7	0.0	97.1 #	10 #	6 #	0 #
Minimum:	0.0	13.8	343.8	0.0	0.0	0	0	0
Maximum:	29.2	17.6	1,648.1	0.0	37.8	1	1	0
%SI	58.33	58.33	58.33	83.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2020 00:00	0.0	13.9	1,432.3	0.0	0.0	1	1	0
03/24/2020 01:00	0.0	13.9	1,379.4	0.0	0.0	1	1	0
03/24/2020 02:00	0.0	13.8	1,580.7	0.0	0.0	1	1	0
03/24/2020 03:00	0.0	13.8	1,524.7	0.0	0.0	1	1	0
03/24/2020 04:00	0.0	13.8	1,725.2	0.0	0.0	1	1	0
03/24/2020 05:00	0.0	13.8	1,700.6	0.0	0.0	1	1	0
03/24/2020 06:00	0.0	13.8	1,686.9	0.0	0.0	1	1	0
03/24/2020 07:00	0.0	13.8	1,701.5	0.0	0.0	1	1	0
03/24/2020 08:00	0.0	13.8	1,575.3	0.0	0.0	1	1	0
03/24/2020 09:00	0.0	13.8	1,681.6	0.0	0.0	1	1	0
03/24/2020 10:00	0.0	13.8	1,701.8	0.0	0.0	1	1	0
03/24/2020 11:00	0.0	13.8	1,614.3	0.0	0.0	1	1	0
03/24/2020 12:00	0.0	13.8	1,648.1	0.0	0.0	1	1	0
03/24/2020 13:00	0.0	13.9	1,548.1	0.0	0.0	1	1	0
03/24/2020 14:00	0.0	13.9	1,570.7	0.0	0.0	1	1	0
03/24/2020 15:00	0.0	13.9	1,586.9	0.0	0.0	1	1	0
03/24/2020 16:00	0.0	13.9	1,604.7	0.0	0.0	1	1	1
03/24/2020 17:00	0.0	12.7	2,020.6	0.0	0.0	1	1	1
03/24/2020 18:00	0.0	12.9	1,996.4	0.0	0.0	1	1	1
03/24/2020 19:00	0.0	12.8	2,019.1	0.0	0.0	1	1	1
03/24/2020 20:00	0.0	12.4	2,110.1	0.0	0.0	1	1	1
03/24/2020 21:00	0.0	12.7	2,046.7	0.0	0.0	1	1	1
03/24/2020 22:00	0.0	12.8	2,047.3	0.0	0.0	1	1	1
03/24/2020 23:00	4.4	14.3	1,244.1	0.0	5.3	1	0	1
Average/Sum#:	0.2	13.6	1,697.8	0.0	5.3 #	24 #	23 #	8 #
Minimum:	0.0	12.4	1,244.1	0.0	0.0	1	0	0
Maximum:	4.4	14.3	2,110.1	0.0	5.3	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/27/2020 17:00	45.8	17.5	483.2	0.0	80.0	1	0	0
03/27/2020 18:00	9.1	17.2	524.0	0.0	17.0	1	0	0
03/27/2020 19:00	18.5	15.4	882.5	0.0	39.2	1	0	0
03/27/2020 20:00	0.0	13.9	1,598.1	0.0	0.0	1	1	0
03/27/2020 21:00	0.0	13.9	1,427.6	0.0	0.0	1	1	0
03/27/2020 22:00	0.0	13.9	1,428.1	0.0	0.0	1	1	0
03/27/2020 23:00	0.0	13.8	1,683.7	0.0	0.0	1	1	0
Average/Sum#:	10.5	15.1	1,146.7	0.0	136.2 #	7 #	4 #	0 #
Minimum:	0.0	13.8	483.2	0.0	0.0	0	0	0
Maximum:	45.8	17.5	1,683.7	0.0	80.0	1	1	0
%SI	70.83	70.83	70.83	91.67	70.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/28/2020 00:00	0.0	13.9	1,514.3	0.0	0.0	1	1	0
03/28/2020 01:00	0.0	13.8	1,683.8	0.0	0.0	1	1	0
03/28/2020 02:00	0.0	13.8	1,693.4	0.0	0.0	1	1	0
03/28/2020 03:00	0.0	13.8	1,696.4	0.0	0.0	1	1	0
03/28/2020 04:00	0.0	13.8	1,676.9	0.0	0.0	1	1	0
03/28/2020 05:00	0.0	13.8	1,678.7	0.0	0.0	1	1	0
03/28/2020 06:00	0.0	13.8	1,559.6	0.0	0.0	1	1	0
03/28/2020 07:00	0.0	13.8	1,527.0	0.0	0.0	1	1	0
03/28/2020 08:00	0.0	13.8	1,639.4	0.0	0.0	1	1	0
03/28/2020 09:00	0.0	13.8	1,665.2	0.0	0.0	1	1	0
03/28/2020 10:00	0.0	13.8	1,692.7	0.0	0.0	1	1	0
03/28/2020 11:00	0.0	13.8	1,698.4	0.0	0.0	1	1	0
03/28/2020 12:00	0.0	13.8	1,687.9	0.0	0.0	1	1	0
03/28/2020 13:00	0.0	13.8	1,691.7	0.0	0.0	1	1	0
03/28/2020 14:00	0.0	13.8	1,670.2	0.0	0.0	1	1	0
03/28/2020 15:00	0.0	13.9	1,670.5	0.0	0.0	1	1	0
03/28/2020 16:00	0.0	13.8	1,698.8	0.0	0.0	1	1	0
03/28/2020 17:00	0.0	13.3	1,846.2	0.0	0.0	1	1	1
03/28/2020 18:00	0.0	12.4	2,114.3	0.0	0.0	1	1	1
03/28/2020 19:00	0.0	12.5	2,080.3	0.0	0.0	1	1	1
03/28/2020 20:00	0.0	12.3	2,117.6	0.0	0.0	1	1	1
03/28/2020 21:00	0.0	12.6	2,064.6	0.0	0.0	1	1	1
03/28/2020 22:00	0.0	12.6	2,055.4	0.0	0.0	1	1	1
03/28/2020 23:00	0.0	12.9	1,968.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,766.3	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.3	1,514.3	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,117.6	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/29/2020 00:00	0.0	13.8	1,646.7	0.0	0.0	1	1	0
03/29/2020 01:00	0.0	13.8	1,606.5	0.0	0.0	1	1	0
03/29/2020 02:00	0.0	13.8	1,615.4	0.0	0.0	1	1	0
03/29/2020 03:00	0.0	13.8	1,564.6	0.0	0.0	1	1	0
03/29/2020 04:00	0.0	13.8	1,699.9	0.0	0.0	1	1	0
03/29/2020 05:00	0.0	13.8	1,615.7	0.0	0.0	1	1	0
03/29/2020 06:00	0.0	13.8	1,593.2	0.0	0.0	1	1	0
03/29/2020 07:00	0.0	13.8	1,618.2	0.0	0.0	1	1	0
03/29/2020 08:00	0.0	13.8	1,603.0	0.0	0.0	1	1	0
03/29/2020 09:00	0.0	13.8	1,679.2	0.0	0.0	1	1	0
03/29/2020 10:00	0.0	13.8	1,702.6	0.0	0.0	1	1	0
03/29/2020 11:00	0.0	13.8	1,679.4	0.0	0.0	1	1	0
03/29/2020 12:00	0.0	13.9	1,571.1	0.0	0.0	1	1	0
03/29/2020 13:00	0.0	13.8	1,614.5	0.0	0.0	1	1	0
03/29/2020 14:00	0.0	13.9	1,597.8	0.0	0.0	1	1	0
03/29/2020 15:00	0.0	13.9	1,595.7	0.0	0.0	1	1	0
03/29/2020 16:00	0.0	13.9	1,652.6	0.0	0.0	1	1	0
03/29/2020 17:00	0.0	13.8	1,561.9	0.0	0.0	1	1	1
03/29/2020 18:00	0.0	12.6	2,026.3	0.0	0.0	1	1	1
03/29/2020 19:00	0.0	12.3	2,096.9	0.0	0.0	1	1	1
03/29/2020 20:00	0.0	12.4	2,079.0	0.0	0.0	1	1	1
03/29/2020 21:00	0.0	12.4	2,074.3	0.0	0.0	1	1	1
03/29/2020 22:00	0.0	13.0	1,951.3	0.0	0.0	1	1	1
03/29/2020 23:00	0.0	12.9	1,958.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,725.2	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.3	1,561.9	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,096.9	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/30/2020 00:00	0.0	13.8	1,687.9	0.0	0.0	1	1	0
03/30/2020 01:00	0.0	13.8	1,688.9	0.0	0.0	1	1	0
03/30/2020 02:00	0.0	13.8	1,677.1	0.0	0.0	1	1	0
03/30/2020 03:00	0.0	13.8	1,649.8	0.0	0.0	1	1	0
03/30/2020 04:00	0.0	13.8	1,626.3	0.0	0.0	1	1	0
03/30/2020 05:00	0.0	13.8	1,677.8	0.0	0.0	1	1	0
03/30/2020 06:00	0.0	13.8	1,686.9	0.0	0.0	1	1	0
03/30/2020 07:00	0.0	13.8	1,663.8	0.0	0.0	1	1	0
03/30/2020 08:00	0.0	13.8	1,640.7	0.0	0.0	1	1	0
03/30/2020 09:00	0.0	13.8	1,664.4	0.0	0.0	1	1	0
03/30/2020 10:00	0.0	13.9	1,666.9	0.0	0.0	1	1	0
03/30/2020 11:00	0.0	13.9	1,641.2	0.0	0.0	1	1	0
03/30/2020 12:00	0.0	13.9	1,606.7	0.0	0.0	1	1	0
03/30/2020 13:00	0.0	13.9	1,595.8	0.0	0.0	1	1	0
03/30/2020 14:00	0.0	13.9	1,651.7	0.0	0.0	1	1	0
03/30/2020 15:00	0.0	13.9	1,613.2	0.0	0.0	1	1	0
03/30/2020 16:00	0.0	13.9	1,663.6	0.0	0.0	1	1	0
03/30/2020 17:00	0.0	13.9	1,657.4	0.0	0.0	1	1	1
03/30/2020 18:00	0.0	12.7	2,003.2	0.0	0.0	1	1	1
03/30/2020 19:00	0.0	12.5	2,049.4	0.0	0.0	1	1	1
03/30/2020 20:00	0.0	12.3	2,103.5	0.0	0.0	1	1	1
03/30/2020 21:00	0.0	12.3	2,103.4	0.0	0.0	1	1	1
03/30/2020 22:00	0.0	12.4	2,089.8	0.0	0.0	1	1	1
03/30/2020 23:00	0.0	12.7	2,025.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,755.6	0.0	0.0 #	24 #	24 #	7 #
Minimum:	0.0	12.3	1,595.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,103.5	0.0	0.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
03/31/2020 00:00	0.0	12.6	2,033.6	0.0	0.0	1	1	1
03/31/2020 01:00	0.0	12.6	2,033.7	0.0	0.0	1	1	1
03/31/2020 02:00	0.0	12.7	2,035.1	0.0	0.0	1	1	1
03/31/2020 03:00	0.0	12.7	2,032.8	0.0	0.0	1	1	1
03/31/2020 04:00	0.0	12.8	2,017.7	0.0	0.0	1	1	1
03/31/2020 05:00	0.0	13.1	1,948.6	0.0	0.0	1	1	1
03/31/2020 06:00	0.0	12.7	2,032.9	0.0	0.0	1	1	1
03/31/2020 07:00	5.0	14.3	1,217.9	0.0	6.1	1	0	1
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
03/31/2020 18:00	11.9	17.5	469.7	0.0	18.9	1	0	0
03/31/2020 19:00	20.5	15.2	919.4	0.0	43.7	1	0	0
03/31/2020 20:00	0.0	13.9	1,430.6	0.0	0.0	1	1	0
03/31/2020 21:00	0.0	13.9	1,349.9	0.0	0.0	1	1	0
03/31/2020 22:00	0.0	13.9	1,359.3	0.0	0.0	1	1	0
03/31/2020 23:00	0.0	13.9	1,510.0	0.0	0.0	1	1	0
Average/Sum#:	2.7	13.7	1,599.4	0.0	68.7 #	14 #	11 #	8 #
Minimum:	0.0	12.6	469.7	0.0	0.0	0	0	0
Maximum:	20.5	17.5	2,035.1	0.0	43.7	1	1	1
%SI	41.67	41.67	41.67	62.50	41.67	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:56 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:56 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/01/2020 00:00	10.6	13.4	8.3	132.5	3,378,023.5	2,047.4	1.3	1.0
01/01/2020 01:00	10.5	13.4	8.3	132.4	3,394,502.4	2,032.6	1.3	1.0
01/01/2020 02:00	17.3	15.0	17.3	136.0	2,460,616.5	1,132.0	1.8	0.8
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.8	13.9	11.3	133.6	3,077,714.1	1,737.3	1.5	0.9
Minimum:	10.5	13.4	8.3	132.4	2,460,616.5	1,132.0	1.3	0.8
Maximum:	17.3	15.0	17.3	136.0	3,394,502.4	2,047.4	1.8	1.0
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 07:00	29.0	17.8	55.2	0.0	1,904,007.1	375.4	0.0	0.0
01/02/2020 08:00	43.9	15.9	51.8	147.0	2,134,422.4	794.9	0.0	0.0
01/02/2020 09:00	8.5	13.9	7.2	106.3	2,973,802.9	1,520.1	1.2	0.8
01/02/2020 10:00	8.7	13.9	7.3	103.6	3,234,189.1	1,653.2	1.0	0.7
01/02/2020 11:00	8.7	13.9	7.3	104.6	3,266,468.4	1,669.7	1.0	0.7
01/02/2020 12:00	8.7	14.0	7.4	104.7	3,161,022.7	1,615.8	1.1	0.6
01/02/2020 13:00	8.7	14.0	7.4	102.9	3,206,409.4	1,639.0	1.0	0.7
01/02/2020 14:00	8.7	14.0	7.4	102.2	3,179,216.5	1,625.1	1.1	0.7
01/02/2020 15:00	9.3	13.9	7.8	100.7	3,105,072.0	1,587.2	1.1	0.6
01/02/2020 16:00	11.4	13.5	9.1	141.9	3,336,775.8	2,022.4	1.4	1.0
01/02/2020 17:00	11.0	13.5	8.8	147.1	3,315,134.8	2,057.7	1.5	1.2
01/02/2020 18:00	11.0	13.4	8.7	155.4	3,346,013.3	2,101.3	1.6	1.3
01/02/2020 19:00	10.8	13.4	8.5	154.1	3,347,924.1	2,102.5	1.6	1.3
01/02/2020 20:00	10.6	13.4	8.3	153.1	3,357,000.6	2,108.2	1.5	1.3
01/02/2020 21:00	10.7	13.4	8.4	159.1	3,310,894.7	2,127.6	1.6	1.3
01/02/2020 22:00	10.9	13.4	8.6	162.0	3,328,488.3	2,114.6	1.7	1.5
01/02/2020 23:00	10.4	13.4	8.2	143.8	3,402,442.1	2,062.2	1.4	1.0
Average/Sum#:	13.0	14.0	13.4	122.9	3,112,310.8	1,716.3	1.2	0.9
Minimum:	8.5	13.4	7.2	0.0	1,904,007.1	375.4	0.0	0.0
Maximum:	43.9	17.8	55.2	162.0	3,402,442.1	2,127.6	1.7	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/03/2020 00:00	10.4	13.5	8.3	137.1	3,413,039.8	2,043.7	1.3	1.0
01/03/2020 01:00	10.5	13.5	8.4	140.3	3,366,639.1	2,040.5	1.4	1.0
01/03/2020 02:00	10.4	13.5	8.3	136.2	3,397,675.5	2,034.5	1.3	1.0
01/03/2020 03:00	10.3	13.5	8.2	134.0	3,417,381.8	2,046.3	1.3	1.0
01/03/2020 04:00	10.3	13.5	8.2	135.1	3,420,888.9	2,048.4	1.3	1.0
01/03/2020 05:00	10.4	13.5	8.3	141.7	3,402,852.6	2,037.6	1.4	1.0
01/03/2020 06:00	10.7	13.5	8.5	130.8	3,413,078.9	2,018.8	1.3	1.0
01/03/2020 07:00	10.3	13.5	8.2	129.4	3,437,424.3	2,033.2	1.3	1.0
01/03/2020 08:00	8.7	13.7	7.1	111.8	3,394,370.6	1,883.8	1.1	0.8
01/03/2020 09:00	8.6	13.9	7.2	96.2	2,975,954.8	1,521.2	1.1	0.6
01/03/2020 10:00	8.6	13.9	7.2	97.3	3,025,645.4	1,546.6	1.1	0.6
01/03/2020 11:00	8.7	13.9	7.3	100.4	3,115,049.2	1,592.3	1.1	0.6
01/03/2020 12:00	8.7	13.9	7.3	105.1	3,276,250.0	1,674.7	1.1	0.7
01/03/2020 13:00	8.7	13.9	7.3	104.1	3,234,580.4	1,653.4	1.1	0.7
01/03/2020 14:00	8.7	13.9	7.3	97.2	3,012,733.6	1,540.0	1.1	0.6
01/03/2020 15:00	8.7	13.9	7.3	98.5	3,081,009.2	1,574.9	1.0	0.6
01/03/2020 16:00	10.5	13.5	8.4	122.5	3,375,197.7	1,947.1	1.2	1.0
01/03/2020 17:00	10.6	13.4	8.3	132.5	3,386,319.3	2,027.7	1.3	1.0
01/03/2020 18:00	10.5	13.4	8.3	136.4	3,394,357.6	2,057.3	1.3	1.0
01/03/2020 19:00	10.5	13.4	8.3	137.1	3,372,743.8	2,044.2	1.4	1.0
01/03/2020 20:00	10.4	13.4	8.2	135.5	3,403,432.1	2,062.8	1.3	1.0
01/03/2020 21:00	10.4	13.4	8.2	142.3	3,369,580.2	2,116.1	1.4	1.1
01/03/2020 22:00	10.4	13.4	8.2	143.0	3,413,088.9	2,118.5	1.4	1.1
01/03/2020 23:00	13.1	14.0	11.2	140.4	2,985,523.0	1,678.7	1.6	1.0
Average/Sum#:	10.0	13.6	8.1	124.4	3,295,200.7	1,889.3	1.3	0.9
Minimum:	8.6	13.4	7.1	96.2	2,975,954.8	1,521.2	1.0	0.6
Maximum:	13.1	14.0	11.2	143.0	3,437,424.3	2,118.5	1.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/04/2020 00:00	3.1	19.3	11.4	22.5	1,825.9	0.2	462.2	0.0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	3.1	19.3	11.4	22.5	1,825.9	0.2	462.2	0.0
Minimum:	3.1	19.3	11.4	22.5	1,825.9	0.2	462.2	0.0
Maximum:	3.1	19.3	11.4	22.5	1,825.9	0.2	462.2	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 07:00	14.4	18.5	35.4	0.0	2,081,525.1	212.8	0.0	0.0
01/06/2020 08:00	48.1	16.7	67.6	86.4	1,916,238.7	601.7	0.0	0.0
01/06/2020 09:00	14.5	14.1	12.6	161.6	3,080,197.9	1,529.5	1.8	1.1
01/06/2020 10:00	8.5	14.0	7.3	97.0	3,025,254.1	1,546.4	1.0	0.6
01/06/2020 11:00	8.6	14.0	7.4	102.9	3,215,604.1	1,643.7	1.0	0.7
01/06/2020 12:00	8.7	14.0	7.4	99.9	3,081,009.2	1,574.9	1.1	0.6
01/06/2020 13:00	8.8	13.9	7.4	102.5	3,184,694.2	1,627.9	1.1	0.7
01/06/2020 14:00	8.8	13.9	7.4	98.3	3,048,143.0	1,558.1	1.1	0.6
01/06/2020 15:00	9.0	13.9	7.6	97.7	3,019,776.4	1,543.6	1.1	0.6
01/06/2020 16:00	11.0	13.5	8.8	129.1	3,418,150.9	2,021.8	1.2	1.0
01/06/2020 17:00	10.8	13.4	8.5	134.8	3,388,912.9	2,054.0	1.3	1.0
01/06/2020 18:00	10.6	13.4	8.3	134.2	3,420,554.9	2,048.2	1.3	1.0
01/06/2020 19:00	10.6	13.4	8.3	134.1	3,443,172.5	2,036.6	1.3	1.0
01/06/2020 20:00	10.6	13.5	8.5	134.3	3,432,859.5	2,030.5	1.3	1.0
01/06/2020 21:00	10.4	13.4	8.2	130.3	3,440,467.4	2,035.0	1.3	1.0
01/06/2020 22:00	10.4	13.4	8.2	134.0	3,437,923.2	2,058.6	1.3	1.0
01/06/2020 23:00	10.3	13.5	8.2	127.4	3,498,619.3	2,018.3	1.2	1.0
Average/Sum#:	12.6	14.1	13.4	112.0	3,125,476.7	1,655.4	1.1	0.8
Minimum:	8.5	13.4	7.3	0.0	1,916,238.7	212.8	0.0	0.0
Maximum:	48.1	18.5	67.6	161.6	3,498,619.3	2,058.6	1.8	1.1
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/07/2020 00:00	10.4	13.4	8.2	130.1	3,446,046.6	2,038.3	1.3	1.0
01/07/2020 01:00	10.3	13.5	8.2	125.8	3,504,339.7	2,021.6	1.2	1.0
01/07/2020 02:00	10.4	13.5	8.3	126.4	3,485,791.8	2,010.9	1.2	1.0
01/07/2020 03:00	10.2	13.5	8.1	125.9	3,484,058.3	2,009.9	1.2	1.0
01/07/2020 04:00	10.4	13.4	8.2	129.3	3,474,229.7	2,029.6	1.2	1.0
01/07/2020 05:00	10.5	13.5	8.4	137.3	3,485,013.9	2,035.9	1.3	1.0
01/07/2020 06:00	10.7	13.4	8.4	128.7	3,484,500.3	2,035.6	1.2	1.0
01/07/2020 07:00	10.4	13.4	8.2	132.8	3,475,331.9	2,081.0	1.3	1.0
01/07/2020 08:00	9.0	13.7	7.4	113.9	3,470,409.7	1,926.0	1.1	0.8
01/07/2020 09:00	8.5	13.9	7.2	106.7	3,308,606.5	1,715.4	1.1	0.7
01/07/2020 10:00	8.5	13.9	7.2	101.1	3,119,394.4	1,617.3	1.1	0.6
01/07/2020 11:00	8.7	13.9	7.3	100.5	3,095,284.9	1,604.8	1.1	0.6
01/07/2020 12:00	8.7	13.9	7.3	104.5	3,223,162.1	1,671.1	1.1	0.7
01/07/2020 13:00	8.8	13.9	7.4	102.8	3,163,370.3	1,640.1	1.1	0.7
01/07/2020 14:00	8.7	13.9	7.3	99.6	3,059,216.9	1,586.1	1.1	0.6
01/07/2020 15:00	8.9	13.9	7.5	98.5	3,019,098.6	1,565.3	1.1	0.6
01/07/2020 16:00	10.3	13.5	8.2	121.6	3,441,877.0	2,010.7	1.2	1.0
01/07/2020 17:00	10.6	13.4	8.3	128.3	3,445,032.2	2,037.7	1.2	1.0
01/07/2020 18:00	10.4	13.4	8.2	127.7	3,441,312.8	2,035.5	1.2	1.0
01/07/2020 19:00	10.4	13.4	8.2	127.8	3,422,715.6	2,024.5	1.2	1.0
01/07/2020 20:00	10.3	13.4	8.1	129.1	3,437,422.2	2,058.3	1.3	1.0
01/07/2020 21:00	10.2	13.4	8.0	130.6	3,426,035.8	2,076.5	1.3	1.0
01/07/2020 22:00	16.0	14.8	15.5	132.8	2,581,875.9	1,263.2	1.7	0.9
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.1	13.6	8.2	120.1	3,325,831.6	1,873.7	1.2	0.9
Minimum:	8.5	13.4	7.2	98.5	2,581,875.9	1,263.2	1.1	0.6
Maximum:	16.0	14.8	15.5	137.3	3,504,339.7	2,081.0	1.7	1.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/09/2020 02:00	28.6	17.8	54.4	0.0	1,933,424.4	381.2	0.0	0.0
01/09/2020 03:00	36.9	15.5	40.3	118.9	2,281,212.0	916.2	0.0	0.0
01/09/2020 04:00	8.9	13.8	7.4	110.7	3,250,357.7	1,685.2	1.1	0.7
01/09/2020 05:00	8.8	13.9	7.4	103.2	3,140,610.9	1,628.3	1.1	0.7
01/09/2020 06:00	8.7	13.9	7.3	88.1	2,712,634.1	1,386.6	1.1	0.6
01/09/2020 07:00	9.0	13.9	7.6	94.7	2,860,361.1	1,483.0	1.1	0.6
01/09/2020 08:00	9.0	13.9	7.6	102.6	3,131,545.7	1,623.6	1.1	0.6
01/09/2020 09:00	8.9	13.9	7.5	107.2	3,273,888.7	1,697.4	1.1	0.7
01/09/2020 10:00	8.9	13.9	7.5	99.9	3,033,950.1	1,573.0	1.1	0.6
01/09/2020 11:00	8.8	13.9	7.4	105.3	3,217,375.8	1,668.1	1.1	0.7
01/09/2020 12:00	8.8	13.9	7.4	103.2	3,155,655.3	1,636.1	1.1	0.7
01/09/2020 13:00	8.8	13.9	7.4	105.8	3,281,727.7	1,677.5	1.1	0.7
01/09/2020 14:00	8.8	13.9	7.4	101.6	3,140,090.1	1,605.1	1.1	0.6
01/09/2020 15:00	9.0	13.9	7.6	99.3	3,051,860.1	1,560.0	1.1	0.6
01/09/2020 16:00	11.0	13.5	8.8	133.6	3,404,689.6	2,038.7	1.3	1.0
01/09/2020 17:00	10.9	13.4	8.6	145.4	3,383,928.2	2,100.4	1.4	1.1
01/09/2020 18:00	10.9	13.4	8.6	156.4	3,375,080.2	2,144.2	1.6	1.3
01/09/2020 19:00	10.7	13.4	8.4	157.6	3,362,015.6	2,135.9	1.6	1.3
01/09/2020 20:00	10.8	13.4	8.5	159.9	3,369,728.4	2,140.8	1.6	1.3
01/09/2020 21:00	10.8	13.4	8.5	152.4	3,365,917.7	2,113.8	1.5	1.3
01/09/2020 22:00	10.6	13.4	8.3	152.5	3,389,166.1	2,128.4	1.5	1.3
01/09/2020 23:00	10.7	13.4	8.4	151.5	3,384,548.3	2,125.5	1.5	1.3
Average/Sum#:	11.7	14.0	11.5	115.9	3,113,625.8	1,702.2	1.1	0.8
Minimum:	8.7	13.4	7.3	0.0	1,933,424.4	381.2	0.0	0.0
Maximum:	36.9	17.8	54.4	159.9	3,404,689.6	2,144.2	1.6	1.3
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/10/2020 00:00	10.4	13.4	8.2	143.3	3,381,663.1	2,074.3	1.4	1.0
01/10/2020 01:00	10.4	13.5	8.3	138.8	3,432,579.1	2,055.4	1.4	1.0
01/10/2020 02:00	10.6	13.4	8.3	150.9	3,414,538.9	2,119.4	1.5	1.3
01/10/2020 03:00	10.5	13.4	8.3	149.0	3,382,796.7	2,124.4	1.5	1.3
01/10/2020 04:00	10.5	13.5	8.4	138.2	3,413,707.8	2,044.1	1.4	1.0
01/10/2020 05:00	10.5	13.5	8.4	141.0	3,442,432.3	2,061.3	1.4	1.0
01/10/2020 06:00	10.6	13.4	8.3	142.2	3,490,401.9	2,141.0	1.4	1.1
01/10/2020 07:00	10.5	13.4	8.3	156.1	3,428,229.5	2,203.0	1.5	1.3
01/10/2020 08:00	10.3	13.4	8.1	136.5	3,468,317.8	2,076.8	1.3	1.0
01/10/2020 09:00	8.5	13.7	7.0	113.2	3,449,147.6	1,914.2	1.1	0.8
01/10/2020 10:00	8.4	13.9	7.1	105.5	3,319,680.3	1,696.9	1.0	0.7
01/10/2020 11:00	8.5	13.9	7.2	103.5	3,195,195.0	1,656.6	1.1	0.7
01/10/2020 12:00	8.6	13.9	7.2	102.3	3,145,432.8	1,630.8	1.1	0.7
01/10/2020 13:00	8.6	13.9	7.2	104.5	3,230,684.3	1,675.0	1.1	0.7
01/10/2020 14:00	8.7	13.9	7.3	96.8	2,999,430.7	1,533.2	1.1	0.6
01/10/2020 15:00	8.8	13.9	7.4	96.9	2,972,036.7	1,540.9	1.1	0.6
01/10/2020 16:00	10.7	13.5	8.5	127.5	3,438,945.9	2,034.1	1.2	1.0
01/10/2020 17:00	10.7	13.4	8.4	138.6	3,398,943.9	2,084.9	1.4	1.0
01/10/2020 18:00	10.6	13.4	8.3	144.6	3,411,961.1	2,117.8	1.4	1.1
01/10/2020 19:00	10.5	13.4	8.3	140.5	3,415,246.6	2,094.9	1.4	1.0
01/10/2020 20:00	10.4	13.4	8.2	136.7	3,435,110.3	2,082.0	1.3	1.0
01/10/2020 21:00	10.4	13.4	8.2	137.3	3,413,826.5	2,069.1	1.3	1.0
01/10/2020 22:00	10.4	13.4	8.2	133.2	3,403,854.6	2,038.2	1.3	1.0
01/10/2020 23:00	10.3	13.4	8.1	128.4	3,417,643.7	2,021.5	1.3	1.0
Average/Sum#:	9.9	13.6	8.0	129.4	3,354,242.0	1,962.1	1.3	1.0
Minimum:	8.4	13.4	7.0	96.8	2,972,036.7	1,533.2	1.0	0.6
Maximum:	10.7	13.9	8.5	156.1	3,490,401.9	2,203.0	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/11/2020 00:00	10.3	13.4	8.1	130.4	3,440,298.4	2,034.9	1.3	1.0
01/11/2020 01:00	10.3	13.4	8.1	127.7	3,431,507.0	2,029.7	1.2	1.0
01/11/2020 02:00	10.1	13.4	7.9	125.3	3,444,694.1	2,037.5	1.2	1.0
01/11/2020 03:00	10.3	13.4	8.1	128.2	3,488,608.6	2,038.0	1.2	1.0
01/11/2020 04:00	10.3	13.4	8.1	129.1	3,458,050.2	2,045.4	1.2	1.0
01/11/2020 05:00	10.3	13.4	8.1	127.4	3,438,607.7	2,033.9	1.2	1.0
01/11/2020 06:00	10.7	13.4	8.4	129.5	3,443,172.5	2,036.6	1.2	1.0
01/11/2020 07:00	10.5	13.4	8.3	130.1	3,452,302.0	2,042.0	1.3	1.0
01/11/2020 08:00	15.8	14.7	15.0	132.5	2,638,288.1	1,290.8	1.6	0.8
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.0	13.5	8.9	128.9	3,359,503.2	1,954.3	1.3	1.0
Minimum:	10.1	13.4	7.9	125.3	2,638,288.1	1,290.8	1.2	0.8
Maximum:	15.8	14.7	15.0	132.5	3,488,608.6	2,045.4	1.6	1.0
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/13/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/13/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/13/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/13/2020 03:00	21.6	18.2	47.2	0.0	2,033,269.2	311.8	0.0	0.0
01/13/2020 04:00	45.7	16.7	64.2	107.3	1,925,019.4	590.4	0.0	0.0
01/13/2020 05:00	50.3	15.6	56.0	243.3	2,021,519.4	811.9	3.8	1.2
01/13/2020 06:00	8.4	13.9	7.1	121.7	3,142,732.5	1,629.4	1.3	0.8
01/13/2020 07:00	8.6	13.9	7.2	102.5	3,111,679.4	1,613.3	1.1	0.6
01/13/2020 08:00	8.8	13.9	7.4	98.3	2,970,300.8	1,540.0	1.1	0.6
01/13/2020 09:00	8.8	13.9	7.4	105.6	3,203,681.6	1,661.0	1.1	0.7
01/13/2020 10:00	8.8	13.9	7.4	101.9	3,068,860.8	1,591.1	1.1	0.6
01/13/2020 11:00	8.8	13.9	7.4	96.2	2,932,111.2	1,520.2	1.1	0.6
01/13/2020 12:00	8.9	13.9	7.5	102.5	3,110,329.2	1,612.6	1.1	0.6
01/13/2020 13:00	8.9	13.9	7.5	106.8	3,258,265.7	1,689.3	1.1	0.7
01/13/2020 14:00	8.8	13.9	7.4	100.5	3,074,944.6	1,571.8	1.1	0.6
01/13/2020 15:00	9.0	13.9	7.6	98.9	2,984,959.4	1,547.6	1.1	0.6
01/13/2020 16:00	10.8	13.4	8.5	127.6	3,387,655.3	2,028.5	1.2	1.0
01/13/2020 17:00	10.9	13.3	8.5	155.9	3,312,314.5	2,152.7	1.6	1.3
01/13/2020 18:00	10.8	13.3	8.4	163.3	3,304,116.7	2,171.5	1.7	1.5
01/13/2020 19:00	10.7	13.3	8.3	155.3	3,321,084.9	2,158.4	1.6	1.3
01/13/2020 20:00	10.6	13.3	8.2	154.0	3,301,389.8	2,145.6	1.6	1.3
01/13/2020 21:00	10.5	13.3	8.2	140.8	3,330,726.7	2,091.7	1.4	1.0
01/13/2020 22:00	10.5	13.4	8.3	136.4	3,314,651.4	2,057.4	1.4	1.0
01/13/2020 23:00	10.5	13.4	8.3	133.9	3,327,701.3	2,041.2	1.3	1.0
Average/Sum#:	13.8	14.1	14.7	121.6	3,020,824.5	1,644.6	1.3	0.8
Minimum:	8.4	13.3	7.1	0.0	1,925,019.4	311.8	0.0	0.0
Maximum:	50.3	18.2	64.2	243.3	3,387,655.3	2,171.5	3.8	1.5
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/14/2020 00:00	10.4	13.4	8.2	135.9	3,343,025.8	2,050.6	1.4	1.0
01/14/2020 01:00	10.6	13.4	8.3	137.8	3,324,766.8	2,039.4	1.4	1.0
01/14/2020 02:00	10.6	13.4	8.3	140.6	3,331,450.9	2,043.5	1.4	1.0
01/14/2020 03:00	10.4	13.4	8.2	137.2	3,328,353.4	2,041.6	1.4	1.0
01/14/2020 04:00	10.4	13.4	8.2	135.7	3,369,608.9	2,042.3	1.4	1.0
01/14/2020 05:00	10.5	13.4	8.3	142.6	3,338,978.9	2,072.5	1.4	1.0
01/14/2020 06:00	10.9	13.4	8.6	145.5	3,363,529.2	2,112.3	1.5	1.3
01/14/2020 07:00	10.7	13.3	8.3	159.7	3,358,782.6	2,182.9	1.6	1.3
01/14/2020 08:00	10.4	13.4	8.2	140.9	3,385,118.1	2,051.7	1.4	1.0
01/14/2020 09:00	10.1	13.5	8.1	155.2	3,284,308.6	1,990.6	1.6	1.2
01/14/2020 10:00	8.3	13.9	7.0	127.8	3,233,384.6	1,676.4	1.3	0.8
01/14/2020 11:00	8.5	13.9	7.2	115.5	3,258,072.8	1,689.2	1.2	0.8
01/14/2020 12:00	8.6	13.9	7.2	120.9	3,200,016.9	1,659.1	1.3	0.8
01/14/2020 13:00	8.6	13.9	7.2	115.3	3,242,642.6	1,681.2	1.2	0.8
01/14/2020 14:00	8.6	13.9	7.2	112.1	1,065,333.5	1,625.9	3.8	2.4
01/14/2020 15:00	8.7	13.9	7.3	106.1	2,958,149.5	1,533.7	1.2	0.8
01/14/2020 16:00	9.0	13.9	7.6	108.9	2,987,081.0	1,548.7	1.2	0.8
01/14/2020 17:00	10.8	13.5	8.6	159.3	3,382,985.4	2,001.0	1.6	1.2
01/14/2020 18:00	10.8	13.4	8.5	164.2	3,373,568.7	2,044.7	1.7	1.4
01/14/2020 19:00	10.6	13.4	8.3	162.2	3,388,582.9	2,053.8	1.6	1.2
01/14/2020 20:00	10.5	13.4	8.3	165.3	3,372,328.4	2,093.2	1.7	1.5
01/14/2020 21:00	10.4	13.4	8.2	162.7	3,385,086.7	2,076.4	1.6	1.2
01/14/2020 22:00	10.3	13.4	8.1	158.3	3,413,206.8	2,043.8	1.6	1.2
01/14/2020 23:00	9.8	13.5	7.8	144.7	3,442,455.5	1,985.9	1.4	1.0
Average/Sum#:	9.9	13.6	8.0	139.8	3,307,195.0	1,930.9	1.4	1.1
Minimum:	8.3	13.3	7.0	106.1	2,958,149.5	1,533.7	1.2	0.8
Maximum:	10.9	13.9	8.6	165.3	3,442,455.5	2,182.9	1.7	1.5
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/15/2020 00:00	10.3	13.4	8.1	153.2	3,442,834.3	2,036.4	1.5	1.2
01/15/2020 01:00	10.3	13.4	8.1	156.1	3,406,693.7	2,039.9	1.6	1.2
01/15/2020 02:00	10.3	13.4	8.1	158.3	3,411,369.7	2,042.7	1.6	1.2
01/15/2020 03:00	10.0	13.4	7.9	150.5	3,448,244.4	2,039.6	1.5	1.2
01/15/2020 04:00	10.1	13.4	7.9	151.7	3,451,118.5	2,041.3	1.5	1.2
01/15/2020 05:00	10.1	13.4	7.9	151.4	3,412,011.6	2,068.0	1.5	1.2
01/15/2020 06:00	10.5	13.4	8.3	177.4	3,431,431.2	2,180.0	1.8	1.5
01/15/2020 07:00	10.2	13.3	7.9	195.0	3,407,782.8	2,289.4	2.0	1.8
01/15/2020 08:00	9.4	13.5	7.5	147.2	3,405,023.6	2,038.9	1.5	1.2
01/15/2020 09:00	8.2	13.9	6.9	100.3	3,107,050.3	1,610.9	1.1	0.6
01/15/2020 10:00	8.8	13.9	7.4	103.9	3,187,287.0	1,652.5	1.1	0.7
01/15/2020 11:00	8.9	13.8	7.4	105.2	3,218,533.1	1,668.7	1.1	0.7
01/15/2020 12:00	8.9	13.8	7.4	102.9	3,139,453.6	1,627.7	1.1	0.7
01/15/2020 13:00	8.8	13.8	7.3	105.0	3,225,090.9	1,672.1	1.1	0.7
01/15/2020 14:00	8.8	13.9	7.4	105.6	3,254,215.2	1,687.2	1.1	0.7
01/15/2020 15:00	8.8	13.8	7.3	100.1	3,067,703.5	1,590.5	1.1	0.6
01/15/2020 16:00	10.7	13.4	8.4	160.8	3,350,851.0	2,055.4	1.6	1.2
01/15/2020 17:00	10.7	13.3	8.3	181.3	3,319,546.3	2,157.4	1.9	1.5
01/15/2020 18:00	10.5	13.3	8.2	174.0	3,355,404.6	2,131.7	1.8	1.5
01/15/2020 19:00	10.5	13.3	8.2	190.0	3,338,656.6	2,194.2	2.0	1.8
01/15/2020 20:00	10.3	13.3	8.0	184.4	3,328,918.5	2,187.8	1.9	1.5
01/15/2020 21:00	10.4	13.3	8.1	184.2	3,305,029.7	2,172.1	1.9	1.5
01/15/2020 22:00	10.1	13.3	7.8	165.8	3,330,567.5	2,091.6	1.7	1.5
01/15/2020 23:00	10.2	13.4	8.0	159.5	3,350,362.0	2,055.1	1.6	1.2
Average/Sum#:	9.8	13.5	7.8	148.5	3,320,632.5	1,972.1	1.5	1.2
Minimum:	8.2	13.3	6.9	100.1	3,067,703.5	1,590.5	1.1	0.6
Maximum:	10.7	13.9	8.4	195.0	3,451,118.5	2,289.4	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/16/2020 00:00	10.2	13.4	8.0	154.8	3,365,319.2	2,039.7	1.6	1.2
01/16/2020 01:00	10.2	13.4	8.0	158.1	3,329,494.5	2,042.3	1.6	1.2
01/16/2020 02:00	10.4	13.4	8.2	160.1	3,334,385.3	2,045.3	1.6	1.2
01/16/2020 03:00	10.4	13.4	8.2	158.8	3,337,971.9	2,047.5	1.6	1.2
01/16/2020 04:00	10.4	13.4	8.2	161.0	3,343,188.8	2,050.7	1.6	1.2
01/16/2020 05:00	10.4	13.4	8.2	167.7	3,297,412.8	2,046.7	1.8	1.4
01/16/2020 06:00	10.8	13.4	8.5	165.7	3,309,707.7	2,078.5	1.7	1.5
01/16/2020 07:00	10.5	13.3	8.2	181.4	3,301,682.2	2,169.9	1.9	1.5
01/16/2020 08:00	10.4	13.4	8.2	165.3	3,298,083.5	2,071.2	1.7	1.4
01/16/2020 09:00	9.9	13.5	7.9	143.6	3,324,658.1	1,966.5	1.5	1.2
01/16/2020 10:00	8.4	13.9	7.1	104.8	3,200,788.4	1,659.5	1.1	0.7
01/16/2020 11:00	8.7	13.8	7.2	100.2	3,037,229.0	1,574.7	1.1	0.6
01/16/2020 12:00	8.7	13.9	7.3	96.1	2,934,425.7	1,521.4	1.1	0.6
01/16/2020 13:00	8.7	13.9	7.3	104.3	3,195,580.7	1,656.8	1.1	0.7
01/16/2020 14:00	8.7	13.9	7.3	100.8	3,079,083.2	1,596.4	1.1	0.6
01/16/2020 15:00	8.8	13.9	7.4	107.7	3,331,558.8	1,727.3	1.1	0.7
01/16/2020 16:00	10.7	13.4	8.4	162.9	3,340,735.5	2,024.8	1.7	1.4
01/16/2020 17:00	10.5	13.4	8.3	160.1	3,321,995.3	2,037.7	1.6	1.2
01/16/2020 18:00	10.4	13.4	8.2	159.7	3,354,264.8	2,033.0	1.6	1.2
01/16/2020 19:00	10.4	13.4	8.2	159.0	3,380,663.3	2,049.0	1.6	1.2
01/16/2020 20:00	10.4	13.4	8.2	165.6	3,373,778.4	2,094.1	1.7	1.5
01/16/2020 21:00	10.3	13.4	8.1	167.0	3,381,672.7	2,099.0	1.7	1.5
01/16/2020 22:00	10.2	13.4	8.0	155.8	3,391,997.4	2,031.1	1.6	1.2
01/16/2020 23:00	10.2	13.4	8.0	156.8	3,402,518.6	2,037.4	1.6	1.2
Average/Sum#:	9.9	13.5	7.9	146.6	3,290,341.5	1,945.9	1.5	1.1
Minimum:	8.4	13.3	7.1	96.1	2,934,425.7	1,521.4	1.1	0.6
Maximum:	10.8	13.9	8.5	181.4	3,402,518.6	2,169.9	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/17/2020 00:00	10.0	13.4	7.9	153.6	3,415,544.8	2,045.2	1.5	1.2
01/17/2020 01:00	10.1	13.4	7.9	153.8	3,411,388.3	2,017.8	1.5	1.2
01/17/2020 02:00	10.1	13.4	7.9	153.1	3,451,287.6	2,041.4	1.5	1.2
01/17/2020 03:00	10.0	13.4	7.9	149.2	3,487,410.4	2,037.3	1.5	1.2
01/17/2020 04:00	10.0	13.4	7.9	152.6	3,467,179.7	2,050.8	1.5	1.2
01/17/2020 05:00	10.0	13.4	7.9	157.1	3,448,945.4	2,065.2	1.6	1.2
01/17/2020 06:00	10.4	13.3	8.1	180.1	3,436,321.5	2,208.2	1.8	1.5
01/17/2020 07:00	10.3	13.3	8.0	196.8	3,399,893.7	2,284.1	2.0	1.8
01/17/2020 08:00	9.8	13.4	7.7	152.7	3,440,428.3	2,060.1	1.5	1.2
01/17/2020 09:00	9.1	13.6	7.4	129.9	3,408,826.6	1,966.5	1.3	1.0
01/17/2020 10:00	8.3	13.8	6.9	105.3	3,245,921.5	1,682.9	1.1	0.7
01/17/2020 11:00	8.5	13.8	7.1	102.6	3,150,061.8	1,633.2	1.1	0.7
01/17/2020 12:00	8.6	13.8	7.1	104.6	3,209,467.9	1,664.0	1.1	0.7
01/17/2020 13:00	8.6	13.8	7.1	104.2	3,181,500.7	1,649.5	1.1	0.7
01/17/2020 14:00	8.7	13.8	7.2	102.9	3,130,774.2	1,623.2	1.1	0.6
01/17/2020 15:00	8.8	13.9	7.4	97.1	2,906,651.5	1,507.0	1.1	0.6
01/17/2020 16:00	10.2	13.5	8.1	153.3	3,387,719.2	2,003.8	1.5	1.2
01/17/2020 17:00	9.7	13.6	7.8	158.2	3,395,132.4	1,958.6	1.6	1.2
01/17/2020 18:00	10.0	13.5	8.0	141.8	3,410,733.4	1,967.6	1.4	1.0
01/17/2020 19:00	10.4	13.4	8.2	164.3	3,415,083.6	2,094.8	1.6	1.3
01/17/2020 20:00	10.3	13.4	8.1	170.8	3,387,892.2	2,127.6	1.7	1.5
01/17/2020 21:00	10.3	13.4	8.1	167.2	3,413,733.3	2,118.9	1.7	1.5
01/17/2020 22:00	10.2	13.4	8.0	162.9	3,417,692.0	2,096.4	1.6	1.3
01/17/2020 23:00	10.1	13.4	7.9	159.5	3,422,901.0	2,074.6	1.6	1.2
Average/Sum#:	9.7	13.5	7.7	144.7	3,351,770.5	1,957.4	1.5	1.1
Minimum:	8.3	13.3	6.9	97.1	2,906,651.5	1,507.0	1.1	0.6
Maximum:	10.4	13.9	8.2	196.8	3,487,410.4	2,284.1	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/18/2020 00:00	10.2	13.4	8.0	158.4	3,431,577.1	2,054.8	1.6	1.2
01/18/2020 01:00	10.1	13.4	7.9	156.8	3,405,741.9	2,064.2	1.6	1.2
01/18/2020 02:00	10.2	13.4	8.0	154.9	3,443,679.7	2,036.9	1.5	1.2
01/18/2020 03:00	10.0	13.4	7.9	154.3	3,445,539.4	2,038.0	1.5	1.2
01/18/2020 04:00	10.2	13.4	8.0	156.5	3,445,708.4	2,038.1	1.5	1.2
01/18/2020 05:00	10.3	13.4	8.1	174.4	3,445,201.2	2,037.8	1.7	1.4
01/18/2020 06:00	10.5	13.4	8.3	154.1	3,455,852.3	2,044.1	1.5	1.2
01/18/2020 07:00	10.2	13.4	8.0	151.8	3,446,215.6	2,038.4	1.5	1.2
01/18/2020 08:00	9.2	13.6	7.4	130.0	3,483,078.3	1,983.9	1.3	1.0
01/18/2020 09:00	8.3	13.9	7.0	105.8	3,239,170.9	1,679.4	1.1	0.7
01/18/2020 10:00	8.4	13.9	7.1	102.1	3,153,533.6	1,635.0	1.1	0.7
01/18/2020 11:00	8.5	13.9	7.2	100.7	3,108,014.7	1,611.4	1.1	0.6
01/18/2020 12:00	8.6	13.9	7.2	101.9	3,140,803.8	1,628.4	1.1	0.7
01/18/2020 13:00	8.6	13.9	7.2	103.4	3,185,358.3	1,651.5	1.1	0.7
01/18/2020 14:00	8.6	13.9	7.2	101.7	3,118,815.8	1,617.0	1.1	0.6
01/18/2020 15:00	8.8	13.9	7.4	101.2	3,087,762.7	1,600.9	1.1	0.6
01/18/2020 16:00	10.6	13.5	8.5	165.3	3,402,596.9	2,012.6	1.7	1.4
01/18/2020 17:00	10.6	13.4	8.3	161.8	3,409,699.7	2,041.7	1.6	1.2
01/18/2020 18:00	9.6	13.5	7.7	138.6	3,393,225.6	1,957.5	1.4	1.0
01/18/2020 19:00	10.5	13.4	8.3	166.7	3,400,132.3	2,060.8	1.7	1.4
01/18/2020 20:00	10.5	13.4	8.3	176.6	3,374,516.5	2,119.2	1.8	1.5
01/18/2020 21:00	10.4	13.4	8.2	176.9	3,387,255.3	2,127.2	1.8	1.5
01/18/2020 22:00	10.4	13.4	8.2	181.6	3,369,571.0	2,140.7	1.9	1.5
01/18/2020 23:00	10.4	13.4	8.2	178.5	3,369,261.7	2,115.9	1.8	1.5
Average/Sum#:	9.7	13.6	7.8	143.9	3,339,263.0	1,930.6	1.5	1.1
Minimum:	8.3	13.4	7.0	100.7	3,087,762.7	1,600.9	1.1	0.6
Maximum:	10.6	13.9	8.5	181.6	3,483,078.3	2,140.7	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/19/2020 00:00	9.8	13.5	7.8	158.9	3,307,812.0	2,029.0	1.7	1.4
01/19/2020 01:00	8.1	13.9	6.8	105.5	3,279,482.1	1,700.3	1.1	0.7
01/19/2020 02:00	8.3	13.9	7.0	97.3	2,993,446.0	1,552.0	1.1	0.6
01/19/2020 03:00	8.5	13.9	7.2	102.0	3,141,382.4	1,628.7	1.1	0.7
01/19/2020 04:00	8.4	13.9	7.1	102.0	3,126,145.1	1,620.8	1.1	0.6
01/19/2020 05:00	8.5	13.9	7.2	104.9	3,227,405.4	1,673.3	1.1	0.7
01/19/2020 06:00	8.7	13.9	7.3	106.1	3,265,016.3	1,692.8	1.1	0.7
01/19/2020 07:00	8.6	13.9	7.2	101.2	3,088,727.1	1,601.4	1.1	0.6
01/19/2020 08:00	8.6	13.9	7.2	98.3	2,999,810.9	1,555.3	1.1	0.6
01/19/2020 09:00	8.6	13.8	7.1	102.2	3,117,658.6	1,616.4	1.1	0.6
01/19/2020 10:00	8.6	13.8	7.1	98.8	3,020,063.0	1,565.8	1.1	0.6
01/19/2020 11:00	8.6	13.9	7.2	103.6	3,162,984.6	1,639.9	1.1	0.7
01/19/2020 12:00	8.6	13.9	7.2	104.2	3,199,052.5	1,658.6	1.1	0.7
01/19/2020 13:00	8.7	13.9	7.3	105.4	3,224,319.4	1,671.7	1.1	0.7
01/19/2020 14:00	8.7	13.9	7.3	100.2	3,051,309.0	1,582.0	1.1	0.6
01/19/2020 15:00	8.8	13.9	7.4	102.9	3,124,602.1	1,620.0	1.1	0.6
01/19/2020 16:00	8.9	13.8	7.4	101.9	3,113,993.9	1,614.5	1.1	0.6
01/19/2020 17:00	10.4	13.4	8.2	158.6	3,401,075.3	2,011.7	1.6	1.2
01/19/2020 18:00	10.5	13.4	8.3	158.1	3,376,208.6	2,046.3	1.6	1.2
01/19/2020 19:00	10.4	13.4	8.2	158.6	3,364,989.2	2,039.5	1.6	1.2
01/19/2020 20:00	10.4	13.3	8.1	164.3	3,352,701.2	2,105.5	1.7	1.5
01/19/2020 21:00	10.2	13.3	7.9	167.2	3,358,237.8	2,133.5	1.7	1.5
01/19/2020 22:00	10.2	13.3	7.9	168.5	3,352,886.1	2,130.1	1.7	1.5
01/19/2020 23:00	10.3	13.3	8.0	170.0	3,373,401.8	2,118.5	1.7	1.5
Average/Sum#:	9.1	13.7	7.5	122.5	3,209,279.6	1,775.3	1.3	0.9
Minimum:	8.1	13.3	6.8	97.3	2,993,446.0	1,552.0	1.1	0.6
Maximum:	10.5	13.9	8.3	170.0	3,401,075.3	2,133.5	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/20/2020 00:00	10.3	13.3	8.0	164.9	3,357,989.7	2,084.3	1.7	1.5
01/20/2020 01:00	10.2	13.4	8.0	158.2	3,377,858.5	2,047.3	1.6	1.2
01/20/2020 02:00	10.1	13.4	7.9	152.4	3,390,494.4	2,030.2	1.5	1.2
01/20/2020 03:00	10.1	13.4	7.9	153.5	3,401,683.6	2,036.9	1.5	1.2
01/20/2020 04:00	10.3	13.4	8.1	157.8	3,367,794.0	2,041.2	1.6	1.2
01/20/2020 05:00	10.3	13.4	8.1	171.7	3,347,753.5	2,053.5	1.8	1.4
01/20/2020 06:00	10.6	13.4	8.3	160.7	3,400,627.2	2,061.1	1.6	1.2
01/20/2020 07:00	10.4	13.3	8.1	169.0	3,381,204.3	2,123.4	1.7	1.5
01/20/2020 08:00	10.4	13.3	8.1	174.4	3,373,348.7	2,143.1	1.8	1.5
01/20/2020 09:00	10.4	13.3	8.1	173.0	3,339,034.4	2,121.3	1.8	1.5
01/20/2020 10:00	10.2	13.3	7.9	172.9	3,335,482.1	2,143.4	1.8	1.5
01/20/2020 11:00	10.2	13.3	7.9	171.9	3,332,266.0	2,117.0	1.8	1.5
01/20/2020 12:00	10.4	13.3	8.1	179.8	3,290,157.5	2,138.3	1.9	1.5
01/20/2020 13:00	10.3	13.3	8.0	177.8	3,317,897.4	2,132.1	1.9	1.5
01/20/2020 14:00	10.3	13.3	8.0	189.2	3,277,336.9	2,153.9	2.0	1.7
01/20/2020 15:00	10.3	13.3	8.0	181.2	3,294,243.7	2,116.9	1.9	1.5
01/20/2020 16:00	10.2	13.4	8.0	167.8	3,301,905.1	2,073.6	1.8	1.5
01/20/2020 17:00	10.3	13.3	8.0	176.2	3,308,871.7	2,126.3	1.8	1.5
01/20/2020 18:00	10.3	13.3	8.0	172.9	3,301,557.7	2,121.6	1.8	1.5
01/20/2020 19:00	10.2	13.3	7.9	172.3	3,337,145.6	2,120.1	1.8	1.5
01/20/2020 20:00	10.2	13.3	7.9	170.6	3,333,997.5	2,118.1	1.8	1.5
01/20/2020 21:00	10.2	13.3	7.9	170.8	3,334,312.3	2,118.3	1.8	1.5
01/20/2020 22:00	10.1	13.3	7.8	166.1	3,348,083.4	2,102.6	1.7	1.5
01/20/2020 23:00	10.2	13.4	8.0	163.8	3,336,562.2	2,071.0	1.7	1.4
Average/Sum#:	10.3	13.3	8.0	169.5	3,341,150.3	2,099.8	1.8	1.4
Minimum:	10.1	13.3	7.8	152.4	3,277,336.9	2,030.2	1.5	1.2
Maximum:	10.6	13.4	8.3	189.2	3,401,683.6	2,153.9	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/21/2020 00:00	10.3	13.4	8.1	159.1	3,374,063.7	2,045.0	1.6	1.2
01/21/2020 01:00	10.3	13.4	8.1	157.8	3,359,544.5	2,036.2	1.6	1.2
01/21/2020 02:00	10.1	13.4	7.9	155.0	3,367,464.1	2,041.0	1.6	1.2
01/21/2020 03:00	10.3	13.4	8.1	158.0	3,355,749.7	2,033.9	1.6	1.2
01/21/2020 04:00	10.3	13.4	8.1	160.3	3,363,504.3	2,038.6	1.6	1.2
01/21/2020 05:00	10.2	13.4	8.0	157.7	3,367,794.0	2,041.2	1.6	1.2
01/21/2020 06:00	10.6	13.4	8.3	157.5	3,357,260.8	2,010.3	1.6	1.2
01/21/2020 07:00	10.5	13.3	8.2	168.4	3,334,070.7	2,093.8	1.7	1.5
01/21/2020 08:00	10.4	13.4	8.2	160.9	3,357,535.1	2,059.5	1.6	1.2
01/21/2020 09:00	9.7	13.5	7.7	142.2	3,330,068.2	1,969.7	1.5	1.2
01/21/2020 10:00	8.4	13.8	7.0	105.2	3,229,719.9	1,674.5	1.1	0.7
01/21/2020 11:00	8.6	13.8	7.1	105.5	3,250,743.5	1,685.4	1.1	0.7
01/21/2020 12:00	8.7	13.8	7.2	104.1	3,183,815.3	1,650.7	1.1	0.7
01/21/2020 13:00	8.8	13.8	7.3	102.9	3,129,424.0	1,622.5	1.1	0.6
01/21/2020 14:00	8.8	13.8	7.3	103.4	3,147,747.3	1,632.0	1.1	0.7
01/21/2020 15:00	8.8	13.8	7.3	100.7	2,993,638.9	1,552.1	1.1	0.6
01/21/2020 16:00	10.9	13.4	8.6	166.8	3,306,181.7	2,028.0	1.7	1.4
01/21/2020 17:00	10.7	13.3	8.3	162.7	3,309,657.1	2,054.3	1.7	1.4
01/21/2020 18:00	10.5	13.3	8.2	161.9	3,299,829.4	2,048.2	1.7	1.4
01/21/2020 19:00	10.4	13.3	8.1	159.3	3,292,740.7	2,043.8	1.7	1.4
01/21/2020 20:00	10.4	13.3	8.1	161.9	3,286,135.2	2,039.7	1.7	1.4
01/21/2020 21:00	10.4	13.4	8.2	159.3	3,319,386.9	2,036.1	1.6	1.2
01/21/2020 22:00	10.3	13.3	8.0	161.3	3,300,312.8	2,072.6	1.7	1.5
01/21/2020 23:00	10.3	13.4	8.1	161.2	3,333,407.2	2,044.7	1.7	1.4
Average/Sum#:	9.9	13.5	7.9	145.5	3,289,574.8	1,939.7	1.5	1.1
Minimum:	8.4	13.3	7.0	100.7	2,993,638.9	1,552.1	1.1	0.6
Maximum:	10.9	13.8	8.6	168.4	3,374,063.7	2,093.8	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/22/2020 00:00	9.2	13.6	7.4	127.4	3,209,895.6	1,828.3	1.3	0.9
01/22/2020 01:00	9.2	13.9	7.8	87.7	2,514,533.2	1,303.7	1.2	0.7
01/22/2020 02:00	8.6	13.9	7.2	85.8	2,633,538.1	1,365.4	1.1	0.5
01/22/2020 03:00	9.0	13.9	7.6	86.7	2,566,995.7	1,330.9	1.1	0.5
01/22/2020 04:00	8.8	13.8	7.3	95.8	2,882,067.7	1,515.3	1.1	0.6
01/22/2020 05:00	8.8	13.9	7.4	93.6	2,760,531.3	1,451.4	1.1	0.6
01/22/2020 06:00	9.1	13.8	7.6	101.1	3,015,776.8	1,585.6	1.1	0.6
01/22/2020 07:00	9.0	13.8	7.5	104.9	3,119,244.4	1,640.0	1.1	0.7
01/22/2020 08:00	9.1	13.8	7.6	95.7	2,860,746.8	1,483.2	1.1	0.6
01/22/2020 09:00	8.9	13.8	7.4	101.9	3,012,923.8	1,584.1	1.1	0.6
01/22/2020 10:00	8.9	13.8	7.4	102.5	3,069,602.8	1,613.9	1.1	0.6
01/22/2020 11:00	8.8	13.8	7.3	106.4	3,224,614.0	1,695.4	1.1	0.7
01/22/2020 12:00	8.8	13.8	7.3	106.4	3,269,066.7	1,694.9	1.1	0.7
01/22/2020 13:00	8.8	13.8	7.3	104.5	3,189,022.9	1,653.4	1.1	0.7
01/22/2020 14:00	8.8	13.8	7.3	102.8	3,148,518.8	1,632.4	1.1	0.7
01/22/2020 15:00	8.9	13.8	7.4	101.8	3,084,483.8	1,599.2	1.1	0.6
01/22/2020 16:00	10.9	13.4	8.6	167.2	3,348,490.1	2,029.5	1.7	1.4
01/22/2020 17:00	10.8	13.4	8.5	163.8	3,314,337.0	2,008.8	1.7	1.4
01/22/2020 18:00	10.8	13.3	8.4	180.2	3,308,871.7	2,126.3	1.9	1.5
01/22/2020 19:00	10.6	13.3	8.2	177.4	3,336,358.5	2,119.6	1.8	1.5
01/22/2020 20:00	10.4	13.4	8.2	162.3	3,341,884.6	2,049.9	1.7	1.4
01/22/2020 21:00	10.5	13.4	8.3	162.7	3,369,114.0	2,042.0	1.6	1.2
01/22/2020 22:00	10.4	13.4	8.2	161.9	3,380,498.3	2,048.9	1.6	1.2
01/22/2020 23:00	9.4	13.5	7.5	145.6	3,386,291.8	1,953.5	1.5	1.2
Average/Sum#:	9.4	13.7	7.7	121.9	3,097,808.7	1,723.2	1.3	0.9
Minimum:	8.6	13.3	7.2	85.8	2,514,533.2	1,303.7	1.1	0.5
Maximum:	10.9	13.9	8.6	180.2	3,386,291.8	2,126.3	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/23/2020 00:00	10.5	13.3	8.2	164.6	3,341,077.0	2,098.2	1.7	1.5
01/23/2020 01:00	10.3	13.3	8.0	165.4	3,340,758.6	2,098.0	1.7	1.5
01/23/2020 02:00	10.4	13.4	8.2	160.6	3,376,373.6	2,046.4	1.6	1.2
01/23/2020 03:00	10.4	13.4	8.2	159.0	3,376,043.6	2,046.2	1.6	1.2
01/23/2020 04:00	10.4	13.3	8.1	170.4	3,339,191.8	2,121.4	1.8	1.5
01/23/2020 05:00	10.2	13.4	8.0	160.0	3,402,112.1	2,062.0	1.6	1.2
01/23/2020 06:00	10.6	13.3	8.2	170.9	3,396,015.1	2,157.5	1.7	1.5
01/23/2020 07:00	10.2	13.3	7.9	163.9	3,405,033.5	2,113.5	1.7	1.5
01/23/2020 08:00	9.0	13.6	7.3	127.4	3,363,063.6	1,940.1	1.3	1.0
01/23/2020 09:00	8.4	13.8	7.0	104.6	3,179,537.1	1,671.7	1.1	0.7
01/23/2020 10:00	8.6	13.8	7.1	97.7	2,984,959.4	1,547.6	1.1	0.6
01/23/2020 11:00	8.7	13.8	7.2	101.1	3,093,356.1	1,603.8	1.1	0.6
01/23/2020 12:00	8.8	13.8	7.3	103.2	3,144,275.5	1,630.2	1.1	0.7
01/23/2020 13:00	8.8	13.8	7.3	104.9	3,203,102.9	1,660.7	1.1	0.7
01/23/2020 14:00	8.7	13.8	7.2	104.0	3,182,272.2	1,649.9	1.1	0.7
01/23/2020 15:00	8.7	13.8	7.2	102.2	3,118,044.3	1,616.6	1.1	0.6
01/23/2020 16:00	9.0	13.9	7.6	98.2	2,886,592.3	1,496.6	1.1	0.6
01/23/2020 17:00	10.3	13.5	8.2	150.8	3,285,762.6	1,919.5	1.6	1.2
01/23/2020 18:00	10.7	13.3	8.3	173.7	3,309,649.7	2,126.8	1.8	1.5
01/23/2020 19:00	10.6	13.3	8.2	174.7	3,305,603.7	2,124.2	1.8	1.5
01/23/2020 20:00	10.5	13.3	8.2	172.0	3,300,468.4	2,120.9	1.8	1.5
01/23/2020 21:00	10.3	13.3	8.0	172.6	3,318,571.8	2,108.3	1.8	1.5
01/23/2020 22:00	10.4	13.4	8.2	167.1	3,335,917.8	2,070.6	1.7	1.4
01/23/2020 23:00	9.1	13.6	7.4	126.9	3,353,009.6	1,934.3	1.3	1.0
Average/Sum#:	9.7	13.5	7.8	141.5	3,264,199.7	1,915.2	1.5	1.1
Minimum:	8.4	13.3	7.0	97.7	2,886,592.3	1,496.6	1.1	0.6
Maximum:	10.7	13.9	8.3	174.7	3,405,033.5	2,157.5	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/24/2020 00:00	9.1	13.6	7.4	125.8	3,360,181.2	1,913.9	1.3	1.0
01/24/2020 01:00	8.5	13.8	7.1	103.0	3,101,936.4	1,630.9	1.1	0.7
01/24/2020 02:00	8.6	13.8	7.1	103.9	3,156,903.6	1,659.8	1.1	0.7
01/24/2020 03:00	8.6	13.8	7.1	105.7	3,220,239.5	1,693.1	1.1	0.7
01/24/2020 04:00	8.6	13.8	7.1	105.9	3,222,521.9	1,694.3	1.1	0.7
01/24/2020 05:00	8.7	13.8	7.2	104.6	3,030,041.6	1,593.1	1.2	0.8
01/24/2020 06:00	8.9	13.8	7.4	103.9	3,142,448.6	1,652.2	1.1	0.7
01/24/2020 07:00	8.9	13.8	7.4	104.0	3,133,889.7	1,647.7	1.1	0.7
01/24/2020 08:00	8.8	13.8	7.3	100.3	3,022,814.1	1,589.3	1.1	0.6
01/24/2020 09:00	8.8	13.8	7.3	105.0	3,159,946.8	1,661.4	1.1	0.7
01/24/2020 10:00	8.6	13.9	7.2	92.8	2,836,830.1	1,470.8	1.1	0.6
01/24/2020 11:00	8.9	13.8	7.4	105.1	3,144,921.1	1,653.5	1.1	0.7
01/24/2020 12:00	8.8	13.8	7.3	102.9	3,089,193.2	1,624.2	1.1	0.6
01/24/2020 13:00	8.8	13.8	7.3	105.5	3,169,076.3	1,666.2	1.1	0.7
01/24/2020 14:00	8.8	13.8	7.3	104.5	3,123,809.2	1,642.4	1.1	0.7
01/24/2020 15:00	8.8	13.8	7.3	98.1	2,987,273.9	1,548.8	1.1	0.6
01/24/2020 16:00	8.8	13.8	7.3	101.8	3,046,872.8	1,579.7	1.1	0.6
01/24/2020 17:00	10.9	13.4	8.6	161.4	3,350,140.0	2,030.5	1.6	1.2
01/24/2020 18:00	10.7	13.3	8.3	174.9	3,300,935.2	2,121.2	1.8	1.5
01/24/2020 19:00	10.5	13.3	8.2	174.4	3,295,488.7	2,117.7	1.8	1.5
01/24/2020 20:00	10.5	13.3	8.2	174.7	3,286,618.5	2,112.0	1.8	1.5
01/24/2020 21:00	10.4	13.3	8.1	170.1	3,317,828.7	2,083.6	1.8	1.5
01/24/2020 22:00	10.3	13.3	8.0	162.1	3,303,857.2	2,050.7	1.7	1.4
01/24/2020 23:00	15.8	14.7	15.0	152.7	2,515,374.6	1,267.4	2.0	1.0
Average/Sum#:	9.5	13.7	7.8	122.6	3,138,297.6	1,737.7	1.3	0.9
Minimum:	8.5	13.3	7.1	92.8	2,515,374.6	1,267.4	1.1	0.6
Maximum:	15.8	14.7	15.0	174.9	3,360,181.2	2,121.2	2.0	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/28/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/28/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/28/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/28/2020 03:00	33.7	17.5	58.5	0.1	1,882,336.1	453.6	0.0	0.0
01/28/2020 04:00	30.6	15.1	31.1	166.6	2,375,006.9	1,005.9	2.4	0.9
01/28/2020 05:00	8.5	13.8	7.1	101.2	3,035,557.4	1,596.0	1.1	0.6
01/28/2020 06:00	8.6	13.8	7.1	104.8	3,225,945.4	1,696.1	1.1	0.7
01/28/2020 07:00	8.7	13.8	7.2	100.0	3,095,284.9	1,604.8	1.1	0.6
01/28/2020 08:00	8.9	13.8	7.4	108.1	3,169,837.1	1,666.6	1.1	0.7
01/28/2020 09:00	8.8	13.8	7.3	105.2	3,194,182.4	1,679.4	1.1	0.7
01/28/2020 10:00	9.0	13.8	7.5	97.2	2,948,698.6	1,528.8	1.1	0.6
01/28/2020 11:00	8.8	13.8	7.3	101.6	3,060,853.7	1,609.3	1.1	0.6
01/28/2020 12:00	8.7	13.9	7.3	100.4	3,082,362.1	1,598.1	1.1	0.6
01/28/2020 13:00	8.7	13.8	7.2	103.9	3,192,109.0	1,655.0	1.1	0.7
01/28/2020 14:00	8.8	13.8	7.3	99.1	2,985,915.8	1,569.9	1.1	0.6
01/28/2020 15:00	8.8	13.8	7.3	98.7	3,007,333.1	1,559.2	1.1	0.6
01/28/2020 16:00	8.9	13.8	7.4	100.6	2,979,449.0	1,566.5	1.1	0.6
01/28/2020 17:00	10.9	13.4	8.6	164.2	3,334,795.9	2,021.2	1.7	1.4
01/28/2020 18:00	10.8	13.3	8.4	167.0	3,285,663.1	2,063.4	1.7	1.4
01/28/2020 19:00	10.6	13.3	8.2	168.1	3,320,058.0	2,085.0	1.7	1.5
01/28/2020 20:00	10.6	13.3	8.2	172.8	3,293,154.4	2,116.2	1.8	1.5
01/28/2020 21:00	10.5	13.3	8.2	176.5	3,297,667.3	2,119.1	1.8	1.5
01/28/2020 22:00	15.8	14.7	15.0	157.2	2,533,832.0	1,276.7	2.0	1.0
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.9	14.0	11.7	119.7	3,015,002.1	1,623.5	1.3	0.8
Minimum:	8.5	13.3	7.1	0.1	1,882,336.1	453.6	0.0	0.0
Maximum:	33.7	17.5	58.5	176.5	3,334,795.9	2,119.1	2.4	1.5
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/30/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/30/2020 02:00	38.5	17.4	64.9	13.1	1,853,153.4	460.1	0.0	0.0
01/30/2020 03:00	29.2	14.6	27.3	190.6	2,395,405.8	1,102.0	2.6	1.1
01/30/2020 04:00	8.5	13.8	7.1	103.2	3,110,495.3	1,635.4	1.1	0.7
01/30/2020 05:00	8.6	13.9	7.2	88.7	2,669,027.4	1,383.8	1.1	0.6
01/30/2020 06:00	9.5	13.6	7.7	114.6	3,282,883.7	1,845.9	1.2	0.9
01/30/2020 07:00	11.2	13.4	8.8	155.4	3,397,639.7	2,084.1	1.5	1.3
01/30/2020 08:00	9.4	13.6	7.6	128.2	3,337,235.2	1,925.2	1.3	1.0
01/30/2020 09:00	8.5	13.8	7.1	102.8	3,094,328.5	1,626.9	1.1	0.7
01/30/2020 10:00	8.6	13.8	7.1	102.2	3,143,118.3	1,629.6	1.1	0.7
01/30/2020 11:00	8.6	13.8	7.1	105.3	3,243,992.8	1,681.9	1.1	0.7
01/30/2020 12:00	8.5	13.9	7.2	93.9	2,881,770.4	1,494.1	1.1	0.6
01/30/2020 13:00	8.6	13.9	7.2	102.9	3,183,236.6	1,650.4	1.1	0.7
01/30/2020 14:00	8.6	13.9	7.2	97.6	2,989,588.4	1,550.0	1.1	0.6
01/30/2020 15:00	8.6	13.9	7.2	102.1	3,144,082.7	1,630.1	1.1	0.7
01/30/2020 16:00	8.7	13.9	7.3	96.2	2,915,716.7	1,511.7	1.1	0.6
01/30/2020 17:00	8.5	13.9	7.2	102.4	3,149,483.2	1,632.9	1.1	0.7
01/30/2020 18:00	8.9	13.9	7.5	109.6	3,296,069.5	1,708.9	1.1	0.7
01/30/2020 19:00	11.4	13.4	9.0	175.2	3,285,490.8	2,039.3	1.8	1.4
01/30/2020 20:00	11.4	13.3	8.9	195.5	3,262,121.0	2,143.9	2.1	1.7
01/30/2020 21:00	11.2	13.3	8.7	192.6	3,270,308.5	2,125.4	2.0	1.7
01/30/2020 22:00	10.9	13.4	8.6	178.5	3,302,064.4	2,073.7	1.9	1.5
01/30/2020 23:00	9.3	13.7	7.6	133.4	3,155,622.3	1,751.3	1.4	0.9
Average/Sum#:	11.6	13.9	11.2	122.0	3,061,947.0	1,667.6	1.3	0.9
Minimum:	8.5	13.3	7.1	13.1	1,853,153.4	460.1	0.0	0.0
Maximum:	38.5	17.4	64.9	195.5	3,397,639.7	2,143.9	2.6	1.7
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
01/31/2020 00:00	14.2	14.8	13.7	112.7	2,230,265.6	1,058.6	1.6	0.6
01/31/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/31/2020 05:00	41.4	17.0	62.6	224.1	1,693,521.5	519.4	3.8	0.8
01/31/2020 06:00	25.8	14.4	23.4	194.2	2,652,118.6	1,278.2	2.4	1.2
01/31/2020 07:00	8.4	13.9	7.1	100.7	3,027,759.3	1,591.9	1.1	0.6
01/31/2020 08:00	8.5	13.9	7.2	95.2	2,939,633.4	1,524.1	1.1	0.6
01/31/2020 09:00	8.6	13.9	7.2	100.0	3,119,587.3	1,617.4	1.1	0.6
01/31/2020 10:00	8.7	13.9	7.3	102.6	3,094,518.7	1,627.0	1.1	0.7
01/31/2020 11:00	8.7	13.9	7.3	102.7	3,158,548.4	1,637.6	1.1	0.7
01/31/2020 12:00	8.7	13.9	7.3	101.4	3,116,308.4	1,615.7	1.1	0.6
01/31/2020 13:00	8.6	13.9	7.2	105.1	3,263,859.1	1,692.2	1.1	0.7
01/31/2020 14:00	8.6	13.9	7.2	104.3	3,236,856.3	1,678.2	1.1	0.7
01/31/2020 15:00	8.6	13.9	7.2	103.4	3,206,574.7	1,662.5	1.1	0.7
01/31/2020 16:00	8.9	13.9	7.5	96.9	2,857,467.9	1,481.5	1.1	0.6
01/31/2020 17:00	8.6	13.9	7.2	104.4	3,226,055.2	1,672.6	1.1	0.7
01/31/2020 18:00	9.8	13.6	7.9	136.2	3,248,025.7	1,826.3	1.4	0.9
01/31/2020 19:00	10.6	13.4	8.3	161.5	3,315,326.9	2,009.4	1.7	1.4
01/31/2020 20:00	10.7	13.3	8.3	172.6	3,270,590.0	2,101.7	1.8	1.5
01/31/2020 21:00	10.4	13.3	8.1	171.8	3,273,702.4	2,103.7	1.8	1.5
01/31/2020 22:00	10.3	13.3	8.0	171.0	3,298,896.1	2,095.8	1.8	1.5
01/31/2020 23:00	16.2	14.6	15.2	159.1	2,550,106.4	1,284.9	2.1	1.0
Average/Sum#:	12.2	14.0	11.8	131.0	2,988,986.1	1,603.9	1.5	0.9
Minimum:	8.4	13.3	7.1	95.2	1,693,521.5	519.4	1.1	0.6
Maximum:	41.4	17.0	62.6	224.1	3,315,326.9	2,103.7	3.8	1.5
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/03/2020 03:00	12.1	18.9	35.7	0.1	2,184,854.4	175.5	0.0	0.0
02/03/2020 04:00	45.1	17.0	68.2	87.4	1,927,464.8	563.0	0.0	0.0
02/03/2020 05:00	21.7	14.4	19.7	193.3	2,807,115.6	1,373.4	2.3	1.2
02/03/2020 06:00	8.2	13.9	6.9	105.7	3,281,410.9	1,701.3	1.1	0.7
02/03/2020 07:00	8.3	13.9	7.0	100.9	3,116,115.5	1,615.6	1.1	0.6
02/03/2020 08:00	8.5	14.0	7.3	100.9	2,987,659.7	1,549.0	1.1	0.6
02/03/2020 09:00	8.5	14.0	7.3	93.0	2,850,331.5	1,477.8	1.1	0.6
02/03/2020 10:00	8.5	13.9	7.2	97.8	3,011,383.5	1,561.3	1.1	0.6
02/03/2020 11:00	8.4	13.9	7.1	104.9	3,267,330.9	1,694.0	1.1	0.7
02/03/2020 12:00	8.3	13.9	7.0	102.7	3,194,616.3	1,656.3	1.1	0.7
02/03/2020 13:00	8.4	13.9	7.1	102.2	3,165,299.1	1,641.1	1.1	0.7
02/03/2020 14:00	8.5	13.9	7.2	97.8	3,016,205.4	1,563.8	1.1	0.6
02/03/2020 15:00	8.4	13.9	7.1	102.8	3,191,144.6	1,654.5	1.1	0.7
02/03/2020 16:00	8.6	13.9	7.2	99.2	3,056,323.8	1,584.6	1.1	0.6
02/03/2020 17:00	10.6	13.5	8.5	169.0	3,396,502.5	2,058.6	1.7	1.4
02/03/2020 18:00	10.9	13.3	8.5	201.9	3,383,983.1	2,248.7	2.1	1.8
02/03/2020 19:00	10.8	13.3	8.4	223.3	3,332,071.8	2,287.2	2.4	2.1
02/03/2020 20:00	10.6	13.3	8.2	209.2	3,340,958.4	2,293.3	2.2	1.8
02/03/2020 21:00	10.3	13.4	8.1	180.3	3,390,505.9	2,154.0	1.8	1.5
02/03/2020 22:00	10.3	13.4	8.1	176.8	3,411,777.5	2,142.6	1.8	1.5
02/03/2020 23:00	10.3	13.4	8.1	173.0	3,437,907.3	2,108.8	1.7	1.5
Average/Sum#:	11.7	14.1	12.4	129.6	3,083,379.2	1,671.6	1.3	0.9
Minimum:	8.2	13.3	6.9	0.1	1,927,464.8	175.5	0.0	0.0
Maximum:	45.1	18.9	68.2	223.3	3,437,907.3	2,293.3	2.4	2.1
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/04/2020 00:00	10.3	13.4	8.1	167.3	3,424,715.9	2,075.7	1.7	1.5
02/04/2020 01:00	10.3	13.5	8.2	160.8	3,469,377.5	2,052.1	1.6	1.2
02/04/2020 02:00	10.3	13.5	8.2	160.6	3,479,352.3	2,058.0	1.6	1.2
02/04/2020 03:00	10.3	13.5	8.2	160.8	3,468,701.2	2,051.7	1.6	1.2
02/04/2020 04:00	10.4	13.4	8.2	166.4	3,470,989.8	2,078.4	1.6	1.2
02/04/2020 05:00	10.4	13.4	8.2	169.5	3,365,121.6	2,113.3	1.7	1.5
02/04/2020 06:00	10.8	13.4	8.5	184.0	3,450,949.4	2,167.2	1.8	1.5
02/04/2020 07:00	10.3	13.4	8.1	178.9	3,405,353.8	2,188.3	1.8	1.5
02/04/2020 08:00	9.8	13.5	7.8	162.3	3,418,884.9	2,047.2	1.6	1.2
02/04/2020 09:00	7.9	13.9	6.7	107.8	3,386,142.9	1,755.6	1.1	0.7
02/04/2020 10:00	8.2	13.9	6.9	107.7	3,387,493.0	1,756.3	1.1	0.7
02/04/2020 11:00	8.2	13.9	6.9	107.7	3,384,021.2	1,754.5	1.1	0.7
02/04/2020 12:00	8.3	13.9	7.0	107.9	3,432,560.0	1,754.6	1.0	0.7
02/04/2020 13:00	8.3	13.9	7.0	107.9	3,433,342.6	1,755.0	1.0	0.7
02/04/2020 14:00	8.3	13.9	7.0	108.1	3,435,494.5	1,756.1	1.0	0.7
02/04/2020 15:00	8.3	13.9	7.0	108.2	3,434,320.7	1,755.5	1.0	0.7
02/04/2020 16:00	9.6	13.7	7.9	138.7	3,340,665.1	1,829.6	1.4	0.9
02/04/2020 17:00	10.4	13.5	8.3	159.3	3,399,215.6	2,010.6	1.6	1.2
02/04/2020 18:00	10.8	13.4	8.5	187.2	3,381,682.1	2,123.7	1.9	1.5
02/04/2020 19:00	10.7	13.4	8.4	198.7	3,351,590.1	2,202.7	2.1	1.8
02/04/2020 20:00	10.5	13.4	8.3	200.4	3,363,398.6	2,185.9	2.1	1.7
02/04/2020 21:00	10.6	13.3	8.2	210.0	3,368,188.6	2,262.8	2.2	1.8
02/04/2020 22:00	10.5	13.4	8.3	186.9	3,365,917.7	2,113.8	1.9	1.5
02/04/2020 23:00	10.4	13.4	8.2	174.5	3,373,295.0	2,093.8	1.8	1.5
Average/Sum#:	9.7	13.6	7.8	155.1	3,407,948.9	1,997.6	1.6	1.2
Minimum:	7.9	13.3	6.7	107.7	3,340,665.1	1,754.5	1.0	0.7
Maximum:	10.8	13.9	8.5	210.0	3,479,352.3	2,262.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/05/2020 00:00	10.5	13.4	8.3	186.0	3,374,198.0	2,119.0	1.9	1.5
02/05/2020 01:00	10.5	13.4	8.3	174.3	3,399,759.1	2,085.4	1.8	1.5
02/05/2020 02:00	10.4	13.4	8.2	170.0	3,383,303.2	2,050.6	1.7	1.4
02/05/2020 03:00	10.4	13.5	8.3	172.4	3,379,673.4	2,048.4	1.8	1.4
02/05/2020 04:00	10.5	13.4	8.3	169.7	3,378,402.6	2,072.3	1.7	1.5
02/05/2020 05:00	9.6	13.6	7.8	177.2	3,407,299.0	1,990.5	1.8	1.4
02/05/2020 06:00	10.4	13.5	8.3	156.6	3,405,471.0	2,014.3	1.6	1.2
02/05/2020 07:00	10.7	13.4	8.4	196.5	3,360,871.8	2,208.8	2.0	1.8
02/05/2020 08:00	10.3	13.4	8.1	170.1	3,418,446.2	2,071.9	1.7	1.5
02/05/2020 09:00	9.1	13.6	7.4	140.3	3,372,944.3	1,945.8	1.4	1.0
02/05/2020 10:00	8.4	13.9	7.1	109.7	3,096,827.9	1,605.6	1.2	0.8
02/05/2020 11:00	8.3	13.9	7.0	100.3	3,101,649.8	1,608.1	1.1	0.6
02/05/2020 12:00	8.4	13.9	7.1	103.0	3,193,459.1	1,655.7	1.1	0.7
02/05/2020 13:00	8.4	13.9	7.1	103.3	3,208,310.6	1,663.4	1.1	0.7
02/05/2020 14:00	8.4	13.9	7.1	99.6	3,066,546.2	1,589.9	1.1	0.6
02/05/2020 15:00	8.4	13.9	7.1	104.0	3,228,562.6	1,673.9	1.1	0.7
02/05/2020 16:00	9.7	13.7	7.9	114.2	3,295,447.7	1,828.9	1.2	0.9
02/05/2020 17:00	10.6	13.5	8.5	120.1	3,332,773.2	1,971.3	1.2	1.0
02/05/2020 18:00	10.8	13.3	8.4	179.1	3,294,895.3	2,189.5	1.9	1.5
02/05/2020 19:00	10.5	13.4	8.3	190.9	3,318,675.5	2,132.6	2.0	1.7
02/05/2020 20:00	10.5	13.4	8.3	193.4	3,293,617.8	2,164.6	2.0	1.7
02/05/2020 21:00	10.4	13.4	8.2	182.2	3,315,581.1	2,106.4	1.9	1.5
02/05/2020 22:00	10.5	13.4	8.3	183.0	3,300,779.6	2,121.1	1.9	1.5
02/05/2020 23:00	10.5	13.4	8.3	174.7	3,314,651.4	2,057.4	1.8	1.4
Average/Sum#:	9.8	13.6	7.9	152.9	3,301,756.1	1,957.3	1.6	1.2
Minimum:	8.3	13.3	7.0	99.6	3,066,546.2	1,589.9	1.1	0.6
Maximum:	10.8	13.9	8.5	196.5	3,418,446.2	2,208.8	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/06/2020 00:00	10.2	13.4	8.0	164.7	3,347,665.2	2,029.0	1.7	1.4
02/06/2020 01:00	10.2	13.4	8.0	157.8	3,394,143.7	2,007.6	1.6	1.2
02/06/2020 02:00	10.2	13.4	8.0	153.5	3,387,888.3	2,003.9	1.5	1.2
02/06/2020 03:00	10.3	13.4	8.1	165.1	3,389,993.4	2,029.9	1.7	1.4
02/06/2020 04:00	10.3	13.4	8.1	159.6	3,407,837.9	2,015.7	1.6	1.2
02/06/2020 05:00	10.3	13.4	8.1	172.7	3,368,619.0	2,041.7	1.8	1.4
02/06/2020 06:00	10.5	13.4	8.3	162.8	3,382,152.2	2,074.6	1.6	1.2
02/06/2020 07:00	10.5	13.4	8.3	175.0	3,377,645.0	2,096.5	1.8	1.5
02/06/2020 08:00	8.7	13.7	7.1	122.5	3,420,004.0	1,923.0	1.2	1.0
02/06/2020 09:00	8.2	13.9	6.9	105.5	3,268,295.2	1,694.5	1.1	0.7
02/06/2020 10:00	8.4	13.9	7.1	105.0	3,243,221.3	1,681.5	1.1	0.7
02/06/2020 11:00	8.5	13.9	7.2	105.1	3,232,034.4	1,675.7	1.1	0.7
02/06/2020 12:00	8.6	13.9	7.2	100.1	3,066,160.5	1,589.7	1.1	0.6
02/06/2020 13:00	8.6	13.9	7.2	105.3	3,245,535.8	1,682.7	1.1	0.7
02/06/2020 14:00	8.5	13.9	7.2	103.7	3,198,473.9	1,658.3	1.1	0.7
02/06/2020 15:00	8.6	13.9	7.2	97.6	2,981,487.6	1,545.8	1.1	0.6
02/06/2020 16:00	8.7	13.9	7.3	101.6	3,016,398.3	1,563.9	1.1	0.6
02/06/2020 17:00	11.0	13.4	8.7	164.4	3,298,662.9	1,999.3	1.7	1.4
02/06/2020 18:00	10.9	13.3	8.5	177.1	3,274,324.8	2,104.1	1.9	1.5
02/06/2020 19:00	10.6	13.4	8.3	183.6	3,254,872.8	2,091.6	2.0	1.7
02/06/2020 20:00	10.5	13.3	8.2	173.8	3,328,645.7	2,114.7	1.8	1.5
02/06/2020 21:00	10.4	13.3	8.1	178.6	3,295,177.4	2,117.5	1.9	1.5
02/06/2020 22:00	10.4	13.3	8.1	177.7	3,295,433.2	2,093.6	1.9	1.5
02/06/2020 23:00	9.2	13.6	7.4	131.6	3,350,236.1	1,932.7	1.3	1.0
Average/Sum#:	9.7	13.6	7.8	143.5	3,284,371.2	1,907.0	1.5	1.1
Minimum:	8.2	13.3	6.9	97.6	2,981,487.6	1,545.8	1.1	0.6
Maximum:	11.0	13.9	8.7	183.6	3,420,004.0	2,117.5	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/07/2020 00:00	9.0	13.6	7.3	125.3	3,355,616.4	1,911.3	1.3	1.0
02/07/2020 01:00	8.3	13.8	6.9	106.0	3,275,238.8	1,698.1	1.1	0.7
02/07/2020 02:00	8.6	13.8	7.1	98.6	3,010,997.8	1,561.1	1.1	0.6
02/07/2020 03:00	8.6	13.8	7.1	98.3	3,003,089.8	1,557.0	1.1	0.6
02/07/2020 04:00	8.6	13.9	7.2	96.3	2,944,455.3	1,526.6	1.1	0.6
02/07/2020 05:00	8.9	13.9	7.5	97.5	2,962,331.2	1,557.5	1.1	0.6
02/07/2020 06:00	10.4	13.4	8.2	159.9	3,382,311.2	2,025.3	1.6	1.2
02/07/2020 07:00	10.5	13.4	8.3	164.3	3,392,911.9	2,081.2	1.7	1.5
02/07/2020 08:00	9.2	13.6	7.4	128.7	3,361,850.2	1,939.4	1.3	1.0
02/07/2020 09:00	8.4	13.9	7.1	103.9	3,181,693.6	1,649.6	1.1	0.7
02/07/2020 10:00	8.6	13.8	7.1	103.9	3,202,910.0	1,660.6	1.1	0.7
02/07/2020 11:00	8.6	13.8	7.1	105.1	3,245,535.8	1,682.7	1.1	0.7
02/07/2020 12:00	8.6	13.9	7.2	105.6	3,250,357.7	1,685.2	1.1	0.7
02/07/2020 13:00	8.5	13.9	7.2	105.2	3,255,951.1	1,688.1	1.1	0.7
02/07/2020 14:00	8.5	13.9	7.2	103.6	3,203,295.8	1,660.8	1.1	0.7
02/07/2020 15:00	8.5	13.9	7.2	104.4	3,235,120.4	1,677.3	1.1	0.7
02/07/2020 16:00	8.7	13.9	7.3	103.9	3,064,617.5	1,588.9	1.1	0.6
02/07/2020 17:00	11.1	13.4	8.7	169.2	3,278,304.2	2,010.9	1.8	1.4
02/07/2020 18:00	10.9	13.3	8.5	183.5	3,250,459.6	2,112.5	2.0	1.7
02/07/2020 19:00	10.7	13.4	8.4	181.7	3,254,405.9	2,091.3	1.9	1.5
02/07/2020 20:00	10.6	13.4	8.3	175.9	3,277,437.2	2,106.1	1.9	1.5
02/07/2020 21:00	10.4	13.3	8.1	177.4	3,277,904.0	2,106.4	1.9	1.5
02/07/2020 22:00	10.3	13.4	8.1	168.2	3,304,662.7	2,051.2	1.8	1.4
02/07/2020 23:00	16.7	14.6	15.6	154.6	2,508,981.1	1,282.5	2.0	1.0
Average/Sum#:	9.6	13.7	7.9	130.0	3,186,685.0	1,788.0	1.4	1.0
Minimum:	8.3	13.3	6.9	96.3	2,508,981.1	1,282.5	1.1	0.6
Maximum:	16.7	14.6	15.6	183.5	3,392,911.9	2,112.5	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/10/2020 03:00	40.4	17.5	70.1	0.1	1,922,588.8	463.3	0.0	0.0
02/10/2020 04:00	55.2	15.9	65.1	221.7	1,861,890.5	707.0	3.7	1.0
02/10/2020 05:00	27.9	14.6	26.1	186.6	2,440,946.3	1,158.6	2.5	1.2
02/10/2020 06:00	8.4	13.9	7.1	105.4	3,272,538.5	1,696.7	1.1	0.7
02/10/2020 07:00	8.4	13.9	7.1	106.3	3,276,781.8	1,698.9	1.1	0.7
02/10/2020 08:00	8.6	14.0	7.4	106.0	3,231,645.9	1,651.9	1.1	0.7
02/10/2020 09:00	8.6	14.0	7.4	103.8	3,229,298.3	1,650.7	1.1	0.7
02/10/2020 10:00	8.6	14.0	7.4	102.7	3,202,301.1	1,636.9	1.1	0.7
02/10/2020 11:00	8.7	14.0	7.4	104.6	3,264,707.7	1,668.8	1.1	0.7
02/10/2020 12:00	8.7	14.0	7.4	104.4	3,260,990.7	1,666.9	1.1	0.7
02/10/2020 13:00	8.6	14.0	7.4	103.4	3,236,145.5	1,654.2	1.1	0.7
02/10/2020 14:00	8.6	14.0	7.4	103.3	3,224,603.2	1,648.3	1.1	0.7
02/10/2020 15:00	8.7	14.0	7.4	104.0	3,238,493.0	1,655.4	1.1	0.7
02/10/2020 16:00	8.8	14.0	7.5	105.5	3,297,769.5	1,685.7	1.1	0.7
02/10/2020 17:00	10.2	13.6	8.2	148.7	3,308,241.0	1,836.0	1.5	1.1
02/10/2020 18:00	11.0	13.4	8.7	159.6	3,341,069.4	2,049.4	1.6	1.2
02/10/2020 19:00	10.9	13.3	8.5	170.4	3,328,023.5	2,065.7	1.8	1.4
02/10/2020 20:00	10.8	13.3	8.4	176.1	3,320,303.2	2,109.4	1.8	1.5
02/10/2020 21:00	10.7	13.3	8.3	175.2	3,339,978.9	2,121.9	1.8	1.5
02/10/2020 22:00	10.5	13.3	8.2	173.0	3,346,968.7	2,101.9	1.8	1.5
02/10/2020 23:00	10.4	13.4	8.2	161.3	3,364,824.2	2,039.4	1.6	1.2
Average/Sum#:	13.9	14.1	14.3	129.6	3,110,005.2	1,665.1	1.4	0.9
Minimum:	8.4	13.3	7.1	0.1	1,861,890.5	463.3	0.0	0.0
Maximum:	55.2	17.5	70.1	221.7	3,364,824.2	2,121.9	3.7	1.5
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/11/2020 00:00	9.5	13.5	7.6	132.0	3,364,219.2	1,916.2	1.3	1.0
02/11/2020 01:00	8.5	13.9	7.2	105.9	3,021,991.7	1,566.8	1.2	0.8
02/11/2020 02:00	8.4	14.0	7.2	91.8	2,863,662.0	1,463.8	1.1	0.6
02/11/2020 03:00	8.5	13.9	7.2	96.4	2,997,083.1	1,532.0	1.1	0.6
02/11/2020 04:00	8.5	13.9	7.2	94.8	2,905,880.0	1,506.6	1.1	0.6
02/11/2020 05:00	8.5	13.9	7.2	117.6	3,154,305.1	1,635.4	1.3	0.8
02/11/2020 06:00	8.6	13.9	7.2	104.4	3,157,391.1	1,637.0	1.1	0.7
02/11/2020 07:00	8.5	13.9	7.2	99.1	3,026,427.9	1,569.1	1.1	0.6
02/11/2020 08:00	8.4	14.0	7.2	86.7	2,698,939.8	1,379.6	1.1	0.6
02/11/2020 09:00	8.6	13.9	7.2	96.8	3,030,340.5	1,549.0	1.1	0.6
02/11/2020 10:00	8.5	13.9	7.2	99.9	3,132,460.5	1,601.2	1.1	0.6
02/11/2020 11:00	8.5	13.9	7.2	100.9	3,172,369.4	1,621.6	1.1	0.6
02/11/2020 12:00	8.6	13.9	7.2	103.4	3,250,622.2	1,661.6	1.1	0.7
02/11/2020 13:00	8.8	14.0	7.5	105.5	3,285,249.1	1,679.3	1.1	0.7
02/11/2020 14:00	8.8	14.0	7.5	105.7	3,225,190.1	1,648.6	1.1	0.7
02/11/2020 15:00	8.5	14.0	7.3	96.3	2,993,757.3	1,530.3	1.1	0.6
02/11/2020 16:00	9.0	13.9	7.6	114.5	2,883,420.9	1,473.9	1.3	0.7
02/11/2020 17:00	8.4	13.9	7.1	105.1	3,176,673.3	1,623.8	1.1	0.6
02/11/2020 18:00	9.8	13.6	7.9	133.7	3,288,574.8	1,849.1	1.4	0.9
02/11/2020 19:00	11.0	13.3	8.5	183.9	3,291,944.1	2,163.5	1.9	1.5
02/11/2020 20:00	10.8	13.3	8.4	188.7	3,281,351.5	2,180.5	2.0	1.7
02/11/2020 21:00	11.2	13.4	8.8	217.2	3,239,581.8	2,176.4	2.3	2.0
02/11/2020 22:00	11.0	13.4	8.7	198.5	3,235,302.7	2,149.9	2.1	1.7
02/11/2020 23:00	10.8	13.4	8.5	194.4	3,247,558.8	2,086.9	2.1	1.7
Average/Sum#:	9.2	13.8	7.6	123.9	3,121,845.7	1,716.8	1.3	0.9
Minimum:	8.4	13.3	7.1	86.7	2,698,939.8	1,379.6	1.1	0.6
Maximum:	11.2	14.0	8.8	217.2	3,364,219.2	2,180.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/12/2020 00:00	10.6	13.5	8.5	157.0	3,252,467.4	1,923.8	1.6	1.2
02/12/2020 01:00	8.2	13.9	6.9	99.0	3,056,359.6	1,562.3	1.1	0.6
02/12/2020 02:00	8.4	13.9	7.1	96.5	2,973,965.4	1,541.9	1.1	0.6
02/12/2020 03:00	8.4	13.9	7.1	93.9	2,894,886.0	1,500.9	1.1	0.6
02/12/2020 04:00	8.4	13.9	7.1	130.7	3,176,678.8	1,647.0	1.4	0.8
02/12/2020 05:00	8.4	13.9	7.1	101.6	3,179,572.0	1,648.5	1.1	0.7
02/12/2020 06:00	8.6	13.9	7.2	100.9	3,112,065.1	1,613.5	1.1	0.6
02/12/2020 07:00	8.6	13.9	7.2	98.1	2,996,146.3	1,553.4	1.1	0.6
02/12/2020 08:00	8.5	13.9	7.2	105.4	3,260,580.2	1,690.5	1.1	0.7
02/12/2020 09:00	8.5	13.9	7.2	104.8	3,234,734.7	1,677.1	1.1	0.7
02/12/2020 10:00	8.5	13.9	7.2	104.0	3,218,147.3	1,668.5	1.1	0.7
02/12/2020 11:00	8.4	13.9	7.1	104.0	3,270,772.3	1,671.9	1.1	0.7
02/12/2020 12:00	8.5	13.9	7.2	102.2	3,202,105.5	1,636.8	1.1	0.7
02/12/2020 13:00	8.6	13.9	7.2	104.8	3,288,183.6	1,680.8	1.1	0.7
02/12/2020 14:00	8.5	14.0	7.3	101.4	3,167,283.0	1,619.0	1.1	0.6
02/12/2020 15:00	8.6	14.0	7.4	101.4	3,155,740.7	1,613.1	1.1	0.6
02/12/2020 16:00	9.0	14.0	7.7	108.9	2,749,804.2	1,405.6	1.3	0.7
02/12/2020 17:00	8.3	13.9	7.0	105.1	3,185,672.4	1,628.4	1.1	0.7
02/12/2020 18:00	9.0	13.9	7.6	118.6	3,323,984.2	1,699.1	1.2	0.8
02/12/2020 19:00	11.5	13.4	9.0	175.4	3,314,168.1	2,057.1	1.8	1.4
02/12/2020 20:00	10.6	13.3	8.2	189.1	3,268,756.5	2,196.0	2.0	1.8
02/12/2020 21:00	10.4	13.3	8.1	185.4	3,280,684.3	2,156.1	2.0	1.7
02/12/2020 22:00	10.5	13.3	8.2	177.8	3,295,850.6	2,142.0	1.9	1.5
02/12/2020 23:00	10.4	13.3	8.1	169.7	3,308,593.0	2,077.8	1.8	1.5
Average/Sum#:	9.1	13.8	7.5	122.3	3,173,633.4	1,733.8	1.3	0.9
Minimum:	8.2	13.3	6.9	93.9	2,749,804.2	1,405.6	1.1	0.6
Maximum:	11.5	14.0	9.0	189.1	3,323,984.2	2,196.0	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/13/2020 00:00	10.6	13.4	8.3	176.9	3,280,249.1	2,060.0	1.9	1.4
02/13/2020 01:00	10.5	13.4	8.3	163.2	3,302,106.1	2,025.5	1.7	1.4
02/13/2020 02:00	10.4	13.4	8.2	164.1	3,355,584.7	2,033.8	1.7	1.4
02/13/2020 03:00	10.5	13.4	8.3	167.2	3,321,506.2	2,037.4	1.7	1.4
02/13/2020 04:00	10.5	13.4	8.3	164.3	3,318,897.8	2,035.8	1.7	1.4
02/13/2020 05:00	10.5	13.4	8.3	191.8	3,333,244.2	2,044.6	2.0	1.6
02/13/2020 06:00	10.7	13.3	8.3	178.3	3,357,424.0	2,157.5	1.8	1.5
02/13/2020 07:00	10.3	13.4	8.1	168.8	3,326,268.1	2,088.9	1.7	1.5
02/13/2020 08:00	9.1	13.6	7.4	128.4	3,365,623.8	1,917.0	1.3	1.0
02/13/2020 09:00	8.2	13.9	6.9	103.1	3,196,545.1	1,657.3	1.1	0.7
02/13/2020 10:00	8.4	13.9	7.1	102.4	3,169,156.6	1,643.1	1.1	0.7
02/13/2020 11:00	8.4	13.9	7.1	102.7	3,182,079.4	1,649.8	1.1	0.7
02/13/2020 12:00	8.4	13.9	7.1	104.3	3,234,927.6	1,677.2	1.1	0.7
02/13/2020 13:00	8.5	13.9	7.2	101.0	3,117,465.7	1,616.3	1.1	0.6
02/13/2020 14:00	8.4	13.9	7.1	101.6	3,149,483.2	1,632.9	1.1	0.7
02/13/2020 15:00	8.5	13.9	7.2	99.1	3,053,623.5	1,583.2	1.1	0.6
02/13/2020 16:00	8.8	13.9	7.4	107.5	3,073,682.7	1,593.6	1.2	0.8
02/13/2020 17:00	10.9	13.4	8.6	163.6	3,294,996.2	2,045.2	1.7	1.4
02/13/2020 18:00	10.7	13.3	8.3	177.6	3,288,772.7	2,137.4	1.9	1.5
02/13/2020 19:00	10.6	13.3	8.2	178.2	3,278,249.8	2,154.5	1.9	1.5
02/13/2020 20:00	10.5	13.3	8.2	182.5	3,265,925.0	2,146.4	1.9	1.5
02/13/2020 21:00	10.3	13.3	8.0	179.9	3,297,850.9	2,143.3	1.9	1.5
02/13/2020 22:00	10.4	13.3	8.1	171.1	3,323,136.5	2,111.2	1.8	1.5
02/13/2020 23:00	10.4	13.3	8.1	174.4	3,308,340.4	2,101.8	1.8	1.5
Average/Sum#:	9.8	13.5	7.8	148.0	3,258,130.8	1,928.9	1.6	1.2
Minimum:	8.2	13.3	6.9	99.1	3,053,623.5	1,583.2	1.1	0.6
Maximum:	10.9	13.9	8.6	191.8	3,365,623.8	2,157.5	2.0	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/14/2020 00:00	12.7	14.2	11.2	135.8	2,958,331.9	1,577.0	1.5	0.9
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.7	14.2	11.2	135.8	2,958,331.9	1,577.0	1.5	0.9
Minimum:	12.7	14.2	11.2	135.8	2,958,331.9	1,577.0	1.5	0.9
Maximum:	12.7	14.2	11.2	135.8	2,958,331.9	1,577.0	1.5	0.9
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 15:00	42.1	17.3	69.0	38.7	1,812,204.9	476.4	0.0	0.0
02/17/2020 16:00	34.0	14.9	33.4	214.4	2,378,982.0	1,059.7	3.0	1.3
02/17/2020 17:00	8.0	13.9	6.7	105.0	3,255,951.1	1,688.1	1.1	0.7
02/17/2020 18:00	8.6	13.9	7.2	107.8	3,350,074.9	1,736.9	1.1	0.7
02/17/2020 19:00	11.2	13.5	8.9	172.6	3,428,125.7	2,027.7	1.7	1.4
02/17/2020 20:00	11.0	13.4	8.7	208.5	3,281,293.0	2,156.5	2.2	1.7
02/17/2020 21:00	10.9	13.4	8.6	193.2	3,302,005.3	2,146.0	2.0	1.7
02/17/2020 22:00	10.7	13.4	8.4	192.3	3,305,915.0	2,124.4	2.0	1.7
02/17/2020 23:00	10.8	13.4	8.5	179.2	3,337,528.9	2,071.6	1.8	1.5
Average/Sum#:	16.4	14.1	17.7	156.9	3,050,231.2	1,720.8	1.7	1.2
Minimum:	8.0	13.4	6.7	38.7	1,812,204.9	476.4	0.0	0.0
Maximum:	42.1	17.3	69.0	214.4	3,428,125.7	2,156.5	3.0	1.7
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/18/2020 00:00	10.8	13.4	8.5	174.5	3,329,312.3	2,066.5	1.8	1.4
02/18/2020 01:00	10.6	13.4	8.3	175.6	3,329,795.7	2,066.8	1.8	1.4
02/18/2020 02:00	10.4	13.4	8.2	160.7	3,365,979.1	2,040.1	1.6	1.2
02/18/2020 03:00	10.5	13.4	8.3	171.6	3,368,131.9	2,066.0	1.7	1.4
02/18/2020 04:00	10.7	13.4	8.4	171.1	3,372,533.6	2,068.7	1.7	1.4
02/18/2020 05:00	10.9	13.4	8.6	199.7	3,331,682.1	2,092.3	2.1	1.7
02/18/2020 06:00	11.1	13.4	8.7	191.1	3,357,923.0	2,133.3	2.0	1.7
02/18/2020 07:00	10.8	13.4	8.5	181.2	3,341,238.1	2,122.7	1.9	1.5
02/18/2020 08:00	10.8	13.4	8.5	179.2	3,325,606.8	2,064.2	1.9	1.4
02/18/2020 09:00	9.5	13.6	7.7	145.8	3,364,970.4	1,941.2	1.5	1.2
02/18/2020 10:00	9.0	13.6	7.3	122.4	3,401,263.9	1,937.3	1.2	1.0
02/18/2020 11:00	9.2	13.6	7.4	127.0	3,404,599.7	1,939.2	1.3	1.0
02/18/2020 12:00	9.5	13.5	7.6	130.5	3,359,423.4	1,938.0	1.3	1.0
02/18/2020 13:00	8.6	13.7	7.0	114.8	3,261,635.8	1,762.5	1.2	0.9
02/18/2020 14:00	8.5	14.0	7.3	91.8	2,714,546.3	1,407.4	1.1	0.6
02/18/2020 15:00	8.6	13.9	7.2	98.8	2,886,399.4	1,496.5	1.1	0.6
02/18/2020 16:00	10.6	13.4	8.3	154.1	3,357,761.8	2,010.6	1.6	1.2
02/18/2020 17:00	10.6	13.3	8.2	181.3	3,305,544.3	2,148.3	1.9	1.5
02/18/2020 18:00	10.6	13.3	8.2	187.7	3,298,943.3	2,168.1	2.0	1.7
02/18/2020 19:00	10.4	13.3	8.1	194.6	3,312,220.8	2,225.2	2.0	1.8
02/18/2020 20:00	10.4	13.3	8.1	205.3	3,304,583.0	2,244.2	2.2	1.8
02/18/2020 21:00	10.5	13.4	8.3	202.0	3,268,108.7	2,171.7	2.2	1.7
02/18/2020 22:00	10.7	13.4	8.4	187.9	3,268,462.1	2,124.2	2.0	1.7
02/18/2020 23:00	10.3	13.4	8.1	168.1	3,326,734.6	2,064.9	1.7	1.4
Average/Sum#:	10.2	13.5	8.1	163.2	3,289,891.7	2,012.5	1.7	1.3
Minimum:	8.5	13.3	7.0	91.8	2,714,546.3	1,407.4	1.1	0.6
Maximum:	11.1	14.0	8.7	205.3	3,404,599.7	2,244.2	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/19/2020 00:00	10.4	13.3	8.1	211.3	3,348,540.3	2,249.6	2.2	1.8
02/19/2020 01:00	9.9	13.4	7.8	153.6	3,352,119.9	2,031.7	1.6	1.2
02/19/2020 02:00	9.7	13.6	7.8	139.8	3,375,280.0	1,922.5	1.4	1.0
02/19/2020 03:00	9.2	13.6	7.4	128.3	3,386,165.1	1,928.7	1.3	1.0
02/19/2020 04:00	10.6	13.4	8.3	179.6	3,347,517.6	2,077.8	1.9	1.5
02/19/2020 05:00	10.4	13.4	8.2	157.2	3,397,783.6	2,109.0	1.6	1.3
02/19/2020 06:00	10.7	13.4	8.4	177.9	3,369,898.6	2,116.3	1.8	1.5
02/19/2020 07:00	10.6	13.3	8.2	193.4	3,323,788.6	2,208.7	2.0	1.8
02/19/2020 08:00	9.7	13.5	7.7	147.7	3,347,143.7	1,979.8	1.5	1.2
02/19/2020 09:00	10.3	13.5	8.2	154.2	3,282,978.3	1,893.9	1.6	1.1
02/19/2020 10:00	9.4	13.5	7.5	127.5	3,342,800.0	1,904.0	1.3	1.0
02/19/2020 11:00	9.5	13.5	7.6	131.3	3,345,258.0	1,905.4	1.3	1.0
02/19/2020 12:00	9.4	13.5	7.5	130.3	3,340,166.5	1,902.5	1.3	1.0
02/19/2020 13:00	10.2	13.5	8.1	147.9	3,313,660.3	1,911.6	1.5	1.1
02/19/2020 14:00	10.5	13.4	8.3	145.9	3,317,820.6	1,914.0	1.5	1.1
02/19/2020 15:00	10.4	13.4	8.2	151.6	3,309,326.7	1,909.1	1.6	1.1
02/19/2020 16:00	10.6	13.4	8.3	161.6	3,277,163.0	2,010.2	1.7	1.4
02/19/2020 17:00	10.6	13.3	8.2	185.7	3,260,751.6	2,143.0	2.0	1.7
02/19/2020 18:00	10.4	13.3	8.1	191.9	3,228,831.8	2,145.6	2.1	1.7
02/19/2020 19:00	10.4	13.2	8.0	212.0	3,239,125.7	2,223.4	2.3	2.0
02/19/2020 20:00	10.3	13.3	8.0	194.8	3,241,412.8	2,201.3	2.1	1.8
02/19/2020 21:00	10.2	13.3	7.9	199.1	3,227,865.8	2,192.1	2.2	1.8
02/19/2020 22:00	10.1	13.3	7.8	168.3	3,271,809.6	2,054.7	1.8	1.4
02/19/2020 23:00	10.3	13.4	8.1	165.0	3,289,879.1	2,018.0	1.7	1.4
Average/Sum#:	10.2	13.4	8.0	164.8	3,314,045.3	2,039.7	1.7	1.4
Minimum:	9.2	13.2	7.4	127.5	3,227,865.8	1,893.9	1.3	1.0
Maximum:	10.7	13.6	8.4	212.0	3,397,783.6	2,249.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/20/2020 00:00	10.0	13.4	7.9	153.7	3,330,206.3	1,994.1	1.6	1.2
02/20/2020 01:00	10.3	13.4	8.1	163.4	3,319,286.7	2,011.8	1.7	1.4
02/20/2020 02:00	10.5	13.4	8.3	168.3	3,281,238.6	2,012.7	1.8	1.4
02/20/2020 03:00	10.4	13.4	8.2	161.3	3,279,608.4	2,011.7	1.7	1.4
02/20/2020 04:00	10.5	13.4	8.3	167.9	3,279,934.4	2,011.9	1.8	1.4
02/20/2020 05:00	10.4	13.4	8.2	156.0	3,304,062.4	2,026.7	1.6	1.2
02/20/2020 06:00	10.7	13.4	8.4	170.1	3,297,090.6	2,046.5	1.8	1.4
02/20/2020 07:00	10.2	13.4	8.0	162.2	3,306,112.7	2,052.1	1.7	1.4
02/20/2020 08:00	10.4	13.4	8.2	165.5	3,297,704.3	2,022.8	1.7	1.4
02/20/2020 09:00	9.1	13.6	7.4	136.0	3,306,033.1	1,907.2	1.4	1.0
02/20/2020 10:00	8.8	13.6	7.1	120.9	3,304,993.1	1,906.6	1.2	1.0
02/20/2020 11:00	9.0	13.6	7.3	123.3	3,303,953.0	1,906.0	1.3	1.0
02/20/2020 12:00	9.2	13.6	7.4	127.6	3,307,766.6	1,908.2	1.3	1.0
02/20/2020 13:00	9.3	13.5	7.4	129.1	3,306,206.5	1,907.3	1.3	1.0
02/20/2020 14:00	9.8	13.5	7.8	140.2	3,294,663.9	1,924.7	1.4	1.0
02/20/2020 15:00	10.6	13.4	8.3	155.9	3,288,956.6	1,969.4	1.6	1.2
02/20/2020 16:00	10.6	13.3	8.2	172.6	3,274,994.3	2,056.7	1.8	1.4
02/20/2020 17:00	10.4	13.3	8.1	170.3	3,252,461.6	2,066.3	1.8	1.4
02/20/2020 18:00	10.4	13.3	8.1	170.2	3,255,924.5	2,068.5	1.8	1.4
02/20/2020 19:00	10.3	13.3	8.0	173.2	3,252,227.3	2,089.9	1.8	1.5
02/20/2020 20:00	10.3	13.3	8.0	180.2	3,250,459.6	2,112.5	1.9	1.5
02/20/2020 21:00	10.4	13.3	8.1	184.3	3,272,924.3	2,127.1	2.0	1.7
02/20/2020 22:00	10.3	13.3	8.0	180.2	3,253,690.8	2,114.6	1.9	1.5
02/20/2020 23:00	10.3	13.3	8.0	163.5	3,290,646.2	2,042.5	1.7	1.4
Average/Sum#:	10.1	13.4	8.0	158.2	3,287,964.4	2,012.4	1.7	1.3
Minimum:	8.8	13.3	7.1	120.9	3,250,459.6	1,906.0	1.2	1.0
Maximum:	10.7	13.6	8.4	184.3	3,330,206.3	2,127.1	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/21/2020 00:00	9.4	13.5	7.5	138.8	3,227,562.1	1,885.5	1.5	1.1
02/21/2020 01:00	8.0	13.9	6.7	96.6	2,907,808.7	1,507.6	1.1	0.6
02/21/2020 02:00	8.1	13.9	6.8	92.9	2,798,254.8	1,450.8	1.1	0.6
02/21/2020 03:00	8.3	13.9	7.0	98.2	2,959,499.7	1,534.4	1.1	0.6
02/21/2020 04:00	8.3	13.9	7.0	105.1	3,183,622.4	1,650.6	1.1	0.7
02/21/2020 05:00	8.3	13.9	7.0	102.9	3,002,704.1	1,556.8	1.1	0.6
02/21/2020 06:00	8.4	13.9	7.1	106.3	3,178,221.8	1,647.8	1.1	0.7
02/21/2020 07:00	8.2	13.9	6.9	103.2	3,063,516.5	1,610.7	1.1	0.6
02/21/2020 08:00	8.4	13.9	7.1	98.0	2,892,528.6	1,520.8	1.1	0.6
02/21/2020 09:00	8.4	13.9	7.1	105.5	3,126,091.6	1,643.6	1.1	0.7
02/21/2020 10:00	8.3	13.9	7.0	102.3	3,067,510.6	1,590.4	1.1	0.6
02/21/2020 11:00	8.4	13.9	7.1	101.1	3,045,522.7	1,579.0	1.1	0.6
02/21/2020 12:00	8.5	13.8	7.1	105.5	3,127,613.1	1,644.4	1.1	0.7
02/21/2020 13:00	8.5	13.8	7.1	105.6	3,124,570.0	1,642.8	1.1	0.7
02/21/2020 14:00	8.5	13.8	7.1	106.6	3,169,456.7	1,666.4	1.1	0.7
02/21/2020 15:00	8.5	13.8	7.1	106.1	3,147,393.7	1,654.8	1.1	0.7
02/21/2020 16:00	8.9	13.8	7.4	115.6	3,167,744.9	1,665.5	1.2	0.8
02/21/2020 17:00	10.9	13.4	8.6	154.2	3,248,835.6	1,969.1	1.6	1.2
02/21/2020 18:00	10.7	13.3	8.3	172.6	3,192,605.2	2,074.9	1.9	1.5
02/21/2020 19:00	10.6	13.3	8.2	170.8	3,219,878.8	2,045.6	1.8	1.4
02/21/2020 20:00	10.5	13.3	8.2	172.4	3,201,807.6	2,057.5	1.9	1.4
02/21/2020 21:00	10.5	13.3	8.2	166.9	3,238,051.7	2,033.5	1.8	1.4
02/21/2020 22:00	10.4	13.3	8.1	173.0	3,214,101.3	2,065.4	1.9	1.4
02/21/2020 23:00	16.1	14.7	15.3	159.2	2,446,965.7	1,250.8	2.2	1.0
Average/Sum#:	9.3	13.8	7.7	123.3	3,081,327.8	1,706.2	1.3	0.9
Minimum:	8.0	13.3	6.7	92.9	2,446,965.7	1,250.8	1.1	0.6
Maximum:	16.1	14.7	15.3	173.0	3,248,835.6	2,074.9	2.2	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/25/2020 14:00	41.6	17.3	68.2	0.1	1,782,599.3	455.6	0.0	0.0
02/25/2020 15:00	49.7	15.4	53.3	221.2	1,967,080.3	804.4	3.8	1.2
02/25/2020 16:00	8.1	14.0	6.9	116.4	3,091,041.6	1,602.6	1.3	0.8
02/25/2020 17:00	8.6	14.0	7.4	96.7	2,937,318.9	1,522.9	1.1	0.6
02/25/2020 18:00	10.5	13.4	8.3	122.0	3,275,262.3	1,961.2	1.2	1.0
02/25/2020 19:00	10.6	13.3	8.2	178.8	3,205,974.6	2,107.0	1.9	1.5
02/25/2020 20:00	10.5	13.3	8.2	187.6	3,222,661.9	2,141.5	2.0	1.7
02/25/2020 21:00	10.5	13.3	8.2	184.0	3,229,559.2	2,122.5	2.0	1.7
02/25/2020 22:00	10.4	13.3	8.1	180.3	3,218,299.5	2,115.1	1.9	1.5
02/25/2020 23:00	10.4	13.3	8.1	180.9	3,241,535.2	2,106.7	1.9	1.5
Average/Sum#:	17.1	14.1	18.5	146.8	2,917,133.3	1,694.0	1.7	1.2
Minimum:	8.1	13.3	6.9	0.1	1,782,599.3	455.6	0.0	0.0
Maximum:	49.7	17.3	68.2	221.2	3,275,262.3	2,141.5	3.8	1.7
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/26/2020 00:00	10.3	13.4	8.1	164.2	3,255,524.5	2,020.7	1.7	1.4
02/26/2020 01:00	10.5	13.4	8.3	174.6	3,219,421.2	2,021.8	1.9	1.4
02/26/2020 02:00	10.5	13.4	8.3	173.4	3,217,828.8	2,020.8	1.9	1.4
02/26/2020 03:00	10.5	13.4	8.3	170.6	3,248,596.9	2,016.4	1.8	1.4
02/26/2020 04:00	10.3	13.4	8.1	166.8	3,283,195.0	2,013.9	1.7	1.4
02/26/2020 05:00	10.6	13.4	8.3	161.0	3,269,663.7	2,005.6	1.7	1.4
02/26/2020 06:00	10.9	13.4	8.6	167.9	3,300,807.7	2,000.6	1.7	1.4
02/26/2020 07:00	10.7	13.4	8.4	164.1	3,318,349.1	1,987.0	1.7	1.4
02/26/2020 08:00	16.6	14.9	16.3	158.1	2,444,115.9	1,195.8	2.1	1.0
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.2	13.6	9.2	166.7	3,173,055.9	1,920.3	1.8	1.4
Minimum:	10.3	13.4	8.1	158.1	2,444,115.9	1,195.8	1.7	1.0
Maximum:	16.6	14.9	16.3	174.6	3,318,349.1	2,021.8	2.1	1.4
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/27/2020 02:00	35.0	17.7	64.5	1.5	1,823,984.9	412.9	0.0	0.0
02/27/2020 03:00	39.8	15.0	39.8	218.0	2,214,289.6	954.0	3.2	1.1
02/27/2020 04:00	8.2	13.9	6.9	111.2	3,280,342.0	1,724.7	1.1	0.7
02/27/2020 05:00	8.3	13.9	7.0	108.2	3,283,575.4	1,726.4	1.1	0.7
02/27/2020 06:00	8.2	13.9	6.9	107.9	3,272,734.1	1,720.7	1.1	0.7
02/27/2020 07:00	8.4	13.9	7.1	107.4	3,281,102.8	1,725.1	1.1	0.7
02/27/2020 08:00	8.5	13.9	7.2	109.1	3,275,587.0	1,722.2	1.1	0.7
02/27/2020 09:00	8.7	13.9	7.3	109.6	3,283,955.8	1,726.6	1.1	0.7
02/27/2020 10:00	9.3	13.8	7.7	116.6	3,285,287.1	1,727.3	1.2	0.9
02/27/2020 11:00	9.6	13.8	8.0	123.2	3,278,630.2	1,723.8	1.3	0.9
02/27/2020 12:00	8.8	13.8	7.3	114.2	3,245,916.2	1,706.6	1.2	0.9
02/27/2020 13:00	8.5	13.8	7.1	105.5	3,149,676.1	1,656.0	1.1	0.7
02/27/2020 14:00	8.6	13.8	7.1	104.8	3,130,466.1	1,645.9	1.1	0.7
02/27/2020 15:00	8.6	13.8	7.1	104.5	3,106,691.4	1,633.4	1.1	0.7
02/27/2020 16:00	9.9	13.6	8.0	116.0	3,177,240.1	1,809.7	1.2	0.9
02/27/2020 17:00	10.8	13.3	8.4	129.2	3,201,462.4	2,033.9	1.4	1.0
02/27/2020 18:00	10.6	13.3	8.2	128.6	3,203,823.4	2,035.4	1.4	1.0
02/27/2020 19:00	10.5	13.3	8.2	128.6	3,209,175.2	2,038.8	1.4	1.0
02/27/2020 20:00	10.4	13.3	8.1	131.9	3,234,487.0	2,078.5	1.4	1.0
02/27/2020 21:00	10.3	13.3	8.0	132.3	3,201,683.4	2,080.8	1.4	1.0
02/27/2020 22:00	10.3	13.3	8.0	132.8	3,209,376.8	2,085.8	1.4	1.0
02/27/2020 23:00	9.6	13.4	7.6	122.8	3,250,100.5	1,993.6	1.3	1.0
Average/Sum#:	11.9	13.9	11.6	116.5	3,118,163.1	1,725.6	1.3	0.8
Minimum:	8.2	13.3	6.9	1.5	1,823,984.9	412.9	0.0	0.0
Maximum:	39.8	17.7	64.5	218.0	3,285,287.1	2,085.8	3.2	1.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/28/2020 00:00	9.1	13.6	7.4	113.1	3,271,017.5	1,887.0	1.2	0.9
02/28/2020 01:00	8.4	13.9	7.1	99.2	2,961,570.4	1,557.1	1.1	0.6
02/28/2020 02:00	8.4	13.9	7.1	93.5	2,793,435.5	1,468.7	1.1	0.6
02/28/2020 03:00	8.5	13.9	7.2	94.9	2,840,985.0	1,493.7	1.1	0.6
02/28/2020 04:00	8.5	13.9	7.2	94.4	2,828,812.3	1,487.3	1.1	0.6
02/28/2020 05:00	8.5	13.9	7.2	102.6	3,074,928.3	1,616.7	1.1	0.6
02/28/2020 06:00	8.6	13.9	7.2	105.2	3,146,062.3	1,654.1	1.1	0.7
02/28/2020 07:00	8.5	13.9	7.2	103.0	3,071,504.8	1,614.9	1.1	0.6
02/28/2020 08:00	8.5	13.9	7.2	97.5	2,891,958.0	1,520.5	1.1	0.6
02/28/2020 09:00	8.5	13.9	7.2	95.7	2,865,140.1	1,506.4	1.1	0.6
02/28/2020 10:00	8.5	13.9	7.2	92.4	2,798,447.7	1,450.9	1.1	0.6
02/28/2020 11:00	8.5	13.9	7.2	94.5	2,862,675.6	1,484.2	1.1	0.6
02/28/2020 12:00	8.4	13.9	7.1	98.0	2,978,208.7	1,544.1	1.1	0.6
02/28/2020 13:00	8.5	13.9	7.2	100.6	3,042,822.4	1,577.6	1.1	0.6
02/28/2020 14:00	8.5	13.9	7.2	91.6	2,744,635.1	1,423.0	1.1	0.6
02/28/2020 15:00	9.0	13.9	7.6	108.8	2,918,395.5	1,534.4	1.2	0.8
02/28/2020 16:00	10.9	13.3	8.5	163.2	3,181,682.4	1,998.1	1.8	1.4
02/28/2020 17:00	10.8	13.3	8.4	168.6	3,156,990.1	2,028.7	1.8	1.4
02/28/2020 18:00	10.6	13.3	8.2	166.9	3,171,083.2	2,014.6	1.8	1.4
02/28/2020 19:00	10.6	13.3	8.2	168.4	3,187,138.5	2,024.8	1.8	1.4
02/28/2020 20:00	10.5	13.3	8.2	163.6	3,194,739.7	2,006.3	1.8	1.4
02/28/2020 21:00	10.5	13.3	8.2	168.3	3,209,332.6	2,038.9	1.8	1.4
02/28/2020 22:00	10.4	13.3	8.1	165.2	3,208,433.9	2,014.9	1.8	1.4
02/28/2020 23:00	15.4	14.7	14.7	149.9	2,405,622.2	1,212.1	2.1	1.0
Average/Sum#:	9.4	13.7	7.8	120.8	2,991,900.9	1,673.3	1.4	0.9
Minimum:	8.4	13.3	7.1	91.6	2,405,622.2	1,212.1	1.1	0.6
Maximum:	15.4	14.7	14.7	168.6	3,271,017.5	2,038.9	2.1	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 15:00	41.8	17.4	70.5	0.1	1,761,321.4	437.3	0.0	0.0
03/03/2020 16:00	45.4	15.5	49.6	198.6	2,043,679.2	820.8	3.3	1.1
03/03/2020 17:00	8.7	13.9	7.3	126.0	3,002,463.0	1,578.6	1.4	0.8
03/03/2020 18:00	10.3	13.3	8.0	175.9	3,191,528.2	2,074.2	1.9	1.5
03/03/2020 19:00	10.2	13.3	7.9	200.1	3,159,689.1	2,145.8	2.2	1.7
03/03/2020 20:00	10.3	13.3	8.0	205.1	3,160,278.1	2,146.2	2.3	1.9
03/03/2020 21:00	10.3	13.3	8.0	195.3	3,164,990.1	2,149.4	2.2	1.7
03/03/2020 22:00	10.1	13.3	7.8	182.6	3,184,137.4	2,115.9	2.0	1.7
03/03/2020 23:00	10.0	13.3	7.8	174.5	3,205,068.5	2,083.0	1.9	1.5
Average/Sum#:	17.5	14.1	19.4	162.0	2,874,795.0	1,727.9	1.9	1.3
Minimum:	8.7	13.3	7.3	0.1	1,761,321.4	437.3	0.0	0.0
Maximum:	45.4	17.4	70.5	205.1	3,205,068.5	2,149.4	3.3	1.9
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/04/2020 00:00	9.9	13.4	7.8	161.8	3,232,160.0	2,029.8	1.7	1.4
03/04/2020 01:00	10.1	13.4	7.9	161.6	3,213,847.9	2,018.3	1.7	1.4
03/04/2020 02:00	10.0	13.4	7.9	154.4	3,246,855.7	1,967.9	1.6	1.2
03/04/2020 03:00	10.1	13.4	7.9	155.2	3,279,103.4	1,963.5	1.6	1.2
03/04/2020 04:00	10.1	13.4	7.9	161.6	3,247,952.4	2,016.0	1.7	1.4
03/04/2020 05:00	10.0	13.4	7.9	167.2	3,245,858.0	2,014.7	1.8	1.4
03/04/2020 06:00	10.7	13.4	8.4	168.0	3,244,408.0	2,013.8	1.8	1.4
03/04/2020 07:00	10.6	13.4	8.3	172.7	3,226,686.1	2,002.8	1.8	1.4
03/04/2020 08:00	8.1	13.9	6.8	100.4	2,814,357.3	1,479.7	1.2	0.7
03/04/2020 09:00	8.1	14.0	6.9	84.9	2,610,971.5	1,353.7	1.1	0.5
03/04/2020 10:00	8.1	14.0	6.9	84.7	2,613,093.2	1,354.8	1.1	0.5
03/04/2020 11:00	8.4	13.9	7.1	97.3	2,988,816.9	1,549.6	1.1	0.6
03/04/2020 12:00	8.4	13.9	7.1	104.3	3,230,684.3	1,675.0	1.1	0.7
03/04/2020 13:00	8.3	14.0	7.1	95.4	2,915,138.0	1,511.4	1.1	0.6
03/04/2020 14:00	8.6	14.0	7.4	108.4	3,087,569.8	1,600.8	1.2	0.8
03/04/2020 15:00	8.2	14.0	7.0	99.5	3,043,015.3	1,577.7	1.1	0.6
03/04/2020 16:00	8.8	13.9	7.4	117.8	2,934,618.6	1,521.5	1.4	0.8
03/04/2020 17:00	10.6	13.4	8.3	157.1	3,199,994.5	2,009.6	1.7	1.4
03/04/2020 18:00	10.5	13.3	8.2	165.6	3,201,934.6	2,034.2	1.8	1.4
03/04/2020 19:00	10.3	13.3	8.0	164.6	3,196,110.6	2,030.5	1.8	1.4
03/04/2020 20:00	10.3	13.3	8.0	179.9	3,197,910.3	2,101.7	2.0	1.7
03/04/2020 21:00	10.1	13.3	7.8	178.8	3,179,622.8	2,112.9	2.0	1.7
03/04/2020 22:00	10.0	13.3	7.8	175.6	3,192,736.9	2,098.3	1.9	1.5
03/04/2020 23:00	10.0	13.3	7.8	167.6	3,213,897.4	2,041.8	1.8	1.4
Average/Sum#:	9.5	13.6	7.7	141.0	3,106,556.0	1,836.7	1.5	1.1
Minimum:	8.1	13.3	6.8	84.7	2,610,971.5	1,353.7	1.1	0.5
Maximum:	10.7	14.0	8.4	179.9	3,279,103.4	2,112.9	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/05/2020 00:00	9.9	13.4	7.8	155.2	3,243,885.9	1,966.1	1.6	1.2
03/05/2020 01:00	10.4	13.4	8.2	161.6	3,221,942.1	1,952.8	1.7	1.4
03/05/2020 02:00	10.3	13.4	8.1	162.0	3,234,151.4	1,960.2	1.7	1.4
03/05/2020 03:00	10.4	13.4	8.2	160.8	3,234,646.4	1,960.5	1.7	1.4
03/05/2020 04:00	10.3	13.4	8.1	172.3	3,201,777.2	2,034.1	1.9	1.4
03/05/2020 05:00	10.4	13.4	8.2	172.2	3,202,406.8	2,034.5	1.9	1.4
03/05/2020 06:00	10.5	13.4	8.3	166.9	3,218,784.2	2,021.4	1.8	1.4
03/05/2020 07:00	9.8	13.5	7.8	153.9	3,232,996.5	1,959.5	1.6	1.2
03/05/2020 08:00	8.1	13.9	6.8	101.5	3,038,030.0	1,597.3	1.1	0.6
03/05/2020 09:00	8.2	13.9	6.9	104.5	3,162,038.9	1,662.5	1.1	0.7
03/05/2020 10:00	8.3	13.9	7.0	104.7	3,173,831.2	1,668.7	1.1	0.7
03/05/2020 11:00	8.4	13.8	7.0	104.4	3,152,148.7	1,657.3	1.1	0.7
03/05/2020 12:00	8.4	13.8	7.0	103.3	3,100,795.2	1,630.3	1.1	0.7
03/05/2020 13:00	8.5	13.8	7.1	105.1	3,168,886.1	1,666.1	1.1	0.7
03/05/2020 14:00	8.6	13.8	7.1	100.2	2,933,006.9	1,563.5	1.1	0.6
03/05/2020 15:00	8.6	13.8	7.1	96.5	2,848,592.9	1,497.7	1.1	0.6
03/05/2020 16:00	9.2	13.9	7.8	116.1	2,773,845.2	1,458.4	1.4	0.7
03/05/2020 17:00	10.8	13.3	8.4	154.0	3,152,383.1	1,979.7	1.7	1.4
03/05/2020 18:00	10.7	13.3	8.3	171.9	3,141,213.3	2,041.5	1.9	1.4
03/05/2020 19:00	10.6	13.3	8.2	171.3	3,175,664.0	2,040.7	1.9	1.4
03/05/2020 20:00	10.5	13.3	8.2	169.2	3,194,379.1	2,029.4	1.8	1.4
03/05/2020 21:00	10.4	13.3	8.1	174.9	3,204,141.8	2,059.0	1.9	1.4
03/05/2020 22:00	10.4	13.3	8.1	172.7	3,202,896.9	2,058.2	1.9	1.4
03/05/2020 23:00	10.3	13.4	8.1	162.5	3,203,474.9	1,965.0	1.7	1.4
Average/Sum#:	9.7	13.5	7.7	142.4	3,142,329.9	1,852.7	1.5	1.1
Minimum:	8.1	13.3	6.8	96.5	2,773,845.2	1,458.4	1.1	0.6
Maximum:	10.8	13.9	8.4	174.9	3,243,885.9	2,059.0	1.9	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/06/2020 00:00	10.4	13.3	8.1	171.5	3,205,397.5	2,036.4	1.8	1.4
03/06/2020 01:00	10.3	13.3	8.0	173.9	3,209,962.2	2,039.3	1.9	1.4
03/06/2020 02:00	10.3	13.4	8.1	158.6	3,208,691.8	1,968.2	1.7	1.4
03/06/2020 03:00	10.3	13.4	8.1	163.9	3,223,463.9	2,000.8	1.7	1.4
03/06/2020 04:00	10.4	13.3	8.1	164.5	3,206,682.4	2,013.8	1.8	1.4
03/06/2020 05:00	10.3	13.4	8.1	173.4	3,199,888.3	2,032.9	1.9	1.4
03/06/2020 06:00	10.5	13.3	8.2	158.6	3,222,765.1	2,023.9	1.7	1.4
03/06/2020 07:00	10.5	13.4	8.3	166.3	3,230,069.3	2,004.9	1.8	1.4
03/06/2020 08:00	9.8	13.5	7.8	150.7	3,205,455.1	1,919.4	1.6	1.2
03/06/2020 09:00	8.2	13.9	6.9	102.3	3,051,153.6	1,604.2	1.1	0.6
03/06/2020 10:00	8.4	13.9	7.1	104.5	3,133,699.5	1,647.6	1.1	0.7
03/06/2020 11:00	8.4	13.9	7.1	105.1	3,163,560.5	1,663.3	1.1	0.7
03/06/2020 12:00	8.3	13.9	7.0	103.3	3,106,691.4	1,633.4	1.1	0.7
03/06/2020 13:00	8.3	13.9	7.0	104.5	3,147,964.3	1,655.1	1.1	0.7
03/06/2020 14:00	8.3	13.9	7.0	102.8	3,079,302.9	1,619.0	1.1	0.6
03/06/2020 15:00	8.4	13.9	7.1	101.8	3,045,447.7	1,601.2	1.1	0.6
03/06/2020 16:00	8.9	13.9	7.5	109.2	2,848,212.5	1,497.5	1.3	0.7
03/06/2020 17:00	10.6	13.3	8.2	155.9	3,185,120.0	1,977.0	1.7	1.4
03/06/2020 18:00	10.6	13.3	8.2	164.5	3,174,860.9	2,017.0	1.8	1.4
03/06/2020 19:00	10.4	13.3	8.1	165.1	3,181,629.3	2,021.3	1.8	1.4
03/06/2020 20:00	10.5	13.3	8.2	179.3	3,165,804.9	2,080.6	2.0	1.7
03/06/2020 21:00	10.2	13.3	7.9	182.6	3,168,035.4	2,105.2	2.0	1.7
03/06/2020 22:00	10.2	13.3	7.9	175.7	3,183,988.6	2,069.3	1.9	1.4
03/06/2020 23:00	10.1	13.3	7.8	168.4	3,164,304.0	2,033.4	1.8	1.4
Average/Sum#:	9.7	13.5	7.7	146.1	3,154,673.0	1,886.0	1.6	1.2
Minimum:	8.2	13.3	6.9	101.8	2,848,212.5	1,497.5	1.1	0.6
Maximum:	10.6	13.9	8.3	182.6	3,230,069.3	2,105.2	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/07/2020 00:00	16.1	14.7	15.3	151.4	2,412,730.1	1,233.3	2.1	1.0
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.1	14.7	15.3	151.4	2,412,730.1	1,233.3	2.1	1.0
Minimum:	16.1	14.7	15.3	151.4	2,412,730.1	1,233.3	2.1	1.0
Maximum:	16.1	14.7	15.3	151.4	2,412,730.1	1,233.3	2.1	1.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/09/2020 01:00	22.8	18.0	46.4	0.1	1,941,605.6	326.1	0.0	0.0
03/09/2020 02:00	48.8	16.4	64.0	110.8	1,854,379.2	622.9	0.0	0.0
03/09/2020 03:00	9.8	13.9	8.3	139.0	2,788,870.8	1,466.3	1.7	1.0
03/09/2020 04:00	8.3	13.9	7.0	98.7	2,965,184.2	1,559.0	1.1	0.6
03/09/2020 05:00	10.3	13.4	8.1	158.2	3,295,528.0	1,997.4	1.6	1.2
03/09/2020 06:00	10.7	13.3	8.3	172.4	3,277,540.3	2,130.1	1.8	1.5
03/09/2020 07:00	10.7	13.3	8.3	184.0	3,249,228.6	2,111.7	2.0	1.7
03/09/2020 08:00	10.6	13.3	8.2	187.9	3,232,149.3	2,100.6	2.0	1.7
03/09/2020 09:00	8.3	13.8	6.9	106.0	3,046,969.3	1,646.5	1.2	0.8
03/09/2020 10:00	8.2	13.9	6.9	99.2	2,981,731.4	1,567.7	1.1	0.6
03/09/2020 11:00	8.3	13.9	7.0	97.4	2,932,089.8	1,541.6	1.1	0.6
03/09/2020 12:00	8.3	13.9	7.0	104.3	3,167,364.5	1,665.3	1.1	0.7
03/09/2020 13:00	8.3	13.9	7.0	104.3	3,172,690.0	1,668.1	1.1	0.7
03/09/2020 14:00	8.2	13.9	6.9	104.0	3,166,603.7	1,664.9	1.1	0.7
03/09/2020 15:00	8.2	13.9	6.9	102.8	3,118,864.0	1,639.8	1.1	0.7
03/09/2020 16:00	8.6	13.9	7.2	105.5	3,151,768.3	1,657.1	1.1	0.7
03/09/2020 17:00	10.6	13.4	8.3	158.8	3,221,691.7	1,999.7	1.7	1.4
03/09/2020 18:00	10.6	13.3	8.2	183.1	3,187,186.4	2,141.2	2.0	1.7
03/09/2020 19:00	10.4	13.3	8.1	184.5	3,195,224.3	2,146.6	2.0	1.7
03/09/2020 20:00	10.3	13.3	8.0	182.3	3,212,517.4	2,111.3	2.0	1.7
03/09/2020 21:00	10.5	13.3	8.2	190.5	3,182,181.1	2,114.6	2.1	1.7
03/09/2020 22:00	10.5	13.3	8.2	191.4	3,181,278.2	2,114.0	2.1	1.7
03/09/2020 23:00	10.2	13.3	7.9	184.9	3,180,826.7	2,113.7	2.0	1.7
Average/Sum#:	11.8	13.9	11.8	137.0	3,030,585.8	1,743.7	1.4	1.1
Minimum:	8.2	13.3	6.9	0.1	1,854,379.2	326.1	0.0	0.0
Maximum:	48.8	18.0	64.0	191.4	3,295,528.0	2,146.6	2.1	1.7
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/10/2020 00:00	10.3	13.3	8.0	188.6	3,183,986.9	2,115.8	2.1	1.7
03/10/2020 01:00	10.3	13.3	8.0	185.7	3,202,931.5	2,105.0	2.0	1.7
03/10/2020 02:00	10.3	13.4	8.1	186.4	3,186,194.1	2,094.0	2.0	1.7
03/10/2020 03:00	10.3	13.4	8.1	170.7	3,224,915.7	2,048.8	1.8	1.4
03/10/2020 04:00	10.1	13.4	7.9	169.8	3,229,795.3	2,051.9	1.8	1.4
03/10/2020 05:00	10.4	13.4	8.2	202.5	3,159,100.1	2,145.4	2.2	1.7
03/10/2020 06:00	10.8	13.3	8.4	212.0	3,193,209.4	2,215.2	2.3	2.0
03/10/2020 07:00	10.4	13.3	8.1	197.2	3,171,091.5	2,176.7	2.2	1.7
03/10/2020 08:00	0.0	0.0	0.0	171.9	1,408,869.0	2,150.2	4.6	3.9
03/10/2020 09:00	10.7	13.3	8.3	174.0	3,342,510.1	2,099.1	1.8	1.5
03/10/2020 10:00	10.9	13.3	8.5	160.6	3,324,801.3	2,063.7	1.6	1.2
03/10/2020 11:00	11.0	13.3	8.5	168.3	3,294,488.8	2,093.0	1.8	1.5
03/10/2020 12:00	10.7	13.3	8.3	173.1	3,290,664.5	2,114.6	1.8	1.5
03/10/2020 13:00	10.6	13.3	8.2	173.1	3,267,788.9	2,099.9	1.8	1.5
03/10/2020 14:00	10.7	13.3	8.3	176.4	3,252,921.4	2,114.1	1.9	1.5
03/10/2020 15:00	10.6	13.3	8.2	170.5	3,288,350.0	2,089.1	1.8	1.5
03/10/2020 16:00	10.6	13.3	8.2	174.8	3,252,382.9	2,090.0	1.9	1.5
03/10/2020 17:00	10.5	13.3	8.2	166.2	3,280,726.8	2,060.3	1.7	1.4
03/10/2020 18:00	10.6	13.3	8.2	185.2	3,249,147.5	2,159.1	2.0	1.7
03/10/2020 19:00	10.6	13.3	8.2	196.3	3,231,252.5	2,194.4	2.1	1.8
03/10/2020 20:00	10.6	13.3	8.2	196.4	3,263,695.5	2,192.6	2.1	1.8
03/10/2020 21:00	10.4	13.3	8.1	176.5	3,254,460.1	2,115.1	1.9	1.5
03/10/2020 22:00	10.3	13.3	8.0	165.5	3,304,720.1	2,099.5	1.7	1.5
03/10/2020 23:00	10.5	13.4	8.3	173.6	3,262,220.7	2,072.5	1.8	1.5
Average/Sum#:	10.5	13.3	8.2	179.8	3,248,319.8	2,115.0	1.9	1.6
Minimum:	10.1	13.3	7.9	160.6	3,159,100.1	2,048.8	1.6	1.2
Maximum:	11.0	13.4	8.5	212.0	3,342,510.1	2,215.2	2.3	2.0
%SI	4.17	4.17	4.17	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/11/2020 00:00	10.6	13.4	8.3	161.9	3,311,862.1	2,007.3	1.7	1.4
03/11/2020 01:00	10.6	13.4	8.3	160.3	3,302,127.7	2,001.4	1.7	1.4
03/11/2020 02:00	10.8	13.4	8.5	165.0	3,284,336.1	2,014.6	1.7	1.4
03/11/2020 03:00	10.8	13.4	8.5	164.5	3,289,390.0	2,017.7	1.7	1.4
03/11/2020 04:00	10.8	13.4	8.5	165.6	3,335,852.6	2,046.2	1.7	1.4
03/11/2020 05:00	10.8	13.4	8.5	166.3	3,238,150.1	2,104.5	1.8	1.5
03/11/2020 06:00	11.2	13.3	8.7	196.7	3,258,634.6	2,189.2	2.1	1.8
03/11/2020 07:00	10.9	13.3	8.5	179.2	3,313,377.4	2,105.0	1.9	1.5
03/11/2020 08:00	10.7	13.3	8.3	170.3	3,304,562.7	2,099.4	1.8	1.5
03/11/2020 09:00	8.7	13.7	7.1	115.4	3,203,311.9	1,684.2	1.2	0.8
03/11/2020 10:00	8.6	13.8	7.1	103.8	3,166,696.1	1,618.7	1.1	0.6
03/11/2020 11:00	8.8	13.8	7.3	99.2	2,999,626.3	1,533.3	1.1	0.6
03/11/2020 12:00	8.7	13.9	7.3	99.8	3,111,570.4	1,567.8	1.1	0.6
03/11/2020 13:00	8.6	13.9	7.2	104.9	3,284,435.4	1,654.9	1.1	0.7
03/11/2020 14:00	8.5	13.9	7.2	103.2	3,218,544.2	1,621.7	1.1	0.6
03/11/2020 15:00	8.7	13.9	7.3	98.1	3,035,755.9	1,529.6	1.1	0.6
03/11/2020 16:00	8.8	14.0	7.5	88.1	2,665,141.5	1,323.4	1.1	0.5
03/11/2020 17:00	8.7	13.9	7.3	102.6	3,193,537.4	1,609.1	1.1	0.6
03/11/2020 18:00	8.9	13.8	7.4	113.3	3,278,010.7	1,675.6	1.2	0.8
03/11/2020 19:00	11.2	13.3	8.7	154.6	3,304,437.5	2,002.8	1.6	1.2
03/11/2020 20:00	11.1	13.3	8.6	194.8	3,230,204.2	2,170.1	2.1	1.7
03/11/2020 21:00	10.7	13.3	8.3	176.0	3,253,690.8	2,114.6	1.9	1.5
03/11/2020 22:00	10.6	13.3	8.2	164.5	3,271,331.9	2,054.4	1.7	1.4
03/11/2020 23:00	10.5	13.3	8.2	168.7	3,303,460.9	2,098.7	1.8	1.5
Average/Sum#:	9.9	13.6	8.0	142.4	3,214,918.7	1,868.5	1.5	1.1
Minimum:	8.5	13.3	7.1	88.1	2,665,141.5	1,323.4	1.1	0.5
Maximum:	11.2	14.0	8.7	196.7	3,335,852.6	2,189.2	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/12/2020 00:00	10.6	13.4	8.3	168.1	3,273,083.5	2,055.5	1.8	1.4
03/12/2020 01:00	10.6	13.4	8.3	164.1	3,297,052.2	2,022.4	1.7	1.4
03/12/2020 02:00	10.6	13.4	8.3	155.6	3,279,103.4	1,963.5	1.6	1.2
03/12/2020 03:00	10.7	13.4	8.4	163.3	3,290,857.2	2,018.6	1.7	1.4
03/12/2020 04:00	10.8	13.4	8.5	170.6	3,275,312.8	2,056.9	1.8	1.4
03/12/2020 05:00	10.8	13.4	8.5	175.5	3,188,450.8	2,072.2	1.9	1.5
03/12/2020 06:00	11.1	13.3	8.6	204.9	3,231,694.3	2,194.7	2.2	1.8
03/12/2020 07:00	10.4	13.3	8.1	183.7	3,283,608.8	2,182.0	1.9	1.5
03/12/2020 08:00	10.2	13.3	7.9	167.8	3,230,267.5	2,052.2	1.8	1.4
03/12/2020 09:00	8.2	13.9	6.9	107.1	3,201,322.9	1,636.4	1.1	0.7
03/12/2020 10:00	8.4	13.9	7.1	106.7	3,221,668.7	1,646.8	1.1	0.7
03/12/2020 11:00	8.9	13.9	7.5	107.0	3,236,604.8	1,630.8	1.1	0.7
03/12/2020 12:00	9.6	13.9	8.1	118.0	3,302,694.4	1,664.1	1.2	0.8
03/12/2020 13:00	8.7	13.9	7.3	107.3	3,090,532.8	1,557.2	1.2	0.8
03/12/2020 14:00	8.5	13.9	7.2	105.2	3,214,821.6	1,643.3	1.1	0.7
03/12/2020 15:00	10.1	13.6	8.2	126.8	3,251,842.3	1,804.7	1.3	0.9
03/12/2020 16:00	10.9	13.3	8.5	167.9	3,239,155.5	2,081.5	1.8	1.5
03/12/2020 17:00	10.7	13.3	8.3	188.6	3,230,336.7	2,146.6	2.0	1.7
03/12/2020 18:00	10.4	13.3	8.1	191.0	3,219,914.3	2,186.7	2.1	1.7
03/12/2020 19:00	10.5	13.2	8.0	194.9	3,234,197.5	2,196.4	2.1	1.8
03/12/2020 20:00	10.3	13.3	8.0	167.5	3,270,248.4	2,077.6	1.8	1.5
03/12/2020 21:00	10.5	13.3	8.2	189.0	3,230,501.9	2,170.3	2.0	1.7
03/12/2020 22:00	10.4	13.3	8.1	193.6	3,225,657.0	2,190.6	2.1	1.8
03/12/2020 23:00	10.5	13.3	8.2	194.6	3,248,512.8	2,182.4	2.1	1.7
Average/Sum#:	10.1	13.5	8.0	159.1	3,240,310.1	1,976.4	1.7	1.3
Minimum:	8.2	13.2	6.9	105.2	3,090,532.8	1,557.2	1.1	0.7
Maximum:	11.1	13.9	8.6	204.9	3,302,694.4	2,196.4	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/13/2020 00:00	10.4	13.3	8.1	193.5	3,237,497.9	2,175.0	2.1	1.7
03/13/2020 01:00	10.4	13.3	8.1	192.1	3,271,118.4	2,173.7	2.0	1.7
03/13/2020 02:00	10.3	13.3	8.0	184.0	3,253,361.1	2,161.9	2.0	1.7
03/13/2020 03:00	10.3	13.3	8.0	181.6	3,247,191.1	2,157.8	1.9	1.5
03/13/2020 04:00	10.4	13.3	8.1	170.7	3,285,373.6	2,111.2	1.8	1.5
03/13/2020 05:00	10.6	13.3	8.2	184.0	3,223,595.5	2,189.2	2.0	1.8
03/13/2020 06:00	10.9	13.3	8.5	180.5	3,259,230.0	2,165.8	1.9	1.5
03/13/2020 07:00	10.4	13.3	8.1	175.2	3,296,004.5	2,142.1	1.8	1.5
03/13/2020 08:00	10.4	13.3	8.1	180.0	3,269,424.6	2,148.7	1.9	1.5
03/13/2020 09:00	8.5	13.8	7.1	114.1	3,170,123.7	1,689.9	1.2	0.8
03/13/2020 10:00	8.3	13.9	7.0	99.8	3,120,302.9	1,572.2	1.1	0.6
03/13/2020 11:00	8.5	14.0	7.3	101.5	3,188,774.1	1,606.7	1.1	0.6
03/13/2020 12:00	8.8	13.9	7.4	104.5	3,280,466.0	1,652.9	1.1	0.7
03/13/2020 13:00	9.0	13.9	7.6	107.1	3,182,820.1	1,603.7	1.1	0.6
03/13/2020 14:00	9.0	13.9	7.6	106.0	3,206,213.7	1,638.9	1.1	0.7
03/13/2020 15:00	8.9	13.9	7.5	105.2	3,265,779.5	1,645.5	1.1	0.7
03/13/2020 16:00	9.0	13.9	7.6	105.9	3,295,152.6	1,660.3	1.1	0.7
03/13/2020 17:00	10.4	13.5	8.3	138.4	3,227,697.2	1,791.3	1.4	0.9
03/13/2020 18:00	10.8	13.3	8.4	155.2	3,268,896.6	2,029.0	1.6	1.2
03/13/2020 19:00	10.7	13.3	8.3	188.9	3,235,265.1	2,173.5	2.0	1.7
03/13/2020 20:00	10.7	13.2	8.2	197.3	3,230,663.5	2,194.0	2.1	1.8
03/13/2020 21:00	10.5	13.3	8.2	174.5	3,269,846.9	2,125.1	1.8	1.5
03/13/2020 22:00	10.3	13.3	8.0	165.5	3,278,276.1	2,082.7	1.7	1.5
03/13/2020 23:00	10.5	13.4	8.3	164.5	3,279,690.8	2,035.7	1.7	1.4
Average/Sum#:	9.9	13.5	7.9	152.9	3,243,448.6	1,955.3	1.6	1.2
Minimum:	8.3	13.2	7.0	99.8	3,120,302.9	1,572.2	1.1	0.6
Maximum:	10.9	14.0	8.5	197.3	3,296,004.5	2,194.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/14/2020 00:00	10.5	13.3	8.2	174.4	3,272,146.2	2,102.7	1.8	1.5
03/14/2020 01:00	10.4	13.3	8.1	175.7	3,249,536.4	2,111.9	1.9	1.5
03/14/2020 02:00	10.5	13.3	8.2	174.7	3,274,791.7	2,104.4	1.8	1.5
03/14/2020 03:00	10.3	13.3	8.0	167.4	3,267,788.9	2,099.9	1.8	1.5
03/14/2020 04:00	10.4	13.4	8.2	160.6	3,306,996.9	2,028.5	1.7	1.4
03/14/2020 05:00	10.5	13.4	8.3	177.4	3,260,961.5	2,071.7	1.9	1.5
03/14/2020 06:00	11.0	13.3	8.5	169.6	3,287,085.4	2,112.3	1.8	1.5
03/14/2020 07:00	10.6	13.4	8.3	173.2	3,289,007.1	2,065.5	1.8	1.4
03/14/2020 08:00	8.3	13.9	7.0	109.4	3,420,385.5	1,723.4	1.1	0.7
03/14/2020 09:00	8.3	13.9	7.0	107.4	3,407,683.6	1,717.0	1.0	0.7
03/14/2020 10:00	8.4	13.9	7.1	107.3	3,401,134.2	1,713.7	1.0	0.7
03/14/2020 11:00	8.4	13.9	7.1	107.3	3,401,928.0	1,714.1	1.0	0.7
03/14/2020 12:00	8.4	13.9	7.1	107.4	3,398,554.1	1,712.4	1.0	0.7
03/14/2020 13:00	8.5	13.9	7.2	107.7	3,390,416.9	1,708.3	1.1	0.7
03/14/2020 14:00	8.6	13.9	7.2	108.1	3,396,370.9	1,711.3	1.1	0.7
03/14/2020 15:00	8.6	13.9	7.2	108.1	3,395,974.0	1,711.1	1.1	0.7
03/14/2020 16:00	8.8	13.9	7.4	117.5	3,409,866.7	1,718.1	1.1	0.7
03/14/2020 17:00	10.0	13.7	8.2	129.2	3,290,270.3	1,802.0	1.3	0.9
03/14/2020 18:00	11.1	13.4	8.7	176.4	3,324,835.0	2,088.0	1.8	1.5
03/14/2020 19:00	10.8	13.3	8.4	196.2	3,274,429.1	2,175.9	2.1	1.7
03/14/2020 20:00	10.3	13.3	8.0	182.6	3,294,465.8	2,141.1	1.9	1.5
03/14/2020 21:00	10.3	13.4	8.1	165.6	3,334,389.1	2,094.0	1.7	1.5
03/14/2020 22:00	10.2	13.4	8.0	152.5	3,335,455.8	2,021.6	1.6	1.2
03/14/2020 23:00	10.3	13.4	8.1	152.7	3,360,934.8	2,012.5	1.5	1.2
Average/Sum#:	9.7	13.6	7.8	146.2	3,335,225.3	1,935.9	1.5	1.2
Minimum:	8.3	13.3	7.0	107.3	3,249,536.4	1,708.3	1.0	0.7
Maximum:	11.1	13.9	8.7	196.2	3,420,385.5	2,175.9	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/15/2020 00:00	10.4	13.4	8.2	163.6	3,324,318.0	2,063.4	1.7	1.4
03/15/2020 01:00	10.1	13.4	7.9	152.1	3,343,375.4	2,026.4	1.6	1.2
03/15/2020 02:00	10.2	13.4	8.0	149.7	3,365,109.9	2,015.0	1.5	1.2
03/15/2020 03:00	10.3	13.4	8.1	150.7	3,366,278.9	2,015.7	1.5	1.2
03/15/2020 04:00	10.2	13.4	8.0	148.5	3,346,180.2	2,028.1	1.5	1.2
03/15/2020 05:00	10.2	13.4	8.0	150.7	3,382,645.2	2,025.5	1.5	1.2
03/15/2020 06:00	10.5	13.4	8.3	150.9	3,336,341.7	2,046.5	1.5	1.2
03/15/2020 07:00	10.4	13.4	8.2	151.5	3,333,081.1	2,044.5	1.5	1.2
03/15/2020 08:00	10.0	13.4	7.9	149.7	3,296,353.0	1,997.9	1.6	1.2
03/15/2020 09:00	8.2	13.9	6.9	108.2	3,364,480.1	1,719.8	1.1	0.7
03/15/2020 10:00	8.4	13.9	7.1	108.7	3,373,479.2	1,724.4	1.1	0.7
03/15/2020 11:00	8.4	13.9	7.1	108.3	3,354,502.8	1,714.7	1.1	0.7
03/15/2020 12:00	8.5	13.9	7.2	108.5	3,404,508.1	1,715.4	1.1	0.7
03/15/2020 13:00	8.5	13.9	7.2	108.6	3,409,271.3	1,717.8	1.1	0.7
03/15/2020 14:00	8.5	13.9	7.2	100.2	3,091,922.1	1,557.9	1.1	0.6
03/15/2020 15:00	8.5	13.9	7.2	96.1	2,961,330.6	1,492.1	1.1	0.6
03/15/2020 16:00	8.7	13.9	7.3	96.4	2,953,788.9	1,488.3	1.1	0.6
03/15/2020 17:00	9.8	13.7	8.0	125.2	3,320,669.1	1,794.4	1.3	0.9
03/15/2020 18:00	11.0	13.3	8.5	195.6	3,302,899.5	2,170.7	2.1	1.7
03/15/2020 19:00	10.7	13.3	8.3	208.8	3,301,950.1	2,218.3	2.2	1.8
03/15/2020 20:00	10.6	13.3	8.2	203.0	3,277,389.8	2,201.8	2.2	1.8
03/15/2020 21:00	10.5	13.3	8.2	196.3	3,307,837.1	2,198.1	2.1	1.8
03/15/2020 22:00	10.4	13.4	8.2	165.1	3,352,673.1	2,081.0	1.7	1.5
03/15/2020 23:00	10.4	13.4	8.2	166.2	3,365,722.9	2,089.1	1.7	1.5
Average/Sum#:	9.7	13.6	7.8	144.3	3,301,504.5	1,922.8	1.5	1.1
Minimum:	8.2	13.3	6.9	96.1	2,953,788.9	1,488.3	1.1	0.6
Maximum:	11.0	13.9	8.5	208.8	3,409,271.3	2,218.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/16/2020 00:00	10.3	13.3	8.0	165.3	3,344,421.0	2,100.3	1.7	1.5
03/16/2020 01:00	10.3	13.3	8.0	163.9	3,361,211.9	2,086.3	1.7	1.5
03/16/2020 02:00	10.3	13.3	8.0	165.1	3,345,057.9	2,100.7	1.7	1.5
03/16/2020 03:00	10.3	13.3	8.0	164.3	3,373,133.9	2,093.7	1.7	1.5
03/16/2020 04:00	10.3	13.3	8.0	177.2	3,359,913.8	2,159.1	1.8	1.5
03/16/2020 05:00	10.2	13.3	7.9	179.3	3,319,636.9	2,181.7	1.9	1.5
03/16/2020 06:00	10.6	13.3	8.2	187.8	3,321,747.2	2,231.6	2.0	1.8
03/16/2020 07:00	10.4	13.3	8.1	168.8	3,378,815.8	2,121.9	1.7	1.5
03/16/2020 08:00	10.3	13.3	8.0	167.7	3,357,000.6	2,108.2	1.7	1.5
03/16/2020 09:00	10.4	13.4	8.2	169.0	3,339,803.1	2,097.4	1.7	1.5
03/16/2020 10:00	10.4	13.4	8.2	167.7	3,340,440.1	2,097.8	1.7	1.5
03/16/2020 11:00	10.3	13.4	8.1	173.6	3,322,349.5	2,110.7	1.8	1.5
03/16/2020 12:00	10.3	13.4	8.1	172.4	3,332,637.6	2,092.9	1.8	1.5
03/16/2020 13:00	10.3	13.4	8.1	162.8	3,321,095.8	2,061.4	1.7	1.4
03/16/2020 14:00	10.3	13.4	8.1	162.3	3,290,162.9	2,042.2	1.7	1.4
03/16/2020 15:00	10.4	13.4	8.2	160.2	3,314,172.0	2,008.7	1.7	1.4
03/16/2020 16:00	10.5	13.4	8.3	159.7	3,311,697.1	2,007.2	1.6	1.2
03/16/2020 17:00	10.3	13.4	8.1	160.0	3,331,496.0	2,019.2	1.6	1.2
03/16/2020 18:00	10.4	13.3	8.1	190.5	3,305,429.3	2,196.5	2.0	1.8
03/16/2020 19:00	10.4	13.3	8.1	194.3	3,277,092.1	2,201.6	2.1	1.8
03/16/2020 20:00	10.3	13.3	8.0	183.0	3,302,159.2	2,146.1	1.9	1.5
03/16/2020 21:00	10.3	13.3	8.0	183.6	3,289,509.5	2,161.9	1.9	1.5
03/16/2020 22:00	10.3	13.3	8.0	169.8	3,296,062.8	2,094.0	1.8	1.5
03/16/2020 23:00	10.3	13.3	8.0	170.2	3,297,007.3	2,094.6	1.8	1.5
Average/Sum#:	10.3	13.3	8.1	171.6	3,326,335.6	2,109.0	1.8	1.5
Minimum:	10.2	13.3	7.9	159.7	3,277,092.1	2,007.2	1.6	1.2
Maximum:	10.6	13.4	8.3	194.3	3,378,815.8	2,231.6	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/17/2020 00:00	10.4	13.3	8.1	165.0	3,310,822.3	2,079.2	1.7	1.5
03/17/2020 01:00	10.3	13.3	8.0	158.2	3,339,623.3	2,072.9	1.6	1.2
03/17/2020 02:00	10.2	13.4	8.0	150.1	3,361,602.9	2,012.9	1.5	1.2
03/17/2020 03:00	10.3	13.4	8.1	154.0	3,369,114.0	2,042.0	1.6	1.2
03/17/2020 04:00	10.2	13.4	8.0	148.7	3,350,246.7	2,006.1	1.5	1.2
03/17/2020 05:00	10.3	13.3	8.0	167.7	3,293,229.5	2,092.2	1.8	1.5
03/17/2020 06:00	10.7	13.3	8.3	168.3	3,344,352.2	2,149.1	1.7	1.5
03/17/2020 07:00	10.2	13.4	8.0	147.8	3,394,650.9	2,007.9	1.5	1.2
03/17/2020 08:00	9.1	13.6	7.4	121.1	3,344,596.7	1,880.6	1.2	0.9
03/17/2020 09:00	8.3	13.9	7.0	108.5	3,346,677.6	1,710.7	1.1	0.7
03/17/2020 10:00	8.4	13.9	7.1	108.6	3,366,827.7	1,721.0	1.1	0.7
03/17/2020 11:00	8.5	13.9	7.2	109.0	3,372,892.3	1,724.1	1.1	0.7
03/17/2020 12:00	8.5	13.9	7.2	109.0	3,374,457.3	1,724.9	1.1	0.7
03/17/2020 13:00	8.4	13.9	7.1	108.7	3,372,109.7	1,723.7	1.1	0.7
03/17/2020 14:00	8.4	13.9	7.1	108.4	3,368,784.0	1,722.0	1.1	0.7
03/17/2020 15:00	8.4	13.9	7.1	108.8	3,368,001.5	1,721.6	1.1	0.7
03/17/2020 16:00	8.5	13.9	7.2	109.2	3,376,218.0	1,725.8	1.1	0.7
03/17/2020 17:00	10.8	13.4	8.5	147.4	3,347,143.7	1,979.8	1.5	1.2
03/17/2020 18:00	10.7	13.3	8.3	167.1	3,315,121.7	2,081.9	1.7	1.5
03/17/2020 19:00	10.6	13.3	8.2	173.8	3,297,479.5	2,094.9	1.8	1.5
03/17/2020 20:00	10.3	13.4	8.1	158.1	3,319,876.0	2,036.4	1.6	1.2
03/17/2020 21:00	10.3	13.4	8.1	157.9	3,329,657.6	2,042.4	1.6	1.2
03/17/2020 22:00	10.3	13.4	8.1	159.4	3,331,613.9	2,043.6	1.6	1.2
03/17/2020 23:00	10.3	13.4	8.1	154.8	3,348,242.6	2,004.9	1.6	1.2
Average/Sum#:	9.7	13.6	7.8	140.4	3,347,639.2	1,933.4	1.4	1.1
Minimum:	8.3	13.3	7.0	108.4	3,293,229.5	1,710.7	1.1	0.7
Maximum:	10.8	13.9	8.5	173.8	3,394,650.9	2,149.1	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/18/2020 00:00	10.3	13.4	8.1	151.7	3,343,733.5	2,002.2	1.5	1.2
03/18/2020 01:00	10.0	13.4	7.9	146.0	3,344,067.5	2,002.4	1.5	1.2
03/18/2020 02:00	10.1	13.4	7.9	147.1	3,345,403.6	2,003.2	1.5	1.2
03/18/2020 03:00	10.2	13.4	8.0	147.9	3,352,250.7	2,007.3	1.5	1.2
03/18/2020 04:00	10.2	13.4	8.0	146.4	3,337,220.4	1,998.3	1.5	1.2
03/18/2020 05:00	9.7	13.5	7.7	144.9	3,258,414.9	1,998.7	1.5	1.2
03/18/2020 06:00	10.7	13.3	8.3	165.7	3,301,257.2	2,097.3	1.7	1.5
03/18/2020 07:00	10.4	13.3	8.1	156.5	3,325,284.6	2,064.0	1.6	1.2
03/18/2020 08:00	9.8	13.4	7.7	145.8	3,296,683.0	1,998.1	1.5	1.2
03/18/2020 09:00	8.2	13.9	6.9	103.6	3,171,391.2	1,621.1	1.1	0.6
03/18/2020 10:00	8.5	13.9	7.2	102.2	3,128,547.8	1,599.2	1.1	0.6
03/18/2020 11:00	8.6	13.9	7.2	101.4	3,100,963.7	1,585.1	1.1	0.6
03/18/2020 12:00	8.6	13.9	7.2	103.2	3,145,959.1	1,608.1	1.1	0.6
03/18/2020 13:00	8.7	13.8	7.2	101.9	3,103,311.3	1,586.3	1.1	0.6
03/18/2020 14:00	8.7	13.8	7.2	104.2	3,170,804.3	1,620.8	1.1	0.6
03/18/2020 15:00	8.7	13.8	7.2	102.9	3,127,569.7	1,598.7	1.1	0.6
03/18/2020 16:00	8.7	13.8	7.2	106.0	3,232,428.4	1,652.3	1.1	0.7
03/18/2020 17:00	8.9	13.8	7.4	99.4	3,000,604.5	1,533.8	1.1	0.6
03/18/2020 18:00	10.7	13.4	8.4	148.8	3,304,201.3	1,954.4	1.5	1.2
03/18/2020 19:00	10.6	13.4	8.3	148.9	3,312,838.0	1,983.7	1.5	1.2
03/18/2020 20:00	10.5	13.4	8.3	155.3	3,318,734.8	2,035.7	1.6	1.2
03/18/2020 21:00	10.4	13.4	8.2	155.7	3,330,011.1	2,018.3	1.6	1.2
03/18/2020 22:00	10.3	13.4	8.1	156.8	3,333,310.9	2,020.3	1.6	1.2
03/18/2020 23:00	9.9	13.5	7.9	143.4	3,342,578.9	1,977.1	1.5	1.2
Average/Sum#:	9.6	13.6	7.7	132.7	3,251,148.8	1,856.9	1.4	1.0
Minimum:	8.2	13.3	6.9	99.4	3,000,604.5	1,533.8	1.1	0.6
Maximum:	10.7	13.9	8.4	165.7	3,352,250.7	2,097.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/19/2020 00:00	9.0	13.6	7.3	117.6	3,364,693.5	1,891.9	1.2	0.9
03/19/2020 01:00	8.8	13.6	7.1	116.0	3,364,337.8	1,891.7	1.2	0.9
03/19/2020 02:00	8.7	13.7	7.1	120.0	3,422,479.8	1,899.4	1.2	0.9
03/19/2020 03:00	9.3	13.6	7.5	131.4	3,412,149.1	1,943.5	1.3	1.0
03/19/2020 04:00	10.4	13.3	8.1	160.0	3,358,956.4	2,084.9	1.6	1.3
03/19/2020 05:00	9.3	13.6	7.5	131.8	3,381,958.2	1,951.0	1.3	1.0
03/19/2020 06:00	10.6	13.3	8.2	157.2	3,382,641.3	2,074.9	1.6	1.2
03/19/2020 07:00	10.3	13.3	8.0	158.2	3,386,879.9	2,077.5	1.6	1.2
03/19/2020 08:00	9.7	13.5	7.7	141.5	3,321,107.7	1,964.4	1.4	1.0
03/19/2020 09:00	8.4	13.9	7.1	98.9	2,977,128.6	1,521.8	1.1	0.6
03/19/2020 10:00	8.5	13.9	7.2	99.9	3,049,512.5	1,558.8	1.1	0.6
03/19/2020 11:00	8.6	13.9	7.2	93.9	2,859,913.8	1,441.0	1.1	0.6
03/19/2020 12:00	8.5	13.9	7.2	96.3	2,934,872.1	1,500.2	1.1	0.6
03/19/2020 13:00	8.7	14.0	7.4	89.7	2,674,743.8	1,347.7	1.1	0.5
03/19/2020 14:00	9.1	14.0	7.8	87.1	2,533,435.1	1,276.5	1.1	0.5
03/19/2020 15:00	8.6	13.9	7.2	98.6	3,048,457.8	1,536.0	1.1	0.6
03/19/2020 16:00	8.9	13.9	7.5	100.1	2,998,047.1	1,510.6	1.1	0.6
03/19/2020 17:00	11.2	13.4	8.8	157.2	3,316,345.1	1,985.8	1.6	1.2
03/19/2020 18:00	10.8	13.4	8.5	167.2	3,279,529.7	2,035.6	1.7	1.4
03/19/2020 19:00	10.7	13.4	8.4	180.3	3,287,563.0	2,088.6	1.9	1.5
03/19/2020 20:00	10.5	13.4	8.3	176.9	3,292,442.5	2,091.7	1.9	1.5
03/19/2020 21:00	10.4	13.4	8.2	169.9	3,293,465.6	2,068.3	1.8	1.4
03/19/2020 22:00	10.3	13.4	8.1	159.7	3,318,679.2	2,059.9	1.6	1.2
03/19/2020 23:00	10.3	13.4	8.1	153.8	3,356,425.8	2,009.8	1.6	1.2
Average/Sum#:	9.6	13.6	7.7	131.8	3,192,323.6	1,825.5	1.4	1.0
Minimum:	8.4	13.3	7.1	87.1	2,533,435.1	1,276.5	1.1	0.5
Maximum:	11.2	14.0	8.8	180.3	3,422,479.8	2,091.7	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/20/2020 00:00	10.1	13.4	7.9	149.6	3,387,719.2	2,003.8	1.5	1.2
03/20/2020 01:00	10.1	13.4	7.9	151.0	3,393,129.3	2,007.0	1.5	1.2
03/20/2020 02:00	10.3	13.4	8.1	151.5	3,389,917.1	2,005.1	1.5	1.2
03/20/2020 03:00	10.3	13.4	8.1	150.7	3,387,719.2	2,003.8	1.5	1.2
03/20/2020 04:00	10.3	13.4	8.1	150.4	3,389,071.8	2,004.6	1.5	1.2
03/20/2020 05:00	9.3	13.6	7.5	132.4	3,410,042.3	1,942.3	1.3	1.0
03/20/2020 06:00	10.5	13.4	8.3	148.7	3,426,604.1	2,026.8	1.5	1.2
03/20/2020 07:00	8.8	13.7	7.2	119.6	3,392,929.1	1,883.0	1.2	0.9
03/20/2020 08:00	8.4	13.9	7.1	101.5	3,111,723.5	1,590.6	1.1	0.6
03/20/2020 09:00	8.4	14.0	7.2	86.7	2,680,499.4	1,350.6	1.1	0.5
03/20/2020 10:00	8.6	13.9	7.2	103.3	3,170,217.4	1,620.5	1.1	0.6
03/20/2020 11:00	8.6	13.9	7.2	97.8	2,984,171.4	1,525.4	1.1	0.6
03/20/2020 12:00	8.6	13.9	7.2	95.9	2,976,811.1	1,499.9	1.1	0.6
03/20/2020 13:00	8.5	13.9	7.2	102.8	3,202,865.3	1,613.8	1.1	0.6
03/20/2020 14:00	8.6	13.9	7.2	96.5	2,984,154.4	1,503.6	1.1	0.6
03/20/2020 15:00	9.0	13.9	7.6	99.7	3,035,427.0	1,551.6	1.1	0.6
03/20/2020 16:00	11.4	13.4	9.0	126.3	3,306,658.9	1,980.0	1.3	1.0
03/20/2020 17:00	11.0	13.4	8.7	130.1	3,291,509.3	2,019.0	1.3	1.0
03/20/2020 18:00	10.9	13.4	8.6	169.7	3,295,258.9	2,021.3	1.8	1.4
03/20/2020 19:00	10.7	13.4	8.4	168.6	3,270,829.9	2,030.2	1.8	1.4
03/20/2020 20:00	10.7	13.4	8.4	173.1	3,309,818.2	2,054.4	1.8	1.4
03/20/2020 21:00	10.4	13.4	8.2	169.9	3,296,650.4	2,070.3	1.8	1.4
03/20/2020 22:00	10.4	13.4	8.2	171.7	3,304,179.4	2,050.9	1.8	1.4
03/20/2020 23:00	10.4	13.4	8.2	159.1	3,319,451.7	2,011.9	1.6	1.2
Average/Sum#:	9.8	13.6	7.9	133.6	3,238,223.3	1,848.8	1.4	1.0
Minimum:	8.4	13.4	7.1	86.7	2,680,499.4	1,350.6	1.1	0.5
Maximum:	11.4	14.0	9.0	173.1	3,426,604.1	2,070.3	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/21/2020 00:00	10.3	13.4	8.1	160.4	3,345,634.2	2,052.2	1.6	1.2
03/21/2020 01:00	10.4	13.4	8.2	166.7	3,380,358.9	2,073.5	1.7	1.5
03/21/2020 02:00	10.4	13.4	8.2	163.7	3,328,990.1	2,066.3	1.7	1.4
03/21/2020 03:00	10.4	13.4	8.2	168.7	3,341,234.4	2,073.9	1.7	1.5
03/21/2020 04:00	10.5	13.4	8.3	165.4	3,330,472.7	2,042.9	1.7	1.4
03/21/2020 05:00	10.5	13.4	8.3	166.5	3,316,615.4	2,034.4	1.7	1.4
03/21/2020 06:00	10.3	13.5	8.2	143.2	3,333,618.5	1,971.8	1.5	1.2
03/21/2020 07:00	16.8	14.9	16.5	136.3	2,499,627.4	1,168.2	1.7	0.8
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.2	13.6	9.3	158.9	3,234,569.0	1,935.4	1.7	1.3
Minimum:	10.3	13.4	8.1	136.3	2,499,627.4	1,168.2	1.5	0.8
Maximum:	16.8	14.9	16.5	168.7	3,380,358.9	2,073.9	1.7	1.5
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/24/2020 02:00	37.9	17.5	65.8	0.1	1,932,600.2	451.6	0.0	0.0
03/24/2020 03:00	41.8	15.6	46.5	207.8	2,191,869.1	832.3	3.0	1.0
03/24/2020 04:00	8.6	13.8	7.1	116.0	3,267,716.6	1,694.2	1.2	0.8
03/24/2020 05:00	8.4	13.9	7.1	99.4	3,064,380.5	1,566.4	1.1	0.6
03/24/2020 06:00	8.5	13.9	7.2	105.4	3,242,014.4	1,657.2	1.1	0.7
03/24/2020 07:00	8.7	13.9	7.3	106.4	3,261,968.9	1,667.4	1.1	0.7
03/24/2020 08:00	8.7	13.9	7.3	99.0	3,025,254.1	1,546.4	1.1	0.6
03/24/2020 09:00	8.6	13.9	7.2	105.0	3,230,080.9	1,651.1	1.1	0.7
03/24/2020 10:00	8.6	13.9	7.2	105.8	3,269,207.3	1,671.1	1.1	0.7
03/24/2020 11:00	8.7	13.9	7.3	101.8	3,097,833.6	1,583.5	1.1	0.6
03/24/2020 12:00	8.6	13.9	7.2	102.5	3,153,001.8	1,611.7	1.1	0.6
03/24/2020 13:00	8.6	13.9	7.2	97.4	2,963,238.7	1,514.7	1.1	0.6
03/24/2020 14:00	8.6	13.9	7.2	98.5	3,004,908.4	1,536.0	1.1	0.6
03/24/2020 15:00	8.6	13.9	7.2	99.5	3,080,014.1	1,551.9	1.1	0.6
03/24/2020 16:00	8.7	13.9	7.3	99.8	3,113,753.5	1,568.9	1.1	0.6
03/24/2020 17:00	11.4	13.4	9.0	164.2	3,326,866.2	1,992.1	1.7	1.4
03/24/2020 18:00	11.0	13.5	8.8	154.8	3,313,499.8	1,959.9	1.6	1.2
03/24/2020 19:00	10.4	13.5	8.3	152.4	3,353,061.0	1,983.3	1.5	1.2
03/24/2020 20:00	10.8	13.4	8.5	170.5	3,322,446.5	2,086.5	1.8	1.5
03/24/2020 21:00	10.5	13.4	8.3	160.2	3,328,691.2	2,017.5	1.6	1.2
03/24/2020 22:00	10.4	13.4	8.2	153.7	3,386,653.3	2,027.9	1.5	1.2
03/24/2020 23:00	16.7	14.8	16.2	145.3	2,558,716.8	1,214.5	1.8	0.9
Average/Sum#:	12.4	14.1	12.4	120.3	3,067,626.2	1,608.5	1.3	0.8
Minimum:	8.4	13.4	7.1	0.1	1,932,600.2	451.6	0.0	0.0
Maximum:	41.8	17.5	65.8	207.8	3,386,653.3	2,086.5	3.0	1.5
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 23:00	38.5	17.4	64.9	40.7	1,891,416.7	469.6	0.0	0.0
Average/Sum#:	38.5	17.4	64.9	40.7	1,891,416.7	469.6	0.0	0.0
Minimum:	38.5	17.4	64.9	40.7	1,891,416.7	469.6	0.0	0.0
Maximum:	38.5	17.4	64.9	40.7	1,891,416.7	469.6	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/28/2020 00:00	35.4	15.1	36.0	224.1	2,373,826.3	1,005.4	3.0	1.2
03/28/2020 01:00	8.3	13.9	7.0	106.2	3,235,949.8	1,654.1	1.1	0.7
03/28/2020 02:00	8.5	13.9	7.2	105.1	3,253,948.0	1,663.3	1.1	0.7
03/28/2020 03:00	8.6	13.9	7.2	104.2	3,257,665.0	1,665.2	1.1	0.7
03/28/2020 04:00	8.6	13.9	7.2	104.4	3,218,538.6	1,645.2	1.1	0.7
03/28/2020 05:00	8.6	13.9	7.2	104.5	3,223,038.1	1,647.5	1.1	0.7
03/28/2020 06:00	8.9	13.9	7.5	98.6	2,986,518.9	1,526.6	1.1	0.6
03/28/2020 07:00	8.8	13.9	7.4	96.1	2,925,873.0	1,495.6	1.1	0.6
03/28/2020 08:00	8.8	13.9	7.4	102.4	3,145,567.8	1,607.9	1.1	0.6
03/28/2020 09:00	8.7	13.9	7.3	104.2	3,191,932.6	1,631.6	1.1	0.7
03/28/2020 10:00	8.7	13.9	7.3	105.3	3,235,362.9	1,653.8	1.1	0.7
03/28/2020 11:00	8.6	13.9	7.2	105.5	3,250,035.3	1,661.3	1.1	0.7
03/28/2020 12:00	8.6	13.9	7.2	104.9	3,229,885.2	1,651.0	1.1	0.7
03/28/2020 13:00	8.6	13.9	7.2	105.1	3,232,232.8	1,652.2	1.1	0.7
03/28/2020 14:00	8.6	13.9	7.2	104.1	3,191,932.6	1,631.6	1.1	0.7
03/28/2020 15:00	8.6	13.9	7.2	104.0	3,193,497.7	1,632.4	1.1	0.7
03/28/2020 16:00	8.6	13.9	7.2	105.3	3,250,035.3	1,661.3	1.1	0.7
03/28/2020 17:00	10.1	13.6	8.2	131.4	3,282,784.1	1,797.9	1.3	0.9
03/28/2020 18:00	11.2	13.3	8.7	172.7	3,273,396.5	2,079.6	1.8	1.5
03/28/2020 19:00	11.0	13.3	8.5	170.3	3,298,379.5	2,047.3	1.8	1.4
03/28/2020 20:00	10.8	13.3	8.4	174.7	3,288,350.0	2,089.1	1.8	1.5
03/28/2020 21:00	10.8	13.3	8.4	165.4	3,316,778.5	2,034.5	1.7	1.4
03/28/2020 22:00	10.7	13.3	8.3	163.1	3,304,225.4	2,026.8	1.7	1.4
03/28/2020 23:00	10.3	13.4	8.1	149.9	3,310,412.3	1,933.9	1.5	1.2
Average/Sum#:	10.4	13.8	8.8	125.5	3,186,256.9	1,712.3	1.3	0.9
Minimum:	8.3	13.3	7.0	96.1	2,373,826.3	1,005.4	1.1	0.6
Maximum:	35.4	15.1	36.0	224.1	3,316,778.5	2,089.1	3.0	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/29/2020 00:00	8.4	13.8	7.0	103.3	3,155,545.0	1,613.0	1.1	0.6
03/29/2020 01:00	8.6	13.8	7.1	100.9	3,079,639.8	1,574.2	1.1	0.6
03/29/2020 02:00	8.6	13.8	7.1	101.3	3,091,769.0	1,580.4	1.1	0.6
03/29/2020 03:00	8.6	13.8	7.1	98.3	2,996,300.6	1,531.6	1.1	0.6
03/29/2020 04:00	8.7	13.8	7.2	105.7	3,245,731.4	1,659.1	1.1	0.7
03/29/2020 05:00	8.7	13.8	7.2	103.7	3,091,964.6	1,580.5	1.1	0.6
03/29/2020 06:00	8.9	13.8	7.4	101.4	3,056,164.0	1,562.2	1.1	0.6
03/29/2020 07:00	8.9	13.8	7.4	102.3	3,100,181.2	1,584.7	1.1	0.6
03/29/2020 08:00	8.8	13.8	7.3	101.1	3,067,706.3	1,568.1	1.1	0.6
03/29/2020 09:00	8.8	13.8	7.3	105.1	3,204,844.3	1,638.2	1.1	0.7
03/29/2020 10:00	8.7	13.8	7.2	106.3	3,252,578.5	1,662.6	1.1	0.7
03/29/2020 11:00	8.7	13.9	7.3	105.2	3,216,386.6	1,644.1	1.1	0.7
03/29/2020 12:00	8.7	13.9	7.3	99.4	3,007,060.3	1,537.1	1.1	0.6
03/29/2020 13:00	8.8	13.9	7.4	101.2	3,088,247.6	1,578.6	1.1	0.6
03/29/2020 14:00	8.7	13.9	7.3	100.5	3,067,706.3	1,568.1	1.1	0.6
03/29/2020 15:00	8.6	13.9	7.2	100.5	3,106,211.7	1,565.1	1.1	0.6
03/29/2020 16:00	8.6	13.9	7.2	103.0	3,167,674.2	1,619.2	1.1	0.6
03/29/2020 17:00	8.9	13.9	7.5	98.9	2,998,452.5	1,532.7	1.1	0.6
03/29/2020 18:00	11.2	13.4	8.8	161.1	3,317,141.8	2,010.5	1.6	1.2
03/29/2020 19:00	11.1	13.3	8.6	183.0	3,255,339.6	2,091.9	1.9	1.5
03/29/2020 20:00	10.8	13.3	8.4	176.3	3,255,137.5	2,068.0	1.9	1.4
03/29/2020 21:00	10.7	13.3	8.3	171.3	3,280,886.0	2,060.4	1.8	1.4
03/29/2020 22:00	10.1	13.5	8.1	141.2	3,316,607.2	1,913.3	1.4	1.0
03/29/2020 23:00	10.2	13.4	8.0	145.9	3,298,772.2	1,927.1	1.5	1.2
Average/Sum#:	9.2	13.7	7.5	117.4	3,154,918.7	1,694.6	1.2	0.8
Minimum:	8.4	13.3	7.0	98.3	2,996,300.6	1,531.6	1.1	0.6
Maximum:	11.2	13.9	8.8	183.0	3,317,141.8	2,091.9	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/30/2020 00:00	8.3	13.9	7.0	105.5	3,234,776.0	1,653.5	1.1	0.7
03/30/2020 01:00	8.5	13.9	7.2	105.4	3,236,732.3	1,654.5	1.1	0.7
03/30/2020 02:00	8.6	13.9	7.2	105.0	3,215,799.7	1,643.8	1.1	0.7
03/30/2020 03:00	8.6	13.9	7.2	103.4	3,157,892.6	1,614.2	1.1	0.6
03/30/2020 04:00	8.6	13.9	7.2	102.1	3,111,723.5	1,590.6	1.1	0.6
03/30/2020 05:00	8.6	13.9	7.2	105.9	3,211,691.4	1,641.7	1.1	0.7
03/30/2020 06:00	8.8	13.9	7.4	106.2	3,237,319.2	1,654.8	1.1	0.7
03/30/2020 07:00	8.8	13.9	7.4	104.7	3,192,715.1	1,632.0	1.1	0.7
03/30/2020 08:00	8.8	13.9	7.4	103.2	3,147,132.9	1,608.7	1.1	0.6
03/30/2020 09:00	8.7	13.9	7.3	104.3	3,184,889.9	1,628.0	1.1	0.7
03/30/2020 10:00	8.7	13.9	7.3	104.5	3,189,193.8	1,630.2	1.1	0.7
03/30/2020 11:00	8.6	13.9	7.2	102.9	3,144,980.9	1,607.6	1.1	0.6
03/30/2020 12:00	8.7	13.9	7.3	101.1	3,083,748.1	1,576.3	1.1	0.6
03/30/2020 13:00	8.7	13.9	7.3	100.2	3,062,032.9	1,565.2	1.1	0.6
03/30/2020 14:00	8.5	13.9	7.2	103.2	3,167,869.9	1,619.3	1.1	0.6
03/30/2020 15:00	8.7	13.9	7.3	100.9	3,096,268.5	1,582.7	1.1	0.6
03/30/2020 16:00	8.6	13.9	7.2	103.8	3,189,193.8	1,630.2	1.1	0.7
03/30/2020 17:00	8.9	13.9	7.5	103.7	3,176,673.3	1,623.8	1.1	0.6
03/30/2020 18:00	11.2	13.4	8.8	156.1	3,308,161.9	1,980.9	1.6	1.2
03/30/2020 19:00	11.0	13.4	8.7	167.8	3,280,013.1	2,035.9	1.7	1.4
03/30/2020 20:00	11.0	13.3	8.5	183.6	3,246,151.3	2,109.7	2.0	1.7
03/30/2020 21:00	10.8	13.3	8.4	183.7	3,249,382.5	2,111.8	2.0	1.7
03/30/2020 22:00	10.6	13.3	8.2	173.7	3,288,192.6	2,089.0	1.8	1.5
03/30/2020 23:00	10.6	13.4	8.3	159.0	3,301,632.7	2,001.1	1.6	1.2
Average/Sum#:	9.2	13.8	7.6	120.4	3,196,423.7	1,728.6	1.3	0.9
Minimum:	8.3	13.3	7.0	100.2	3,062,032.9	1,565.2	1.1	0.6
Maximum:	11.2	13.9	8.8	183.7	3,308,161.9	2,111.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:57 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
03/31/2020 00:00	10.6	13.4	8.3	164.3	3,284,988.3	2,015.0	1.7	1.4
03/31/2020 01:00	10.6	13.4	8.3	160.7	3,288,574.8	2,017.2	1.7	1.4
03/31/2020 02:00	10.6	13.4	8.3	157.9	3,324,566.4	2,015.0	1.6	1.2
03/31/2020 03:00	10.5	13.4	8.3	155.0	3,320,606.6	2,012.6	1.6	1.2
03/31/2020 04:00	10.5	13.4	8.3	154.7	3,332,878.3	1,995.7	1.6	1.2
03/31/2020 05:00	9.4	13.6	7.6	153.3	3,349,296.0	1,907.7	1.6	1.1
03/31/2020 06:00	11.0	13.4	8.7	153.3	3,322,091.6	2,013.5	1.6	1.2
03/31/2020 07:00	16.6	14.7	15.8	143.3	2,501,754.4	1,224.0	1.9	0.9
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.2	13.6	9.2	155.3	3,215,594.6	1,900.1	1.7	1.2
Minimum:	9.4	13.4	7.6	143.3	2,501,754.4	1,224.0	1.6	0.9
Maximum:	16.6	14.7	15.8	164.3	3,349,296.0	2,017.2	1.9	1.4
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/01/2020 00:00	8.4	13.3	6.5	112.0	3,358,059.6	2,035.3	1.1	0.8
01/01/2020 01:00	8.4	13.3	6.5	111.0	3,342,715.4	2,026.0	1.1	0.8
01/01/2020 02:00	15.5	14.9	15.2	137.9	2,412,083.0	1,144.9	1.8	0.8
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.8	13.8	9.4	120.3	3,037,619.3	1,735.4	1.3	0.8
Minimum:	8.4	13.3	6.5	111.0	2,412,083.0	1,144.9	1.1	0.8
Maximum:	15.5	14.9	15.2	137.9	3,358,059.6	2,035.3	1.8	0.8
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/02/2020 01:00	34.8	17.5	60.4	0.0	1,809,596.5	462.5	-0.2	0.0
01/02/2020 02:00	46.8	15.9	55.2	241.5	1,809,707.2	700.4	4.0	1.1
01/02/2020 03:00	36.4	15.0	36.4	238.1	2,169,751.9	966.5	3.4	1.3
01/02/2020 04:00	7.1	13.8	5.9	88.3	2,893,049.7	1,542.2	1.0	0.6
01/02/2020 05:00	8.2	13.5	6.5	100.9	3,272,924.3	1,864.2	1.0	0.7
01/02/2020 06:00	9.6	13.1	7.3	142.1	3,294,399.3	2,117.0	1.4	1.1
01/02/2020 07:00	7.8	13.8	6.5	100.6	3,293,559.4	1,755.7	0.9	0.5
01/02/2020 08:00	7.5	13.8	6.2	87.9	2,883,670.1	1,537.2	0.9	0.5
01/02/2020 09:00	7.6	13.8	6.3	85.6	2,860,033.4	1,524.6	0.9	0.5
01/02/2020 10:00	7.7	13.8	6.4	94.2	3,114,596.3	1,660.3	0.9	0.5
01/02/2020 11:00	7.7	13.9	6.5	95.7	3,196,084.4	1,680.4	0.9	0.5
01/02/2020 12:00	7.5	13.9	6.3	92.3	3,092,997.1	1,626.2	0.9	0.5
01/02/2020 13:00	7.6	13.9	6.4	93.7	3,131,036.7	1,646.2	0.9	0.5
01/02/2020 14:00	7.7	13.9	6.5	93.0	3,106,501.2	1,633.3	0.9	0.5
01/02/2020 15:00	7.9	13.8	6.6	90.7	2,991,348.1	1,594.6	0.9	0.5
01/02/2020 16:00	9.3	13.3	7.2	114.3	3,286,292.5	2,015.8	1.1	0.8
01/02/2020 17:00	9.0	13.3	7.0	116.9	3,296,123.9	2,045.9	1.1	0.8
01/02/2020 18:00	9.0	13.2	6.9	120.3	3,307,319.1	2,077.0	1.2	1.0
01/02/2020 19:00	8.8	13.2	6.7	119.4	3,315,599.4	2,082.2	1.2	1.0
01/02/2020 20:00	8.8	13.2	6.7	119.6	3,315,917.8	2,082.4	1.2	1.0
01/02/2020 21:00	8.9	13.2	6.8	122.5	3,294,016.6	2,092.7	1.2	1.0
01/02/2020 22:00	9.0	13.2	6.9	124.6	3,274,498.3	2,080.3	1.2	1.0
01/02/2020 23:00	8.4	13.3	6.5	113.9	3,339,113.1	2,048.2	1.1	0.8
Average/Sum#:	12.3	13.9	12.4	112.9	3,015,136.4	1,688.5	1.2	0.7
Minimum:	7.1	13.1	5.9	0.0	1,809,596.5	462.5	-0.2	0.0
Maximum:	46.8	17.5	60.4	241.5	3,339,113.1	2,117.0	4.0	1.3
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/03/2020 00:00	8.5	13.3	6.6	112.4	3,358,224.6	2,035.4	1.1	0.8
01/03/2020 01:00	8.7	13.3	6.8	114.2	3,307,649.0	2,028.9	1.1	0.8
01/03/2020 02:00	8.5	13.3	6.6	111.5	3,380,307.2	2,024.1	1.0	0.8
01/03/2020 03:00	8.5	13.3	6.6	112.4	3,361,359.4	2,037.3	1.1	0.8
01/03/2020 04:00	8.5	13.3	6.6	112.6	3,362,019.4	2,037.7	1.1	0.8
01/03/2020 05:00	8.4	13.3	6.5	110.8	3,350,140.0	2,030.5	1.0	0.8
01/03/2020 06:00	8.6	13.4	6.8	109.4	3,368,951.0	2,017.3	1.0	0.8
01/03/2020 07:00	8.6	13.3	6.7	111.0	3,386,653.3	2,027.9	1.0	0.8
01/03/2020 08:00	7.5	13.5	6.0	100.9	3,344,380.1	1,904.9	1.0	0.8
01/03/2020 09:00	7.2	13.8	6.0	86.1	2,915,352.4	1,532.8	0.9	0.5
01/03/2020 10:00	7.2	13.8	6.0	86.9	2,921,188.6	1,557.2	0.9	0.5
01/03/2020 11:00	7.3	13.8	6.1	90.0	3,013,484.0	1,606.4	0.9	0.5
01/03/2020 12:00	7.4	13.8	6.1	94.3	3,171,624.4	1,690.7	0.9	0.5
01/03/2020 13:00	7.4	13.8	6.1	93.7	3,130,541.7	1,668.8	0.9	0.5
01/03/2020 14:00	7.4	13.8	6.1	87.6	2,940,078.1	1,545.8	0.9	0.5
01/03/2020 15:00	7.4	13.8	6.1	88.6	3,007,408.1	1,581.2	0.9	0.5
01/03/2020 16:00	8.8	13.4	6.9	108.9	3,301,496.2	1,952.8	1.0	0.8
01/03/2020 17:00	8.7	13.3	6.8	113.7	3,317,267.5	2,034.8	1.1	0.8
01/03/2020 18:00	8.6	13.3	6.7	115.9	3,352,318.3	2,056.3	1.1	0.8
01/03/2020 19:00	8.4	13.3	6.5	114.2	3,327,701.3	2,041.2	1.1	0.8
01/03/2020 20:00	8.4	13.3	6.5	114.8	3,346,938.4	2,053.0	1.1	0.8
01/03/2020 21:00	8.5	13.2	6.5	120.0	3,336,936.9	2,095.6	1.1	0.8
01/03/2020 22:00	8.4	13.2	6.4	119.7	3,380,544.9	2,098.3	1.1	0.8
01/03/2020 23:00	11.2	13.9	9.4	128.6	2,939,346.5	1,674.2	1.4	0.8
Average/Sum#:	8.3	13.5	6.6	106.6	3,234,246.3	1,888.9	1.0	0.7
Minimum:	7.2	13.2	6.0	86.1	2,915,352.4	1,532.8	0.9	0.5
Maximum:	11.2	13.9	9.4	128.6	3,386,653.3	2,098.3	1.4	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/04/2020 00:00	2.7	19.3	10.0	29.7	1,521.6	0.2	685.7	0.1
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	2.7	19.3	10.0	29.7	1,521.6	0.2	685.7	0.1
Minimum:	2.7	19.3	10.0	29.7	1,521.6	0.2	685.7	0.1
Maximum:	2.7	19.3	10.0	29.7	1,521.6	0.2	685.7	0.1
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/06/2020 04:00	31.1	17.6	55.6	0.0	1,841,668.3	443.8	-0.2	0.0
01/06/2020 05:00	41.1	16.7	57.7	141.3	1,872,687.8	601.7	2.2	0.5
01/06/2020 06:00	45.2	15.4	48.5	264.3	2,024,345.6	842.6	4.0	1.3
01/06/2020 07:00	7.2	13.8	6.0	109.7	3,021,102.3	1,588.4	1.2	0.8
01/06/2020 08:00	7.6	13.8	6.3	99.9	3,293,934.6	1,755.9	0.9	0.5
01/06/2020 09:00	7.4	13.8	6.1	98.0	3,127,352.6	1,667.1	1.0	0.7
01/06/2020 10:00	7.4	13.9	6.2	88.8	2,959,097.9	1,555.8	0.9	0.5
01/06/2020 11:00	7.6	13.9	6.4	95.2	3,147,393.7	1,654.8	0.9	0.5
01/06/2020 12:00	7.3	13.9	6.2	90.0	3,011,782.7	1,583.5	0.9	0.5
01/06/2020 13:00	7.4	13.9	6.2	93.4	3,116,771.9	1,638.7	0.9	0.5
01/06/2020 14:00	7.4	13.9	6.2	89.9	2,980,590.2	1,567.1	0.9	0.5
01/06/2020 15:00	7.7	13.8	6.4	89.7	2,912,559.3	1,552.6	1.0	0.6
01/06/2020 16:00	8.8	13.3	6.8	112.2	3,364,775.9	2,014.8	1.0	0.8
01/06/2020 17:00	8.6	13.3	6.7	115.2	3,347,590.5	2,053.4	1.1	0.8
01/06/2020 18:00	8.5	13.3	6.6	114.1	3,381,653.3	2,049.6	1.1	0.8
01/06/2020 19:00	8.4	13.3	6.5	112.4	3,359,214.5	2,036.0	1.1	0.8
01/06/2020 20:00	8.4	13.4	6.6	111.8	3,392,832.4	2,031.6	1.0	0.8
01/06/2020 21:00	8.4	13.3	6.5	112.3	3,398,343.5	2,034.9	1.0	0.8
01/06/2020 22:00	8.3	13.3	6.4	113.5	3,387,098.0	2,052.9	1.1	0.8
01/06/2020 23:00	8.2	13.4	6.5	109.3	3,410,881.1	2,017.5	1.0	0.8
Average/Sum#:	12.6	14.1	13.5	108.1	3,017,583.8	1,637.1	1.2	0.7
Minimum:	7.2	13.3	6.0	0.0	1,841,668.3	443.8	-0.2	0.0
Maximum:	45.2	17.6	57.7	264.3	3,410,881.1	2,053.4	4.0	1.3
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/07/2020 00:00	8.3	13.3	6.4	112.1	3,400,681.6	2,036.3	1.0	0.8
01/07/2020 01:00	8.2	13.4	6.5	109.2	3,409,021.4	2,016.4	1.0	0.8
01/07/2020 02:00	8.2	13.4	6.5	108.8	3,395,158.1	2,008.2	1.0	0.8
01/07/2020 03:00	8.1	13.4	6.4	108.9	3,398,032.2	2,009.9	1.0	0.8
01/07/2020 04:00	8.2	13.4	6.5	110.7	3,424,406.3	2,025.5	1.0	0.8
01/07/2020 05:00	8.2	13.4	6.5	110.8	3,429,647.3	2,028.6	1.0	0.8
01/07/2020 06:00	8.4	13.4	6.6	111.1	3,391,830.4	2,031.0	1.0	0.8
01/07/2020 07:00	8.5	13.3	6.6	115.1	3,415,971.4	2,070.4	1.1	0.8
01/07/2020 08:00	7.6	13.6	6.1	103.8	3,441,995.5	1,960.5	1.0	0.8
01/07/2020 09:00	7.1	13.8	5.9	96.9	3,232,967.1	1,723.4	0.9	0.5
01/07/2020 10:00	7.2	13.8	6.0	91.9	3,048,939.0	1,625.3	0.9	0.5
01/07/2020 11:00	7.2	13.8	6.0	91.1	3,029,241.8	1,614.8	0.9	0.5
01/07/2020 12:00	7.3	13.8	6.1	95.2	3,147,049.8	1,677.6	0.9	0.5
01/07/2020 13:00	7.3	13.8	6.1	93.4	3,087,207.8	1,645.7	0.9	0.5
01/07/2020 14:00	7.3	13.8	6.1	90.8	2,989,284.6	1,593.5	0.9	0.5
01/07/2020 15:00	7.5	13.8	6.2	90.0	2,952,328.9	1,573.8	0.9	0.5
01/07/2020 16:00	8.5	13.4	6.7	110.7	3,365,276.9	2,015.1	1.0	0.8
01/07/2020 17:00	8.5	13.3	6.6	113.2	3,363,834.3	2,038.8	1.1	0.8
01/07/2020 18:00	8.4	13.3	6.5	112.6	3,359,379.5	2,036.1	1.1	0.8
01/07/2020 19:00	8.4	13.3	6.5	111.4	3,382,478.2	2,025.4	1.0	0.8
01/07/2020 20:00	8.4	13.3	6.5	114.3	3,392,377.7	2,056.1	1.1	0.8
01/07/2020 21:00	8.4	13.3	6.5	115.3	3,365,034.4	2,064.1	1.1	0.8
01/07/2020 22:00	14.3	14.7	13.6	134.1	2,548,337.7	1,265.4	1.6	0.8
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.2	13.6	6.7	106.6	3,259,586.2	1,875.7	1.0	0.7
Minimum:	7.1	13.3	5.9	90.0	2,548,337.7	1,265.4	0.9	0.5
Maximum:	14.3	14.7	13.6	134.1	3,441,995.5	2,070.4	1.6	0.8
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/08/2020 21:00	32.9	17.5	57.1	0.0	1,825,247.1	466.5	-0.2	0.0
01/08/2020 22:00	33.3	17.2	53.1	235.4	1,813,460.2	529.7	3.8	0.8
01/08/2020 23:00	31.8	15.6	35.4	243.6	2,159,955.7	867.5	3.4	1.1
Average/Sum#:	32.7	16.8	48.5	159.7	1,932,887.7	621.2	2.3	0.6
Minimum:	31.8	15.6	35.4	0.0	1,813,460.2	466.5	-0.2	0.0
Maximum:	33.3	17.5	57.1	243.6	2,159,955.7	867.5	3.8	1.1
%SI	87.50	87.50	87.50	87.50	87.50	87.50	87.50	87.50

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/09/2020 00:00	6.9	13.8	5.7	86.5	2,781,995.0	1,483.0	1.0	0.6
01/09/2020 01:00	7.4	13.8	6.1	78.6	2,612,177.0	1,373.4	0.9	0.4
01/09/2020 02:00	7.5	13.8	6.2	95.2	3,143,485.5	1,675.7	0.9	0.5
01/09/2020 03:00	7.5	13.8	6.2	88.9	2,838,085.1	1,512.9	1.0	0.6
01/09/2020 04:00	7.4	13.8	6.1	96.7	3,179,315.7	1,694.8	0.9	0.5
01/09/2020 05:00	7.3	13.8	6.1	94.0	3,066,760.3	1,634.8	1.0	0.7
01/09/2020 06:00	7.6	13.8	6.3	83.5	2,620,853.2	1,397.1	1.0	0.6
01/09/2020 07:00	7.5	13.8	6.2	85.8	2,798,315.6	1,491.7	1.0	0.6
01/09/2020 08:00	7.4	13.8	6.1	93.2	3,057,380.6	1,629.8	0.9	0.5
01/09/2020 09:00	7.4	13.8	6.1	97.6	3,203,327.5	1,707.6	1.0	0.7
01/09/2020 10:00	7.4	13.8	6.1	90.8	2,960,770.6	1,578.3	1.0	0.6
01/09/2020 11:00	7.4	13.8	6.1	96.0	3,140,671.6	1,674.2	1.0	0.7
01/09/2020 12:00	7.4	13.8	6.1	94.0	3,087,395.4	1,645.8	0.9	0.5
01/09/2020 13:00	7.5	13.8	6.2	97.2	3,171,436.8	1,690.6	1.0	0.7
01/09/2020 14:00	7.5	13.8	6.2	93.3	3,028,679.0	1,614.5	1.0	0.6
01/09/2020 15:00	7.6	13.8	6.3	90.9	2,941,073.4	1,567.8	1.0	0.6
01/09/2020 16:00	9.0	13.4	7.1	114.0	3,312,522.1	2,007.7	1.1	0.8
01/09/2020 17:00	8.8	13.3	6.8	119.3	3,344,617.7	2,076.0	1.1	0.8
01/09/2020 18:00	8.8	13.2	6.7	123.8	3,370,535.6	2,116.7	1.2	1.1
01/09/2020 19:00	8.7	13.2	6.7	123.9	3,322,192.1	2,110.6	1.2	1.1
01/09/2020 20:00	8.7	13.2	6.7	124.0	3,325,969.8	2,113.0	1.2	1.1
01/09/2020 21:00	8.7	13.3	6.8	121.4	3,334,389.1	2,094.0	1.2	1.0
01/09/2020 22:00	8.5	13.3	6.6	121.0	3,349,994.2	2,103.8	1.2	1.1
01/09/2020 23:00	8.5	13.3	6.6	121.2	3,344,580.2	2,100.4	1.2	1.1
Average/Sum#:	7.9	13.6	6.3	101.3	3,097,355.1	1,753.9	1.0	0.7
Minimum:	6.9	13.2	5.7	78.6	2,612,177.0	1,373.4	0.9	0.4
Maximum:	9.0	13.8	7.1	124.0	3,370,535.6	2,116.7	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/10/2020 00:00	8.4	13.3	6.5	116.7	3,359,328.4	2,060.6	1.1	0.8
01/10/2020 01:00	8.4	13.3	6.5	114.0	3,371,423.8	2,043.4	1.1	0.8
01/10/2020 02:00	8.5	13.3	6.6	120.2	3,373,617.2	2,094.0	1.1	0.8
01/10/2020 03:00	8.5	13.3	6.6	120.9	3,379,417.2	2,097.6	1.1	0.8
01/10/2020 04:00	8.4	13.4	6.6	113.5	3,352,614.9	2,032.0	1.1	0.8
01/10/2020 05:00	8.3	13.4	6.5	113.8	3,381,323.3	2,049.4	1.1	0.8
01/10/2020 06:00	8.5	13.3	6.6	123.2	3,373,561.0	2,118.6	1.2	1.1
01/10/2020 07:00	8.7	13.2	6.7	127.1	3,396,802.1	2,158.0	1.2	1.1
01/10/2020 08:00	8.4	13.3	6.5	115.6	3,414,486.5	2,069.5	1.1	0.8
01/10/2020 09:00	7.4	13.6	6.0	103.2	3,355,089.7	1,935.5	1.0	0.8
01/10/2020 10:00	7.0	13.8	5.8	95.8	3,196,011.4	1,703.7	0.9	0.5
01/10/2020 11:00	7.0	13.8	5.8	93.7	3,129,040.9	1,668.0	0.9	0.5
01/10/2020 12:00	7.1	13.8	5.9	92.6	3,075,201.9	1,639.3	0.9	0.5
01/10/2020 13:00	7.2	13.8	6.0	95.1	3,153,052.7	1,680.8	0.9	0.5
01/10/2020 14:00	7.1	13.8	5.9	87.6	2,896,801.6	1,544.2	0.9	0.5
01/10/2020 15:00	7.5	13.8	6.2	88.4	2,912,371.7	1,552.5	0.9	0.5
01/10/2020 16:00	8.5	13.4	6.7	112.0	3,401,015.6	2,036.5	1.0	0.8
01/10/2020 17:00	8.5	13.3	6.6	116.8	3,355,734.2	2,082.9	1.1	0.8
01/10/2020 18:00	8.4	13.3	6.5	119.2	3,357,478.3	2,108.5	1.1	0.8
01/10/2020 19:00	8.3	13.3	6.4	117.0	3,364,917.4	2,088.6	1.1	0.8
01/10/2020 20:00	8.2	13.3	6.4	115.4	3,389,488.4	2,079.1	1.1	0.8
01/10/2020 21:00	8.2	13.3	6.4	114.3	3,368,784.0	2,066.4	1.1	0.8
01/10/2020 22:00	8.2	13.4	6.5	111.8	3,361,524.4	2,037.4	1.1	0.8
01/10/2020 23:00	8.2	13.4	6.5	110.4	3,378,804.2	2,023.2	1.0	0.8
Average/Sum#:	8.0	13.5	6.4	109.9	3,295,745.5	1,957.1	1.0	0.8
Minimum:	7.0	13.2	5.8	87.6	2,896,801.6	1,544.2	0.9	0.5
Maximum:	8.7	13.8	6.7	127.1	3,414,486.5	2,158.0	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/11/2020 00:00	8.2	13.4	6.5	110.7	3,388,323.3	2,028.9	1.0	0.8
01/11/2020 01:00	8.1	13.4	6.4	110.2	3,379,806.2	2,023.8	1.0	0.8
01/11/2020 02:00	8.1	13.4	6.4	110.2	3,387,488.3	2,028.4	1.0	0.8
01/11/2020 03:00	8.1	13.4	6.4	110.0	3,386,319.3	2,027.7	1.0	0.8
01/11/2020 04:00	8.2	13.4	6.5	111.1	3,397,007.5	2,034.1	1.0	0.8
01/11/2020 05:00	8.2	13.4	6.5	110.5	3,384,482.3	2,026.6	1.0	0.8
01/11/2020 06:00	8.4	13.4	6.6	109.6	3,390,160.4	2,030.0	1.0	0.8
01/11/2020 07:00	8.4	13.4	6.6	111.4	3,395,003.5	2,032.9	1.0	0.8
01/11/2020 08:00	14.2	14.6	13.3	131.2	2,590,990.6	1,305.5	1.6	0.8
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.9	13.5	7.2	112.8	3,299,953.5	1,948.7	1.1	0.8
Minimum:	8.1	13.4	6.4	109.6	2,590,990.6	1,305.5	1.0	0.8
Maximum:	14.2	14.6	13.3	131.2	3,397,007.5	2,034.1	1.6	0.8
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/12/2020 23:00	30.0	17.6	53.6	0.0	1,832,538.8	441.6	-0.2	0.0
Average/Sum#:	30.0	17.6	53.6	0.0	1,832,538.8	441.6	-0.2	0.0
Minimum:	30.0	17.6	53.6	0.0	1,832,538.8	441.6	-0.2	0.0
Maximum:	30.0	17.6	53.6	0.0	1,832,538.8	441.6	-0.2	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/13/2020 00:00	42.6	16.2	53.5	170.4	1,849,281.9	661.7	2.7	0.7
01/13/2020 01:00	34.9	15.0	34.9	233.9	2,216,896.0	987.5	3.2	1.2
01/13/2020 02:00	6.9	13.8	5.7	83.9	2,717,088.1	1,448.4	1.0	0.6
01/13/2020 03:00	7.2	13.8	6.0	82.5	2,722,528.2	1,451.3	0.9	0.4
01/13/2020 04:00	7.5	13.8	6.2	88.8	3,134,293.5	1,670.8	0.9	0.5
01/13/2020 05:00	7.4	13.8	6.1	95.8	3,129,416.1	1,668.2	1.0	0.7
01/13/2020 06:00	7.4	13.8	6.1	94.6	3,088,708.6	1,646.5	1.0	0.7
01/13/2020 07:00	7.4	13.8	6.1	94.3	3,060,006.9	1,631.2	1.0	0.7
01/13/2020 08:00	7.3	13.8	6.1	89.0	2,917,811.9	1,555.4	1.0	0.6
01/13/2020 09:00	7.3	13.8	6.1	96.1	3,150,238.9	1,679.3	1.0	0.7
01/13/2020 10:00	7.3	13.8	6.1	92.4	3,005,980.3	1,602.4	1.0	0.6
01/13/2020 11:00	7.3	13.8	6.1	87.5	2,863,597.7	1,526.5	1.0	0.6
01/13/2020 12:00	7.4	13.8	6.1	93.3	3,037,683.4	1,619.3	1.0	0.6
01/13/2020 13:00	7.5	13.8	6.2	97.6	3,181,379.2	1,695.9	1.0	0.7
01/13/2020 14:00	7.4	13.8	6.1	91.6	2,972,964.1	1,584.8	1.0	0.6
01/13/2020 15:00	7.8	13.8	6.5	91.2	2,923,814.9	1,558.6	1.0	0.6
01/13/2020 16:00	8.8	13.3	6.8	113.9	3,338,095.7	2,023.2	1.1	0.8
01/13/2020 17:00	9.0	13.2	6.9	125.6	3,331,747.3	2,141.0	1.2	1.1
01/13/2020 18:00	8.8	13.2	6.7	127.0	3,315,084.1	2,154.5	1.2	1.1
01/13/2020 19:00	8.6	13.2	6.6	124.7	3,298,466.4	2,143.7	1.2	1.1
01/13/2020 20:00	8.5	13.2	6.5	123.2	3,319,298.0	2,133.0	1.2	1.1
01/13/2020 21:00	8.4	13.2	6.4	118.1	3,324,994.3	2,088.1	1.1	0.8
01/13/2020 22:00	8.3	13.3	6.4	114.8	3,314,329.2	2,057.2	1.1	0.8
01/13/2020 23:00	8.3	13.3	6.4	113.5	3,328,842.4	2,041.9	1.1	0.8
Average/Sum#:	10.4	13.8	9.4	110.2	3,022,606.1	1,698.8	1.2	0.8
Minimum:	6.9	13.2	5.7	82.5	1,849,281.9	661.7	0.9	0.4
Maximum:	42.6	16.2	53.5	233.9	3,338,095.7	2,154.5	3.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/14/2020 00:00	8.4	13.3	6.5	115.4	3,343,840.9	2,051.1	1.1	0.8
01/14/2020 01:00	8.4	13.3	6.5	114.5	3,324,766.8	2,039.4	1.1	0.8
01/14/2020 02:00	8.5	13.3	6.6	114.9	3,327,375.2	2,041.0	1.1	0.8
01/14/2020 03:00	8.5	13.3	6.6	114.5	3,323,951.6	2,038.9	1.1	0.8
01/14/2020 04:00	8.4	13.3	6.5	113.8	3,365,814.1	2,040.0	1.1	0.8
01/14/2020 05:00	8.4	13.3	6.5	116.1	3,368,457.9	2,066.2	1.1	0.8
01/14/2020 06:00	8.7	13.3	6.8	120.6	3,345,535.6	2,101.0	1.1	0.8
01/14/2020 07:00	8.8	13.2	6.7	127.5	3,361,470.0	2,160.1	1.2	1.1
01/14/2020 08:00	8.4	13.4	6.6	114.2	3,375,383.6	2,045.8	1.1	0.8
01/14/2020 09:00	8.3	13.4	6.5	110.5	3,322,357.2	1,989.4	1.1	0.8
01/14/2020 10:00	7.0	13.8	5.8	95.5	1,102,812.5	1,683.1	2.9	1.9
01/14/2020 11:00	7.4	13.8	6.1	104.7	3,189,445.7	1,700.2	1.0	0.7
01/14/2020 12:00	7.3	13.8	6.1	95.4	3,126,227.0	1,666.5	1.0	0.7
01/14/2020 13:00	7.5	13.9	6.3	96.9	1,106,481.8	1,688.7	2.9	1.9
01/14/2020 14:00	7.3	13.9	6.2	93.6	1,068,151.0	1,630.2	3.0	2.0
01/14/2020 15:00	7.3	13.9	6.2	88.2	2,892,674.5	1,542.0	0.9	0.5
01/14/2020 16:00	7.6	13.8	6.3	90.2	2,925,503.2	1,559.5	1.0	0.6
01/14/2020 17:00	8.8	13.4	6.9	111.5	3,354,588.7	2,008.7	1.0	0.8
01/14/2020 18:00	8.6	13.3	6.7	114.1	3,374,393.7	2,045.2	1.1	0.8
01/14/2020 19:00	8.4	13.3	6.5	113.7	3,384,458.1	2,051.3	1.1	0.8
01/14/2020 20:00	8.4	13.3	6.5	117.1	3,363,789.6	2,087.9	1.1	0.8
01/14/2020 21:00	8.3	13.3	6.4	115.7	3,382,478.2	2,074.8	1.1	0.8
01/14/2020 22:00	8.3	13.3	6.4	112.6	3,375,053.6	2,045.6	1.1	0.8
01/14/2020 23:00	7.9	13.4	6.2	106.7	3,420,308.6	1,998.1	1.0	0.8
Average/Sum#:	8.1	13.5	6.4	109.1	3,297,517.8	1,931.4	1.1	0.8
Minimum:	7.0	13.2	5.8	88.2	2,892,674.5	1,542.0	0.9	0.5
Maximum:	8.8	13.9	6.9	127.5	3,420,308.6	2,160.1	1.2	1.1
%SI	0.00	0.00	0.00	0.00	12.50	0.00	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/15/2020 00:00	8.2	13.4	6.5	111.2	3,405,691.6	2,039.3	1.0	0.8
01/15/2020 01:00	8.3	13.4	6.5	111.9	3,412,204.8	2,043.2	1.0	0.8
01/15/2020 02:00	8.2	13.4	6.5	111.8	3,410,200.7	2,042.0	1.0	0.8
01/15/2020 03:00	8.1	13.4	6.4	110.3	3,415,377.8	2,045.1	1.0	0.8
01/15/2020 04:00	8.2	13.4	6.5	111.3	3,411,870.8	2,043.0	1.0	0.8
01/15/2020 05:00	8.3	13.4	6.5	113.5	3,415,476.4	2,070.1	1.1	0.8
01/15/2020 06:00	8.6	13.2	6.6	124.8	3,368,472.8	2,164.6	1.2	1.1
01/15/2020 07:00	8.6	13.1	6.5	133.3	3,427,060.6	2,252.3	1.3	1.1
01/15/2020 08:00	7.8	13.4	6.1	112.8	3,379,178.4	2,048.1	1.1	0.8
01/15/2020 09:00	6.8	13.8	5.7	90.2	3,039,934.5	1,620.5	0.9	0.5
01/15/2020 10:00	7.5	13.8	6.2	94.8	3,111,970.0	1,658.9	0.9	0.5
01/15/2020 11:00	7.7	13.8	6.4	96.9	3,144,048.3	1,676.0	1.0	0.7
01/15/2020 12:00	7.4	13.8	6.1	93.8	3,068,636.2	1,635.8	1.0	0.7
01/15/2020 13:00	7.4	13.8	6.1	95.5	3,154,928.7	1,681.8	0.9	0.5
01/15/2020 14:00	7.4	13.8	6.1	96.3	3,182,504.7	1,696.5	0.9	0.5
01/15/2020 15:00	7.6	13.8	6.3	91.1	3,002,416.1	1,600.5	0.9	0.5
01/15/2020 16:00	8.7	13.3	6.8	115.7	3,373,185.7	2,069.1	1.1	0.8
01/15/2020 17:00	8.5	13.2	6.5	123.9	3,329,547.7	2,163.9	1.2	1.1
01/15/2020 18:00	8.3	13.2	6.4	121.3	3,330,346.7	2,140.1	1.2	1.1
01/15/2020 19:00	8.4	13.2	6.4	126.7	3,338,504.5	2,194.1	1.2	1.1
01/15/2020 20:00	8.3	13.2	6.4	126.2	3,329,222.8	2,188.0	1.2	1.1
01/15/2020 21:00	8.3	13.2	6.4	124.7	3,342,934.2	2,172.6	1.2	1.1
01/15/2020 22:00	8.2	13.3	6.4	117.4	3,333,911.4	2,093.7	1.1	0.8
01/15/2020 23:00	8.2	13.3	6.4	114.1	3,350,198.9	2,055.0	1.1	0.8
Average/Sum#:	8.0	13.4	6.4	111.2	3,294,909.3	1,974.8	1.1	0.8
Minimum:	6.8	13.1	5.7	90.2	3,002,416.1	1,600.5	0.9	0.5
Maximum:	8.7	13.8	6.8	133.3	3,427,060.6	2,252.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/16/2020 00:00	8.2	13.3	6.4	112.9	3,325,255.9	2,039.7	1.1	0.8
01/16/2020 01:00	8.3	13.3	6.4	113.9	3,336,830.7	2,046.8	1.1	0.8
01/16/2020 02:00	8.3	13.3	6.4	114.3	3,344,167.0	2,051.3	1.1	0.8
01/16/2020 03:00	8.3	13.3	6.4	114.7	3,349,220.8	2,054.4	1.1	0.8
01/16/2020 04:00	8.3	13.3	6.4	115.3	3,355,415.8	2,058.2	1.1	0.8
01/16/2020 05:00	8.3	13.3	6.4	114.9	3,352,481.3	2,056.4	1.1	0.8
01/16/2020 06:00	8.6	13.3	6.7	117.0	3,337,414.6	2,095.9	1.1	0.8
01/16/2020 07:00	8.7	13.2	6.7	127.6	3,315,832.9	2,179.2	1.2	1.1
01/16/2020 08:00	8.4	13.3	6.5	117.5	3,341,073.3	2,073.8	1.1	0.8
01/16/2020 09:00	8.1	13.4	6.4	109.1	3,303,318.8	1,978.0	1.0	0.8
01/16/2020 10:00	7.0	13.8	5.8	94.7	3,133,543.1	1,670.4	1.0	0.7
01/16/2020 11:00	7.2	13.8	6.0	91.1	2,968,837.0	1,582.6	1.0	0.6
01/16/2020 12:00	7.3	13.8	6.1	87.5	2,868,662.7	1,529.2	1.0	0.6
01/16/2020 13:00	7.4	13.8	6.1	95.4	3,120,411.7	1,663.4	1.0	0.7
01/16/2020 14:00	7.3	13.8	6.1	91.8	3,006,918.3	1,602.9	1.0	0.6
01/16/2020 15:00	7.6	13.8	6.3	98.8	3,258,104.5	1,736.8	0.9	0.5
01/16/2020 16:00	8.8	13.3	6.8	114.3	3,335,125.8	2,021.4	1.1	0.8
01/16/2020 17:00	8.4	13.3	6.5	114.6	3,334,874.4	2,045.6	1.1	0.8
01/16/2020 18:00	8.4	13.3	6.5	113.6	3,324,603.7	2,039.3	1.1	0.8
01/16/2020 19:00	8.3	13.3	6.4	113.9	3,341,395.5	2,049.6	1.1	0.8
01/16/2020 20:00	8.3	13.3	6.4	117.3	3,361,211.9	2,086.3	1.1	0.8
01/16/2020 21:00	8.3	13.3	6.4	117.2	3,368,945.1	2,091.1	1.1	0.8
01/16/2020 22:00	8.1	13.3	6.3	111.1	3,390,995.4	2,030.5	1.0	0.8
01/16/2020 23:00	8.2	13.4	6.5	111.5	3,402,852.6	2,037.6	1.0	0.8
Average/Sum#:	8.1	13.4	6.4	109.6	3,274,062.2	1,950.9	1.1	0.8
Minimum:	7.0	13.2	5.8	87.5	2,868,662.7	1,529.2	0.9	0.5
Maximum:	8.8	13.8	6.8	127.6	3,402,852.6	2,179.2	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/17/2020 00:00	8.2	13.3	6.4	111.9	3,415,544.8	2,045.2	1.0	0.8
01/17/2020 01:00	8.1	13.4	6.4	109.3	3,417,305.6	2,021.3	1.0	0.8
01/17/2020 02:00	8.1	13.4	6.4	109.8	3,411,369.7	2,042.7	1.0	0.8
01/17/2020 03:00	8.0	13.4	6.3	109.5	3,450,949.4	2,041.2	1.0	0.8
01/17/2020 04:00	8.1	13.4	6.4	110.7	3,423,561.0	2,050.0	1.0	0.8
01/17/2020 05:00	8.1	13.3	6.3	112.0	3,447,275.4	2,064.2	1.0	0.8
01/17/2020 06:00	8.5	13.2	6.5	128.6	3,374,631.0	2,193.2	1.2	1.1
01/17/2020 07:00	8.6	13.1	6.5	133.2	3,421,430.7	2,248.6	1.3	1.1
01/17/2020 08:00	8.0	13.3	6.2	111.6	3,435,418.2	2,057.1	1.0	0.8
01/17/2020 09:00	7.6	13.5	6.1	105.1	3,395,830.1	1,983.8	1.0	0.8
01/17/2020 10:00	6.8	13.8	5.7	94.9	3,175,563.8	1,692.8	0.9	0.5
01/17/2020 11:00	7.0	13.8	5.8	92.8	3,072,200.4	1,637.7	0.9	0.5
01/17/2020 12:00	7.1	13.8	5.9	94.8	3,131,292.0	1,669.2	0.9	0.5
01/17/2020 13:00	7.2	13.8	6.0	94.7	3,107,467.8	1,656.5	1.0	0.7
01/17/2020 14:00	7.2	13.8	6.0	93.4	3,062,820.8	1,632.7	1.0	0.7
01/17/2020 15:00	7.3	13.8	6.1	87.2	2,847,277.2	1,517.8	1.0	0.6
01/17/2020 16:00	8.4	13.4	6.6	110.3	3,357,093.8	2,010.2	1.0	0.8
01/17/2020 17:00	8.0	13.4	6.3	107.0	3,334,463.8	1,972.3	1.0	0.8
01/17/2020 18:00	8.2	13.4	6.5	107.3	3,388,811.8	1,979.7	1.0	0.8
01/17/2020 19:00	8.4	13.3	6.5	117.1	3,363,145.2	2,087.5	1.1	0.8
01/17/2020 20:00	8.3	13.3	6.4	119.7	3,370,854.0	2,116.9	1.1	0.8
01/17/2020 21:00	8.2	13.3	6.4	118.0	3,394,239.2	2,106.8	1.1	0.8
01/17/2020 22:00	8.2	13.3	6.4	116.2	3,361,050.8	2,086.2	1.1	0.8
01/17/2020 23:00	8.2	13.3	6.4	113.9	3,408,381.8	2,065.8	1.1	0.8
Average/Sum#:	7.9	13.5	6.3	108.7	3,315,332.4	1,957.5	1.0	0.8
Minimum:	6.8	13.1	5.7	87.2	2,847,277.2	1,517.8	0.9	0.5
Maximum:	8.6	13.8	6.6	133.2	3,450,949.4	2,248.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/18/2020 00:00	8.2	13.3	6.4	112.2	3,378,683.4	2,047.8	1.1	0.8
01/18/2020 01:00	8.2	13.3	6.4	113.5	3,398,812.3	2,060.0	1.1	0.8
01/18/2020 02:00	8.2	13.4	6.5	110.6	3,391,830.4	2,031.0	1.0	0.8
01/18/2020 03:00	8.2	13.4	6.5	110.8	3,396,172.5	2,033.6	1.0	0.8
01/18/2020 04:00	8.2	13.4	6.5	110.8	3,397,341.5	2,034.3	1.0	0.8
01/18/2020 05:00	8.1	13.4	6.4	110.7	3,396,339.5	2,033.7	1.0	0.8
01/18/2020 06:00	8.3	13.4	6.5	112.1	3,399,846.5	2,035.8	1.0	0.8
01/18/2020 07:00	8.3	13.4	6.5	111.0	3,393,667.4	2,032.1	1.0	0.8
01/18/2020 08:00	7.7	13.5	6.1	105.3	3,480,764.8	2,008.0	1.0	0.8
01/18/2020 09:00	6.9	13.8	5.7	94.6	3,161,682.0	1,685.4	0.9	0.5
01/18/2020 10:00	7.1	13.8	5.9	92.7	3,070,699.7	1,636.9	0.9	0.5
01/18/2020 11:00	7.2	13.8	6.0	91.7	3,032,806.0	1,616.7	0.9	0.5
01/18/2020 12:00	7.2	13.8	6.0	92.7	3,066,009.9	1,634.4	0.9	0.5
01/18/2020 13:00	7.2	13.8	6.0	94.1	3,121,162.0	1,663.8	0.9	0.5
01/18/2020 14:00	7.3	13.8	6.1	92.6	3,060,194.5	1,631.3	0.9	0.5
01/18/2020 15:00	7.4	13.8	6.1	91.9	3,023,238.8	1,611.6	0.9	0.5
01/18/2020 16:00	8.6	13.4	6.8	111.1	3,370,621.0	2,018.3	1.0	0.8
01/18/2020 17:00	8.4	13.3	6.5	113.0	3,368,454.0	2,041.6	1.1	0.8
01/18/2020 18:00	7.8	13.5	6.2	105.4	3,376,487.0	1,972.5	1.0	0.8
01/18/2020 19:00	8.5	13.3	6.6	115.0	3,359,002.4	2,060.4	1.1	0.8
01/18/2020 20:00	8.5	13.3	6.6	120.4	3,364,643.9	2,113.0	1.1	0.8
01/18/2020 21:00	8.4	13.3	6.5	121.0	3,373,561.0	2,118.6	1.1	0.8
01/18/2020 22:00	8.5	13.2	6.5	123.8	3,350,997.2	2,128.9	1.2	1.1
01/18/2020 23:00	8.5	13.3	6.6	122.1	3,356,204.4	2,107.7	1.2	1.1
Average/Sum#:	8.0	13.5	6.3	107.5	3,295,384.3	1,931.6	1.0	0.7
Minimum:	6.9	13.2	5.7	91.7	3,023,238.8	1,611.6	0.9	0.5
Maximum:	8.6	13.8	6.8	123.8	3,480,764.8	2,128.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/19/2020 00:00	8.1	13.4	6.4	115.2	3,303,573.3	2,026.4	1.1	0.8
01/19/2020 01:00	6.8	13.8	5.7	95.2	3,204,077.9	1,708.0	0.9	0.5
01/19/2020 02:00	7.0	13.8	5.8	88.1	2,925,690.8	1,559.6	0.9	0.5
01/19/2020 03:00	7.1	13.8	5.9	92.7	3,071,825.2	1,637.5	0.9	0.5
01/19/2020 04:00	7.1	13.8	5.9	92.7	3,057,755.8	1,630.0	0.9	0.5
01/19/2020 05:00	7.1	13.8	5.9	94.9	3,148,550.5	1,678.4	0.9	0.5
01/19/2020 06:00	7.2	13.8	6.0	95.8	3,188,882.9	1,699.9	0.9	0.5
01/19/2020 07:00	7.3	13.8	6.1	92.5	3,007,105.9	1,603.0	1.0	0.6
01/19/2020 08:00	7.2	13.8	6.0	89.5	2,933,569.7	1,563.8	1.0	0.6
01/19/2020 09:00	7.3	13.8	6.1	93.1	3,063,196.0	1,632.9	0.9	0.5
01/19/2020 10:00	7.3	13.8	6.1	89.9	2,957,956.7	1,576.8	0.9	0.5
01/19/2020 11:00	7.3	13.8	6.1	94.1	3,093,586.0	1,649.1	0.9	0.5
01/19/2020 12:00	7.3	13.8	6.1	95.0	3,129,791.3	1,668.4	0.9	0.5
01/19/2020 13:00	7.3	13.8	6.1	96.4	3,163,370.3	1,686.3	1.0	0.7
01/19/2020 14:00	7.3	13.8	6.1	91.3	2,993,411.6	1,595.7	1.0	0.6
01/19/2020 15:00	7.3	13.8	6.1	93.1	3,055,504.7	1,628.8	1.0	0.7
01/19/2020 16:00	7.6	13.8	6.3	93.2	3,044,624.3	1,623.0	1.0	0.6
01/19/2020 17:00	8.5	13.4	6.7	110.8	3,366,111.9	2,015.6	1.0	0.8
01/19/2020 18:00	8.4	13.3	6.5	113.5	3,338,624.0	2,047.9	1.1	0.8
01/19/2020 19:00	8.3	13.3	6.4	112.5	3,368,949.0	2,041.9	1.1	0.8
01/19/2020 20:00	8.3	13.2	6.4	118.3	3,347,924.1	2,102.5	1.1	0.8
01/19/2020 21:00	8.3	13.2	6.4	120.5	3,345,960.2	2,125.7	1.2	1.1
01/19/2020 22:00	8.3	13.2	6.4	119.8	3,336,988.2	2,120.0	1.2	1.1
01/19/2020 23:00	8.3	13.2	6.4	118.8	3,361,459.2	2,111.0	1.1	0.8
Average/Sum#:	7.6	13.6	6.2	100.7	3,158,687.1	1,780.5	1.0	0.7
Minimum:	6.8	13.2	5.7	88.1	2,925,690.8	1,559.6	0.9	0.5
Maximum:	8.5	13.8	6.7	120.5	3,368,949.0	2,125.7	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/20/2020 00:00	8.2	13.3	6.4	116.0	3,350,578.7	2,079.7	1.1	0.8
01/20/2020 01:00	8.1	13.3	6.3	112.5	3,374,228.7	2,045.1	1.1	0.8
01/20/2020 02:00	8.1	13.3	6.3	110.9	3,344,365.3	2,027.0	1.1	0.8
01/20/2020 03:00	8.2	13.3	6.4	111.7	3,354,264.8	2,033.0	1.1	0.8
01/20/2020 04:00	8.2	13.3	6.4	112.5	3,360,864.4	2,037.0	1.1	0.8
01/20/2020 05:00	8.2	13.3	6.4	113.6	3,339,113.1	2,048.2	1.1	0.8
01/20/2020 06:00	8.4	13.3	6.5	114.3	3,349,546.8	2,054.6	1.1	0.8
01/20/2020 07:00	8.5	13.2	6.5	120.5	3,362,096.1	2,111.4	1.1	0.8
01/20/2020 08:00	8.4	13.2	6.4	121.8	3,350,367.6	2,128.5	1.2	1.1
01/20/2020 09:00	8.3	13.2	6.4	120.3	3,319,201.4	2,108.7	1.2	1.1
01/20/2020 10:00	8.3	13.2	6.4	121.5	3,343,599.2	2,124.2	1.2	1.1
01/20/2020 11:00	8.3	13.2	6.4	120.0	3,311,331.1	2,103.7	1.2	1.1
01/20/2020 12:00	8.3	13.2	6.4	122.4	3,295,644.3	2,117.8	1.2	1.1
01/20/2020 13:00	8.3	13.2	6.4	121.5	3,324,868.0	2,112.3	1.2	1.1
01/20/2020 14:00	8.3	13.2	6.4	123.9	3,316,341.3	2,131.1	1.2	1.1
01/20/2020 15:00	8.3	13.2	6.4	120.9	3,307,238.6	2,101.1	1.2	1.1
01/20/2020 16:00	8.3	13.3	6.4	116.6	3,327,862.4	2,065.6	1.1	0.8
01/20/2020 17:00	8.3	13.2	6.4	121.7	3,324,238.3	2,111.9	1.2	1.1
01/20/2020 18:00	8.3	13.2	6.4	121.4	3,327,229.0	2,113.8	1.2	1.1
01/20/2020 19:00	8.3	13.2	6.4	121.1	3,321,090.2	2,109.9	1.2	1.1
01/20/2020 20:00	8.3	13.2	6.4	120.6	3,320,618.0	2,109.6	1.2	1.1
01/20/2020 21:00	8.3	13.2	6.4	119.8	3,350,631.1	2,104.2	1.1	0.8
01/20/2020 22:00	8.2	13.2	6.3	118.5	3,328,815.9	2,090.5	1.1	0.8
01/20/2020 23:00	8.2	13.3	6.4	115.5	3,327,217.9	2,065.2	1.1	0.8
Average/Sum#:	8.3	13.2	6.4	118.3	3,334,639.7	2,088.9	1.2	1.0
Minimum:	8.1	13.2	6.3	110.9	3,295,644.3	2,027.0	1.1	0.8
Maximum:	8.5	13.3	6.5	123.9	3,374,228.7	2,131.1	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/21/2020 00:00	8.2	13.3	6.4	112.8	3,325,581.9	2,039.9	1.1	0.8
01/21/2020 01:00	8.2	13.3	6.4	112.3	3,354,099.8	2,032.9	1.1	0.8
01/21/2020 02:00	8.2	13.3	6.4	112.5	3,362,349.3	2,037.9	1.1	0.8
01/21/2020 03:00	8.2	13.3	6.4	112.9	3,325,418.9	2,039.8	1.1	0.8
01/21/2020 04:00	8.3	13.3	6.4	112.8	3,319,386.9	2,036.1	1.1	0.8
01/21/2020 05:00	8.3	13.3	6.4	112.9	3,320,854.1	2,037.0	1.1	0.8
01/21/2020 06:00	8.4	13.3	6.5	113.0	3,316,646.9	2,010.2	1.1	0.8
01/21/2020 07:00	8.7	13.2	6.7	119.1	3,320,058.0	2,085.0	1.1	0.8
01/21/2020 08:00	8.4	13.3	6.5	115.4	3,347,101.4	2,053.1	1.1	0.8
01/21/2020 09:00	8.0	13.4	6.3	108.6	3,311,168.0	1,982.7	1.0	0.8
01/21/2020 10:00	7.1	13.8	5.9	95.4	3,111,554.3	1,681.4	1.0	0.7
01/21/2020 11:00	7.3	13.8	6.1	96.5	3,175,563.8	1,692.8	1.0	0.7
01/21/2020 12:00	7.4	13.8	6.1	95.2	3,112,345.2	1,659.1	1.0	0.7
01/21/2020 13:00	7.4	13.8	6.1	93.7	3,059,256.6	1,630.8	1.0	0.7
01/21/2020 14:00	7.5	13.8	6.2	94.3	3,077,077.8	1,640.3	1.0	0.7
01/21/2020 15:00	7.7	13.8	6.4	90.1	2,933,382.1	1,563.7	1.0	0.6
01/21/2020 16:00	8.7	13.3	6.8	113.8	3,316,289.4	2,034.2	1.1	0.8
01/21/2020 17:00	8.5	13.2	6.5	115.6	3,312,718.1	2,056.2	1.1	0.8
01/21/2020 18:00	8.4	13.2	6.4	114.3	3,299,829.4	2,048.2	1.1	0.8
01/21/2020 19:00	8.3	13.2	6.4	113.9	3,294,351.7	2,044.8	1.1	0.8
01/21/2020 20:00	8.3	13.3	6.4	113.1	3,286,457.4	2,039.9	1.1	0.8
01/21/2020 21:00	8.2	13.3	6.4	112.3	3,316,289.4	2,034.2	1.1	0.8
01/21/2020 22:00	8.3	13.2	6.4	115.8	3,296,809.6	2,070.4	1.1	0.8
01/21/2020 23:00	8.2	13.3	6.4	113.1	3,333,570.2	2,044.8	1.1	0.8
Average/Sum#:	8.1	13.4	6.4	108.7	3,259,506.7	1,941.5	1.1	0.8
Minimum:	7.1	13.2	5.9	90.1	2,933,382.1	1,563.7	1.0	0.6
Maximum:	8.7	13.8	6.8	119.1	3,362,349.3	2,085.0	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/22/2020 00:00	7.6	13.5	6.1	102.0	3,191,972.2	1,841.4	1.0	0.7
01/22/2020 01:00	7.5	13.9	6.3	79.4	2,457,085.0	1,309.8	1.0	0.5
01/22/2020 02:00	7.4	13.8	6.1	78.8	2,591,213.6	1,381.3	0.9	0.4
01/22/2020 03:00	7.5	13.8	6.2	79.1	2,524,430.7	1,345.7	1.0	0.5
01/22/2020 04:00	7.4	13.8	6.1	87.1	2,865,473.6	1,527.5	0.9	0.5
01/22/2020 05:00	7.5	13.8	6.2	84.1	2,744,476.5	1,463.0	1.0	0.6
01/22/2020 06:00	7.5	13.8	6.2	89.2	2,994,724.8	1,596.4	0.9	0.5
01/22/2020 07:00	7.6	13.8	6.3	95.3	3,088,521.0	1,646.4	1.0	0.7
01/22/2020 08:00	7.6	13.8	6.3	87.0	2,801,692.2	1,493.5	1.0	0.6
01/22/2020 09:00	7.5	13.8	6.2	91.3	2,992,098.5	1,595.0	1.0	0.6
01/22/2020 10:00	7.4	13.8	6.1	93.2	3,047,438.2	1,624.5	1.0	0.6
01/22/2020 11:00	7.4	13.8	6.1	96.9	3,198,637.7	1,705.1	0.9	0.5
01/22/2020 12:00	7.4	13.8	6.1	97.2	3,208,392.5	1,710.3	0.9	0.5
01/22/2020 13:00	7.4	13.8	6.1	95.2	3,132,230.0	1,669.7	0.9	0.5
01/22/2020 14:00	7.4	13.8	6.1	93.5	3,078,015.8	1,640.8	0.9	0.5
01/22/2020 15:00	7.6	13.8	6.3	92.3	3,016,673.1	1,608.1	1.0	0.6
01/22/2020 16:00	8.8	13.3	6.8	113.4	3,354,099.8	2,032.9	1.1	0.8
01/22/2020 17:00	8.4	13.3	6.5	111.4	3,329,351.2	2,017.9	1.1	0.8
01/22/2020 18:00	8.5	13.2	6.5	120.8	3,339,191.8	2,121.4	1.2	1.1
01/22/2020 19:00	8.3	13.2	6.4	119.8	3,327,701.3	2,114.1	1.2	1.1
01/22/2020 20:00	8.2	13.3	6.4	112.5	3,339,928.3	2,048.7	1.1	0.8
01/22/2020 21:00	8.2	13.3	6.4	111.8	3,367,134.1	2,040.8	1.1	0.8
01/22/2020 22:00	8.2	13.3	6.4	112.2	3,335,363.5	2,045.9	1.1	0.8
01/22/2020 23:00	7.8	13.4	6.1	104.6	3,370,838.1	1,969.2	1.0	0.8
Average/Sum#:	7.8	13.6	6.3	97.8	3,070,695.1	1,731.2	1.0	0.7
Minimum:	7.4	13.2	6.1	78.8	2,457,085.0	1,309.8	0.9	0.4
Maximum:	8.8	13.9	6.8	120.8	3,370,838.1	2,121.4	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/23/2020 00:00	8.4	13.2	6.4	117.5	3,373,456.1	2,093.9	1.1	0.8
01/23/2020 01:00	8.3	13.2	6.4	117.5	3,332,319.1	2,092.7	1.1	0.8
01/23/2020 02:00	8.2	13.3	6.4	112.4	3,333,733.2	2,044.9	1.1	0.8
01/23/2020 03:00	8.2	13.3	6.4	111.9	3,370,433.9	2,042.8	1.1	0.8
01/23/2020 04:00	8.3	13.2	6.4	119.0	3,356,045.2	2,107.6	1.1	0.8
01/23/2020 05:00	8.1	13.3	6.3	113.0	3,387,263.0	2,053.0	1.1	0.8
01/23/2020 06:00	8.4	13.2	6.4	122.2	3,359,811.9	2,134.5	1.2	1.1
01/23/2020 07:00	8.4	13.2	6.4	118.2	3,379,900.5	2,097.9	1.1	0.8
01/23/2020 08:00	7.6	13.5	6.1	104.4	3,339,341.4	1,950.8	1.0	0.8
01/23/2020 09:00	6.9	13.8	5.7	94.1	3,157,930.1	1,683.4	0.9	0.5
01/23/2020 10:00	7.1	13.8	5.9	88.2	2,924,940.4	1,559.2	0.9	0.5
01/23/2020 11:00	7.2	13.8	6.0	91.1	3,030,930.1	1,615.7	0.9	0.5
01/23/2020 12:00	7.2	13.8	6.0	93.5	3,080,266.9	1,642.0	0.9	0.5
01/23/2020 13:00	7.3	13.8	6.1	95.0	3,137,857.8	1,672.7	0.9	0.5
01/23/2020 14:00	7.3	13.8	6.1	94.5	3,119,098.5	1,662.7	0.9	0.5
01/23/2020 15:00	7.3	13.8	6.1	92.9	3,060,194.5	1,631.3	0.9	0.5
01/23/2020 16:00	7.5	13.8	6.2	87.3	2,824,766.1	1,505.8	1.0	0.6
01/23/2020 17:00	8.4	13.4	6.6	108.9	3,299,799.2	1,927.7	1.0	0.8
01/23/2020 18:00	8.5	13.2	6.5	121.3	3,304,981.3	2,123.8	1.2	1.1
01/23/2020 19:00	8.4	13.2	6.4	120.3	3,298,601.0	2,119.7	1.2	1.1
01/23/2020 20:00	8.3	13.2	6.4	119.7	3,331,006.8	2,116.2	1.2	1.1
01/23/2020 21:00	8.2	13.2	6.3	118.1	3,308,812.6	2,102.1	1.1	0.8
01/23/2020 22:00	8.1	13.3	6.3	114.3	3,329,151.2	2,066.4	1.1	0.8
01/23/2020 23:00	7.5	13.5	6.0	103.3	3,347,557.9	1,955.6	1.0	0.8
Average/Sum#:	7.9	13.5	6.2	107.4	3,241,174.9	1,916.8	1.0	0.8
Minimum:	6.9	13.2	5.7	87.3	2,824,766.1	1,505.8	0.9	0.5
Maximum:	8.5	13.8	6.6	122.2	3,387,263.0	2,134.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/24/2020 00:00	7.6	13.5	6.1	102.4	3,315,547.6	1,936.9	1.0	0.8
01/24/2020 01:00	7.0	13.8	5.8	92.8	3,089,271.3	1,646.8	0.9	0.5
01/24/2020 02:00	7.1	13.8	5.9	93.9	3,124,351.1	1,665.5	0.9	0.5
01/24/2020 03:00	7.2	13.8	6.0	95.9	3,187,944.9	1,699.4	0.9	0.5
01/24/2020 04:00	7.2	13.8	6.0	96.4	3,192,447.1	1,701.8	0.9	0.5
01/24/2020 05:00	7.3	13.8	6.1	91.4	3,002,040.9	1,600.3	0.9	0.5
01/24/2020 06:00	7.4	13.8	6.1	92.3	3,109,906.5	1,657.8	0.9	0.5
01/24/2020 07:00	7.4	13.8	6.1	94.9	3,103,715.9	1,654.5	1.0	0.7
01/24/2020 08:00	7.4	13.8	6.1	91.6	2,996,413.1	1,597.3	1.0	0.6
01/24/2020 09:00	7.3	13.8	6.1	95.1	3,132,042.4	1,669.6	0.9	0.5
01/24/2020 10:00	7.4	13.8	6.1	85.0	2,781,807.4	1,482.9	1.0	0.6
01/24/2020 11:00	7.3	13.8	6.1	94.4	3,123,413.1	1,665.0	0.9	0.5
01/24/2020 12:00	7.3	13.8	6.1	93.6	3,074,826.7	1,639.1	1.0	0.7
01/24/2020 13:00	7.3	13.8	6.1	95.6	3,154,741.1	1,681.7	0.9	0.5
01/24/2020 14:00	7.3	13.8	6.1	94.3	3,101,277.2	1,653.2	0.9	0.5
01/24/2020 15:00	7.3	13.8	6.1	89.1	2,921,376.2	1,557.3	1.0	0.6
01/24/2020 16:00	7.6	13.8	6.3	90.8	2,981,405.7	1,589.3	0.9	0.5
01/24/2020 17:00	8.7	13.3	6.8	113.0	3,308,301.1	2,029.3	1.1	0.8
01/24/2020 18:00	8.5	13.2	6.5	120.8	3,330,062.3	2,115.6	1.2	1.1
01/24/2020 19:00	8.3	13.2	6.4	119.9	3,324,395.7	2,112.0	1.2	1.1
01/24/2020 20:00	8.3	13.2	6.4	119.1	3,312,433.0	2,104.4	1.2	1.1
01/24/2020 21:00	8.2	13.2	6.3	116.5	3,308,433.8	2,077.7	1.1	0.8
01/24/2020 22:00	8.1	13.3	6.3	113.5	3,339,113.1	2,048.2	1.1	0.8
01/24/2020 23:00	14.4	14.6	13.5	136.9	2,501,547.1	1,278.7	1.7	0.9
Average/Sum#:	7.9	13.7	6.5	101.2	3,117,367.3	1,744.3	1.0	0.7
Minimum:	7.0	13.2	5.8	85.0	2,501,547.1	1,278.7	0.9	0.5
Maximum:	14.4	14.6	13.5	136.9	3,339,113.1	2,115.6	1.7	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/27/2020 18:00	31.1	17.4	52.4	0.0	1,811,444.1	476.2	-0.1	0.0
01/27/2020 19:00	32.7	17.1	50.8	233.9	1,785,929.8	534.7	3.9	0.8
01/27/2020 20:00	34.8	15.5	38.0	248.0	2,157,577.0	882.3	3.5	1.1
01/27/2020 21:00	6.9	13.8	5.7	84.5	2,689,324.4	1,433.6	1.0	0.6
01/27/2020 22:00	7.3	13.8	6.1	78.5	2,600,955.3	1,367.5	0.9	0.4
01/27/2020 23:00	7.4	13.9	6.2	78.8	2,605,900.5	1,370.1	0.9	0.4
Average/Sum#:	20.0	15.3	26.5	120.6	2,275,188.5	1,010.7	1.7	0.6
Minimum:	6.9	13.8	5.7	0.0	1,785,929.8	476.2	-0.1	0.0
Maximum:	34.8	17.4	52.4	248.0	2,689,324.4	1,433.6	3.9	1.1
%SI	75.00	75.00	75.00	75.00	75.00	75.00	75.00	75.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/28/2020 00:00	7.5	13.8	6.2	78.8	2,600,574.9	1,367.3	0.9	0.4
01/28/2020 01:00	7.6	13.8	6.3	79.0	2,556,321.4	1,362.7	1.0	0.5
01/28/2020 02:00	7.6	13.8	6.3	79.0	2,555,195.8	1,362.1	1.0	0.5
01/28/2020 03:00	7.4	13.8	6.1	92.1	3,066,197.5	1,634.5	0.9	0.5
01/28/2020 04:00	7.5	13.8	6.2	86.7	2,804,693.7	1,495.1	1.0	0.6
01/28/2020 05:00	7.4	13.8	6.1	90.6	3,005,980.3	1,602.4	0.9	0.5
01/28/2020 06:00	7.4	13.8	6.1	93.8	3,195,448.6	1,703.4	0.9	0.5
01/28/2020 07:00	7.5	13.8	6.2	92.4	3,023,426.4	1,611.7	1.0	0.6
01/28/2020 08:00	7.4	13.8	6.1	94.9	3,138,045.4	1,672.8	0.9	0.5
01/28/2020 09:00	7.4	13.8	6.1	96.0	3,164,871.1	1,687.1	0.9	0.5
01/28/2020 10:00	7.5	13.8	6.2	88.4	2,886,859.2	1,538.9	1.0	0.6
01/28/2020 11:00	7.4	13.8	6.1	92.4	3,040,872.5	1,621.0	0.9	0.5
01/28/2020 12:00	7.4	13.8	6.1	91.9	3,026,240.3	1,613.2	0.9	0.5
01/28/2020 13:00	7.5	13.8	6.2	95.3	3,135,606.7	1,671.5	0.9	0.5
01/28/2020 14:00	7.4	13.8	6.1	90.3	2,964,710.0	1,580.4	1.0	0.6
01/28/2020 15:00	7.4	13.8	6.1	89.6	2,945,012.8	1,569.9	0.9	0.5
01/28/2020 16:00	7.7	13.8	6.4	90.2	2,952,516.5	1,573.9	0.9	0.5
01/28/2020 17:00	8.6	13.3	6.7	112.0	3,339,745.6	2,024.2	1.1	0.8
01/28/2020 18:00	8.5	13.3	6.6	115.8	3,329,634.6	2,066.7	1.1	0.8
01/28/2020 19:00	8.4	13.2	6.4	117.3	3,322,128.0	2,086.3	1.1	0.8
01/28/2020 20:00	8.4	13.2	6.4	119.9	3,326,284.6	2,113.2	1.2	1.1
01/28/2020 21:00	8.3	13.2	6.4	119.9	3,325,497.6	2,112.7	1.2	1.1
01/28/2020 22:00	14.1	14.6	13.2	136.8	2,523,849.1	1,290.1	1.7	0.9
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.0	13.7	6.5	97.5	3,009,987.5	1,667.9	1.0	0.6
Minimum:	7.4	13.2	6.1	78.8	2,523,849.1	1,290.1	0.9	0.4
Maximum:	14.1	14.6	13.2	136.8	3,339,745.6	2,113.2	1.7	1.1
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
01/29/2020 17:00	35.9	17.5	62.3	20.4	1,751,722.0	460.5	0.1	0.0
01/29/2020 18:00	45.4	16.1	55.8	257.9	1,799,971.4	657.2	4.3	1.1
01/29/2020 19:00	24.7	14.4	22.4	185.4	2,712,277.8	1,327.0	2.1	1.1
01/29/2020 20:00	7.9	13.6	6.4	108.8	3,212,080.2	1,853.0	1.1	0.7
01/29/2020 21:00	9.0	13.2	6.9	141.7	3,247,642.6	2,158.1	1.4	1.1
01/29/2020 22:00	7.9	13.7	6.5	99.3	2,941,559.6	1,632.5	1.1	0.7
01/29/2020 23:00	7.2	13.9	6.1	86.6	2,906,983.7	1,528.4	0.9	0.5
Average/Sum#:	19.7	14.6	23.8	128.6	2,653,176.8	1,373.8	1.6	0.7
Minimum:	7.2	13.2	6.1	20.4	1,751,722.0	460.5	0.1	0.0
Maximum:	45.4	17.5	62.3	257.9	3,247,642.6	2,158.1	4.3	1.1
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/30/2020 00:00	7.1	13.8	5.9	87.6	2,912,184.1	1,552.4	0.9	0.5
01/30/2020 01:00	7.2	13.8	6.0	88.4	2,919,125.0	1,556.1	0.9	0.5
01/30/2020 02:00	7.4	13.8	6.1	95.9	3,174,063.1	1,692.0	0.9	0.5
01/30/2020 03:00	7.4	13.8	6.1	85.7	2,762,297.8	1,472.5	1.0	0.6
01/30/2020 04:00	7.3	13.8	6.1	93.1	3,081,392.5	1,642.6	0.9	0.5
01/30/2020 05:00	7.6	13.8	6.3	81.7	2,609,972.8	1,391.3	1.0	0.6
01/30/2020 06:00	8.0	13.6	6.5	103.2	3,183,055.8	1,859.5	1.0	0.7
01/30/2020 07:00	8.6	13.3	6.7	117.6	3,368,945.1	2,091.1	1.1	0.8
01/30/2020 08:00	7.7	13.5	6.1	104.0	3,332,494.2	1,946.8	1.0	0.8
01/30/2020 09:00	7.0	13.8	5.8	92.6	3,068,261.0	1,635.6	0.9	0.5
01/30/2020 10:00	7.2	13.8	6.0	92.8	3,082,330.4	1,643.1	0.9	0.5
01/30/2020 11:00	7.4	13.8	6.1	96.9	3,178,377.7	1,694.3	1.0	0.7
01/30/2020 12:00	7.2	13.8	6.0	85.7	2,813,510.5	1,499.8	1.0	0.6
01/30/2020 13:00	7.4	13.8	6.1	94.4	3,108,968.5	1,657.3	0.9	0.5
01/30/2020 14:00	7.2	13.8	6.0	88.9	2,916,498.8	1,554.7	1.0	0.6
01/30/2020 15:00	7.3	13.8	6.1	93.2	3,064,884.3	1,633.8	0.9	0.5
01/30/2020 16:00	7.6	13.8	6.3	88.7	2,844,650.9	1,516.4	1.0	0.6
01/30/2020 17:00	7.2	13.8	6.0	93.6	3,080,829.7	1,642.3	1.0	0.7
01/30/2020 18:00	7.5	13.8	6.2	98.0	3,223,775.1	1,718.5	0.9	0.5
01/30/2020 19:00	8.7	13.3	6.8	114.2	3,263,741.1	2,025.8	1.1	0.8
01/30/2020 20:00	8.7	13.2	6.7	124.7	3,257,383.6	2,117.0	1.2	1.1
01/30/2020 21:00	8.5	13.2	6.5	124.9	3,268,567.0	2,100.4	1.2	1.1
01/30/2020 22:00	8.3	13.3	6.4	117.8	3,270,376.5	2,053.8	1.2	1.0
01/30/2020 23:00	7.4	13.6	6.0	100.5	3,122,465.4	1,755.7	1.0	0.7
Average/Sum#:	7.6	13.7	6.2	98.5	3,079,506.3	1,727.2	1.0	0.7
Minimum:	7.0	13.2	5.8	81.7	2,609,972.8	1,391.3	0.9	0.5
Maximum:	8.7	13.8	6.8	124.9	3,368,945.1	2,117.0	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
01/31/2020 00:00	7.3	13.9	6.2	83.1	2,714,123.0	1,427.0	1.0	0.6
01/31/2020 01:00	7.4	13.9	6.2	79.1	2,639,375.3	1,387.7	0.9	0.4
01/31/2020 02:00	7.3	13.8	6.1	78.8	2,635,190.9	1,385.5	0.9	0.4
01/31/2020 03:00	7.4	13.8	6.1	79.4	2,619,915.2	1,396.6	0.9	0.4
01/31/2020 04:00	7.3	13.8	6.1	82.6	2,744,476.5	1,463.0	0.9	0.4
01/31/2020 05:00	7.3	13.8	6.1	96.7	3,195,823.8	1,703.6	0.9	0.5
01/31/2020 06:00	7.5	13.8	6.2	87.9	2,904,305.2	1,548.2	0.9	0.5
01/31/2020 07:00	7.4	13.8	6.1	92.1	3,001,102.9	1,599.8	1.0	0.6
01/31/2020 08:00	7.2	13.8	6.0	87.0	2,875,416.0	1,532.8	0.9	0.5
01/31/2020 09:00	7.2	13.8	6.0	91.7	3,058,506.2	1,630.4	0.9	0.5
01/31/2020 10:00	7.2	13.8	6.0	93.2	3,083,643.6	1,643.8	0.9	0.5
01/31/2020 11:00	7.3	13.8	6.1	93.3	3,096,024.7	1,650.4	0.9	0.5
01/31/2020 12:00	7.3	13.8	6.1	92.3	3,045,374.7	1,623.4	0.9	0.5
01/31/2020 13:00	7.5	13.8	6.2	96.7	3,184,943.5	1,697.8	0.9	0.5
01/31/2020 14:00	7.6	13.8	6.3	96.8	3,162,057.2	1,685.6	1.0	0.7
01/31/2020 15:00	7.6	13.8	6.3	95.4	3,133,543.1	1,670.4	0.9	0.5
01/31/2020 16:00	7.7	13.9	6.5	87.1	2,831,475.1	1,488.7	1.0	0.6
01/31/2020 17:00	7.4	13.8	6.1	95.6	3,151,176.8	1,679.8	0.9	0.5
01/31/2020 18:00	8.2	13.6	6.6	104.8	3,210,949.0	1,828.9	1.0	0.7
01/31/2020 19:00	8.4	13.3	6.5	112.0	3,284,662.2	2,014.8	1.1	0.8
01/31/2020 20:00	8.5	13.2	6.5	119.4	3,302,673.8	2,098.2	1.2	1.0
01/31/2020 21:00	8.3	13.2	6.4	119.0	3,304,405.3	2,099.3	1.2	1.0
01/31/2020 22:00	8.2	13.2	6.3	117.7	3,293,544.3	2,092.4	1.1	0.8
01/31/2020 23:00	14.1	14.6	13.2	134.8	2,533,832.0	1,276.7	1.7	0.9
Average/Sum#:	7.9	13.7	6.5	96.5	3,000,272.5	1,651.0	1.0	0.6
Minimum:	7.2	13.2	6.0	78.8	2,533,832.0	1,276.7	0.9	0.4
Maximum:	14.1	14.6	13.2	134.8	3,304,405.3	2,099.3	1.7	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/02/2020 23:00	35.4	17.4	59.7	1.2	1,816,389.3	477.5	-0.1	0.0
Average/Sum#:	35.4	17.4	59.7	1.2	1,816,389.3	477.5	-0.1	0.0
Minimum:	35.4	17.4	59.7	1.2	1,816,389.3	477.5	-0.1	0.0
Maximum:	35.4	17.4	59.7	1.2	1,816,389.3	477.5	-0.1	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/03/2020 00:00	34.9	17.2	55.7	249.3	1,809,009.6	528.4	4.0	0.8
02/03/2020 01:00	44.4	16.1	54.6	267.9	1,959,372.4	715.4	4.1	1.1
02/03/2020 02:00	6.7	13.8	5.6	100.2	2,743,413.5	1,442.4	1.2	0.7
02/03/2020 03:00	7.0	13.8	5.8	80.8	2,786,398.2	1,465.0	0.9	0.4
02/03/2020 04:00	7.3	13.8	6.1	94.1	3,204,640.7	1,708.3	0.9	0.5
02/03/2020 05:00	7.3	13.8	6.1	88.3	2,966,135.2	1,559.5	0.9	0.5
02/03/2020 06:00	7.3	13.8	6.1	98.4	3,208,580.1	1,710.4	1.0	0.7
02/03/2020 07:00	7.3	13.8	6.1	93.1	3,043,686.4	1,622.5	1.0	0.6
02/03/2020 08:00	7.2	13.9	6.1	88.3	2,953,582.1	1,552.9	0.9	0.5
02/03/2020 09:00	7.3	13.9	6.2	84.4	2,821,965.2	1,483.7	0.9	0.4
02/03/2020 10:00	7.2	13.9	6.1	89.1	2,979,829.4	1,566.7	0.9	0.5
02/03/2020 11:00	7.4	13.8	6.1	96.9	3,235,835.7	1,701.3	0.9	0.5
02/03/2020 12:00	7.3	13.8	6.1	94.8	3,166,033.1	1,664.6	0.9	0.5
02/03/2020 13:00	7.3	13.9	6.2	94.0	3,141,307.4	1,651.6	0.9	0.5
02/03/2020 14:00	7.3	13.9	6.2	89.5	2,996,566.8	1,575.5	0.9	0.5
02/03/2020 15:00	7.3	13.9	6.2	94.6	3,169,076.3	1,666.2	0.9	0.5
02/03/2020 16:00	7.4	13.8	6.1	90.9	3,030,612.2	1,593.4	0.9	0.5
02/03/2020 17:00	8.8	13.4	6.9	115.5	3,397,492.4	2,059.2	1.1	0.8
02/03/2020 18:00	8.9	13.2	6.8	137.7	3,373,044.4	2,216.8	1.3	1.1
02/03/2020 19:00	8.9	13.1	6.7	145.5	3,378,866.6	2,245.3	1.4	1.1
02/03/2020 20:00	8.7	13.1	6.6	143.0	3,383,230.7	2,248.2	1.4	1.1
02/03/2020 21:00	8.5	13.3	6.6	124.6	3,406,682.0	2,139.4	1.2	1.1
02/03/2020 22:00	8.5	13.3	6.6	123.0	3,388,051.5	2,127.7	1.2	1.1
02/03/2020 23:00	8.5	13.3	6.6	119.2	3,418,996.2	2,097.2	1.1	0.8
Average/Sum#:	10.4	13.9	10.3	116.8	3,040,100.3	1,680.9	1.3	0.7
Minimum:	6.7	13.1	5.6	80.8	1,809,009.6	528.4	0.9	0.4
Maximum:	44.4	17.2	55.7	267.9	3,418,996.2	2,248.2	4.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/04/2020 00:00	8.4	13.3	6.5	116.4	3,410,361.7	2,067.0	1.1	0.8
02/04/2020 01:00	8.4	13.4	6.6	113.4	3,413,039.8	2,043.7	1.1	0.8
02/04/2020 02:00	8.4	13.4	6.6	113.7	3,419,719.9	2,047.7	1.1	0.8
02/04/2020 03:00	8.4	13.4	6.6	113.3	3,410,701.7	2,042.3	1.1	0.8
02/04/2020 04:00	8.4	13.4	6.6	116.2	3,409,536.7	2,066.5	1.1	0.8
02/04/2020 05:00	8.5	13.3	6.6	120.4	3,422,256.7	2,099.2	1.1	0.8
02/04/2020 06:00	8.8	13.3	6.8	132.0	3,377,441.3	2,145.7	1.3	1.1
02/04/2020 07:00	8.8	13.2	6.7	127.8	3,406,561.2	2,164.2	1.2	1.1
02/04/2020 08:00	8.2	13.4	6.5	116.2	3,367,629.0	2,041.1	1.1	0.8
02/04/2020 09:00	7.0	13.8	5.8	98.8	3,355,470.1	1,764.2	0.9	0.5
02/04/2020 10:00	7.2	13.8	6.0	99.5	3,356,040.7	1,764.5	0.9	0.5
02/04/2020 11:00	7.3	13.8	6.1	99.5	3,355,279.9	1,764.1	0.9	0.5
02/04/2020 12:00	7.2	13.8	6.0	99.5	3,356,230.9	1,764.6	0.9	0.5
02/04/2020 13:00	7.2	13.8	6.0	99.4	3,356,991.7	1,765.0	0.9	0.5
02/04/2020 14:00	7.2	13.9	6.1	99.4	3,358,132.9	1,765.6	0.9	0.5
02/04/2020 15:00	7.2	13.9	6.1	99.3	3,358,323.1	1,765.7	0.9	0.5
02/04/2020 16:00	8.0	13.6	6.5	104.1	3,309,862.7	1,836.9	1.0	0.7
02/04/2020 17:00	8.4	13.4	6.6	112.9	3,376,899.1	1,997.4	1.1	0.8
02/04/2020 18:00	8.7	13.3	6.8	122.9	3,374,357.2	2,119.1	1.2	1.1
02/04/2020 19:00	8.8	13.2	6.7	136.9	3,357,243.9	2,181.9	1.3	1.1
02/04/2020 20:00	8.7	13.2	6.7	132.9	3,372,518.8	2,167.2	1.3	1.1
02/04/2020 21:00	8.8	13.1	6.7	143.6	3,385,977.9	2,225.3	1.4	1.1
02/04/2020 22:00	8.5	13.3	6.6	123.3	3,356,682.1	2,108.0	1.2	1.1
02/04/2020 23:00	8.5	13.3	6.6	121.9	3,365,400.7	2,088.9	1.2	1.0
Average/Sum#:	8.1	13.5	6.5	115.1	3,376,360.8	1,991.5	1.1	0.8
Minimum:	7.0	13.1	5.8	98.8	3,309,862.7	1,764.1	0.9	0.5
Maximum:	8.8	13.9	6.8	143.6	3,422,256.7	2,225.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/05/2020 00:00	8.5	13.3	6.6	124.9	3,358,274.4	2,109.0	1.2	1.1
02/05/2020 01:00	8.4	13.3	6.5	119.7	3,388,999.3	2,078.8	1.1	0.8
02/05/2020 02:00	8.4	13.3	6.5	116.0	3,377,693.5	2,047.2	1.1	0.8
02/05/2020 03:00	8.4	13.3	6.5	115.7	3,376,538.6	2,046.5	1.1	0.8
02/05/2020 04:00	8.5	13.3	6.6	118.5	3,371,066.4	2,067.8	1.1	0.8
02/05/2020 05:00	8.0	13.4	6.3	109.0	3,375,377.5	1,996.5	1.0	0.8
02/05/2020 06:00	8.3	13.4	6.5	117.9	3,365,777.9	2,015.4	1.1	0.8
02/05/2020 07:00	8.9	13.2	6.8	132.9	3,362,783.1	2,185.5	1.3	1.1
02/05/2020 08:00	8.4	13.3	6.5	117.2	3,370,414.3	2,067.4	1.1	0.8
02/05/2020 09:00	7.6	13.5	6.1	105.9	3,348,927.3	1,956.4	1.0	0.8
02/05/2020 10:00	7.0	13.8	5.8	91.3	3,035,057.1	1,617.9	0.9	0.5
02/05/2020 11:00	7.1	13.8	5.9	91.4	3,044,624.3	1,623.0	0.9	0.5
02/05/2020 12:00	7.4	13.8	6.1	94.9	3,135,231.5	1,671.3	0.9	0.5
02/05/2020 13:00	7.4	13.8	6.1	95.3	3,136,169.4	1,671.8	0.9	0.5
02/05/2020 14:00	7.3	13.8	6.1	91.5	3,038,600.5	1,597.6	0.9	0.5
02/05/2020 15:00	7.4	13.8	6.1	96.0	3,160,931.6	1,685.0	0.9	0.5
02/05/2020 16:00	8.1	13.6	6.5	104.4	3,267,233.2	1,837.1	1.0	0.7
02/05/2020 17:00	8.5	13.4	6.7	108.7	3,336,492.6	1,973.5	1.0	0.8
02/05/2020 18:00	8.7	13.1	6.6	132.2	3,336,625.6	2,168.5	1.3	1.1
02/05/2020 19:00	8.4	13.2	6.4	123.0	3,298,445.4	2,119.6	1.2	1.1
02/05/2020 20:00	8.4	13.2	6.4	128.7	3,337,349.5	2,144.6	1.2	1.1
02/05/2020 21:00	8.3	13.2	6.4	119.3	3,347,764.9	2,102.4	1.1	0.8
02/05/2020 22:00	8.4	13.2	6.4	121.8	3,328,330.9	2,114.5	1.2	1.1
02/05/2020 23:00	8.3	13.3	6.4	116.0	3,313,845.9	2,056.9	1.1	0.8
Average/Sum#:	8.1	13.4	6.4	112.2	3,283,856.4	1,956.4	1.1	0.8
Minimum:	7.0	13.1	5.8	91.3	3,035,057.1	1,597.6	0.9	0.5
Maximum:	8.9	13.8	6.8	132.9	3,388,999.3	2,185.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/06/2020 00:00	8.2	13.3	6.4	112.0	3,343,375.4	2,026.4	1.1	0.8
02/06/2020 01:00	8.2	13.4	6.5	109.7	3,353,419.7	2,008.0	1.0	0.8
02/06/2020 02:00	8.2	13.4	6.5	109.3	3,393,129.3	2,007.0	1.0	0.8
02/06/2020 03:00	8.3	13.3	6.4	111.6	3,386,987.3	2,028.1	1.0	0.8
02/06/2020 04:00	8.3	13.4	6.5	110.5	3,370,788.0	2,018.4	1.0	0.8
02/06/2020 05:00	8.3	13.3	6.4	112.6	3,411,202.7	2,042.6	1.1	0.8
02/06/2020 06:00	8.5	13.3	6.6	120.7	3,297,605.8	2,070.9	1.2	1.0
02/06/2020 07:00	8.6	13.3	6.7	119.1	3,363,145.2	2,087.5	1.1	0.8
02/06/2020 08:00	7.5	13.5	6.0	103.3	3,364,103.7	1,940.7	1.0	0.8
02/06/2020 09:00	7.0	13.8	5.8	95.9	3,191,509.2	1,701.3	0.9	0.5
02/06/2020 10:00	7.2	13.8	6.0	95.8	3,168,998.1	1,689.3	0.9	0.5
02/06/2020 11:00	7.3	13.8	6.1	96.3	3,170,686.4	1,690.2	0.9	0.5
02/06/2020 12:00	7.3	13.8	6.1	91.5	2,998,289.0	1,598.3	1.0	0.6
02/06/2020 13:00	7.6	13.8	6.3	97.3	3,166,747.0	1,688.1	1.0	0.7
02/06/2020 14:00	7.5	13.8	6.2	96.0	3,134,293.5	1,670.8	1.0	0.7
02/06/2020 15:00	7.4	13.8	6.1	89.3	2,914,435.2	1,553.6	1.0	0.6
02/06/2020 16:00	7.5	13.8	6.2	89.8	2,949,139.8	1,572.1	0.9	0.5
02/06/2020 17:00	8.9	13.3	6.9	112.3	3,301,467.7	2,001.0	1.1	0.8
02/06/2020 18:00	8.6	13.2	6.6	119.7	3,298,896.1	2,095.8	1.2	1.0
02/06/2020 19:00	8.5	13.2	6.5	117.6	3,286,775.9	2,088.1	1.1	0.8
02/06/2020 20:00	8.3	13.2	6.4	118.1	3,313,377.4	2,105.0	1.1	0.8
02/06/2020 21:00	8.3	13.2	6.4	118.4	3,317,312.5	2,107.5	1.1	0.8
02/06/2020 22:00	8.3	13.2	6.4	116.4	3,318,624.8	2,084.1	1.1	0.8
02/06/2020 23:00	7.6	13.5	6.1	102.0	3,335,746.6	1,948.7	1.0	0.8
Average/Sum#:	8.0	13.5	6.3	106.9	3,256,252.3	1,909.3	1.0	0.7
Minimum:	7.0	13.2	5.8	89.3	2,914,435.2	1,553.6	0.9	0.5
Maximum:	8.9	13.8	6.9	120.7	3,411,202.7	2,107.5	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/07/2020 00:00	7.6	13.5	6.1	100.8	3,300,483.9	1,928.1	1.0	0.8
02/07/2020 01:00	7.0	13.8	5.8	94.2	3,198,450.1	1,705.0	0.9	0.5
02/07/2020 02:00	7.1	13.8	5.9	87.9	2,945,200.4	1,570.0	0.9	0.5
02/07/2020 03:00	7.2	13.8	6.0	87.7	2,938,071.9	1,566.2	0.9	0.5
02/07/2020 04:00	7.2	13.8	6.0	86.1	2,880,668.6	1,535.6	0.9	0.5
02/07/2020 05:00	7.7	13.8	6.4	88.8	2,938,071.9	1,566.2	0.9	0.5
02/07/2020 06:00	8.6	13.4	6.8	108.8	3,320,039.0	2,036.5	1.0	0.8
02/07/2020 07:00	8.7	13.3	6.8	115.8	3,361,534.1	2,086.5	1.1	0.8
02/07/2020 08:00	7.8	13.5	6.2	104.0	3,355,774.5	1,960.4	1.0	0.8
02/07/2020 09:00	7.1	13.8	5.9	92.0	3,102,778.0	1,654.0	0.9	0.5
02/07/2020 10:00	7.2	13.8	6.0	93.2	3,130,541.7	1,668.8	0.9	0.5
02/07/2020 11:00	7.4	13.8	6.1	94.9	3,188,132.5	1,699.5	0.9	0.5
02/07/2020 12:00	7.6	13.8	6.3	96.4	3,192,634.7	1,701.9	0.9	0.5
02/07/2020 13:00	7.6	13.8	6.3	96.0	3,188,507.7	1,699.7	0.9	0.5
02/07/2020 14:00	7.5	13.8	6.2	94.0	3,131,104.4	1,669.1	0.9	0.5
02/07/2020 15:00	7.5	13.8	6.2	95.0	3,162,807.5	1,686.0	0.9	0.5
02/07/2020 16:00	7.5	13.8	6.2	89.7	2,998,289.0	1,598.3	0.9	0.5
02/07/2020 17:00	8.9	13.3	6.9	112.4	3,288,411.8	2,017.1	1.1	0.8
02/07/2020 18:00	8.7	13.2	6.7	120.6	3,276,970.3	2,105.8	1.2	1.1
02/07/2020 19:00	8.5	13.2	6.5	117.8	3,284,257.4	2,086.5	1.2	1.0
02/07/2020 20:00	8.4	13.2	6.4	118.1	3,302,673.8	2,098.2	1.1	0.8
02/07/2020 21:00	8.4	13.2	6.4	118.2	3,300,942.4	2,097.1	1.1	0.8
02/07/2020 22:00	8.2	13.3	6.4	113.0	3,303,051.6	2,050.2	1.1	0.8
02/07/2020 23:00	14.4	14.7	13.7	133.7	2,513,296.5	1,248.0	1.7	0.9
Average/Sum#:	8.1	13.6	6.6	102.5	3,150,112.2	1,793.1	1.0	0.7
Minimum:	7.0	13.2	5.8	86.1	2,513,296.5	1,248.0	0.9	0.5
Maximum:	14.4	14.7	13.7	133.7	3,361,534.1	2,105.8	1.7	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/09/2020 23:00	36.9	17.5	64.0	0.0	1,790,142.0	470.6	-0.2	0.0
Average/Sum#:	36.9	17.5	64.0	0.0	1,790,142.0	470.6	-0.2	0.0
Minimum:	36.9	17.5	64.0	0.0	1,790,142.0	470.6	-0.2	0.0
Maximum:	36.9	17.5	64.0	0.0	1,790,142.0	470.6	-0.2	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/10/2020 00:00	49.3	15.8	57.0	227.1	1,825,210.2	706.4	3.8	1.1
02/10/2020 01:00	37.5	15.0	37.5	231.2	2,241,366.1	998.4	3.2	1.2
02/10/2020 02:00	6.7	13.9	5.6	80.9	2,745,505.7	1,443.5	0.9	0.4
02/10/2020 03:00	7.3	13.9	6.2	77.4	2,617,882.9	1,376.4	0.9	0.4
02/10/2020 04:00	7.1	13.9	6.0	83.7	2,876,932.4	1,512.6	0.9	0.5
02/10/2020 05:00	7.3	13.9	6.2	81.6	2,732,191.8	1,436.5	0.9	0.4
02/10/2020 06:00	7.4	13.9	6.2	93.2	3,234,884.7	1,700.8	0.9	0.5
02/10/2020 07:00	7.5	13.9	6.3	96.0	3,243,253.4	1,705.2	0.9	0.5
02/10/2020 08:00	7.2	13.9	6.1	93.0	3,161,088.0	1,662.0	0.9	0.5
02/10/2020 09:00	7.2	13.9	6.1	92.8	3,164,321.3	1,663.7	0.9	0.5
02/10/2020 10:00	7.2	13.9	6.1	91.8	3,130,466.1	1,645.9	0.9	0.5
02/10/2020 11:00	7.2	13.9	6.1	93.3	3,189,998.0	1,677.2	0.9	0.5
02/10/2020 12:00	7.2	13.9	6.1	93.2	3,187,905.8	1,676.1	0.9	0.5
02/10/2020 13:00	7.2	13.9	6.1	92.5	3,159,566.4	1,661.2	0.9	0.5
02/10/2020 14:00	7.2	13.9	6.1	92.2	3,155,001.6	1,658.8	0.9	0.5
02/10/2020 15:00	7.2	13.9	6.1	92.5	3,172,309.6	1,667.9	0.9	0.5
02/10/2020 16:00	7.1	13.9	6.0	93.3	3,229,178.8	1,697.8	0.9	0.5
02/10/2020 17:00	7.9	13.6	6.4	102.0	3,275,592.0	1,841.8	1.0	0.7
02/10/2020 18:00	8.2	13.3	6.4	111.8	3,351,014.1	2,055.5	1.1	0.8
02/10/2020 19:00	8.1	13.3	6.3	112.9	3,335,273.4	2,070.2	1.1	0.8
02/10/2020 20:00	8.1	13.2	6.2	116.8	3,356,204.4	2,107.7	1.1	0.8
02/10/2020 21:00	8.1	13.2	6.2	117.6	3,330,377.1	2,115.8	1.1	0.8
02/10/2020 22:00	8.0	13.2	6.1	115.2	3,325,790.4	2,088.6	1.1	0.8
02/10/2020 23:00	7.9	13.3	6.1	109.5	3,355,419.7	2,033.7	1.0	0.8
Average/Sum#:	10.5	13.9	9.6	108.0	3,058,197.2	1,675.2	1.2	0.6
Minimum:	6.7	13.2	5.6	77.4	1,825,210.2	706.4	0.9	0.4
Maximum:	49.3	15.8	57.0	231.2	3,356,204.4	2,115.8	3.8	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/11/2020 00:00	7.3	13.5	5.8	100.5	3,345,729.1	1,930.1	1.0	0.8
02/11/2020 01:00	6.9	13.9	5.8	86.8	2,994,284.5	1,574.3	0.9	0.5
02/11/2020 02:00	7.0	13.9	5.9	81.6	2,806,178.8	1,475.4	0.9	0.4
02/11/2020 03:00	6.9	13.9	5.8	85.0	2,941,599.7	1,546.6	0.9	0.5
02/11/2020 04:00	7.0	13.9	5.9	83.9	2,888,534.5	1,518.7	0.9	0.5
02/11/2020 05:00	7.3	13.9	6.2	91.2	3,134,460.3	1,648.0	0.9	0.5
02/11/2020 06:00	7.2	13.9	6.1	87.8	3,137,693.6	1,649.7	0.9	0.5
02/11/2020 07:00	7.4	13.9	6.2	89.3	3,010,261.1	1,582.7	0.9	0.5
02/11/2020 08:00	7.4	13.9	6.2	78.9	2,679,828.5	1,389.4	0.9	0.4
02/11/2020 09:00	7.1	13.9	6.0	86.2	2,959,097.9	1,555.8	0.9	0.5
02/11/2020 10:00	7.2	13.9	6.1	89.6	3,060,663.5	1,609.2	0.9	0.5
02/11/2020 11:00	7.2	13.9	6.1	90.3	3,097,752.1	1,628.7	0.9	0.5
02/11/2020 12:00	7.2	13.9	6.1	92.3	3,168,315.5	1,665.8	0.9	0.5
02/11/2020 13:00	7.2	13.9	6.1	93.2	3,202,741.3	1,683.9	0.9	0.5
02/11/2020 14:00	7.2	13.9	6.1	91.6	3,157,474.2	1,660.1	0.9	0.5
02/11/2020 15:00	7.2	13.9	6.1	86.2	2,927,905.4	1,539.4	0.9	0.5
02/11/2020 16:00	7.6	13.9	6.4	86.6	2,817,400.5	1,481.3	1.0	0.6
02/11/2020 17:00	7.2	13.9	6.1	91.2	3,091,665.7	1,625.5	0.9	0.5
02/11/2020 18:00	7.9	13.6	6.4	103.0	3,234,826.2	1,842.5	1.0	0.7
02/11/2020 19:00	9.1	13.3	7.1	129.7	3,254,405.9	2,091.3	1.3	1.0
02/11/2020 20:00	8.9	13.2	6.8	137.1	3,247,689.9	2,110.7	1.4	1.1
02/11/2020 21:00	8.9	13.2	6.8	142.0	3,258,621.4	2,141.6	1.4	1.1
02/11/2020 22:00	8.7	13.2	6.7	136.8	3,262,922.9	2,120.6	1.4	1.1
02/11/2020 23:00	8.6	13.3	6.7	127.6	3,294,261.8	2,068.8	1.2	1.0
Average/Sum#:	7.6	13.7	6.2	98.7	3,082,263.1	1,714.2	1.0	0.6
Minimum:	6.9	13.2	5.8	78.9	2,679,828.5	1,389.4	0.9	0.4
Maximum:	9.1	13.9	7.1	142.0	3,345,729.1	2,141.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/12/2020 00:00	8.1	13.4	6.4	107.6	3,257,539.4	1,926.8	1.1	0.8
02/12/2020 01:00	6.6	13.9	5.6	85.5	2,985,915.8	1,569.9	0.9	0.5
02/12/2020 02:00	6.9	13.9	5.8	85.1	2,945,784.0	1,548.8	0.9	0.5
02/12/2020 03:00	7.0	13.9	5.9	83.3	2,866,661.7	1,507.2	0.9	0.5
02/12/2020 04:00	7.1	13.9	6.0	91.5	3,157,854.6	1,660.3	0.9	0.5
02/12/2020 05:00	7.1	13.9	6.0	92.0	3,166,033.1	1,664.6	0.9	0.5
02/12/2020 06:00	7.0	13.9	5.9	87.2	3,088,052.0	1,623.6	0.9	0.5
02/12/2020 07:00	7.3	13.8	6.1	87.6	2,972,031.3	1,562.6	0.9	0.5
02/12/2020 08:00	7.1	13.8	5.9	93.8	3,237,547.5	1,702.2	0.9	0.5
02/12/2020 09:00	7.3	13.8	6.1	94.3	3,219,668.9	1,692.8	0.9	0.5
02/12/2020 10:00	7.2	13.9	6.1	93.4	3,194,943.2	1,679.8	0.9	0.5
02/12/2020 11:00	7.2	13.9	6.1	93.3	3,197,035.3	1,680.9	0.9	0.5
02/12/2020 12:00	7.1	13.9	6.0	91.4	3,128,754.3	1,645.0	0.9	0.5
02/12/2020 13:00	7.2	13.9	6.1	93.4	3,213,392.4	1,689.5	0.9	0.5
02/12/2020 14:00	7.2	13.9	6.1	90.9	3,100,605.0	1,630.2	0.9	0.5
02/12/2020 15:00	7.1	13.9	6.0	89.3	3,076,640.1	1,617.6	0.9	0.5
02/12/2020 16:00	7.7	13.9	6.5	85.3	2,688,826.7	1,413.7	1.0	0.6
02/12/2020 17:00	7.3	13.9	6.2	92.1	3,109,544.3	1,634.9	0.9	0.5
02/12/2020 18:00	7.5	13.9	6.3	95.4	3,248,008.4	1,707.7	0.9	0.5
02/12/2020 19:00	9.2	13.3	7.1	121.8	3,265,513.3	2,026.9	1.2	1.0
02/12/2020 20:00	9.0	13.2	6.9	134.3	3,264,615.4	2,121.7	1.3	1.1
02/12/2020 21:00	8.4	13.2	6.4	123.1	3,274,480.4	2,104.2	1.2	1.1
02/12/2020 22:00	8.3	13.2	6.4	119.1	3,267,010.9	2,099.4	1.2	1.0
02/12/2020 23:00	8.2	13.3	6.4	113.7	3,299,668.3	2,048.1	1.1	0.8
Average/Sum#:	7.5	13.7	6.2	97.7	3,134,421.9	1,731.6	1.0	0.6
Minimum:	6.6	13.2	5.6	83.3	2,688,826.7	1,413.7	0.9	0.5
Maximum:	9.2	13.9	7.1	134.3	3,299,668.3	2,121.7	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/13/2020 00:00	8.3	13.3	6.4	114.1	3,300,151.7	2,048.4	1.1	0.8
02/13/2020 01:00	8.2	13.4	6.5	111.1	3,328,856.2	2,017.6	1.1	0.8
02/13/2020 02:00	8.0	13.3	6.2	109.6	3,335,620.8	2,021.7	1.0	0.8
02/13/2020 03:00	8.1	13.3	6.3	111.3	3,351,130.0	2,031.1	1.1	0.8
02/13/2020 04:00	8.1	13.3	6.3	111.2	3,347,335.2	2,028.8	1.1	0.8
02/13/2020 05:00	8.2	13.3	6.4	112.1	3,361,194.4	2,037.2	1.1	0.8
02/13/2020 06:00	8.4	13.2	6.4	120.8	3,318,364.3	2,132.4	1.2	1.1
02/13/2020 07:00	8.3	13.3	6.4	116.5	3,344,456.6	2,075.9	1.1	0.8
02/13/2020 08:00	7.4	13.5	5.9	100.6	3,350,582.8	1,932.9	1.0	0.8
02/13/2020 09:00	6.7	13.8	5.6	90.7	3,124,538.7	1,665.6	0.9	0.5
02/13/2020 10:00	6.9	13.8	5.7	91.0	3,104,091.1	1,654.7	0.9	0.5
02/13/2020 11:00	7.2	13.8	6.0	92.0	3,161,468.3	1,662.2	0.9	0.5
02/13/2020 12:00	7.4	13.8	6.1	94.5	3,214,343.3	1,690.0	0.9	0.5
02/13/2020 13:00	7.3	13.8	6.1	91.4	3,089,383.4	1,624.3	0.9	0.5
02/13/2020 14:00	7.4	13.8	6.1	92.0	3,120,005.2	1,640.4	0.9	0.5
02/13/2020 15:00	7.3	13.8	6.1	89.5	3,026,047.5	1,591.0	0.9	0.5
02/13/2020 16:00	7.5	13.8	6.2	89.3	3,000,165.0	1,599.3	0.9	0.5
02/13/2020 17:00	9.0	13.3	7.0	112.6	3,270,641.9	2,006.2	1.1	0.8
02/13/2020 18:00	8.8	13.2	6.7	120.5	3,255,495.2	2,092.0	1.2	1.0
02/13/2020 19:00	8.6	13.2	6.6	121.1	3,276,659.1	2,105.6	1.2	1.1
02/13/2020 20:00	8.5	13.2	6.5	120.1	3,269,967.6	2,101.3	1.2	1.1
02/13/2020 21:00	8.4	13.2	6.4	119.4	3,273,702.4	2,103.7	1.2	1.1
02/13/2020 22:00	8.3	13.2	6.4	117.3	3,325,949.7	2,088.7	1.1	0.8
02/13/2020 23:00	8.3	13.2	6.4	116.6	3,313,051.6	2,080.6	1.1	0.8
Average/Sum#:	7.9	13.5	6.3	106.9	3,244,300.1	1,918.0	1.0	0.8
Minimum:	6.7	13.2	5.6	89.3	3,000,165.0	1,591.0	0.9	0.5
Maximum:	9.0	13.8	7.0	121.1	3,361,194.4	2,132.4	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/14/2020 00:00	11.0	14.1	9.5	117.1	2,940,561.3	1,589.0	1.2	0.8
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.0	14.1	9.5	117.1	2,940,561.3	1,589.0	1.2	0.8
Minimum:	11.0	14.1	9.5	117.1	2,940,561.3	1,589.0	1.2	0.8
Maximum:	11.0	14.1	9.5	117.1	2,940,561.3	1,589.0	1.2	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/17/2020 09:00	36.8	17.4	62.0	0.0	1,801,553.9	473.6	-0.1	0.0
02/17/2020 10:00	37.6	17.1	58.4	247.8	1,809,352.0	528.5	4.0	0.8
02/17/2020 11:00	46.7	16.2	58.6	268.7	1,847,046.1	660.9	4.4	1.1
02/17/2020 12:00	37.2	15.2	38.5	232.3	2,248,873.4	968.9	3.2	1.2
02/17/2020 13:00	6.9	13.9	5.8	81.4	2,649,836.2	1,393.2	1.0	0.6
02/17/2020 14:00	7.3	13.9	6.2	81.1	2,648,885.2	1,392.7	1.0	0.6
02/17/2020 15:00	7.3	13.9	6.2	90.6	3,082,155.9	1,620.5	0.9	0.5
02/17/2020 16:00	7.2	13.9	6.1	85.2	2,886,061.9	1,517.4	0.9	0.5
02/17/2020 17:00	7.3	13.9	6.2	94.2	3,220,239.5	1,693.1	0.9	0.5
02/17/2020 18:00	7.2	13.9	6.1	96.2	3,321,424.7	1,746.3	0.9	0.5
02/17/2020 19:00	8.9	13.4	7.0	115.0	3,329,186.2	2,017.8	1.1	0.8
02/17/2020 20:00	9.0	13.2	6.9	133.6	3,313,073.3	2,129.0	1.3	1.1
02/17/2020 21:00	8.8	13.3	6.8	129.8	3,296,266.7	2,118.2	1.3	1.1
02/17/2020 22:00	8.7	13.3	6.8	125.6	3,304,562.7	2,099.4	1.2	1.0
02/17/2020 23:00	8.5	13.3	6.6	118.4	3,348,568.7	2,054.0	1.1	0.8
Average/Sum#:	16.4	14.4	19.2	126.7	2,807,139.1	1,494.2	1.5	0.7
Minimum:	6.9	13.2	5.8	0.0	1,801,553.9	473.6	-0.1	0.0
Maximum:	46.7	17.4	62.0	268.7	3,348,568.7	2,129.0	4.4	1.2
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/18/2020 00:00	8.4	13.3	6.5	114.7	3,337,971.9	2,047.5	1.1	0.8
02/18/2020 01:00	8.4	13.3	6.5	114.8	3,336,341.7	2,046.5	1.1	0.8
02/18/2020 02:00	8.3	13.4	6.5	111.3	3,336,610.8	2,022.3	1.1	0.8
02/18/2020 03:00	8.4	13.3	6.5	113.7	3,336,178.6	2,046.4	1.1	0.8
02/18/2020 04:00	8.3	13.3	6.4	113.4	3,340,091.3	2,048.8	1.1	0.8
02/18/2020 05:00	8.4	13.3	6.5	116.0	3,333,017.8	2,068.8	1.1	0.8
02/18/2020 06:00	8.6	13.3	6.7	122.1	3,352,382.7	2,105.3	1.2	1.1
02/18/2020 07:00	8.6	13.3	6.7	120.2	3,351,586.6	2,104.8	1.1	0.8
02/18/2020 08:00	8.4	13.3	6.5	115.5	3,358,350.3	2,060.0	1.1	0.8
02/18/2020 09:00	7.8	13.5	6.2	103.5	3,350,467.9	1,957.3	1.0	0.8
02/18/2020 10:00	7.4	13.5	5.9	101.1	3,390,105.4	1,955.7	0.9	0.6
02/18/2020 11:00	7.4	13.5	5.9	101.4	3,386,118.5	1,953.4	0.9	0.6
02/18/2020 12:00	7.4	13.5	5.9	101.2	3,381,438.2	1,950.7	0.9	0.6
02/18/2020 13:00	7.2	13.7	5.9	98.1	3,238,597.4	1,773.7	1.0	0.7
02/18/2020 14:00	7.3	13.9	6.2	83.9	2,691,109.1	1,414.9	1.0	0.6
02/18/2020 15:00	7.3	13.9	6.2	86.0	2,859,814.6	1,503.6	0.9	0.5
02/18/2020 16:00	8.2	13.3	6.4	108.4	3,365,944.9	2,015.5	1.0	0.8
02/18/2020 17:00	8.3	13.2	6.4	120.3	3,322,099.1	2,134.8	1.2	1.1
02/18/2020 18:00	8.2	13.2	6.3	121.2	3,350,421.2	2,153.0	1.2	1.1
02/18/2020 19:00	8.2	13.1	6.2	126.6	3,341,699.8	2,196.2	1.2	1.1
02/18/2020 20:00	8.4	13.2	6.4	132.5	3,341,395.5	2,196.0	1.3	1.1
02/18/2020 21:00	8.3	13.2	6.4	126.3	3,307,544.6	2,149.6	1.2	1.1
02/18/2020 22:00	8.4	13.3	6.5	124.9	3,320,145.8	2,109.3	1.2	1.1
02/18/2020 23:00	8.0	13.3	6.2	112.6	3,347,916.6	2,053.6	1.1	0.8
Average/Sum#:	8.1	13.4	6.3	112.1	3,294,889.6	2,002.8	1.1	0.8
Minimum:	7.2	13.1	5.9	83.9	2,691,109.1	1,414.9	0.9	0.5
Maximum:	8.6	13.9	6.7	132.5	3,390,105.4	2,196.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/19/2020 00:00	8.3	13.2	6.4	130.2	3,366,653.8	2,212.6	1.3	1.1
02/19/2020 01:00	7.9	13.4	6.2	110.3	3,353,439.8	2,032.5	1.1	0.8
02/19/2020 02:00	8.1	13.5	6.5	103.6	3,367,570.6	1,942.7	1.0	0.8
02/19/2020 03:00	7.5	13.5	6.0	101.1	3,369,650.7	1,943.9	0.9	0.6
02/19/2020 04:00	8.3	13.3	6.4	117.8	3,368,131.9	2,066.0	1.1	0.8
02/19/2020 05:00	8.1	13.3	6.3	115.9	3,374,583.9	2,094.6	1.1	0.8
02/19/2020 06:00	8.3	13.3	6.4	124.7	3,305,507.1	2,100.0	1.2	1.1
02/19/2020 07:00	8.6	13.2	6.6	127.7	3,351,396.9	2,178.1	1.2	1.1
02/19/2020 08:00	7.8	13.4	6.1	106.5	3,374,194.1	1,995.8	1.0	0.8
02/19/2020 09:00	8.3	13.5	6.6	104.2	3,374,677.7	1,946.8	1.0	0.8
02/19/2020 10:00	7.5	13.5	6.0	100.4	3,375,544.4	1,947.3	0.9	0.6
02/19/2020 11:00	7.7	13.4	6.1	101.3	3,378,144.6	1,948.8	0.9	0.6
02/19/2020 12:00	8.0	13.4	6.3	102.7	3,379,358.0	1,949.5	1.0	0.8
02/19/2020 13:00	8.0	13.4	6.3	102.4	3,378,144.6	1,948.8	1.0	0.8
02/19/2020 14:00	8.0	13.4	6.3	102.2	3,372,250.9	1,945.4	1.0	0.8
02/19/2020 15:00	7.9	13.4	6.2	101.9	3,365,490.4	1,941.5	1.0	0.8
02/19/2020 16:00	8.1	13.3	6.3	110.4	3,358,389.6	2,035.5	1.0	0.8
02/19/2020 17:00	8.6	13.2	6.6	129.3	3,281,483.2	2,108.7	1.3	1.1
02/19/2020 18:00	8.5	13.2	6.5	127.7	3,289,419.6	2,113.8	1.3	1.1
02/19/2020 19:00	8.6	13.2	6.6	137.7	3,275,031.1	2,176.3	1.4	1.1
02/19/2020 20:00	8.4	13.2	6.4	130.8	3,292,704.9	2,164.0	1.3	1.1
02/19/2020 21:00	8.4	13.2	6.4	130.2	3,322,315.9	2,159.2	1.3	1.1
02/19/2020 22:00	8.0	13.3	6.2	113.9	3,305,629.4	2,051.8	1.1	0.8
02/19/2020 23:00	8.1	13.3	6.3	111.9	3,336,341.7	2,046.5	1.1	0.8
Average/Sum#:	8.1	13.3	6.3	114.4	3,346,502.3	2,043.8	1.1	0.9
Minimum:	7.5	13.2	6.0	100.4	3,275,031.1	1,941.5	0.9	0.6
Maximum:	8.6	13.5	6.6	137.7	3,379,358.0	2,212.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/20/2020 00:00	8.0	13.4	6.3	108.7	3,383,647.2	2,026.1	1.0	0.8
02/20/2020 01:00	8.1	13.3	6.3	110.9	3,365,814.1	2,040.0	1.1	0.8
02/20/2020 02:00	8.1	13.3	6.3	111.6	3,370,268.9	2,042.7	1.1	0.8
02/20/2020 03:00	8.2	13.3	6.4	111.8	3,363,504.3	2,038.6	1.1	0.8
02/20/2020 04:00	8.2	13.3	6.4	112.3	3,322,321.4	2,037.9	1.1	0.8
02/20/2020 05:00	8.0	13.3	6.2	111.8	3,387,592.9	2,053.2	1.1	0.8
02/20/2020 06:00	8.3	13.3	6.4	113.7	3,374,979.0	2,070.2	1.1	0.8
02/20/2020 07:00	8.3	13.3	6.4	115.4	3,388,184.2	2,078.3	1.1	0.8
02/20/2020 08:00	8.2	13.3	6.4	112.5	3,373,733.7	2,044.8	1.1	0.8
02/20/2020 09:00	7.5	13.5	6.0	102.2	3,342,251.4	1,952.5	1.0	0.8
02/20/2020 10:00	7.3	13.5	5.8	101.0	3,380,051.4	1,949.9	0.9	0.6
02/20/2020 11:00	7.4	13.5	5.9	101.2	3,376,757.8	1,948.0	0.9	0.6
02/20/2020 12:00	7.5	13.5	6.0	101.7	3,337,287.2	1,949.6	1.0	0.8
02/20/2020 13:00	7.6	13.4	6.0	101.8	3,338,143.1	1,950.1	1.0	0.8
02/20/2020 14:00	7.8	13.4	6.1	103.5	3,319,755.2	1,963.6	1.0	0.8
02/20/2020 15:00	8.0	13.3	6.2	107.0	3,333,212.4	1,995.9	1.0	0.8
02/20/2020 16:00	8.2	13.2	6.3	115.2	3,345,745.4	2,076.7	1.1	0.8
02/20/2020 17:00	8.0	13.2	6.1	115.9	3,324,357.3	2,087.7	1.1	0.8
02/20/2020 18:00	7.9	13.2	6.1	115.6	3,327,542.0	2,089.7	1.1	0.8
02/20/2020 19:00	8.1	13.3	6.3	116.9	3,324,516.5	2,087.8	1.1	0.8
02/20/2020 20:00	8.4	13.3	6.5	121.4	3,286,618.5	2,088.0	1.2	1.0
02/20/2020 21:00	8.4	13.3	6.5	123.8	3,302,831.2	2,098.3	1.2	1.0
02/20/2020 22:00	8.3	13.3	6.4	123.6	3,283,627.8	2,086.1	1.2	1.0
02/20/2020 23:00	8.2	13.3	6.4	113.5	3,298,356.4	2,023.2	1.1	0.8
Average/Sum#:	8.0	13.3	6.2	111.4	3,343,795.8	2,032.5	1.1	0.8
Minimum:	7.3	13.2	5.8	101.0	3,283,627.8	1,948.0	0.9	0.6
Maximum:	8.4	13.5	6.5	123.8	3,388,184.2	2,098.3	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/21/2020 00:00	7.7	13.5	6.1	103.4	3,278,915.5	1,915.5	1.0	0.8
02/21/2020 01:00	6.7	13.8	5.6	85.2	2,929,427.0	1,540.2	0.9	0.5
02/21/2020 02:00	7.0	13.8	5.8	82.9	2,823,486.8	1,484.5	0.9	0.4
02/21/2020 03:00	7.0	13.8	5.8	87.7	2,980,400.0	1,567.0	0.9	0.5
02/21/2020 04:00	7.3	13.8	6.1	95.4	3,205,784.4	1,685.5	0.9	0.5
02/21/2020 05:00	7.0	13.9	5.9	89.6	3,025,857.3	1,590.9	0.9	0.5
02/21/2020 06:00	7.4	13.8	6.1	90.3	3,211,680.6	1,688.6	0.9	0.5
02/21/2020 07:00	7.3	13.8	6.1	93.8	3,137,883.8	1,649.8	0.9	0.5
02/21/2020 08:00	7.2	13.8	6.0	87.8	2,914,810.4	1,553.8	0.9	0.5
02/21/2020 09:00	7.3	13.8	6.1	95.2	3,160,368.8	1,684.7	0.9	0.5
02/21/2020 10:00	7.2	13.9	6.1	92.5	3,091,285.3	1,625.3	0.9	0.5
02/21/2020 11:00	7.2	13.9	6.1	91.1	3,058,761.5	1,608.2	0.9	0.5
02/21/2020 12:00	7.2	13.9	6.1	94.8	3,188,666.6	1,676.5	0.9	0.5
02/21/2020 13:00	7.2	13.8	6.0	94.4	3,145,924.2	1,677.0	0.9	0.5
02/21/2020 14:00	7.3	13.8	6.1	96.0	3,184,943.5	1,697.8	0.9	0.5
02/21/2020 15:00	7.3	13.8	6.1	95.5	3,163,933.1	1,686.6	0.9	0.5
02/21/2020 16:00	8.0	13.7	6.6	97.5	3,175,563.8	1,692.8	1.0	0.7
02/21/2020 17:00	8.5	13.4	6.7	108.7	3,276,719.1	1,986.0	1.0	0.8
02/21/2020 18:00	8.2	13.2	6.3	117.2	3,301,572.0	2,097.5	1.1	0.8
02/21/2020 19:00	8.0	13.3	6.2	114.3	3,308,115.3	2,077.5	1.1	0.8
02/21/2020 20:00	8.0	13.2	6.1	115.2	3,335,185.3	2,094.5	1.1	0.8
02/21/2020 21:00	7.9	13.3	6.1	112.9	3,328,829.0	2,066.2	1.1	0.8
02/21/2020 22:00	8.0	13.2	6.1	115.8	3,335,026.1	2,094.4	1.1	0.8
02/21/2020 23:00	14.2	14.6	13.3	137.9	2,509,176.7	1,282.6	1.7	0.9
Average/Sum#:	7.8	13.7	6.4	99.8	3,128,013.2	1,738.5	1.0	0.6
Minimum:	6.7	13.2	5.6	82.9	2,509,176.7	1,282.6	0.9	0.4
Maximum:	14.2	14.6	13.3	137.9	3,335,185.3	2,097.5	1.7	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/24/2020 13:00	37.9	17.4	63.9	0.0	1,812,585.3	476.5	-0.2	0.0
02/24/2020 14:00	46.0	16.4	60.3	232.6	1,786,528.2	626.2	3.9	0.9
02/24/2020 15:00	45.7	15.1	46.5	253.9	2,043,227.6	880.3	3.9	1.3
02/24/2020 16:00	6.7	13.9	5.6	86.8	2,863,048.0	1,505.3	1.0	0.6
02/24/2020 17:00	8.5	13.2	6.5	114.7	3,400,411.2	2,085.8	1.1	0.8
02/24/2020 18:00	8.7	13.1	6.6	128.5	3,335,086.9	2,167.5	1.2	1.1
02/24/2020 19:00	8.5	13.2	6.5	123.2	3,362,870.6	2,161.0	1.2	1.1
02/24/2020 20:00	8.4	13.2	6.4	117.0	3,369,106.2	2,091.2	1.1	0.8
02/24/2020 21:00	8.6	13.3	6.7	116.4	3,362,984.1	2,087.4	1.1	0.8
02/24/2020 22:00	8.0	13.4	6.3	104.4	3,363,306.3	1,964.8	1.0	0.8
02/24/2020 23:00	8.4	13.3	6.5	112.3	3,339,085.6	2,023.8	1.1	0.8
Average/Sum#:	17.8	14.1	20.2	126.3	2,912,567.3	1,642.7	1.5	0.8
Minimum:	6.7	13.1	5.6	0.0	1,786,528.2	476.5	-0.2	0.0
Maximum:	46.0	17.4	63.9	253.9	3,400,411.2	2,167.5	3.9	1.3
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/25/2020 00:00	6.9	13.9	5.8	86.6	2,971,841.1	1,562.5	0.9	0.5
02/25/2020 01:00	7.0	13.9	5.9	83.6	2,878,834.4	1,513.6	0.9	0.5
02/25/2020 02:00	7.2	13.9	6.1	76.5	2,596,200.4	1,365.0	0.9	0.4
02/25/2020 03:00	7.3	13.9	6.2	76.8	2,587,641.5	1,360.5	0.9	0.4
02/25/2020 04:00	7.2	13.9	6.1	81.6	2,802,374.8	1,473.4	0.9	0.4
02/25/2020 05:00	8.2	13.5	6.5	103.2	3,386,291.8	1,953.5	1.0	0.8
02/25/2020 06:00	8.1	13.5	6.5	103.6	3,369,297.5	1,968.3	1.0	0.8
02/25/2020 07:00	8.2	13.5	6.5	104.4	3,337,458.4	1,949.7	1.0	0.8
02/25/2020 08:00	7.1	13.9	6.0	79.0	2,642,038.1	1,389.1	0.9	0.4
02/25/2020 09:00	7.3	13.9	6.2	82.7	2,624,349.7	1,379.8	1.0	0.6
02/25/2020 10:00	7.3	13.9	6.2	84.4	2,625,490.9	1,380.4	1.0	0.6
02/25/2020 11:00	7.3	13.9	6.2	84.6	2,610,275.0	1,372.4	1.0	0.5
02/25/2020 12:00	7.3	13.9	6.2	85.9	2,617,312.4	1,376.1	1.0	0.6
02/25/2020 13:00	7.3	13.9	6.2	85.5	2,620,545.7	1,377.8	1.0	0.6
02/25/2020 14:00	7.5	13.9	6.3	92.3	3,127,422.9	1,644.3	0.9	0.5
02/25/2020 15:00	7.3	13.9	6.2	86.2	2,929,997.6	1,540.5	0.9	0.5
02/25/2020 16:00	7.3	13.9	6.2	90.7	3,107,832.6	1,634.0	0.9	0.5
02/25/2020 17:00	7.5	13.9	6.3	87.9	2,950,919.3	1,551.5	0.9	0.5
02/25/2020 18:00	8.4	13.3	6.5	107.3	3,318,516.1	1,987.1	1.0	0.8
02/25/2020 19:00	8.3	13.2	6.4	119.6	3,308,249.2	2,125.9	1.2	1.1
02/25/2020 20:00	8.2	13.1	6.2	122.6	3,318,623.0	2,156.8	1.2	1.1
02/25/2020 21:00	8.1	13.2	6.2	120.0	3,333,925.9	2,142.4	1.2	1.1
02/25/2020 22:00	8.1	13.2	6.2	119.1	3,323,499.6	2,135.7	1.2	1.1
02/25/2020 23:00	8.0	13.2	6.1	117.8	3,349,895.4	2,128.2	1.1	0.9
Average/Sum#:	7.6	13.7	6.2	95.1	2,989,118.1	1,686.2	1.0	0.7
Minimum:	6.9	13.1	5.8	76.5	2,587,641.5	1,360.5	0.9	0.4
Maximum:	8.4	13.9	6.5	122.6	3,386,291.8	2,156.8	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/26/2020 00:00	7.9	13.3	6.1	111.0	3,367,479.8	2,065.6	1.1	0.8
02/26/2020 01:00	8.3	13.3	6.4	113.8	3,338,298.0	2,047.7	1.1	0.8
02/26/2020 02:00	8.3	13.3	6.4	113.4	3,329,820.6	2,042.5	1.1	0.8
02/26/2020 03:00	8.2	13.4	6.5	112.8	3,319,386.9	2,036.1	1.1	0.8
02/26/2020 04:00	8.0	13.4	6.3	110.4	3,351,459.9	2,031.3	1.1	0.8
02/26/2020 05:00	8.1	13.4	6.4	110.1	3,342,880.4	2,026.1	1.0	0.8
02/26/2020 06:00	8.3	13.4	6.5	110.2	3,375,965.1	2,021.5	1.0	0.8
02/26/2020 07:00	8.4	13.4	6.6	109.6	3,361,435.9	2,012.8	1.0	0.8
02/26/2020 08:00	15.4	14.8	14.9	137.4	2,476,644.3	1,229.8	1.7	0.9
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/26/2020 15:00	40.5	17.1	62.9	47.0	1,809,802.4	502.2	0.5	0.1
02/26/2020 16:00	21.2	14.3	19.0	164.4	2,635,940.6	1,308.9	2.0	1.0
02/26/2020 17:00	8.4	13.3	6.5	110.8	3,312,702.8	2,032.0	1.1	0.8
02/26/2020 18:00	8.4	13.3	6.5	113.0	3,290,162.9	2,042.2	1.1	0.8
02/26/2020 19:00	7.9	13.4	6.2	102.7	3,341,053.1	1,951.8	1.0	0.8
02/26/2020 20:00	8.5	13.2	6.5	116.3	3,323,720.4	2,087.3	1.1	0.8
02/26/2020 21:00	8.2	13.3	6.4	107.6	3,333,880.4	1,996.3	1.0	0.8
02/26/2020 22:00	8.0	13.4	6.3	103.9	3,353,891.5	1,959.3	1.0	0.8
02/26/2020 23:00	7.4	13.6	6.0	97.5	3,199,295.5	1,798.9	1.0	0.7
Average/Sum#:	11.1	13.7	10.7	110.7	3,159,101.1	1,844.0	1.1	0.8
Minimum:	7.4	13.2	6.0	47.0	1,809,802.4	502.2	0.5	0.1
Maximum:	40.5	17.1	62.9	164.4	3,375,965.1	2,087.3	2.0	1.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/27/2020 00:00	7.0	13.8	5.8	83.4	2,829,831.1	1,508.5	0.9	0.5
02/27/2020 01:00	7.1	13.9	6.0	81.6	2,803,135.6	1,473.8	0.9	0.4
02/27/2020 02:00	7.3	13.8	6.1	87.0	2,995,615.8	1,575.0	0.9	0.5
02/27/2020 03:00	7.2	13.9	6.1	85.2	2,849,543.9	1,498.2	0.9	0.4
02/27/2020 04:00	7.3	13.8	6.1	96.7	3,305,002.6	1,761.8	0.9	0.5
02/27/2020 05:00	7.3	13.8	6.1	97.6	3,309,692.4	1,764.3	0.9	0.5
02/27/2020 06:00	7.4	13.8	6.1	98.5	3,301,250.7	1,759.8	0.9	0.5
02/27/2020 07:00	7.5	13.8	6.2	98.7	3,300,312.8	1,759.3	0.9	0.5
02/27/2020 08:00	7.4	13.8	6.1	98.5	3,304,815.0	1,761.7	0.9	0.5
02/27/2020 09:00	7.4	13.8	6.1	98.3	3,309,880.0	1,764.4	0.9	0.5
02/27/2020 10:00	7.4	13.8	6.1	98.1	3,308,754.4	1,763.8	0.9	0.5
02/27/2020 11:00	7.8	13.7	6.4	99.4	3,255,158.8	1,759.0	1.0	0.7
02/27/2020 12:00	7.9	13.8	6.6	99.3	3,267,296.5	1,741.7	0.9	0.5
02/27/2020 13:00	7.3	13.8	6.1	94.2	3,167,497.4	1,688.5	0.9	0.5
02/27/2020 14:00	7.4	13.8	6.1	93.8	3,147,049.8	1,677.6	0.9	0.5
02/27/2020 15:00	7.3	13.8	6.1	93.6	3,123,788.3	1,665.2	0.9	0.5
02/27/2020 16:00	8.0	13.5	6.4	103.0	3,223,941.0	1,836.3	1.0	0.7
02/27/2020 17:00	8.2	13.2	6.3	112.8	3,263,688.6	2,049.6	1.1	0.8
02/27/2020 18:00	8.1	13.3	6.3	112.1	3,302,729.4	2,050.0	1.1	0.8
02/27/2020 19:00	8.0	13.3	6.2	112.2	3,308,207.1	2,053.4	1.1	0.8
02/27/2020 20:00	8.0	13.2	6.1	115.1	3,324,038.8	2,087.5	1.1	0.8
02/27/2020 21:00	8.0	13.2	6.1	115.7	3,293,229.5	2,092.2	1.1	0.8
02/27/2020 22:00	8.0	13.2	6.1	116.3	3,299,525.7	2,096.2	1.1	0.8
02/27/2020 23:00	7.6	13.3	5.9	107.7	3,326,546.3	2,016.2	1.0	0.8
Average/Sum#:	7.6	13.6	6.1	100.0	3,205,022.1	1,800.2	1.0	0.6
Minimum:	7.0	13.2	5.8	81.6	2,803,135.6	1,473.8	0.9	0.4
Maximum:	8.2	13.9	6.6	116.3	3,326,546.3	2,096.2	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/28/2020 00:00	7.3	13.5	5.8	99.2	3,338,448.6	1,925.9	0.9	0.6
02/28/2020 01:00	6.8	13.8	5.7	87.5	3,026,047.5	1,591.0	0.9	0.5
02/28/2020 02:00	7.0	13.8	5.8	82.7	2,854,298.9	1,500.7	0.9	0.5
02/28/2020 03:00	7.0	13.8	5.8	84.1	2,892,718.8	1,520.9	0.9	0.5
02/28/2020 04:00	7.0	13.9	5.9	83.7	2,878,644.2	1,513.5	0.9	0.5
02/28/2020 05:00	7.1	13.8	5.9	91.4	3,100,339.3	1,652.7	0.9	0.5
02/28/2020 06:00	7.2	13.8	6.0	91.7	3,179,315.7	1,694.8	0.9	0.5
02/28/2020 07:00	7.4	13.8	6.1	93.0	3,102,027.6	1,653.6	0.9	0.5
02/28/2020 08:00	7.2	13.8	6.0	87.5	2,911,996.5	1,552.3	0.9	0.5
02/28/2020 09:00	7.1	13.9	6.0	85.5	2,916,303.3	1,533.3	0.9	0.5
02/28/2020 10:00	7.2	13.9	6.1	84.0	2,808,080.8	1,476.4	0.9	0.4
02/28/2020 11:00	7.3	13.9	6.2	85.5	2,879,405.0	1,513.9	0.9	0.5
02/28/2020 12:00	7.3	13.9	6.2	87.9	2,995,045.2	1,574.7	0.9	0.5
02/28/2020 13:00	7.4	13.9	6.2	90.2	3,060,473.3	1,609.1	0.9	0.5
02/28/2020 14:00	7.3	13.9	6.2	82.7	2,763,384.3	1,452.9	0.9	0.4
02/28/2020 15:00	7.7	13.8	6.4	90.4	2,933,569.7	1,563.8	1.0	0.6
02/28/2020 16:00	8.6	13.3	6.7	111.4	3,284,662.2	2,014.8	1.1	0.8
02/28/2020 17:00	8.3	13.2	6.4	114.0	3,262,255.5	2,048.7	1.1	0.8
02/28/2020 18:00	8.2	13.2	6.3	111.9	3,278,240.9	2,034.8	1.1	0.8
02/28/2020 19:00	8.2	13.2	6.3	112.9	3,253,975.3	2,043.5	1.1	0.8
02/28/2020 20:00	8.1	13.3	6.3	110.9	3,303,736.3	2,026.5	1.1	0.8
02/28/2020 21:00	8.2	13.2	6.3	113.9	3,271,491.2	2,054.5	1.1	0.8
02/28/2020 22:00	8.1	13.3	6.3	111.6	3,273,407.6	2,031.8	1.1	0.8
02/28/2020 23:00	13.8	14.6	12.9	133.3	2,477,268.9	1,248.2	1.7	0.9
Average/Sum#:	7.8	13.7	6.4	97.0	3,043,547.4	1,701.3	1.0	0.6
Minimum:	6.8	13.2	5.7	82.7	2,477,268.9	1,248.2	0.9	0.4
Maximum:	13.8	14.6	12.9	133.3	3,338,448.6	2,054.5	1.7	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/03/2020 08:00	17.5	18.2	38.2	0.0	1,781,496.6	286.2	-0.3	0.0
03/03/2020 09:00	37.8	17.1	58.7	73.2	1,803,189.6	526.7	1.2	0.3
03/03/2020 10:00	39.2	16.8	56.4	267.3	1,823,563.7	572.6	4.3	1.0
03/03/2020 11:00	50.1	15.7	56.8	268.2	1,831,478.3	722.2	4.5	1.2
03/03/2020 12:00	25.6	14.5	23.6	181.8	2,403,445.1	1,140.8	2.4	1.0
03/03/2020 13:00	6.9	13.9	5.8	81.1	2,694,101.4	1,396.8	0.9	0.4
03/03/2020 14:00	7.2	13.9	6.1	82.6	2,687,736.4	1,393.5	1.0	0.6
03/03/2020 15:00	7.4	13.9	6.2	87.9	3,006,947.3	1,559.0	0.9	0.5
03/03/2020 16:00	7.2	14.0	6.2	88.0	3,027,392.3	1,569.6	0.9	0.5
03/03/2020 17:00	8.1	13.9	6.8	92.3	3,046,398.7	1,601.7	0.9	0.5
03/03/2020 18:00	8.5	13.2	6.5	117.8	3,302,831.2	2,098.3	1.1	0.8
03/03/2020 19:00	8.4	13.1	6.4	124.7	3,290,726.8	2,162.7	1.2	1.1
03/03/2020 20:00	8.3	13.1	6.3	124.5	3,280,988.7	2,156.3	1.2	1.1
03/03/2020 21:00	8.3	13.1	6.3	124.7	3,280,532.2	2,156.0	1.2	1.1
03/03/2020 22:00	8.1	13.2	6.2	120.5	3,276,309.4	2,129.3	1.2	1.1
03/03/2020 23:00	8.0	13.2	6.1	117.0	3,312,590.4	2,104.5	1.1	0.8
Average/Sum#:	16.0	14.4	18.9	122.0	2,740,608.0	1,473.5	1.5	0.8
Minimum:	6.9	13.1	5.8	0.0	1,781,496.6	286.2	-0.3	0.0
Maximum:	50.1	18.2	58.7	268.2	3,312,590.4	2,162.7	4.5	1.2
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/04/2020 00:00	8.0	13.3	6.2	112.0	3,357,209.1	2,059.3	1.1	0.8
03/04/2020 01:00	8.0	13.3	6.2	111.5	3,341,721.6	2,049.8	1.1	0.8
03/04/2020 02:00	7.9	13.3	6.1	107.2	3,342,898.5	2,001.7	1.0	0.8
03/04/2020 03:00	7.9	13.3	6.1	106.4	3,336,385.4	1,997.8	1.0	0.8
03/04/2020 04:00	8.0	13.3	6.2	110.9	3,336,993.8	2,046.9	1.1	0.8
03/04/2020 05:00	8.0	13.3	6.2	110.6	3,373,073.7	2,044.4	1.0	0.8
03/04/2020 06:00	8.4	13.3	6.5	119.1	3,330,798.8	2,043.1	1.1	0.8
03/04/2020 07:00	8.5	13.3	6.6	113.5	3,307,975.0	2,029.1	1.1	0.8
03/04/2020 08:00	7.0	13.9	5.9	84.5	2,829,831.1	1,508.5	0.9	0.5
03/04/2020 09:00	7.1	13.9	6.0	79.6	2,623,779.1	1,379.5	0.9	0.4
03/04/2020 10:00	7.2	13.9	6.1	82.2	2,629,675.2	1,382.6	1.0	0.6
03/04/2020 11:00	7.2	13.9	6.1	87.8	3,005,125.7	1,580.0	0.9	0.5
03/04/2020 12:00	7.3	13.9	6.2	94.3	3,249,339.7	1,708.4	0.9	0.5
03/04/2020 13:00	7.2	13.9	6.1	86.1	2,928,285.8	1,539.6	0.9	0.5
03/04/2020 14:00	7.5	13.9	6.3	91.6	3,112,777.7	1,636.6	0.9	0.5
03/04/2020 15:00	7.2	13.9	6.1	89.9	3,060,473.3	1,609.1	0.9	0.5
03/04/2020 16:00	7.7	13.8	6.4	89.4	2,954,723.3	1,553.5	0.9	0.5
03/04/2020 17:00	8.5	13.3	6.6	111.7	3,309,605.3	2,030.1	1.1	0.8
03/04/2020 18:00	8.2	13.2	6.3	113.9	3,271,650.4	2,054.6	1.1	0.8
03/04/2020 19:00	8.2	13.2	6.3	113.2	3,303,696.0	2,050.6	1.1	0.8
03/04/2020 20:00	8.2	13.2	6.3	118.9	3,288,174.7	2,113.0	1.2	1.1
03/04/2020 21:00	8.2	13.2	6.3	119.8	3,301,402.1	2,121.5	1.2	1.1
03/04/2020 22:00	8.2	13.2	6.3	118.4	3,282,105.6	2,109.1	1.2	1.1
03/04/2020 23:00	8.0	13.2	6.1	113.2	3,319,484.7	2,060.4	1.1	0.8
Average/Sum#:	7.8	13.5	6.2	103.6	3,174,882.7	1,862.9	1.0	0.7
Minimum:	7.0	13.2	5.9	79.6	2,623,779.1	1,379.5	0.9	0.4
Maximum:	8.5	13.9	6.6	119.8	3,373,073.7	2,121.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/05/2020 00:00	7.9	13.3	6.1	106.9	3,354,588.7	2,008.7	1.0	0.8
03/05/2020 01:00	8.1	13.4	6.4	107.4	3,337,554.4	1,998.5	1.0	0.8
03/05/2020 02:00	8.3	13.4	6.5	108.3	3,323,359.2	1,990.0	1.0	0.8
03/05/2020 03:00	8.3	13.4	6.5	108.1	3,322,190.2	1,989.3	1.0	0.8
03/05/2020 04:00	8.4	13.3	6.5	114.7	3,311,751.5	2,055.6	1.1	0.8
03/05/2020 05:00	8.2	13.3	6.4	114.3	3,306,434.9	2,052.3	1.1	0.8
03/05/2020 06:00	8.3	13.3	6.4	114.9	3,369,608.9	2,042.3	1.1	0.8
03/05/2020 07:00	8.1	13.4	6.4	109.8	3,314,341.0	1,984.6	1.1	0.8
03/05/2020 08:00	7.0	13.8	5.8	90.6	3,069,761.7	1,636.4	0.9	0.5
03/05/2020 09:00	7.4	13.8	6.1	95.6	3,197,512.1	1,704.5	0.9	0.5
03/05/2020 10:00	7.4	13.8	6.1	95.6	3,243,824.0	1,705.5	0.9	0.5
03/05/2020 11:00	7.3	13.8	6.1	94.5	3,167,685.0	1,688.6	0.9	0.5
03/05/2020 12:00	7.4	13.8	6.1	93.3	3,117,222.6	1,661.7	0.9	0.5
03/05/2020 13:00	7.4	13.8	6.1	94.9	3,186,819.4	1,698.8	0.9	0.5
03/05/2020 14:00	7.4	13.8	6.1	90.4	2,991,348.1	1,594.6	0.9	0.5
03/05/2020 15:00	7.5	13.8	6.2	86.7	2,867,724.7	1,528.7	0.9	0.5
03/05/2020 16:00	7.9	13.8	6.6	86.8	2,793,063.0	1,488.9	1.0	0.6
03/05/2020 17:00	9.0	13.3	7.0	111.3	3,244,231.6	1,990.0	1.1	0.8
03/05/2020 18:00	8.5	13.2	6.5	116.1	3,252,146.8	2,066.1	1.1	0.8
03/05/2020 19:00	8.3	13.2	6.4	114.9	3,279,293.7	2,059.4	1.1	0.8
03/05/2020 20:00	8.3	13.2	6.4	113.9	3,270,535.7	2,053.9	1.1	0.8
03/05/2020 21:00	8.3	13.2	6.4	116.3	3,305,567.5	2,075.9	1.1	0.8
03/05/2020 22:00	8.3	13.2	6.4	116.2	3,306,522.9	2,076.5	1.1	0.8
03/05/2020 23:00	8.2	13.3	6.4	108.6	3,289,753.3	1,993.9	1.0	0.8
Average/Sum#:	8.0	13.5	6.3	104.6	3,217,618.4	1,881.0	1.0	0.7
Minimum:	7.0	13.2	5.8	86.7	2,793,063.0	1,488.9	0.9	0.5
Maximum:	9.0	13.8	7.0	116.3	3,369,608.9	2,076.5	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/06/2020 00:00	8.4	13.3	6.5	115.0	3,310,945.9	2,055.1	1.1	0.8
03/06/2020 01:00	8.4	13.3	6.5	115.5	3,315,295.9	2,057.8	1.1	0.8
03/06/2020 02:00	8.3	13.3	6.4	108.9	3,290,743.3	1,994.5	1.1	0.8
03/06/2020 03:00	8.4	13.3	6.5	111.7	3,299,986.7	2,024.2	1.1	0.8
03/06/2020 04:00	8.4	13.3	6.5	113.2	3,323,788.6	2,038.8	1.1	0.8
03/06/2020 05:00	8.3	13.3	6.4	114.3	3,313,201.5	2,056.5	1.1	0.8
03/06/2020 06:00	8.4	13.3	6.5	116.3	3,333,407.2	2,044.7	1.1	0.8
03/06/2020 07:00	8.5	13.3	6.6	112.8	3,307,812.0	2,029.0	1.1	0.8
03/06/2020 08:00	8.0	13.4	6.3	105.9	3,300,312.8	1,952.1	1.0	0.8
03/06/2020 09:00	7.1	13.8	5.9	91.3	3,069,574.1	1,636.3	0.9	0.5
03/06/2020 10:00	7.4	13.8	6.1	94.0	3,156,992.2	1,682.9	0.9	0.5
03/06/2020 11:00	7.6	13.8	6.3	96.4	3,190,008.4	1,700.5	0.9	0.5
03/06/2020 12:00	7.4	13.8	6.1	94.3	3,138,420.5	1,673.0	0.9	0.5
03/06/2020 13:00	7.5	13.8	6.2	95.8	3,179,128.1	1,694.7	0.9	0.5
03/06/2020 14:00	7.5	13.8	6.2	93.6	3,109,906.5	1,657.8	0.9	0.5
03/06/2020 15:00	7.5	13.8	6.2	92.6	3,078,766.2	1,641.2	0.9	0.5
03/06/2020 16:00	7.7	13.8	6.4	87.3	2,868,662.7	1,529.2	0.9	0.5
03/06/2020 17:00	8.6	13.3	6.7	110.7	3,273,087.3	2,007.7	1.1	0.8
03/06/2020 18:00	8.3	13.2	6.4	113.7	3,255,249.1	2,044.3	1.1	0.8
03/06/2020 19:00	8.2	13.2	6.3	113.8	3,265,758.7	2,050.9	1.1	0.8
03/06/2020 20:00	8.4	13.2	6.4	119.8	3,267,010.9	2,099.4	1.2	1.0
03/06/2020 21:00	8.4	13.2	6.4	121.8	3,262,922.9	2,120.6	1.2	1.1
03/06/2020 22:00	8.1	13.2	6.2	117.7	3,283,470.4	2,086.0	1.2	1.0
03/06/2020 23:00	8.0	13.3	6.2	113.8	3,271,809.6	2,054.7	1.1	0.8
Average/Sum#:	8.0	13.5	6.3	107.1	3,227,760.9	1,913.8	1.0	0.7
Minimum:	7.1	13.2	5.9	87.3	2,868,662.7	1,529.2	0.9	0.5
Maximum:	8.6	13.8	6.7	121.8	3,333,407.2	2,120.6	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/07/2020 00:00	14.0	14.7	13.3	132.0	2,457,915.4	1,220.5	1.7	0.9
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.0	14.7	13.3	132.0	2,457,915.4	1,220.5	1.7	0.9
Minimum:	14.0	14.7	13.3	132.0	2,457,915.4	1,220.5	1.7	0.9
Maximum:	14.0	14.7	13.3	132.0	2,457,915.4	1,220.5	1.7	0.9
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/08/2020 20:00	33.0	17.4	55.6	0.0	1,782,914.5	468.7	-0.1	0.0
03/08/2020 21:00	33.6	17.1	52.2	233.2	1,812,775.5	529.5	3.8	0.8
03/08/2020 22:00	22.8	14.6	21.4	182.8	2,480,155.9	1,159.1	2.3	1.0
03/08/2020 23:00	6.8	13.8	5.7	84.1	2,905,993.6	1,549.1	0.9	0.5
Average/Sum#:	24.1	15.7	33.7	125.0	2,245,459.9	926.6	1.7	0.6
Minimum:	6.8	13.8	5.7	0.0	1,782,914.5	468.7	-0.1	0.0
Maximum:	33.6	17.4	55.6	233.2	2,905,993.6	1,549.1	3.8	1.0
%SI	83.33	83.33	83.33	83.33	83.33	83.33	83.33	83.33

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/09/2020 00:00	6.9	13.8	5.7	84.1	2,899,803.0	1,545.8	0.9	0.5
03/09/2020 01:00	7.1	13.8	5.9	90.4	3,090,959.7	1,647.7	0.9	0.5
03/09/2020 02:00	7.0	13.8	5.8	88.8	3,016,860.7	1,608.2	0.9	0.5
03/09/2020 03:00	7.1	13.8	5.9	83.0	2,820,451.5	1,503.5	0.9	0.5
03/09/2020 04:00	7.4	13.8	6.1	87.6	2,985,532.7	1,591.5	0.9	0.5
03/09/2020 05:00	8.3	13.4	6.5	109.5	3,391,663.4	2,030.9	1.0	0.8
03/09/2020 06:00	8.6	13.2	6.6	121.7	3,390,191.1	2,153.8	1.1	0.9
03/09/2020 07:00	8.5	13.2	6.5	121.8	3,366,422.9	2,138.7	1.2	1.1
03/09/2020 08:00	8.3	13.2	6.4	121.7	3,348,006.5	2,127.0	1.2	1.1
03/09/2020 09:00	6.8	13.7	5.6	92.2	3,115,810.6	1,683.7	0.9	0.5
03/09/2020 10:00	6.9	13.8	5.7	88.0	3,004,479.6	1,601.6	0.9	0.5
03/09/2020 11:00	7.2	13.8	6.0	87.6	2,948,014.3	1,571.5	0.9	0.5
03/09/2020 12:00	7.3	13.8	6.1	94.8	3,185,131.0	1,697.9	0.9	0.5
03/09/2020 13:00	7.3	13.8	6.1	95.0	3,230,700.4	1,698.6	0.9	0.5
03/09/2020 14:00	7.3	13.9	6.2	94.7	3,231,271.0	1,698.9	0.9	0.5
03/09/2020 15:00	7.3	13.9	6.2	93.3	3,181,058.7	1,672.5	0.9	0.5
03/09/2020 16:00	7.2	13.8	6.0	93.3	3,167,685.0	1,688.6	0.9	0.5
03/09/2020 17:00	8.2	13.3	6.4	109.9	3,336,115.8	2,022.0	1.0	0.8
03/09/2020 18:00	8.2	13.2	6.3	122.3	3,320,007.9	2,157.7	1.2	1.1
03/09/2020 19:00	8.0	13.2	6.1	122.7	3,327,547.4	2,162.6	1.2	1.1
03/09/2020 20:00	8.1	13.2	6.2	119.9	3,315,874.4	2,130.8	1.2	1.1
03/09/2020 21:00	8.3	13.2	6.4	122.0	3,310,739.1	2,127.5	1.2	1.1
03/09/2020 22:00	8.3	13.2	6.4	121.9	3,310,272.2	2,127.2	1.2	1.1
03/09/2020 23:00	8.3	13.2	6.4	121.7	3,307,938.0	2,125.7	1.2	1.1
Average/Sum#:	7.7	13.5	6.1	103.7	3,191,772.4	1,854.7	1.0	0.7
Minimum:	6.8	13.2	5.6	83.0	2,820,451.5	1,503.5	0.9	0.5
Maximum:	8.6	13.9	6.6	122.7	3,391,663.4	2,162.6	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/10/2020 00:00	8.2	13.2	6.3	121.7	3,309,649.7	2,126.8	1.2	1.1
03/10/2020 01:00	8.2	13.2	6.3	121.8	3,293,310.0	2,116.3	1.2	1.1
03/10/2020 02:00	8.2	13.2	6.3	120.1	3,314,007.0	2,105.4	1.2	1.1
03/10/2020 03:00	8.0	13.3	6.2	114.3	3,327,056.8	2,065.1	1.1	0.8
03/10/2020 04:00	8.0	13.3	6.2	114.3	3,332,051.2	2,068.2	1.1	0.8
03/10/2020 05:00	8.3	13.2	6.4	124.9	3,307,698.4	2,149.7	1.2	1.1
03/10/2020 06:00	8.5	13.2	6.5	133.3	3,313,706.0	2,202.0	1.3	1.1
03/10/2020 07:00	8.6	13.2	6.6	128.7	3,292,400.5	2,163.8	1.3	1.1
03/10/2020 08:00	8.1	13.1	6.1	124.1	3,313,545.4	2,153.5	1.2	1.1
03/10/2020 09:00	8.0	13.2	6.1	119.9	3,326,599.4	2,113.4	1.2	1.1
03/10/2020 10:00	8.0	13.2	6.1	116.3	3,328,019.7	2,090.0	1.1	0.8
03/10/2020 11:00	0.0	0.0	0.0	135.6	1,385,739.5	2,114.9	3.4	2.7
03/10/2020 12:00	9.0	13.2	6.9	128.5	3,351,154.6	2,129.0	1.2	1.1
03/10/2020 13:00	8.6	13.2	6.6	122.4	3,367,510.1	2,114.8	1.2	1.1
03/10/2020 14:00	8.4	13.2	6.4	123.0	3,344,701.0	2,124.9	1.2	1.1
03/10/2020 15:00	8.3	13.2	6.4	120.4	3,348,879.6	2,103.1	1.2	1.1
03/10/2020 16:00	8.3	13.2	6.4	120.3	3,352,223.5	2,105.2	1.2	1.1
03/10/2020 17:00	8.3	13.2	6.4	117.7	3,341,878.8	2,074.3	1.1	0.8
03/10/2020 18:00	8.4	13.1	6.4	128.0	3,355,867.8	2,156.5	1.2	1.1
03/10/2020 19:00	8.4	13.1	6.4	131.5	3,358,013.2	2,182.4	1.3	1.1
03/10/2020 20:00	8.3	13.1	6.3	130.0	3,357,397.8	2,182.0	1.3	1.1
03/10/2020 21:00	8.2	13.2	6.3	122.4	3,383,592.9	2,124.9	1.2	1.1
03/10/2020 22:00	8.2	13.2	6.3	120.4	3,418,083.3	2,121.6	1.1	0.8
03/10/2020 23:00	8.4	13.2	6.4	125.4	3,366,689.6	2,089.7	1.2	1.0
Average/Sum#:	8.3	13.2	6.4	123.5	3,339,305.9	2,124.1	1.2	1.0
Minimum:	8.0	13.1	6.1	114.3	3,292,400.5	2,065.1	1.1	0.8
Maximum:	9.0	13.3	6.9	135.6	3,418,083.3	2,202.0	1.3	1.1
%SI	4.17	4.17	4.17	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/11/2020 00:00	8.4	13.3	6.5	118.1	3,357,234.6	2,034.8	1.1	0.8
03/11/2020 01:00	8.4	13.3	6.5	116.5	3,383,981.3	2,026.3	1.1	0.8
03/11/2020 02:00	8.5	13.3	6.6	118.0	3,376,538.6	2,046.5	1.1	0.8
03/11/2020 03:00	8.6	13.3	6.7	118.1	3,376,703.5	2,046.6	1.1	0.8
03/11/2020 04:00	8.6	13.3	6.7	118.9	3,375,305.1	2,070.4	1.1	0.8
03/11/2020 05:00	8.5	13.2	6.5	126.1	3,418,083.3	2,121.6	1.2	1.1
03/11/2020 06:00	8.9	13.1	6.7	142.9	3,371,707.5	2,191.3	1.4	1.1
03/11/2020 07:00	8.8	13.2	6.7	125.4	3,382,955.9	2,124.5	1.2	1.1
03/11/2020 08:00	8.5	13.2	6.5	121.9	3,369,898.6	2,116.3	1.2	1.1
03/11/2020 09:00	7.3	13.7	6.0	97.1	3,224,900.6	1,719.1	1.0	0.7
03/11/2020 10:00	7.4	13.8	6.1	93.3	3,182,079.4	1,649.8	0.9	0.5
03/11/2020 11:00	7.6	13.8	6.3	90.2	3,012,926.5	1,562.1	0.9	0.5
03/11/2020 12:00	7.6	13.9	6.4	90.9	3,126,200.2	1,598.0	0.9	0.5
03/11/2020 13:00	7.7	13.9	6.5	96.2	3,300,704.0	1,687.2	0.9	0.5
03/11/2020 14:00	7.7	13.9	6.5	94.7	3,233,993.5	1,653.1	0.9	0.5
03/11/2020 15:00	7.6	13.9	6.4	89.3	3,051,860.1	1,560.0	0.9	0.5
03/11/2020 16:00	7.9	13.9	6.7	82.0	2,680,499.4	1,350.6	0.9	0.4
03/11/2020 17:00	8.0	13.9	6.7	94.8	3,218,929.8	1,645.4	0.9	0.5
03/11/2020 18:00	8.3	13.8	6.9	98.9	3,292,211.9	1,706.9	0.9	0.5
03/11/2020 19:00	9.1	13.3	7.1	114.4	3,388,657.3	2,029.1	1.1	0.8
03/11/2020 20:00	9.0	13.1	6.8	133.0	3,342,934.2	2,172.6	1.3	1.1
03/11/2020 21:00	8.6	13.2	6.6	124.9	3,345,802.8	2,125.6	1.2	1.1
03/11/2020 22:00	8.4	13.2	6.4	117.0	3,378,728.6	2,072.5	1.1	0.8
03/11/2020 23:00	8.4	13.2	6.4	120.5	3,368,306.3	2,115.3	1.2	1.1
Average/Sum#:	8.2	13.5	6.6	110.1	3,273,381.0	1,892.7	1.1	0.8
Minimum:	7.3	13.1	6.0	82.0	2,680,499.4	1,350.6	0.9	0.4
Maximum:	9.1	13.9	7.1	142.9	3,418,083.3	2,191.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/12/2020 00:00	8.6	13.2	6.6	122.7	3,343,328.8	2,075.2	1.2	1.0
03/12/2020 01:00	8.5	13.3	6.6	119.4	3,372,413.8	2,044.0	1.1	0.8
03/12/2020 02:00	8.5	13.4	6.7	115.1	3,364,219.2	1,989.9	1.1	0.8
03/12/2020 03:00	8.6	13.3	6.7	120.4	3,363,834.3	2,038.8	1.1	0.8
03/12/2020 04:00	8.7	13.3	6.8	125.5	3,337,528.9	2,071.6	1.2	1.0
03/12/2020 05:00	8.7	13.3	6.8	130.9	3,353,156.4	2,081.3	1.3	1.0
03/12/2020 06:00	9.0	13.1	6.8	141.3	3,351,243.0	2,178.0	1.4	1.1
03/12/2020 07:00	8.8	13.1	6.7	132.1	3,337,087.2	2,168.8	1.3	1.1
03/12/2020 08:00	8.3	13.2	6.4	121.1	3,329,151.2	2,066.4	1.2	1.0
03/12/2020 09:00	7.0	13.8	5.8	94.9	3,216,604.3	1,667.7	0.9	0.5
03/12/2020 10:00	7.3	13.8	6.1	95.9	3,233,963.2	1,676.7	0.9	0.5
03/12/2020 11:00	7.7	13.9	6.5	97.1	3,254,143.6	1,663.4	0.9	0.5
03/12/2020 12:00	8.6	13.8	7.1	102.0	3,278,131.9	1,699.6	1.0	0.7
03/12/2020 13:00	7.6	13.9	6.4	91.2	3,104,876.3	1,587.1	0.9	0.5
03/12/2020 14:00	7.5	13.8	6.2	94.8	3,280,162.7	1,676.7	0.9	0.5
03/12/2020 15:00	8.3	13.5	6.6	104.4	3,290,042.1	1,825.9	1.0	0.7
03/12/2020 16:00	8.7	13.2	6.7	120.4	3,336,777.7	2,095.5	1.2	1.0
03/12/2020 17:00	8.5	13.1	6.4	128.3	3,303,082.4	2,146.7	1.3	1.1
03/12/2020 18:00	8.4	13.1	6.4	131.1	3,348,781.2	2,176.4	1.3	1.1
03/12/2020 19:00	8.4	13.1	6.4	131.3	3,321,462.8	2,182.9	1.3	1.1
03/12/2020 20:00	8.1	13.2	6.2	120.1	3,326,108.9	2,088.8	1.2	1.0
03/12/2020 21:00	8.9	13.2	6.8	144.2	3,292,065.1	2,115.5	1.4	1.1
03/12/2020 22:00	9.1	13.2	7.0	153.0	3,301,246.5	2,121.4	1.5	1.3
03/12/2020 23:00	9.1	13.2	7.0	152.0	3,293,621.3	2,116.5	1.5	1.3
Average/Sum#:	8.4	13.4	6.6	120.4	3,305,543.0	1,981.5	1.2	0.9
Minimum:	7.0	13.1	5.8	91.2	3,104,876.3	1,587.1	0.9	0.5
Maximum:	9.1	13.9	7.1	153.0	3,372,413.8	2,182.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/13/2020 00:00	9.1	13.2	7.0	150.1	3,274,324.8	2,104.1	1.5	1.3
03/13/2020 01:00	9.1	13.2	7.0	149.0	3,276,659.1	2,105.6	1.5	1.3
03/13/2020 02:00	9.0	13.2	6.9	143.8	3,312,905.2	2,104.7	1.4	1.1
03/13/2020 03:00	8.9	13.2	6.8	143.0	3,313,377.4	2,105.0	1.4	1.1
03/13/2020 04:00	8.9	13.3	6.9	137.3	3,331,729.0	2,068.0	1.3	1.0
03/13/2020 05:00	9.0	13.2	6.9	148.5	3,310,272.2	2,127.2	1.5	1.3
03/13/2020 06:00	9.2	13.2	7.0	144.4	3,325,812.4	2,112.9	1.4	1.1
03/13/2020 07:00	9.0	13.2	6.9	135.3	3,338,404.8	2,120.9	1.3	1.1
03/13/2020 08:00	8.5	13.1	6.4	128.1	3,372,674.4	2,167.3	1.2	1.1
03/13/2020 09:00	7.2	13.7	5.9	97.4	3,230,903.6	1,722.3	1.0	0.7
03/13/2020 10:00	7.3	13.9	6.2	90.2	3,133,243.0	1,601.6	0.9	0.5
03/13/2020 11:00	7.4	13.9	6.2	92.0	3,202,496.7	1,637.0	0.9	0.5
03/13/2020 12:00	7.6	13.9	6.4	94.4	3,290,531.2	1,682.0	0.9	0.5
03/13/2020 13:00	7.7	13.9	6.5	92.7	3,198,192.8	1,634.8	0.9	0.5
03/13/2020 14:00	7.9	13.8	6.6	95.5	3,228,562.6	1,673.9	0.9	0.5
03/13/2020 15:00	7.8	13.8	6.5	95.3	3,283,684.0	1,678.5	0.9	0.5
03/13/2020 16:00	7.8	13.8	6.5	96.3	3,312,833.2	1,693.4	0.9	0.5
03/13/2020 17:00	8.6	13.5	6.9	103.9	3,273,104.5	1,816.5	1.0	0.7
03/13/2020 18:00	8.7	13.2	6.7	116.0	3,347,427.5	2,053.3	1.1	0.8
03/13/2020 19:00	8.7	13.1	6.6	129.1	3,338,933.6	2,170.0	1.2	1.1
03/13/2020 20:00	8.6	13.1	6.5	131.1	3,330,896.6	2,189.1	1.3	1.1
03/13/2020 21:00	8.4	13.1	6.4	123.4	3,363,747.0	2,137.0	1.2	1.1
03/13/2020 22:00	8.4	13.2	6.4	119.6	3,387,311.5	2,102.5	1.1	0.8
03/13/2020 23:00	8.6	13.3	6.7	119.5	3,357,698.2	2,059.6	1.1	0.8
Average/Sum#:	8.4	13.4	6.6	119.8	3,297,321.9	1,952.8	1.2	0.9
Minimum:	7.2	13.1	5.9	90.2	3,133,243.0	1,601.6	0.9	0.5
Maximum:	9.2	13.9	7.0	150.1	3,387,311.5	2,189.1	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/14/2020 00:00	8.6	13.2	6.6	126.5	3,367,350.9	2,114.7	1.2	1.1
03/14/2020 01:00	8.5	13.2	6.5	124.4	3,372,287.2	2,117.8	1.2	1.1
03/14/2020 02:00	8.4	13.2	6.4	122.9	3,364,803.1	2,113.1	1.2	1.1
03/14/2020 03:00	8.4	13.2	6.4	121.0	3,361,299.9	2,110.9	1.2	1.1
03/14/2020 04:00	8.3	13.3	6.4	114.2	3,377,198.5	2,046.9	1.1	0.8
03/14/2020 05:00	8.4	13.2	6.4	119.9	3,402,367.5	2,087.0	1.1	0.8
03/14/2020 06:00	8.7	13.2	6.7	126.0	3,417,599.9	2,121.3	1.2	1.1
03/14/2020 07:00	8.6	13.3	6.7	121.8	3,346,712.1	2,077.3	1.2	1.0
03/14/2020 08:00	7.2	13.8	6.0	97.7	3,444,689.2	1,760.8	0.9	0.5
03/14/2020 09:00	7.4	13.8	6.1	97.9	3,425,321.6	1,750.9	0.9	0.5
03/14/2020 10:00	7.5	13.8	6.2	97.9	3,415,540.0	1,745.9	0.9	0.5
03/14/2020 11:00	7.5	13.9	6.3	97.8	3,418,670.2	1,747.5	0.9	0.5
03/14/2020 12:00	7.5	13.9	6.3	97.9	3,419,648.3	1,748.0	0.9	0.5
03/14/2020 13:00	7.5	13.9	6.3	97.9	3,418,670.2	1,747.5	0.9	0.5
03/14/2020 14:00	7.5	13.9	6.3	97.8	3,423,365.3	1,749.9	0.9	0.5
03/14/2020 15:00	7.4	13.9	6.2	97.7	3,424,734.8	1,750.6	0.9	0.5
03/14/2020 16:00	7.5	13.9	6.3	98.5	3,434,516.4	1,755.6	0.9	0.5
03/14/2020 17:00	8.3	13.6	6.7	104.8	3,355,820.1	1,837.9	1.0	0.7
03/14/2020 18:00	8.9	13.2	6.8	125.8	3,406,966.8	2,114.7	1.2	1.1
03/14/2020 19:00	8.7	13.1	6.6	136.1	3,401,619.0	2,185.9	1.3	1.1
03/14/2020 20:00	8.5	13.2	6.5	128.6	3,389,404.1	2,153.3	1.2	1.1
03/14/2020 21:00	8.3	13.2	6.4	121.0	3,399,878.0	2,110.3	1.1	0.8
03/14/2020 22:00	8.2	13.3	6.4	113.5	3,421,389.9	2,048.7	1.1	0.8
03/14/2020 23:00	8.2	13.3	6.4	113.1	3,406,860.7	2,040.0	1.1	0.8
Average/Sum#:	8.1	13.5	6.4	112.5	3,400,696.4	1,959.9	1.1	0.8
Minimum:	7.2	13.1	6.0	97.7	3,346,712.1	1,745.9	0.9	0.5
Maximum:	8.9	13.9	6.8	136.1	3,444,689.2	2,185.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/15/2020 00:00	8.3	13.3	6.4	117.5	3,432,965.4	2,080.7	1.1	0.8
03/15/2020 01:00	8.2	13.3	6.4	113.2	3,419,218.9	2,047.4	1.1	0.8
03/15/2020 02:00	8.2	13.3	6.4	112.2	3,403,186.6	2,037.8	1.1	0.8
03/15/2020 03:00	8.2	13.3	6.4	112.1	3,402,518.6	2,037.4	1.1	0.8
03/15/2020 04:00	8.2	13.3	6.4	113.1	3,419,218.9	2,047.4	1.1	0.8
03/15/2020 05:00	8.2	13.3	6.4	112.9	3,414,876.8	2,044.8	1.1	0.8
03/15/2020 06:00	8.5	13.3	6.6	116.2	3,444,770.3	2,062.7	1.1	0.8
03/15/2020 07:00	8.5	13.3	6.6	116.2	3,401,947.2	2,061.9	1.1	0.8
03/15/2020 08:00	8.2	13.3	6.4	113.3	3,369,953.0	2,017.9	1.1	0.8
03/15/2020 09:00	7.2	13.8	6.0	97.8	3,380,742.3	1,752.8	0.9	0.5
03/15/2020 10:00	7.4	13.8	6.1	98.7	3,391,350.6	1,758.3	0.9	0.5
03/15/2020 11:00	7.5	13.8	6.2	98.7	3,367,819.6	1,746.1	0.9	0.5
03/15/2020 12:00	7.5	13.8	6.2	98.7	3,370,327.0	1,747.4	0.9	0.5
03/15/2020 13:00	7.5	13.8	6.2	98.9	3,426,886.7	1,751.7	0.9	0.5
03/15/2020 14:00	7.2	13.9	6.1	90.0	3,115,831.7	1,592.7	0.9	0.5
03/15/2020 15:00	7.3	13.9	6.2	86.0	2,978,693.7	1,522.6	0.9	0.5
03/15/2020 16:00	7.3	13.9	6.2	86.2	2,974,781.0	1,520.6	0.9	0.5
03/15/2020 17:00	8.2	13.6	6.6	103.5	3,343,586.6	1,831.2	1.0	0.7
03/15/2020 18:00	9.0	13.2	6.9	138.2	3,398,662.3	2,184.0	1.3	1.1
03/15/2020 19:00	8.8	13.1	6.7	143.5	3,379,891.5	2,221.3	1.4	1.1
03/15/2020 20:00	8.6	13.1	6.5	141.7	3,402,327.2	2,211.2	1.4	1.1
03/15/2020 21:00	8.5	13.1	6.4	137.9	3,422,938.5	2,199.6	1.3	1.1
03/15/2020 22:00	8.2	13.2	6.3	120.3	3,432,690.5	2,105.6	1.1	0.8
03/15/2020 23:00	8.3	13.2	6.4	120.2	3,437,581.3	2,108.6	1.1	0.8
Average/Sum#:	8.0	13.5	6.4	112.0	3,355,531.9	1,945.5	1.1	0.7
Minimum:	7.2	13.1	6.0	86.0	2,974,781.0	1,520.6	0.9	0.5
Maximum:	9.0	13.9	6.9	143.5	3,444,770.3	2,221.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/16/2020 00:00	8.3	13.2	6.4	119.8	3,406,483.4	2,114.4	1.1	0.8
03/16/2020 01:00	8.2	13.2	6.3	118.1	3,425,680.3	2,101.3	1.1	0.8
03/16/2020 02:00	8.2	13.2	6.3	119.0	3,408,416.7	2,115.6	1.1	0.8
03/16/2020 03:00	8.3	13.2	6.4	118.9	3,443,776.3	2,112.4	1.1	0.8
03/16/2020 04:00	8.4	13.2	6.4	127.6	3,446,650.1	2,164.5	1.2	1.1
03/16/2020 05:00	8.3	13.1	6.3	129.3	3,435,208.9	2,182.4	1.2	1.1
03/16/2020 06:00	8.6	13.1	6.5	146.7	3,418,175.6	2,221.5	1.4	1.1
03/16/2020 07:00	8.5	13.2	6.5	122.1	3,430,166.4	2,129.1	1.1	0.9
03/16/2020 08:00	8.4	13.2	6.4	121.7	3,418,727.7	2,122.0	1.1	0.8
03/16/2020 09:00	8.4	13.2	6.4	121.5	3,400,361.3	2,110.6	1.1	0.8
03/16/2020 10:00	8.3	13.2	6.4	122.6	3,400,039.1	2,110.4	1.2	1.1
03/16/2020 11:00	8.4	13.2	6.4	126.1	3,417,116.6	2,121.0	1.2	1.1
03/16/2020 12:00	8.3	13.2	6.4	123.0	3,393,755.8	2,106.5	1.2	1.1
03/16/2020 13:00	8.3	13.3	6.4	122.0	3,394,053.1	2,081.9	1.2	1.0
03/16/2020 14:00	8.3	13.3	6.4	119.5	3,409,701.7	2,066.6	1.1	0.8
03/16/2020 15:00	8.3	13.3	6.4	116.9	3,404,689.6	2,038.7	1.1	0.8
03/16/2020 16:00	8.3	13.3	6.4	116.0	3,409,198.7	2,041.4	1.1	0.8
03/16/2020 17:00	8.2	13.3	6.4	115.8	3,385,943.0	2,052.2	1.1	0.8
03/16/2020 18:00	8.5	13.1	6.4	132.8	3,382,016.6	2,198.0	1.3	1.1
03/16/2020 19:00	8.4	13.1	6.4	133.9	3,392,018.0	2,204.5	1.3	1.1
03/16/2020 20:00	8.3	13.1	6.3	127.0	3,402,940.9	2,161.9	1.2	1.1
03/16/2020 21:00	8.4	13.1	6.4	127.2	3,374,074.9	2,168.2	1.2	1.1
03/16/2020 22:00	8.2	13.2	6.3	120.5	3,413,733.3	2,118.9	1.1	0.8
03/16/2020 23:00	8.2	13.2	6.3	120.6	3,407,772.3	2,115.2	1.1	0.8
Average/Sum#:	8.3	13.2	6.4	123.7	3,409,195.8	2,123.3	1.2	0.9
Minimum:	8.2	13.1	6.3	115.8	3,374,074.9	2,038.7	1.1	0.8
Maximum:	8.6	13.3	6.5	146.7	3,446,650.1	2,221.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/17/2020 00:00	8.2	13.2	6.3	118.6	3,424,702.1	2,100.7	1.1	0.8
03/17/2020 01:00	8.2	13.2	6.3	117.4	3,407,584.3	2,090.2	1.1	0.8
03/17/2020 02:00	8.1	13.3	6.3	111.7	3,442,834.3	2,036.4	1.0	0.8
03/17/2020 03:00	8.2	13.3	6.4	114.2	3,443,768.3	2,062.1	1.1	0.8
03/17/2020 04:00	8.1	13.3	6.3	111.3	3,438,945.9	2,034.1	1.0	0.8
03/17/2020 05:00	8.3	13.2	6.4	119.8	3,445,895.6	2,113.7	1.1	0.8
03/17/2020 06:00	8.5	13.2	6.5	129.6	3,435,185.1	2,157.3	1.2	1.1
03/17/2020 07:00	8.3	13.3	6.4	112.4	3,444,694.1	2,037.5	1.0	0.8
03/17/2020 08:00	7.6	13.5	6.1	102.6	3,429,074.2	1,928.1	0.9	0.6
03/17/2020 09:00	7.4	13.8	6.1	98.6	3,388,843.2	1,757.0	0.9	0.5
03/17/2020 10:00	7.5	13.8	6.2	99.2	3,391,929.2	1,758.6	0.9	0.5
03/17/2020 11:00	7.5	13.8	6.2	99.5	3,398,101.2	1,761.8	0.9	0.5
03/17/2020 12:00	7.5	13.8	6.2	99.4	3,401,958.8	1,763.8	0.9	0.5
03/17/2020 13:00	7.5	13.8	6.2	99.0	3,395,015.2	1,760.2	0.9	0.5
03/17/2020 14:00	7.5	13.8	6.2	99.3	3,393,858.0	1,759.6	0.9	0.5
03/17/2020 15:00	7.5	13.8	6.2	99.1	3,392,314.9	1,758.8	0.9	0.5
03/17/2020 16:00	7.5	13.8	6.2	99.3	3,396,365.3	1,760.9	0.9	0.5
03/17/2020 17:00	8.6	13.3	6.7	111.2	3,421,701.2	2,023.9	1.0	0.8
03/17/2020 18:00	8.5	13.2	6.5	121.2	3,408,416.7	2,115.6	1.1	0.8
03/17/2020 19:00	8.4	13.2	6.4	125.2	3,383,752.1	2,125.0	1.2	1.1
03/17/2020 20:00	8.2	13.3	6.4	116.9	3,416,301.4	2,070.6	1.1	0.8
03/17/2020 21:00	8.3	13.3	6.4	118.0	3,421,416.1	2,073.7	1.1	0.8
03/17/2020 22:00	8.3	13.3	6.4	118.3	3,380,521.9	2,073.6	1.1	0.8
03/17/2020 23:00	8.2	13.3	6.4	113.9	3,407,194.7	2,040.2	1.1	0.8
Average/Sum#:	8.0	13.5	6.3	110.7	3,412,932.2	1,965.1	1.0	0.7
Minimum:	7.4	13.2	6.1	98.6	3,380,521.9	1,757.0	0.9	0.5
Maximum:	8.6	13.8	6.7	129.6	3,445,895.6	2,157.3	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/18/2020 00:00	8.2	13.3	6.4	113.0	3,394,502.4	2,032.6	1.1	0.8
03/18/2020 01:00	8.1	13.3	6.3	110.9	3,431,337.9	2,029.6	1.0	0.8
03/18/2020 02:00	8.1	13.3	6.3	110.7	3,433,366.7	2,030.8	1.0	0.8
03/18/2020 03:00	8.1	13.3	6.3	111.7	3,408,697.7	2,041.1	1.0	0.8
03/18/2020 04:00	8.1	13.3	6.3	110.7	3,434,212.0	2,031.3	1.0	0.8
03/18/2020 05:00	8.1	13.3	6.3	111.5	3,392,114.9	2,006.4	1.0	0.8
03/18/2020 06:00	8.6	13.1	6.5	125.0	3,369,589.5	2,091.5	1.2	1.0
03/18/2020 07:00	8.6	13.1	6.5	117.6	3,369,762.1	2,067.0	1.1	0.8
03/18/2020 08:00	8.2	13.2	6.3	113.8	3,358,095.8	2,010.8	1.1	0.8
03/18/2020 09:00	6.9	13.8	5.7	91.7	3,191,337.4	1,654.6	0.9	0.5
03/18/2020 10:00	7.1	13.8	5.9	91.3	3,144,082.7	1,630.1	0.9	0.5
03/18/2020 11:00	7.2	13.8	6.0	90.5	3,115,151.2	1,615.1	0.9	0.5
03/18/2020 12:00	7.3	13.8	6.1	92.5	3,163,177.5	1,640.0	0.9	0.5
03/18/2020 13:00	7.3	13.8	6.1	91.3	3,118,044.3	1,616.6	0.9	0.5
03/18/2020 14:00	7.3	13.8	6.1	93.2	3,182,850.9	1,650.2	0.9	0.5
03/18/2020 15:00	7.3	13.8	6.1	92.1	3,149,483.2	1,632.9	0.9	0.5
03/18/2020 16:00	7.3	13.8	6.1	94.9	3,243,799.9	1,681.8	0.9	0.5
03/18/2020 17:00	7.6	13.8	6.3	89.9	3,016,012.5	1,563.7	0.9	0.5
03/18/2020 18:00	8.6	13.4	6.8	111.9	3,410,722.6	1,992.5	1.0	0.8
03/18/2020 19:00	8.4	13.3	6.5	111.1	3,419,503.4	2,022.6	1.0	0.8
03/18/2020 20:00	8.4	13.3	6.5	116.0	3,408,876.8	2,066.1	1.1	0.8
03/18/2020 21:00	8.2	13.3	6.4	114.2	3,426,734.0	2,051.9	1.1	0.8
03/18/2020 22:00	8.2	13.3	6.4	114.1	3,429,239.1	2,053.4	1.1	0.8
03/18/2020 23:00	7.9	13.4	6.2	110.1	3,408,007.0	2,015.8	1.0	0.8
Average/Sum#:	7.9	13.5	6.3	105.4	3,309,112.6	1,884.5	1.0	0.7
Minimum:	6.9	13.1	5.7	89.9	3,016,012.5	1,563.7	0.9	0.5
Maximum:	8.6	13.8	6.8	125.0	3,434,212.0	2,091.5	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/19/2020 00:00	7.4	13.5	5.9	100.8	3,452,194.4	1,941.1	0.9	0.6
03/19/2020 01:00	7.4	13.5	5.9	100.8	3,453,439.3	1,941.8	0.9	0.6
03/19/2020 02:00	7.5	13.5	6.0	101.3	3,465,177.2	1,948.4	0.9	0.6
03/19/2020 03:00	7.5	13.5	6.0	101.6	3,465,888.6	1,948.8	0.9	0.6
03/19/2020 04:00	7.6	13.5	6.1	104.2	3,477,109.0	1,980.5	0.9	0.6
03/19/2020 05:00	7.8	13.4	6.1	105.7	3,447,829.2	1,989.0	1.0	0.8
03/19/2020 06:00	8.4	13.3	6.5	120.8	3,470,253.4	2,103.3	1.1	0.8
03/19/2020 07:00	8.4	13.3	6.5	117.4	3,465,468.6	2,100.4	1.1	0.8
03/19/2020 08:00	7.9	13.4	6.2	109.9	3,421,506.8	1,998.8	1.0	0.8
03/19/2020 09:00	7.0	13.8	5.8	87.6	2,998,267.9	1,554.5	0.9	0.5
03/19/2020 10:00	7.0	13.8	5.8	88.6	3,073,489.8	1,593.5	0.9	0.5
03/19/2020 11:00	7.3	13.9	6.2	84.3	2,881,660.2	1,473.0	0.9	0.4
03/19/2020 12:00	7.2	13.9	6.1	86.2	2,996,496.2	1,531.7	0.9	0.5
03/19/2020 13:00	7.5	13.9	6.3	80.8	2,687,984.4	1,374.0	0.9	0.4
03/19/2020 14:00	7.8	13.9	6.6	78.8	2,542,825.4	1,299.8	1.0	0.5
03/19/2020 15:00	7.5	13.9	6.3	89.0	3,064,576.1	1,566.5	0.9	0.5
03/19/2020 16:00	7.6	13.9	6.4	88.2	3,011,168.6	1,539.2	0.9	0.5
03/19/2020 17:00	9.0	13.4	7.1	117.3	3,370,120.0	2,018.0	1.1	0.8
03/19/2020 18:00	8.7	13.3	6.8	124.2	3,363,893.2	2,063.4	1.2	1.0
03/19/2020 19:00	8.6	13.2	6.6	130.3	3,358,752.2	2,109.3	1.2	1.1
03/19/2020 20:00	8.5	13.2	6.5	127.3	3,404,066.8	2,112.9	1.2	1.1
03/19/2020 21:00	8.4	13.2	6.4	123.2	3,373,456.1	2,093.9	1.2	1.0
03/19/2020 22:00	8.2	13.3	6.4	118.7	3,433,955.4	2,081.3	1.1	0.8
03/19/2020 23:00	8.2	13.3	6.4	114.3	3,441,820.0	2,035.8	1.1	0.8
Average/Sum#:	7.9	13.5	6.3	104.2	3,255,058.3	1,850.0	1.0	0.7
Minimum:	7.0	13.2	5.8	78.8	2,542,825.4	1,299.8	0.9	0.4
Maximum:	9.0	13.9	7.1	130.3	3,477,109.0	2,112.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/20/2020 00:00	8.2	13.4	6.5	110.8	3,477,139.7	2,031.3	1.0	0.8
03/20/2020 01:00	8.2	13.4	6.5	113.0	3,479,536.2	2,032.7	1.0	0.8
03/20/2020 02:00	8.2	13.4	6.5	112.5	3,433,535.8	2,030.9	1.0	0.8
03/20/2020 03:00	8.2	13.4	6.5	112.0	3,474,400.8	2,029.7	1.0	0.8
03/20/2020 04:00	8.2	13.4	6.5	111.9	3,474,572.0	2,029.8	1.0	0.8
03/20/2020 05:00	7.7	13.5	6.1	104.8	3,481,849.3	1,983.2	1.0	0.8
03/20/2020 06:00	8.4	13.3	6.5	117.6	3,507,609.4	2,049.1	1.1	0.8
03/20/2020 07:00	7.7	13.6	6.2	102.6	3,430,141.3	1,928.7	0.9	0.6
03/20/2020 08:00	7.0	13.8	5.8	90.3	3,119,201.6	1,617.2	0.9	0.5
03/20/2020 09:00	7.3	13.9	6.2	78.4	2,702,265.6	1,381.3	0.9	0.4
03/20/2020 10:00	7.4	13.8	6.1	93.0	3,201,559.9	1,659.9	0.9	0.5
03/20/2020 11:00	7.2	13.9	6.1	87.4	3,047,556.2	1,557.8	0.9	0.5
03/20/2020 12:00	7.3	13.9	6.2	85.8	2,987,692.7	1,527.2	0.9	0.5
03/20/2020 13:00	7.5	13.9	6.3	93.2	3,217,560.4	1,644.7	0.9	0.5
03/20/2020 14:00	7.3	13.9	6.2	86.6	2,996,887.4	1,531.9	0.9	0.5
03/20/2020 15:00	7.7	13.8	6.4	89.8	3,094,116.6	1,581.6	0.9	0.5
03/20/2020 16:00	9.1	13.4	7.2	116.8	3,391,438.7	2,006.0	1.1	0.8
03/20/2020 17:00	8.8	13.3	6.8	125.0	3,369,608.9	2,042.3	1.2	1.0
03/20/2020 18:00	8.6	13.3	6.7	124.4	3,370,433.9	2,042.8	1.2	1.0
03/20/2020 19:00	8.5	13.3	6.6	123.3	3,391,387.7	2,055.5	1.2	1.0
03/20/2020 20:00	8.5	13.3	6.6	124.3	3,388,836.3	2,078.7	1.2	1.0
03/20/2020 21:00	8.4	13.3	6.5	123.3	3,374,100.6	2,094.3	1.2	1.0
03/20/2020 22:00	8.4	13.3	6.5	121.5	3,380,195.9	2,073.4	1.2	1.0
03/20/2020 23:00	8.2	13.3	6.4	114.7	3,402,017.6	2,037.1	1.1	0.8
Average/Sum#:	8.0	13.5	6.4	106.8	3,299,735.2	1,877.0	1.0	0.7
Minimum:	7.0	13.3	5.8	78.4	2,702,265.6	1,381.3	0.9	0.4
Maximum:	9.1	13.9	7.2	125.0	3,507,609.4	2,094.3	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/21/2020 00:00	8.2	13.3	6.4	116.2	3,458,297.6	2,070.8	1.1	0.8
03/21/2020 01:00	8.3	13.3	6.4	118.9	3,450,289.5	2,091.2	1.1	0.8
03/21/2020 02:00	8.3	13.3	6.4	119.4	3,400,248.1	2,085.7	1.1	0.8
03/21/2020 03:00	8.3	13.3	6.4	122.4	3,414,268.4	2,094.3	1.2	1.0
03/21/2020 04:00	8.3	13.3	6.4	119.3	3,405,412.0	2,064.0	1.1	0.8
03/21/2020 05:00	8.3	13.3	6.4	118.7	3,392,047.7	2,055.9	1.1	0.8
03/21/2020 06:00	8.2	13.4	6.5	118.2	3,515,031.5	2,002.1	1.1	0.8
03/21/2020 07:00	15.4	14.8	14.9	134.0	2,569,810.4	1,201.0	1.6	0.7
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.2	13.5	7.5	120.9	3,325,675.7	1,958.1	1.2	0.8
Minimum:	8.2	13.3	6.4	116.2	2,569,810.4	1,201.0	1.1	0.7
Maximum:	15.4	14.8	14.9	134.0	3,515,031.5	2,094.3	1.6	1.0
%SI	66.67	66.67	66.67	66.67	66.67	66.67	66.67	66.67

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/22/2020 17:00	38.2	17.4	64.4	0.0	1,928,813.5	464.8	-0.1	0.0
03/22/2020 18:00	36.6	17.1	56.8	246.6	1,880,796.3	521.9	3.8	0.8
03/22/2020 19:00	33.4	15.4	35.8	235.4	2,335,122.2	920.8	3.0	1.1
03/22/2020 20:00	6.7	13.9	5.6	84.3	2,892,811.2	1,478.7	0.9	0.4
03/22/2020 21:00	7.0	13.9	5.9	78.6	2,771,128.1	1,416.5	0.9	0.4
03/22/2020 22:00	7.1	13.9	6.0	79.1	2,816,514.7	1,439.7	0.9	0.4
03/22/2020 23:00	7.1	13.8	5.9	82.5	2,890,854.9	1,477.7	0.9	0.4
Average/Sum#:	19.4	15.1	25.8	115.2	2,502,291.6	1,102.9	1.5	0.5
Minimum:	6.7	13.8	5.6	0.0	1,880,796.3	464.8	-0.1	0.0
Maximum:	38.2	17.4	64.4	246.6	2,892,811.2	1,478.7	3.8	1.1
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/23/2020 00:00	7.2	13.9	6.1	77.2	2,675,855.2	1,367.8	0.9	0.4
03/23/2020 01:00	7.2	13.9	6.1	78.6	2,643,576.0	1,351.3	0.9	0.4
03/23/2020 02:00	29.6	17.1	46.0	201.0	1,094,902.6	343.8	5.7	0.8
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/23/2020 17:00	40.1	17.4	67.6	12.3	1,918,024.1	462.2	0.0	0.0
03/23/2020 18:00	37.2	17.2	59.3	250.4	1,880,075.5	521.7	3.8	0.8
03/23/2020 19:00	37.0	15.5	40.4	246.8	2,232,678.5	864.1	3.4	1.1
03/23/2020 20:00	6.7	13.8	5.6	88.5	3,035,035.7	1,551.4	0.9	0.5
03/23/2020 21:00	7.1	13.9	6.0	85.3	3,009,799.2	1,538.5	0.9	0.5
03/23/2020 22:00	7.1	13.8	5.9	83.9	3,027,992.9	1,547.8	0.9	0.5
03/23/2020 23:00	7.2	13.8	6.0	92.0	3,178,800.5	1,648.1	0.9	0.5
Average/Sum#:	18.6	15.0	24.9	121.6	2,469,674.0	1,119.7	1.8	0.6
Minimum:	6.7	13.8	5.6	12.3	1,094,902.6	343.8	0.0	0.0
Maximum:	40.1	17.4	67.6	250.4	3,178,800.5	1,648.1	5.7	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/24/2020 00:00	7.3	13.9	6.2	80.7	2,802,037.9	1,432.3	0.9	0.4
03/24/2020 01:00	7.5	13.9	6.3	77.8	2,698,548.6	1,379.4	0.9	0.4
03/24/2020 02:00	7.3	13.8	6.1	87.8	3,048,801.6	1,580.7	0.9	0.5
03/24/2020 03:00	7.3	13.8	6.1	87.3	2,940,790.6	1,524.7	0.9	0.5
03/24/2020 04:00	7.5	13.8	6.2	96.2	3,327,508.4	1,725.2	0.9	0.5
03/24/2020 05:00	7.7	13.7	6.3	95.7	3,280,060.7	1,700.6	0.9	0.5
03/24/2020 06:00	7.2	13.8	6.0	94.6	3,253,636.6	1,686.9	0.9	0.5
03/24/2020 07:00	7.3	13.8	6.1	95.3	3,281,796.6	1,701.5	0.9	0.5
03/24/2020 08:00	7.3	13.8	6.1	88.5	3,038,386.2	1,575.3	0.9	0.5
03/24/2020 09:00	7.3	13.8	6.1	94.1	3,243,414.1	1,681.6	0.9	0.5
03/24/2020 10:00	7.3	13.8	6.1	95.1	3,282,375.2	1,701.8	0.9	0.5
03/24/2020 11:00	7.3	13.8	6.1	91.4	3,113,608.1	1,614.3	0.9	0.5
03/24/2020 12:00	7.4	13.8	6.1	92.4	3,178,800.5	1,648.1	0.9	0.5
03/24/2020 13:00	7.2	13.9	6.1	86.9	3,028,579.8	1,548.1	0.9	0.5
03/24/2020 14:00	7.2	13.9	6.1	87.8	3,072,792.7	1,570.7	0.9	0.5
03/24/2020 15:00	7.2	13.9	6.1	89.1	3,104,485.1	1,586.9	0.9	0.5
03/24/2020 16:00	7.4	13.9	6.2	89.5	3,139,307.6	1,604.7	0.9	0.5
03/24/2020 17:00	8.9	13.4	7.0	113.6	3,374,462.1	2,020.6	1.1	0.8
03/24/2020 18:00	8.5	13.4	6.7	112.7	3,417,398.6	1,996.4	1.0	0.8
03/24/2020 19:00	8.1	13.4	6.4	110.6	3,413,586.1	2,019.1	1.0	0.8
03/24/2020 20:00	8.5	13.3	6.6	123.0	3,399,555.8	2,110.1	1.2	1.1
03/24/2020 21:00	8.3	13.3	6.4	116.6	3,418,049.9	2,046.7	1.1	0.8
03/24/2020 22:00	8.2	13.3	6.4	112.9	3,461,262.4	2,047.3	1.0	0.8
03/24/2020 23:00	14.8	14.7	14.1	134.2	2,581,365.0	1,244.1	1.6	0.7
Average/Sum#:	7.9	13.7	6.6	98.1	3,162,525.4	1,697.8	1.0	0.6
Minimum:	7.2	13.3	6.0	77.8	2,581,365.0	1,244.1	0.9	0.4
Maximum:	14.8	14.7	14.1	134.2	3,461,262.4	2,110.1	1.6	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/27/2020 17:00	36.9	17.3	60.5	23.0	1,946,193.7	483.2	0.3	0.0
03/27/2020 18:00	36.4	17.2	58.0	260.7	1,939,401.0	524.0	3.9	0.8
03/27/2020 19:00	39.3	15.4	42.2	243.1	2,197,303.7	882.5	3.4	1.1
03/27/2020 20:00	6.6	13.9	5.6	90.3	3,126,395.9	1,598.1	0.9	0.5
03/27/2020 21:00	7.0	13.9	5.9	79.2	2,792,843.2	1,427.6	0.9	0.4
03/27/2020 22:00	7.2	13.9	6.1	79.7	2,793,821.4	1,428.1	0.9	0.4
03/27/2020 23:00	7.2	13.8	6.0	92.9	3,247,464.6	1,683.7	0.9	0.5
Average/Sum#:	20.1	15.1	26.3	124.1	2,577,631.9	1,146.7	1.6	0.5
Minimum:	6.6	13.8	5.6	23.0	1,939,401.0	483.2	0.3	0.0
Maximum:	39.3	17.3	60.5	260.7	3,247,464.6	1,683.7	3.9	1.1
%SI	70.83	70.83	70.83	70.83	70.83	70.83	70.83	70.83

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/28/2020 00:00	7.2	13.8	6.0	84.5	2,962,456.2	1,514.3	0.9	0.5
03/28/2020 01:00	7.2	13.8	6.0	93.2	3,247,657.4	1,683.8	0.9	0.5
03/28/2020 02:00	7.2	13.8	6.0	93.9	3,266,173.6	1,693.4	0.9	0.5
03/28/2020 03:00	7.2	13.8	6.0	94.2	3,271,959.9	1,696.4	0.9	0.5
03/28/2020 04:00	7.2	13.8	6.0	93.2	3,234,348.9	1,676.9	0.9	0.5
03/28/2020 05:00	7.2	13.8	6.0	93.5	3,237,820.7	1,678.7	0.9	0.5
03/28/2020 06:00	7.3	13.8	6.1	89.4	3,008,104.6	1,559.6	0.9	0.5
03/28/2020 07:00	7.4	13.8	6.1	86.0	2,945,226.8	1,527.0	0.9	0.5
03/28/2020 08:00	7.3	13.8	6.1	91.4	3,162,020.2	1,639.4	0.9	0.5
03/28/2020 09:00	7.2	13.8	6.0	92.8	3,211,782.4	1,665.2	0.9	0.5
03/28/2020 10:00	7.3	13.8	6.1	94.1	3,264,823.5	1,692.7	0.9	0.5
03/28/2020 11:00	7.4	13.8	6.1	94.9	3,275,817.4	1,698.4	0.9	0.5
03/28/2020 12:00	7.4	13.8	6.1	94.5	3,255,565.4	1,687.9	0.9	0.5
03/28/2020 13:00	7.4	13.8	6.1	94.9	3,262,894.7	1,691.7	0.9	0.5
03/28/2020 14:00	7.3	13.8	6.1	93.7	3,221,426.2	1,670.2	0.9	0.5
03/28/2020 15:00	7.5	13.8	6.2	94.0	3,268,033.5	1,670.5	0.9	0.5
03/28/2020 16:00	7.5	13.8	6.2	95.6	3,276,588.9	1,698.8	0.9	0.5
03/28/2020 17:00	8.2	13.6	6.6	104.4	3,326,620.1	1,846.2	1.0	0.7
03/28/2020 18:00	8.6	13.2	6.6	121.0	3,406,322.3	2,114.3	1.1	0.8
03/28/2020 19:00	8.3	13.3	6.4	116.8	3,391,444.7	2,080.3	1.1	0.8
03/28/2020 20:00	8.4	13.2	6.4	121.4	3,371,968.7	2,117.6	1.2	1.1
03/28/2020 21:00	8.2	13.3	6.4	114.7	3,406,401.9	2,064.6	1.1	0.8
03/28/2020 22:00	8.3	13.3	6.4	113.8	3,391,222.7	2,055.4	1.1	0.8
03/28/2020 23:00	8.0	13.4	6.3	108.2	3,370,324.6	1,968.9	1.0	0.8
Average/Sum#:	7.6	13.7	6.2	98.9	3,251,541.9	1,766.3	1.0	0.6
Minimum:	7.2	13.2	6.0	84.5	2,945,226.8	1,514.3	0.9	0.5
Maximum:	8.6	13.8	6.6	121.4	3,406,401.9	2,117.6	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/29/2020 00:00	6.9	13.8	5.7	90.9	3,176,100.2	1,646.7	0.9	0.5
03/29/2020 01:00	7.1	13.8	5.9	89.5	3,098,563.8	1,606.5	0.9	0.5
03/29/2020 02:00	7.1	13.8	5.9	90.1	3,115,729.8	1,615.4	0.9	0.5
03/29/2020 03:00	7.2	13.8	6.0	87.6	3,017,748.4	1,564.6	0.9	0.5
03/29/2020 04:00	7.2	13.8	6.0	94.3	3,278,710.6	1,699.9	0.9	0.5
03/29/2020 05:00	7.3	13.8	6.1	91.2	3,116,308.4	1,615.7	0.9	0.5
03/29/2020 06:00	7.4	13.8	6.1	88.3	3,072,911.2	1,593.2	0.9	0.5
03/29/2020 07:00	7.4	13.8	6.1	92.0	3,121,130.3	1,618.2	0.9	0.5
03/29/2020 08:00	7.4	13.8	6.1	90.3	3,091,813.1	1,603.0	0.9	0.5
03/29/2020 09:00	7.3	13.8	6.1	94.0	3,238,785.1	1,679.2	0.9	0.5
03/29/2020 10:00	7.4	13.8	6.1	95.6	3,283,918.2	1,702.6	0.9	0.5
03/29/2020 11:00	7.5	13.8	6.2	95.0	3,239,170.9	1,679.4	0.9	0.5
03/29/2020 12:00	7.5	13.8	6.2	89.8	3,073,575.2	1,571.1	0.9	0.5
03/29/2020 13:00	7.4	13.8	6.1	90.9	3,113,993.9	1,614.5	0.9	0.5
03/29/2020 14:00	7.6	13.8	6.3	91.2	3,125,809.0	1,597.8	0.9	0.5
03/29/2020 15:00	7.5	13.9	6.3	91.3	3,121,700.7	1,595.7	0.9	0.5
03/29/2020 16:00	7.5	13.8	6.2	93.1	3,233,015.3	1,652.6	0.9	0.5
03/29/2020 17:00	7.6	13.8	6.3	89.4	3,012,540.8	1,561.9	0.9	0.5
03/29/2020 18:00	9.0	13.3	7.0	116.1	3,343,210.4	2,026.3	1.1	0.8
03/29/2020 19:00	8.8	13.1	6.7	128.2	3,339,007.0	2,096.9	1.2	1.0
03/29/2020 20:00	8.6	13.2	6.6	124.9	3,349,450.9	2,079.0	1.2	1.0
03/29/2020 21:00	8.5	13.2	6.5	124.8	3,341,878.8	2,074.3	1.2	1.0
03/29/2020 22:00	8.1	13.4	6.4	107.9	3,382,478.2	1,951.3	1.0	0.8
03/29/2020 23:00	8.1	13.3	6.3	111.3	3,352,522.1	1,958.5	1.1	0.8
Average/Sum#:	7.6	13.7	6.2	98.2	3,193,336.3	1,725.2	1.0	0.6
Minimum:	6.9	13.1	5.7	87.6	3,012,540.8	1,561.9	0.9	0.5
Maximum:	9.0	13.9	7.0	128.2	3,382,478.2	2,096.9	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/30/2020 00:00	7.0	13.8	5.8	93.7	3,255,565.4	1,687.9	0.9	0.5
03/30/2020 01:00	7.1	13.8	5.9	93.6	3,257,494.1	1,688.9	0.9	0.5
03/30/2020 02:00	7.2	13.8	6.0	93.6	3,234,734.7	1,677.1	0.9	0.5
03/30/2020 03:00	7.3	13.8	6.1	92.5	3,182,079.4	1,649.8	0.9	0.5
03/30/2020 04:00	7.2	13.8	6.0	91.2	3,136,753.3	1,626.3	0.9	0.5
03/30/2020 05:00	7.3	13.8	6.1	93.8	3,236,084.8	1,677.8	0.9	0.5
03/30/2020 06:00	7.4	13.8	6.1	93.3	3,253,636.6	1,686.9	0.9	0.5
03/30/2020 07:00	7.4	13.8	6.1	93.8	3,209,082.1	1,663.8	0.9	0.5
03/30/2020 08:00	7.3	13.8	6.1	92.3	3,164,527.6	1,640.7	0.9	0.5
03/30/2020 09:00	7.4	13.8	6.1	93.9	3,210,239.4	1,664.4	0.9	0.5
03/30/2020 10:00	7.5	13.8	6.2	94.4	3,260,990.7	1,666.9	0.9	0.5
03/30/2020 11:00	7.4	13.9	6.2	92.7	3,210,713.3	1,641.2	0.9	0.5
03/30/2020 12:00	7.3	13.8	6.1	90.6	3,143,220.2	1,606.7	0.9	0.5
03/30/2020 13:00	7.5	13.9	6.3	90.5	3,121,896.3	1,595.8	0.9	0.5
03/30/2020 14:00	7.5	13.8	6.2	94.1	3,231,254.6	1,651.7	0.9	0.5
03/30/2020 15:00	7.4	13.9	6.2	90.7	3,155,936.3	1,613.2	0.9	0.5
03/30/2020 16:00	7.5	13.8	6.2	94.2	3,254,534.9	1,663.6	0.9	0.5
03/30/2020 17:00	7.5	13.8	6.2	92.9	3,242,405.7	1,657.4	0.9	0.5
03/30/2020 18:00	8.9	13.3	6.9	113.9	3,345,403.6	2,003.2	1.1	0.8
03/30/2020 19:00	8.8	13.2	6.7	121.3	3,341,069.4	2,049.4	1.2	1.0
03/30/2020 20:00	8.7	13.1	6.6	130.6	3,349,516.5	2,103.5	1.3	1.1
03/30/2020 21:00	8.6	13.1	6.5	131.2	3,349,357.3	2,103.4	1.3	1.1
03/30/2020 22:00	8.4	13.2	6.4	125.1	3,366,850.7	2,089.8	1.2	1.0
03/30/2020 23:00	8.4	13.3	6.5	117.2	3,383,313.2	2,025.9	1.1	0.8
Average/Sum#:	7.7	13.7	6.2	100.5	3,245,694.2	1,755.6	1.0	0.6
Minimum:	7.0	13.1	5.8	90.5	3,121,896.3	1,595.8	0.9	0.5
Maximum:	8.9	13.9	6.9	131.2	3,383,313.2	2,103.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 08:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
03/31/2020 00:00	8.4	13.2	6.4	117.4	3,355,254.7	2,033.6	1.1	0.8
03/31/2020 01:00	8.4	13.3	6.5	117.2	3,355,419.7	2,033.7	1.1	0.8
03/31/2020 02:00	8.3	13.3	6.4	115.7	3,398,677.5	2,035.1	1.1	0.8
03/31/2020 03:00	8.3	13.3	6.4	114.8	3,394,836.4	2,032.8	1.1	0.8
03/31/2020 04:00	8.3	13.3	6.4	112.4	3,411,219.2	2,017.7	1.1	0.8
03/31/2020 05:00	7.8	13.5	6.2	103.0	3,421,103.0	1,948.6	1.0	0.8
03/31/2020 06:00	8.5	13.3	6.6	117.7	3,395,003.5	2,032.9	1.1	0.8
03/31/2020 07:00	14.8	14.7	14.1	134.3	2,527,003.0	1,217.9	1.6	0.7
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
03/31/2020 18:00	38.8	17.3	63.6	100.7	1,891,819.5	469.7	1.4	0.2
03/31/2020 19:00	40.3	15.1	41.0	242.5	2,208,857.5	919.4	3.4	1.2
03/31/2020 20:00	6.8	13.9	5.7	82.8	2,798,712.2	1,430.6	0.9	0.4
03/31/2020 21:00	7.2	13.9	6.1	76.4	2,640,837.1	1,349.9	0.9	0.4
03/31/2020 22:00	7.3	13.9	6.2	77.4	2,659,226.5	1,359.3	0.9	0.4
03/31/2020 23:00	7.2	13.9	6.1	84.5	2,954,044.0	1,510.0	0.9	0.5
Average/Sum#:	12.9	14.0	13.4	114.1	2,958,001.0	1,599.4	1.3	0.7
Minimum:	6.8	13.2	5.7	76.4	1,891,819.5	469.7	0.9	0.2
Maximum:	40.3	17.3	63.6	242.5	3,421,103.0	2,035.1	3.4	1.2
%SI	41.67	41.67	41.67	41.67	41.67	41.67	41.67	41.67

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2019 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 08:59 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 3,407.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 985.00 Hour(s) Report Time: 4,392.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**3,407.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:00 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,348.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 836.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,348.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:00 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:01 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 13

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:02 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	3.3	1.1	0.4	2.5	0.0
February	3.0	0.9	0.4	2.0	0.0
March	3.6	0.8	0.5	2.5	0.0
Quarter 1	9.9	2.8	1.3	7.0	0.0
YTD	9.9	2.8	1.3	7.0	0.0

Cumulative Emissions Report

CT1

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:08 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
January	7,994,043	618,742	8,612,781.9	487	133.2
February	6,279,580	518,657	6,798,234.6	381	140.3
March	7,993,503	789,486	8,782,986.1	480	142.1
Quarter 1	22,267,126	1,926,885	24,194,002.6	1,348	138.5
YTD	22,267,126	1,926,885	24,194,002.6	1,348	138.5

Cumulative Emissions Report

CT2

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:08 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	8,607,222	613,441	9,220,664.7	527	56,238.7
February	7,034,272	533,494	7,567,762.9	431	46,062.6
March	8,536,618	746,653	9,283,266.3	523	57,568.8
Quarter 1	24,178,112	1,893,588	26,071,693.9	1,481	159,870.1
YTD	24,178,112	1,893,588	26,071,693.9	1,481	159,870.1

Monthly Summary By Day Report

VOC PM10

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
01/01/2020	3.1	11.4	1.3	13.7
01/02/2020	20.3	72.5	11.6	115.8
01/03/2020	31.5	113.1	13.6	135.7
01/04/2020	0.0	0.0	0.0	0.0
01/05/2020	0.0	0.0	0.0	0.0
01/06/2020	19.4	69.9	9.8	97.7
01/07/2020	29.4	106.1	12.7	127.3
01/08/2020	0.0	0.0	0.6	5.2
01/09/2020	26.0	93.1	12.4	126.0
01/10/2020	33.0	117.8	13.8	140.8
01/11/2020	11.7	42.5	5.0	50.8
01/12/2020	0.0	0.0	0.0	0.6
01/13/2020	23.9	85.8	12.1	122.5
01/14/2020	32.4	115.8	13.7	139.0
01/15/2020	32.8	118.3	14.1	142.1
01/16/2020	32.5	116.5	13.9	140.4
01/17/2020	32.9	117.4	14.0	141.1
01/18/2020	32.1	115.9	13.7	139.1
01/19/2020	29.7	106.6	12.8	128.1
01/20/2020	35.3	126.1	14.4	150.2
01/21/2020	32.3	116.3	13.8	139.6
01/22/2020	28.8	103.3	12.4	124.4
01/23/2020	32.2	114.9	13.6	138.1
01/24/2020	28.9	102.7	12.3	123.5
01/25/2020	0.0	0.0	0.0	0.0
01/26/2020	0.0	0.0	0.0	0.0
01/27/2020	0.0	0.0	1.8	17.8
01/28/2020	22.3	79.2	11.3	113.1
01/29/2020	0.0	0.0	2.9	28.6
01/30/2020	25.5	91.6	12.4	124.6
01/31/2020	21.8	77.3	11.5	117.2
Monthly Avg/Sum*:	617.8 *	2,214.1 *	281.5 *	2,843.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.3	126.1	14.4	150.2
Jan 2020 - Jan 2020	617.8	2,214.1	281.5	2,843.0
QTD:	617.8 *	2,214.1 *	281.5 *	2,843.0 *
YTD 2020:	617.8 *	2,214.1 *	281.5 *	2,843.0 *

Monthly Summary By Day Report

VOC PM10

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
02/01/2020	0.0	0.0	0.0	0.0
02/02/2020	0.0	0.0	0.1	1.1
02/03/2020	24.5	87.3	12.1	121.1
02/04/2020	33.3	119.9	14.0	143.3
02/05/2020	33.0	117.4	14.0	140.8
02/06/2020	32.3	114.3	13.6	137.6
02/07/2020	29.9	105.6	12.7	127.5
02/08/2020	0.0	0.0	0.0	0.0
02/09/2020	0.0	0.0	0.1	1.0
02/10/2020	24.6	87.0	11.9	120.4
02/11/2020	28.8	103.1	12.4	123.3
02/12/2020	29.2	104.0	12.5	124.6
02/13/2020	32.3	115.9	13.6	138.2
02/14/2020	1.1	3.8	0.5	4.7
02/15/2020	0.0	0.0	0.0	0.0
02/16/2020	0.0	0.0	0.0	0.0
02/17/2020	10.8	38.6	6.6	67.2
02/18/2020	33.7	120.7	14.2	144.1
02/19/2020	34.0	122.5	14.7	146.7
02/20/2020	33.4	120.8	14.4	146.4
02/21/2020	28.4	100.6	12.3	123.3
02/22/2020	0.0	0.0	0.0	0.0
02/23/2020	0.0	0.0	0.0	0.0
02/24/2020	0.0	0.0	5.4	53.9
02/25/2020	11.9	42.0	12.0	121.3
02/26/2020	11.6	41.7	9.6	97.0
02/27/2020	26.6	94.4	12.6	129.7
02/28/2020	27.5	98.8	12.3	120.7
02/29/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	486.9 *	1,738.4 *	231.6 *	2,333.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	34.0	122.5	14.7	146.7
Jan 2020 - Feb 2020	1,104.7	3,952.5	513.1	5,176.9
QTD:	1,104.7 *	3,952.5 *	513.1 *	5,176.9 *
YTD 2020:	1,104.7 *	3,952.5 *	513.1 *	5,176.9 *

Monthly Summary By Day Report

VOC PM10

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
03/01/2020	0.0	0.0	0.0	0.0
03/02/2020	0.0	0.0	0.0	0.0
03/03/2020	10.9	38.6	6.8	70.2
03/04/2020	30.8	110.1	13.3	133.9
03/05/2020	31.1	111.1	13.4	135.7
03/06/2020	31.5	113.1	13.6	138.0
03/07/2020	0.4	1.5	0.2	1.9
03/08/2020	0.0	0.0	1.1	10.7
03/09/2020	28.1	100.0	13.1	133.7
03/10/2020	35.7	126.8	14.7	152.8
03/11/2020	31.4	111.8	13.5	136.3
03/12/2020	33.1	118.7	14.1	142.4
03/13/2020	32.8	117.3	13.8	140.5
03/14/2020	32.7	116.4	13.6	140.9
03/15/2020	32.1	115.3	13.9	140.1
03/16/2020	35.6	126.5	14.9	152.7
03/17/2020	32.5	115.8	13.6	141.6
03/18/2020	31.1	111.5	13.5	135.7
03/19/2020	30.9	109.5	13.3	133.0
03/20/2020	30.8	111.0	13.5	135.0
03/21/2020	10.4	37.2	4.4	45.2
03/22/2020	0.0	0.0	2.2	22.7
03/23/2020	0.0	0.0	3.4	32.4
03/24/2020	24.5	86.5	12.1	120.1
03/25/2020	0.0	0.0	0.0	0.0
03/26/2020	0.0	0.0	0.0	0.0
03/27/2020	0.3	1.1	2.4	24.0
03/28/2020	29.1	102.7	12.7	127.2
03/29/2020	28.4	101.5	12.6	124.1
03/30/2020	28.9	103.7	12.6	126.4
03/31/2020	10.1	36.3	6.5	65.2
Monthly Avg/Sum*:	623.2 *	2,224.0 *	282.8 *	2,862.4 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.7	126.8	14.9	152.8
Jan 2020 - Mar 2020	1,727.9	6,176.5	795.9	8,039.3
QTD:	1,727.9 *	6,176.5 *	795.9 *	8,039.3 *
YTD 2020:	1,727.9 *	6,176.5 *	795.9 *	8,039.3 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
01/01/2020	9.7	18.05	2.7	6.1	18.61	2.7
01/02/2020	106.8	175.23	17.6	157.7	243.36	23.1
01/03/2020	23.3	121.18	26.9	6.5	136.48	26.9
01/04/2020	0.0	0.00	0.0	0.0	0.00	0.0
01/05/2020	0.0	0.00	0.0	0.0	0.00	0.0
01/06/2020	114.3	191.62	16.5	155.4	235.27	19.4
01/07/2020	20.2	116.35	25.3	5.6	109.27	25.3
01/08/2020	0.0	0.00	0.0	132.1	115.12	1.0
01/09/2020	110.1	187.21	22.4	0.0	90.30	25.3
01/10/2020	18.0	119.90	28.0	0.0	148.50	28.0
01/11/2020	15.3	57.61	10.0	5.6	57.61	10.0
01/12/2020	0.0	0.00	0.0	74.1	32.58	0.1
01/13/2020	194.6	234.52	20.6	93.8	194.00	24.6
01/14/2020	30.4	132.70	27.5	0.0	145.50	27.5
01/15/2020	30.3	142.10	28.3	0.0	146.90	28.3
01/16/2020	32.9	142.10	27.7	0.0	139.70	27.8
01/17/2020	31.7	145.10	28.2	0.0	150.70	28.1
01/18/2020	27.6	139.00	27.8	0.0	142.70	27.8
01/19/2020	15.5	127.80	25.6	0.0	88.30	25.7
01/20/2020	43.0	153.60	30.4	0.0	191.90	30.3
01/21/2020	33.3	139.60	27.6	0.0	144.60	27.6
01/22/2020	15.0	124.10	25.0	0.0	90.40	25.0
01/23/2020	27.8	137.80	27.9	0.0	133.40	27.9
01/24/2020	20.3	126.55	24.8	5.3	84.95	24.9
01/25/2020	0.0	0.00	0.0	0.0	0.00	0.0
01/26/2020	0.0	0.00	0.0	0.0	0.00	0.0
01/27/2020	0.0	0.00	0.0	164.8	131.70	3.5
01/28/2020	138.6	215.89	19.1	5.3	75.91	22.6
01/29/2020	0.0	0.00	0.0	101.9	171.72	5.7
01/30/2020	103.6	215.18	22.1	0.0	79.70	24.9
01/31/2020	79.1	139.38	18.8	5.8	70.38	23.5
Monthly Avg/Sum*:	1,241.4 *	3,302.57 *	530.8 *	920.0 *	3,369.56 *	567.5 *
Daily Min:	0.0	0.00	0.0	0.0	0.00	0.0
Daily Max:	194.6	234.52	30.4	164.8	243.36	30.3
Jan 2020 - Jan 2020	1,241.4	3,302.57	530.8	920.0	3,369.56	567.5
QTD:	1,241.4 *	3,302.57 *	530.8 *	920.0 *	3,369.56 *	567.5 *
YTD 2020:	1,241.4 *	3,302.57 *	530.8 *	920.0 *	3,369.56 *	567.5 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
02/01/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/02/2020	0.0	0.00	0.0	73.4	73.01	0.2
02/03/2020	134.2	239.76	20.9	76.8	164.30	24.0
02/04/2020	26.8	148.50	29.0	0.0	152.40	28.9
02/05/2020	30.4	152.90	28.3	0.0	150.70	28.2
02/06/2020	30.4	139.30	27.6	0.0	138.00	27.6
02/07/2020	27.8	129.84	25.3	6.1	110.90	25.5
02/08/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/09/2020	0.0	0.00	0.0	67.6	66.22	0.2
02/10/2020	164.8	294.72	20.9	93.5	216.80	24.1
02/11/2020	11.5	120.30	24.7	0.0	81.90	24.7
02/12/2020	11.1	121.50	24.9	0.0	81.90	24.9
02/13/2020	33.3	138.70	27.9	0.0	147.80	27.8
02/14/2020	10.0	9.22	0.9	6.0	10.77	0.9
02/15/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/16/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/17/2020	109.6	199.58	9.2	189.3	284.10	13.3
02/18/2020	40.1	143.90	28.9	0.0	172.00	28.8
02/19/2020	52.4	150.60	29.0	0.0	184.40	29.7
02/20/2020	46.2	148.50	28.7	0.0	181.70	29.4
02/21/2020	21.1	123.90	24.1	5.1	89.77	24.6
02/22/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/23/2020	0.0	0.00	0.0	0.0	0.00	0.0
02/24/2020	0.0	0.00	0.0	137.2	275.49	10.9
02/25/2020	111.2	217.75	10.3	0.0	84.10	24.2
02/26/2020	21.8	53.38	9.9	39.1	210.19	19.3
02/27/2020	98.3	263.60	22.3	0.0	95.40	26.2
02/28/2020	26.0	125.12	23.7	5.7	94.00	24.0
02/29/2020	0.0	0.00	0.0	0.0	0.00	0.0
Monthly Avg/Sum*:	1,007.0 *	2,921.07 *	416.5 *	699.8 *	3,065.85 *	467.4 *
Daily Min:	10.0	9.22	0.9	0.0	10.77	0.2
Daily Max:	164.8	294.72	29.0	189.3	284.10	29.7
Jan 2020 - Feb 2020	2,248.4	6,223.64	947.3	1,619.8	6,435.41	1,034.9
QTD:	2,248.4 *	6,223.64 *	947.3 *	1,619.8 *	6,435.41 *	1,034.9 *
YTD 2020:	2,248.4 *	6,223.64 *	947.3 *	1,619.8 *	6,435.41 *	1,034.9 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:09 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
03/01/2020	0.0	0.00	0.0	0.0	0.00	0.0
03/02/2020	0.0	0.00	0.0	0.0	0.00	0.0
03/03/2020	97.6	206.37	9.2	193.8	298.47	13.9
03/04/2020	29.2	134.00	26.4	0.0	137.00	26.5
03/05/2020	31.8	133.60	26.7	0.0	137.50	26.8
03/06/2020	37.0	139.80	27.2	0.0	143.50	27.4
03/07/2020	7.4	4.75	0.4	6.3	7.30	0.4
03/08/2020	0.0	0.00	0.0	122.3	121.81	2.1
03/09/2020	131.8	231.50	24.1	0.0	117.10	26.8
03/10/2020	31.0	147.90	30.7	0.0	195.60	30.9
03/11/2020	20.6	135.30	27.0	0.0	153.00	27.1
03/12/2020	19.2	139.60	28.2	0.0	170.50	28.5
03/13/2020	19.7	142.90	28.2	0.0	165.80	28.3
03/14/2020	19.7	139.20	27.8	0.0	154.80	28.3
03/15/2020	21.3	136.70	27.3	0.0	158.00	27.8
03/16/2020	33.9	154.10	30.7	0.0	203.90	30.7
03/17/2020	24.1	141.10	27.4	0.0	162.20	28.6
03/18/2020	21.3	132.80	27.0	0.0	155.80	27.0
03/19/2020	25.2	129.30	26.2	0.0	147.80	26.8
03/20/2020	23.0	145.80	26.5	0.0	155.10	26.7
03/21/2020	17.5	48.96	8.7	5.7	62.67	9.0
03/22/2020	0.0	0.00	0.0	109.0	161.98	4.6
03/23/2020	0.0	0.00	0.0	97.1	168.33	6.3
03/24/2020	145.2	231.13	20.7	5.3	111.48	23.9
03/25/2020	0.0	0.00	0.0	0.0	0.00	0.0
03/26/2020	0.0	0.00	0.0	0.0	0.00	0.0
03/27/2020	88.3	87.33	0.3	136.2	192.40	4.9
03/28/2020	45.7	164.10	24.8	0.0	111.60	25.2
03/29/2020	4.3	114.20	24.1	0.0	107.00	25.0
03/30/2020	8.7	122.90	25.2	0.0	109.10	25.5
03/31/2020	16.6	47.08	8.7	68.7	190.94	13.0
Monthly Avg/Sum*:	920.1 *	3,210.42 *	533.5 *	744.4 *	4,000.68 *	572.0 *
Daily Min:	4.3	4.75	0.3	0.0	7.30	0.4
Daily Max:	145.2	231.50	30.7	193.8	298.47	30.9
Jan 2020 - Mar 2020	3,168.5	9,434.06	1,480.8	2,364.2	10,436.09	1,606.9
QTD:	3,168.5 *	9,434.06 *	1,480.8 *	2,364.2 *	10,436.09 *	1,606.9 *
YTD 2020:	3,168.5 *	9,434.06 *	1,480.8 *	2,364.2 *	10,436.09 *	1,606.9 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:15 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2020	2.43	40,483.4	2.08	3,940.0	44,423.4	400.9	4,566.760
01/02/2020	16.28	258,615.0	8.10	22,578.4	281,193.4	2,088.5	28,906.612
01/03/2020	23.92	406,384.1	16.46	33,491.4	439,875.5	2,984.9	45,219.100
01/04/2020	0.02	0.0	0.00	0.0	0.0	22.5	0.004
01/05/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/06/2020	16.13	257,109.7	8.07	14,840.2	271,949.9	1,904.5	27,956.464
01/07/2020	22.48	387,946.4	15.23	24,879.5	412,825.9	2,761.8	42,438.436
01/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/09/2020	21.28	338,871.8	8.07	22,747.0	361,618.8	2,549.8	37,174.536
01/10/2020	24.00	418,159.9	18.02	39,910.2	458,070.1	3,105.5	47,089.800
01/11/2020	8.52	151,989.6	8.22	13,079.6	165,069.2	1,160.2	16,969.216
01/12/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/13/2020	20.20	311,160.1	8.07	22,380.6	333,540.7	2,552.7	34,287.960
01/14/2020	24.00	413,781.2	17.02	37,003.1	450,784.3	3,354.4	46,340.400
01/15/2020	24.00	417,458.9	17.00	42,960.5	460,419.4	3,563.8	47,331.100
01/16/2020	24.00	413,755.3	18.05	40,528.6	454,283.9	3,517.3	46,700.500
01/17/2020	24.00	420,518.1	18.08	36,472.8	456,990.9	3,473.6	46,978.700
01/18/2020	24.00	416,760.5	17.08	33,974.1	450,734.6	3,454.0	46,335.400
01/19/2020	24.00	396,000.5	8.00	18,470.7	414,471.2	2,940.7	42,607.600
01/20/2020	24.00	427,771.7	24.00	62,456.1	490,227.8	4,068.9	50,395.500
01/21/2020	24.00	415,195.7	18.03	37,660.1	452,855.8	3,493.1	46,553.800
01/22/2020	24.00	384,278.0	8.78	18,012.8	402,290.8	2,926.1	41,355.600
01/23/2020	24.00	410,712.9	15.73	36,416.1	447,129.0	3,395.9	45,965.000
01/24/2020	23.50	382,721.1	7.25	16,799.4	399,520.4	2,943.1	41,070.700
01/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/27/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/28/2020	19.14	295,370.8	5.29	12,855.6	308,226.4	2,393.3	31,685.616
01/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/30/2020	21.67	339,329.7	6.93	16,067.3	355,397.0	2,684.0	36,534.767
01/31/2020	18.87	289,666.5	4.75	11,217.0	300,883.5	2,619.9	30,931.092
Monthly Avg/Sum*:	478.44 *	7,994,040.9 *	278.31 *	618,741.1 *	8,612,781.9 *	64,359.4 *	885,394.663 *
Daily Min:	0.02	0.0	0.00	0.0	0.0	22.5	0.004
Daily Max:	24.00	427,771.7	24.00	62,456.1	490,227.8	4,068.9	50,395.500
Jan 2020 - Jan 2020	478.44	7,994,040.9	278.31	618,741.1	8,612,781.9	64,359.4	885,394.663
QTD:	478.44 *	7,994,040.9 *	278.31 *	618,741.1 *	8,612,781.9 *	64,359.4 *	885,394.663 *
YTD 2020:	478.44 *	7,994,040.9 *	278.31 *	618,741.1 *	8,612,781.9 *	64,359.4 *	885,394.663 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:15 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/03/2020	20.13	317,329.2	7.05	22,669.6	339,998.8	2,722.2	34,951.715
02/04/2020	24.00	424,818.5	16.50	41,546.5	466,365.0	3,721.6	47,942.400
02/05/2020	24.00	414,004.8	17.50	42,952.4	456,957.2	3,670.6	46,975.400
02/06/2020	24.00	411,121.7	16.02	34,084.7	445,206.4	3,444.4	45,767.500
02/07/2020	23.48	387,639.4	10.23	23,299.6	410,939.0	3,121.0	42,244.700
02/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/09/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/10/2020	20.70	323,334.6	6.55	15,457.9	338,792.5	2,722.1	34,828.010
02/11/2020	24.00	381,559.8	6.48	19,240.2	400,800.0	2,973.2	41,202.100
02/12/2020	24.00	387,938.5	5.96	16,839.8	404,778.3	2,935.7	41,611.100
02/13/2020	24.00	409,690.1	16.03	40,636.7	450,326.8	3,552.0	46,293.700
02/14/2020	0.97	14,267.2	0.70	613.4	14,880.7	135.8	1,529.690
02/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/17/2020	8.95	135,819.5	5.05	14,602.6	150,422.1	1,411.7	15,463.480
02/18/2020	24.00	417,316.6	21.28	52,525.4	469,842.0	3,916.8	48,299.900
02/19/2020	24.00	426,301.7	24.00	54,333.9	480,635.6	3,955.9	48,952.900
02/20/2020	24.00	425,408.1	24.00	51,372.0	476,780.1	3,795.9	48,297.800
02/21/2020	23.48	381,000.1	7.18	16,810.4	397,810.5	2,959.4	40,298.284
02/22/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/24/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/25/2020	9.67	148,236.1	6.07	17,501.1	165,737.2	1,468.0	16,789.152
02/26/2020	8.47	146,976.9	8.20	17,376.0	164,352.9	1,500.7	16,648.826
02/27/2020	21.55	354,247.8	7.55	18,668.4	372,916.2	2,563.9	37,776.295
02/28/2020	23.52	372,567.3	8.18	18,126.0	390,693.3	2,899.1	39,577.192
02/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	376.92 *	6,279,577.9 *	214.53 *	518,656.6 *	6,798,234.6 *	53,470.0 *	695,450.144 *
Daily Min:	0.97	14,267.2	0.70	613.4	14,880.7	135.8	1,529.690
Daily Max:	24.00	426,301.7	24.00	54,333.9	480,635.6	3,955.9	48,952.900
Jan 2020 - Feb 2020	855.36	14,273,618.8	492.84	1,137,397.7	15,411,016.5	117,829.4	1,580,844.807
QTD:	855.36 *	14,273,618.8 *	492.84 *	1,137,397.7 *	15,411,016.5 *	117,829.4 *	1,580,844.807 *
YTD 2020:	855.36 *	14,273,618.8 *	492.84 *	1,137,397.7 *	15,411,016.5 *	117,829.4 *	1,580,844.807 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:15 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/03/2020	8.63	131,476.9	6.07	20,443.2	151,920.1	1,458.2	15,389.399
03/04/2020	24.00	398,649.7	15.05	36,492.8	435,142.5	3,384.4	44,080.000
03/05/2020	24.00	404,829.3	14.96	34,109.1	438,938.4	3,417.7	44,464.400
03/06/2020	24.00	408,148.2	16.02	38,688.7	446,836.9	3,506.4	45,264.700
03/07/2020	0.48	5,714.0	0.20	129.9	5,843.9	151.4	591.984
03/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/09/2020	22.20	360,308.7	11.32	33,029.2	393,337.9	3,150.1	39,845.320
03/10/2020	24.00	421,185.7	24.00	79,900.9	501,086.6	4,315.3	50,760.000
03/11/2020	24.00	401,409.7	14.29	41,274.9	442,684.6	3,416.8	44,844.200
03/12/2020	24.00	409,438.5	17.54	58,811.1	468,249.6	3,818.8	47,433.400
03/13/2020	24.00	408,700.1	15.81	54,543.7	463,243.8	3,670.0	46,926.800
03/14/2020	24.00	415,775.8	14.54	42,875.0	458,650.8	3,508.4	46,461.400
03/15/2020	24.00	412,872.1	15.52	42,673.5	455,545.6	3,462.6	46,146.800
03/16/2020	24.00	426,317.8	24.00	73,343.7	499,661.5	4,118.5	50,615.700
03/17/2020	24.00	419,306.2	15.95	38,743.5	458,049.7	3,369.6	46,400.600
03/18/2020	24.00	407,650.2	14.83	32,295.0	439,945.2	3,185.7	44,566.400
03/19/2020	24.00	397,333.6	15.98	35,158.4	432,492.0	3,163.2	43,811.500
03/20/2020	24.00	403,305.0	16.00	34,705.9	438,010.9	3,206.6	44,370.400
03/21/2020	7.47	129,118.7	7.15	17,613.5	146,732.2	1,270.9	14,864.054
03/22/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/24/2020	21.20	328,256.4	6.22	13,581.6	341,838.0	2,645.5	34,628.112
03/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/27/2020	0.93	4,311.4	0.00	0.0	4,311.4	40.7	436.728
03/28/2020	24.00	390,399.3	6.43	15,276.9	405,676.2	3,011.5	41,095.100
03/29/2020	24.00	387,192.2	6.00	14,292.0	401,484.2	2,816.9	40,670.700
03/30/2020	24.00	392,582.5	6.07	16,948.3	409,530.8	2,889.9	41,485.500
03/31/2020	7.48	129,219.9	7.18	14,553.4	143,773.3	1,242.5	14,564.220
Monthly Avg/Sum*:	476.39 *	7,993,501.9 *	291.13 *	789,484.2 *	8,782,986.1 *	68,221.6 *	889,717.417 *
Daily Min:	0.48	4,311.4	0.00	0.0	4,311.4	40.7	436.728
Daily Max:	24.00	426,317.8	24.00	79,900.9	501,086.6	4,315.3	50,760.000
Jan 2020 - Mar 2020	1,331.75	22,267,120.7	783.97	1,926,881.9	24,194,002.6	186,051.0	2,470,562.224
QTD:	1,331.75 *	22,267,120.7 *	783.97 *	1,926,881.9 *	24,194,002.6 *	186,051.0 *	2,470,562.224 *
YTD 2020:	1,331.75 *	22,267,120.7 *	783.97 *	1,926,881.9 *	24,194,002.6 *	186,051.0 *	2,470,562.224 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2020	2.43	40,477.0	2.08	3,818.4	44,295.4	360.9	4,553.607
01/02/2020	22.63	351,719.2	9.83	24,395.2	376,114.4	2,596.1	38,664.675
01/03/2020	23.92	407,374.4	16.46	32,403.4	439,777.8	2,558.2	45,209.436
01/04/2020	0.02	0.0	0.00	0.0	0.0	29.7	0.004
01/05/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/06/2020	19.47	301,413.8	8.07	14,805.2	316,219.0	2,161.0	32,507.486
01/07/2020	22.48	388,270.9	15.22	24,995.8	413,266.7	2,451.4	42,483.892
01/08/2020	2.70	16,768.3	0.00	0.0	16,768.3	479.0	1,723.750
01/09/2020	24.00	388,532.6	7.97	20,942.7	409,475.3	2,430.8	42,094.200
01/10/2020	24.00	418,322.7	18.02	38,579.1	456,901.8	2,638.3	46,969.700
01/11/2020	8.52	151,252.6	8.22	13,254.1	164,506.7	1,014.9	16,911.260
01/12/2020	0.45	1,932.9	0.00	0.0	1,932.9	0.0	198.720
01/13/2020	24.00	374,988.9	8.02	21,609.2	396,598.1	2,643.7	40,770.400
01/14/2020	24.00	414,650.5	17.02	36,269.1	450,919.6	2,617.9	46,354.700
01/15/2020	24.00	418,322.8	17.00	42,710.2	461,033.0	2,669.5	47,394.200
01/16/2020	24.00	415,202.9	18.03	40,247.4	455,450.3	2,630.0	46,820.400
01/17/2020	24.00	420,856.2	18.05	36,141.3	456,997.5	2,609.0	46,979.400
01/18/2020	24.00	417,199.1	17.07	33,745.4	450,944.5	2,579.1	46,357.400
01/19/2020	24.00	397,457.1	7.96	18,227.1	415,684.2	2,416.9	42,732.200
01/20/2020	24.00	427,796.7	24.00	59,889.8	487,686.5	2,839.5	50,134.100
01/21/2020	24.00	415,864.1	18.10	37,400.2	453,264.3	2,609.4	46,595.400
01/22/2020	24.00	386,291.8	8.78	17,882.7	404,174.5	2,348.1	41,549.400
01/23/2020	24.00	411,866.2	15.73	35,629.1	447,495.3	2,578.6	46,002.400
01/24/2020	23.50	384,502.3	7.23	16,517.4	401,019.8	2,429.2	41,224.950
01/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
01/27/2020	5.80	58,065.6	0.00	0.0	58,065.6	723.7	5,969.160
01/28/2020	22.52	354,517.4	5.25	12,620.3	367,137.7	2,243.1	37,741.852
01/29/2020	6.70	87,597.9	1.98	4,606.2	92,204.1	900.1	9,478.550
01/30/2020	24.00	387,440.9	6.99	15,796.1	403,237.0	2,364.1	41,452.800
01/31/2020	23.52	368,535.9	4.73	10,958.6	379,494.4	2,316.5	39,011.984
Monthly Avg/Sum*:	520.66 *	8,607,220.7 *	281.81 *	613,444.0 *	9,220,664.7 *	56,238.7 *	947,886.026 *
Daily Min:	0.02	0.0	0.00	0.0	0.0	0.0	0.004
Daily Max:	24.00	427,796.7	24.00	59,889.8	487,686.5	2,839.5	50,134.100
Jan 2020 - Jan 2020	520.66	8,607,220.7	281.81	613,444.0	9,220,664.7	56,238.7	947,886.026
QTD:	520.66 *	8,607,220.7 *	281.81 *	613,444.0 *	9,220,664.7 *	56,238.7 *	947,886.026 *
YTD 2020:	520.66 *	8,607,220.7 *	281.81 *	613,444.0 *	9,220,664.7 *	56,238.7 *	947,886.026 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/02/2020	0.78	3,622.7	0.00	0.0	3,622.7	1.2	372.450
02/03/2020	24.00	370,885.0	7.05	21,543.8	392,428.8	2,803.1	40,341.600
02/04/2020	24.00	424,768.1	16.43	40,172.5	464,940.6	2,763.3	47,795.800
02/05/2020	24.00	414,958.9	17.52	41,794.6	456,753.5	2,692.2	46,954.200
02/06/2020	24.00	412,135.8	15.99	33,617.2	445,753.0	2,565.2	45,823.500
02/07/2020	23.50	389,635.2	10.21	22,922.7	412,557.9	2,459.1	42,410.700
02/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/09/2020	0.70	3,204.7	0.00	0.0	3,204.7	0.0	329.420
02/10/2020	24.00	375,990.0	6.55	15,091.4	391,081.4	2,591.5	40,203.700
02/11/2020	24.00	381,967.9	6.50	18,226.9	400,194.8	2,368.4	41,140.100
02/12/2020	24.00	388,144.0	5.98	16,121.2	404,265.2	2,344.4	41,558.400
02/13/2020	24.00	408,708.1	16.05	39,066.7	447,774.8	2,565.3	46,031.600
02/14/2020	0.97	14,363.3	0.70	630.5	14,993.8	117.1	1,541.330
02/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/16/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/17/2020	14.82	203,121.4	5.05	14,079.2	217,200.6	1,899.9	22,328.252
02/18/2020	24.00	417,077.8	21.28	50,506.6	467,584.4	2,689.7	48,067.700
02/19/2020	24.00	424,987.7	24.00	52,154.2	477,141.9	2,744.8	49,050.100
02/20/2020	24.00	424,062.3	24.00	50,441.5	474,503.8	2,673.0	48,778.900
02/21/2020	23.48	382,938.1	7.20	16,444.3	399,382.4	2,395.1	41,056.448
02/22/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/23/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
02/24/2020	10.72	157,602.0	7.02	16,876.5	174,478.5	1,389.8	17,936.380
02/25/2020	24.00	373,365.9	9.04	20,300.6	393,666.5	2,281.9	40,468.500
02/26/2020	17.07	285,956.3	14.93	28,632.5	314,588.8	1,991.9	32,339.626
02/27/2020	24.00	402,821.8	7.55	17,448.9	420,270.7	2,398.8	43,204.000
02/28/2020	23.52	373,955.2	8.18	17,418.9	391,374.1	2,326.9	40,233.164
02/29/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	427.56 *	7,034,272.2 *	231.23 *	533,490.7 *	7,567,762.9 *	46,062.6 *	777,965.870 *
Daily Min:	0.70	3,204.7	0.00	0.0	3,204.7	0.0	329.420
Daily Max:	24.00	424,987.7	24.00	52,154.2	477,141.9	2,803.1	49,050.100
Jan 2020 - Feb 2020	948.22	15,641,492.9	513.04	1,146,934.7	16,788,427.6	102,301.3	1,725,851.896
QTD:	948.22 *	15,641,492.9 *	513.04 *	1,146,934.7 *	16,788,427.6 *	102,301.3 *	1,725,851.896 *
YTD 2020:	948.22 *	15,641,492.9 *	513.04 *	1,146,934.7 *	16,788,427.6 *	102,301.3 *	1,725,851.896 *

Monthly Summary By Day Report

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/02/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/03/2020	15.18	208,119.9	6.07	18,939.5	227,059.4	1,951.6	23,341.516
03/04/2020	24.00	400,058.5	15.05	34,857.9	434,916.4	2,485.7	44,709.200
03/05/2020	24.00	406,341.1	14.96	32,807.6	439,148.7	2,510.1	45,144.700
03/06/2020	24.00	409,731.5	16.00	37,076.8	446,808.3	2,570.2	45,931.900
03/07/2020	0.50	5,809.1	0.20	127.3	5,936.5	132.0	610.250
03/08/2020	3.72	34,777.6	0.00	0.0	34,777.6	500.1	3,575.164
03/09/2020	24.00	401,249.3	11.30	31,767.6	433,016.9	2,487.9	44,513.900
03/10/2020	24.00	421,626.8	24.00	74,264.0	495,890.8	2,965.0	50,977.500
03/11/2020	24.00	402,634.7	14.29	39,251.2	441,885.9	2,643.1	45,425.600
03/12/2020	24.00	408,727.9	17.52	53,866.7	462,594.6	2,889.2	47,554.800
03/13/2020	24.00	405,805.8	15.81	50,099.1	455,904.9	2,875.9	46,867.200
03/14/2020	24.00	417,313.0	14.54	40,240.0	457,553.0	2,700.7	47,036.500
03/15/2020	24.00	413,734.7	15.50	40,465.1	454,199.8	2,687.0	46,691.700
03/16/2020	24.00	426,396.4	24.00	69,317.1	495,713.5	2,968.6	50,959.200
03/17/2020	24.00	421,151.9	15.95	37,636.8	458,788.7	2,655.7	47,163.400
03/18/2020	24.00	409,019.7	14.78	30,947.7	439,967.4	2,529.7	45,228.400
03/19/2020	24.00	398,637.8	15.98	33,257.4	431,895.2	2,501.3	44,398.900
03/20/2020	24.00	404,393.7	16.00	33,808.1	438,201.8	2,563.0	45,047.100
03/21/2020	7.47	129,415.8	7.15	16,775.4	146,191.3	967.1	15,028.470
03/22/2020	6.73	73,877.6	0.00	0.0	73,877.6	806.5	7,594.604
03/23/2020	8.87	104,792.5	0.00	0.0	104,792.5	1,216.0	10,772.686
03/24/2020	23.48	376,762.1	6.22	13,316.6	390,078.7	2,353.8	40,100.168
03/25/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
03/27/2020	6.93	77,755.4	0.00	0.0	77,755.4	868.9	7,993.376
03/28/2020	24.00	397,131.3	6.48	15,243.5	412,374.8	2,374.1	42,392.200
03/29/2020	24.00	389,266.8	6.00	13,497.4	402,764.2	2,357.7	41,404.300
03/30/2020	24.00	394,559.8	6.07	15,316.9	409,876.7	2,411.1	42,135.300
03/31/2020	13.37	197,523.7	7.18	13,772.0	211,295.7	1,596.8	21,721.189
Monthly Avg/Sum*:	518.25 *	8,536,614.4 *	291.05 *	746,651.7 *	9,283,266.3 *	57,568.8 *	954,319.223 *
Daily Min:	0.50	5,809.1	0.00	0.0	5,936.5	132.0	610.250
Daily Max:	24.00	426,396.4	24.00	74,264.0	495,890.8	2,968.6	50,977.500
Jan 2020 - Mar 2020	1,466.47	24,178,107.3	804.09	1,893,586.4	26,071,693.9	159,870.1	2,680,171.119
QTD:	1,466.47 *	24,178,107.3 *	804.09 *	1,893,586.4 *	26,071,693.9 *	159,870.1 *	2,680,171.119 *
YTD 2020:	1,466.47 *	24,178,107.3 *	804.09 *	1,893,586.4 *	26,071,693.9 *	159,870.1 *	2,680,171.119 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
01/01/2020	36.7	15.8	4.4	25.1	5.4
01/02/2020	418.6	264.5	31.9	188.3	40.7
01/03/2020	257.7	29.8	45.1	248.8	26.9
01/04/2020	0.0	0.0	0.0	0.0	0.0
01/05/2020	0.0	0.0	0.0	0.0	0.0
01/06/2020	426.9	269.7	29.2	167.6	19.4
01/07/2020	225.7	25.8	42.1	233.4	25.3
01/08/2020	115.1	132.1	0.6	5.2	1.0
01/09/2020	277.5	110.1	38.4	219.1	25.3
01/10/2020	268.4	18.0	46.8	258.6	28.0
01/11/2020	115.2	20.9	16.7	93.3	10.0
01/12/2020	32.6	74.1	0.0	0.6	0.1
01/13/2020	428.5	288.4	36.0	208.3	24.6
01/14/2020	278.2	30.4	46.1	254.8	27.5
01/15/2020	289.0	30.3	46.9	260.4	28.3
01/16/2020	281.8	32.9	46.4	256.9	27.8
01/17/2020	295.8	31.7	46.9	258.5	28.1
01/18/2020	281.7	27.6	45.8	255.0	27.8
01/19/2020	216.1	15.5	42.5	234.7	25.7
01/20/2020	345.5	43.0	49.7	276.3	30.3
01/21/2020	284.2	33.3	46.1	255.9	27.6
01/22/2020	214.5	15.0	41.2	227.7	25.0
01/23/2020	271.2	27.8	45.8	253.0	27.9
01/24/2020	211.6	25.6	41.2	226.2	24.9
01/25/2020	0.0	0.0	0.0	0.0	0.0
01/26/2020	0.0	0.0	0.0	0.0	0.0
01/27/2020	131.7	164.8	1.8	17.8	3.5
01/28/2020	291.8	143.9	33.6	192.3	22.6
01/29/2020	171.7	101.9	2.9	28.6	5.7
01/30/2020	294.9	103.6	37.9	216.2	24.9
01/31/2020	209.8	84.9	33.3	194.5	23.5
Monthly Avg/Sum*:	6,672.4 *	2,161.4 *	899.3 *	5,057.1 *	46.1 *
Daily Min:	0.0	0.0	0.0	0.0	5.4
Daily Max:	428.5	288.4	49.7	276.3	40.7
Jan 2020 - Jan 2020	6,672.4	2,161.4	899.3	5,057.1	46.1
QTD:	6,672.4 *	2,161.4 *	899.3 *	5,057.1 *	46.1 *
YTD 2020:	6,672.4 *	2,161.4 *	899.3 *	5,057.1 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
02/01/2020	0.0	0.0	0.0	0.0	0.0
02/02/2020	73.0	73.4	0.1	1.1	0.2
02/03/2020	404.1	211.0	36.6	208.4	24.0
02/04/2020	300.9	26.8	47.3	263.2	28.9
02/05/2020	303.6	30.4	47.0	258.2	28.2
02/06/2020	277.3	30.4	45.9	251.9	27.6
02/07/2020	240.7	33.9	42.6	233.1	25.5
02/08/2020	0.0	0.0	0.0	0.0	0.0
02/09/2020	66.2	67.6	0.1	1.0	0.2
02/10/2020	511.5	258.3	36.5	207.4	24.1
02/11/2020	202.2	11.5	41.2	226.4	24.7
02/12/2020	203.4	11.1	41.7	228.6	24.9
02/13/2020	286.5	33.3	45.9	254.1	27.8
02/14/2020	20.0	16.0	1.6	8.5	0.9
02/15/2020	0.0	0.0	0.0	0.0	0.0
02/16/2020	0.0	0.0	0.0	0.0	0.0
02/17/2020	483.7	298.9	17.4	105.8	13.3
02/18/2020	315.9	40.1	47.9	264.8	28.8
02/19/2020	335.0	52.4	48.7	269.2	29.7
02/20/2020	330.2	46.2	47.8	267.2	29.4
02/21/2020	213.7	26.2	40.7	223.9	24.6
02/22/2020	0.0	0.0	0.0	0.0	0.0
02/23/2020	0.0	0.0	0.0	0.0	0.0
02/24/2020	275.5	137.2	5.4	53.9	10.9
02/25/2020	301.9	111.2	23.9	163.3	24.2
02/26/2020	263.6	60.9	21.2	138.7	19.3
02/27/2020	359.0	98.3	39.2	224.1	26.2
02/28/2020	219.1	31.7	39.8	219.5	24.0
02/29/2020	0.0	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	5,987.0 *	1,706.8 *	718.5 *	4,072.3 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	511.5	298.9	48.7	269.2	-
Jan 2020 - Feb 2020	12,659.4	3,868.2	1,617.8	9,129.4	46.1
QTD:	12,659.4 *	3,868.2 *	1,617.8 *	9,129.4 *	46.1 *
YTD 2020:	12,659.4 *	3,868.2 *	1,617.8 *	9,129.4 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
03/01/2020	0.0	0.0	0.0	0.0	0.0
03/02/2020	0.0	0.0	0.0	0.0	0.0
03/03/2020	504.9	291.4	17.7	108.8	13.9
03/04/2020	271.0	29.2	44.1	244.0	26.5
03/05/2020	271.1	31.8	44.5	246.8	26.8
03/06/2020	283.3	37.0	45.1	251.1	27.4
03/07/2020	12.1	13.7	0.6	3.4	0.4
03/08/2020	121.8	122.3	1.1	10.7	2.1
03/09/2020	348.6	131.8	41.2	233.7	26.8
03/10/2020	343.5	31.0	50.4	279.6	30.9
03/11/2020	288.3	20.6	44.9	248.1	27.1
03/12/2020	310.1	19.2	47.2	261.1	28.5
03/13/2020	308.7	19.7	46.6	257.8	28.3
03/14/2020	294.0	19.7	46.3	257.3	28.3
03/15/2020	294.7	21.3	46.0	255.4	27.8
03/16/2020	358.0	33.9	50.5	279.2	30.7
03/17/2020	303.3	24.1	46.1	257.4	28.6
03/18/2020	288.6	21.3	44.6	247.2	27.0
03/19/2020	277.1	25.2	44.2	242.5	26.8
03/20/2020	300.9	23.0	44.3	246.0	26.7
03/21/2020	111.7	23.2	14.8	82.4	9.0
03/22/2020	162.0	109.0	2.2	22.7	4.6
03/23/2020	168.3	97.1	3.4	32.4	6.3
03/24/2020	342.6	150.5	36.6	206.6	23.9
03/25/2020	0.0	0.0	0.0	0.0	0.0
03/26/2020	0.0	0.0	0.0	0.0	0.0
03/27/2020	279.7	224.5	2.7	25.1	4.9
03/28/2020	275.7	45.7	41.8	229.9	25.2
03/29/2020	221.2	4.3	41.0	225.6	25.0
03/30/2020	232.0	8.7	41.5	230.1	25.5
03/31/2020	238.0	85.3	16.6	101.5	13.0
Monthly Avg/Sum*:	7,211.2 *	1,664.5 *	906.0 *	5,086.4 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	504.9	291.4	50.5	279.6	-
Jan 2020 - Mar 2020	19,870.6	5,532.7	2,523.8	14,215.8	46.1
QTD:	19,870.6 *	5,532.7 *	2,523.8 *	14,215.8 *	46.1 *
YTD 2020:	19,870.6 *	5,532.7 *	2,523.8 *	14,215.8 *	46.1 *

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/01/2020 00:00	12.2	1.3	2.0	11.2	2.4
01/01/2020 01:00	12.2	1.0	2.0	11.2	2.4
01/01/2020 02:00	12.3	13.5	0.4	2.7	0.6
01/01/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/01/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	36.7 #	15.8 #	4.4 #	25.1 #	5.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	12.3	13.5	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/02/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/02/2020 01:00	52.2	60.9	0.1	0.9	0.2
01/02/2020 02:00	54.6	47.6	0.2	2.1	0.4
01/02/2020 03:00	46.4	49.2	0.3	2.9	0.6
01/02/2020 04:00	1.5	0.0	0.5	4.6	0.9
01/02/2020 05:00	3.7	0.0	0.6	5.6	1.1
01/02/2020 06:00	6.4	0.0	0.6	6.4	1.3
01/02/2020 07:00	18.6	56.2	0.6	5.6	1.2
01/02/2020 08:00	95.3	44.1	1.1	6.6	1.4
01/02/2020 09:00	3.0	0.0	1.6	8.4	1.8
01/02/2020 10:00	3.4	0.0	1.7	9.1	2.0
01/02/2020 11:00	5.0	0.0	1.7	9.2	2.0
01/02/2020 12:00	3.2	0.0	1.6	8.9	2.0
01/02/2020 13:00	3.2	0.0	1.6	9.0	2.0
01/02/2020 14:00	3.2	0.0	1.6	9.0	2.0
01/02/2020 15:00	4.8	0.0	1.6	8.8	2.0
01/02/2020 16:00	12.1	1.0	2.0	11.1	2.4
01/02/2020 17:00	14.4	1.0	2.0	11.2	2.4
01/02/2020 18:00	14.6	1.0	2.1	11.5	2.5
01/02/2020 19:00	14.6	0.6	2.1	11.5	2.5
01/02/2020 20:00	14.6	1.0	2.1	11.5	2.5
01/02/2020 21:00	14.8	0.6	2.1	11.6	2.6
01/02/2020 22:00	14.6	0.6	2.1	11.5	2.5
01/02/2020 23:00	14.4	0.7	2.0	11.3	2.4
Average/Sum#:	418.6 #	264.5 #	31.9 #	188.3 #	40.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	95.3	60.9	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/03/2020 00:00	14.2	0.7	2.0	11.2	2.4
01/03/2020 01:00	14.2	0.6	2.0	11.2	2.4
01/03/2020 02:00	14.2	0.7	2.0	11.2	2.4
01/03/2020 03:00	14.2	0.7	2.0	11.2	2.4
01/03/2020 04:00	14.3	0.7	2.0	11.2	2.4
01/03/2020 05:00	12.2	1.0	2.0	11.2	2.4
01/03/2020 06:00	14.2	1.0	2.0	11.1	2.4
01/03/2020 07:00	14.2	1.0	2.0	11.2	2.4
01/03/2020 08:00	9.5	1.0	1.9	10.4	2.2
01/03/2020 09:00	3.0	0.0	1.6	8.4	1.8
01/03/2020 10:00	3.1	0.0	1.6	8.6	1.8
01/03/2020 11:00	4.8	0.0	1.6	8.8	2.0
01/03/2020 12:00	5.0	0.0	1.7	9.3	2.0
01/03/2020 13:00	3.4	0.0	1.7	9.1	2.0
01/03/2020 14:00	2.8	0.0	1.5	7.8	1.8
01/03/2020 15:00	4.7	0.0	1.6	8.6	1.8
01/03/2020 16:00	11.7	1.0	2.0	10.8	2.4
01/03/2020 17:00	12.2	1.0	2.0	11.2	2.4
01/03/2020 18:00	12.4	1.0	2.0	11.3	2.4
01/03/2020 19:00	12.2	1.0	2.0	11.2	2.4
01/03/2020 20:00	12.4	1.0	2.0	11.4	2.4
01/03/2020 21:00	12.6	1.0	2.1	11.6	2.6
01/03/2020 22:00	12.7	1.0	2.1	11.6	2.6
01/03/2020 23:00	23.5	15.4	1.7	9.2	2.0
Average/Sum#:	257.7 #	29.8 #	45.1 #	248.8 #	53.8 #
Minimum:	2.8	0.0	1.5	7.8	1.8
Maximum:	23.5	15.4	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/04/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/04/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/05/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/05/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/06/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/06/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/06/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/06/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/06/2020 04:00	35.7	72.3	0.0	0.6	0.1
01/06/2020 05:00	78.2	31.6	0.2	1.8	0.4
01/06/2020 06:00	57.3	51.5	0.3	2.5	0.5
01/06/2020 07:00	1.5	29.5	0.5	4.9	1.0
01/06/2020 08:00	110.1	73.0	0.9	6.8	1.5
01/06/2020 09:00	23.1	8.0	1.6	8.8	1.9
01/06/2020 10:00	3.1	0.0	1.6	8.6	1.8
01/06/2020 11:00	3.3	0.0	1.7	9.1	2.0
01/06/2020 12:00	3.2	0.0	1.6	8.7	1.9
01/06/2020 13:00	3.2	0.0	1.6	9.0	2.0
01/06/2020 14:00	3.2	0.0	1.6	8.6	1.8
01/06/2020 15:00	3.1	0.0	1.6	8.6	1.8
01/06/2020 16:00	12.1	1.3	2.0	11.1	2.4
01/06/2020 17:00	14.4	0.7	2.0	11.3	2.4
01/06/2020 18:00	12.2	0.3	2.0	11.2	2.4
01/06/2020 19:00	12.2	0.3	2.0	11.2	2.4
01/06/2020 20:00	12.2	0.3	2.0	11.2	2.4
01/06/2020 21:00	12.2	0.3	2.0	11.2	2.4
01/06/2020 22:00	12.4	0.3	2.0	11.3	2.4
01/06/2020 23:00	14.2	0.3	2.0	11.1	2.4
Average/Sum#:	426.9 #	269.7 #	29.2 #	167.6 #	35.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	110.1	73.0	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/07/2020 00:00	12.2	0.3	2.0	11.2	2.4
01/07/2020 01:00	14.1	0.3	2.0	11.1	2.4
01/07/2020 02:00	14.0	0.7	2.0	11.0	2.4
01/07/2020 03:00	12.0	0.7	2.0	11.0	2.4
01/07/2020 04:00	14.2	0.7	2.0	11.2	2.4
01/07/2020 05:00	12.2	0.7	2.0	11.2	2.4
01/07/2020 06:00	12.2	0.7	2.0	11.2	2.4
01/07/2020 07:00	12.4	0.7	2.1	11.4	2.4
01/07/2020 08:00	11.7	1.0	1.9	10.7	2.4
01/07/2020 09:00	5.1	0.0	1.7	9.5	2.0
01/07/2020 10:00	3.2	0.0	1.6	8.9	2.0
01/07/2020 11:00	3.2	0.0	1.6	8.8	2.0
01/07/2020 12:00	3.4	0.0	1.7	9.2	2.0
01/07/2020 13:00	3.2	0.0	1.6	9.0	2.0
01/07/2020 14:00	3.2	0.0	1.6	8.8	2.0
01/07/2020 15:00	3.2	0.0	1.6	8.6	1.8
01/07/2020 16:00	12.0	1.7	2.0	11.0	2.4
01/07/2020 17:00	12.2	1.3	2.0	11.2	2.4
01/07/2020 18:00	12.2	1.0	2.0	11.2	2.4
01/07/2020 19:00	12.2	1.0	2.0	11.2	2.4
01/07/2020 20:00	12.4	1.3	2.0	11.3	2.4
01/07/2020 21:00	12.4	1.3	2.1	11.4	2.4
01/07/2020 22:00	12.7	12.4	0.6	3.3	0.8
01/07/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	225.6 #	25.8 #	42.1 #	233.4 #	50.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.2	12.4	2.1	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/08/2020 21:00	57.8	78.9	0.1	1.0	0.2
01/08/2020 22:00	31.3	21.3	0.2	1.6	0.3
01/08/2020 23:00	26.0	31.9	0.3	2.6	0.5
Average/Sum#:	115.1 #	132.1 #	0.6 #	5.2 #	1.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	57.8	78.9	0.3	2.6	0.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/09/2020 00:00	1.5	0.0	0.4	4.4	0.9
01/09/2020 01:00	1.4	0.0	0.4	4.1	0.8
01/09/2020 02:00	19.3	59.3	0.6	5.3	1.1
01/09/2020 03:00	99.5	42.5	1.1	6.8	1.4
01/09/2020 04:00	3.4	0.0	1.7	9.3	2.0
01/09/2020 05:00	3.2	0.0	1.6	9.0	2.0
01/09/2020 06:00	2.8	0.0	1.4	7.7	1.6
01/09/2020 07:00	3.0	0.0	1.4	8.2	1.8
01/09/2020 08:00	4.8	0.0	1.6	9.0	2.0
01/09/2020 09:00	3.4	0.0	1.7	9.3	2.0
01/09/2020 10:00	3.2	0.0	1.6	8.6	1.8
01/09/2020 11:00	3.4	0.0	1.7	9.2	2.0
01/09/2020 12:00	3.2	0.0	1.6	9.0	2.0
01/09/2020 13:00	3.4	0.0	1.7	9.3	2.0
01/09/2020 14:00	3.2	0.0	1.6	8.8	2.0
01/09/2020 15:00	3.2	0.0	1.6	8.6	1.8
01/09/2020 16:00	12.1	1.3	2.0	11.1	2.4
01/09/2020 17:00	14.6	1.0	2.1	11.5	2.5
01/09/2020 18:00	14.9	1.0	2.1	11.8	2.6
01/09/2020 19:00	14.8	1.0	2.1	11.6	2.6
01/09/2020 20:00	14.9	1.0	2.1	11.7	2.6
01/09/2020 21:00	14.7	1.0	2.1	11.6	2.6
01/09/2020 22:00	14.8	1.0	2.1	11.6	2.6
01/09/2020 23:00	14.8	1.0	2.1	11.6	2.6
Average/Sum#:	277.5 #	110.1 #	38.4 #	219.1 #	47.7 #
Minimum:	1.4	0.0	0.4	4.1	0.8
Maximum:	99.5	59.3	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/10/2020 00:00	14.4	0.7	2.1	11.4	2.4
01/10/2020 01:00	14.4	0.7	2.0	11.2	2.4
01/10/2020 02:00	14.8	1.0	2.1	11.6	2.6
01/10/2020 03:00	14.8	1.0	2.1	11.6	2.6
01/10/2020 04:00	14.2	0.7	2.0	11.2	2.4
01/10/2020 05:00	14.4	1.0	2.0	11.3	2.4
01/10/2020 06:00	14.9	1.3	2.1	11.8	2.6
01/10/2020 07:00	13.1	1.0	2.1	12.0	2.6
01/10/2020 08:00	14.5	0.7	2.1	11.4	2.4
01/10/2020 09:00	7.7	1.0	1.9	10.6	2.3
01/10/2020 10:00	3.4	0.0	1.7	9.3	2.0
01/10/2020 11:00	3.4	0.0	1.7	9.1	2.0
01/10/2020 12:00	3.2	0.0	1.6	9.0	2.0
01/10/2020 13:00	3.4	0.0	1.7	9.2	2.0
01/10/2020 14:00	3.0	0.0	1.6	8.4	1.8
01/10/2020 15:00	3.1	0.0	1.6	8.6	1.8
01/10/2020 16:00	12.2	1.3	2.0	11.2	2.4
01/10/2020 17:00	14.6	1.3	2.1	11.4	2.5
01/10/2020 18:00	14.8	1.3	2.1	11.6	2.6
01/10/2020 19:00	14.7	1.0	2.1	11.5	2.6
01/10/2020 20:00	14.5	1.0	2.1	11.4	2.4
01/10/2020 21:00	14.5	1.0	2.0	11.4	2.4
01/10/2020 22:00	14.2	1.0	2.0	11.2	2.4
01/10/2020 23:00	12.2	1.0	2.0	11.2	2.4
Average/Sum#:	268.4 #	18.0 #	46.8 #	258.6 #	56.0 #
Minimum:	3.0	0.0	1.6	8.4	1.8
Maximum:	14.9	1.3	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/11/2020 00:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 01:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 02:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 03:00	14.3	1.0	2.0	11.2	2.4
01/11/2020 04:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 05:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 06:00	14.2	1.0	2.0	11.2	2.4
01/11/2020 07:00	12.2	1.0	2.0	11.2	2.4
01/11/2020 08:00	13.5	12.9	0.7	3.7	0.8
01/11/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/11/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	115.2 #	20.9 #	16.7 #	93.3 #	20.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.3	12.9	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/12/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/12/2020 23:00	32.6	74.1	0.0	0.6	0.1
Average/Sum#:	32.6 #	74.1 #	0.0 #	0.6 #	0.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	32.6	74.1	0.0	0.6	0.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/13/2020 00:00	68.8	45.3	0.2	2.0	0.4
01/13/2020 01:00	41.5	48.5	0.3	3.0	0.6
01/13/2020 02:00	0.0	0.0	0.4	4.3	0.9
01/13/2020 03:00	10.4	51.5	0.4	4.6	0.9
01/13/2020 04:00	96.6	62.9	0.9	6.5	1.4
01/13/2020 05:00	65.8	66.7	1.1	7.0	1.5
01/13/2020 06:00	3.2	0.0	1.6	9.0	2.0
01/13/2020 07:00	3.2	0.0	1.6	8.9	2.0
01/13/2020 08:00	3.1	0.0	1.6	8.6	1.8
01/13/2020 09:00	3.4	0.0	1.7	9.2	2.0
01/13/2020 10:00	3.2	0.0	1.6	8.8	2.0
01/13/2020 11:00	3.0	0.0	1.6	8.4	1.8
01/13/2020 12:00	3.2	0.0	1.6	8.9	2.0
01/13/2020 13:00	5.1	0.0	1.7	9.3	2.0
01/13/2020 14:00	3.2	0.0	1.6	8.7	1.9
01/13/2020 15:00	3.1	0.0	1.6	8.6	1.8
01/13/2020 16:00	12.2	2.0	2.0	11.2	2.4
01/13/2020 17:00	15.1	1.9	2.1	11.8	2.6
01/13/2020 18:00	15.1	1.6	2.1	11.9	2.6
01/13/2020 19:00	15.1	1.6	2.1	11.8	2.6
01/13/2020 20:00	14.9	1.6	2.1	11.8	2.6
01/13/2020 21:00	14.7	1.6	2.1	11.5	2.6
01/13/2020 22:00	12.4	1.6	2.0	11.3	2.4
01/13/2020 23:00	12.2	1.6	2.0	11.2	2.4
Average/Sum#:	428.5 #	288.4 #	36.0 #	208.3 #	45.2 #
Minimum:	0.0	0.0	0.2	2.0	0.4
Maximum:	96.6	66.7	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/14/2020 00:00	14.4	1.6	2.0	11.3	2.4
01/14/2020 01:00	14.3	1.6	2.0	11.2	2.4
01/14/2020 02:00	14.3	1.6	2.0	11.2	2.4
01/14/2020 03:00	14.3	1.6	2.0	11.2	2.4
01/14/2020 04:00	14.3	1.6	2.0	11.2	2.4
01/14/2020 05:00	14.5	1.9	2.1	11.4	2.4
01/14/2020 06:00	14.7	1.9	2.1	11.6	2.6
01/14/2020 07:00	15.1	1.6	2.1	12.0	2.6
01/14/2020 08:00	16.4	1.6	2.0	11.2	2.4
01/14/2020 09:00	14.0	1.6	2.0	11.0	2.4
01/14/2020 10:00	3.4	0.0	1.7	9.2	2.0
01/14/2020 11:00	6.8	0.0	1.7	9.3	2.0
01/14/2020 12:00	6.7	0.0	1.7	9.1	2.0
01/14/2020 13:00	5.0	0.0	1.7	9.3	2.0
01/14/2020 14:00	0.0	0.0	1.6	9.0	2.0
01/14/2020 15:00	6.1	0.0	1.6	8.4	1.8
01/14/2020 16:00	7.7	0.3	1.6	8.6	1.8
01/14/2020 17:00	12.0	2.3	2.0	11.0	2.4
01/14/2020 18:00	14.3	2.0	2.0	11.2	2.4
01/14/2020 19:00	14.4	1.6	2.0	11.3	2.4
01/14/2020 20:00	14.7	2.0	2.1	11.5	2.6
01/14/2020 21:00	14.5	2.0	2.1	11.4	2.4
01/14/2020 22:00	14.3	1.6	2.0	11.2	2.4
01/14/2020 23:00	12.0	2.0	2.0	11.0	2.4
Average/Sum#:	269.8 #	30.4 #	46.1 #	254.8 #	55.0 #
Minimum:	6.1	0.0	1.6	8.4	1.8
Maximum:	16.4	2.3	2.1	12.0	2.6
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/15/2020 00:00	12.2	1.7	2.0	11.2	2.4
01/15/2020 01:00	14.3	1.6	2.0	11.2	2.4
01/15/2020 02:00	14.3	1.6	2.0	11.2	2.4
01/15/2020 03:00	12.2	1.7	2.0	11.2	2.4
01/15/2020 04:00	14.3	1.7	2.0	11.2	2.4
01/15/2020 05:00	14.5	2.0	2.0	11.4	2.4
01/15/2020 06:00	15.2	2.0	2.1	12.0	2.6
01/15/2020 07:00	15.9	2.0	2.3	12.5	2.8
01/15/2020 08:00	12.2	1.6	2.0	11.2	2.4
01/15/2020 09:00	6.4	0.0	1.6	8.9	2.0
01/15/2020 10:00	6.7	0.0	1.7	9.1	2.0
01/15/2020 11:00	6.7	0.0	1.7	9.2	2.0
01/15/2020 12:00	6.5	0.0	1.6	9.0	2.0
01/15/2020 13:00	6.7	0.0	1.7	9.2	2.0
01/15/2020 14:00	6.8	0.0	1.7	9.3	2.0
01/15/2020 15:00	6.4	0.0	1.6	8.8	2.0
01/15/2020 16:00	12.4	2.3	2.0	11.3	2.4
01/15/2020 17:00	15.2	1.9	2.1	11.9	2.6
01/15/2020 18:00	15.0	1.9	2.1	11.7	2.6
01/15/2020 19:00	15.4	1.9	2.2	12.1	2.6
01/15/2020 20:00	15.4	1.6	2.2	12.1	2.6
01/15/2020 21:00	15.2	1.6	2.2	11.9	2.6
01/15/2020 22:00	14.7	1.6	2.1	11.5	2.6
01/15/2020 23:00	14.4	1.6	2.0	11.3	2.4
Average/Sum#:	289.0 #	30.3 #	46.9 #	260.4 #	56.6 #
Minimum:	6.4	0.0	1.6	8.8	2.0
Maximum:	15.9	2.3	2.3	12.5	2.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/16/2020 00:00	12.2	1.6	2.0	11.2	2.4
01/16/2020 01:00	12.2	1.9	2.0	11.2	2.4
01/16/2020 02:00	12.3	1.9	2.0	11.3	2.4
01/16/2020 03:00	12.3	1.9	2.0	11.3	2.4
01/16/2020 04:00	12.4	1.9	2.0	11.3	2.4
01/16/2020 05:00	14.4	1.9	2.0	11.3	2.4
01/16/2020 06:00	14.6	1.9	2.1	11.5	2.5
01/16/2020 07:00	15.2	1.9	2.2	11.9	2.6
01/16/2020 08:00	12.4	1.9	2.0	11.4	2.4
01/16/2020 09:00	11.8	1.9	2.0	10.8	2.4
01/16/2020 10:00	6.7	0.0	1.7	9.1	2.0
01/16/2020 11:00	6.3	0.0	1.6	8.6	1.8
01/16/2020 12:00	6.1	0.0	1.6	8.4	1.8
01/16/2020 13:00	6.7	0.0	1.7	9.1	2.0
01/16/2020 14:00	6.4	0.0	1.6	8.8	2.0
01/16/2020 15:00	6.9	0.0	1.7	9.5	2.0
01/16/2020 16:00	12.2	1.9	2.0	11.2	2.4
01/16/2020 17:00	14.3	1.9	2.0	11.2	2.4
01/16/2020 18:00	14.3	1.6	2.0	11.2	2.4
01/16/2020 19:00	14.3	1.6	2.0	11.2	2.4
01/16/2020 20:00	14.6	2.0	2.1	11.5	2.6
01/16/2020 21:00	14.7	2.0	2.1	11.5	2.6
01/16/2020 22:00	14.2	1.6	2.0	11.2	2.4
01/16/2020 23:00	14.3	1.6	2.0	11.2	2.4
Average/Sum#:	281.8 #	32.9 #	46.4 #	256.9 #	55.5 #
Minimum:	6.1	0.0	1.6	8.4	1.8
Maximum:	15.2	2.0	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/17/2020 00:00	14.3	1.6	2.0	11.2	2.4
01/17/2020 01:00	14.2	1.6	2.0	11.1	2.4
01/17/2020 02:00	14.3	1.7	2.0	11.2	2.4
01/17/2020 03:00	16.3	1.7	2.0	11.2	2.4
01/17/2020 04:00	14.4	1.7	2.0	11.3	2.4
01/17/2020 05:00	16.6	2.0	2.0	11.4	2.4
01/17/2020 06:00	15.4	2.0	2.2	12.1	2.6
01/17/2020 07:00	15.9	2.0	2.3	12.4	2.7
01/17/2020 08:00	12.4	1.7	2.0	11.4	2.4
01/17/2020 09:00	11.9	1.6	2.0	10.9	2.4
01/17/2020 10:00	6.7	0.0	1.7	9.3	2.0
01/17/2020 11:00	6.5	0.0	1.6	9.0	2.0
01/17/2020 12:00	6.7	0.0	1.7	9.2	2.0
01/17/2020 13:00	6.6	0.0	1.7	9.1	2.0
01/17/2020 14:00	6.5	0.0	1.6	9.0	2.0
01/17/2020 15:00	6.0	0.0	1.6	8.4	1.8
01/17/2020 16:00	12.0	2.0	2.0	11.0	2.4
01/17/2020 17:00	11.8	1.6	2.0	10.8	2.4
01/17/2020 18:00	13.8	1.6	2.0	10.8	2.4
01/17/2020 19:00	14.7	2.0	2.1	11.5	2.6
01/17/2020 20:00	14.9	2.0	2.1	11.7	2.6
01/17/2020 21:00	14.8	1.6	2.1	11.6	2.6
01/17/2020 22:00	14.6	1.6	2.1	11.5	2.6
01/17/2020 23:00	14.5	1.7	2.1	11.4	2.4
Average/Sum#:	295.8 #	31.7 #	46.9 #	258.5 #	56.3 #
Minimum:	6.0	0.0	1.6	8.4	1.8
Maximum:	16.6	2.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/18/2020 00:00	14.4	1.7	2.0	11.2	2.4
01/18/2020 01:00	14.4	1.6	2.0	11.4	2.4
01/18/2020 02:00	14.2	1.3	2.0	11.2	2.4
01/18/2020 03:00	14.2	1.7	2.0	11.2	2.4
01/18/2020 04:00	14.2	1.3	2.0	11.2	2.4
01/18/2020 05:00	14.2	1.7	2.0	11.2	2.4
01/18/2020 06:00	14.2	1.7	2.0	11.2	2.4
01/18/2020 07:00	12.2	1.7	2.0	11.2	2.4
01/18/2020 08:00	12.0	1.7	2.0	11.0	2.4
01/18/2020 09:00	6.7	0.0	1.7	9.3	2.0
01/18/2020 10:00	6.5	0.0	1.6	9.0	2.0
01/18/2020 11:00	6.4	0.0	1.6	8.9	2.0
01/18/2020 12:00	6.5	0.0	1.6	9.0	2.0
01/18/2020 13:00	6.7	0.0	1.7	9.1	2.0
01/18/2020 14:00	6.5	0.0	1.6	8.9	2.0
01/18/2020 15:00	6.4	0.0	1.6	8.8	2.0
01/18/2020 16:00	12.1	2.0	2.0	11.1	2.4
01/18/2020 17:00	14.3	1.6	2.0	11.2	2.4
01/18/2020 18:00	11.8	1.6	2.0	10.8	2.4
01/18/2020 19:00	14.4	1.6	2.0	11.4	2.4
01/18/2020 20:00	14.9	1.6	2.1	11.6	2.6
01/18/2020 21:00	14.9	1.6	2.1	11.7	2.6
01/18/2020 22:00	14.9	1.6	2.1	11.8	2.6
01/18/2020 23:00	14.7	1.6	2.1	11.6	2.6
Average/Sum#:	281.7 #	27.6 #	45.8 #	255.0 #	55.6 #
Minimum:	6.4	0.0	1.6	8.8	2.0
Maximum:	14.9	2.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/19/2020 00:00	14.2	1.6	2.0	11.2	2.4
01/19/2020 01:00	6.8	0.0	1.7	9.4	2.0
01/19/2020 02:00	6.3	0.0	1.6	8.6	1.8
01/19/2020 03:00	6.5	0.0	1.6	9.0	2.0
01/19/2020 04:00	6.5	0.0	1.6	9.0	2.0
01/19/2020 05:00	6.7	0.0	1.7	9.2	2.0
01/19/2020 06:00	6.8	0.0	1.7	9.3	2.0
01/19/2020 07:00	6.4	0.0	1.6	8.8	2.0
01/19/2020 08:00	6.3	0.0	1.6	8.6	1.8
01/19/2020 09:00	6.4	0.0	1.6	8.9	2.0
01/19/2020 10:00	6.3	0.0	1.6	8.6	1.8
01/19/2020 11:00	6.5	0.0	1.6	9.0	2.0
01/19/2020 12:00	6.7	0.0	1.7	9.1	2.0
01/19/2020 13:00	6.7	0.0	1.7	9.3	2.0
01/19/2020 14:00	6.3	0.0	1.6	8.8	1.9
01/19/2020 15:00	6.5	0.0	1.6	9.0	2.0
01/19/2020 16:00	6.4	0.0	1.6	8.9	2.0
01/19/2020 17:00	12.0	2.3	2.0	11.0	2.4
01/19/2020 18:00	12.2	2.0	2.0	11.2	2.4
01/19/2020 19:00	14.3	1.9	2.0	11.2	2.4
01/19/2020 20:00	14.7	1.9	2.1	11.6	2.6
01/19/2020 21:00	14.9	1.9	2.1	11.7	2.6
01/19/2020 22:00	14.9	1.9	2.1	11.7	2.6
01/19/2020 23:00	14.8	2.0	2.1	11.6	2.6
Average/Sum#:	216.1 #	15.5 #	42.5 #	234.7 #	51.3 #
Minimum:	6.3	0.0	1.6	8.6	1.8
Maximum:	14.9	2.3	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/20/2020 00:00	14.6	1.9	2.1	11.4	2.5
01/20/2020 01:00	14.3	2.0	2.0	11.2	2.4
01/20/2020 02:00	14.2	1.6	2.0	11.2	2.4
01/20/2020 03:00	14.2	1.6	2.0	11.2	2.4
01/20/2020 04:00	14.2	1.6	2.0	11.2	2.4
01/20/2020 05:00	14.4	1.9	2.0	11.2	2.4
01/20/2020 06:00	14.4	2.0	2.0	11.4	2.4
01/20/2020 07:00	16.9	2.0	2.1	11.6	2.6
01/20/2020 08:00	12.8	2.0	2.1	11.8	2.6
01/20/2020 09:00	14.8	1.6	2.1	11.6	2.6
01/20/2020 10:00	14.9	1.9	2.1	11.8	2.6
01/20/2020 11:00	12.7	1.6	2.1	11.6	2.6
01/20/2020 12:00	14.9	1.6	2.1	11.7	2.6
01/20/2020 13:00	14.8	1.6	2.1	11.6	2.6
01/20/2020 14:00	15.0	1.6	2.1	11.8	2.6
01/20/2020 15:00	14.8	1.6	2.1	11.6	2.6
01/20/2020 16:00	14.5	1.6	2.1	11.4	2.4
01/20/2020 17:00	14.8	1.9	2.1	11.6	2.6
01/20/2020 18:00	14.9	1.9	2.1	11.6	2.6
01/20/2020 19:00	12.7	1.9	2.1	11.6	2.6
01/20/2020 20:00	12.7	1.9	2.1	11.6	2.6
01/20/2020 21:00	14.8	1.9	2.1	11.6	2.6
01/20/2020 22:00	14.7	1.9	2.1	11.6	2.6
01/20/2020 23:00	14.5	1.9	2.0	11.4	2.4
Average/Sum#:	345.5 #	43.0 #	49.7 #	276.3 #	60.7 #
Minimum:	12.7	1.6	2.0	11.2	2.4
Maximum:	16.9	2.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/21/2020 00:00	14.3	1.6	2.0	11.2	2.4
01/21/2020 01:00	14.2	1.9	2.0	11.2	2.4
01/21/2020 02:00	14.3	1.9	2.0	11.2	2.4
01/21/2020 03:00	14.3	1.9	2.0	11.2	2.4
01/21/2020 04:00	14.2	1.9	2.0	11.2	2.4
01/21/2020 05:00	14.2	1.9	2.0	11.2	2.4
01/21/2020 06:00	12.0	1.9	2.0	11.0	2.4
01/21/2020 07:00	14.6	1.9	2.1	11.5	2.6
01/21/2020 08:00	14.4	1.9	2.0	11.3	2.4
01/21/2020 09:00	11.8	1.9	2.0	10.8	2.4
01/21/2020 10:00	6.7	0.0	1.7	9.2	2.0
01/21/2020 11:00	6.8	0.0	1.7	9.3	2.0
01/21/2020 12:00	6.7	0.0	1.7	9.1	2.0
01/21/2020 13:00	6.5	0.0	1.6	9.0	2.0
01/21/2020 14:00	6.5	0.0	1.6	9.0	2.0
01/21/2020 15:00	6.3	0.0	1.6	8.6	1.8
01/21/2020 16:00	12.2	2.2	2.0	11.2	2.4
01/21/2020 17:00	12.4	1.9	2.0	11.3	2.4
01/21/2020 18:00	14.3	1.9	2.0	11.2	2.4
01/21/2020 19:00	14.3	1.9	2.0	11.2	2.4
01/21/2020 20:00	14.3	1.6	2.0	11.2	2.4
01/21/2020 21:00	12.2	1.6	2.0	11.2	2.4
01/21/2020 22:00	14.5	1.9	2.1	11.4	2.4
01/21/2020 23:00	12.2	1.6	2.0	11.2	2.4
Average/Sum#:	284.2 #	33.3 #	46.1 #	255.9 #	55.2 #
Minimum:	6.3	0.0	1.6	8.6	1.8
Maximum:	14.6	2.2	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/22/2020 00:00	11.0	1.2	1.9	10.1	2.2
01/22/2020 01:00	5.2	0.0	1.3	7.2	1.6
01/22/2020 02:00	5.5	0.0	1.4	7.5	1.6
01/22/2020 03:00	5.3	0.0	1.3	7.3	1.6
01/22/2020 04:00	6.0	0.0	1.6	8.4	1.8
01/22/2020 05:00	5.9	0.0	1.4	8.0	1.8
01/22/2020 06:00	6.4	0.0	1.6	8.8	2.0
01/22/2020 07:00	6.5	0.0	1.6	9.0	2.0
01/22/2020 08:00	5.9	0.0	1.4	8.2	1.8
01/22/2020 09:00	6.4	0.0	1.6	8.8	2.0
01/22/2020 10:00	6.4	0.0	1.6	8.9	2.0
01/22/2020 11:00	6.8	0.0	1.7	9.3	2.0
01/22/2020 12:00	6.8	0.0	1.7	9.3	2.0
01/22/2020 13:00	6.7	0.0	1.7	9.1	2.0
01/22/2020 14:00	6.5	0.0	1.6	9.0	2.0
01/22/2020 15:00	6.4	0.0	1.6	8.8	2.0
01/22/2020 16:00	12.2	1.9	2.0	11.2	2.4
01/22/2020 17:00	14.1	1.6	2.0	11.1	2.4
01/22/2020 18:00	14.9	1.9	2.1	11.7	2.6
01/22/2020 19:00	14.9	1.6	2.1	11.6	2.6
01/22/2020 20:00	14.3	1.6	2.0	11.2	2.4
01/22/2020 21:00	14.3	1.6	2.0	11.2	2.4
01/22/2020 22:00	14.3	1.6	2.0	11.2	2.4
01/22/2020 23:00	11.8	2.0	2.0	10.8	2.4
Average/Sum#:	214.5 #	15.0 #	41.2 #	227.7 #	50.0 #
Minimum:	5.2	0.0	1.3	7.2	1.6
Maximum:	14.9	2.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/23/2020 00:00	14.7	1.9	2.1	11.5	2.6
01/23/2020 01:00	14.7	1.9	2.1	11.5	2.6
01/23/2020 02:00	14.3	1.6	2.0	11.2	2.4
01/23/2020 03:00	14.3	1.6	2.0	11.2	2.4
01/23/2020 04:00	14.8	1.9	2.1	11.6	2.6
01/23/2020 05:00	14.4	1.6	2.0	11.4	2.4
01/23/2020 06:00	12.9	2.0	2.1	11.8	2.6
01/23/2020 07:00	14.7	1.6	2.1	11.6	2.6
01/23/2020 08:00	11.7	1.6	2.0	10.8	2.4
01/23/2020 09:00	6.7	0.0	1.7	9.3	2.0
01/23/2020 10:00	6.2	0.0	1.6	8.6	1.8
01/23/2020 11:00	6.4	0.0	1.6	8.8	2.0
01/23/2020 12:00	6.5	0.0	1.6	9.0	2.0
01/23/2020 13:00	6.7	0.0	1.7	9.2	2.0
01/23/2020 14:00	6.6	0.0	1.7	9.1	2.0
01/23/2020 15:00	6.4	0.0	1.6	8.9	2.0
01/23/2020 16:00	6.0	0.0	1.5	8.2	1.8
01/23/2020 17:00	9.7	1.6	1.9	10.6	2.4
01/23/2020 18:00	12.8	1.9	2.1	11.7	2.6
01/23/2020 19:00	14.9	1.9	2.1	11.7	2.6
01/23/2020 20:00	14.9	1.6	2.1	11.6	2.6
01/23/2020 21:00	14.7	1.6	2.1	11.6	2.6
01/23/2020 22:00	14.5	1.6	2.0	11.4	2.4
01/23/2020 23:00	11.7	1.9	2.0	10.7	2.4
Average/Sum#:	271.2 #	27.8 #	45.8 #	253.0 #	55.8 #
Minimum:	6.0	0.0	1.5	8.2	1.8
Maximum:	14.9	2.0	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/24/2020 00:00	11.5	1.9	1.9	10.6	2.3
01/24/2020 01:00	6.5	0.0	1.6	9.0	2.0
01/24/2020 02:00	6.7	0.0	1.7	9.1	2.0
01/24/2020 03:00	6.8	0.0	1.7	9.3	2.0
01/24/2020 04:00	6.8	0.0	1.7	9.3	2.0
01/24/2020 05:00	6.4	0.0	1.6	8.8	2.0
01/24/2020 06:00	6.7	0.0	1.7	9.1	2.0
01/24/2020 07:00	6.6	0.0	1.7	9.1	2.0
01/24/2020 08:00	6.4	0.0	1.6	8.8	2.0
01/24/2020 09:00	6.7	0.0	1.7	9.2	2.0
01/24/2020 10:00	5.9	0.0	1.4	8.1	1.8
01/24/2020 11:00	6.7	0.0	1.7	9.1	2.0
01/24/2020 12:00	6.5	0.0	1.6	9.0	2.0
01/24/2020 13:00	6.7	0.0	1.7	9.2	2.0
01/24/2020 14:00	6.6	0.0	1.6	9.1	2.0
01/24/2020 15:00	6.2	0.0	1.6	8.6	1.8
01/24/2020 16:00	6.3	0.0	1.6	8.7	1.9
01/24/2020 17:00	12.2	2.3	2.0	11.2	2.4
01/24/2020 18:00	12.7	1.9	2.1	11.6	2.6
01/24/2020 19:00	14.8	1.9	2.1	11.6	2.6
01/24/2020 20:00	14.7	1.9	2.1	11.6	2.6
01/24/2020 21:00	14.6	1.6	2.1	11.4	2.5
01/24/2020 22:00	14.4	1.6	2.0	11.2	2.4
01/24/2020 23:00	12.1	12.5	0.7	3.5	0.8
Average/Sum#:	211.5 #	25.6 #	41.2 #	226.2 #	49.7 #
Minimum:	5.9	0.0	0.7	3.5	0.8
Maximum:	14.8	12.5	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/25/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
01/26/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/27/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 17:00	0.0	0.0	0.0	0.0	0.0
01/27/2020 18:00	64.8	87.4	0.1	1.1	0.2
01/27/2020 19:00	31.5	19.8	0.2	1.6	0.3
01/27/2020 20:00	32.6	57.6	0.3	2.6	0.5
01/27/2020 21:00	0.0	0.0	0.4	4.3	0.9
01/27/2020 22:00	1.4	0.0	0.4	4.1	0.8
01/27/2020 23:00	1.4	0.0	0.4	4.1	0.8
Average/Sum#:	131.7 #	164.8 #	1.8 #	17.8 #	3.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	64.8	87.4	0.4	4.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/28/2020 00:00	1.4	0.0	0.4	4.1	0.8
01/28/2020 01:00	1.4	0.0	0.4	4.1	0.8
01/28/2020 02:00	1.4	0.0	0.4	4.1	0.8
01/28/2020 03:00	54.5	89.3	0.7	5.6	1.2
01/28/2020 04:00	69.9	32.8	1.1	7.0	1.5
01/28/2020 05:00	6.4	0.0	1.6	8.8	2.0
01/28/2020 06:00	6.8	0.0	1.7	9.3	2.0
01/28/2020 07:00	6.4	0.0	1.6	8.8	2.0
01/28/2020 08:00	6.7	0.0	1.7	9.2	2.0
01/28/2020 09:00	6.7	0.0	1.7	9.3	2.0
01/28/2020 10:00	6.1	0.0	1.6	8.4	1.8
01/28/2020 11:00	6.4	0.0	1.6	8.9	2.0
01/28/2020 12:00	6.4	0.0	1.6	8.8	2.0
01/28/2020 13:00	6.7	0.0	1.7	9.1	2.0
01/28/2020 14:00	6.3	0.0	1.6	8.6	1.8
01/28/2020 15:00	6.3	0.0	1.6	8.6	1.8
01/28/2020 16:00	6.3	0.0	1.6	8.6	1.8
01/28/2020 17:00	12.2	2.3	2.0	11.2	2.4
01/28/2020 18:00	14.5	1.9	2.0	11.4	2.4
01/28/2020 19:00	14.6	1.6	2.1	11.5	2.6
01/28/2020 20:00	14.8	1.9	2.1	11.6	2.6
01/28/2020 21:00	14.9	1.6	2.1	11.6	2.6
01/28/2020 22:00	14.7	12.5	0.7	3.7	0.8
01/28/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	291.8 #	143.9 #	33.6 #	192.3 #	41.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	69.9	89.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/29/2020 00:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 01:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 06:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 07:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 08:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 09:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 10:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 11:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 12:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 13:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 14:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 15:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 16:00	0.0	0.0	0.0	0.0	0.0
01/29/2020 17:00	56.4	37.6	0.1	1.0	0.2
01/29/2020 18:00	49.9	37.1	0.2	2.0	0.4
01/29/2020 19:00	46.4	27.2	0.4	4.0	0.8
01/29/2020 20:00	5.6	0.0	0.6	5.6	1.1
01/29/2020 21:00	8.6	0.0	0.6	6.5	1.3
01/29/2020 22:00	3.3	0.0	0.5	4.9	1.0
01/29/2020 23:00	1.5	0.0	0.5	4.6	0.9
Average/Sum#:	171.7 #	101.9 #	2.9 #	28.6 #	5.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	56.4	37.6	0.6	6.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/30/2020 00:00	1.6	0.0	0.5	4.7	0.9
01/30/2020 01:00	1.6	0.0	0.5	4.7	0.9
01/30/2020 02:00	64.3	61.4	0.7	5.9	1.2
01/30/2020 03:00	46.7	30.0	1.2	7.2	1.6
01/30/2020 04:00	6.5	0.0	1.6	9.0	2.0
01/30/2020 05:00	5.6	0.0	1.4	7.7	1.6
01/30/2020 06:00	13.0	1.3	1.9	10.2	2.2
01/30/2020 07:00	12.6	2.0	2.1	11.5	2.6
01/30/2020 08:00	11.6	1.9	1.9	10.6	2.4
01/30/2020 09:00	6.5	0.0	1.6	9.0	2.0
01/30/2020 10:00	6.5	0.0	1.6	9.0	2.0
01/30/2020 11:00	6.7	0.0	1.7	9.3	2.0
01/30/2020 12:00	6.0	0.0	1.4	8.2	1.8
01/30/2020 13:00	6.7	0.0	1.7	9.1	2.0
01/30/2020 14:00	6.3	0.0	1.6	8.6	1.8
01/30/2020 15:00	6.5	0.0	1.6	9.0	2.0
01/30/2020 16:00	6.0	0.0	1.6	8.3	1.8
01/30/2020 17:00	6.5	0.0	1.6	9.0	2.0
01/30/2020 18:00	6.8	0.0	1.7	9.5	2.0
01/30/2020 19:00	12.2	1.9	2.0	11.2	2.4
01/30/2020 20:00	14.9	1.6	2.1	11.8	2.6
01/30/2020 21:00	14.8	1.6	2.1	11.6	2.6
01/30/2020 22:00	14.4	1.6	2.1	11.4	2.4
01/30/2020 23:00	10.6	0.3	1.7	9.7	2.2
Average/Sum#:	294.9 #	103.6 #	37.9 #	216.2 #	47.0 #
Minimum:	1.6	0.0	0.5	4.7	0.9
Maximum:	64.3	61.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
01/31/2020 00:00	6.4	6.4	0.9	6.0	1.3
01/31/2020 01:00	1.4	0.0	0.4	4.2	0.8
01/31/2020 02:00	1.4	0.0	0.4	4.2	0.8
01/31/2020 03:00	1.4	0.0	0.4	4.2	0.8
01/31/2020 04:00	1.5	0.0	0.4	4.4	0.9
01/31/2020 05:00	13.3	24.2	0.8	6.0	1.2
01/31/2020 06:00	34.7	32.5	1.4	7.8	1.7
01/31/2020 07:00	6.4	0.0	1.6	8.8	2.0
01/31/2020 08:00	6.1	0.0	1.6	8.4	1.8
01/31/2020 09:00	6.5	0.0	1.6	8.9	2.0
01/31/2020 10:00	6.5	0.0	1.6	9.0	2.0
01/31/2020 11:00	6.6	0.0	1.6	9.1	2.0
01/31/2020 12:00	6.4	0.0	1.6	8.9	2.0
01/31/2020 13:00	6.8	0.0	1.7	9.3	2.0
01/31/2020 14:00	6.7	0.0	1.7	9.3	2.0
01/31/2020 15:00	6.7	0.0	1.7	9.2	2.0
01/31/2020 16:00	5.9	0.0	1.4	8.2	1.8
01/31/2020 17:00	6.7	0.0	1.7	9.2	2.0
01/31/2020 18:00	9.2	0.9	1.8	10.1	2.2
01/31/2020 19:00	12.0	1.9	2.0	11.0	2.4
01/31/2020 20:00	14.7	1.9	2.1	11.6	2.6
01/31/2020 21:00	14.7	1.9	2.1	11.6	2.6
01/31/2020 22:00	14.7	1.9	2.1	11.5	2.6
01/31/2020 23:00	13.1	13.3	0.7	3.6	0.8
Average/Sum#:	209.8 #	84.9 #	33.3 #	194.5 #	42.3 #
Minimum:	1.4	0.0	0.4	3.6	0.8
Maximum:	34.7	32.5	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/01/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/01/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/02/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/02/2020 23:00	73.0	73.4	0.1	1.1	0.2
Average/Sum#:	73.0 #	73.4 #	0.1 #	1.1 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	73.0	73.4	0.1	1.1	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/03/2020 00:00	32.8	18.0	0.2	1.6	0.3
02/03/2020 01:00	50.1	58.8	0.2	2.1	0.4
02/03/2020 02:00	0.0	0.0	0.4	4.3	0.9
02/03/2020 03:00	2.5	28.4	0.4	4.5	0.9
02/03/2020 04:00	103.0	69.9	0.9	6.5	1.3
02/03/2020 05:00	40.1	23.8	1.5	8.1	1.7
02/03/2020 06:00	6.8	0.0	1.7	9.4	2.0
02/03/2020 07:00	6.4	0.0	1.6	8.9	2.0
02/03/2020 08:00	6.2	0.0	1.6	8.6	1.8
02/03/2020 09:00	5.9	0.0	1.4	8.2	1.8
02/03/2020 10:00	6.3	0.0	1.6	8.6	1.8
02/03/2020 11:00	6.8	0.0	1.7	9.3	2.0
02/03/2020 12:00	6.7	0.0	1.7	9.1	2.0
02/03/2020 13:00	6.6	0.0	1.6	9.1	2.0
02/03/2020 14:00	6.3	0.0	1.6	8.6	1.8
02/03/2020 15:00	6.7	0.0	1.7	9.1	2.0
02/03/2020 16:00	6.4	0.0	1.6	8.8	2.0
02/03/2020 17:00	12.4	2.0	2.0	11.3	2.4
02/03/2020 18:00	15.6	2.0	2.3	12.3	2.6
02/03/2020 19:00	15.9	1.6	2.3	12.4	2.7
02/03/2020 20:00	15.9	1.6	2.3	12.4	2.7
02/03/2020 21:00	15.1	1.6	2.1	11.8	2.6
02/03/2020 22:00	14.9	1.6	2.1	11.8	2.6
02/03/2020 23:00	14.7	1.7	2.1	11.6	2.6
Average/Sum#:	404.1 #	211.0 #	36.6 #	208.4 #	44.9 #
Minimum:	0.0	0.0	0.2	1.6	0.3
Maximum:	103.0	69.9	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/04/2020 00:00	14.5	1.7	2.1	11.4	2.4
02/04/2020 01:00	14.4	1.3	2.0	11.2	2.4
02/04/2020 02:00	14.4	1.7	2.0	11.2	2.4
02/04/2020 03:00	14.4	1.7	2.0	11.2	2.4
02/04/2020 04:00	14.5	1.7	2.1	11.4	2.4
02/04/2020 05:00	16.9	1.9	2.1	11.6	2.6
02/04/2020 06:00	17.3	1.7	2.1	11.8	2.6
02/04/2020 07:00	15.3	1.6	2.1	12.0	2.6
02/04/2020 08:00	14.3	1.3	2.0	11.2	2.4
02/04/2020 09:00	8.8	0.0	1.7	9.7	2.2
02/04/2020 10:00	8.8	0.0	1.7	9.7	2.2
02/04/2020 11:00	7.1	0.0	1.7	9.7	2.2
02/04/2020 12:00	7.1	0.0	1.7	9.7	2.2
02/04/2020 13:00	7.1	0.0	1.7	9.7	2.2
02/04/2020 14:00	7.1	0.0	1.7	9.7	2.2
02/04/2020 15:00	7.1	0.0	1.7	9.7	2.2
02/04/2020 16:00	9.2	0.6	1.9	10.1	2.2
02/04/2020 17:00	12.0	1.6	2.0	11.0	2.4
02/04/2020 18:00	14.9	2.0	2.1	11.7	2.6
02/04/2020 19:00	15.3	1.6	2.2	12.0	2.6
02/04/2020 20:00	15.3	1.6	2.2	12.0	2.6
02/04/2020 21:00	15.7	1.6	2.3	12.4	2.7
02/04/2020 22:00	14.7	1.6	2.1	11.6	2.6
02/04/2020 23:00	14.7	1.6	2.1	11.5	2.6
Average/Sum#:	300.9 #	26.8 #	47.3 #	263.2 #	57.9 #
Minimum:	7.1	0.0	1.7	9.7	2.2
Maximum:	17.3	2.0	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/05/2020 00:00	14.8	1.6	2.1	11.6	2.6
02/05/2020 01:00	14.6	1.6	2.1	11.4	2.5
02/05/2020 02:00	14.4	1.6	2.0	11.2	2.4
02/05/2020 03:00	14.3	1.6	2.0	11.2	2.4
02/05/2020 04:00	14.5	1.6	2.1	11.4	2.4
02/05/2020 05:00	16.0	2.0	2.0	11.0	2.4
02/05/2020 06:00	12.0	1.6	2.0	11.0	2.4
02/05/2020 07:00	15.3	1.6	2.2	12.1	2.6
02/05/2020 08:00	14.5	1.6	2.1	11.4	2.4
02/05/2020 09:00	11.7	1.6	2.0	10.8	2.4
02/05/2020 10:00	6.4	0.0	1.6	8.9	2.0
02/05/2020 11:00	6.4	0.0	1.6	8.9	2.0
02/05/2020 12:00	6.7	0.0	1.7	9.1	2.0
02/05/2020 13:00	6.7	0.0	1.7	9.2	2.0
02/05/2020 14:00	6.4	0.0	1.6	8.8	2.0
02/05/2020 15:00	6.7	0.0	1.7	9.3	2.0
02/05/2020 16:00	11.0	1.0	1.9	10.1	2.2
02/05/2020 17:00	19.7	1.9	2.0	10.8	2.4
02/05/2020 18:00	17.5	1.9	2.2	12.0	2.6
02/05/2020 19:00	14.9	1.9	2.1	11.7	2.6
02/05/2020 20:00	15.1	1.6	2.1	11.8	2.6
02/05/2020 21:00	14.7	1.9	2.1	11.6	2.6
02/05/2020 22:00	14.9	1.9	2.1	11.6	2.6
02/05/2020 23:00	14.4	1.9	2.0	11.3	2.4
Average/Sum#:	303.6 #	30.4 #	47.0 #	258.2 #	56.5 #
Minimum:	6.4	0.0	1.6	8.8	2.0
Maximum:	19.7	2.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/06/2020 00:00	14.2	1.9	2.0	11.2	2.4
02/06/2020 01:00	14.0	1.6	2.0	11.0	2.4
02/06/2020 02:00	14.0	1.6	2.0	11.0	2.4
02/06/2020 03:00	14.2	2.0	2.0	11.2	2.4
02/06/2020 04:00	14.1	1.6	2.0	11.1	2.4
02/06/2020 05:00	16.4	1.9	2.0	11.2	2.4
02/06/2020 06:00	14.5	2.3	2.1	11.4	2.4
02/06/2020 07:00	14.7	2.0	2.1	11.5	2.6
02/06/2020 08:00	11.6	1.6	1.9	10.6	2.4
02/06/2020 09:00	6.8	0.0	1.7	9.3	2.0
02/06/2020 10:00	6.7	0.0	1.7	9.3	2.0
02/06/2020 11:00	6.7	0.0	1.7	9.3	2.0
02/06/2020 12:00	6.4	0.0	1.6	8.8	2.0
02/06/2020 13:00	6.7	0.0	1.7	9.3	2.0
02/06/2020 14:00	6.7	0.0	1.7	9.1	2.0
02/06/2020 15:00	6.2	0.0	1.6	8.6	1.8
02/06/2020 16:00	6.3	0.0	1.6	8.6	1.8
02/06/2020 17:00	12.0	2.2	2.0	11.0	2.4
02/06/2020 18:00	14.7	2.2	2.1	11.6	2.6
02/06/2020 19:00	14.7	1.9	2.1	11.5	2.6
02/06/2020 20:00	14.7	1.9	2.1	11.6	2.6
02/06/2020 21:00	14.8	1.9	2.1	11.6	2.6
02/06/2020 22:00	14.6	1.9	2.1	11.5	2.6
02/06/2020 23:00	11.6	1.9	2.0	10.6	2.4
Average/Sum#:	277.3 #	30.4 #	45.9 #	251.9 #	55.2 #
Minimum:	6.2	0.0	1.6	8.6	1.8
Maximum:	16.4	2.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/07/2020 00:00	11.5	1.9	1.9	10.6	2.3
02/07/2020 01:00	6.8	0.0	1.7	9.3	2.0
02/07/2020 02:00	6.3	0.0	1.6	8.6	1.8
02/07/2020 03:00	6.3	0.0	1.6	8.6	1.8
02/07/2020 04:00	6.1	0.0	1.6	8.4	1.8
02/07/2020 05:00	6.3	0.3	1.6	8.6	1.8
02/07/2020 06:00	14.2	2.6	2.0	11.2	2.4
02/07/2020 07:00	14.5	2.3	2.1	11.5	2.5
02/07/2020 08:00	11.7	1.9	2.0	10.7	2.4
02/07/2020 09:00	6.6	0.0	1.7	9.1	2.0
02/07/2020 10:00	6.7	0.0	1.7	9.2	2.0
02/07/2020 11:00	6.7	0.0	1.7	9.3	2.0
02/07/2020 12:00	8.5	0.0	1.7	9.3	2.0
02/07/2020 13:00	8.5	0.0	1.7	9.3	2.0
02/07/2020 14:00	6.7	0.0	1.7	9.2	2.0
02/07/2020 15:00	6.7	0.0	1.7	9.3	2.0
02/07/2020 16:00	6.4	0.0	1.6	8.8	2.0
02/07/2020 17:00	14.1	2.2	2.0	11.1	2.4
02/07/2020 18:00	14.7	1.9	2.1	11.6	2.6
02/07/2020 19:00	14.6	1.9	2.1	11.5	2.6
02/07/2020 20:00	14.7	1.9	2.1	11.6	2.6
02/07/2020 21:00	14.7	1.9	2.1	11.6	2.6
02/07/2020 22:00	14.4	1.9	2.0	11.3	2.4
02/07/2020 23:00	13.0	13.2	0.6	3.4	0.8
Average/Sum#:	240.7 #	33.9 #	42.6 #	233.1 #	50.8 #
Minimum:	6.1	0.0	0.6	3.4	0.8
Maximum:	14.7	13.2	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/08/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/09/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/09/2020 23:00	66.2	67.6	0.1	1.0	0.2
Average/Sum#:	66.2 #	67.6 #	0.1 #	1.0 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	66.2	67.6	0.1	1.0	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/10/2020 00:00	75.6	47.7	0.2	2.1	0.4
02/10/2020 01:00	61.9	45.8	0.3	3.0	0.6
02/10/2020 02:00	1.4	0.0	0.4	4.3	0.9
02/10/2020 03:00	76.0	70.5	0.6	4.9	1.0
02/10/2020 04:00	84.2	53.9	1.0	6.3	1.3
02/10/2020 05:00	40.8	28.0	1.2	7.2	1.6
02/10/2020 06:00	8.5	0.0	1.7	9.3	2.0
02/10/2020 07:00	6.8	0.0	1.7	9.3	2.0
02/10/2020 08:00	6.7	0.0	1.7	9.1	2.0
02/10/2020 09:00	6.7	0.0	1.7	9.1	2.0
02/10/2020 10:00	6.5	0.0	1.6	9.0	2.0
02/10/2020 11:00	6.7	0.0	1.7	9.2	2.0
02/10/2020 12:00	6.7	0.0	1.7	9.2	2.0
02/10/2020 13:00	6.7	0.0	1.7	9.1	2.0
02/10/2020 14:00	6.6	0.0	1.7	9.1	2.0
02/10/2020 15:00	6.7	0.0	1.7	9.1	2.0
02/10/2020 16:00	8.5	0.0	1.7	9.3	2.0
02/10/2020 17:00	9.2	1.0	1.9	10.1	2.2
02/10/2020 18:00	12.3	1.9	2.0	11.3	2.4
02/10/2020 19:00	14.5	1.9	2.0	11.4	2.4
02/10/2020 20:00	14.7	1.9	2.1	11.6	2.6
02/10/2020 21:00	14.9	1.9	2.1	11.6	2.6
02/10/2020 22:00	14.7	1.9	2.1	11.6	2.6
02/10/2020 23:00	14.2	1.9	2.0	11.2	2.4
Average/Sum#:	511.5 #	258.3 #	36.5 #	207.4 #	45.0 #
Minimum:	1.4	0.0	0.2	2.1	0.4
Maximum:	84.2	70.5	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/11/2020 00:00	11.5	1.9	1.9	10.6	2.3
02/11/2020 01:00	6.3	0.0	1.6	8.6	1.8
02/11/2020 02:00	5.9	0.0	1.4	8.1	1.8
02/11/2020 03:00	6.1	0.0	1.6	8.4	1.8
02/11/2020 04:00	6.0	0.0	1.6	8.4	1.8
02/11/2020 05:00	6.5	0.0	1.6	9.0	2.0
02/11/2020 06:00	8.2	0.0	1.6	9.0	2.0
02/11/2020 07:00	6.3	0.0	1.6	8.6	1.8
02/11/2020 08:00	4.2	0.0	1.4	7.6	1.6
02/11/2020 09:00	6.2	0.0	1.6	8.6	1.8
02/11/2020 10:00	6.4	0.0	1.6	8.8	2.0
02/11/2020 11:00	6.5	0.0	1.6	9.0	2.0
02/11/2020 12:00	6.7	0.0	1.7	9.2	2.0
02/11/2020 13:00	8.4	0.0	1.7	9.3	2.0
02/11/2020 14:00	6.6	0.0	1.7	9.1	2.0
02/11/2020 15:00	6.1	0.0	1.6	8.4	1.8
02/11/2020 16:00	5.9	0.0	1.4	8.1	1.8
02/11/2020 17:00	4.8	0.0	1.6	9.0	2.0
02/11/2020 18:00	9.2	1.0	1.9	10.1	2.2
02/11/2020 19:00	14.9	1.9	2.1	11.7	2.6
02/11/2020 20:00	14.9	1.9	2.1	11.8	2.6
02/11/2020 21:00	15.1	1.6	2.1	11.8	2.6
02/11/2020 22:00	14.9	1.6	2.1	11.8	2.6
02/11/2020 23:00	14.6	1.6	2.1	11.4	2.5
Average/Sum#:	202.2 #	11.5 #	41.2 #	226.4 #	49.4 #
Minimum:	4.2	0.0	1.4	7.6	1.6
Maximum:	15.1	1.9	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/12/2020 00:00	13.5	1.3	1.9	10.6	2.4
02/12/2020 01:00	6.3	0.0	1.6	8.6	1.8
02/12/2020 02:00	6.1	0.0	1.6	8.5	1.8
02/12/2020 03:00	6.0	0.0	1.6	8.3	1.8
02/12/2020 04:00	5.0	0.0	1.7	9.1	2.0
02/12/2020 05:00	6.6	0.0	1.7	9.1	2.0
02/12/2020 06:00	6.4	0.0	1.6	8.9	2.0
02/12/2020 07:00	6.3	0.0	1.6	8.6	1.8
02/12/2020 08:00	6.8	0.0	1.7	9.3	2.0
02/12/2020 09:00	6.7	0.0	1.7	9.3	2.0
02/12/2020 10:00	6.7	0.0	1.7	9.2	2.0
02/12/2020 11:00	6.7	0.0	1.7	9.2	2.0
02/12/2020 12:00	6.5	0.0	1.6	9.0	2.0
02/12/2020 13:00	8.4	0.0	1.7	9.3	2.0
02/12/2020 14:00	6.5	0.0	1.6	8.9	2.0
02/12/2020 15:00	6.4	0.0	1.6	8.9	2.0
02/12/2020 16:00	5.6	0.0	1.4	7.7	1.6
02/12/2020 17:00	4.9	0.0	1.6	9.0	2.0
02/12/2020 18:00	8.5	0.0	1.7	9.3	2.0
02/12/2020 19:00	14.3	2.2	2.0	11.2	2.4
02/12/2020 20:00	15.1	1.9	2.1	11.9	2.6
02/12/2020 21:00	14.9	1.9	2.1	11.7	2.6
02/12/2020 22:00	14.8	1.9	2.1	11.7	2.6
02/12/2020 23:00	14.4	1.9	2.1	11.3	2.4
Average/Sum#:	203.4 #	11.1 #	41.7 #	228.6 #	49.8 #
Minimum:	4.9	0.0	1.4	7.7	1.6
Maximum:	15.1	2.2	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/13/2020 00:00	14.4	1.9	2.0	11.3	2.4
02/13/2020 01:00	14.2	1.9	2.0	11.2	2.4
02/13/2020 02:00	14.2	1.9	2.0	11.2	2.4
02/13/2020 03:00	14.2	1.9	2.0	11.2	2.4
02/13/2020 04:00	14.2	1.9	2.0	11.2	2.4
02/13/2020 05:00	14.2	2.3	2.0	11.2	2.4
02/13/2020 06:00	15.0	2.3	2.1	11.8	2.6
02/13/2020 07:00	14.6	1.9	2.1	11.4	2.5
02/13/2020 08:00	11.6	1.9	1.9	10.6	2.4
02/13/2020 09:00	6.7	0.0	1.7	9.1	2.0
02/13/2020 10:00	6.6	0.0	1.7	9.1	2.0
02/13/2020 11:00	6.6	0.0	1.7	9.1	2.0
02/13/2020 12:00	8.4	0.0	1.7	9.3	2.0
02/13/2020 13:00	8.0	0.0	1.6	8.9	2.0
02/13/2020 14:00	8.2	0.0	1.6	9.0	2.0
02/13/2020 15:00	6.3	0.0	1.6	8.8	1.9
02/13/2020 16:00	6.4	0.0	1.6	8.8	2.0
02/13/2020 17:00	14.1	2.5	2.0	11.1	2.4
02/13/2020 18:00	14.8	2.2	2.1	11.6	2.6
02/13/2020 19:00	14.9	2.2	2.1	11.7	2.6
02/13/2020 20:00	14.8	2.2	2.1	11.7	2.6
02/13/2020 21:00	14.8	2.2	2.1	11.7	2.6
02/13/2020 22:00	14.7	2.2	2.1	11.6	2.6
02/13/2020 23:00	14.6	1.9	2.1	11.5	2.5
Average/Sum#:	286.5 #	33.3 #	45.9 #	254.1 #	55.7 #
Minimum:	6.3	0.0	1.6	8.8	1.9
Maximum:	15.0	2.5	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/14/2020 00:00	20.0	16.0	1.6	8.5	1.8
02/14/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/14/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	20.0 #	16.0 #	1.6 #	8.5 #	1.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	20.0	16.0	1.6	8.5	1.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/15/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/15/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/16/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/16/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/17/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/17/2020 09:00	78.8	71.1	0.1	1.1	0.2
02/17/2020 10:00	39.6	14.8	0.2	1.6	0.3
02/17/2020 11:00	54.2	43.3	0.2	2.0	0.4
02/17/2020 12:00	60.1	60.1	0.3	2.9	0.6
02/17/2020 13:00	0.0	0.0	0.4	4.2	0.8
02/17/2020 14:00	1.4	0.0	0.4	4.2	0.8
02/17/2020 15:00	98.9	70.1	0.8	6.0	1.3
02/17/2020 16:00	61.9	30.5	1.2	7.2	1.5
02/17/2020 17:00	6.8	0.0	1.7	9.3	2.0
02/17/2020 18:00	8.7	0.0	1.7	9.5	2.0
02/17/2020 19:00	14.2	2.0	2.0	11.2	2.4
02/17/2020 20:00	15.0	1.9	2.1	11.8	2.6
02/17/2020 21:00	14.9	1.9	2.1	11.8	2.6
02/17/2020 22:00	14.8	1.6	2.1	11.6	2.6
02/17/2020 23:00	14.4	1.6	2.1	11.4	2.4
Average/Sum#:	483.7 #	298.9 #	17.4 #	105.8 #	22.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	98.9	71.1	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/18/2020 00:00	14.4	1.6	2.0	11.3	2.4
02/18/2020 01:00	14.4	1.9	2.0	11.3	2.4
02/18/2020 02:00	14.2	1.6	2.0	11.2	2.4
02/18/2020 03:00	14.4	1.9	2.0	11.3	2.4
02/18/2020 04:00	14.4	2.0	2.0	11.3	2.4
02/18/2020 05:00	14.6	1.9	2.1	11.4	2.5
02/18/2020 06:00	14.8	1.9	2.1	11.6	2.6
02/18/2020 07:00	14.8	1.9	2.1	11.6	2.6
02/18/2020 08:00	14.4	1.6	2.0	11.4	2.4
02/18/2020 09:00	13.6	1.6	2.0	10.8	2.4
02/18/2020 10:00	11.7	2.3	2.0	10.7	2.4
02/18/2020 11:00	13.7	2.3	2.0	10.7	2.4
02/18/2020 12:00	11.7	2.3	2.0	10.7	2.4
02/18/2020 13:00	8.8	0.3	1.7	9.7	2.2
02/18/2020 14:00	4.2	0.0	1.4	7.7	1.6
02/18/2020 15:00	4.5	0.0	1.5	8.2	1.8
02/18/2020 16:00	12.0	2.3	2.0	11.0	2.4
02/18/2020 17:00	14.9	2.2	2.1	11.8	2.6
02/18/2020 18:00	15.1	1.9	2.1	11.9	2.6
02/18/2020 19:00	15.5	1.9	2.3	12.2	2.6
02/18/2020 20:00	15.5	1.9	2.3	12.2	2.6
02/18/2020 21:00	15.1	1.6	2.1	11.8	2.6
02/18/2020 22:00	14.8	1.6	2.1	11.6	2.6
02/18/2020 23:00	14.4	1.6	2.0	11.4	2.4
Average/Sum#:	315.9 #	40.1 #	47.9 #	264.8 #	57.7 #
Minimum:	4.2	0.0	1.4	7.7	1.6
Maximum:	15.5	2.3	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/19/2020 00:00	15.6	1.9	2.3	12.2	2.6
02/19/2020 01:00	14.2	1.6	2.0	11.2	2.4
02/19/2020 02:00	13.6	1.6	1.9	10.6	2.4
02/19/2020 03:00	11.6	2.0	2.0	10.6	2.4
02/19/2020 04:00	14.5	1.9	2.1	11.4	2.4
02/19/2020 05:00	16.8	2.3	2.1	11.6	2.6
02/19/2020 06:00	14.7	1.9	2.1	11.6	2.6
02/19/2020 07:00	15.3	1.9	2.2	12.0	2.6
02/19/2020 08:00	11.9	1.6	2.0	10.9	2.4
02/19/2020 09:00	13.5	1.9	1.9	10.5	2.3
02/19/2020 10:00	11.5	2.9	1.9	10.6	2.3
02/19/2020 11:00	11.5	3.2	1.9	10.6	2.3
02/19/2020 12:00	11.5	3.2	1.9	10.6	2.3
02/19/2020 13:00	15.4	3.2	1.9	10.6	2.3
02/19/2020 14:00	13.5	2.9	1.9	10.6	2.3
02/19/2020 15:00	13.5	2.9	1.9	10.6	2.3
02/19/2020 16:00	12.1	2.2	2.0	11.1	2.4
02/19/2020 17:00	14.8	1.9	2.1	11.7	2.6
02/19/2020 18:00	14.9	1.9	2.1	11.7	2.6
02/19/2020 19:00	15.4	1.9	2.3	12.1	2.6
02/19/2020 20:00	15.3	1.9	2.1	12.0	2.6
02/19/2020 21:00	15.2	1.9	2.1	12.0	2.6
02/19/2020 22:00	14.4	1.9	2.0	11.3	2.4
02/19/2020 23:00	14.3	1.9	2.0	11.1	2.4
Average/Sum#:	335.0 #	52.4 #	48.7 #	269.2 #	58.7 #
Minimum:	11.5	1.6	1.9	10.5	2.3
Maximum:	16.8	3.2	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/20/2020 00:00	14.1	1.6	2.0	11.1	2.4
02/20/2020 01:00	14.2	1.9	2.0	11.1	2.4
02/20/2020 02:00	14.2	1.9	2.0	11.1	2.4
02/20/2020 03:00	14.2	1.9	2.0	11.1	2.4
02/20/2020 04:00	14.2	1.9	2.0	11.1	2.4
02/20/2020 05:00	14.3	1.9	2.0	11.3	2.4
02/20/2020 06:00	14.4	2.2	2.0	11.3	2.4
02/20/2020 07:00	14.5	1.9	2.0	11.3	2.4
02/20/2020 08:00	14.3	1.9	2.0	11.2	2.4
02/20/2020 09:00	11.6	1.6	1.9	10.7	2.3
02/20/2020 10:00	11.5	1.9	1.9	10.6	2.3
02/20/2020 11:00	11.5	1.9	1.9	10.6	2.3
02/20/2020 12:00	11.5	1.9	1.9	10.6	2.3
02/20/2020 13:00	13.5	1.9	1.9	10.7	2.3
02/20/2020 14:00	13.6	1.9	1.9	10.7	2.4
02/20/2020 15:00	11.9	1.9	2.0	10.9	2.4
02/20/2020 16:00	14.5	1.9	2.0	11.3	2.4
02/20/2020 17:00	14.6	1.9	2.0	11.5	2.5
02/20/2020 18:00	14.6	2.2	2.0	11.5	2.5
02/20/2020 19:00	14.7	2.2	2.1	11.5	2.6
02/20/2020 20:00	14.7	2.2	2.1	11.6	2.6
02/20/2020 21:00	14.8	1.9	2.1	11.6	2.6
02/20/2020 22:00	14.6	1.9	2.1	11.6	2.6
02/20/2020 23:00	14.2	1.9	2.0	11.2	2.4
Average/Sum#:	330.2 #	46.2 #	47.8 #	267.2 #	58.1 #
Minimum:	11.5	1.6	1.9	10.6	2.3
Maximum:	14.8	2.2	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/21/2020 00:00	13.4	1.6	1.9	10.4	2.2
02/21/2020 01:00	6.0	0.0	1.6	8.4	1.8
02/21/2020 02:00	5.9	0.0	1.4	8.1	1.8
02/21/2020 03:00	6.2	0.0	1.6	8.5	1.8
02/21/2020 04:00	6.7	0.0	1.7	9.2	2.0
02/21/2020 05:00	6.3	0.0	1.6	8.7	1.9
02/21/2020 06:00	8.3	0.0	1.7	9.2	2.0
02/21/2020 07:00	6.4	0.0	1.6	8.9	2.0
02/21/2020 08:00	6.2	0.0	1.6	8.5	1.8
02/21/2020 09:00	6.6	0.0	1.7	9.2	2.0
02/21/2020 10:00	6.4	0.0	1.6	8.9	2.0
02/21/2020 11:00	6.3	0.0	1.6	8.7	1.9
02/21/2020 12:00	6.6	0.0	1.7	9.1	2.0
02/21/2020 13:00	6.6	0.0	1.6	9.1	2.0
02/21/2020 14:00	6.7	0.0	1.7	9.3	2.0
02/21/2020 15:00	6.7	0.0	1.7	9.2	2.0
02/21/2020 16:00	8.4	0.0	1.7	9.3	2.0
02/21/2020 17:00	11.9	2.2	2.0	10.9	2.4
02/21/2020 18:00	12.5	2.2	2.1	11.5	2.5
02/21/2020 19:00	14.4	1.9	2.0	11.3	2.4
02/21/2020 20:00	14.6	1.9	2.0	11.4	2.5
02/21/2020 21:00	14.4	1.9	2.0	11.3	2.4
02/21/2020 22:00	14.6	1.9	2.0	11.5	2.5
02/21/2020 23:00	11.6	12.6	0.6	3.3	0.8
Average/Sum#:	213.7 #	26.2 #	40.7 #	223.9 #	48.7 #
Minimum:	5.9	0.0	0.6	3.3	0.8
Maximum:	14.6	12.6	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/22/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/22/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/23/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/23/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/24/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/24/2020 13:00	71.0	71.4	0.1	1.0	0.2
02/24/2020 14:00	66.4	26.4	0.2	1.9	0.4
02/24/2020 15:00	78.3	39.4	0.3	2.6	0.5
02/24/2020 16:00	1.5	0.0	0.5	4.5	0.9
02/24/2020 17:00	8.3	0.0	0.6	6.3	1.3
02/24/2020 18:00	8.7	0.0	0.7	6.5	1.3
02/24/2020 19:00	8.6	0.0	0.6	6.5	1.3
02/24/2020 20:00	8.4	0.0	0.6	6.3	1.3
02/24/2020 21:00	8.3	0.0	0.6	6.3	1.3
02/24/2020 22:00	7.9	0.0	0.6	5.9	1.2
02/24/2020 23:00	8.1	0.0	0.6	6.1	1.2
Average/Sum#:	275.5 #	137.2 #	5.4 #	53.9 #	10.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	78.3	71.4	0.7	6.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/25/2020 00:00	1.6	0.0	0.5	4.7	0.9
02/25/2020 01:00	1.5	0.0	0.5	4.5	0.9
02/25/2020 02:00	1.4	0.0	0.4	4.1	0.8
02/25/2020 03:00	1.4	0.0	0.4	4.1	0.8
02/25/2020 04:00	1.5	0.0	0.4	4.4	0.9
02/25/2020 05:00	5.9	0.0	0.6	5.9	1.2
02/25/2020 06:00	5.9	0.0	0.6	5.9	1.2
02/25/2020 07:00	5.8	0.0	0.6	5.8	1.2
02/25/2020 08:00	1.4	0.0	0.4	4.2	0.8
02/25/2020 09:00	1.4	0.0	0.4	4.1	0.8
02/25/2020 10:00	0.0	0.0	0.4	4.1	0.8
02/25/2020 11:00	0.0	0.0	0.4	4.1	0.8
02/25/2020 12:00	0.0	0.0	0.4	4.1	0.8
02/25/2020 13:00	0.0	0.0	0.4	4.1	0.8
02/25/2020 14:00	74.5	63.6	0.7	5.6	1.2
02/25/2020 15:00	97.2	36.2	1.1	6.6	1.4
02/25/2020 16:00	8.1	0.0	1.6	8.9	2.0
02/25/2020 17:00	6.2	0.0	1.6	8.5	1.8
02/25/2020 18:00	15.8	1.9	2.0	10.9	2.4
02/25/2020 19:00	12.7	1.9	2.1	11.7	2.6
02/25/2020 20:00	15.0	1.9	2.1	11.9	2.6
02/25/2020 21:00	15.0	1.9	2.1	11.7	2.6
02/25/2020 22:00	14.8	1.9	2.1	11.7	2.6
02/25/2020 23:00	14.8	1.9	2.1	11.7	2.6
Average/Sum#:	301.9 #	111.2 #	23.9 #	163.3 #	34.5 #
Minimum:	0.0	0.0	0.4	4.1	0.8
Maximum:	97.2	63.6	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/26/2020 00:00	14.4	1.9	2.0	11.3	2.4
02/26/2020 01:00	14.3	1.9	2.0	11.2	2.4
02/26/2020 02:00	14.3	1.9	2.0	11.2	2.4
02/26/2020 03:00	14.1	1.9	2.0	11.1	2.4
02/26/2020 04:00	14.1	1.9	2.0	11.1	2.4
02/26/2020 05:00	14.1	1.9	2.0	11.1	2.4
02/26/2020 06:00	14.1	1.9	2.0	11.1	2.4
02/26/2020 07:00	14.1	1.6	2.0	11.0	2.4
02/26/2020 08:00	13.7	12.1	0.6	3.1	0.6
02/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/26/2020 15:00	50.0	16.1	0.1	0.9	0.2
02/26/2020 16:00	36.6	17.8	0.4	3.9	0.8
02/26/2020 17:00	6.1	0.0	0.6	6.1	1.2
02/26/2020 18:00	8.2	0.0	0.6	6.1	1.2
02/26/2020 19:00	5.9	0.0	0.6	5.9	1.2
02/26/2020 20:00	8.3	0.0	0.6	6.3	1.3
02/26/2020 21:00	8.0	0.0	0.6	6.0	1.2
02/26/2020 22:00	7.8	0.0	0.6	5.9	1.2
02/26/2020 23:00	5.4	0.0	0.5	5.4	1.1
Average/Sum#:	263.5 #	60.9 #	21.2 #	138.7 #	29.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	50.0	17.8	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/27/2020 00:00	1.5	0.0	0.5	4.5	0.9
02/27/2020 01:00	1.5	0.0	0.4	4.4	0.9
02/27/2020 02:00	45.0	37.6	0.7	5.3	1.0
02/27/2020 03:00	63.5	44.4	1.1	6.9	1.5
02/27/2020 04:00	7.0	0.0	1.7	9.6	2.1
02/27/2020 05:00	7.0	0.0	1.7	9.6	2.1
02/27/2020 06:00	7.0	0.0	1.7	9.6	2.1
02/27/2020 07:00	7.0	0.0	1.7	9.6	2.1
02/27/2020 08:00	7.0	0.0	1.7	9.6	2.1
02/27/2020 09:00	8.7	0.0	1.7	9.6	2.1
02/27/2020 10:00	10.4	0.0	1.7	9.6	2.1
02/27/2020 11:00	10.4	0.0	1.7	9.6	2.1
02/27/2020 12:00	10.3	0.0	1.7	9.5	2.0
02/27/2020 13:00	6.7	0.0	1.7	9.2	2.0
02/27/2020 14:00	6.6	0.0	1.7	9.1	2.0
02/27/2020 15:00	6.6	0.0	1.6	9.1	2.0
02/27/2020 16:00	10.9	1.2	1.9	10.0	2.2
02/27/2020 17:00	20.4	2.2	2.0	11.2	2.4
02/27/2020 18:00	20.4	2.2	2.0	11.3	2.4
02/27/2020 19:00	20.4	2.2	2.0	11.3	2.4
02/27/2020 20:00	20.9	2.2	2.1	11.5	2.5
02/27/2020 21:00	20.9	2.2	2.1	11.5	2.5
02/27/2020 22:00	20.9	2.2	2.1	11.5	2.6
02/27/2020 23:00	18.0	1.9	2.0	11.0	2.4
Average/Sum#:	359.0 #	98.3 #	39.2 #	224.1 #	48.5 #
Minimum:	1.5	0.0	0.4	4.4	0.9
Maximum:	63.5	44.4	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/28/2020 00:00	15.2	1.9	1.9	10.5	2.3
02/28/2020 01:00	7.9	0.0	1.6	8.7	1.9
02/28/2020 02:00	5.9	0.0	1.5	8.2	1.8
02/28/2020 03:00	6.0	0.0	1.5	8.3	1.8
02/28/2020 04:00	6.0	0.0	1.5	8.2	1.8
02/28/2020 05:00	6.6	0.0	1.6	9.0	2.0
02/28/2020 06:00	6.7	0.0	1.7	9.2	2.0
02/28/2020 07:00	6.5	0.0	1.6	9.0	2.0
02/28/2020 08:00	6.2	0.0	1.6	8.5	1.8
02/28/2020 09:00	6.0	0.0	1.6	8.4	1.8
02/28/2020 10:00	5.9	0.0	1.4	8.0	1.8
02/28/2020 11:00	6.0	0.0	1.5	8.2	1.8
02/28/2020 12:00	6.2	0.0	1.6	8.6	1.8
02/28/2020 13:00	7.9	0.0	1.6	8.7	1.9
02/28/2020 14:00	5.8	0.0	1.4	8.0	1.8
02/28/2020 15:00	6.2	0.0	1.6	8.5	1.8
02/28/2020 16:00	12.0	2.5	2.0	11.0	2.4
02/28/2020 17:00	14.3	2.4	2.0	11.2	2.4
02/28/2020 18:00	14.1	2.1	2.0	11.1	2.4
02/28/2020 19:00	14.3	2.5	2.0	11.2	2.4
02/28/2020 20:00	14.1	2.2	2.0	11.1	2.4
02/28/2020 21:00	14.3	2.5	2.0	11.3	2.4
02/28/2020 22:00	14.1	2.2	2.0	11.1	2.4
02/28/2020 23:00	10.9	13.4	0.6	3.5	0.8
Average/Sum#:	219.1 #	31.7 #	39.8 #	219.5 #	47.7 #
Minimum:	5.8	0.0	0.6	3.5	0.8
Maximum:	15.2	13.4	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
02/29/2020 00:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 01:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 02:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 03:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 04:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 05:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 06:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 07:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 08:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 09:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 10:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 11:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 12:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 13:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 14:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 15:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 16:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 17:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 18:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 19:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 20:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 21:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 22:00	0.0	0.0	0.0	0.0	0.0
02/29/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/01/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/01/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/02/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/02/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/03/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/03/2020 08:00	4.4	37.5	0.0	0.2	0.0
03/03/2020 09:00	90.1	46.4	0.2	1.6	0.3
03/03/2020 10:00	34.4	22.7	0.2	1.7	0.3
03/03/2020 11:00	65.7	60.8	0.2	2.2	0.4
03/03/2020 12:00	45.6	26.4	0.3	3.4	0.7
03/03/2020 13:00	1.4	0.0	0.4	4.2	0.8
03/03/2020 14:00	1.4	0.0	0.4	4.2	0.8
03/03/2020 15:00	66.9	58.5	0.7	5.4	1.1
03/03/2020 16:00	100.1	28.8	1.1	6.8	1.4
03/03/2020 17:00	7.9	0.0	1.6	8.7	1.9
03/03/2020 18:00	12.5	1.8	2.1	11.5	2.5
03/03/2020 19:00	15.1	1.8	2.1	11.9	2.6
03/03/2020 20:00	15.0	1.8	2.1	11.9	2.6
03/03/2020 21:00	15.0	1.5	2.1	11.9	2.6
03/03/2020 22:00	14.8	1.5	2.1	11.7	2.6
03/03/2020 23:00	14.6	1.9	2.1	11.5	2.5
Average/Sum#:	504.9 #	291.4 #	17.7 #	108.8 #	23.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	100.1	60.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/04/2020 00:00	14.3	1.9	2.0	11.3	2.4
03/04/2020 01:00	14.3	1.9	2.0	11.1	2.4
03/04/2020 02:00	11.9	1.6	2.0	10.9	2.4
03/04/2020 03:00	11.9	1.6	2.0	10.9	2.4
03/04/2020 04:00	14.2	1.9	2.0	11.1	2.4
03/04/2020 05:00	14.2	1.9	2.0	11.1	2.4
03/04/2020 06:00	12.1	1.9	2.0	11.1	2.4
03/04/2020 07:00	14.1	1.9	2.0	11.1	2.4
03/04/2020 08:00	7.4	0.0	1.5	8.2	1.8
03/04/2020 09:00	5.5	0.0	1.3	7.5	1.6
03/04/2020 10:00	5.5	0.0	1.3	7.5	1.6
03/04/2020 11:00	6.2	0.0	1.6	8.6	1.8
03/04/2020 12:00	8.4	0.0	1.7	9.3	2.0
03/04/2020 13:00	6.0	0.0	1.6	8.4	1.8
03/04/2020 14:00	8.1	0.0	1.6	8.9	2.0
03/04/2020 15:00	7.9	0.0	1.6	8.7	1.9
03/04/2020 16:00	7.7	0.0	1.6	8.5	1.8
03/04/2020 17:00	14.1	2.2	2.0	11.1	2.4
03/04/2020 18:00	14.3	2.2	2.0	11.3	2.4
03/04/2020 19:00	14.3	2.2	2.0	11.3	2.4
03/04/2020 20:00	14.8	2.2	2.1	11.6	2.6
03/04/2020 21:00	14.8	2.1	2.1	11.7	2.6
03/04/2020 22:00	14.7	1.8	2.1	11.5	2.6
03/04/2020 23:00	14.3	1.9	2.0	11.3	2.4
Average/Sum#:	271.0 #	29.2 #	44.1 #	244.0 #	52.9 #
Minimum:	5.5	0.0	1.3	7.5	1.6
Maximum:	14.8	2.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/05/2020 00:00	13.9	1.9	2.0	10.9	2.4
03/05/2020 01:00	13.9	1.9	2.0	10.9	2.4
03/05/2020 02:00	13.9	1.9	2.0	10.9	2.4
03/05/2020 03:00	13.9	1.9	2.0	10.9	2.4
03/05/2020 04:00	14.3	2.2	2.0	11.3	2.4
03/05/2020 05:00	14.3	2.2	2.0	11.3	2.4
03/05/2020 06:00	14.3	2.2	2.0	11.2	2.4
03/05/2020 07:00	13.8	1.9	2.0	10.9	2.4
03/05/2020 08:00	6.4	0.0	1.6	8.9	2.0
03/05/2020 09:00	8.4	0.0	1.7	9.3	2.0
03/05/2020 10:00	8.4	0.0	1.7	9.3	2.0
03/05/2020 11:00	6.7	0.0	1.7	9.2	2.0
03/05/2020 12:00	6.6	0.0	1.6	9.1	2.0
03/05/2020 13:00	8.4	0.0	1.7	9.3	2.0
03/05/2020 14:00	6.3	0.0	1.6	8.7	1.9
03/05/2020 15:00	6.0	0.0	1.5	8.3	1.8
03/05/2020 16:00	5.9	0.3	1.4	8.1	1.8
03/05/2020 17:00	11.9	2.4	2.0	10.9	2.4
03/05/2020 18:00	12.3	2.1	2.0	11.3	2.4
03/05/2020 19:00	14.3	2.1	2.0	11.3	2.4
03/05/2020 20:00	14.3	2.2	2.0	11.3	2.4
03/05/2020 21:00	14.5	2.2	2.0	11.3	2.4
03/05/2020 22:00	14.5	2.2	2.0	11.3	2.4
03/05/2020 23:00	13.9	2.2	2.0	10.9	2.4
Average/Sum#:	271.1 #	31.8 #	44.5 #	246.8 #	53.5 #
Minimum:	5.9	0.0	1.4	8.1	1.8
Maximum:	14.5	2.4	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/06/2020 00:00	14.3	2.5	2.0	11.3	2.4
03/06/2020 01:00	14.3	2.2	2.0	11.3	2.4
03/06/2020 02:00	13.9	2.2	2.0	10.9	2.4
03/06/2020 03:00	14.1	2.2	2.0	11.1	2.4
03/06/2020 04:00	14.2	2.5	2.0	11.1	2.4
03/06/2020 05:00	16.3	2.5	2.0	11.3	2.4
03/06/2020 06:00	14.3	2.5	2.0	11.2	2.4
03/06/2020 07:00	14.1	2.2	2.0	11.1	2.4
03/06/2020 08:00	11.7	2.2	1.9	10.7	2.4
03/06/2020 09:00	6.4	0.0	1.6	8.9	2.0
03/06/2020 10:00	6.6	0.0	1.7	9.1	2.0
03/06/2020 11:00	8.4	0.0	1.7	9.3	2.0
03/06/2020 12:00	6.6	1.5	1.6	9.1	2.0
03/06/2020 13:00	8.4	0.0	1.7	9.2	2.0
03/06/2020 14:00	6.6	0.0	1.6	9.0	2.0
03/06/2020 15:00	6.4	0.0	1.6	8.9	2.0
03/06/2020 16:00	6.0	0.0	1.5	8.3	1.8
03/06/2020 17:00	13.9	2.5	2.0	10.9	2.4
03/06/2020 18:00	14.3	2.1	2.0	11.1	2.4
03/06/2020 19:00	14.3	2.1	2.0	11.3	2.4
03/06/2020 20:00	14.6	2.1	2.1	11.5	2.5
03/06/2020 21:00	14.8	1.8	2.1	11.7	2.6
03/06/2020 22:00	14.5	1.8	2.0	11.5	2.5
03/06/2020 23:00	14.3	2.1	2.0	11.3	2.4
Average/Sum#:	283.3 #	37.0 #	45.1 #	251.1 #	54.6 #
Minimum:	6.0	0.0	1.5	8.3	1.8
Maximum:	16.3	2.5	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/07/2020 00:00	12.1	13.7	0.6	3.4	0.8
03/07/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/07/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	12.1 #	13.7 #	0.6 #	3.4 #	0.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	12.1	13.7	0.6	3.4	0.8
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/08/2020 20:00	60.4	75.7	0.1	1.0	0.2
03/08/2020 21:00	34.4	20.8	0.2	1.6	0.3
03/08/2020 22:00	25.5	25.8	0.3	3.5	0.7
03/08/2020 23:00	1.5	0.0	0.5	4.6	0.9
Average/Sum#:	121.8 #	122.3 #	1.1 #	10.7 #	2.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	60.4	75.7	0.5	4.6	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/09/2020 00:00	1.5	0.0	0.5	4.6	0.9
03/09/2020 01:00	10.6	47.4	0.5	5.1	1.0
03/09/2020 02:00	98.1	63.7	0.9	6.4	1.4
03/09/2020 03:00	14.7	1.1	1.5	8.2	1.8
03/09/2020 04:00	6.3	0.0	1.6	8.7	1.9
03/09/2020 05:00	12.1	1.6	2.0	11.1	2.4
03/09/2020 06:00	15.0	1.6	2.1	11.8	2.6
03/09/2020 07:00	14.9	1.3	2.1	11.7	2.6
03/09/2020 08:00	14.8	1.2	2.1	11.7	2.6
03/09/2020 09:00	8.3	0.0	1.7	9.2	2.0
03/09/2020 10:00	6.3	0.0	1.6	8.7	1.9
03/09/2020 11:00	6.2	0.0	1.6	8.6	1.8
03/09/2020 12:00	6.7	0.0	1.7	9.3	2.0
03/09/2020 13:00	8.4	0.0	1.7	9.3	2.0
03/09/2020 14:00	8.4	0.0	1.7	9.3	2.0
03/09/2020 15:00	8.2	0.0	1.6	9.1	2.0
03/09/2020 16:00	6.7	0.0	1.7	9.2	2.0
03/09/2020 17:00	12.1	2.2	2.0	11.1	2.4
03/09/2020 18:00	15.0	2.2	2.1	11.9	2.6
03/09/2020 19:00	15.1	2.2	2.1	11.9	2.6
03/09/2020 20:00	14.8	1.9	2.1	11.7	2.6
03/09/2020 21:00	14.8	1.8	2.1	11.7	2.6
03/09/2020 22:00	14.8	1.8	2.1	11.7	2.6
03/09/2020 23:00	14.8	1.8	2.1	11.7	2.6
Average/Sum#:	348.6 #	131.8 #	41.2 #	233.7 #	50.9 #
Minimum:	1.5	0.0	0.5	4.6	0.9
Maximum:	98.1	63.7	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/10/2020 00:00	14.8	1.8	2.1	11.7	2.6
03/10/2020 01:00	14.8	1.9	2.1	11.6	2.6
03/10/2020 02:00	14.7	1.8	2.1	11.5	2.6
03/10/2020 03:00	14.4	1.9	2.0	11.3	2.4
03/10/2020 04:00	14.5	1.9	2.0	11.3	2.4
03/10/2020 05:00	17.2	2.1	2.1	11.8	2.6
03/10/2020 06:00	15.4	1.8	2.3	12.1	2.6
03/10/2020 07:00	15.2	1.8	2.1	11.9	2.6
03/10/2020 08:00	8.6	0.0	2.1	11.9	2.6
03/10/2020 09:00	14.8	1.6	2.1	11.5	2.6
03/10/2020 10:00	14.6	1.3	2.0	11.5	2.5
03/10/2020 11:00	6.3	1.3	2.1	11.5	2.6
03/10/2020 12:00	14.8	1.3	2.1	11.7	2.6
03/10/2020 13:00	14.8	1.3	2.1	11.5	2.6
03/10/2020 14:00	14.8	0.9	2.1	11.7	2.6
03/10/2020 15:00	14.7	1.0	2.1	11.5	2.6
03/10/2020 16:00	14.7	0.9	2.1	11.5	2.6
03/10/2020 17:00	14.5	0.9	2.0	11.4	2.4
03/10/2020 18:00	15.1	0.9	2.1	11.9	2.6
03/10/2020 19:00	15.3	0.9	2.2	12.0	2.6
03/10/2020 20:00	15.3	0.9	2.2	12.0	2.6
03/10/2020 21:00	14.8	0.9	2.1	11.7	2.6
03/10/2020 22:00	14.8	1.0	2.1	11.6	2.6
03/10/2020 23:00	14.6	0.9	2.1	11.5	2.5
Average/Sum#:	328.6 #	29.7 #	50.4 #	279.6 #	61.6 #
Minimum:	14.4	0.9	2.0	11.3	2.4
Maximum:	17.2	2.1	2.3	12.1	2.6
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/11/2020 00:00	14.1	1.0	2.0	11.1	2.4
03/11/2020 01:00	14.1	1.3	2.0	11.1	2.4
03/11/2020 02:00	14.2	1.3	2.0	11.1	2.4
03/11/2020 03:00	14.3	1.6	2.0	11.1	2.4
03/11/2020 04:00	14.4	1.6	2.0	11.3	2.4
03/11/2020 05:00	16.9	1.6	2.1	11.7	2.6
03/11/2020 06:00	15.4	1.3	2.2	12.1	2.6
03/11/2020 07:00	14.8	1.3	2.1	11.7	2.6
03/11/2020 08:00	14.8	1.3	2.1	11.5	2.6
03/11/2020 09:00	10.3	0.0	1.7	9.4	2.0
03/11/2020 10:00	8.2	0.0	1.6	8.9	2.0
03/11/2020 11:00	7.7	0.0	1.6	8.5	1.8
03/11/2020 12:00	7.9	0.0	1.6	8.7	1.9
03/11/2020 13:00	8.4	0.0	1.7	9.2	2.0
03/11/2020 14:00	8.2	0.0	1.6	9.1	2.0
03/11/2020 15:00	7.7	0.0	1.6	8.5	1.8
03/11/2020 16:00	5.3	0.0	1.3	7.4	1.6
03/11/2020 17:00	8.1	0.0	1.6	8.9	2.0
03/11/2020 18:00	10.1	0.0	1.7	9.3	2.0
03/11/2020 19:00	14.1	1.9	2.0	11.1	2.4
03/11/2020 20:00	15.2	1.6	2.2	11.9	2.6
03/11/2020 21:00	14.8	1.6	2.1	11.7	2.6
03/11/2020 22:00	14.5	1.6	2.0	11.3	2.4
03/11/2020 23:00	14.8	1.6	2.1	11.5	2.6
Average/Sum#:	288.3 #	20.6 #	44.9 #	248.1 #	54.1 #
Minimum:	5.3	0.0	1.3	7.4	1.6
Maximum:	16.9	1.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/12/2020 00:00	14.5	1.3	2.0	11.3	2.4
03/12/2020 01:00	14.3	1.3	2.0	11.2	2.4
03/12/2020 02:00	13.9	1.3	2.0	10.9	2.4
03/12/2020 03:00	14.3	1.3	2.0	11.1	2.4
03/12/2020 04:00	14.5	1.3	2.0	11.3	2.4
03/12/2020 05:00	16.6	1.2	2.1	11.4	2.4
03/12/2020 06:00	15.3	1.2	2.2	12.0	2.6
03/12/2020 07:00	15.2	1.3	2.2	12.0	2.6
03/12/2020 08:00	14.5	0.9	2.0	11.3	2.4
03/12/2020 09:00	6.6	0.0	1.6	9.1	2.0
03/12/2020 10:00	6.7	0.0	1.7	9.1	2.0
03/12/2020 11:00	8.2	0.0	1.6	9.1	2.0
03/12/2020 12:00	10.1	0.0	1.7	9.3	2.0
03/12/2020 13:00	7.9	0.0	1.6	8.7	1.9
03/12/2020 14:00	6.7	0.0	1.7	9.1	2.0
03/12/2020 15:00	10.9	0.3	1.8	10.0	2.2
03/12/2020 16:00	14.6	1.2	2.1	11.5	2.5
03/12/2020 17:00	15.0	1.2	2.1	11.8	2.6
03/12/2020 18:00	15.3	0.9	2.2	12.0	2.6
03/12/2020 19:00	15.3	0.9	2.2	12.0	2.6
03/12/2020 20:00	14.6	0.9	2.1	11.5	2.5
03/12/2020 21:00	15.0	0.9	2.1	11.7	2.6
03/12/2020 22:00	15.1	0.9	2.1	11.9	2.6
03/12/2020 23:00	15.0	0.9	2.1	11.8	2.6
Average/Sum#:	310.1 #	19.2 #	47.2 #	261.1 #	56.7 #
Minimum:	6.6	0.0	1.6	8.7	1.9
Maximum:	16.6	1.3	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/13/2020 00:00	14.9	0.9	2.1	11.7	2.6
03/13/2020 01:00	14.9	1.3	2.1	11.7	2.6
03/13/2020 02:00	14.9	1.3	2.1	11.7	2.6
03/13/2020 03:00	14.9	1.3	2.1	11.7	2.6
03/13/2020 04:00	14.6	1.3	2.1	11.5	2.5
03/13/2020 05:00	17.3	1.2	2.1	11.9	2.6
03/13/2020 06:00	15.0	1.3	2.1	11.7	2.6
03/13/2020 07:00	14.9	1.3	2.1	11.8	2.6
03/13/2020 08:00	15.1	1.3	2.2	11.9	2.6
03/13/2020 09:00	10.3	0.0	1.7	9.4	2.0
03/13/2020 10:00	7.9	0.0	1.6	8.7	1.9
03/13/2020 11:00	8.1	0.0	1.6	8.9	2.0
03/13/2020 12:00	8.4	0.0	1.7	9.1	2.0
03/13/2020 13:00	8.1	0.0	1.6	8.9	2.0
03/13/2020 14:00	9.9	0.0	1.6	9.1	2.0
03/13/2020 15:00	9.9	0.0	1.7	9.1	2.0
03/13/2020 16:00	10.1	0.0	1.7	9.3	2.0
03/13/2020 17:00	10.8	0.6	1.8	9.9	2.2
03/13/2020 18:00	14.3	1.6	2.0	11.3	2.4
03/13/2020 19:00	15.2	1.2	2.2	11.9	2.6
03/13/2020 20:00	15.4	1.2	2.2	12.1	2.6
03/13/2020 21:00	14.9	1.3	2.1	11.7	2.6
03/13/2020 22:00	14.6	1.3	2.1	11.5	2.5
03/13/2020 23:00	14.3	1.3	2.0	11.3	2.4
Average/Sum#:	308.7 #	19.7 #	46.6 #	257.8 #	56.5 #
Minimum:	7.9	0.0	1.6	8.7	1.9
Maximum:	17.3	1.6	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/14/2020 00:00	14.8	1.3	2.1	11.6	2.6
03/14/2020 01:00	14.8	1.3	2.1	11.7	2.6
03/14/2020 02:00	14.8	1.3	2.1	11.6	2.6
03/14/2020 03:00	14.7	1.3	2.1	11.5	2.6
03/14/2020 04:00	14.3	1.3	2.0	11.2	2.4
03/14/2020 05:00	14.5	1.6	2.1	11.5	2.5
03/14/2020 06:00	14.8	1.6	2.1	11.7	2.6
03/14/2020 07:00	14.5	1.3	2.0	11.4	2.4
03/14/2020 08:00	8.7	0.0	1.7	9.6	2.1
03/14/2020 09:00	8.7	0.0	1.7	9.6	2.1
03/14/2020 10:00	8.6	0.0	1.7	9.5	2.0
03/14/2020 11:00	8.6	0.0	1.7	9.5	2.0
03/14/2020 12:00	8.6	0.0	1.7	9.5	2.0
03/14/2020 13:00	8.6	0.0	1.7	9.5	2.0
03/14/2020 14:00	8.6	0.0	1.7	9.5	2.0
03/14/2020 15:00	8.6	0.0	1.7	9.6	2.1
03/14/2020 16:00	8.7	0.0	1.7	9.6	2.1
03/14/2020 17:00	10.9	0.3	1.9	10.0	2.2
03/14/2020 18:00	14.8	1.6	2.1	11.5	2.6
03/14/2020 19:00	15.2	1.3	2.2	12.0	2.6
03/14/2020 20:00	15.0	1.3	2.1	11.9	2.6
03/14/2020 21:00	14.7	1.6	2.1	11.5	2.6
03/14/2020 22:00	14.3	1.3	2.0	11.2	2.4
03/14/2020 23:00	14.2	1.3	2.0	11.1	2.4
Average/Sum#:	294.0 #	19.7 #	46.3 #	257.3 #	56.1 #
Minimum:	8.6	0.0	1.7	9.5	2.0
Maximum:	15.2	1.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/15/2020 00:00	14.5	1.6	2.0	11.4	2.4
03/15/2020 01:00	14.3	1.3	2.0	11.2	2.4
03/15/2020 02:00	14.2	1.3	2.0	11.1	2.4
03/15/2020 03:00	14.1	1.3	2.0	11.1	2.4
03/15/2020 04:00	14.3	1.6	2.0	11.2	2.4
03/15/2020 05:00	14.3	1.6	2.0	11.2	2.4
03/15/2020 06:00	14.4	1.6	2.0	11.3	2.4
03/15/2020 07:00	14.3	1.3	2.0	11.3	2.4
03/15/2020 08:00	14.1	1.3	2.0	11.1	2.4
03/15/2020 09:00	6.9	0.0	1.7	9.6	2.1
03/15/2020 10:00	8.7	0.0	1.7	9.6	2.1
03/15/2020 11:00	8.6	0.0	1.7	9.5	2.0
03/15/2020 12:00	8.6	0.0	1.7	9.5	2.0
03/15/2020 13:00	8.7	0.0	1.7	9.6	2.1
03/15/2020 14:00	7.9	0.0	1.6	8.7	1.9
03/15/2020 15:00	7.5	0.0	1.5	8.3	1.8
03/15/2020 16:00	7.5	0.0	1.5	8.3	1.8
03/15/2020 17:00	10.9	0.3	1.8	10.0	2.2
03/15/2020 18:00	15.2	1.6	2.2	12.0	2.6
03/15/2020 19:00	15.6	1.3	2.3	12.2	2.6
03/15/2020 20:00	15.4	1.3	2.2	12.1	2.6
03/15/2020 21:00	15.4	1.3	2.2	12.1	2.6
03/15/2020 22:00	14.6	1.3	2.1	11.5	2.5
03/15/2020 23:00	14.7	1.3	2.1	11.5	2.6
Average/Sum#:	294.7 #	21.3 #	46.0 #	255.4 #	55.1 #
Minimum:	6.9	0.0	1.5	8.3	1.8
Maximum:	15.6	1.6	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/16/2020 00:00	14.8	1.6	2.1	11.6	2.6
03/16/2020 01:00	14.7	1.6	2.1	11.5	2.6
03/16/2020 02:00	14.8	1.6	2.1	11.6	2.6
03/16/2020 03:00	14.7	1.6	2.1	11.5	2.6
03/16/2020 04:00	15.2	1.6	2.1	11.9	2.6
03/16/2020 05:00	17.4	1.6	2.2	12.0	2.6
03/16/2020 06:00	15.6	1.3	2.3	12.3	2.6
03/16/2020 07:00	14.9	1.3	2.1	11.7	2.6
03/16/2020 08:00	14.8	1.3	2.1	11.7	2.6
03/16/2020 09:00	14.7	1.3	2.1	11.5	2.6
03/16/2020 10:00	14.7	1.3	2.1	11.5	2.6
03/16/2020 11:00	14.8	1.3	2.1	11.7	2.6
03/16/2020 12:00	14.7	1.3	2.1	11.5	2.6
03/16/2020 13:00	14.5	1.3	2.0	11.4	2.4
03/16/2020 14:00	14.4	1.3	2.0	11.3	2.4
03/16/2020 15:00	14.2	1.3	2.0	11.1	2.4
03/16/2020 16:00	14.2	1.3	2.0	11.1	2.4
03/16/2020 17:00	14.3	1.3	2.0	11.2	2.4
03/16/2020 18:00	15.4	1.3	2.2	12.1	2.6
03/16/2020 19:00	15.4	1.3	2.2	12.1	2.6
03/16/2020 20:00	15.0	1.3	2.1	11.9	2.6
03/16/2020 21:00	15.2	1.6	2.2	11.9	2.6
03/16/2020 22:00	14.8	1.6	2.1	11.6	2.6
03/16/2020 23:00	14.8	1.6	2.1	11.5	2.6
Average/Sum#:	358.0 #	33.9 #	50.5 #	279.2 #	61.4 #
Minimum:	14.2	1.3	2.0	11.1	2.4
Maximum:	17.4	1.6	2.3	12.3	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/17/2020 00:00	14.6	1.6	2.1	11.5	2.5
03/17/2020 01:00	14.6	1.6	2.1	11.5	2.5
03/17/2020 02:00	14.1	1.3	2.0	11.1	2.4
03/17/2020 03:00	14.3	1.3	2.0	11.3	2.4
03/17/2020 04:00	14.1	1.3	2.0	11.1	2.4
03/17/2020 05:00	16.9	1.9	2.1	11.5	2.6
03/17/2020 06:00	15.0	1.6	2.1	11.9	2.6
03/17/2020 07:00	14.2	1.3	2.0	11.1	2.4
03/17/2020 08:00	13.3	1.3	1.9	10.5	2.3
03/17/2020 09:00	10.4	0.0	1.7	9.6	2.1
03/17/2020 10:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 11:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 12:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 13:00	8.7	0.3	1.7	9.6	2.1
03/17/2020 14:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 15:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 16:00	8.7	0.0	1.7	9.6	2.1
03/17/2020 17:00	14.0	1.6	2.0	11.0	2.4
03/17/2020 18:00	14.7	1.6	2.1	11.5	2.5
03/17/2020 19:00	14.8	1.6	2.1	11.6	2.6
03/17/2020 20:00	14.4	1.3	2.0	11.3	2.4
03/17/2020 21:00	14.4	1.6	2.0	11.3	2.4
03/17/2020 22:00	14.4	1.6	2.0	11.3	2.4
03/17/2020 23:00	14.2	1.3	2.0	11.1	2.4
Average/Sum#:	303.3 #	24.1 #	46.1 #	257.4 #	56.0 #
Minimum:	8.7	0.0	1.7	9.6	2.1
Maximum:	16.9	1.9	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/18/2020 00:00	14.1	1.3	2.0	11.1	2.4
03/18/2020 01:00	14.1	1.3	2.0	11.1	2.4
03/18/2020 02:00	14.1	1.3	2.0	11.1	2.4
03/18/2020 03:00	14.2	1.3	2.0	11.1	2.4
03/18/2020 04:00	14.1	1.3	2.0	11.1	2.4
03/18/2020 05:00	16.0	1.6	2.0	11.0	2.4
03/18/2020 06:00	14.7	1.6	2.1	11.5	2.6
03/18/2020 07:00	14.5	1.6	2.0	11.4	2.4
03/18/2020 08:00	14.0	1.3	2.0	11.0	2.4
03/18/2020 09:00	6.5	0.0	1.6	9.1	2.0
03/18/2020 10:00	8.1	0.0	1.6	8.9	2.0
03/18/2020 11:00	8.0	0.0	1.6	8.8	2.0
03/18/2020 12:00	8.1	0.0	1.6	8.9	2.0
03/18/2020 13:00	8.0	0.0	1.6	8.8	2.0
03/18/2020 14:00	8.2	0.0	1.6	9.1	2.0
03/18/2020 15:00	8.1	0.0	1.6	8.9	2.0
03/18/2020 16:00	8.4	0.0	1.7	9.1	2.0
03/18/2020 17:00	6.2	0.0	1.6	8.5	1.8
03/18/2020 18:00	13.9	1.3	2.0	10.9	2.4
03/18/2020 19:00	14.1	1.3	2.0	11.1	2.4
03/18/2020 20:00	14.4	1.6	2.0	11.3	2.4
03/18/2020 21:00	16.4	1.6	2.0	11.2	2.4
03/18/2020 22:00	16.4	1.6	2.0	11.3	2.4
03/18/2020 23:00	14.0	1.3	2.0	10.9	2.4
Average/Sum#:	288.6 #	21.3 #	44.6 #	247.2 #	54.0 #
Minimum:	6.2	0.0	1.6	8.5	1.8
Maximum:	16.4	1.6	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/19/2020 00:00	15.4	1.3	1.9	10.5	2.3
03/19/2020 01:00	11.5	1.3	1.9	10.5	2.3
03/19/2020 02:00	11.5	1.7	1.9	10.5	2.3
03/19/2020 03:00	11.6	1.6	2.0	10.7	2.4
03/19/2020 04:00	14.2	1.9	2.1	11.1	2.5
03/19/2020 05:00	13.9	1.6	2.0	10.9	2.4
03/19/2020 06:00	14.6	2.0	2.1	11.5	2.5
03/19/2020 07:00	14.6	1.6	2.1	11.5	2.5
03/19/2020 08:00	13.9	1.3	2.0	10.9	2.4
03/19/2020 09:00	6.1	0.0	1.6	8.5	1.8
03/19/2020 10:00	7.9	0.0	1.6	8.7	1.9
03/19/2020 11:00	7.2	0.0	1.4	8.0	1.8
03/19/2020 12:00	7.6	0.0	1.6	8.4	1.8
03/19/2020 13:00	5.4	0.0	1.3	7.5	1.6
03/19/2020 14:00	5.2	0.0	1.3	7.1	1.6
03/19/2020 15:00	7.7	0.0	1.6	8.5	1.8
03/19/2020 16:00	7.6	0.0	1.6	8.4	1.8
03/19/2020 17:00	14.1	1.6	2.0	11.1	2.4
03/19/2020 18:00	14.4	1.6	2.0	11.3	2.4
03/19/2020 19:00	14.7	1.6	2.1	11.5	2.6
03/19/2020 20:00	14.8	1.6	2.1	11.5	2.6
03/19/2020 21:00	14.6	1.6	2.0	11.5	2.5
03/19/2020 22:00	14.5	1.6	2.0	11.3	2.4
03/19/2020 23:00	14.1	1.3	2.0	11.1	2.4
Average/Sum#:	277.1 #	25.2 #	44.2 #	242.5 #	53.0 #
Minimum:	5.2	0.0	1.3	7.1	1.6
Maximum:	15.4	2.0	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/20/2020 00:00	14.1	1.3	2.0	11.1	2.4
03/20/2020 01:00	14.1	1.3	2.0	11.1	2.4
03/20/2020 02:00	14.1	1.3	2.0	11.1	2.4
03/20/2020 03:00	14.1	1.3	2.0	11.1	2.4
03/20/2020 04:00	14.1	1.3	2.0	11.1	2.4
03/20/2020 05:00	13.7	1.3	2.0	10.8	2.4
03/20/2020 06:00	14.3	1.7	2.0	11.2	2.4
03/20/2020 07:00	13.3	1.3	1.9	10.5	2.3
03/20/2020 08:00	8.0	0.0	1.6	8.9	2.0
03/20/2020 09:00	5.5	0.0	1.3	7.5	1.6
03/20/2020 10:00	8.2	0.0	1.6	9.1	2.0
03/20/2020 11:00	7.7	0.0	1.6	8.5	1.8
03/20/2020 12:00	7.6	0.0	1.5	8.3	1.8
03/20/2020 13:00	8.1	0.0	1.6	8.9	2.0
03/20/2020 14:00	7.6	0.0	1.6	8.4	1.8
03/20/2020 15:00	7.9	0.0	1.6	8.6	1.8
03/20/2020 16:00	19.9	1.6	2.0	11.0	2.4
03/20/2020 17:00	20.3	1.6	2.0	11.1	2.4
03/20/2020 18:00	16.3	1.6	2.0	11.2	2.4
03/20/2020 19:00	14.3	1.6	2.0	11.3	2.4
03/20/2020 20:00	14.5	1.6	2.0	11.3	2.4
03/20/2020 21:00	14.6	1.6	2.0	11.5	2.5
03/20/2020 22:00	14.5	1.3	2.0	11.3	2.4
03/20/2020 23:00	14.1	1.3	2.0	11.1	2.4
Average/Sum#:	300.9 #	23.0 #	44.3 #	246.0 #	53.2 #
Minimum:	5.5	0.0	1.3	7.5	1.6
Maximum:	20.3	1.7	2.0	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/21/2020 00:00	14.5	1.6	2.0	11.3	2.4
03/21/2020 01:00	14.6	1.6	2.1	11.5	2.5
03/21/2020 02:00	14.5	1.6	2.0	11.5	2.5
03/21/2020 03:00	14.6	1.6	2.1	11.5	2.5
03/21/2020 04:00	14.4	1.3	2.0	11.3	2.4
03/21/2020 05:00	14.3	1.6	2.0	11.3	2.4
03/21/2020 06:00	11.9	1.3	2.0	10.9	2.4
03/21/2020 07:00	12.8	12.6	0.6	3.1	0.6
03/21/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/21/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	111.6 #	23.2 #	14.8 #	82.4 #	17.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	14.6	12.6	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/22/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/22/2020 17:00	74.7	61.9	0.1	1.0	0.2
03/22/2020 18:00	36.0	16.9	0.2	1.6	0.3
03/22/2020 19:00	39.6	30.2	0.3	2.8	0.6
03/22/2020 20:00	3.0	0.0	0.4	4.4	0.9
03/22/2020 21:00	2.8	0.0	0.4	4.2	0.8
03/22/2020 22:00	2.9	0.0	0.4	4.3	0.9
03/22/2020 23:00	3.0	0.0	0.4	4.4	0.9
Average/Sum#:	162.0 #	109.0 #	2.2 #	22.7 #	4.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	74.7	61.9	0.4	4.4	0.9
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/23/2020 00:00	2.7	0.0	0.4	4.1	0.8
03/23/2020 01:00	2.7	0.0	0.4	4.1	0.8
03/23/2020 02:00	1.8	2.4	0.0	0.2	0.0
03/23/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/23/2020 17:00	68.9	37.8	0.1	1.0	0.2
03/23/2020 18:00	33.9	19.4	0.2	1.6	0.3
03/23/2020 19:00	45.8	37.5	0.3	2.6	0.5
03/23/2020 20:00	3.1	0.0	0.5	4.7	0.9
03/23/2020 21:00	3.1	0.0	0.5	4.6	0.9
03/23/2020 22:00	3.1	0.0	0.5	4.6	0.9
03/23/2020 23:00	3.3	0.0	0.5	4.9	1.0
Average/Sum#:	168.4 #	97.1 #	3.4 #	32.4 #	6.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	68.9	37.8	0.5	4.9	1.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/24/2020 00:00	2.9	0.0	0.4	4.3	0.9
03/24/2020 01:00	2.8	0.0	0.4	4.1	0.8
03/24/2020 02:00	75.7	86.7	0.7	5.5	1.1
03/24/2020 03:00	73.7	42.9	1.1	6.7	1.4
03/24/2020 04:00	6.9	0.0	1.7	9.4	2.0
03/24/2020 05:00	6.5	0.0	1.6	9.0	1.9
03/24/2020 06:00	6.7	0.0	1.7	9.2	2.0
03/24/2020 07:00	6.7	0.0	1.7	9.3	2.0
03/24/2020 08:00	6.3	0.0	1.6	8.6	1.8
03/24/2020 09:00	8.4	0.0	1.7	9.1	2.0
03/24/2020 10:00	6.7	0.0	1.7	9.3	2.0
03/24/2020 11:00	6.4	0.0	1.6	8.8	2.0
03/24/2020 12:00	6.5	0.0	1.6	8.9	2.0
03/24/2020 13:00	6.1	0.0	1.6	8.4	1.8
03/24/2020 14:00	6.2	0.0	1.6	8.5	1.8
03/24/2020 15:00	7.9	0.0	1.6	8.7	1.9
03/24/2020 16:00	7.9	0.0	1.6	8.7	1.9
03/24/2020 17:00	14.1	1.6	2.0	11.1	2.4
03/24/2020 18:00	13.9	1.3	2.0	10.9	2.4
03/24/2020 19:00	14.0	1.3	2.0	11.1	2.4
03/24/2020 20:00	14.7	1.6	2.1	11.5	2.6
03/24/2020 21:00	14.3	1.3	2.0	11.1	2.4
03/24/2020 22:00	14.3	1.6	2.0	11.2	2.4
03/24/2020 23:00	13.0	12.2	0.6	3.2	0.7
Average/Sum#:	342.6 #	150.5 #	36.6 #	206.6 #	44.6 #
Minimum:	2.8	0.0	0.4	3.2	0.7
Maximum:	75.7	86.7	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/25/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/25/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
03/26/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/27/2020 00:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 01:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 02:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 03:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 04:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 05:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 06:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 07:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/27/2020 17:00	93.0	80.0	0.1	1.3	0.3
03/27/2020 18:00	31.4	17.0	0.2	1.6	0.3
03/27/2020 19:00	55.6	39.2	0.3	2.6	0.5
03/27/2020 20:00	3.2	0.0	0.5	4.8	1.0
03/27/2020 21:00	2.9	0.0	0.4	4.3	0.9
03/27/2020 22:00	2.9	0.0	0.4	4.3	0.9
03/27/2020 23:00	90.7	88.3	0.8	6.2	1.3
Average/Sum#:	279.7 #	224.5 #	2.7 #	25.1 #	5.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	93.0	88.3	0.8	6.2	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/28/2020 00:00	48.2	40.3	1.2	7.0	1.5
03/28/2020 01:00	8.4	0.0	1.7	9.2	2.0
03/28/2020 02:00	8.4	0.0	1.7	9.3	2.0
03/28/2020 03:00	8.4	0.0	1.7	9.3	2.0
03/28/2020 04:00	8.3	0.0	1.7	9.1	2.0
03/28/2020 05:00	8.3	0.0	1.7	9.1	2.0
03/28/2020 06:00	6.2	0.0	1.6	8.5	1.8
03/28/2020 07:00	7.6	0.0	1.5	8.3	1.8
03/28/2020 08:00	8.1	0.0	1.6	8.9	2.0
03/28/2020 09:00	8.2	0.0	1.6	9.1	2.0
03/28/2020 10:00	8.4	0.0	1.7	9.2	2.0
03/28/2020 11:00	8.4	0.0	1.7	9.3	2.0
03/28/2020 12:00	8.4	0.0	1.7	9.2	2.0
03/28/2020 13:00	8.4	0.0	1.7	9.2	2.0
03/28/2020 14:00	8.2	0.0	1.6	9.1	2.0
03/28/2020 15:00	8.2	0.0	1.6	9.1	2.0
03/28/2020 16:00	8.4	0.0	1.7	9.3	2.0
03/28/2020 17:00	10.9	0.3	1.9	10.0	2.2
03/28/2020 18:00	14.7	0.9	2.1	11.5	2.5
03/28/2020 19:00	14.4	1.0	2.0	11.3	2.4
03/28/2020 20:00	14.8	0.6	2.1	11.6	2.6
03/28/2020 21:00	14.4	1.0	2.0	11.3	2.4
03/28/2020 22:00	14.3	1.0	2.0	11.3	2.4
03/28/2020 23:00	13.7	0.6	2.0	10.7	2.4
Average/Sum#:	275.7 #	45.7 #	41.8 #	229.9 #	50.0 #
Minimum:	6.2	0.0	1.2	7.0	1.5
Maximum:	48.2	40.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/29/2020 00:00	6.5	0.0	1.6	8.9	2.0
03/29/2020 01:00	7.9	0.0	1.6	8.7	1.9
03/29/2020 02:00	7.9	0.0	1.6	8.8	1.9
03/29/2020 03:00	7.7	0.0	1.6	8.5	1.8
03/29/2020 04:00	8.4	0.0	1.7	9.2	2.0
03/29/2020 05:00	6.4	0.0	1.6	8.8	1.9
03/29/2020 06:00	6.3	0.0	1.6	8.7	1.9
03/29/2020 07:00	8.0	0.0	1.6	8.9	2.0
03/29/2020 08:00	7.9	0.0	1.6	8.7	1.9
03/29/2020 09:00	8.3	0.0	1.6	9.1	2.0
03/29/2020 10:00	8.4	0.0	1.7	9.3	2.0
03/29/2020 11:00	8.3	0.0	1.7	9.1	2.0
03/29/2020 12:00	6.2	0.0	1.6	8.5	1.8
03/29/2020 13:00	7.9	0.0	1.6	8.7	1.9
03/29/2020 14:00	7.9	0.0	1.6	8.7	1.9
03/29/2020 15:00	7.9	0.0	1.6	8.7	1.9
03/29/2020 16:00	8.2	0.0	1.6	9.0	2.0
03/29/2020 17:00	6.2	0.0	1.6	8.5	1.8
03/29/2020 18:00	14.1	1.3	2.0	11.1	2.4
03/29/2020 19:00	14.7	0.6	2.1	11.5	2.6
03/29/2020 20:00	14.5	0.6	2.0	11.4	2.4
03/29/2020 21:00	14.5	0.6	2.0	11.4	2.4
03/29/2020 22:00	13.5	0.6	1.9	10.7	2.3
03/29/2020 23:00	13.6	0.6	1.9	10.7	2.4
Average/Sum#:	221.2 #	4.3 #	41.0 #	225.6 #	49.1 #
Minimum:	6.2	0.0	1.6	8.5	1.8
Maximum:	14.7	1.3	2.1	11.5	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/30/2020 00:00	8.4	0.0	1.7	9.2	2.0
03/30/2020 01:00	8.4	0.0	1.7	9.2	2.0
03/30/2020 02:00	8.3	0.0	1.7	9.1	2.0
03/30/2020 03:00	8.1	0.0	1.6	8.9	2.0
03/30/2020 04:00	8.1	0.0	1.6	8.9	2.0
03/30/2020 05:00	8.3	0.0	1.6	9.1	2.0
03/30/2020 06:00	8.4	0.0	1.7	9.2	2.0
03/30/2020 07:00	8.2	0.0	1.6	9.1	2.0
03/30/2020 08:00	8.1	0.0	1.6	8.9	2.0
03/30/2020 09:00	8.2	0.0	1.6	9.1	2.0
03/30/2020 10:00	8.2	0.0	1.6	9.1	2.0
03/30/2020 11:00	8.1	0.0	1.6	8.9	2.0
03/30/2020 12:00	7.9	0.0	1.6	8.7	1.9
03/30/2020 13:00	7.9	0.0	1.6	8.7	1.9
03/30/2020 14:00	8.2	0.0	1.6	9.0	2.0
03/30/2020 15:00	6.4	0.0	1.6	8.8	1.9
03/30/2020 16:00	8.2	0.0	1.6	9.1	2.0
03/30/2020 17:00	8.2	0.0	1.6	9.1	2.0
03/30/2020 18:00	13.9	1.6	2.0	11.0	2.4
03/30/2020 19:00	14.3	1.6	2.0	11.2	2.4
03/30/2020 20:00	14.7	1.6	2.1	11.6	2.6
03/30/2020 21:00	14.7	1.3	2.1	11.6	2.6
03/30/2020 22:00	14.7	1.3	2.1	11.5	2.6
03/30/2020 23:00	14.1	1.3	2.0	11.1	2.4
Average/Sum#:	232.0 #	8.7 #	41.5 #	230.1 #	50.7 #
Minimum:	6.4	0.0	1.6	8.7	1.9
Maximum:	14.7	1.6	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 09:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
03/31/2020 00:00	14.1	1.3	2.0	11.1	2.4
03/31/2020 01:00	14.2	1.3	2.0	11.1	2.4
03/31/2020 02:00	14.1	1.3	2.0	11.1	2.4
03/31/2020 03:00	14.1	1.3	2.0	11.1	2.4
03/31/2020 04:00	14.1	1.3	2.0	11.1	2.4
03/31/2020 05:00	13.5	1.3	1.9	10.6	2.3
03/31/2020 06:00	14.1	1.6	2.0	11.1	2.4
03/31/2020 07:00	12.6	13.3	0.6	3.4	0.8
03/31/2020 08:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 09:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 10:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 11:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 12:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 13:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 14:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 15:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 16:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 17:00	0.0	0.0	0.0	0.0	0.0
03/31/2020 18:00	61.3	18.9	0.1	1.2	0.2
03/31/2020 19:00	56.1	43.7	0.3	2.8	0.6
03/31/2020 20:00	1.4	0.0	0.4	4.3	0.9
03/31/2020 21:00	2.7	0.0	0.4	4.0	0.8
03/31/2020 22:00	2.7	0.0	0.4	4.1	0.8
03/31/2020 23:00	3.0	0.0	0.5	4.5	0.9
Average/Sum#:	238.0 #	85.3 #	16.6 #	101.5 #	21.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	61.3	43.7	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:21 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:21 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:22 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:22 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:23 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:26 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:25 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:24 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:28 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 77.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 14.00 Day(s) Report Time: 91.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**77.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 09:28 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,481.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 703.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,481.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
CGA/Linearity

FCD: AQ-19
Title V: #13

Airgas
an Air Liquide company

IN SERVICE 5/ DEC 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT 2
CV 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401536233-1
Cylinder Number:	CC233495	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jul 08, 2019

Expiration Date: Jul 08, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	182.9 PPM	G1	+/- 0.6% NIST Traceable	07/01/2019, 07/08/2019
NITRIC OXIDE	180.0 PPM	182.9 PPM	G1	+/- 0.6% NIST Traceable	07/01/2019, 07/08/2019
CARBON MONOXIDE	1150 PPM	1146 PPM	G1	+/- 0.8% NIST Traceable	07/01/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060132	KAL004328	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	14060151	CC436896	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 18, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO HCO	FTIR	Jun 20, 2019
Nicolet 6700 AMP0900119 NO MNO	FTIR	Jun 12, 2019
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jun 12, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 09 JAN 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-2
CV-2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401557322-1
Cylinder Number:	ALM063960	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
		Certification Date:	Jul 29, 2019

Expiration Date: Jul 29, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.02 %	G1	+/- 0.2% NIST Traceable	07/29/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	0.050%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jul 10, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.00PPM, CO: 0.00PPM, CO2: 0.00PPM

MLH

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 22 Nov 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 3

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401380069-1
Cylinder Number:	EB0066209	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Dec 26, 2018

Expiration Date: Dec 26, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	8.953 PPM	G1	+/- 1.0% NIST Traceable	12/18/2018, 12/26/2018
NITRIC OXIDE	9.000 PPM	8.895 PPM	G1	+/- 1.0% NIST Traceable	12/18/2018, 12/26/2018
CARBON MONOXIDE	11.00 PPM	10.95 PPM	G1	+/- 0.6% NIST Traceable	12/18/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060702	CC344925	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	16060702	CC344925-NOX	10.08 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Nov 26, 2018
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Nov 28, 2018
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Nov 28, 2018

Triad Data Available Upon Request

Approved for Release

unit #7 I/S 8-30-17 AM

CV4

Airgas CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Specialty Gases
11711 South Alameda Street
Los Angles, CA 90059-2130
(323) 357-6891
Fax: (323) 567-3686
www.airgas.com

Part Number:	E02NI99E15A0093	Reference Number:	48-124342764-1
Cylinder Number:	SG9163254	Cylinder Volume:	144 Cu.Ft.
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32012	Valve Outlet:	660
Gas Code:	NO	Analysis Date:	Nov 06, 2012

Expiration Date: Nov 06, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
NITRIC OXIDE	110.0 PPM	109.9 PPM	G1	+/- 1% NIST Traceable
NITROGEN	Balance			
Total oxides of nitrogen		110.5 PPM		For Reference Only

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	110605	CC331860	101.2PPM NITRIC OXIDE/NITROGEN	Feb 16, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	Oct 25, 2012

Triad Data Available Upon Request

Notes:

Approved for Release

IN SERVICE 01 OCT 16-5

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2

CV5

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	153-400996727-1
Cylinder Number:	CC254020	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.16 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	50.00 PPM	51.12 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060632	CC442611	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	May 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 9 Apr 19

Airgas
an Air Liquide company

CT 2
CVL

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-401198488-1
Cylinder Number:	CC437300	Cylinder Volume:	128.9 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	1800 PSIG
PGVP Number:	B32018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	May 18, 2018

Expiration Date: May 18, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.207 PPM	G1	+/- 1.4% NIST Traceable	05/18/2018
NITRIC OXIDE	5.500 PPM	4.934 PPM	G1	+/- 1.2% NIST Traceable	05/18/2018
CARBON MONOXIDE	500.0 PPM	500.5 PPM	G1	+/- 0.7% NIST Traceable	05/10/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Apr 23, 2018
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Apr 24, 2018
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Apr 24, 2018

Triad Data Available Upon Request

Approved for Release

In Service 9 Oct 19

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT-2
CV-7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-124604622-1
Cylinder Number:	CC177447	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 28, 2017

Expiration Date: Feb 28, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.586 PPM	G1	+/- 1.4% NIST Traceable	02/21/2017, 02/28/2017
NITRIC OXIDE	2.500 PPM	2.499 PPM	G1	+/- 1.4% NIST Traceable	02/21/2017, 02/28/2017
CARBON MONOXIDE	4.750 PPM	4.712 PPM	G1	+/- 1% NIST Traceable	02/23/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0	Jun 02, 2018
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0	Jun 02, 2018
NTRM	12062834	CC401506	9.766 PPM CARBON MONOXIDE/NITROGEN	0.3%	Sep 07, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO LCO	FTIR	Feb 22, 2017
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 10, 2017
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 10, 2017

Triad Data Available Upon Request

Approved for Release

In Service: 9 April 19

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124618307-1
Cylinder Number:	CC420243	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2017

Expiration Date: May 09, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.04 %	G1	+/- 0.7% NIST Traceable	05/09/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Apr 12, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 13 JAN 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401555373-1
Cylinder Number:	EB0090548	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jul 26, 2019

Expiration Date: Jul 26, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.514 %	G1	+/- 0.4% NIST Traceable	07/26/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jul 10, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Facility Name: COLUSA GENERATION
Component ID: A22
Component Type: O2D
ReasonForTest: QA
Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument
Performance Spec: 5 %
Test End Date/Time: 01/14/2020
Test No.: 93
Status (Pass/Fail): **Passed**
Scale: High
Highest Error: 1.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/14/2020	1226	L	25.0	5.5	5.4		22.0 %
01/14/2020	1232	M	25.0	13.0	12.8		52.0 %
01/14/2020	1238	H	25.0	21.0	20.7		84.0 %
01/14/2020	1247	L	25.0	5.5	5.4		22.0 %
01/14/2020	1253	M	25.0	13.0	12.8		52.0 %
01/14/2020	1259	H	25.0	21.0	20.7		84.0 %
01/14/2020	1307	L	25.0	5.5	5.4		22.0 %
01/14/2020	1313	M	25.0	13.0	12.8		52.0 %
01/14/2020	1319	H	25.0	21.0	20.7		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	**1.8**
M	13.000	12.800	No	**1.5**
H	21.000	20.700	No	**1.4**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Instrument Name: CT2_NOXDualRg_P_Instrume
Performance Spec: 5 %

Facility Name: COLUSA GENERATION
Component ID: A21
Component Type: NOXA
Test End Date/Time: 01/14/2020
Test No.: 92
Status (Pass/Fail): **Passed**

ReasonForTest: QA
Grace Period: 0
Scale: High
Highest Error: 3.3

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/14/2020	1025	L	200.0	51.2	49.2		25.6 %
01/14/2020	1031	M	200.0	109.9	106.7		55.0 %
01/14/2020	1037	H	200.0	182.9	178.1		91.5 %
01/14/2020	1046	L	200.0	51.2	49.7		25.6 %
01/14/2020	1052	M	200.0	109.9	106.8		55.0 %
01/14/2020	1058	H	200.0	182.9	178.1		91.5 %
01/14/2020	1106	L	200.0	51.2	49.7		25.6 %
01/14/2020	1112	M	200.0	109.9	106.8		55.0 %
01/14/2020	1118	H	200.0	182.9	178.2		91.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.200	49.533	No	**3.3**
M	109.900	106.767	No	**2.9**
H	182.900	178.133	No	**2.6**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 01/14/2020
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	15:42	L	2000	500.500	489.400	25.0 %
01/14/2020	15:48	M	2000	1146.000	1144.700	57.3 %
01/14/2020	15:57	L	2000	500.500	489.400	25.0 %
01/14/2020	16:03	M	2000	1146.000	1145.000	57.3 %
01/14/2020	16:11	L	2000	500.500	489.700	25.0 %
01/14/2020	16:17	M	2000	1146.000	1144.700	57.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	500.500	489.500	Std	**2.2**
M	1146.000	1144.800	Std	**0.1**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / Low
Test Date: 01/14/2020
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	13:39	L	20	4.700	4.100	23.5 %
01/14/2020	13:45	M	20	11.000	10.800	55.0 %
01/14/2020	13:54	L	20	4.700	4.100	23.5 %
01/14/2020	14:00	M	20	11.000	10.700	55.0 %
01/14/2020	14:08	L	20	4.700	4.100	23.5 %
01/14/2020	14:14	M	20	11.000	10.800	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.100	Std	**12.8**
M	11.000	10.767	Std	**2.1**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / Low

Test Date: 01/14/2020
Test Result: **Pass**

Instrument Name: CT2_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	14:40	L	10	2.600	1.900	26.0 %
01/14/2020	14:46	M	10	5.200	4.700	52.0 %
01/14/2020	14:55	L	10	2.600	1.900	26.0 %
01/14/2020	15:01	M	10	5.200	4.700	52.0 %
01/14/2020	15:09	L	10	2.600	1.900	26.0 %
01/14/2020	15:15	M	10	5.200	4.600	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	1.900	Alt	**0.7**
M	5.200	4.667	Std	**10.3**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High
Test Date: 01/15/2020
Test Result: **Pass**
Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/15/2020	09:25	L	25	5.500	5.500	22.0 %
01/15/2020	09:31	M	25	13.000	13.000	52.0 %
01/15/2020	09:40	L	25	5.500	5.500	22.0 %
01/15/2020	09:46	M	25	13.000	13.000	52.0 %
01/15/2020	09:54	L	25	5.500	5.500	22.0 %
01/15/2020	10:00	M	25	13.000	13.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.000	13.000	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High
Test Date: 01/15/2020
Test Result: **Pass**
Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/15/2020	10:27	L	200	51.200	50.000	25.6 %
01/15/2020	10:33	M	200	109.900	108.000	55.0 %
01/15/2020	10:41	L	200	51.200	50.100	25.6 %
01/15/2020	10:47	M	200	109.900	108.100	55.0 %
01/15/2020	10:55	L	200	51.200	50.100	25.6 %
01/15/2020	11:01	M	200	109.900	108.000	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	51.200	50.067	Std	**2.2**
M	109.900	108.033	Std	**1.7**

Airgas
an Air Liquide company

IN SERVICE: 07 JAN 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CW 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401557387-1
Cylinder Number:	EB0040440	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Aug 05, 2019

Expiration Date: Aug 05, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	184.8 PPM	G1	+/- 0.7% NIST Traceable	07/29/2019, 08/05/2019
NITRIC OXIDE	180.0 PPM	184.6 PPM	G1	+/- 0.7% NIST Traceable	07/29/2019, 08/05/2019
CARBON MONOXIDE	1150 PPM	1151 PPM	G1	+/- 0.8% NIST Traceable	07/29/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060132	KAL004328	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	14060151	CC436896	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 18, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO HCO	FTIR	Jul 17, 2019
Nicolet 6700 AMP0900119 NO MNO	FTIR	Jul 10, 2019
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jul 11, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE SUBCLIP 8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT 1
CV 2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401535904-1
Cylinder Number:	CC504080	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
		Certification Date:	Jul 02, 2019

Expiration Date: Jul 02, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.02 %	G1	+/- 0.2% NIST Traceable	07/02/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062019	CC367606	22.883 % OXYGEN/NITROGEN	0.050%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jun 13, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 03 JAN 20

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

OT-1
CV3

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401438611-1
Cylinder Number:	EB0097370	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 12, 2019

Expiration Date: Mar 12, 2022

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.117 PPM	G1	+/- 1.1% NIST Traceable	03/05/2019, 03/12/2019
NITRIC OXIDE	9.000 PPM	9.088 PPM	G1	+/- 1.1% NIST Traceable	03/05/2019, 03/12/2019
CARBON MONOXIDE	11.00 PPM	11.08 PPM	G1	+/- 0.6% NIST Traceable	03/05/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060733	CC465060	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO LCO	FTIR	Feb 28, 2019
Nicolet 6700 AHR0801550 NO LNO	FTIR	Feb 20, 2019
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 06, 2019

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 15 JAN 2026

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC268605	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.9 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	110.7 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

Airgas

Airgas Specialty Gases
11711 South Alameda Street
Los Angeles, CA 90059
(323) 568-2203 Fax: (323) 567-3686
www.airgas.com

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	48-124363135-1
Cylinder Number:	CC276685	Cylinder Volume:	144.3 CF
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32013	Valve Outlet:	660
Gas Code:	NO	Certification Date:	Mar 12, 2013

Expiration Date: Mar 12, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.71 PPM	G1	+/- 1.2% NIST Traceable	03/05/2013, 03/12/2013
NITRIC OXIDE	50.00 PPM	50.55 PPM	G1	+/- 1.0% NIST Traceable	03/05/2013, 03/12/2013
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060833	CC283887	49.95 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 16, 2017
PRM	12312	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Feb 14, 2012
GMIS	124208889129	CC323206	4.835 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.0%	Oct 11, 2013

The SRM or PRM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	Feb 16, 2013
Nicolet 6700 AHR0801551 NO2	FTIR	Mar 07, 2013

Triad Data Available Upon Request

Notes:

Approved for Release

IN SERVICE 08/08/19

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

NT 1

CV 6

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-400996728-1
Cylinder Number:	CC185484	Cylinder Volume:	144.3 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32017	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Sep 22, 2017

Expiration Date: Sep 22, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.497 PPM	G1	+/- 1.1% NIST Traceable	09/15/2017, 09/22/2017
NITRIC OXIDE	5.500 PPM	5.360 PPM	G1	+/- 1.2% NIST Traceable	09/15/2017, 09/22/2017
CARBON MONOXIDE	500.0 PPM	505.5 PPM	G1	+/- 0.6% NIST Traceable	09/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Sep 14, 2017
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Aug 31, 2017
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Aug 31, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

INST 1

CV 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401144293-1
Cylinder Number:	EB0061551	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 13, 2018

Expiration Date: Mar 13, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.404 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	2.500 PPM	2.397 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
CARBON MONOXIDE	4.750 PPM	4.653 PPM	G1	+/- 0.6% NIST Traceable	03/06/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 02, 2018
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 02, 2018
NTRM	1	CC401502	9.766 PPM CARBON MONOXIDE/NITROGEN	0.3	Sep 07, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 13, 2018
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 22, 2018
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 22, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124604208-1
Cylinder Number:	CC25033	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 20, 2017

Expiration Date: Feb 20, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.05 %	G1	+/- 0.7% NIST Traceable	02/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Feb 17, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV 9

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401555373-1
Cylinder Number:	EB0090548	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72019	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jul 26, 2019

Expiration Date: Jul 26, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.514 %	G1	+/- 0.4% NIST Traceable	07/26/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Jul 10, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

Linearity Report

ORIS Code: 56298
EDR Site ID: CT1
Facility Name: COLUSA GENERATION
Component ID: A12
Component Type: O2D
ReasonForTest: QA
Grace Period: 0

Instrument Name: CT1_O2D_P_Instrument
Performance Spec: 5 %
Test End Date/Time: 01/14/2020
Test No.: 92
Status (Pass/Fail): **Passed**
Scale: High
Highest Error: 1.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/14/2020	0925	L	25.0	5.5	5.4		22.0 %
01/14/2020	0931	M	25.0	13.1	12.9		52.4 %
01/14/2020	0937	H	25.0	21.0	20.9		84.0 %
01/14/2020	0946	L	25.0	5.5	5.4		22.0 %
01/14/2020	0952	M	25.0	13.1	12.9		52.4 %
01/14/2020	0958	H	25.0	21.0	20.9		84.0 %
01/14/2020	1006	L	25.0	5.5	5.4		22.0 %
01/14/2020	1012	M	25.0	13.1	12.9		52.4 %
01/14/2020	1018	H	25.0	21.0	20.9		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.400	No	**1.8**
M	13.100	12.900	No	**1.5**
H	21.000	20.900	No	**0.5**

Linearity Report

ORIS Code: 56298
Facility Name: COLUSA GENERATION
EDR Site ID: CT1
Component ID: A11
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrume
Test End Date/Time: 01/14/2020
Scale: High
Performance Spec: 5 %
Test No.: 93
Highest Error: 1.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
01/14/2020	1140	L	200.0	50.7	49.3		25.4 %
01/14/2020	1146	M	200.0	110.9	110.8		55.5 %
01/14/2020	1152	H	200.0	184.8	184.7		92.4 %
01/14/2020	1201	L	200.0	50.7	49.9		25.4 %
01/14/2020	1207	M	200.0	110.9	110.9		55.5 %
01/14/2020	1213	H	200.0	184.8	184.8		92.4 %
01/14/2020	1221	L	200.0	50.7	50.1		25.4 %
01/14/2020	1227	M	200.0	110.9	111.0		55.5 %
01/14/2020	1233	H	200.0	184.8	185.1		92.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.700	49.767	No	**1.8**
M	110.900	110.900	No	**0.0**
H	184.800	184.867	No	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / High
Test Date: 01/14/2020
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	15:40	L	2000	505.500	445.000	25.3 %
01/14/2020	15:46	M	2000	1151.000	1070.800	57.6 %
01/14/2020	15:55	L	2000	505.500	445.000	25.3 %
01/14/2020	16:01	M	2000	1151.000	1071.100	57.6 %
01/14/2020	16:09	L	2000	505.500	445.600	25.3 %
01/14/2020	16:15	M	2000	1151.000	1071.900	57.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	505.500	445.200	Std	**11.9**
M	1151.000	1071.267	Std	**6.9**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / Low
Test Date: 01/14/2020
Test Result: **Pass**
Instrument Name: CT1_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	14:29	L	10	2.400	2.100	24.0 %
01/14/2020	14:35	M	10	5.500	5.400	55.0 %
01/14/2020	14:44	L	10	2.400	2.100	24.0 %
01/14/2020	14:50	M	10	5.500	5.400	55.0 %
01/14/2020	14:58	L	10	2.400	2.100	24.0 %
01/14/2020	15:04	M	10	5.500	5.500	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.100	Std	**12.5**
M	5.500	5.433	Std	**1.2**

Cylinder Gas Audit

01/15/2020

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / Low
Test Date: 01/14/2020
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/14/2020	13:29	L	20	4.700	4.600	23.5 %
01/14/2020	13:35	M	20	11.100	11.100	55.5 %
01/14/2020	13:44	L	20	4.700	4.500	23.5 %
01/14/2020	13:50	M	20	11.100	11.100	55.5 %
01/14/2020	13:58	L	20	4.700	4.500	23.5 %
01/14/2020	14:04	M	20	11.100	11.100	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.533	Std	**3.5**
M	11.100	11.100	Std	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / High
Test Date: 01/15/2020
Test Result: **Pass**
Instrument Name: CT1_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/15/2020	09:23	L	200	50.700	49.200	25.4 %
01/15/2020	09:29	M	200	110.900	109.200	55.5 %
01/15/2020	09:38	L	200	50.700	49.500	25.4 %
01/15/2020	09:44	M	200	110.900	109.800	55.5 %
01/15/2020	09:52	L	200	50.700	49.700	25.4 %
01/15/2020	09:58	M	200	110.900	110.000	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.700	49.467	Std	**2.4**
M	110.900	109.667	Std	**1.1**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High
Test Date: 01/15/2020
Test Result: **Pass**
Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
01/15/2020	10:31	L	25	5.500	5.500	22.0 %
01/15/2020	10:37	M	25	13.100	13.000	52.4 %
01/15/2020	10:46	L	25	5.500	5.500	22.0 %
01/15/2020	10:52	M	25	13.100	13.000	52.4 %
01/15/2020	11:00	L	25	5.500	5.500	22.0 %
01/15/2020	11:06	M	25	13.100	13.000	52.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.100	13.000	Std	**0.8**

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:02 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	1.7		
01/02/2020 07:43 01/02/2020 08:54 Warm Start - Gas	72	127.4		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	1.3		
01/06/2020 07:52 01/06/2020 09:13 Warm Start - Gas	82	145.1		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	1.0		
01/09/2020 02:43 01/09/2020 03:45 Warm Start - Gas	63	112.5		
01/11/2020 08:25 01/11/2020 08:30 Shut Down - Gas	6	2.0		
01/13/2020 03:48 01/13/2020 06:00 Warm Start - Gas	133	241.5		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	1.8		
01/28/2020 03:23 01/28/2020 04:41 Cold Start - Gas	79	138.3		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	1.7		
01/30/2020 02:20 01/30/2020 03:32 Warm Start - Gas	73	129.1		
01/31/2020 00:34 01/31/2020 00:39 Shut Down - Gas	6	1.7		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:02 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/31/2020 05:18 01/31/2020 06:28 Hot Start - Gas	71	131.9		
01/31/2020 23:25 01/31/2020 23:29 Shut Down - Gas	5	0.9		
02/03/2020 03:52 02/03/2020 05:22 Warm Start - Gas	91	156.1		
02/07/2020 23:24 02/07/2020 23:28 Shut Down - Gas	5	1.2		
02/10/2020 03:18 02/10/2020 05:28 Warm Start - Gas	131	238.9		
02/14/2020 00:52 02/14/2020 00:57 Shut Down - Gas	6	2.1		
02/17/2020 15:03 02/17/2020 16:39 Cold Start - Gas	97	165.1		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	0.9		
02/25/2020 14:20 02/25/2020 15:57 Cold Start - Gas	98	174.9		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	1.7		
02/27/2020 02:27 02/27/2020 03:45 Warm Start - Gas	79	142.1		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	1.3		
03/03/2020 15:22 03/03/2020 16:53 Cold Start - Gas	92	159.2		
03/07/2020 00:24 03/07/2020 00:28 Shut Down - Gas	5	1.0		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:02 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
03/09/2020 01:48 03/09/2020 03:08 Warm Start - Gas	81	145.5		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	1.8		
03/24/2020 02:17 03/24/2020 03:52 Warm Start - Gas	96	163.0		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	1.9		
03/27/2020 23:04 03/28/2020 00:44 Warm Start - Gas	101	174.9		
03/31/2020 07:24 03/31/2020 07:28 Shut Down - Gas	5	1.1		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:02 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,331.73 Hours
Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:02 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	1.7	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.7 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	0.0	0	0	0	0	0
01/02/2020 02:00	0.0	0	0	0	0	0
01/02/2020 03:00	0.0	0	0	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	0
01/02/2020 05:00	0.0	0	0	0	0	0
01/02/2020 06:00	0.0	0	0	0	0	0
01/02/2020 07:00	56.2	0	1	0	0	0
01/02/2020 08:00	40.6	0	1	0	0	0
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	96.8 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	0.7	0	0	0	1	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	0.0	0	0	0	0	0
01/06/2020 05:00	0.0	0	0	0	0	0
01/06/2020 06:00	0.0	0	0	0	0	0
01/06/2020 07:00	29.5	0	1	0	0	0
01/06/2020 08:00	73.0	0	1	0	0	0
01/06/2020 09:00	1.8	0	1	0	0	0
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	104.3 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	1.1	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	0.0	0	0	0	0	0
01/08/2020 22:00	0.0	0	0	0	0	0
01/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	0
01/09/2020 01:00	0.0	0	0	0	0	0
01/09/2020 02:00	59.3	0	1	0	0	0
01/09/2020 03:00	32.7	0	1	0	0	0
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	92.0 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	1.4	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	0.0	0	0	0	0	0
01/13/2020 01:00	0.0	0	0	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	0
01/13/2020 03:00	51.5	0	1	0	0	0
01/13/2020 04:00	62.9	0	1	0	0	0
01/13/2020 05:00	66.7	0	1	0	0	0
01/13/2020 06:00	0.0	0	1	0	0	0
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	181.1 #	0 #	4 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	0.0	0	0	0	0	0
01/27/2020 19:00	0.0	0	0	0	0	0
01/27/2020 20:00	0.0	0	0	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	0
01/27/2020 22:00	0.0	0	0	0	0	0
01/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	0
01/28/2020 01:00	0.0	0	0	0	0	0
01/28/2020 02:00	0.0	0	0	0	0	0
01/28/2020 03:00	89.3	1	0	0	0	0
01/28/2020 04:00	23.0	1	0	0	0	0
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	1.4	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	113.7 #	2 #	0 #	0 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	89.3	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	0.0	0	0	0	0	0
01/29/2020 18:00	0.0	0	0	0	0	0
01/29/2020 19:00	0.0	0	0	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	0
01/29/2020 21:00	0.0	0	0	0	0	0
01/29/2020 22:00	0.0	0	0	0	0	0
01/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	0
01/30/2020 01:00	0.0	0	0	0	0	0
01/30/2020 02:00	61.4	0	1	0	0	0
01/30/2020 03:00	16.5	0	1	0	0	0
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.9 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	1.0	0	0	0	1	0
01/31/2020 01:00	0.0	0	0	0	0	0
01/31/2020 02:00	0.0	0	0	0	0	0
01/31/2020 03:00	0.0	0	0	0	0	0
01/31/2020 04:00	0.0	0	0	0	0	0
01/31/2020 05:00	24.2	0	0	1	0	0
01/31/2020 06:00	15.6	0	0	1	0	0
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	42.0 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	0.0	0	0	0	0	0
02/03/2020 01:00	0.0	0	0	0	0	0
02/03/2020 02:00	0.0	0	0	0	0	0
02/03/2020 03:00	28.4	0	1	0	0	0
02/03/2020 04:00	69.9	0	1	0	0	0
02/03/2020 05:00	9.0	0	1	0	0	0
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	107.3 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	69.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	0.0	0	0	0	0	0
02/10/2020 01:00	0.0	0	0	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	0
02/10/2020 03:00	70.5	0	1	0	0	0
02/10/2020 04:00	53.9	0	1	0	0	0
02/10/2020 05:00	13.4	0	1	0	0	0
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	137.8 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	1.0	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	0.0	0	0	0	0	0
02/17/2020 10:00	0.0	0	0	0	0	0
02/17/2020 11:00	0.0	0	0	0	0	0
02/17/2020 12:00	0.0	0	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	0
02/17/2020 14:00	0.0	0	0	0	0	0
02/17/2020 15:00	70.1	1	0	0	0	0
02/17/2020 16:00	20.4	1	0	0	0	0
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	90.5 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	0.0	0	0	0	0	0
02/24/2020 14:00	0.0	0	0	0	0	0
02/24/2020 15:00	0.0	0	0	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	0
02/24/2020 17:00	0.0	0	0	0	0	0
02/24/2020 18:00	0.0	0	0	0	0	0
02/24/2020 19:00	0.0	0	0	0	0	0
02/24/2020 20:00	0.0	0	0	0	0	0
02/24/2020 21:00	0.0	0	0	0	0	0
02/24/2020 22:00	0.0	0	0	0	0	0
02/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	0
02/25/2020 01:00	0.0	0	0	0	0	0
02/25/2020 02:00	0.0	0	0	0	0	0
02/25/2020 03:00	0.0	0	0	0	0	0
02/25/2020 04:00	0.0	0	0	0	0	0
02/25/2020 05:00	0.0	0	0	0	0	0
02/25/2020 06:00	0.0	0	0	0	0	0
02/25/2020 07:00	0.0	0	0	0	0	0
02/25/2020 08:00	0.0	0	0	0	0	0
02/25/2020 09:00	0.0	0	0	0	0	0
02/25/2020 10:00	0.0	0	0	0	0	0
02/25/2020 11:00	0.0	0	0	0	0	0
02/25/2020 12:00	0.0	0	0	0	0	0
02/25/2020 13:00	0.0	0	0	0	0	0
02/25/2020 14:00	63.6	1	0	0	0	0
02/25/2020 15:00	35.1	1	0	0	0	0
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	98.7 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	1.5	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	0.0	0	0	0	0	0
02/26/2020 16:00	0.0	0	0	0	0	0
02/26/2020 17:00	0.0	0	0	0	0	0
02/26/2020 18:00	0.0	0	0	0	0	0
02/26/2020 19:00	0.0	0	0	0	0	0
02/26/2020 20:00	0.0	0	0	0	0	0
02/26/2020 21:00	0.0	0	0	0	0	0
02/26/2020 22:00	0.0	0	0	0	0	0
02/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	0
02/27/2020 01:00	0.0	0	0	0	0	0
02/27/2020 02:00	37.6	0	1	0	0	0
02/27/2020 03:00	34.2	0	1	0	0	0
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	71.8 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	1.5	0	0	0	1	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	0.0	0	0	0	0	0
03/03/2020 09:00	0.0	0	0	0	0	0
03/03/2020 10:00	0.0	0	0	0	0	0
03/03/2020 11:00	0.0	0	0	0	0	0
03/03/2020 12:00	0.0	0	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	0
03/03/2020 14:00	0.0	0	0	0	0	0
03/03/2020 15:00	58.5	1	0	0	0	0
03/03/2020 16:00	25.9	1	0	0	0	0
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.4 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.5	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	1.2	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	0.0	0	0	0	0	0
03/08/2020 21:00	0.0	0	0	0	0	0
03/08/2020 22:00	0.0	0	0	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	0
03/09/2020 01:00	47.4	0	1	0	0	0
03/09/2020 02:00	63.7	0	1	0	0	0
03/09/2020 03:00	0.2	0	1	0	0	0
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	111.3 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	1.5	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	0.0	0	0	0	0	0
03/22/2020 18:00	0.0	0	0	0	0	0
03/22/2020 19:00	0.0	0	0	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	0
03/22/2020 21:00	0.0	0	0	0	0	0
03/22/2020 22:00	0.0	0	0	0	0	0
03/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	0
03/23/2020 01:00	0.0	0	0	0	0	0
03/23/2020 02:00	0.0	0	0	0	0	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	0.0	0	0	0	0	0
03/23/2020 18:00	0.0	0	0	0	0	0
03/23/2020 19:00	0.0	0	0	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	0
03/23/2020 21:00	0.0	0	0	0	0	0
03/23/2020 22:00	0.0	0	0	0	0	0
03/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	0
03/24/2020 01:00	0.0	0	0	0	0	0
03/24/2020 02:00	86.7	0	1	0	0	0
03/24/2020 03:00	37.8	0	1	0	0	0
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	125.9 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	86.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	0.0	0	0	0	0	0
03/27/2020 18:00	0.0	0	0	0	0	0
03/27/2020 19:00	0.0	0	0	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	0
03/27/2020 21:00	0.0	0	0	0	0	0
03/27/2020 22:00	0.0	0	0	0	0	0
03/27/2020 23:00	88.3	0	1	0	0	0
Average/Sum#:	88.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	30.2	0	1	0	0	0
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	30.2 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:03 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	1.2	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	0.0	0	0	0	0	0
03/31/2020 19:00	0.0	0	0	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	0
03/31/2020 21:00	0.0	0	0	0	0	0
03/31/2020 22:00	0.0	0	0	0	0	0
03/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	99.7	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	99.7 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	99.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	0.0	0	0	0	0	0
01/02/2020 02:00	0.0	0	0	0	0	0
01/02/2020 03:00	0.0	0	0	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	0
01/02/2020 05:00	0.0	0	0	0	0	0
01/02/2020 06:00	0.0	0	0	0	0	0
01/02/2020 07:00	1,034.7	0	1	0	0	0
01/02/2020 08:00	6,609.4	0	1	0	0	0
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,644.1 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,609.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	80.3	0	0	0	1	0
Average/Sum#:	80.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	0.0	0	0	0	0	0
01/06/2020 05:00	0.0	0	0	0	0	0
01/06/2020 06:00	0.0	0	0	0	0	0
01/06/2020 07:00	276.0	0	1	0	0	0
01/06/2020 08:00	5,853.6	0	1	0	0	0
01/06/2020 09:00	2,575.6	0	1	0	0	0
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,705.2 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,853.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	57.9	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	57.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	0.0	0	0	0	0	0
01/08/2020 22:00	0.0	0	0	0	0	0
01/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	0
01/09/2020 01:00	0.0	0	0	0	0	0
01/09/2020 02:00	1,050.8	0	1	0	0	0
01/09/2020 03:00	5,696.3	0	1	0	0	0
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,747.1 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,696.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	122.6	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	122.6 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	122.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	0.0	0	0	0	0	0
01/13/2020 01:00	0.0	0	0	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	0
01/13/2020 03:00	606.6	0	1	0	0	0
01/13/2020 04:00	5,743.1	0	1	0	0	0
01/13/2020 05:00	7,897.9	0	1	0	0	0
01/13/2020 06:00	241.4	0	1	0	0	0
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,489.0 #	0 #	4 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,897.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	106.1	0	0	0	1	0
Average/Sum#:	106.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	106.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	0.0	0	0	0	0	0
01/27/2020 19:00	0.0	0	0	0	0	0
01/27/2020 20:00	0.0	0	0	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	0
01/27/2020 22:00	0.0	0	0	0	0	0
01/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	0
01/28/2020 01:00	0.0	0	0	0	0	0
01/28/2020 02:00	0.0	0	0	0	0	0
01/28/2020 03:00	2,720.5	1	0	0	0	0
01/28/2020 04:00	5,578.4	1	0	0	0	0
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	100.9	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,399.8 #	2 #	0 #	0 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,578.4	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	0.0	0	0	0	0	0
01/29/2020 18:00	0.0	0	0	0	0	0
01/29/2020 19:00	0.0	0	0	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	0
01/29/2020 21:00	0.0	0	0	0	0	0
01/29/2020 22:00	0.0	0	0	0	0	0
01/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	0
01/30/2020 01:00	0.0	0	0	0	0	0
01/30/2020 02:00	2,983.6	0	1	0	0	0
01/30/2020 03:00	4,762.4	0	1	0	0	0
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,746.0 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,762.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	104.0	0	0	0	1	0
01/31/2020 01:00	0.0	0	0	0	0	0
01/31/2020 02:00	0.0	0	0	0	0	0
01/31/2020 03:00	0.0	0	0	0	0	0
01/31/2020 04:00	0.0	0	0	0	0	0
01/31/2020 05:00	3,536.4	0	0	1	0	0
01/31/2020 06:00	4,379.4	0	0	1	0	0
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	54.2	0	0	0	1	0
Average/Sum#:	8,074.0 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,379.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	0.0	0	0	0	0	0
02/03/2020 01:00	0.0	0	0	0	0	0
02/03/2020 02:00	0.0	0	0	0	0	0
02/03/2020 03:00	227.5	0	1	0	0	0
02/03/2020 04:00	5,476.4	0	1	0	0	0
02/03/2020 05:00	3,661.2	0	1	0	0	0
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,365.1 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,476.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	73.9	0	0	0	1	0
Average/Sum#:	73.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	0.0	0	0	0	0	0
02/10/2020 01:00	0.0	0	0	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	0
02/10/2020 03:00	3,154.8	0	1	0	0	0
02/10/2020 04:00	6,876.9	0	1	0	0	0
02/10/2020 05:00	4,299.7	0	1	0	0	0
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,331.4 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,876.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	123.8	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	123.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	123.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	0.0	0	0	0	0	0
02/17/2020 10:00	0.0	0	0	0	0	0
02/17/2020 11:00	0.0	0	0	0	0	0
02/17/2020 12:00	0.0	0	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	0
02/17/2020 14:00	0.0	0	0	0	0	0
02/17/2020 15:00	4,402.2	1	0	0	0	0
02/17/2020 16:00	5,500.9	1	0	0	0	0
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,903.1 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,500.9	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	54.9	0	0	0	1	0
Average/Sum#:	54.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	0.0	0	0	0	0	0
02/24/2020 14:00	0.0	0	0	0	0	0
02/24/2020 15:00	0.0	0	0	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	0
02/24/2020 17:00	0.0	0	0	0	0	0
02/24/2020 18:00	0.0	0	0	0	0	0
02/24/2020 19:00	0.0	0	0	0	0	0
02/24/2020 20:00	0.0	0	0	0	0	0
02/24/2020 21:00	0.0	0	0	0	0	0
02/24/2020 22:00	0.0	0	0	0	0	0
02/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	0
02/25/2020 01:00	0.0	0	0	0	0	0
02/25/2020 02:00	0.0	0	0	0	0	0
02/25/2020 03:00	0.0	0	0	0	0	0
02/25/2020 04:00	0.0	0	0	0	0	0
02/25/2020 05:00	0.0	0	0	0	0	0
02/25/2020 06:00	0.0	0	0	0	0	0
02/25/2020 07:00	0.0	0	0	0	0	0
02/25/2020 08:00	0.0	0	0	0	0	0
02/25/2020 09:00	0.0	0	0	0	0	0
02/25/2020 10:00	0.0	0	0	0	0	0
02/25/2020 11:00	0.0	0	0	0	0	0
02/25/2020 12:00	0.0	0	0	0	0	0
02/25/2020 13:00	0.0	0	0	0	0	0
02/25/2020 14:00	2,998.0	1	0	0	0	0
02/25/2020 15:00	7,493.7	1	0	0	0	0
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,491.7 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,493.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	101.3	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	0.0	0	0	0	0	0
02/26/2020 16:00	0.0	0	0	0	0	0
02/26/2020 17:00	0.0	0	0	0	0	0
02/26/2020 18:00	0.0	0	0	0	0	0
02/26/2020 19:00	0.0	0	0	0	0	0
02/26/2020 20:00	0.0	0	0	0	0	0
02/26/2020 21:00	0.0	0	0	0	0	0
02/26/2020 22:00	0.0	0	0	0	0	0
02/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	101.3 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	101.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	0
02/27/2020 01:00	0.0	0	0	0	0	0
02/27/2020 02:00	2,241.7	0	1	0	0	0
02/27/2020 03:00	6,281.7	0	1	0	0	0
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,523.4 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,281.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	78.2	0	0	0	1	0
Average/Sum#:	78.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	0.0	0	0	0	0	0
03/03/2020 09:00	0.0	0	0	0	0	0
03/03/2020 10:00	0.0	0	0	0	0	0
03/03/2020 11:00	0.0	0	0	0	0	0
03/03/2020 12:00	0.0	0	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	0
03/03/2020 14:00	0.0	0	0	0	0	0
03/03/2020 15:00	2,733.7	1	0	0	0	0
03/03/2020 16:00	6,817.7	1	0	0	0	0
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,551.4 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,817.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	59.1	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	59.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	0.0	0	0	0	0	0
03/08/2020 21:00	0.0	0	0	0	0	0
03/08/2020 22:00	0.0	0	0	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	0
03/09/2020 01:00	644.0	0	1	0	0	0
03/09/2020 02:00	6,148.7	0	1	0	0	0
03/09/2020 03:00	1,935.2	0	1	0	0	0
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,727.9 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,148.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	108.9	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	108.9 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	108.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	0.0	0	0	0	0	0
03/22/2020 18:00	0.0	0	0	0	0	0
03/22/2020 19:00	0.0	0	0	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	0
03/22/2020 21:00	0.0	0	0	0	0	0
03/22/2020 22:00	0.0	0	0	0	0	0
03/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	0
03/23/2020 01:00	0.0	0	0	0	0	0
03/23/2020 02:00	0.0	0	0	0	0	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	0.0	0	0	0	0	0
03/23/2020 18:00	0.0	0	0	0	0	0
03/23/2020 19:00	0.0	0	0	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	0
03/23/2020 21:00	0.0	0	0	0	0	0
03/23/2020 22:00	0.0	0	0	0	0	0
03/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	0
03/24/2020 01:00	0.0	0	0	0	0	0
03/24/2020 02:00	3,194.7	0	1	0	0	0
03/24/2020 03:00	6,588.0	0	1	0	0	0
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	115.5	0	0	0	1	0
Average/Sum#:	9,898.2 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,588.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	0.0	0	0	0	0	0
03/27/2020 18:00	0.0	0	0	0	0	0
03/27/2020 19:00	0.0	0	0	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	0
03/27/2020 21:00	0.0	0	0	0	0	0
03/27/2020 22:00	0.0	0	0	0	0	0
03/27/2020 23:00	4,326.9	0	1	0	0	0
Average/Sum#:	4,326.9 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,326.9	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	6,164.3	0	1	0	0	0
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,164.3 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,164.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	66.4	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	0.0	0	0	0	0	0
03/31/2020 19:00	0.0	0	0	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	0
03/31/2020 21:00	0.0	0	0	0	0	0
03/31/2020 22:00	0.0	0	0	0	0	0
03/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	66.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	1.4	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	0.0	0	0	0	0	0
01/02/2020 02:00	0.0	0	0	0	0	0
01/02/2020 03:00	0.0	0	0	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	0
01/02/2020 05:00	0.0	0	0	0	0	0
01/02/2020 06:00	0.0	0	0	0	0	0
01/02/2020 07:00	16.8	0	1	0	0	0
01/02/2020 08:00	86.3	0	1	0	0	0
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.1 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	86.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	0.0	0	0	0	0	0
01/06/2020 05:00	0.0	0	0	0	0	0
01/06/2020 06:00	0.0	0	0	0	0	0
01/06/2020 07:00	1.5	0	1	0	0	0
01/06/2020 08:00	108.3	0	1	0	0	0
01/06/2020 09:00	4.9	0	1	0	0	0
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.7 #	0 #	3 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	108.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	1.0	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	0.0	0	0	0	0	0
01/08/2020 22:00	0.0	0	0	0	0	0
01/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	0
01/09/2020 01:00	0.0	0	0	0	0	0
01/09/2020 02:00	17.6	0	1	0	0	0
01/09/2020 03:00	75.5	0	1	0	0	0
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	93.1 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	1.3	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	0.0	0	0	0	0	0
01/13/2020 01:00	0.0	0	0	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	0
01/13/2020 03:00	8.9	0	1	0	0	0
01/13/2020 04:00	93.3	0	1	0	0	0
01/13/2020 05:00	64.1	0	1	0	0	0
01/13/2020 06:00	0.0	0	1	0	0	0
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	166.3 #	0 #	4 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	1.0	0	0	0	1	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	0.0	0	0	0	0	0
01/27/2020 19:00	0.0	0	0	0	0	0
01/27/2020 20:00	0.0	0	0	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	0
01/27/2020 22:00	0.0	0	0	0	0	0
01/27/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	0
01/28/2020 01:00	0.0	0	0	0	0	0
01/28/2020 02:00	0.0	0	0	0	0	0
01/28/2020 03:00	52.9	1	0	0	0	0
01/28/2020 04:00	47.9	1	0	0	0	0
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	1.0	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	101.8 #	2 #	0 #	0 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.9	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	0.0	0	0	0	0	0
01/29/2020 18:00	0.0	0	0	0	0	0
01/29/2020 19:00	0.0	0	0	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	0
01/29/2020 21:00	0.0	0	0	0	0	0
01/29/2020 22:00	0.0	0	0	0	0	0
01/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	0
01/30/2020 01:00	0.0	0	0	0	0	0
01/30/2020 02:00	62.6	0	1	0	0	0
01/30/2020 03:00	24.9	0	1	0	0	0
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.5 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	0.7	0	0	0	1	0
01/31/2020 01:00	0.0	0	0	0	0	0
01/31/2020 02:00	0.0	0	0	0	0	0
01/31/2020 03:00	0.0	0	0	0	0	0
01/31/2020 04:00	0.0	0	0	0	0	0
01/31/2020 05:00	11.6	0	0	1	0	0
01/31/2020 06:00	15.9	0	0	1	0	0
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	0.9	0	0	0	1	0
Average/Sum#:	29.1 #	0 #	0 #	2 #	2 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	0.0	0	0	0	0	0
02/03/2020 01:00	0.0	0	0	0	0	0
02/03/2020 02:00	0.0	0	0	0	0	0
02/03/2020 03:00	1.0	0	1	0	0	0
02/03/2020 04:00	101.3	0	1	0	0	0
02/03/2020 05:00	14.6	0	1	0	0	0
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	116.9 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	101.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	0.0	0	0	0	0	0
02/10/2020 01:00	0.0	0	0	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	0
02/10/2020 03:00	74.6	0	1	0	0	0
02/10/2020 04:00	82.7	0	1	0	0	0
02/10/2020 05:00	18.9	0	1	0	0	0
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	176.2 #	0 #	3 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	82.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	1.0	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	0.0	0	0	0	0	0
02/17/2020 10:00	0.0	0	0	0	0	0
02/17/2020 11:00	0.0	0	0	0	0	0
02/17/2020 12:00	0.0	0	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	0
02/17/2020 14:00	0.0	0	0	0	0	0
02/17/2020 15:00	97.3	1	0	0	0	0
02/17/2020 16:00	40.5	1	0	0	0	0
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	137.8 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	97.3	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	0.0	0	0	0	0	0
02/24/2020 14:00	0.0	0	0	0	0	0
02/24/2020 15:00	0.0	0	0	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	0
02/24/2020 17:00	0.0	0	0	0	0	0
02/24/2020 18:00	0.0	0	0	0	0	0
02/24/2020 19:00	0.0	0	0	0	0	0
02/24/2020 20:00	0.0	0	0	0	0	0
02/24/2020 21:00	0.0	0	0	0	0	0
02/24/2020 22:00	0.0	0	0	0	0	0
02/24/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	0
02/25/2020 01:00	0.0	0	0	0	0	0
02/25/2020 02:00	0.0	0	0	0	0	0
02/25/2020 03:00	0.0	0	0	0	0	0
02/25/2020 04:00	0.0	0	0	0	0	0
02/25/2020 05:00	0.0	0	0	0	0	0
02/25/2020 06:00	0.0	0	0	0	0	0
02/25/2020 07:00	0.0	0	0	0	0	0
02/25/2020 08:00	0.0	0	0	0	0	0
02/25/2020 09:00	0.0	0	0	0	0	0
02/25/2020 10:00	0.0	0	0	0	0	0
02/25/2020 11:00	0.0	0	0	0	0	0
02/25/2020 12:00	0.0	0	0	0	0	0
02/25/2020 13:00	0.0	0	0	0	0	0
02/25/2020 14:00	71.2	1	0	0	0	0
02/25/2020 15:00	92.8	1	0	0	0	0
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	164.0 #	2 #	0 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	92.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	1.1	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	0.0	0	0	0	0	0
02/26/2020 16:00	0.0	0	0	0	0	0
02/26/2020 17:00	0.0	0	0	0	0	0
02/26/2020 18:00	0.0	0	0	0	0	0
02/26/2020 19:00	0.0	0	0	0	0	0
02/26/2020 20:00	0.0	0	0	0	0	0
02/26/2020 21:00	0.0	0	0	0	0	0
02/26/2020 22:00	0.0	0	0	0	0	0
02/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	0
02/27/2020 01:00	0.0	0	0	0	0	0
02/27/2020 02:00	43.4	0	1	0	0	0
02/27/2020 03:00	47.7	0	1	0	0	0
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.1 #	0 #	2 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	0.0	0	0	0	0	0
03/03/2020 09:00	0.0	0	0	0	0	0
03/03/2020 10:00	0.0	0	0	0	0	0
03/03/2020 11:00	0.0	0	0	0	0	0
03/03/2020 12:00	0.0	0	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	0
03/03/2020 14:00	0.0	0	0	0	0	0
03/03/2020 15:00	65.3	1	0	0	0	0
03/03/2020 16:00	88.7	1	0	0	0	0
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	154.0 #	2 #	0 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	0.8	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	0.0	0	0	0	0	0
03/08/2020 21:00	0.0	0	0	0	0	0
03/08/2020 22:00	0.0	0	0	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	0
03/09/2020 01:00	9.0	0	1	0	0	0
03/09/2020 02:00	96.5	0	1	0	0	0
03/09/2020 03:00	2.0	0	1	0	0	0
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	107.5 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	96.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	1.3	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	0.0	0	0	0	0	0
03/22/2020 18:00	0.0	0	0	0	0	0
03/22/2020 19:00	0.0	0	0	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	0
03/22/2020 21:00	0.0	0	0	0	0	0
03/22/2020 22:00	0.0	0	0	0	0	0
03/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	0
03/23/2020 01:00	0.0	0	0	0	0	0
03/23/2020 02:00	0.0	0	0	0	0	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	0.0	0	0	0	0	0
03/23/2020 18:00	0.0	0	0	0	0	0
03/23/2020 19:00	0.0	0	0	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	0
03/23/2020 21:00	0.0	0	0	0	0	0
03/23/2020 22:00	0.0	0	0	0	0	0
03/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	0
03/24/2020 01:00	0.0	0	0	0	0	0
03/24/2020 02:00	72.5	0	1	0	0	0
03/24/2020 03:00	62.2	0	1	0	0	0
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	135.8 #	0 #	2 #	0 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	0.0	0	0	0	0	0
03/27/2020 18:00	0.0	0	0	0	0	0
03/27/2020 19:00	0.0	0	0	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	0
03/27/2020 21:00	0.0	0	0	0	0	0
03/27/2020 22:00	0.0	0	0	0	0	0
03/27/2020 23:00	87.3	0	1	0	0	0
Average/Sum#:	87.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	33.9	0	1	0	0	0
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	33.9 #	0 #	1 #	0 #	0 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:04 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	0.9	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	0.0	0	0	0	0	0
03/31/2020 19:00	0.0	0	0	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	0
03/31/2020 21:00	0.0	0	0	0	0	0
03/31/2020 22:00	0.0	0	0	0	0	0
03/31/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:05 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	1.0	483.5		
01/02/2020 07:43 01/02/2020 08:54 Warm Start - Gas	72	87.9	790.5		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	0.8	483.5		
01/06/2020 07:52 01/06/2020 09:13 Warm Start - Gas	82	98.9	790.5		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	0.3	483.5		
01/09/2020 02:43 01/09/2020 03:45 Warm Start - Gas	63	84.5	790.5		
01/11/2020 08:25 01/11/2020 08:30 Shut Down - Gas	6	1.0	483.5		
01/13/2020 03:48 01/13/2020 06:00 Warm Start - Gas	133	161.1	790.5		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	0.9	483.5		
01/28/2020 03:23 01/28/2020 04:41 Cold Start - Gas	79	111.0	1,355.6		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	0.9	483.5		
01/30/2020 02:20 01/30/2020 03:32 Warm Start - Gas	73	82.5	790.5		
01/31/2020 00:34 01/31/2020 00:39 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:05 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/31/2020 05:18 01/31/2020 06:28 Hot Start - Gas	71	47.7	679.6		
01/31/2020 23:25 01/31/2020 23:29 Shut Down - Gas	5	0.5	483.5		
02/03/2020 03:52 02/03/2020 05:22 Warm Start - Gas	91	107.3	790.5		
02/07/2020 23:24 02/07/2020 23:28 Shut Down - Gas	5	0.7	483.5		
02/10/2020 03:18 02/10/2020 05:28 Warm Start - Gas	131	136.8	790.5		
02/14/2020 00:52 02/14/2020 00:57 Shut Down - Gas	6	1.1	483.5		
02/17/2020 15:03 02/17/2020 16:39 Cold Start - Gas	97	94.4	1,355.6		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	0.5	483.5		
02/25/2020 14:20 02/25/2020 15:57 Cold Start - Gas	98	88.6	1,355.6		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	0.9	483.5		
02/27/2020 02:27 02/27/2020 03:45 Warm Start - Gas	79	71.1	790.5		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	0.8	483.5		
03/03/2020 15:22 03/03/2020 16:53 Cold Start - Gas	92	83.9	1,355.6		
03/07/2020 00:24 03/07/2020 00:28 Shut Down - Gas	5	0.7	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:05 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/09/2020 01:48 03/09/2020 03:08 Warm Start - Gas	81	107.9	790.5		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	1.0	483.5		
03/24/2020 02:17 03/24/2020 03:52 Warm Start - Gas	96	120.5	790.5		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	1.0	483.5		
03/27/2020 23:04 03/28/2020 00:44 Warm Start - Gas	101	115.0	790.5		
03/31/2020 07:24 03/31/2020 07:28 Shut Down - Gas	5	0.7	483.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:05 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:05 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:06 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours
Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	0.55	115.00		
01/02/2020 07:43 01/02/2020 08:54 Warm Start - Gas	72	102.92	456.20		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	0.49	115.00		
01/06/2020 07:52 01/06/2020 09:13 Warm Start - Gas	82	126.61	456.20		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	0.31	115.00		
01/09/2020 02:43 01/09/2020 03:45 Warm Start - Gas	63	102.11	456.20		
01/11/2020 08:25 01/11/2020 08:30 Shut Down - Gas	6	0.66	115.00		
01/13/2020 03:48 01/13/2020 06:00 Warm Start - Gas	133	158.44	456.20		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	0.42	115.00		
01/28/2020 03:23 01/28/2020 04:41 Cold Start - Gas	79	107.92	779.10		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	0.41	115.00		
01/30/2020 02:20 01/30/2020 03:32 Warm Start - Gas	73	98.77	456.20		
01/31/2020 00:34 01/31/2020 00:39 Shut Down - Gas	6	0.37	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:06 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,331.73 Hours
Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/31/2020 05:18 01/31/2020 06:28 Hot Start - Gas	71	36.09	259.90		
01/31/2020 23:25 01/31/2020 23:29 Shut Down - Gas	5	0.22	115.00		
02/03/2020 03:52 02/03/2020 05:22 Warm Start - Gas	91	126.67	456.20		
02/07/2020 23:24 02/07/2020 23:28 Shut Down - Gas	5	0.34	115.00		
02/10/2020 03:18 02/10/2020 05:28 Warm Start - Gas	131	184.04	456.20		
02/14/2020 00:52 02/14/2020 00:57 Shut Down - Gas	6	0.64	115.00		
02/17/2020 15:03 02/17/2020 16:39 Cold Start - Gas	97	146.30	779.10		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	0.22	115.00		
02/25/2020 14:20 02/25/2020 15:57 Cold Start - Gas	98	160.42	779.10		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	0.49	115.00		
02/27/2020 02:27 02/27/2020 03:45 Warm Start - Gas	79	97.95	456.20		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	0.27	115.00		
03/03/2020 15:22 03/03/2020 16:53 Cold Start - Gas	92	155.33	779.10		
03/07/2020 00:24 03/07/2020 00:28 Shut Down - Gas	5	0.25	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:06 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/09/2020 01:48 03/09/2020 03:08 Warm Start - Gas	81	113.04	456.20		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	0.64	115.00		
03/24/2020 02:17 03/24/2020 03:52 Warm Start - Gas	96	134.57	456.20		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	0.59	115.00		
03/27/2020 23:04 03/28/2020 00:44 Warm Start - Gas	101	126.14	456.20		
03/31/2020 07:24 03/31/2020 07:28 Shut Down - Gas	5	0.28	115.00		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:06 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:06 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	2.1		
01/02/2020 01:22 01/02/2020 03:47 Warm Start - Gas	146	270.9		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	1.6		
01/06/2020 04:32 01/06/2020 06:57 Warm Start - Gas	146	260.2		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	1.2		
01/08/2020 21:18 01/08/2020 23:49 Warm Start - Gas	152	241.2		
01/11/2020 08:26 01/11/2020 08:30 Shut Down - Gas	5	1.1		
01/12/2020 23:33 01/13/2020 01:48 Warm Start - Gas	136	253.1		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	2.4		
01/27/2020 18:12 01/27/2020 20:53 Warm Start - Gas	162	268.3		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	2.4		
01/29/2020 17:18 01/29/2020 19:29 Warm Start - Gas	132	234.7		
01/31/2020 23:25 01/31/2020 23:30 Shut Down - Gas	6	1.9		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
02/02/2020 23:13 02/03/2020 02:04 Warm Start - Gas	172	282.4		
02/07/2020 23:24 02/07/2020 23:29 Shut Down - Gas	6	1.8		
02/09/2020 23:18 02/10/2020 01:47 Warm Start - Gas	150	279.6		
02/14/2020 00:53 02/14/2020 00:57 Shut Down - Gas	5	1.2		
02/17/2020 09:11 02/17/2020 12:47 Cold Start - Gas	217	365.8		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	1.2		
02/24/2020 13:17 02/24/2020 15:54 Warm Start - Gas	158	280.9		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	2.3		
02/26/2020 15:24 02/26/2020 16:23 Hot Start - Gas	60	110.1		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	2.2		
03/03/2020 08:49 03/03/2020 12:31 Cold Start - Gas	223	382.9		
03/07/2020 00:24 03/07/2020 00:29 Shut Down - Gas	6	1.6		
03/08/2020 20:17 03/08/2020 22:30 Warm Start - Gas	134	213.6		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	2.1		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
03/22/2020 17:16 03/22/2020 19:48 Warm Start - Gas	153	244.1		
03/23/2020 02:04 03/23/2020 02:09 Shut Down - Gas	6	1.6		
03/23/2020 17:18 03/23/2020 19:52 Warm Start - Gas	155	249.1		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	2.2		
03/27/2020 17:04 03/27/2020 19:51 Warm Start - Gas	168	269.3		
03/31/2020 07:24 03/31/2020 07:29 Shut Down - Gas	6	1.8		
03/31/2020 18:08 03/31/2020 19:50 Warm Start - Gas	103	179.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	1.4	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	60.9	0	1	0	0	0
01/02/2020 02:00	47.6	0	1	0	0	0
01/02/2020 03:00	39.4	0	1	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	1
01/02/2020 05:00	0.0	0	0	0	0	1
01/02/2020 06:00	0.0	0	0	0	0	1
01/02/2020 07:00	0.0	0	0	0	0	1
01/02/2020 08:00	0.0	0	0	0	0	1
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	147.9 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	0.5	0	0	0	1	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	72.3	0	1	0	0	0
01/06/2020 05:00	31.6	0	1	0	0	0
01/06/2020 06:00	50.0	0	1	0	0	0
01/06/2020 07:00	0.0	0	0	0	0	1
01/06/2020 08:00	0.0	0	0	0	0	1
01/06/2020 09:00	0.0	0	0	0	0	1
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	153.9 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	0.9	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	78.9	0	1	0	0	0
01/08/2020 22:00	21.3	0	1	0	0	0
01/08/2020 23:00	26.5	0	1	0	0	0
Average/Sum#:	126.7 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.9	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	1
01/09/2020 01:00	0.0	0	0	0	0	1
01/09/2020 02:00	0.0	0	0	0	0	1
01/09/2020 03:00	0.0	0	0	0	0	1
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	0.9	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	74.1	0	1	0	0	0
Average/Sum#:	74.1 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.1	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	45.3	0	1	0	0	0
01/13/2020 01:00	39.8	0	1	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	1
01/13/2020 03:00	0.0	0	0	0	0	1
01/13/2020 04:00	0.0	0	0	0	0	1
01/13/2020 05:00	0.0	0	0	0	0	1
01/13/2020 06:00	0.0	0	0	0	0	1
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	85.1 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	87.4	0	1	0	0	0
01/27/2020 19:00	19.8	0	1	0	0	0
01/27/2020 20:00	51.8	0	1	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	1
01/27/2020 22:00	0.0	0	0	0	0	1
01/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	159.0 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	1
01/28/2020 01:00	0.0	0	0	0	0	1
01/28/2020 02:00	0.0	0	0	0	0	1
01/28/2020 03:00	0.0	0	0	0	0	1
01/28/2020 04:00	0.0	0	0	0	0	1
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	1.0	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	37.6	0	1	0	0	0
01/29/2020 18:00	37.1	0	1	0	0	0
01/29/2020 19:00	13.6	0	1	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	1
01/29/2020 21:00	0.0	0	0	0	0	1
01/29/2020 22:00	0.0	0	0	0	0	1
01/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.3 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	1
01/30/2020 01:00	0.0	0	0	0	0	1
01/30/2020 02:00	0.0	0	0	0	0	1
01/30/2020 03:00	0.0	0	0	0	0	1
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	0.0	0	0	0	0	1
01/31/2020 01:00	0.0	0	0	0	0	1
01/31/2020 02:00	0.0	0	0	0	0	1
01/31/2020 03:00	0.0	0	0	0	0	1
01/31/2020 04:00	0.0	0	0	0	0	1
01/31/2020 05:00	0.0	0	0	0	0	1
01/31/2020 06:00	0.0	0	0	0	0	1
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	73.4	0	1	0	0	0
Average/Sum#:	73.4 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.4	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	18.0	0	1	0	0	0
02/03/2020 01:00	58.8	0	1	0	0	0
02/03/2020 02:00	0.0	0	1	0	0	0
02/03/2020 03:00	0.0	0	0	0	0	1
02/03/2020 04:00	0.0	0	0	0	0	1
02/03/2020 05:00	0.0	0	0	0	0	1
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.8 #	0 #	3 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	67.6	0	1	0	0	0
Average/Sum#:	67.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	47.7	0	1	0	0	0
02/10/2020 01:00	36.6	0	1	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	1
02/10/2020 03:00	0.0	0	0	0	0	1
02/10/2020 04:00	0.0	0	0	0	0	1
02/10/2020 05:00	0.0	0	0	0	0	1
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	84.3 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	0.5	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.5 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.5	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	71.1	1	0	0	0	0
02/17/2020 10:00	14.8	1	0	0	0	0
02/17/2020 11:00	43.3	1	0	0	0	0
02/17/2020 12:00	48.1	1	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	1
02/17/2020 14:00	0.0	0	0	0	0	1
02/17/2020 15:00	0.0	0	0	0	0	1
02/17/2020 16:00	0.0	0	0	0	0	1
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	177.3 #	4 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	71.4	0	1	0	0	0
02/24/2020 14:00	26.4	0	1	0	0	0
02/24/2020 15:00	36.2	0	1	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	1
02/24/2020 17:00	0.0	0	0	0	0	1
02/24/2020 18:00	0.0	0	0	0	0	1
02/24/2020 19:00	0.0	0	0	0	0	1
02/24/2020 20:00	0.0	0	0	0	0	1
02/24/2020 21:00	0.0	0	0	0	0	1
02/24/2020 22:00	0.0	0	0	0	0	1
02/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	134.0 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	1
02/25/2020 01:00	0.0	0	0	0	0	1
02/25/2020 02:00	0.0	0	0	0	0	1
02/25/2020 03:00	0.0	0	0	0	0	1
02/25/2020 04:00	0.0	0	0	0	0	1
02/25/2020 05:00	0.0	0	0	0	0	1
02/25/2020 06:00	0.0	0	0	0	0	1
02/25/2020 07:00	0.0	0	0	0	0	1
02/25/2020 08:00	0.0	0	0	0	0	1
02/25/2020 09:00	0.0	0	0	0	0	1
02/25/2020 10:00	0.0	0	0	0	0	1
02/25/2020 11:00	0.0	0	0	0	0	1
02/25/2020 12:00	0.0	0	0	0	0	1
02/25/2020 13:00	0.0	0	0	0	0	1
02/25/2020 14:00	0.0	0	0	0	0	1
02/25/2020 15:00	0.0	0	0	0	0	1
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	1.1	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	16.1	0	0	1	0	0
02/26/2020 16:00	7.1	0	0	1	0	0
02/26/2020 17:00	0.0	0	0	0	0	1
02/26/2020 18:00	0.0	0	0	0	0	1
02/26/2020 19:00	0.0	0	0	0	0	1
02/26/2020 20:00	0.0	0	0	0	0	1
02/26/2020 21:00	0.0	0	0	0	0	1
02/26/2020 22:00	0.0	0	0	0	0	1
02/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	24.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	1
02/27/2020 01:00	0.0	0	0	0	0	1
02/27/2020 02:00	0.0	0	0	0	0	1
02/27/2020 03:00	0.0	0	0	0	0	1
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	37.5	1	0	0	0	0
03/03/2020 09:00	46.4	1	0	0	0	0
03/03/2020 10:00	22.7	1	0	0	0	0
03/03/2020 11:00	60.8	1	0	0	0	0
03/03/2020 12:00	14.0	1	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	1
03/03/2020 14:00	0.0	0	0	0	0	1
03/03/2020 15:00	0.0	0	0	0	0	1
03/03/2020 16:00	0.0	0	0	0	0	1
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	181.4 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	1.3	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	75.7	0	1	0	0	0
03/08/2020 21:00	20.8	0	1	0	0	0
03/08/2020 22:00	13.4	0	1	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	109.9 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	1
03/09/2020 01:00	0.0	0	0	0	0	1
03/09/2020 02:00	0.0	0	0	0	0	1
03/09/2020 03:00	0.0	0	0	0	0	1
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	1.2	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	61.9	0	1	0	0	0
03/22/2020 18:00	16.9	0	1	0	0	0
03/22/2020 19:00	24.8	0	1	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	1
03/22/2020 21:00	0.0	0	0	0	0	1
03/22/2020 22:00	0.0	0	0	0	0	1
03/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	103.6 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	1
03/23/2020 01:00	0.0	0	0	0	0	1
03/23/2020 02:00	1.4	0	0	0	1	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	37.8	0	1	0	0	0
03/23/2020 18:00	19.4	0	1	0	0	0
03/23/2020 19:00	33.0	0	1	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	1
03/23/2020 21:00	0.0	0	0	0	0	1
03/23/2020 22:00	0.0	0	0	0	0	1
03/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.6 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	1
03/24/2020 01:00	0.0	0	0	0	0	1
03/24/2020 02:00	0.0	0	0	0	0	1
03/24/2020 03:00	0.0	0	0	0	0	1
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	80.0	0	1	0	0	0
03/27/2020 18:00	17.0	0	1	0	0	0
03/27/2020 19:00	34.1	0	1	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	1
03/27/2020 21:00	0.0	0	0	0	0	1
03/27/2020 22:00	0.0	0	0	0	0	1
03/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	131.1 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	0.0	0	0	0	0	1
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:07 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	1.2	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	18.9	0	1	0	0	0
03/31/2020 19:00	37.1	0	1	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	1
03/31/2020 21:00	0.0	0	0	0	0	1
03/31/2020 22:00	0.0	0	0	0	0	1
03/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	57.2 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	125.4	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	125.4 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	125.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	2,849.7	0	1	0	0	0
01/02/2020 02:00	6,813.7	0	1	0	0	0
01/02/2020 03:00	6,587.9	0	1	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	1
01/02/2020 05:00	0.0	0	0	0	0	1
01/02/2020 06:00	0.0	0	0	0	0	1
01/02/2020 07:00	0.0	0	0	0	0	1
01/02/2020 08:00	0.0	0	0	0	0	1
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,251.3 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,813.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	94.3	0	0	0	1	0
Average/Sum#:	94.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	94.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	2,014.9	0	1	0	0	0
01/06/2020 05:00	5,852.7	0	1	0	0	0
01/06/2020 06:00	7,744.2	0	1	0	0	0
01/06/2020 07:00	0.0	0	0	0	0	1
01/06/2020 08:00	0.0	0	0	0	0	1
01/06/2020 09:00	0.0	0	0	0	0	1
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,611.8 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,744.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	71.3	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	71.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	3,176.5	0	1	0	0	0
01/08/2020 22:00	5,153.0	0	1	0	0	0
01/08/2020 23:00	6,139.8	0	1	0	0	0
Average/Sum#:	14,469.3 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,139.8	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	1
01/09/2020 01:00	0.0	0	0	0	0	1
01/09/2020 02:00	0.0	0	0	0	0	1
01/09/2020 03:00	0.0	0	0	0	0	1
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	67.7	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	67.7 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	1,933.0	0	1	0	0	0
Average/Sum#:	1,933.0 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1,933.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	6,437.4	0	1	0	0	0
01/13/2020 01:00	6,817.7	0	1	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	1
01/13/2020 03:00	0.0	0	0	0	0	1
01/13/2020 04:00	0.0	0	0	0	0	1
01/13/2020 05:00	0.0	0	0	0	0	1
01/13/2020 06:00	0.0	0	0	0	0	1
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,255.1 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,817.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	141.7	0	0	0	1	0
Average/Sum#:	141.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	141.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	3,706.2	0	1	0	0	0
01/27/2020 19:00	5,201.2	0	1	0	0	0
01/27/2020 20:00	7,191.9	0	1	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	1
01/27/2020 22:00	0.0	0	0	0	0	1
01/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,099.3 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,191.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	1
01/28/2020 01:00	0.0	0	0	0	0	1
01/28/2020 02:00	0.0	0	0	0	0	1
01/28/2020 03:00	0.0	0	0	0	0	1
01/28/2020 04:00	0.0	0	0	0	0	1
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	141.7	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	141.7 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	141.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	3,135.8	0	1	0	0	0
01/29/2020 18:00	6,392.9	0	1	0	0	0
01/29/2020 19:00	4,555.6	0	1	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	1
01/29/2020 21:00	0.0	0	0	0	0	1
01/29/2020 22:00	0.0	0	0	0	0	1
01/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,084.3 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,392.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	1
01/30/2020 01:00	0.0	0	0	0	0	1
01/30/2020 02:00	0.0	0	0	0	0	1
01/30/2020 03:00	0.0	0	0	0	0	1
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	0.0	0	0	0	0	1
01/31/2020 01:00	0.0	0	0	0	0	1
01/31/2020 02:00	0.0	0	0	0	0	1
01/31/2020 03:00	0.0	0	0	0	0	1
01/31/2020 04:00	0.0	0	0	0	0	1
01/31/2020 05:00	0.0	0	0	0	0	1
01/31/2020 06:00	0.0	0	0	0	0	1
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	112.8	0	0	0	1	0
Average/Sum#:	112.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	112.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	3,638.3	0	1	0	0	0
Average/Sum#:	3,638.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,638.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	5,140.1	0	1	0	0	0
02/03/2020 01:00	6,958.7	0	1	0	0	0
02/03/2020 02:00	1,206.4	0	1	0	0	0
02/03/2020 03:00	0.0	0	0	0	0	1
02/03/2020 04:00	0.0	0	0	0	0	1
02/03/2020 05:00	0.0	0	0	0	0	1
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,305.2 #	0 #	3 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,958.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	110.7	0	0	0	1	0
Average/Sum#:	110.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	110.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	3,204.6	0	1	0	0	0
Average/Sum#:	3,204.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,204.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	6,871.4	0	1	0	0	0
02/10/2020 01:00	6,697.9	0	1	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	1
02/10/2020 03:00	0.0	0	0	0	0	1
02/10/2020 04:00	0.0	0	0	0	0	1
02/10/2020 05:00	0.0	0	0	0	0	1
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,569.3 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,871.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	73.7	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	73.7 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.7	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	3,762.6	1	0	0	0	0
02/17/2020 10:00	5,141.3	1	0	0	0	0
02/17/2020 11:00	6,429.6	1	0	0	0	0
02/17/2020 12:00	6,611.8	1	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	1
02/17/2020 14:00	0.0	0	0	0	0	1
02/17/2020 15:00	0.0	0	0	0	0	1
02/17/2020 16:00	0.0	0	0	0	0	1
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	21,945.3 #	4 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,611.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	71.4	0	0	0	1	0
Average/Sum#:	71.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	3,322.3	0	1	0	0	0
02/24/2020 14:00	6,090.8	0	1	0	0	0
02/24/2020 15:00	7,440.2	0	1	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	1
02/24/2020 17:00	0.0	0	0	0	0	1
02/24/2020 18:00	0.0	0	0	0	0	1
02/24/2020 19:00	0.0	0	0	0	0	1
02/24/2020 20:00	0.0	0	0	0	0	1
02/24/2020 21:00	0.0	0	0	0	0	1
02/24/2020 22:00	0.0	0	0	0	0	1
02/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,853.3 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,440.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	1
02/25/2020 01:00	0.0	0	0	0	0	1
02/25/2020 02:00	0.0	0	0	0	0	1
02/25/2020 03:00	0.0	0	0	0	0	1
02/25/2020 04:00	0.0	0	0	0	0	1
02/25/2020 05:00	0.0	0	0	0	0	1
02/25/2020 06:00	0.0	0	0	0	0	1
02/25/2020 07:00	0.0	0	0	0	0	1
02/25/2020 08:00	0.0	0	0	0	0	1
02/25/2020 09:00	0.0	0	0	0	0	1
02/25/2020 10:00	0.0	0	0	0	0	1
02/25/2020 11:00	0.0	0	0	0	0	1
02/25/2020 12:00	0.0	0	0	0	0	1
02/25/2020 13:00	0.0	0	0	0	0	1
02/25/2020 14:00	0.0	0	0	0	0	1
02/25/2020 15:00	0.0	0	0	0	0	1
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	139.4	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	2,931.0	0	0	1	0	0
02/26/2020 16:00	3,674.5	0	0	1	0	0
02/26/2020 17:00	0.0	0	0	0	0	1
02/26/2020 18:00	0.0	0	0	0	0	1
02/26/2020 19:00	0.0	0	0	0	0	1
02/26/2020 20:00	0.0	0	0	0	0	1
02/26/2020 21:00	0.0	0	0	0	0	1
02/26/2020 22:00	0.0	0	0	0	0	1
02/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,744.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,674.5	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	1
02/27/2020 01:00	0.0	0	0	0	0	1
02/27/2020 02:00	0.0	0	0	0	0	1
02/27/2020 03:00	0.0	0	0	0	0	1
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	133.3	0	0	0	1	0
Average/Sum#:	133.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	133.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	510.3	1	0	0	0	0
03/03/2020 09:00	5,123.2	1	0	0	0	0
03/03/2020 10:00	5,570.1	1	0	0	0	0
03/03/2020 11:00	7,025.4	1	0	0	0	0
03/03/2020 12:00	4,743.6	1	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	1
03/03/2020 14:00	0.0	0	0	0	0	1
03/03/2020 15:00	0.0	0	0	0	0	1
03/03/2020 16:00	0.0	0	0	0	0	1
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	22,972.6 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,025.4	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	95.4	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	95.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	95.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	3,267.9	0	1	0	0	0
03/08/2020 21:00	5,150.9	0	1	0	0	0
03/08/2020 22:00	4,394.8	0	1	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	12,813.6 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,150.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	1
03/09/2020 01:00	0.0	0	0	0	0	1
03/09/2020 02:00	0.0	0	0	0	0	1
03/09/2020 03:00	0.0	0	0	0	0	1
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	124.6	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	124.6 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	124.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	3,315.7	0	1	0	0	0
03/22/2020 18:00	5,076.7	0	1	0	0	0
03/22/2020 19:00	6,252.9	0	1	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	1
03/22/2020 21:00	0.0	0	0	0	0	1
03/22/2020 22:00	0.0	0	0	0	0	1
03/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	14,645.3 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,252.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	1
03/23/2020 01:00	0.0	0	0	0	0	1
03/23/2020 02:00	95.0	0	0	0	1	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	3,147.2	0	1	0	0	0
03/23/2020 18:00	5,075.3	0	1	0	0	0
03/23/2020 19:00	6,725.6	0	1	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	1
03/23/2020 21:00	0.0	0	0	0	0	1
03/23/2020 22:00	0.0	0	0	0	0	1
03/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	15,043.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,725.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	1
03/24/2020 01:00	0.0	0	0	0	0	1
03/24/2020 02:00	0.0	0	0	0	0	1
03/24/2020 03:00	0.0	0	0	0	0	1
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	132.4	0	0	0	1	0
Average/Sum#:	132.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	132.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	4,386.8	0	1	0	0	0
03/27/2020 18:00	5,097.0	0	1	0	0	0
03/27/2020 19:00	6,677.0	0	1	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	1
03/27/2020 21:00	0.0	0	0	0	0	1
03/27/2020 22:00	0.0	0	0	0	0	1
03/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	16,160.8 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,677.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	0.0	0	0	0	0	1
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	107.9	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	3,959.1	0	1	0	0	0
03/31/2020 19:00	6,837.5	0	1	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	1
03/31/2020 21:00	0.0	0	0	0	0	1
03/31/2020 22:00	0.0	0	0	0	0	1
03/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,904.5 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,837.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/01/2020 00:00	0.0	0	0	0	0	1
01/01/2020 01:00	0.0	0	0	0	0	1
01/01/2020 02:00	1.5	0	0	0	1	0
01/01/2020 03:00	0.0	0	0	0	0	0
01/01/2020 04:00	0.0	0	0	0	0	0
01/01/2020 05:00	0.0	0	0	0	0	0
01/01/2020 06:00	0.0	0	0	0	0	0
01/01/2020 07:00	0.0	0	0	0	0	0
01/01/2020 08:00	0.0	0	0	0	0	0
01/01/2020 09:00	0.0	0	0	0	0	0
01/01/2020 10:00	0.0	0	0	0	0	0
01/01/2020 11:00	0.0	0	0	0	0	0
01/01/2020 12:00	0.0	0	0	0	0	0
01/01/2020 13:00	0.0	0	0	0	0	0
01/01/2020 14:00	0.0	0	0	0	0	0
01/01/2020 15:00	0.0	0	0	0	0	0
01/01/2020 16:00	0.0	0	0	0	0	0
01/01/2020 17:00	0.0	0	0	0	0	0
01/01/2020 18:00	0.0	0	0	0	0	0
01/01/2020 19:00	0.0	0	0	0	0	0
01/01/2020 20:00	0.0	0	0	0	0	0
01/01/2020 21:00	0.0	0	0	0	0	0
01/01/2020 22:00	0.0	0	0	0	0	0
01/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	2 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/02/2020 00:00	0.0	0	0	0	0	0
01/02/2020 01:00	52.2	0	1	0	0	0
01/02/2020 02:00	54.6	0	1	0	0	0
01/02/2020 03:00	37.1	0	1	0	0	0
01/02/2020 04:00	0.0	0	0	0	0	1
01/02/2020 05:00	0.0	0	0	0	0	1
01/02/2020 06:00	0.0	0	0	0	0	1
01/02/2020 07:00	0.0	0	0	0	0	1
01/02/2020 08:00	0.0	0	0	0	0	1
01/02/2020 09:00	0.0	0	0	0	0	1
01/02/2020 10:00	0.0	0	0	0	0	1
01/02/2020 11:00	0.0	0	0	0	0	1
01/02/2020 12:00	0.0	0	0	0	0	1
01/02/2020 13:00	0.0	0	0	0	0	1
01/02/2020 14:00	0.0	0	0	0	0	1
01/02/2020 15:00	0.0	0	0	0	0	1
01/02/2020 16:00	0.0	0	0	0	0	1
01/02/2020 17:00	0.0	0	0	0	0	1
01/02/2020 18:00	0.0	0	0	0	0	1
01/02/2020 19:00	0.0	0	0	0	0	1
01/02/2020 20:00	0.0	0	0	0	0	1
01/02/2020 21:00	0.0	0	0	0	0	1
01/02/2020 22:00	0.0	0	0	0	0	1
01/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	143.9 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/03/2020 00:00	0.0	0	0	0	0	1
01/03/2020 01:00	0.0	0	0	0	0	1
01/03/2020 02:00	0.0	0	0	0	0	1
01/03/2020 03:00	0.0	0	0	0	0	1
01/03/2020 04:00	0.0	0	0	0	0	1
01/03/2020 05:00	0.0	0	0	0	0	1
01/03/2020 06:00	0.0	0	0	0	0	1
01/03/2020 07:00	0.0	0	0	0	0	1
01/03/2020 08:00	0.0	0	0	0	0	1
01/03/2020 09:00	0.0	0	0	0	0	1
01/03/2020 10:00	0.0	0	0	0	0	1
01/03/2020 11:00	0.0	0	0	0	0	1
01/03/2020 12:00	0.0	0	0	0	0	1
01/03/2020 13:00	0.0	0	0	0	0	1
01/03/2020 14:00	0.0	0	0	0	0	1
01/03/2020 15:00	0.0	0	0	0	0	1
01/03/2020 16:00	0.0	0	0	0	0	1
01/03/2020 17:00	0.0	0	0	0	0	1
01/03/2020 18:00	0.0	0	0	0	0	1
01/03/2020 19:00	0.0	0	0	0	0	1
01/03/2020 20:00	0.0	0	0	0	0	1
01/03/2020 21:00	0.0	0	0	0	0	1
01/03/2020 22:00	0.0	0	0	0	0	1
01/03/2020 23:00	0.9	0	0	0	1	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/04/2020 00:00	0.0	0	0	0	1	0
01/04/2020 01:00	0.0	0	0	0	0	0
01/04/2020 02:00	0.0	0	0	0	0	0
01/04/2020 03:00	0.0	0	0	0	0	0
01/04/2020 04:00	0.0	0	0	0	0	0
01/04/2020 05:00	0.0	0	0	0	0	0
01/04/2020 06:00	0.0	0	0	0	0	0
01/04/2020 07:00	0.0	0	0	0	0	0
01/04/2020 08:00	0.0	0	0	0	0	0
01/04/2020 09:00	0.0	0	0	0	0	0
01/04/2020 10:00	0.0	0	0	0	0	0
01/04/2020 11:00	0.0	0	0	0	0	0
01/04/2020 12:00	0.0	0	0	0	0	0
01/04/2020 13:00	0.0	0	0	0	0	0
01/04/2020 14:00	0.0	0	0	0	0	0
01/04/2020 15:00	0.0	0	0	0	0	0
01/04/2020 16:00	0.0	0	0	0	0	0
01/04/2020 17:00	0.0	0	0	0	0	0
01/04/2020 18:00	0.0	0	0	0	0	0
01/04/2020 19:00	0.0	0	0	0	0	0
01/04/2020 20:00	0.0	0	0	0	0	0
01/04/2020 21:00	0.0	0	0	0	0	0
01/04/2020 22:00	0.0	0	0	0	0	0
01/04/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/05/2020 00:00	0.0	0	0	0	0	0
01/05/2020 01:00	0.0	0	0	0	0	0
01/05/2020 02:00	0.0	0	0	0	0	0
01/05/2020 03:00	0.0	0	0	0	0	0
01/05/2020 04:00	0.0	0	0	0	0	0
01/05/2020 05:00	0.0	0	0	0	0	0
01/05/2020 06:00	0.0	0	0	0	0	0
01/05/2020 07:00	0.0	0	0	0	0	0
01/05/2020 08:00	0.0	0	0	0	0	0
01/05/2020 09:00	0.0	0	0	0	0	0
01/05/2020 10:00	0.0	0	0	0	0	0
01/05/2020 11:00	0.0	0	0	0	0	0
01/05/2020 12:00	0.0	0	0	0	0	0
01/05/2020 13:00	0.0	0	0	0	0	0
01/05/2020 14:00	0.0	0	0	0	0	0
01/05/2020 15:00	0.0	0	0	0	0	0
01/05/2020 16:00	0.0	0	0	0	0	0
01/05/2020 17:00	0.0	0	0	0	0	0
01/05/2020 18:00	0.0	0	0	0	0	0
01/05/2020 19:00	0.0	0	0	0	0	0
01/05/2020 20:00	0.0	0	0	0	0	0
01/05/2020 21:00	0.0	0	0	0	0	0
01/05/2020 22:00	0.0	0	0	0	0	0
01/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/06/2020 00:00	0.0	0	0	0	0	0
01/06/2020 01:00	0.0	0	0	0	0	0
01/06/2020 02:00	0.0	0	0	0	0	0
01/06/2020 03:00	0.0	0	0	0	0	0
01/06/2020 04:00	35.7	0	1	0	0	0
01/06/2020 05:00	78.2	0	1	0	0	0
01/06/2020 06:00	55.6	0	1	0	0	0
01/06/2020 07:00	0.0	0	0	0	0	1
01/06/2020 08:00	0.0	0	0	0	0	1
01/06/2020 09:00	0.0	0	0	0	0	1
01/06/2020 10:00	0.0	0	0	0	0	1
01/06/2020 11:00	0.0	0	0	0	0	1
01/06/2020 12:00	0.0	0	0	0	0	1
01/06/2020 13:00	0.0	0	0	0	0	1
01/06/2020 14:00	0.0	0	0	0	0	1
01/06/2020 15:00	0.0	0	0	0	0	1
01/06/2020 16:00	0.0	0	0	0	0	1
01/06/2020 17:00	0.0	0	0	0	0	1
01/06/2020 18:00	0.0	0	0	0	0	1
01/06/2020 19:00	0.0	0	0	0	0	1
01/06/2020 20:00	0.0	0	0	0	0	1
01/06/2020 21:00	0.0	0	0	0	0	1
01/06/2020 22:00	0.0	0	0	0	0	1
01/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	169.5 #	0 #	3 #	0 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/07/2020 00:00	0.0	0	0	0	0	1
01/07/2020 01:00	0.0	0	0	0	0	1
01/07/2020 02:00	0.0	0	0	0	0	1
01/07/2020 03:00	0.0	0	0	0	0	1
01/07/2020 04:00	0.0	0	0	0	0	1
01/07/2020 05:00	0.0	0	0	0	0	1
01/07/2020 06:00	0.0	0	0	0	0	1
01/07/2020 07:00	0.0	0	0	0	0	1
01/07/2020 08:00	0.0	0	0	0	0	1
01/07/2020 09:00	0.0	0	0	0	0	1
01/07/2020 10:00	0.0	0	0	0	0	1
01/07/2020 11:00	0.0	0	0	0	0	1
01/07/2020 12:00	0.0	0	0	0	0	1
01/07/2020 13:00	0.0	0	0	0	0	1
01/07/2020 14:00	0.0	0	0	0	0	1
01/07/2020 15:00	0.0	0	0	0	0	1
01/07/2020 16:00	0.0	0	0	0	0	1
01/07/2020 17:00	0.0	0	0	0	0	1
01/07/2020 18:00	0.0	0	0	0	0	1
01/07/2020 19:00	0.0	0	0	0	0	1
01/07/2020 20:00	0.0	0	0	0	0	1
01/07/2020 21:00	0.0	0	0	0	0	1
01/07/2020 22:00	1.1	0	0	0	1	0
01/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/08/2020 00:00	0.0	0	0	0	0	0
01/08/2020 01:00	0.0	0	0	0	0	0
01/08/2020 02:00	0.0	0	0	0	0	0
01/08/2020 03:00	0.0	0	0	0	0	0
01/08/2020 04:00	0.0	0	0	0	0	0
01/08/2020 05:00	0.0	0	0	0	0	0
01/08/2020 06:00	0.0	0	0	0	0	0
01/08/2020 07:00	0.0	0	0	0	0	0
01/08/2020 08:00	0.0	0	0	0	0	0
01/08/2020 09:00	0.0	0	0	0	0	0
01/08/2020 10:00	0.0	0	0	0	0	0
01/08/2020 11:00	0.0	0	0	0	0	0
01/08/2020 12:00	0.0	0	0	0	0	0
01/08/2020 13:00	0.0	0	0	0	0	0
01/08/2020 14:00	0.0	0	0	0	0	0
01/08/2020 15:00	0.0	0	0	0	0	0
01/08/2020 16:00	0.0	0	0	0	0	0
01/08/2020 17:00	0.0	0	0	0	0	0
01/08/2020 18:00	0.0	0	0	0	0	0
01/08/2020 19:00	0.0	0	0	0	0	0
01/08/2020 20:00	0.0	0	0	0	0	0
01/08/2020 21:00	57.8	0	1	0	0	0
01/08/2020 22:00	31.3	0	1	0	0	0
01/08/2020 23:00	21.6	0	1	0	0	0
Average/Sum#:	110.7 #	0 #	3 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.8	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/09/2020 00:00	0.0	0	0	0	0	1
01/09/2020 01:00	0.0	0	0	0	0	1
01/09/2020 02:00	0.0	0	0	0	0	1
01/09/2020 03:00	0.0	0	0	0	0	1
01/09/2020 04:00	0.0	0	0	0	0	1
01/09/2020 05:00	0.0	0	0	0	0	1
01/09/2020 06:00	0.0	0	0	0	0	1
01/09/2020 07:00	0.0	0	0	0	0	1
01/09/2020 08:00	0.0	0	0	0	0	1
01/09/2020 09:00	0.0	0	0	0	0	1
01/09/2020 10:00	0.0	0	0	0	0	1
01/09/2020 11:00	0.0	0	0	0	0	1
01/09/2020 12:00	0.0	0	0	0	0	1
01/09/2020 13:00	0.0	0	0	0	0	1
01/09/2020 14:00	0.0	0	0	0	0	1
01/09/2020 15:00	0.0	0	0	0	0	1
01/09/2020 16:00	0.0	0	0	0	0	1
01/09/2020 17:00	0.0	0	0	0	0	1
01/09/2020 18:00	0.0	0	0	0	0	1
01/09/2020 19:00	0.0	0	0	0	0	1
01/09/2020 20:00	0.0	0	0	0	0	1
01/09/2020 21:00	0.0	0	0	0	0	1
01/09/2020 22:00	0.0	0	0	0	0	1
01/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/10/2020 00:00	0.0	0	0	0	0	1
01/10/2020 01:00	0.0	0	0	0	0	1
01/10/2020 02:00	0.0	0	0	0	0	1
01/10/2020 03:00	0.0	0	0	0	0	1
01/10/2020 04:00	0.0	0	0	0	0	1
01/10/2020 05:00	0.0	0	0	0	0	1
01/10/2020 06:00	0.0	0	0	0	0	1
01/10/2020 07:00	0.0	0	0	0	0	1
01/10/2020 08:00	0.0	0	0	0	0	1
01/10/2020 09:00	0.0	0	0	0	0	1
01/10/2020 10:00	0.0	0	0	0	0	1
01/10/2020 11:00	0.0	0	0	0	0	1
01/10/2020 12:00	0.0	0	0	0	0	1
01/10/2020 13:00	0.0	0	0	0	0	1
01/10/2020 14:00	0.0	0	0	0	0	1
01/10/2020 15:00	0.0	0	0	0	0	1
01/10/2020 16:00	0.0	0	0	0	0	1
01/10/2020 17:00	0.0	0	0	0	0	1
01/10/2020 18:00	0.0	0	0	0	0	1
01/10/2020 19:00	0.0	0	0	0	0	1
01/10/2020 20:00	0.0	0	0	0	0	1
01/10/2020 21:00	0.0	0	0	0	0	1
01/10/2020 22:00	0.0	0	0	0	0	1
01/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/11/2020 00:00	0.0	0	0	0	0	1
01/11/2020 01:00	0.0	0	0	0	0	1
01/11/2020 02:00	0.0	0	0	0	0	1
01/11/2020 03:00	0.0	0	0	0	0	1
01/11/2020 04:00	0.0	0	0	0	0	1
01/11/2020 05:00	0.0	0	0	0	0	1
01/11/2020 06:00	0.0	0	0	0	0	1
01/11/2020 07:00	0.0	0	0	0	0	1
01/11/2020 08:00	1.0	0	0	0	1	0
01/11/2020 09:00	0.0	0	0	0	0	0
01/11/2020 10:00	0.0	0	0	0	0	0
01/11/2020 11:00	0.0	0	0	0	0	0
01/11/2020 12:00	0.0	0	0	0	0	0
01/11/2020 13:00	0.0	0	0	0	0	0
01/11/2020 14:00	0.0	0	0	0	0	0
01/11/2020 15:00	0.0	0	0	0	0	0
01/11/2020 16:00	0.0	0	0	0	0	0
01/11/2020 17:00	0.0	0	0	0	0	0
01/11/2020 18:00	0.0	0	0	0	0	0
01/11/2020 19:00	0.0	0	0	0	0	0
01/11/2020 20:00	0.0	0	0	0	0	0
01/11/2020 21:00	0.0	0	0	0	0	0
01/11/2020 22:00	0.0	0	0	0	0	0
01/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.0 #	0 #	0 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.0	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/12/2020 00:00	0.0	0	0	0	0	0
01/12/2020 01:00	0.0	0	0	0	0	0
01/12/2020 02:00	0.0	0	0	0	0	0
01/12/2020 03:00	0.0	0	0	0	0	0
01/12/2020 04:00	0.0	0	0	0	0	0
01/12/2020 05:00	0.0	0	0	0	0	0
01/12/2020 06:00	0.0	0	0	0	0	0
01/12/2020 07:00	0.0	0	0	0	0	0
01/12/2020 08:00	0.0	0	0	0	0	0
01/12/2020 09:00	0.0	0	0	0	0	0
01/12/2020 10:00	0.0	0	0	0	0	0
01/12/2020 11:00	0.0	0	0	0	0	0
01/12/2020 12:00	0.0	0	0	0	0	0
01/12/2020 13:00	0.0	0	0	0	0	0
01/12/2020 14:00	0.0	0	0	0	0	0
01/12/2020 15:00	0.0	0	0	0	0	0
01/12/2020 16:00	0.0	0	0	0	0	0
01/12/2020 17:00	0.0	0	0	0	0	0
01/12/2020 18:00	0.0	0	0	0	0	0
01/12/2020 19:00	0.0	0	0	0	0	0
01/12/2020 20:00	0.0	0	0	0	0	0
01/12/2020 21:00	0.0	0	0	0	0	0
01/12/2020 22:00	0.0	0	0	0	0	0
01/12/2020 23:00	32.6	0	1	0	0	0
Average/Sum#:	32.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/13/2020 00:00	68.8	0	1	0	0	0
01/13/2020 01:00	34.0	0	1	0	0	0
01/13/2020 02:00	0.0	0	0	0	0	1
01/13/2020 03:00	0.0	0	0	0	0	1
01/13/2020 04:00	0.0	0	0	0	0	1
01/13/2020 05:00	0.0	0	0	0	0	1
01/13/2020 06:00	0.0	0	0	0	0	1
01/13/2020 07:00	0.0	0	0	0	0	1
01/13/2020 08:00	0.0	0	0	0	0	1
01/13/2020 09:00	0.0	0	0	0	0	1
01/13/2020 10:00	0.0	0	0	0	0	1
01/13/2020 11:00	0.0	0	0	0	0	1
01/13/2020 12:00	0.0	0	0	0	0	1
01/13/2020 13:00	0.0	0	0	0	0	1
01/13/2020 14:00	0.0	0	0	0	0	1
01/13/2020 15:00	0.0	0	0	0	0	1
01/13/2020 16:00	0.0	0	0	0	0	1
01/13/2020 17:00	0.0	0	0	0	0	1
01/13/2020 18:00	0.0	0	0	0	0	1
01/13/2020 19:00	0.0	0	0	0	0	1
01/13/2020 20:00	0.0	0	0	0	0	1
01/13/2020 21:00	0.0	0	0	0	0	1
01/13/2020 22:00	0.0	0	0	0	0	1
01/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	102.8 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/14/2020 00:00	0.0	0	0	0	0	1
01/14/2020 01:00	0.0	0	0	0	0	1
01/14/2020 02:00	0.0	0	0	0	0	1
01/14/2020 03:00	0.0	0	0	0	0	1
01/14/2020 04:00	0.0	0	0	0	0	1
01/14/2020 05:00	0.0	0	0	0	0	1
01/14/2020 06:00	0.0	0	0	0	0	1
01/14/2020 07:00	0.0	0	0	0	0	1
01/14/2020 08:00	0.0	0	0	0	0	1
01/14/2020 09:00	0.0	0	0	0	0	1
01/14/2020 10:00	0.0	0	0	0	0	1
01/14/2020 11:00	0.0	0	0	0	0	1
01/14/2020 12:00	0.0	0	0	0	0	1
01/14/2020 13:00	0.0	0	0	0	0	1
01/14/2020 14:00	0.0	0	0	0	0	1
01/14/2020 15:00	0.0	0	0	0	0	1
01/14/2020 16:00	0.0	0	0	0	0	1
01/14/2020 17:00	0.0	0	0	0	0	1
01/14/2020 18:00	0.0	0	0	0	0	1
01/14/2020 19:00	0.0	0	0	0	0	1
01/14/2020 20:00	0.0	0	0	0	0	1
01/14/2020 21:00	0.0	0	0	0	0	1
01/14/2020 22:00	0.0	0	0	0	0	1
01/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/15/2020 00:00	0.0	0	0	0	0	1
01/15/2020 01:00	0.0	0	0	0	0	1
01/15/2020 02:00	0.0	0	0	0	0	1
01/15/2020 03:00	0.0	0	0	0	0	1
01/15/2020 04:00	0.0	0	0	0	0	1
01/15/2020 05:00	0.0	0	0	0	0	1
01/15/2020 06:00	0.0	0	0	0	0	1
01/15/2020 07:00	0.0	0	0	0	0	1
01/15/2020 08:00	0.0	0	0	0	0	1
01/15/2020 09:00	0.0	0	0	0	0	1
01/15/2020 10:00	0.0	0	0	0	0	1
01/15/2020 11:00	0.0	0	0	0	0	1
01/15/2020 12:00	0.0	0	0	0	0	1
01/15/2020 13:00	0.0	0	0	0	0	1
01/15/2020 14:00	0.0	0	0	0	0	1
01/15/2020 15:00	0.0	0	0	0	0	1
01/15/2020 16:00	0.0	0	0	0	0	1
01/15/2020 17:00	0.0	0	0	0	0	1
01/15/2020 18:00	0.0	0	0	0	0	1
01/15/2020 19:00	0.0	0	0	0	0	1
01/15/2020 20:00	0.0	0	0	0	0	1
01/15/2020 21:00	0.0	0	0	0	0	1
01/15/2020 22:00	0.0	0	0	0	0	1
01/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/16/2020 00:00	0.0	0	0	0	0	1
01/16/2020 01:00	0.0	0	0	0	0	1
01/16/2020 02:00	0.0	0	0	0	0	1
01/16/2020 03:00	0.0	0	0	0	0	1
01/16/2020 04:00	0.0	0	0	0	0	1
01/16/2020 05:00	0.0	0	0	0	0	1
01/16/2020 06:00	0.0	0	0	0	0	1
01/16/2020 07:00	0.0	0	0	0	0	1
01/16/2020 08:00	0.0	0	0	0	0	1
01/16/2020 09:00	0.0	0	0	0	0	1
01/16/2020 10:00	0.0	0	0	0	0	1
01/16/2020 11:00	0.0	0	0	0	0	1
01/16/2020 12:00	0.0	0	0	0	0	1
01/16/2020 13:00	0.0	0	0	0	0	1
01/16/2020 14:00	0.0	0	0	0	0	1
01/16/2020 15:00	0.0	0	0	0	0	1
01/16/2020 16:00	0.0	0	0	0	0	1
01/16/2020 17:00	0.0	0	0	0	0	1
01/16/2020 18:00	0.0	0	0	0	0	1
01/16/2020 19:00	0.0	0	0	0	0	1
01/16/2020 20:00	0.0	0	0	0	0	1
01/16/2020 21:00	0.0	0	0	0	0	1
01/16/2020 22:00	0.0	0	0	0	0	1
01/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/17/2020 00:00	0.0	0	0	0	0	1
01/17/2020 01:00	0.0	0	0	0	0	1
01/17/2020 02:00	0.0	0	0	0	0	1
01/17/2020 03:00	0.0	0	0	0	0	1
01/17/2020 04:00	0.0	0	0	0	0	1
01/17/2020 05:00	0.0	0	0	0	0	1
01/17/2020 06:00	0.0	0	0	0	0	1
01/17/2020 07:00	0.0	0	0	0	0	1
01/17/2020 08:00	0.0	0	0	0	0	1
01/17/2020 09:00	0.0	0	0	0	0	1
01/17/2020 10:00	0.0	0	0	0	0	1
01/17/2020 11:00	0.0	0	0	0	0	1
01/17/2020 12:00	0.0	0	0	0	0	1
01/17/2020 13:00	0.0	0	0	0	0	1
01/17/2020 14:00	0.0	0	0	0	0	1
01/17/2020 15:00	0.0	0	0	0	0	1
01/17/2020 16:00	0.0	0	0	0	0	1
01/17/2020 17:00	0.0	0	0	0	0	1
01/17/2020 18:00	0.0	0	0	0	0	1
01/17/2020 19:00	0.0	0	0	0	0	1
01/17/2020 20:00	0.0	0	0	0	0	1
01/17/2020 21:00	0.0	0	0	0	0	1
01/17/2020 22:00	0.0	0	0	0	0	1
01/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/18/2020 00:00	0.0	0	0	0	0	1
01/18/2020 01:00	0.0	0	0	0	0	1
01/18/2020 02:00	0.0	0	0	0	0	1
01/18/2020 03:00	0.0	0	0	0	0	1
01/18/2020 04:00	0.0	0	0	0	0	1
01/18/2020 05:00	0.0	0	0	0	0	1
01/18/2020 06:00	0.0	0	0	0	0	1
01/18/2020 07:00	0.0	0	0	0	0	1
01/18/2020 08:00	0.0	0	0	0	0	1
01/18/2020 09:00	0.0	0	0	0	0	1
01/18/2020 10:00	0.0	0	0	0	0	1
01/18/2020 11:00	0.0	0	0	0	0	1
01/18/2020 12:00	0.0	0	0	0	0	1
01/18/2020 13:00	0.0	0	0	0	0	1
01/18/2020 14:00	0.0	0	0	0	0	1
01/18/2020 15:00	0.0	0	0	0	0	1
01/18/2020 16:00	0.0	0	0	0	0	1
01/18/2020 17:00	0.0	0	0	0	0	1
01/18/2020 18:00	0.0	0	0	0	0	1
01/18/2020 19:00	0.0	0	0	0	0	1
01/18/2020 20:00	0.0	0	0	0	0	1
01/18/2020 21:00	0.0	0	0	0	0	1
01/18/2020 22:00	0.0	0	0	0	0	1
01/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/19/2020 00:00	0.0	0	0	0	0	1
01/19/2020 01:00	0.0	0	0	0	0	1
01/19/2020 02:00	0.0	0	0	0	0	1
01/19/2020 03:00	0.0	0	0	0	0	1
01/19/2020 04:00	0.0	0	0	0	0	1
01/19/2020 05:00	0.0	0	0	0	0	1
01/19/2020 06:00	0.0	0	0	0	0	1
01/19/2020 07:00	0.0	0	0	0	0	1
01/19/2020 08:00	0.0	0	0	0	0	1
01/19/2020 09:00	0.0	0	0	0	0	1
01/19/2020 10:00	0.0	0	0	0	0	1
01/19/2020 11:00	0.0	0	0	0	0	1
01/19/2020 12:00	0.0	0	0	0	0	1
01/19/2020 13:00	0.0	0	0	0	0	1
01/19/2020 14:00	0.0	0	0	0	0	1
01/19/2020 15:00	0.0	0	0	0	0	1
01/19/2020 16:00	0.0	0	0	0	0	1
01/19/2020 17:00	0.0	0	0	0	0	1
01/19/2020 18:00	0.0	0	0	0	0	1
01/19/2020 19:00	0.0	0	0	0	0	1
01/19/2020 20:00	0.0	0	0	0	0	1
01/19/2020 21:00	0.0	0	0	0	0	1
01/19/2020 22:00	0.0	0	0	0	0	1
01/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/20/2020 00:00	0.0	0	0	0	0	1
01/20/2020 01:00	0.0	0	0	0	0	1
01/20/2020 02:00	0.0	0	0	0	0	1
01/20/2020 03:00	0.0	0	0	0	0	1
01/20/2020 04:00	0.0	0	0	0	0	1
01/20/2020 05:00	0.0	0	0	0	0	1
01/20/2020 06:00	0.0	0	0	0	0	1
01/20/2020 07:00	0.0	0	0	0	0	1
01/20/2020 08:00	0.0	0	0	0	0	1
01/20/2020 09:00	0.0	0	0	0	0	1
01/20/2020 10:00	0.0	0	0	0	0	1
01/20/2020 11:00	0.0	0	0	0	0	1
01/20/2020 12:00	0.0	0	0	0	0	1
01/20/2020 13:00	0.0	0	0	0	0	1
01/20/2020 14:00	0.0	0	0	0	0	1
01/20/2020 15:00	0.0	0	0	0	0	1
01/20/2020 16:00	0.0	0	0	0	0	1
01/20/2020 17:00	0.0	0	0	0	0	1
01/20/2020 18:00	0.0	0	0	0	0	1
01/20/2020 19:00	0.0	0	0	0	0	1
01/20/2020 20:00	0.0	0	0	0	0	1
01/20/2020 21:00	0.0	0	0	0	0	1
01/20/2020 22:00	0.0	0	0	0	0	1
01/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/21/2020 00:00	0.0	0	0	0	0	1
01/21/2020 01:00	0.0	0	0	0	0	1
01/21/2020 02:00	0.0	0	0	0	0	1
01/21/2020 03:00	0.0	0	0	0	0	1
01/21/2020 04:00	0.0	0	0	0	0	1
01/21/2020 05:00	0.0	0	0	0	0	1
01/21/2020 06:00	0.0	0	0	0	0	1
01/21/2020 07:00	0.0	0	0	0	0	1
01/21/2020 08:00	0.0	0	0	0	0	1
01/21/2020 09:00	0.0	0	0	0	0	1
01/21/2020 10:00	0.0	0	0	0	0	1
01/21/2020 11:00	0.0	0	0	0	0	1
01/21/2020 12:00	0.0	0	0	0	0	1
01/21/2020 13:00	0.0	0	0	0	0	1
01/21/2020 14:00	0.0	0	0	0	0	1
01/21/2020 15:00	0.0	0	0	0	0	1
01/21/2020 16:00	0.0	0	0	0	0	1
01/21/2020 17:00	0.0	0	0	0	0	1
01/21/2020 18:00	0.0	0	0	0	0	1
01/21/2020 19:00	0.0	0	0	0	0	1
01/21/2020 20:00	0.0	0	0	0	0	1
01/21/2020 21:00	0.0	0	0	0	0	1
01/21/2020 22:00	0.0	0	0	0	0	1
01/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/22/2020 00:00	0.0	0	0	0	0	1
01/22/2020 01:00	0.0	0	0	0	0	1
01/22/2020 02:00	0.0	0	0	0	0	1
01/22/2020 03:00	0.0	0	0	0	0	1
01/22/2020 04:00	0.0	0	0	0	0	1
01/22/2020 05:00	0.0	0	0	0	0	1
01/22/2020 06:00	0.0	0	0	0	0	1
01/22/2020 07:00	0.0	0	0	0	0	1
01/22/2020 08:00	0.0	0	0	0	0	1
01/22/2020 09:00	0.0	0	0	0	0	1
01/22/2020 10:00	0.0	0	0	0	0	1
01/22/2020 11:00	0.0	0	0	0	0	1
01/22/2020 12:00	0.0	0	0	0	0	1
01/22/2020 13:00	0.0	0	0	0	0	1
01/22/2020 14:00	0.0	0	0	0	0	1
01/22/2020 15:00	0.0	0	0	0	0	1
01/22/2020 16:00	0.0	0	0	0	0	1
01/22/2020 17:00	0.0	0	0	0	0	1
01/22/2020 18:00	0.0	0	0	0	0	1
01/22/2020 19:00	0.0	0	0	0	0	1
01/22/2020 20:00	0.0	0	0	0	0	1
01/22/2020 21:00	0.0	0	0	0	0	1
01/22/2020 22:00	0.0	0	0	0	0	1
01/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/23/2020 00:00	0.0	0	0	0	0	1
01/23/2020 01:00	0.0	0	0	0	0	1
01/23/2020 02:00	0.0	0	0	0	0	1
01/23/2020 03:00	0.0	0	0	0	0	1
01/23/2020 04:00	0.0	0	0	0	0	1
01/23/2020 05:00	0.0	0	0	0	0	1
01/23/2020 06:00	0.0	0	0	0	0	1
01/23/2020 07:00	0.0	0	0	0	0	1
01/23/2020 08:00	0.0	0	0	0	0	1
01/23/2020 09:00	0.0	0	0	0	0	1
01/23/2020 10:00	0.0	0	0	0	0	1
01/23/2020 11:00	0.0	0	0	0	0	1
01/23/2020 12:00	0.0	0	0	0	0	1
01/23/2020 13:00	0.0	0	0	0	0	1
01/23/2020 14:00	0.0	0	0	0	0	1
01/23/2020 15:00	0.0	0	0	0	0	1
01/23/2020 16:00	0.0	0	0	0	0	1
01/23/2020 17:00	0.0	0	0	0	0	1
01/23/2020 18:00	0.0	0	0	0	0	1
01/23/2020 19:00	0.0	0	0	0	0	1
01/23/2020 20:00	0.0	0	0	0	0	1
01/23/2020 21:00	0.0	0	0	0	0	1
01/23/2020 22:00	0.0	0	0	0	0	1
01/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/24/2020 00:00	0.0	0	0	0	0	1
01/24/2020 01:00	0.0	0	0	0	0	1
01/24/2020 02:00	0.0	0	0	0	0	1
01/24/2020 03:00	0.0	0	0	0	0	1
01/24/2020 04:00	0.0	0	0	0	0	1
01/24/2020 05:00	0.0	0	0	0	0	1
01/24/2020 06:00	0.0	0	0	0	0	1
01/24/2020 07:00	0.0	0	0	0	0	1
01/24/2020 08:00	0.0	0	0	0	0	1
01/24/2020 09:00	0.0	0	0	0	0	1
01/24/2020 10:00	0.0	0	0	0	0	1
01/24/2020 11:00	0.0	0	0	0	0	1
01/24/2020 12:00	0.0	0	0	0	0	1
01/24/2020 13:00	0.0	0	0	0	0	1
01/24/2020 14:00	0.0	0	0	0	0	1
01/24/2020 15:00	0.0	0	0	0	0	1
01/24/2020 16:00	0.0	0	0	0	0	1
01/24/2020 17:00	0.0	0	0	0	0	1
01/24/2020 18:00	0.0	0	0	0	0	1
01/24/2020 19:00	0.0	0	0	0	0	1
01/24/2020 20:00	0.0	0	0	0	0	1
01/24/2020 21:00	0.0	0	0	0	0	1
01/24/2020 22:00	0.0	0	0	0	0	1
01/24/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/25/2020 00:00	0.0	0	0	0	0	0
01/25/2020 01:00	0.0	0	0	0	0	0
01/25/2020 02:00	0.0	0	0	0	0	0
01/25/2020 03:00	0.0	0	0	0	0	0
01/25/2020 04:00	0.0	0	0	0	0	0
01/25/2020 05:00	0.0	0	0	0	0	0
01/25/2020 06:00	0.0	0	0	0	0	0
01/25/2020 07:00	0.0	0	0	0	0	0
01/25/2020 08:00	0.0	0	0	0	0	0
01/25/2020 09:00	0.0	0	0	0	0	0
01/25/2020 10:00	0.0	0	0	0	0	0
01/25/2020 11:00	0.0	0	0	0	0	0
01/25/2020 12:00	0.0	0	0	0	0	0
01/25/2020 13:00	0.0	0	0	0	0	0
01/25/2020 14:00	0.0	0	0	0	0	0
01/25/2020 15:00	0.0	0	0	0	0	0
01/25/2020 16:00	0.0	0	0	0	0	0
01/25/2020 17:00	0.0	0	0	0	0	0
01/25/2020 18:00	0.0	0	0	0	0	0
01/25/2020 19:00	0.0	0	0	0	0	0
01/25/2020 20:00	0.0	0	0	0	0	0
01/25/2020 21:00	0.0	0	0	0	0	0
01/25/2020 22:00	0.0	0	0	0	0	0
01/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/26/2020 00:00	0.0	0	0	0	0	0
01/26/2020 01:00	0.0	0	0	0	0	0
01/26/2020 02:00	0.0	0	0	0	0	0
01/26/2020 03:00	0.0	0	0	0	0	0
01/26/2020 04:00	0.0	0	0	0	0	0
01/26/2020 05:00	0.0	0	0	0	0	0
01/26/2020 06:00	0.0	0	0	0	0	0
01/26/2020 07:00	0.0	0	0	0	0	0
01/26/2020 08:00	0.0	0	0	0	0	0
01/26/2020 09:00	0.0	0	0	0	0	0
01/26/2020 10:00	0.0	0	0	0	0	0
01/26/2020 11:00	0.0	0	0	0	0	0
01/26/2020 12:00	0.0	0	0	0	0	0
01/26/2020 13:00	0.0	0	0	0	0	0
01/26/2020 14:00	0.0	0	0	0	0	0
01/26/2020 15:00	0.0	0	0	0	0	0
01/26/2020 16:00	0.0	0	0	0	0	0
01/26/2020 17:00	0.0	0	0	0	0	0
01/26/2020 18:00	0.0	0	0	0	0	0
01/26/2020 19:00	0.0	0	0	0	0	0
01/26/2020 20:00	0.0	0	0	0	0	0
01/26/2020 21:00	0.0	0	0	0	0	0
01/26/2020 22:00	0.0	0	0	0	0	0
01/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/27/2020 00:00	0.0	0	0	0	0	0
01/27/2020 01:00	0.0	0	0	0	0	0
01/27/2020 02:00	0.0	0	0	0	0	0
01/27/2020 03:00	0.0	0	0	0	0	0
01/27/2020 04:00	0.0	0	0	0	0	0
01/27/2020 05:00	0.0	0	0	0	0	0
01/27/2020 06:00	0.0	0	0	0	0	0
01/27/2020 07:00	0.0	0	0	0	0	0
01/27/2020 08:00	0.0	0	0	0	0	0
01/27/2020 09:00	0.0	0	0	0	0	0
01/27/2020 10:00	0.0	0	0	0	0	0
01/27/2020 11:00	0.0	0	0	0	0	0
01/27/2020 12:00	0.0	0	0	0	0	0
01/27/2020 13:00	0.0	0	0	0	0	0
01/27/2020 14:00	0.0	0	0	0	0	0
01/27/2020 15:00	0.0	0	0	0	0	0
01/27/2020 16:00	0.0	0	0	0	0	0
01/27/2020 17:00	0.0	0	0	0	0	0
01/27/2020 18:00	64.8	0	1	0	0	0
01/27/2020 19:00	31.5	0	1	0	0	0
01/27/2020 20:00	29.3	0	1	0	0	0
01/27/2020 21:00	0.0	0	0	0	0	1
01/27/2020 22:00	0.0	0	0	0	0	1
01/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.6 #	0 #	3 #	0 #	0 #	3 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/28/2020 00:00	0.0	0	0	0	0	1
01/28/2020 01:00	0.0	0	0	0	0	1
01/28/2020 02:00	0.0	0	0	0	0	1
01/28/2020 03:00	0.0	0	0	0	0	1
01/28/2020 04:00	0.0	0	0	0	0	1
01/28/2020 05:00	0.0	0	0	0	0	1
01/28/2020 06:00	0.0	0	0	0	0	1
01/28/2020 07:00	0.0	0	0	0	0	1
01/28/2020 08:00	0.0	0	0	0	0	1
01/28/2020 09:00	0.0	0	0	0	0	1
01/28/2020 10:00	0.0	0	0	0	0	1
01/28/2020 11:00	0.0	0	0	0	0	1
01/28/2020 12:00	0.0	0	0	0	0	1
01/28/2020 13:00	0.0	0	0	0	0	1
01/28/2020 14:00	0.0	0	0	0	0	1
01/28/2020 15:00	0.0	0	0	0	0	1
01/28/2020 16:00	0.0	0	0	0	0	1
01/28/2020 17:00	0.0	0	0	0	0	1
01/28/2020 18:00	0.0	0	0	0	0	1
01/28/2020 19:00	0.0	0	0	0	0	1
01/28/2020 20:00	0.0	0	0	0	0	1
01/28/2020 21:00	0.0	0	0	0	0	1
01/28/2020 22:00	1.8	0	0	0	1	0
01/28/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/29/2020 00:00	0.0	0	0	0	0	0
01/29/2020 01:00	0.0	0	0	0	0	0
01/29/2020 02:00	0.0	0	0	0	0	0
01/29/2020 03:00	0.0	0	0	0	0	0
01/29/2020 04:00	0.0	0	0	0	0	0
01/29/2020 05:00	0.0	0	0	0	0	0
01/29/2020 06:00	0.0	0	0	0	0	0
01/29/2020 07:00	0.0	0	0	0	0	0
01/29/2020 08:00	0.0	0	0	0	0	0
01/29/2020 09:00	0.0	0	0	0	0	0
01/29/2020 10:00	0.0	0	0	0	0	0
01/29/2020 11:00	0.0	0	0	0	0	0
01/29/2020 12:00	0.0	0	0	0	0	0
01/29/2020 13:00	0.0	0	0	0	0	0
01/29/2020 14:00	0.0	0	0	0	0	0
01/29/2020 15:00	0.0	0	0	0	0	0
01/29/2020 16:00	0.0	0	0	0	0	0
01/29/2020 17:00	56.4	0	1	0	0	0
01/29/2020 18:00	49.9	0	1	0	0	0
01/29/2020 19:00	23.2	0	1	0	0	0
01/29/2020 20:00	0.0	0	0	0	0	1
01/29/2020 21:00	0.0	0	0	0	0	1
01/29/2020 22:00	0.0	0	0	0	0	1
01/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	129.5 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/30/2020 00:00	0.0	0	0	0	0	1
01/30/2020 01:00	0.0	0	0	0	0	1
01/30/2020 02:00	0.0	0	0	0	0	1
01/30/2020 03:00	0.0	0	0	0	0	1
01/30/2020 04:00	0.0	0	0	0	0	1
01/30/2020 05:00	0.0	0	0	0	0	1
01/30/2020 06:00	0.0	0	0	0	0	1
01/30/2020 07:00	0.0	0	0	0	0	1
01/30/2020 08:00	0.0	0	0	0	0	1
01/30/2020 09:00	0.0	0	0	0	0	1
01/30/2020 10:00	0.0	0	0	0	0	1
01/30/2020 11:00	0.0	0	0	0	0	1
01/30/2020 12:00	0.0	0	0	0	0	1
01/30/2020 13:00	0.0	0	0	0	0	1
01/30/2020 14:00	0.0	0	0	0	0	1
01/30/2020 15:00	0.0	0	0	0	0	1
01/30/2020 16:00	0.0	0	0	0	0	1
01/30/2020 17:00	0.0	0	0	0	0	1
01/30/2020 18:00	0.0	0	0	0	0	1
01/30/2020 19:00	0.0	0	0	0	0	1
01/30/2020 20:00	0.0	0	0	0	0	1
01/30/2020 21:00	0.0	0	0	0	0	1
01/30/2020 22:00	0.0	0	0	0	0	1
01/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
01/31/2020 00:00	0.0	0	0	0	0	1
01/31/2020 01:00	0.0	0	0	0	0	1
01/31/2020 02:00	0.0	0	0	0	0	1
01/31/2020 03:00	0.0	0	0	0	0	1
01/31/2020 04:00	0.0	0	0	0	0	1
01/31/2020 05:00	0.0	0	0	0	0	1
01/31/2020 06:00	0.0	0	0	0	0	1
01/31/2020 07:00	0.0	0	0	0	0	1
01/31/2020 08:00	0.0	0	0	0	0	1
01/31/2020 09:00	0.0	0	0	0	0	1
01/31/2020 10:00	0.0	0	0	0	0	1
01/31/2020 11:00	0.0	0	0	0	0	1
01/31/2020 12:00	0.0	0	0	0	0	1
01/31/2020 13:00	0.0	0	0	0	0	1
01/31/2020 14:00	0.0	0	0	0	0	1
01/31/2020 15:00	0.0	0	0	0	0	1
01/31/2020 16:00	0.0	0	0	0	0	1
01/31/2020 17:00	0.0	0	0	0	0	1
01/31/2020 18:00	0.0	0	0	0	0	1
01/31/2020 19:00	0.0	0	0	0	0	1
01/31/2020 20:00	0.0	0	0	0	0	1
01/31/2020 21:00	0.0	0	0	0	0	1
01/31/2020 22:00	0.0	0	0	0	0	1
01/31/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/01/2020 00:00	0.0	0	0	0	0	0
02/01/2020 01:00	0.0	0	0	0	0	0
02/01/2020 02:00	0.0	0	0	0	0	0
02/01/2020 03:00	0.0	0	0	0	0	0
02/01/2020 04:00	0.0	0	0	0	0	0
02/01/2020 05:00	0.0	0	0	0	0	0
02/01/2020 06:00	0.0	0	0	0	0	0
02/01/2020 07:00	0.0	0	0	0	0	0
02/01/2020 08:00	0.0	0	0	0	0	0
02/01/2020 09:00	0.0	0	0	0	0	0
02/01/2020 10:00	0.0	0	0	0	0	0
02/01/2020 11:00	0.0	0	0	0	0	0
02/01/2020 12:00	0.0	0	0	0	0	0
02/01/2020 13:00	0.0	0	0	0	0	0
02/01/2020 14:00	0.0	0	0	0	0	0
02/01/2020 15:00	0.0	0	0	0	0	0
02/01/2020 16:00	0.0	0	0	0	0	0
02/01/2020 17:00	0.0	0	0	0	0	0
02/01/2020 18:00	0.0	0	0	0	0	0
02/01/2020 19:00	0.0	0	0	0	0	0
02/01/2020 20:00	0.0	0	0	0	0	0
02/01/2020 21:00	0.0	0	0	0	0	0
02/01/2020 22:00	0.0	0	0	0	0	0
02/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/02/2020 00:00	0.0	0	0	0	0	0
02/02/2020 01:00	0.0	0	0	0	0	0
02/02/2020 02:00	0.0	0	0	0	0	0
02/02/2020 03:00	0.0	0	0	0	0	0
02/02/2020 04:00	0.0	0	0	0	0	0
02/02/2020 05:00	0.0	0	0	0	0	0
02/02/2020 06:00	0.0	0	0	0	0	0
02/02/2020 07:00	0.0	0	0	0	0	0
02/02/2020 08:00	0.0	0	0	0	0	0
02/02/2020 09:00	0.0	0	0	0	0	0
02/02/2020 10:00	0.0	0	0	0	0	0
02/02/2020 11:00	0.0	0	0	0	0	0
02/02/2020 12:00	0.0	0	0	0	0	0
02/02/2020 13:00	0.0	0	0	0	0	0
02/02/2020 14:00	0.0	0	0	0	0	0
02/02/2020 15:00	0.0	0	0	0	0	0
02/02/2020 16:00	0.0	0	0	0	0	0
02/02/2020 17:00	0.0	0	0	0	0	0
02/02/2020 18:00	0.0	0	0	0	0	0
02/02/2020 19:00	0.0	0	0	0	0	0
02/02/2020 20:00	0.0	0	0	0	0	0
02/02/2020 21:00	0.0	0	0	0	0	0
02/02/2020 22:00	0.0	0	0	0	0	0
02/02/2020 23:00	73.0	0	1	0	0	0
Average/Sum#:	73.0 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.0	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/03/2020 00:00	32.8	0	1	0	0	0
02/03/2020 01:00	50.1	0	1	0	0	0
02/03/2020 02:00	0.0	0	1	0	0	0
02/03/2020 03:00	0.0	0	0	0	0	1
02/03/2020 04:00	0.0	0	0	0	0	1
02/03/2020 05:00	0.0	0	0	0	0	1
02/03/2020 06:00	0.0	0	0	0	0	1
02/03/2020 07:00	0.0	0	0	0	0	1
02/03/2020 08:00	0.0	0	0	0	0	1
02/03/2020 09:00	0.0	0	0	0	0	1
02/03/2020 10:00	0.0	0	0	0	0	1
02/03/2020 11:00	0.0	0	0	0	0	1
02/03/2020 12:00	0.0	0	0	0	0	1
02/03/2020 13:00	0.0	0	0	0	0	1
02/03/2020 14:00	0.0	0	0	0	0	1
02/03/2020 15:00	0.0	0	0	0	0	1
02/03/2020 16:00	0.0	0	0	0	0	1
02/03/2020 17:00	0.0	0	0	0	0	1
02/03/2020 18:00	0.0	0	0	0	0	1
02/03/2020 19:00	0.0	0	0	0	0	1
02/03/2020 20:00	0.0	0	0	0	0	1
02/03/2020 21:00	0.0	0	0	0	0	1
02/03/2020 22:00	0.0	0	0	0	0	1
02/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	82.9 #	0 #	3 #	0 #	0 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/04/2020 00:00	0.0	0	0	0	0	1
02/04/2020 01:00	0.0	0	0	0	0	1
02/04/2020 02:00	0.0	0	0	0	0	1
02/04/2020 03:00	0.0	0	0	0	0	1
02/04/2020 04:00	0.0	0	0	0	0	1
02/04/2020 05:00	0.0	0	0	0	0	1
02/04/2020 06:00	0.0	0	0	0	0	1
02/04/2020 07:00	0.0	0	0	0	0	1
02/04/2020 08:00	0.0	0	0	0	0	1
02/04/2020 09:00	0.0	0	0	0	0	1
02/04/2020 10:00	0.0	0	0	0	0	1
02/04/2020 11:00	0.0	0	0	0	0	1
02/04/2020 12:00	0.0	0	0	0	0	1
02/04/2020 13:00	0.0	0	0	0	0	1
02/04/2020 14:00	0.0	0	0	0	0	1
02/04/2020 15:00	0.0	0	0	0	0	1
02/04/2020 16:00	0.0	0	0	0	0	1
02/04/2020 17:00	0.0	0	0	0	0	1
02/04/2020 18:00	0.0	0	0	0	0	1
02/04/2020 19:00	0.0	0	0	0	0	1
02/04/2020 20:00	0.0	0	0	0	0	1
02/04/2020 21:00	0.0	0	0	0	0	1
02/04/2020 22:00	0.0	0	0	0	0	1
02/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/05/2020 00:00	0.0	0	0	0	0	1
02/05/2020 01:00	0.0	0	0	0	0	1
02/05/2020 02:00	0.0	0	0	0	0	1
02/05/2020 03:00	0.0	0	0	0	0	1
02/05/2020 04:00	0.0	0	0	0	0	1
02/05/2020 05:00	0.0	0	0	0	0	1
02/05/2020 06:00	0.0	0	0	0	0	1
02/05/2020 07:00	0.0	0	0	0	0	1
02/05/2020 08:00	0.0	0	0	0	0	1
02/05/2020 09:00	0.0	0	0	0	0	1
02/05/2020 10:00	0.0	0	0	0	0	1
02/05/2020 11:00	0.0	0	0	0	0	1
02/05/2020 12:00	0.0	0	0	0	0	1
02/05/2020 13:00	0.0	0	0	0	0	1
02/05/2020 14:00	0.0	0	0	0	0	1
02/05/2020 15:00	0.0	0	0	0	0	1
02/05/2020 16:00	0.0	0	0	0	0	1
02/05/2020 17:00	0.0	0	0	0	0	1
02/05/2020 18:00	0.0	0	0	0	0	1
02/05/2020 19:00	0.0	0	0	0	0	1
02/05/2020 20:00	0.0	0	0	0	0	1
02/05/2020 21:00	0.0	0	0	0	0	1
02/05/2020 22:00	0.0	0	0	0	0	1
02/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/06/2020 00:00	0.0	0	0	0	0	1
02/06/2020 01:00	0.0	0	0	0	0	1
02/06/2020 02:00	0.0	0	0	0	0	1
02/06/2020 03:00	0.0	0	0	0	0	1
02/06/2020 04:00	0.0	0	0	0	0	1
02/06/2020 05:00	0.0	0	0	0	0	1
02/06/2020 06:00	0.0	0	0	0	0	1
02/06/2020 07:00	0.0	0	0	0	0	1
02/06/2020 08:00	0.0	0	0	0	0	1
02/06/2020 09:00	0.0	0	0	0	0	1
02/06/2020 10:00	0.0	0	0	0	0	1
02/06/2020 11:00	0.0	0	0	0	0	1
02/06/2020 12:00	0.0	0	0	0	0	1
02/06/2020 13:00	0.0	0	0	0	0	1
02/06/2020 14:00	0.0	0	0	0	0	1
02/06/2020 15:00	0.0	0	0	0	0	1
02/06/2020 16:00	0.0	0	0	0	0	1
02/06/2020 17:00	0.0	0	0	0	0	1
02/06/2020 18:00	0.0	0	0	0	0	1
02/06/2020 19:00	0.0	0	0	0	0	1
02/06/2020 20:00	0.0	0	0	0	0	1
02/06/2020 21:00	0.0	0	0	0	0	1
02/06/2020 22:00	0.0	0	0	0	0	1
02/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/07/2020 00:00	0.0	0	0	0	0	1
02/07/2020 01:00	0.0	0	0	0	0	1
02/07/2020 02:00	0.0	0	0	0	0	1
02/07/2020 03:00	0.0	0	0	0	0	1
02/07/2020 04:00	0.0	0	0	0	0	1
02/07/2020 05:00	0.0	0	0	0	0	1
02/07/2020 06:00	0.0	0	0	0	0	1
02/07/2020 07:00	0.0	0	0	0	0	1
02/07/2020 08:00	0.0	0	0	0	0	1
02/07/2020 09:00	0.0	0	0	0	0	1
02/07/2020 10:00	0.0	0	0	0	0	1
02/07/2020 11:00	0.0	0	0	0	0	1
02/07/2020 12:00	0.0	0	0	0	0	1
02/07/2020 13:00	0.0	0	0	0	0	1
02/07/2020 14:00	0.0	0	0	0	0	1
02/07/2020 15:00	0.0	0	0	0	0	1
02/07/2020 16:00	0.0	0	0	0	0	1
02/07/2020 17:00	0.0	0	0	0	0	1
02/07/2020 18:00	0.0	0	0	0	0	1
02/07/2020 19:00	0.0	0	0	0	0	1
02/07/2020 20:00	0.0	0	0	0	0	1
02/07/2020 21:00	0.0	0	0	0	0	1
02/07/2020 22:00	0.0	0	0	0	0	1
02/07/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/08/2020 00:00	0.0	0	0	0	0	0
02/08/2020 01:00	0.0	0	0	0	0	0
02/08/2020 02:00	0.0	0	0	0	0	0
02/08/2020 03:00	0.0	0	0	0	0	0
02/08/2020 04:00	0.0	0	0	0	0	0
02/08/2020 05:00	0.0	0	0	0	0	0
02/08/2020 06:00	0.0	0	0	0	0	0
02/08/2020 07:00	0.0	0	0	0	0	0
02/08/2020 08:00	0.0	0	0	0	0	0
02/08/2020 09:00	0.0	0	0	0	0	0
02/08/2020 10:00	0.0	0	0	0	0	0
02/08/2020 11:00	0.0	0	0	0	0	0
02/08/2020 12:00	0.0	0	0	0	0	0
02/08/2020 13:00	0.0	0	0	0	0	0
02/08/2020 14:00	0.0	0	0	0	0	0
02/08/2020 15:00	0.0	0	0	0	0	0
02/08/2020 16:00	0.0	0	0	0	0	0
02/08/2020 17:00	0.0	0	0	0	0	0
02/08/2020 18:00	0.0	0	0	0	0	0
02/08/2020 19:00	0.0	0	0	0	0	0
02/08/2020 20:00	0.0	0	0	0	0	0
02/08/2020 21:00	0.0	0	0	0	0	0
02/08/2020 22:00	0.0	0	0	0	0	0
02/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/09/2020 00:00	0.0	0	0	0	0	0
02/09/2020 01:00	0.0	0	0	0	0	0
02/09/2020 02:00	0.0	0	0	0	0	0
02/09/2020 03:00	0.0	0	0	0	0	0
02/09/2020 04:00	0.0	0	0	0	0	0
02/09/2020 05:00	0.0	0	0	0	0	0
02/09/2020 06:00	0.0	0	0	0	0	0
02/09/2020 07:00	0.0	0	0	0	0	0
02/09/2020 08:00	0.0	0	0	0	0	0
02/09/2020 09:00	0.0	0	0	0	0	0
02/09/2020 10:00	0.0	0	0	0	0	0
02/09/2020 11:00	0.0	0	0	0	0	0
02/09/2020 12:00	0.0	0	0	0	0	0
02/09/2020 13:00	0.0	0	0	0	0	0
02/09/2020 14:00	0.0	0	0	0	0	0
02/09/2020 15:00	0.0	0	0	0	0	0
02/09/2020 16:00	0.0	0	0	0	0	0
02/09/2020 17:00	0.0	0	0	0	0	0
02/09/2020 18:00	0.0	0	0	0	0	0
02/09/2020 19:00	0.0	0	0	0	0	0
02/09/2020 20:00	0.0	0	0	0	0	0
02/09/2020 21:00	0.0	0	0	0	0	0
02/09/2020 22:00	0.0	0	0	0	0	0
02/09/2020 23:00	66.2	0	1	0	0	0
Average/Sum#:	66.2 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.2	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/10/2020 00:00	75.6	0	1	0	0	0
02/10/2020 01:00	49.5	0	1	0	0	0
02/10/2020 02:00	0.0	0	0	0	0	1
02/10/2020 03:00	0.0	0	0	0	0	1
02/10/2020 04:00	0.0	0	0	0	0	1
02/10/2020 05:00	0.0	0	0	0	0	1
02/10/2020 06:00	0.0	0	0	0	0	1
02/10/2020 07:00	0.0	0	0	0	0	1
02/10/2020 08:00	0.0	0	0	0	0	1
02/10/2020 09:00	0.0	0	0	0	0	1
02/10/2020 10:00	0.0	0	0	0	0	1
02/10/2020 11:00	0.0	0	0	0	0	1
02/10/2020 12:00	0.0	0	0	0	0	1
02/10/2020 13:00	0.0	0	0	0	0	1
02/10/2020 14:00	0.0	0	0	0	0	1
02/10/2020 15:00	0.0	0	0	0	0	1
02/10/2020 16:00	0.0	0	0	0	0	1
02/10/2020 17:00	0.0	0	0	0	0	1
02/10/2020 18:00	0.0	0	0	0	0	1
02/10/2020 19:00	0.0	0	0	0	0	1
02/10/2020 20:00	0.0	0	0	0	0	1
02/10/2020 21:00	0.0	0	0	0	0	1
02/10/2020 22:00	0.0	0	0	0	0	1
02/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	125.1 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/11/2020 00:00	0.0	0	0	0	0	1
02/11/2020 01:00	0.0	0	0	0	0	1
02/11/2020 02:00	0.0	0	0	0	0	1
02/11/2020 03:00	0.0	0	0	0	0	1
02/11/2020 04:00	0.0	0	0	0	0	1
02/11/2020 05:00	0.0	0	0	0	0	1
02/11/2020 06:00	0.0	0	0	0	0	1
02/11/2020 07:00	0.0	0	0	0	0	1
02/11/2020 08:00	0.0	0	0	0	0	1
02/11/2020 09:00	0.0	0	0	0	0	1
02/11/2020 10:00	0.0	0	0	0	0	1
02/11/2020 11:00	0.0	0	0	0	0	1
02/11/2020 12:00	0.0	0	0	0	0	1
02/11/2020 13:00	0.0	0	0	0	0	1
02/11/2020 14:00	0.0	0	0	0	0	1
02/11/2020 15:00	0.0	0	0	0	0	1
02/11/2020 16:00	0.0	0	0	0	0	1
02/11/2020 17:00	0.0	0	0	0	0	1
02/11/2020 18:00	0.0	0	0	0	0	1
02/11/2020 19:00	0.0	0	0	0	0	1
02/11/2020 20:00	0.0	0	0	0	0	1
02/11/2020 21:00	0.0	0	0	0	0	1
02/11/2020 22:00	0.0	0	0	0	0	1
02/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/12/2020 00:00	0.0	0	0	0	0	1
02/12/2020 01:00	0.0	0	0	0	0	1
02/12/2020 02:00	0.0	0	0	0	0	1
02/12/2020 03:00	0.0	0	0	0	0	1
02/12/2020 04:00	0.0	0	0	0	0	1
02/12/2020 05:00	0.0	0	0	0	0	1
02/12/2020 06:00	0.0	0	0	0	0	1
02/12/2020 07:00	0.0	0	0	0	0	1
02/12/2020 08:00	0.0	0	0	0	0	1
02/12/2020 09:00	0.0	0	0	0	0	1
02/12/2020 10:00	0.0	0	0	0	0	1
02/12/2020 11:00	0.0	0	0	0	0	1
02/12/2020 12:00	0.0	0	0	0	0	1
02/12/2020 13:00	0.0	0	0	0	0	1
02/12/2020 14:00	0.0	0	0	0	0	1
02/12/2020 15:00	0.0	0	0	0	0	1
02/12/2020 16:00	0.0	0	0	0	0	1
02/12/2020 17:00	0.0	0	0	0	0	1
02/12/2020 18:00	0.0	0	0	0	0	1
02/12/2020 19:00	0.0	0	0	0	0	1
02/12/2020 20:00	0.0	0	0	0	0	1
02/12/2020 21:00	0.0	0	0	0	0	1
02/12/2020 22:00	0.0	0	0	0	0	1
02/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/13/2020 00:00	0.0	0	0	0	0	1
02/13/2020 01:00	0.0	0	0	0	0	1
02/13/2020 02:00	0.0	0	0	0	0	1
02/13/2020 03:00	0.0	0	0	0	0	1
02/13/2020 04:00	0.0	0	0	0	0	1
02/13/2020 05:00	0.0	0	0	0	0	1
02/13/2020 06:00	0.0	0	0	0	0	1
02/13/2020 07:00	0.0	0	0	0	0	1
02/13/2020 08:00	0.0	0	0	0	0	1
02/13/2020 09:00	0.0	0	0	0	0	1
02/13/2020 10:00	0.0	0	0	0	0	1
02/13/2020 11:00	0.0	0	0	0	0	1
02/13/2020 12:00	0.0	0	0	0	0	1
02/13/2020 13:00	0.0	0	0	0	0	1
02/13/2020 14:00	0.0	0	0	0	0	1
02/13/2020 15:00	0.0	0	0	0	0	1
02/13/2020 16:00	0.0	0	0	0	0	1
02/13/2020 17:00	0.0	0	0	0	0	1
02/13/2020 18:00	0.0	0	0	0	0	1
02/13/2020 19:00	0.0	0	0	0	0	1
02/13/2020 20:00	0.0	0	0	0	0	1
02/13/2020 21:00	0.0	0	0	0	0	1
02/13/2020 22:00	0.0	0	0	0	0	1
02/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/14/2020 00:00	0.9	0	0	0	1	0
02/14/2020 01:00	0.0	0	0	0	0	0
02/14/2020 02:00	0.0	0	0	0	0	0
02/14/2020 03:00	0.0	0	0	0	0	0
02/14/2020 04:00	0.0	0	0	0	0	0
02/14/2020 05:00	0.0	0	0	0	0	0
02/14/2020 06:00	0.0	0	0	0	0	0
02/14/2020 07:00	0.0	0	0	0	0	0
02/14/2020 08:00	0.0	0	0	0	0	0
02/14/2020 09:00	0.0	0	0	0	0	0
02/14/2020 10:00	0.0	0	0	0	0	0
02/14/2020 11:00	0.0	0	0	0	0	0
02/14/2020 12:00	0.0	0	0	0	0	0
02/14/2020 13:00	0.0	0	0	0	0	0
02/14/2020 14:00	0.0	0	0	0	0	0
02/14/2020 15:00	0.0	0	0	0	0	0
02/14/2020 16:00	0.0	0	0	0	0	0
02/14/2020 17:00	0.0	0	0	0	0	0
02/14/2020 18:00	0.0	0	0	0	0	0
02/14/2020 19:00	0.0	0	0	0	0	0
02/14/2020 20:00	0.0	0	0	0	0	0
02/14/2020 21:00	0.0	0	0	0	0	0
02/14/2020 22:00	0.0	0	0	0	0	0
02/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/15/2020 00:00	0.0	0	0	0	0	0
02/15/2020 01:00	0.0	0	0	0	0	0
02/15/2020 02:00	0.0	0	0	0	0	0
02/15/2020 03:00	0.0	0	0	0	0	0
02/15/2020 04:00	0.0	0	0	0	0	0
02/15/2020 05:00	0.0	0	0	0	0	0
02/15/2020 06:00	0.0	0	0	0	0	0
02/15/2020 07:00	0.0	0	0	0	0	0
02/15/2020 08:00	0.0	0	0	0	0	0
02/15/2020 09:00	0.0	0	0	0	0	0
02/15/2020 10:00	0.0	0	0	0	0	0
02/15/2020 11:00	0.0	0	0	0	0	0
02/15/2020 12:00	0.0	0	0	0	0	0
02/15/2020 13:00	0.0	0	0	0	0	0
02/15/2020 14:00	0.0	0	0	0	0	0
02/15/2020 15:00	0.0	0	0	0	0	0
02/15/2020 16:00	0.0	0	0	0	0	0
02/15/2020 17:00	0.0	0	0	0	0	0
02/15/2020 18:00	0.0	0	0	0	0	0
02/15/2020 19:00	0.0	0	0	0	0	0
02/15/2020 20:00	0.0	0	0	0	0	0
02/15/2020 21:00	0.0	0	0	0	0	0
02/15/2020 22:00	0.0	0	0	0	0	0
02/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/16/2020 00:00	0.0	0	0	0	0	0
02/16/2020 01:00	0.0	0	0	0	0	0
02/16/2020 02:00	0.0	0	0	0	0	0
02/16/2020 03:00	0.0	0	0	0	0	0
02/16/2020 04:00	0.0	0	0	0	0	0
02/16/2020 05:00	0.0	0	0	0	0	0
02/16/2020 06:00	0.0	0	0	0	0	0
02/16/2020 07:00	0.0	0	0	0	0	0
02/16/2020 08:00	0.0	0	0	0	0	0
02/16/2020 09:00	0.0	0	0	0	0	0
02/16/2020 10:00	0.0	0	0	0	0	0
02/16/2020 11:00	0.0	0	0	0	0	0
02/16/2020 12:00	0.0	0	0	0	0	0
02/16/2020 13:00	0.0	0	0	0	0	0
02/16/2020 14:00	0.0	0	0	0	0	0
02/16/2020 15:00	0.0	0	0	0	0	0
02/16/2020 16:00	0.0	0	0	0	0	0
02/16/2020 17:00	0.0	0	0	0	0	0
02/16/2020 18:00	0.0	0	0	0	0	0
02/16/2020 19:00	0.0	0	0	0	0	0
02/16/2020 20:00	0.0	0	0	0	0	0
02/16/2020 21:00	0.0	0	0	0	0	0
02/16/2020 22:00	0.0	0	0	0	0	0
02/16/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/17/2020 00:00	0.0	0	0	0	0	0
02/17/2020 01:00	0.0	0	0	0	0	0
02/17/2020 02:00	0.0	0	0	0	0	0
02/17/2020 03:00	0.0	0	0	0	0	0
02/17/2020 04:00	0.0	0	0	0	0	0
02/17/2020 05:00	0.0	0	0	0	0	0
02/17/2020 06:00	0.0	0	0	0	0	0
02/17/2020 07:00	0.0	0	0	0	0	0
02/17/2020 08:00	0.0	0	0	0	0	0
02/17/2020 09:00	78.8	1	0	0	0	0
02/17/2020 10:00	39.6	1	0	0	0	0
02/17/2020 11:00	54.2	1	0	0	0	0
02/17/2020 12:00	48.1	1	0	0	0	0
02/17/2020 13:00	0.0	0	0	0	0	1
02/17/2020 14:00	0.0	0	0	0	0	1
02/17/2020 15:00	0.0	0	0	0	0	1
02/17/2020 16:00	0.0	0	0	0	0	1
02/17/2020 17:00	0.0	0	0	0	0	1
02/17/2020 18:00	0.0	0	0	0	0	1
02/17/2020 19:00	0.0	0	0	0	0	1
02/17/2020 20:00	0.0	0	0	0	0	1
02/17/2020 21:00	0.0	0	0	0	0	1
02/17/2020 22:00	0.0	0	0	0	0	1
02/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	220.7 #	4 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.8	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/18/2020 00:00	0.0	0	0	0	0	1
02/18/2020 01:00	0.0	0	0	0	0	1
02/18/2020 02:00	0.0	0	0	0	0	1
02/18/2020 03:00	0.0	0	0	0	0	1
02/18/2020 04:00	0.0	0	0	0	0	1
02/18/2020 05:00	0.0	0	0	0	0	1
02/18/2020 06:00	0.0	0	0	0	0	1
02/18/2020 07:00	0.0	0	0	0	0	1
02/18/2020 08:00	0.0	0	0	0	0	1
02/18/2020 09:00	0.0	0	0	0	0	1
02/18/2020 10:00	0.0	0	0	0	0	1
02/18/2020 11:00	0.0	0	0	0	0	1
02/18/2020 12:00	0.0	0	0	0	0	1
02/18/2020 13:00	0.0	0	0	0	0	1
02/18/2020 14:00	0.0	0	0	0	0	1
02/18/2020 15:00	0.0	0	0	0	0	1
02/18/2020 16:00	0.0	0	0	0	0	1
02/18/2020 17:00	0.0	0	0	0	0	1
02/18/2020 18:00	0.0	0	0	0	0	1
02/18/2020 19:00	0.0	0	0	0	0	1
02/18/2020 20:00	0.0	0	0	0	0	1
02/18/2020 21:00	0.0	0	0	0	0	1
02/18/2020 22:00	0.0	0	0	0	0	1
02/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/19/2020 00:00	0.0	0	0	0	0	1
02/19/2020 01:00	0.0	0	0	0	0	1
02/19/2020 02:00	0.0	0	0	0	0	1
02/19/2020 03:00	0.0	0	0	0	0	1
02/19/2020 04:00	0.0	0	0	0	0	1
02/19/2020 05:00	0.0	0	0	0	0	1
02/19/2020 06:00	0.0	0	0	0	0	1
02/19/2020 07:00	0.0	0	0	0	0	1
02/19/2020 08:00	0.0	0	0	0	0	1
02/19/2020 09:00	0.0	0	0	0	0	1
02/19/2020 10:00	0.0	0	0	0	0	1
02/19/2020 11:00	0.0	0	0	0	0	1
02/19/2020 12:00	0.0	0	0	0	0	1
02/19/2020 13:00	0.0	0	0	0	0	1
02/19/2020 14:00	0.0	0	0	0	0	1
02/19/2020 15:00	0.0	0	0	0	0	1
02/19/2020 16:00	0.0	0	0	0	0	1
02/19/2020 17:00	0.0	0	0	0	0	1
02/19/2020 18:00	0.0	0	0	0	0	1
02/19/2020 19:00	0.0	0	0	0	0	1
02/19/2020 20:00	0.0	0	0	0	0	1
02/19/2020 21:00	0.0	0	0	0	0	1
02/19/2020 22:00	0.0	0	0	0	0	1
02/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/20/2020 00:00	0.0	0	0	0	0	1
02/20/2020 01:00	0.0	0	0	0	0	1
02/20/2020 02:00	0.0	0	0	0	0	1
02/20/2020 03:00	0.0	0	0	0	0	1
02/20/2020 04:00	0.0	0	0	0	0	1
02/20/2020 05:00	0.0	0	0	0	0	1
02/20/2020 06:00	0.0	0	0	0	0	1
02/20/2020 07:00	0.0	0	0	0	0	1
02/20/2020 08:00	0.0	0	0	0	0	1
02/20/2020 09:00	0.0	0	0	0	0	1
02/20/2020 10:00	0.0	0	0	0	0	1
02/20/2020 11:00	0.0	0	0	0	0	1
02/20/2020 12:00	0.0	0	0	0	0	1
02/20/2020 13:00	0.0	0	0	0	0	1
02/20/2020 14:00	0.0	0	0	0	0	1
02/20/2020 15:00	0.0	0	0	0	0	1
02/20/2020 16:00	0.0	0	0	0	0	1
02/20/2020 17:00	0.0	0	0	0	0	1
02/20/2020 18:00	0.0	0	0	0	0	1
02/20/2020 19:00	0.0	0	0	0	0	1
02/20/2020 20:00	0.0	0	0	0	0	1
02/20/2020 21:00	0.0	0	0	0	0	1
02/20/2020 22:00	0.0	0	0	0	0	1
02/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/21/2020 00:00	0.0	0	0	0	0	1
02/21/2020 01:00	0.0	0	0	0	0	1
02/21/2020 02:00	0.0	0	0	0	0	1
02/21/2020 03:00	0.0	0	0	0	0	1
02/21/2020 04:00	0.0	0	0	0	0	1
02/21/2020 05:00	0.0	0	0	0	0	1
02/21/2020 06:00	0.0	0	0	0	0	1
02/21/2020 07:00	0.0	0	0	0	0	1
02/21/2020 08:00	0.0	0	0	0	0	1
02/21/2020 09:00	0.0	0	0	0	0	1
02/21/2020 10:00	0.0	0	0	0	0	1
02/21/2020 11:00	0.0	0	0	0	0	1
02/21/2020 12:00	0.0	0	0	0	0	1
02/21/2020 13:00	0.0	0	0	0	0	1
02/21/2020 14:00	0.0	0	0	0	0	1
02/21/2020 15:00	0.0	0	0	0	0	1
02/21/2020 16:00	0.0	0	0	0	0	1
02/21/2020 17:00	0.0	0	0	0	0	1
02/21/2020 18:00	0.0	0	0	0	0	1
02/21/2020 19:00	0.0	0	0	0	0	1
02/21/2020 20:00	0.0	0	0	0	0	1
02/21/2020 21:00	0.0	0	0	0	0	1
02/21/2020 22:00	0.0	0	0	0	0	1
02/21/2020 23:00	1.1	0	0	0	1	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/22/2020 00:00	0.0	0	0	0	0	0
02/22/2020 01:00	0.0	0	0	0	0	0
02/22/2020 02:00	0.0	0	0	0	0	0
02/22/2020 03:00	0.0	0	0	0	0	0
02/22/2020 04:00	0.0	0	0	0	0	0
02/22/2020 05:00	0.0	0	0	0	0	0
02/22/2020 06:00	0.0	0	0	0	0	0
02/22/2020 07:00	0.0	0	0	0	0	0
02/22/2020 08:00	0.0	0	0	0	0	0
02/22/2020 09:00	0.0	0	0	0	0	0
02/22/2020 10:00	0.0	0	0	0	0	0
02/22/2020 11:00	0.0	0	0	0	0	0
02/22/2020 12:00	0.0	0	0	0	0	0
02/22/2020 13:00	0.0	0	0	0	0	0
02/22/2020 14:00	0.0	0	0	0	0	0
02/22/2020 15:00	0.0	0	0	0	0	0
02/22/2020 16:00	0.0	0	0	0	0	0
02/22/2020 17:00	0.0	0	0	0	0	0
02/22/2020 18:00	0.0	0	0	0	0	0
02/22/2020 19:00	0.0	0	0	0	0	0
02/22/2020 20:00	0.0	0	0	0	0	0
02/22/2020 21:00	0.0	0	0	0	0	0
02/22/2020 22:00	0.0	0	0	0	0	0
02/22/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/23/2020 00:00	0.0	0	0	0	0	0
02/23/2020 01:00	0.0	0	0	0	0	0
02/23/2020 02:00	0.0	0	0	0	0	0
02/23/2020 03:00	0.0	0	0	0	0	0
02/23/2020 04:00	0.0	0	0	0	0	0
02/23/2020 05:00	0.0	0	0	0	0	0
02/23/2020 06:00	0.0	0	0	0	0	0
02/23/2020 07:00	0.0	0	0	0	0	0
02/23/2020 08:00	0.0	0	0	0	0	0
02/23/2020 09:00	0.0	0	0	0	0	0
02/23/2020 10:00	0.0	0	0	0	0	0
02/23/2020 11:00	0.0	0	0	0	0	0
02/23/2020 12:00	0.0	0	0	0	0	0
02/23/2020 13:00	0.0	0	0	0	0	0
02/23/2020 14:00	0.0	0	0	0	0	0
02/23/2020 15:00	0.0	0	0	0	0	0
02/23/2020 16:00	0.0	0	0	0	0	0
02/23/2020 17:00	0.0	0	0	0	0	0
02/23/2020 18:00	0.0	0	0	0	0	0
02/23/2020 19:00	0.0	0	0	0	0	0
02/23/2020 20:00	0.0	0	0	0	0	0
02/23/2020 21:00	0.0	0	0	0	0	0
02/23/2020 22:00	0.0	0	0	0	0	0
02/23/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/24/2020 00:00	0.0	0	0	0	0	0
02/24/2020 01:00	0.0	0	0	0	0	0
02/24/2020 02:00	0.0	0	0	0	0	0
02/24/2020 03:00	0.0	0	0	0	0	0
02/24/2020 04:00	0.0	0	0	0	0	0
02/24/2020 05:00	0.0	0	0	0	0	0
02/24/2020 06:00	0.0	0	0	0	0	0
02/24/2020 07:00	0.0	0	0	0	0	0
02/24/2020 08:00	0.0	0	0	0	0	0
02/24/2020 09:00	0.0	0	0	0	0	0
02/24/2020 10:00	0.0	0	0	0	0	0
02/24/2020 11:00	0.0	0	0	0	0	0
02/24/2020 12:00	0.0	0	0	0	0	0
02/24/2020 13:00	71.0	0	1	0	0	0
02/24/2020 14:00	66.4	0	1	0	0	0
02/24/2020 15:00	72.0	0	1	0	0	0
02/24/2020 16:00	0.0	0	0	0	0	1
02/24/2020 17:00	0.0	0	0	0	0	1
02/24/2020 18:00	0.0	0	0	0	0	1
02/24/2020 19:00	0.0	0	0	0	0	1
02/24/2020 20:00	0.0	0	0	0	0	1
02/24/2020 21:00	0.0	0	0	0	0	1
02/24/2020 22:00	0.0	0	0	0	0	1
02/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	209.4 #	0 #	3 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/25/2020 00:00	0.0	0	0	0	0	1
02/25/2020 01:00	0.0	0	0	0	0	1
02/25/2020 02:00	0.0	0	0	0	0	1
02/25/2020 03:00	0.0	0	0	0	0	1
02/25/2020 04:00	0.0	0	0	0	0	1
02/25/2020 05:00	0.0	0	0	0	0	1
02/25/2020 06:00	0.0	0	0	0	0	1
02/25/2020 07:00	0.0	0	0	0	0	1
02/25/2020 08:00	0.0	0	0	0	0	1
02/25/2020 09:00	0.0	0	0	0	0	1
02/25/2020 10:00	0.0	0	0	0	0	1
02/25/2020 11:00	0.0	0	0	0	0	1
02/25/2020 12:00	0.0	0	0	0	0	1
02/25/2020 13:00	0.0	0	0	0	0	1
02/25/2020 14:00	0.0	0	0	0	0	1
02/25/2020 15:00	0.0	0	0	0	0	1
02/25/2020 16:00	0.0	0	0	0	0	1
02/25/2020 17:00	0.0	0	0	0	0	1
02/25/2020 18:00	0.0	0	0	0	0	1
02/25/2020 19:00	0.0	0	0	0	0	1
02/25/2020 20:00	0.0	0	0	0	0	1
02/25/2020 21:00	0.0	0	0	0	0	1
02/25/2020 22:00	0.0	0	0	0	0	1
02/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/26/2020 00:00	0.0	0	0	0	0	1
02/26/2020 01:00	0.0	0	0	0	0	1
02/26/2020 02:00	0.0	0	0	0	0	1
02/26/2020 03:00	0.0	0	0	0	0	1
02/26/2020 04:00	0.0	0	0	0	0	1
02/26/2020 05:00	0.0	0	0	0	0	1
02/26/2020 06:00	0.0	0	0	0	0	1
02/26/2020 07:00	0.0	0	0	0	0	1
02/26/2020 08:00	1.8	0	0	0	1	0
02/26/2020 09:00	0.0	0	0	0	0	0
02/26/2020 10:00	0.0	0	0	0	0	0
02/26/2020 11:00	0.0	0	0	0	0	0
02/26/2020 12:00	0.0	0	0	0	0	0
02/26/2020 13:00	0.0	0	0	0	0	0
02/26/2020 14:00	0.0	0	0	0	0	0
02/26/2020 15:00	50.0	0	0	1	0	0
02/26/2020 16:00	14.6	0	0	1	0	0
02/26/2020 17:00	0.0	0	0	0	0	1
02/26/2020 18:00	0.0	0	0	0	0	1
02/26/2020 19:00	0.0	0	0	0	0	1
02/26/2020 20:00	0.0	0	0	0	0	1
02/26/2020 21:00	0.0	0	0	0	0	1
02/26/2020 22:00	0.0	0	0	0	0	1
02/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	66.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/27/2020 00:00	0.0	0	0	0	0	1
02/27/2020 01:00	0.0	0	0	0	0	1
02/27/2020 02:00	0.0	0	0	0	0	1
02/27/2020 03:00	0.0	0	0	0	0	1
02/27/2020 04:00	0.0	0	0	0	0	1
02/27/2020 05:00	0.0	0	0	0	0	1
02/27/2020 06:00	0.0	0	0	0	0	1
02/27/2020 07:00	0.0	0	0	0	0	1
02/27/2020 08:00	0.0	0	0	0	0	1
02/27/2020 09:00	0.0	0	0	0	0	1
02/27/2020 10:00	0.0	0	0	0	0	1
02/27/2020 11:00	0.0	0	0	0	0	1
02/27/2020 12:00	0.0	0	0	0	0	1
02/27/2020 13:00	0.0	0	0	0	0	1
02/27/2020 14:00	0.0	0	0	0	0	1
02/27/2020 15:00	0.0	0	0	0	0	1
02/27/2020 16:00	0.0	0	0	0	0	1
02/27/2020 17:00	0.0	0	0	0	0	1
02/27/2020 18:00	0.0	0	0	0	0	1
02/27/2020 19:00	0.0	0	0	0	0	1
02/27/2020 20:00	0.0	0	0	0	0	1
02/27/2020 21:00	0.0	0	0	0	0	1
02/27/2020 22:00	0.0	0	0	0	0	1
02/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/28/2020 00:00	0.0	0	0	0	0	1
02/28/2020 01:00	0.0	0	0	0	0	1
02/28/2020 02:00	0.0	0	0	0	0	1
02/28/2020 03:00	0.0	0	0	0	0	1
02/28/2020 04:00	0.0	0	0	0	0	1
02/28/2020 05:00	0.0	0	0	0	0	1
02/28/2020 06:00	0.0	0	0	0	0	1
02/28/2020 07:00	0.0	0	0	0	0	1
02/28/2020 08:00	0.0	0	0	0	0	1
02/28/2020 09:00	0.0	0	0	0	0	1
02/28/2020 10:00	0.0	0	0	0	0	1
02/28/2020 11:00	0.0	0	0	0	0	1
02/28/2020 12:00	0.0	0	0	0	0	1
02/28/2020 13:00	0.0	0	0	0	0	1
02/28/2020 14:00	0.0	0	0	0	0	1
02/28/2020 15:00	0.0	0	0	0	0	1
02/28/2020 16:00	0.0	0	0	0	0	1
02/28/2020 17:00	0.0	0	0	0	0	1
02/28/2020 18:00	0.0	0	0	0	0	1
02/28/2020 19:00	0.0	0	0	0	0	1
02/28/2020 20:00	0.0	0	0	0	0	1
02/28/2020 21:00	0.0	0	0	0	0	1
02/28/2020 22:00	0.0	0	0	0	0	1
02/28/2020 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
02/29/2020 00:00	0.0	0	0	0	0	0
02/29/2020 01:00	0.0	0	0	0	0	0
02/29/2020 02:00	0.0	0	0	0	0	0
02/29/2020 03:00	0.0	0	0	0	0	0
02/29/2020 04:00	0.0	0	0	0	0	0
02/29/2020 05:00	0.0	0	0	0	0	0
02/29/2020 06:00	0.0	0	0	0	0	0
02/29/2020 07:00	0.0	0	0	0	0	0
02/29/2020 08:00	0.0	0	0	0	0	0
02/29/2020 09:00	0.0	0	0	0	0	0
02/29/2020 10:00	0.0	0	0	0	0	0
02/29/2020 11:00	0.0	0	0	0	0	0
02/29/2020 12:00	0.0	0	0	0	0	0
02/29/2020 13:00	0.0	0	0	0	0	0
02/29/2020 14:00	0.0	0	0	0	0	0
02/29/2020 15:00	0.0	0	0	0	0	0
02/29/2020 16:00	0.0	0	0	0	0	0
02/29/2020 17:00	0.0	0	0	0	0	0
02/29/2020 18:00	0.0	0	0	0	0	0
02/29/2020 19:00	0.0	0	0	0	0	0
02/29/2020 20:00	0.0	0	0	0	0	0
02/29/2020 21:00	0.0	0	0	0	0	0
02/29/2020 22:00	0.0	0	0	0	0	0
02/29/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/01/2020 00:00	0.0	0	0	0	0	0
03/01/2020 01:00	0.0	0	0	0	0	0
03/01/2020 02:00	0.0	0	0	0	0	0
03/01/2020 03:00	0.0	0	0	0	0	0
03/01/2020 04:00	0.0	0	0	0	0	0
03/01/2020 05:00	0.0	0	0	0	0	0
03/01/2020 06:00	0.0	0	0	0	0	0
03/01/2020 07:00	0.0	0	0	0	0	0
03/01/2020 08:00	0.0	0	0	0	0	0
03/01/2020 09:00	0.0	0	0	0	0	0
03/01/2020 10:00	0.0	0	0	0	0	0
03/01/2020 11:00	0.0	0	0	0	0	0
03/01/2020 12:00	0.0	0	0	0	0	0
03/01/2020 13:00	0.0	0	0	0	0	0
03/01/2020 14:00	0.0	0	0	0	0	0
03/01/2020 15:00	0.0	0	0	0	0	0
03/01/2020 16:00	0.0	0	0	0	0	0
03/01/2020 17:00	0.0	0	0	0	0	0
03/01/2020 18:00	0.0	0	0	0	0	0
03/01/2020 19:00	0.0	0	0	0	0	0
03/01/2020 20:00	0.0	0	0	0	0	0
03/01/2020 21:00	0.0	0	0	0	0	0
03/01/2020 22:00	0.0	0	0	0	0	0
03/01/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/02/2020 00:00	0.0	0	0	0	0	0
03/02/2020 01:00	0.0	0	0	0	0	0
03/02/2020 02:00	0.0	0	0	0	0	0
03/02/2020 03:00	0.0	0	0	0	0	0
03/02/2020 04:00	0.0	0	0	0	0	0
03/02/2020 05:00	0.0	0	0	0	0	0
03/02/2020 06:00	0.0	0	0	0	0	0
03/02/2020 07:00	0.0	0	0	0	0	0
03/02/2020 08:00	0.0	0	0	0	0	0
03/02/2020 09:00	0.0	0	0	0	0	0
03/02/2020 10:00	0.0	0	0	0	0	0
03/02/2020 11:00	0.0	0	0	0	0	0
03/02/2020 12:00	0.0	0	0	0	0	0
03/02/2020 13:00	0.0	0	0	0	0	0
03/02/2020 14:00	0.0	0	0	0	0	0
03/02/2020 15:00	0.0	0	0	0	0	0
03/02/2020 16:00	0.0	0	0	0	0	0
03/02/2020 17:00	0.0	0	0	0	0	0
03/02/2020 18:00	0.0	0	0	0	0	0
03/02/2020 19:00	0.0	0	0	0	0	0
03/02/2020 20:00	0.0	0	0	0	0	0
03/02/2020 21:00	0.0	0	0	0	0	0
03/02/2020 22:00	0.0	0	0	0	0	0
03/02/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/03/2020 00:00	0.0	0	0	0	0	0
03/03/2020 01:00	0.0	0	0	0	0	0
03/03/2020 02:00	0.0	0	0	0	0	0
03/03/2020 03:00	0.0	0	0	0	0	0
03/03/2020 04:00	0.0	0	0	0	0	0
03/03/2020 05:00	0.0	0	0	0	0	0
03/03/2020 06:00	0.0	0	0	0	0	0
03/03/2020 07:00	0.0	0	0	0	0	0
03/03/2020 08:00	4.4	1	0	0	0	0
03/03/2020 09:00	90.1	1	0	0	0	0
03/03/2020 10:00	34.4	1	0	0	0	0
03/03/2020 11:00	65.7	1	0	0	0	0
03/03/2020 12:00	24.2	1	0	0	0	0
03/03/2020 13:00	0.0	0	0	0	0	1
03/03/2020 14:00	0.0	0	0	0	0	1
03/03/2020 15:00	0.0	0	0	0	0	1
03/03/2020 16:00	0.0	0	0	0	0	1
03/03/2020 17:00	0.0	0	0	0	0	1
03/03/2020 18:00	0.0	0	0	0	0	1
03/03/2020 19:00	0.0	0	0	0	0	1
03/03/2020 20:00	0.0	0	0	0	0	1
03/03/2020 21:00	0.0	0	0	0	0	1
03/03/2020 22:00	0.0	0	0	0	0	1
03/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	218.8 #	5 #	0 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	90.1	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/04/2020 00:00	0.0	0	0	0	0	1
03/04/2020 01:00	0.0	0	0	0	0	1
03/04/2020 02:00	0.0	0	0	0	0	1
03/04/2020 03:00	0.0	0	0	0	0	1
03/04/2020 04:00	0.0	0	0	0	0	1
03/04/2020 05:00	0.0	0	0	0	0	1
03/04/2020 06:00	0.0	0	0	0	0	1
03/04/2020 07:00	0.0	0	0	0	0	1
03/04/2020 08:00	0.0	0	0	0	0	1
03/04/2020 09:00	0.0	0	0	0	0	1
03/04/2020 10:00	0.0	0	0	0	0	1
03/04/2020 11:00	0.0	0	0	0	0	1
03/04/2020 12:00	0.0	0	0	0	0	1
03/04/2020 13:00	0.0	0	0	0	0	1
03/04/2020 14:00	0.0	0	0	0	0	1
03/04/2020 15:00	0.0	0	0	0	0	1
03/04/2020 16:00	0.0	0	0	0	0	1
03/04/2020 17:00	0.0	0	0	0	0	1
03/04/2020 18:00	0.0	0	0	0	0	1
03/04/2020 19:00	0.0	0	0	0	0	1
03/04/2020 20:00	0.0	0	0	0	0	1
03/04/2020 21:00	0.0	0	0	0	0	1
03/04/2020 22:00	0.0	0	0	0	0	1
03/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/05/2020 00:00	0.0	0	0	0	0	1
03/05/2020 01:00	0.0	0	0	0	0	1
03/05/2020 02:00	0.0	0	0	0	0	1
03/05/2020 03:00	0.0	0	0	0	0	1
03/05/2020 04:00	0.0	0	0	0	0	1
03/05/2020 05:00	0.0	0	0	0	0	1
03/05/2020 06:00	0.0	0	0	0	0	1
03/05/2020 07:00	0.0	0	0	0	0	1
03/05/2020 08:00	0.0	0	0	0	0	1
03/05/2020 09:00	0.0	0	0	0	0	1
03/05/2020 10:00	0.0	0	0	0	0	1
03/05/2020 11:00	0.0	0	0	0	0	1
03/05/2020 12:00	0.0	0	0	0	0	1
03/05/2020 13:00	0.0	0	0	0	0	1
03/05/2020 14:00	0.0	0	0	0	0	1
03/05/2020 15:00	0.0	0	0	0	0	1
03/05/2020 16:00	0.0	0	0	0	0	1
03/05/2020 17:00	0.0	0	0	0	0	1
03/05/2020 18:00	0.0	0	0	0	0	1
03/05/2020 19:00	0.0	0	0	0	0	1
03/05/2020 20:00	0.0	0	0	0	0	1
03/05/2020 21:00	0.0	0	0	0	0	1
03/05/2020 22:00	0.0	0	0	0	0	1
03/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/06/2020 00:00	0.0	0	0	0	0	1
03/06/2020 01:00	0.0	0	0	0	0	1
03/06/2020 02:00	0.0	0	0	0	0	1
03/06/2020 03:00	0.0	0	0	0	0	1
03/06/2020 04:00	0.0	0	0	0	0	1
03/06/2020 05:00	0.0	0	0	0	0	1
03/06/2020 06:00	0.0	0	0	0	0	1
03/06/2020 07:00	0.0	0	0	0	0	1
03/06/2020 08:00	0.0	0	0	0	0	1
03/06/2020 09:00	0.0	0	0	0	0	1
03/06/2020 10:00	0.0	0	0	0	0	1
03/06/2020 11:00	0.0	0	0	0	0	1
03/06/2020 12:00	0.0	0	0	0	0	1
03/06/2020 13:00	0.0	0	0	0	0	1
03/06/2020 14:00	0.0	0	0	0	0	1
03/06/2020 15:00	0.0	0	0	0	0	1
03/06/2020 16:00	0.0	0	0	0	0	1
03/06/2020 17:00	0.0	0	0	0	0	1
03/06/2020 18:00	0.0	0	0	0	0	1
03/06/2020 19:00	0.0	0	0	0	0	1
03/06/2020 20:00	0.0	0	0	0	0	1
03/06/2020 21:00	0.0	0	0	0	0	1
03/06/2020 22:00	0.0	0	0	0	0	1
03/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/07/2020 00:00	1.5	0	0	0	1	0
03/07/2020 01:00	0.0	0	0	0	0	0
03/07/2020 02:00	0.0	0	0	0	0	0
03/07/2020 03:00	0.0	0	0	0	0	0
03/07/2020 04:00	0.0	0	0	0	0	0
03/07/2020 05:00	0.0	0	0	0	0	0
03/07/2020 06:00	0.0	0	0	0	0	0
03/07/2020 07:00	0.0	0	0	0	0	0
03/07/2020 08:00	0.0	0	0	0	0	0
03/07/2020 09:00	0.0	0	0	0	0	0
03/07/2020 10:00	0.0	0	0	0	0	0
03/07/2020 11:00	0.0	0	0	0	0	0
03/07/2020 12:00	0.0	0	0	0	0	0
03/07/2020 13:00	0.0	0	0	0	0	0
03/07/2020 14:00	0.0	0	0	0	0	0
03/07/2020 15:00	0.0	0	0	0	0	0
03/07/2020 16:00	0.0	0	0	0	0	0
03/07/2020 17:00	0.0	0	0	0	0	0
03/07/2020 18:00	0.0	0	0	0	0	0
03/07/2020 19:00	0.0	0	0	0	0	0
03/07/2020 20:00	0.0	0	0	0	0	0
03/07/2020 21:00	0.0	0	0	0	0	0
03/07/2020 22:00	0.0	0	0	0	0	0
03/07/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/08/2020 00:00	0.0	0	0	0	0	0
03/08/2020 01:00	0.0	0	0	0	0	0
03/08/2020 02:00	0.0	0	0	0	0	0
03/08/2020 03:00	0.0	0	0	0	0	0
03/08/2020 04:00	0.0	0	0	0	0	0
03/08/2020 05:00	0.0	0	0	0	0	0
03/08/2020 06:00	0.0	0	0	0	0	0
03/08/2020 07:00	0.0	0	0	0	0	0
03/08/2020 08:00	0.0	0	0	0	0	0
03/08/2020 09:00	0.0	0	0	0	0	0
03/08/2020 10:00	0.0	0	0	0	0	0
03/08/2020 11:00	0.0	0	0	0	0	0
03/08/2020 12:00	0.0	0	0	0	0	0
03/08/2020 13:00	0.0	0	0	0	0	0
03/08/2020 14:00	0.0	0	0	0	0	0
03/08/2020 15:00	0.0	0	0	0	0	0
03/08/2020 16:00	0.0	0	0	0	0	0
03/08/2020 17:00	0.0	0	0	0	0	0
03/08/2020 18:00	0.0	0	0	0	0	0
03/08/2020 19:00	0.0	0	0	0	0	0
03/08/2020 20:00	60.4	0	1	0	0	0
03/08/2020 21:00	34.4	0	1	0	0	0
03/08/2020 22:00	13.3	0	1	0	0	0
03/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	108.1 #	0 #	3 #	0 #	0 #	1 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/09/2020 00:00	0.0	0	0	0	0	1
03/09/2020 01:00	0.0	0	0	0	0	1
03/09/2020 02:00	0.0	0	0	0	0	1
03/09/2020 03:00	0.0	0	0	0	0	1
03/09/2020 04:00	0.0	0	0	0	0	1
03/09/2020 05:00	0.0	0	0	0	0	1
03/09/2020 06:00	0.0	0	0	0	0	1
03/09/2020 07:00	0.0	0	0	0	0	1
03/09/2020 08:00	0.0	0	0	0	0	1
03/09/2020 09:00	0.0	0	0	0	0	1
03/09/2020 10:00	0.0	0	0	0	0	1
03/09/2020 11:00	0.0	0	0	0	0	1
03/09/2020 12:00	0.0	0	0	0	0	1
03/09/2020 13:00	0.0	0	0	0	0	1
03/09/2020 14:00	0.0	0	0	0	0	1
03/09/2020 15:00	0.0	0	0	0	0	1
03/09/2020 16:00	0.0	0	0	0	0	1
03/09/2020 17:00	0.0	0	0	0	0	1
03/09/2020 18:00	0.0	0	0	0	0	1
03/09/2020 19:00	0.0	0	0	0	0	1
03/09/2020 20:00	0.0	0	0	0	0	1
03/09/2020 21:00	0.0	0	0	0	0	1
03/09/2020 22:00	0.0	0	0	0	0	1
03/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/10/2020 00:00	0.0	0	0	0	0	1
03/10/2020 01:00	0.0	0	0	0	0	1
03/10/2020 02:00	0.0	0	0	0	0	1
03/10/2020 03:00	0.0	0	0	0	0	1
03/10/2020 04:00	0.0	0	0	0	0	1
03/10/2020 05:00	0.0	0	0	0	0	1
03/10/2020 06:00	0.0	0	0	0	0	1
03/10/2020 07:00	0.0	0	0	0	0	1
03/10/2020 08:00	0.0	0	0	0	0	1
03/10/2020 09:00	0.0	0	0	0	0	1
03/10/2020 10:00	0.0	0	0	0	0	1
03/10/2020 11:00	0.0	0	0	0	0	1
03/10/2020 12:00	0.0	0	0	0	0	1
03/10/2020 13:00	0.0	0	0	0	0	1
03/10/2020 14:00	0.0	0	0	0	0	1
03/10/2020 15:00	0.0	0	0	0	0	1
03/10/2020 16:00	0.0	0	0	0	0	1
03/10/2020 17:00	0.0	0	0	0	0	1
03/10/2020 18:00	0.0	0	0	0	0	1
03/10/2020 19:00	0.0	0	0	0	0	1
03/10/2020 20:00	0.0	0	0	0	0	1
03/10/2020 21:00	0.0	0	0	0	0	1
03/10/2020 22:00	0.0	0	0	0	0	1
03/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/11/2020 00:00	0.0	0	0	0	0	1
03/11/2020 01:00	0.0	0	0	0	0	1
03/11/2020 02:00	0.0	0	0	0	0	1
03/11/2020 03:00	0.0	0	0	0	0	1
03/11/2020 04:00	0.0	0	0	0	0	1
03/11/2020 05:00	0.0	0	0	0	0	1
03/11/2020 06:00	0.0	0	0	0	0	1
03/11/2020 07:00	0.0	0	0	0	0	1
03/11/2020 08:00	0.0	0	0	0	0	1
03/11/2020 09:00	0.0	0	0	0	0	1
03/11/2020 10:00	0.0	0	0	0	0	1
03/11/2020 11:00	0.0	0	0	0	0	1
03/11/2020 12:00	0.0	0	0	0	0	1
03/11/2020 13:00	0.0	0	0	0	0	1
03/11/2020 14:00	0.0	0	0	0	0	1
03/11/2020 15:00	0.0	0	0	0	0	1
03/11/2020 16:00	0.0	0	0	0	0	1
03/11/2020 17:00	0.0	0	0	0	0	1
03/11/2020 18:00	0.0	0	0	0	0	1
03/11/2020 19:00	0.0	0	0	0	0	1
03/11/2020 20:00	0.0	0	0	0	0	1
03/11/2020 21:00	0.0	0	0	0	0	1
03/11/2020 22:00	0.0	0	0	0	0	1
03/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/12/2020 00:00	0.0	0	0	0	0	1
03/12/2020 01:00	0.0	0	0	0	0	1
03/12/2020 02:00	0.0	0	0	0	0	1
03/12/2020 03:00	0.0	0	0	0	0	1
03/12/2020 04:00	0.0	0	0	0	0	1
03/12/2020 05:00	0.0	0	0	0	0	1
03/12/2020 06:00	0.0	0	0	0	0	1
03/12/2020 07:00	0.0	0	0	0	0	1
03/12/2020 08:00	0.0	0	0	0	0	1
03/12/2020 09:00	0.0	0	0	0	0	1
03/12/2020 10:00	0.0	0	0	0	0	1
03/12/2020 11:00	0.0	0	0	0	0	1
03/12/2020 12:00	0.0	0	0	0	0	1
03/12/2020 13:00	0.0	0	0	0	0	1
03/12/2020 14:00	0.0	0	0	0	0	1
03/12/2020 15:00	0.0	0	0	0	0	1
03/12/2020 16:00	0.0	0	0	0	0	1
03/12/2020 17:00	0.0	0	0	0	0	1
03/12/2020 18:00	0.0	0	0	0	0	1
03/12/2020 19:00	0.0	0	0	0	0	1
03/12/2020 20:00	0.0	0	0	0	0	1
03/12/2020 21:00	0.0	0	0	0	0	1
03/12/2020 22:00	0.0	0	0	0	0	1
03/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/13/2020 00:00	0.0	0	0	0	0	1
03/13/2020 01:00	0.0	0	0	0	0	1
03/13/2020 02:00	0.0	0	0	0	0	1
03/13/2020 03:00	0.0	0	0	0	0	1
03/13/2020 04:00	0.0	0	0	0	0	1
03/13/2020 05:00	0.0	0	0	0	0	1
03/13/2020 06:00	0.0	0	0	0	0	1
03/13/2020 07:00	0.0	0	0	0	0	1
03/13/2020 08:00	0.0	0	0	0	0	1
03/13/2020 09:00	0.0	0	0	0	0	1
03/13/2020 10:00	0.0	0	0	0	0	1
03/13/2020 11:00	0.0	0	0	0	0	1
03/13/2020 12:00	0.0	0	0	0	0	1
03/13/2020 13:00	0.0	0	0	0	0	1
03/13/2020 14:00	0.0	0	0	0	0	1
03/13/2020 15:00	0.0	0	0	0	0	1
03/13/2020 16:00	0.0	0	0	0	0	1
03/13/2020 17:00	0.0	0	0	0	0	1
03/13/2020 18:00	0.0	0	0	0	0	1
03/13/2020 19:00	0.0	0	0	0	0	1
03/13/2020 20:00	0.0	0	0	0	0	1
03/13/2020 21:00	0.0	0	0	0	0	1
03/13/2020 22:00	0.0	0	0	0	0	1
03/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/14/2020 00:00	0.0	0	0	0	0	1
03/14/2020 01:00	0.0	0	0	0	0	1
03/14/2020 02:00	0.0	0	0	0	0	1
03/14/2020 03:00	0.0	0	0	0	0	1
03/14/2020 04:00	0.0	0	0	0	0	1
03/14/2020 05:00	0.0	0	0	0	0	1
03/14/2020 06:00	0.0	0	0	0	0	1
03/14/2020 07:00	0.0	0	0	0	0	1
03/14/2020 08:00	0.0	0	0	0	0	1
03/14/2020 09:00	0.0	0	0	0	0	1
03/14/2020 10:00	0.0	0	0	0	0	1
03/14/2020 11:00	0.0	0	0	0	0	1
03/14/2020 12:00	0.0	0	0	0	0	1
03/14/2020 13:00	0.0	0	0	0	0	1
03/14/2020 14:00	0.0	0	0	0	0	1
03/14/2020 15:00	0.0	0	0	0	0	1
03/14/2020 16:00	0.0	0	0	0	0	1
03/14/2020 17:00	0.0	0	0	0	0	1
03/14/2020 18:00	0.0	0	0	0	0	1
03/14/2020 19:00	0.0	0	0	0	0	1
03/14/2020 20:00	0.0	0	0	0	0	1
03/14/2020 21:00	0.0	0	0	0	0	1
03/14/2020 22:00	0.0	0	0	0	0	1
03/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/15/2020 00:00	0.0	0	0	0	0	1
03/15/2020 01:00	0.0	0	0	0	0	1
03/15/2020 02:00	0.0	0	0	0	0	1
03/15/2020 03:00	0.0	0	0	0	0	1
03/15/2020 04:00	0.0	0	0	0	0	1
03/15/2020 05:00	0.0	0	0	0	0	1
03/15/2020 06:00	0.0	0	0	0	0	1
03/15/2020 07:00	0.0	0	0	0	0	1
03/15/2020 08:00	0.0	0	0	0	0	1
03/15/2020 09:00	0.0	0	0	0	0	1
03/15/2020 10:00	0.0	0	0	0	0	1
03/15/2020 11:00	0.0	0	0	0	0	1
03/15/2020 12:00	0.0	0	0	0	0	1
03/15/2020 13:00	0.0	0	0	0	0	1
03/15/2020 14:00	0.0	0	0	0	0	1
03/15/2020 15:00	0.0	0	0	0	0	1
03/15/2020 16:00	0.0	0	0	0	0	1
03/15/2020 17:00	0.0	0	0	0	0	1
03/15/2020 18:00	0.0	0	0	0	0	1
03/15/2020 19:00	0.0	0	0	0	0	1
03/15/2020 20:00	0.0	0	0	0	0	1
03/15/2020 21:00	0.0	0	0	0	0	1
03/15/2020 22:00	0.0	0	0	0	0	1
03/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/16/2020 00:00	0.0	0	0	0	0	1
03/16/2020 01:00	0.0	0	0	0	0	1
03/16/2020 02:00	0.0	0	0	0	0	1
03/16/2020 03:00	0.0	0	0	0	0	1
03/16/2020 04:00	0.0	0	0	0	0	1
03/16/2020 05:00	0.0	0	0	0	0	1
03/16/2020 06:00	0.0	0	0	0	0	1
03/16/2020 07:00	0.0	0	0	0	0	1
03/16/2020 08:00	0.0	0	0	0	0	1
03/16/2020 09:00	0.0	0	0	0	0	1
03/16/2020 10:00	0.0	0	0	0	0	1
03/16/2020 11:00	0.0	0	0	0	0	1
03/16/2020 12:00	0.0	0	0	0	0	1
03/16/2020 13:00	0.0	0	0	0	0	1
03/16/2020 14:00	0.0	0	0	0	0	1
03/16/2020 15:00	0.0	0	0	0	0	1
03/16/2020 16:00	0.0	0	0	0	0	1
03/16/2020 17:00	0.0	0	0	0	0	1
03/16/2020 18:00	0.0	0	0	0	0	1
03/16/2020 19:00	0.0	0	0	0	0	1
03/16/2020 20:00	0.0	0	0	0	0	1
03/16/2020 21:00	0.0	0	0	0	0	1
03/16/2020 22:00	0.0	0	0	0	0	1
03/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/17/2020 00:00	0.0	0	0	0	0	1
03/17/2020 01:00	0.0	0	0	0	0	1
03/17/2020 02:00	0.0	0	0	0	0	1
03/17/2020 03:00	0.0	0	0	0	0	1
03/17/2020 04:00	0.0	0	0	0	0	1
03/17/2020 05:00	0.0	0	0	0	0	1
03/17/2020 06:00	0.0	0	0	0	0	1
03/17/2020 07:00	0.0	0	0	0	0	1
03/17/2020 08:00	0.0	0	0	0	0	1
03/17/2020 09:00	0.0	0	0	0	0	1
03/17/2020 10:00	0.0	0	0	0	0	1
03/17/2020 11:00	0.0	0	0	0	0	1
03/17/2020 12:00	0.0	0	0	0	0	1
03/17/2020 13:00	0.0	0	0	0	0	1
03/17/2020 14:00	0.0	0	0	0	0	1
03/17/2020 15:00	0.0	0	0	0	0	1
03/17/2020 16:00	0.0	0	0	0	0	1
03/17/2020 17:00	0.0	0	0	0	0	1
03/17/2020 18:00	0.0	0	0	0	0	1
03/17/2020 19:00	0.0	0	0	0	0	1
03/17/2020 20:00	0.0	0	0	0	0	1
03/17/2020 21:00	0.0	0	0	0	0	1
03/17/2020 22:00	0.0	0	0	0	0	1
03/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/18/2020 00:00	0.0	0	0	0	0	1
03/18/2020 01:00	0.0	0	0	0	0	1
03/18/2020 02:00	0.0	0	0	0	0	1
03/18/2020 03:00	0.0	0	0	0	0	1
03/18/2020 04:00	0.0	0	0	0	0	1
03/18/2020 05:00	0.0	0	0	0	0	1
03/18/2020 06:00	0.0	0	0	0	0	1
03/18/2020 07:00	0.0	0	0	0	0	1
03/18/2020 08:00	0.0	0	0	0	0	1
03/18/2020 09:00	0.0	0	0	0	0	1
03/18/2020 10:00	0.0	0	0	0	0	1
03/18/2020 11:00	0.0	0	0	0	0	1
03/18/2020 12:00	0.0	0	0	0	0	1
03/18/2020 13:00	0.0	0	0	0	0	1
03/18/2020 14:00	0.0	0	0	0	0	1
03/18/2020 15:00	0.0	0	0	0	0	1
03/18/2020 16:00	0.0	0	0	0	0	1
03/18/2020 17:00	0.0	0	0	0	0	1
03/18/2020 18:00	0.0	0	0	0	0	1
03/18/2020 19:00	0.0	0	0	0	0	1
03/18/2020 20:00	0.0	0	0	0	0	1
03/18/2020 21:00	0.0	0	0	0	0	1
03/18/2020 22:00	0.0	0	0	0	0	1
03/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/19/2020 00:00	0.0	0	0	0	0	1
03/19/2020 01:00	0.0	0	0	0	0	1
03/19/2020 02:00	0.0	0	0	0	0	1
03/19/2020 03:00	0.0	0	0	0	0	1
03/19/2020 04:00	0.0	0	0	0	0	1
03/19/2020 05:00	0.0	0	0	0	0	1
03/19/2020 06:00	0.0	0	0	0	0	1
03/19/2020 07:00	0.0	0	0	0	0	1
03/19/2020 08:00	0.0	0	0	0	0	1
03/19/2020 09:00	0.0	0	0	0	0	1
03/19/2020 10:00	0.0	0	0	0	0	1
03/19/2020 11:00	0.0	0	0	0	0	1
03/19/2020 12:00	0.0	0	0	0	0	1
03/19/2020 13:00	0.0	0	0	0	0	1
03/19/2020 14:00	0.0	0	0	0	0	1
03/19/2020 15:00	0.0	0	0	0	0	1
03/19/2020 16:00	0.0	0	0	0	0	1
03/19/2020 17:00	0.0	0	0	0	0	1
03/19/2020 18:00	0.0	0	0	0	0	1
03/19/2020 19:00	0.0	0	0	0	0	1
03/19/2020 20:00	0.0	0	0	0	0	1
03/19/2020 21:00	0.0	0	0	0	0	1
03/19/2020 22:00	0.0	0	0	0	0	1
03/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/20/2020 00:00	0.0	0	0	0	0	1
03/20/2020 01:00	0.0	0	0	0	0	1
03/20/2020 02:00	0.0	0	0	0	0	1
03/20/2020 03:00	0.0	0	0	0	0	1
03/20/2020 04:00	0.0	0	0	0	0	1
03/20/2020 05:00	0.0	0	0	0	0	1
03/20/2020 06:00	0.0	0	0	0	0	1
03/20/2020 07:00	0.0	0	0	0	0	1
03/20/2020 08:00	0.0	0	0	0	0	1
03/20/2020 09:00	0.0	0	0	0	0	1
03/20/2020 10:00	0.0	0	0	0	0	1
03/20/2020 11:00	0.0	0	0	0	0	1
03/20/2020 12:00	0.0	0	0	0	0	1
03/20/2020 13:00	0.0	0	0	0	0	1
03/20/2020 14:00	0.0	0	0	0	0	1
03/20/2020 15:00	0.0	0	0	0	0	1
03/20/2020 16:00	0.0	0	0	0	0	1
03/20/2020 17:00	0.0	0	0	0	0	1
03/20/2020 18:00	0.0	0	0	0	0	1
03/20/2020 19:00	0.0	0	0	0	0	1
03/20/2020 20:00	0.0	0	0	0	0	1
03/20/2020 21:00	0.0	0	0	0	0	1
03/20/2020 22:00	0.0	0	0	0	0	1
03/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/21/2020 00:00	0.0	0	0	0	0	1
03/21/2020 01:00	0.0	0	0	0	0	1
03/21/2020 02:00	0.0	0	0	0	0	1
03/21/2020 03:00	0.0	0	0	0	0	1
03/21/2020 04:00	0.0	0	0	0	0	1
03/21/2020 05:00	0.0	0	0	0	0	1
03/21/2020 06:00	0.0	0	0	0	0	1
03/21/2020 07:00	1.4	0	0	0	1	0
03/21/2020 08:00	0.0	0	0	0	0	0
03/21/2020 09:00	0.0	0	0	0	0	0
03/21/2020 10:00	0.0	0	0	0	0	0
03/21/2020 11:00	0.0	0	0	0	0	0
03/21/2020 12:00	0.0	0	0	0	0	0
03/21/2020 13:00	0.0	0	0	0	0	0
03/21/2020 14:00	0.0	0	0	0	0	0
03/21/2020 15:00	0.0	0	0	0	0	0
03/21/2020 16:00	0.0	0	0	0	0	0
03/21/2020 17:00	0.0	0	0	0	0	0
03/21/2020 18:00	0.0	0	0	0	0	0
03/21/2020 19:00	0.0	0	0	0	0	0
03/21/2020 20:00	0.0	0	0	0	0	0
03/21/2020 21:00	0.0	0	0	0	0	0
03/21/2020 22:00	0.0	0	0	0	0	0
03/21/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/22/2020 00:00	0.0	0	0	0	0	0
03/22/2020 01:00	0.0	0	0	0	0	0
03/22/2020 02:00	0.0	0	0	0	0	0
03/22/2020 03:00	0.0	0	0	0	0	0
03/22/2020 04:00	0.0	0	0	0	0	0
03/22/2020 05:00	0.0	0	0	0	0	0
03/22/2020 06:00	0.0	0	0	0	0	0
03/22/2020 07:00	0.0	0	0	0	0	0
03/22/2020 08:00	0.0	0	0	0	0	0
03/22/2020 09:00	0.0	0	0	0	0	0
03/22/2020 10:00	0.0	0	0	0	0	0
03/22/2020 11:00	0.0	0	0	0	0	0
03/22/2020 12:00	0.0	0	0	0	0	0
03/22/2020 13:00	0.0	0	0	0	0	0
03/22/2020 14:00	0.0	0	0	0	0	0
03/22/2020 15:00	0.0	0	0	0	0	0
03/22/2020 16:00	0.0	0	0	0	0	0
03/22/2020 17:00	74.7	0	1	0	0	0
03/22/2020 18:00	36.0	0	1	0	0	0
03/22/2020 19:00	32.5	0	1	0	0	0
03/22/2020 20:00	0.0	0	0	0	0	1
03/22/2020 21:00	0.0	0	0	0	0	1
03/22/2020 22:00	0.0	0	0	0	0	1
03/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	143.2 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/23/2020 00:00	0.0	0	0	0	0	1
03/23/2020 01:00	0.0	0	0	0	0	1
03/23/2020 02:00	1.0	0	0	0	1	0
03/23/2020 03:00	0.0	0	0	0	0	0
03/23/2020 04:00	0.0	0	0	0	0	0
03/23/2020 05:00	0.0	0	0	0	0	0
03/23/2020 06:00	0.0	0	0	0	0	0
03/23/2020 07:00	0.0	0	0	0	0	0
03/23/2020 08:00	0.0	0	0	0	0	0
03/23/2020 09:00	0.0	0	0	0	0	0
03/23/2020 10:00	0.0	0	0	0	0	0
03/23/2020 11:00	0.0	0	0	0	0	0
03/23/2020 12:00	0.0	0	0	0	0	0
03/23/2020 13:00	0.0	0	0	0	0	0
03/23/2020 14:00	0.0	0	0	0	0	0
03/23/2020 15:00	0.0	0	0	0	0	0
03/23/2020 16:00	0.0	0	0	0	0	0
03/23/2020 17:00	68.9	0	1	0	0	0
03/23/2020 18:00	33.9	0	1	0	0	0
03/23/2020 19:00	40.3	0	1	0	0	0
03/23/2020 20:00	0.0	0	0	0	0	1
03/23/2020 21:00	0.0	0	0	0	0	1
03/23/2020 22:00	0.0	0	0	0	0	1
03/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	144.1 #	0 #	3 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/24/2020 00:00	0.0	0	0	0	0	1
03/24/2020 01:00	0.0	0	0	0	0	1
03/24/2020 02:00	0.0	0	0	0	0	1
03/24/2020 03:00	0.0	0	0	0	0	1
03/24/2020 04:00	0.0	0	0	0	0	1
03/24/2020 05:00	0.0	0	0	0	0	1
03/24/2020 06:00	0.0	0	0	0	0	1
03/24/2020 07:00	0.0	0	0	0	0	1
03/24/2020 08:00	0.0	0	0	0	0	1
03/24/2020 09:00	0.0	0	0	0	0	1
03/24/2020 10:00	0.0	0	0	0	0	1
03/24/2020 11:00	0.0	0	0	0	0	1
03/24/2020 12:00	0.0	0	0	0	0	1
03/24/2020 13:00	0.0	0	0	0	0	1
03/24/2020 14:00	0.0	0	0	0	0	1
03/24/2020 15:00	0.0	0	0	0	0	1
03/24/2020 16:00	0.0	0	0	0	0	1
03/24/2020 17:00	0.0	0	0	0	0	1
03/24/2020 18:00	0.0	0	0	0	0	1
03/24/2020 19:00	0.0	0	0	0	0	1
03/24/2020 20:00	0.0	0	0	0	0	1
03/24/2020 21:00	0.0	0	0	0	0	1
03/24/2020 22:00	0.0	0	0	0	0	1
03/24/2020 23:00	1.6	0	0	0	1	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/25/2020 00:00	0.0	0	0	0	0	0
03/25/2020 01:00	0.0	0	0	0	0	0
03/25/2020 02:00	0.0	0	0	0	0	0
03/25/2020 03:00	0.0	0	0	0	0	0
03/25/2020 04:00	0.0	0	0	0	0	0
03/25/2020 05:00	0.0	0	0	0	0	0
03/25/2020 06:00	0.0	0	0	0	0	0
03/25/2020 07:00	0.0	0	0	0	0	0
03/25/2020 08:00	0.0	0	0	0	0	0
03/25/2020 09:00	0.0	0	0	0	0	0
03/25/2020 10:00	0.0	0	0	0	0	0
03/25/2020 11:00	0.0	0	0	0	0	0
03/25/2020 12:00	0.0	0	0	0	0	0
03/25/2020 13:00	0.0	0	0	0	0	0
03/25/2020 14:00	0.0	0	0	0	0	0
03/25/2020 15:00	0.0	0	0	0	0	0
03/25/2020 16:00	0.0	0	0	0	0	0
03/25/2020 17:00	0.0	0	0	0	0	0
03/25/2020 18:00	0.0	0	0	0	0	0
03/25/2020 19:00	0.0	0	0	0	0	0
03/25/2020 20:00	0.0	0	0	0	0	0
03/25/2020 21:00	0.0	0	0	0	0	0
03/25/2020 22:00	0.0	0	0	0	0	0
03/25/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/26/2020 00:00	0.0	0	0	0	0	0
03/26/2020 01:00	0.0	0	0	0	0	0
03/26/2020 02:00	0.0	0	0	0	0	0
03/26/2020 03:00	0.0	0	0	0	0	0
03/26/2020 04:00	0.0	0	0	0	0	0
03/26/2020 05:00	0.0	0	0	0	0	0
03/26/2020 06:00	0.0	0	0	0	0	0
03/26/2020 07:00	0.0	0	0	0	0	0
03/26/2020 08:00	0.0	0	0	0	0	0
03/26/2020 09:00	0.0	0	0	0	0	0
03/26/2020 10:00	0.0	0	0	0	0	0
03/26/2020 11:00	0.0	0	0	0	0	0
03/26/2020 12:00	0.0	0	0	0	0	0
03/26/2020 13:00	0.0	0	0	0	0	0
03/26/2020 14:00	0.0	0	0	0	0	0
03/26/2020 15:00	0.0	0	0	0	0	0
03/26/2020 16:00	0.0	0	0	0	0	0
03/26/2020 17:00	0.0	0	0	0	0	0
03/26/2020 18:00	0.0	0	0	0	0	0
03/26/2020 19:00	0.0	0	0	0	0	0
03/26/2020 20:00	0.0	0	0	0	0	0
03/26/2020 21:00	0.0	0	0	0	0	0
03/26/2020 22:00	0.0	0	0	0	0	0
03/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/27/2020 00:00	0.0	0	0	0	0	0
03/27/2020 01:00	0.0	0	0	0	0	0
03/27/2020 02:00	0.0	0	0	0	0	0
03/27/2020 03:00	0.0	0	0	0	0	0
03/27/2020 04:00	0.0	0	0	0	0	0
03/27/2020 05:00	0.0	0	0	0	0	0
03/27/2020 06:00	0.0	0	0	0	0	0
03/27/2020 07:00	0.0	0	0	0	0	0
03/27/2020 08:00	0.0	0	0	0	0	0
03/27/2020 09:00	0.0	0	0	0	0	0
03/27/2020 10:00	0.0	0	0	0	0	0
03/27/2020 11:00	0.0	0	0	0	0	0
03/27/2020 12:00	0.0	0	0	0	0	0
03/27/2020 13:00	0.0	0	0	0	0	0
03/27/2020 14:00	0.0	0	0	0	0	0
03/27/2020 15:00	0.0	0	0	0	0	0
03/27/2020 16:00	0.0	0	0	0	0	0
03/27/2020 17:00	93.0	0	1	0	0	0
03/27/2020 18:00	31.4	0	1	0	0	0
03/27/2020 19:00	48.4	0	1	0	0	0
03/27/2020 20:00	0.0	0	0	0	0	1
03/27/2020 21:00	0.0	0	0	0	0	1
03/27/2020 22:00	0.0	0	0	0	0	1
03/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	172.8 #	0 #	3 #	0 #	0 #	4 #
Minimum:	0.0	0	0	0	0	0
Maximum:	93.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/28/2020 00:00	0.0	0	0	0	0	1
03/28/2020 01:00	0.0	0	0	0	0	1
03/28/2020 02:00	0.0	0	0	0	0	1
03/28/2020 03:00	0.0	0	0	0	0	1
03/28/2020 04:00	0.0	0	0	0	0	1
03/28/2020 05:00	0.0	0	0	0	0	1
03/28/2020 06:00	0.0	0	0	0	0	1
03/28/2020 07:00	0.0	0	0	0	0	1
03/28/2020 08:00	0.0	0	0	0	0	1
03/28/2020 09:00	0.0	0	0	0	0	1
03/28/2020 10:00	0.0	0	0	0	0	1
03/28/2020 11:00	0.0	0	0	0	0	1
03/28/2020 12:00	0.0	0	0	0	0	1
03/28/2020 13:00	0.0	0	0	0	0	1
03/28/2020 14:00	0.0	0	0	0	0	1
03/28/2020 15:00	0.0	0	0	0	0	1
03/28/2020 16:00	0.0	0	0	0	0	1
03/28/2020 17:00	0.0	0	0	0	0	1
03/28/2020 18:00	0.0	0	0	0	0	1
03/28/2020 19:00	0.0	0	0	0	0	1
03/28/2020 20:00	0.0	0	0	0	0	1
03/28/2020 21:00	0.0	0	0	0	0	1
03/28/2020 22:00	0.0	0	0	0	0	1
03/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/29/2020 00:00	0.0	0	0	0	0	1
03/29/2020 01:00	0.0	0	0	0	0	1
03/29/2020 02:00	0.0	0	0	0	0	1
03/29/2020 03:00	0.0	0	0	0	0	1
03/29/2020 04:00	0.0	0	0	0	0	1
03/29/2020 05:00	0.0	0	0	0	0	1
03/29/2020 06:00	0.0	0	0	0	0	1
03/29/2020 07:00	0.0	0	0	0	0	1
03/29/2020 08:00	0.0	0	0	0	0	1
03/29/2020 09:00	0.0	0	0	0	0	1
03/29/2020 10:00	0.0	0	0	0	0	1
03/29/2020 11:00	0.0	0	0	0	0	1
03/29/2020 12:00	0.0	0	0	0	0	1
03/29/2020 13:00	0.0	0	0	0	0	1
03/29/2020 14:00	0.0	0	0	0	0	1
03/29/2020 15:00	0.0	0	0	0	0	1
03/29/2020 16:00	0.0	0	0	0	0	1
03/29/2020 17:00	0.0	0	0	0	0	1
03/29/2020 18:00	0.0	0	0	0	0	1
03/29/2020 19:00	0.0	0	0	0	0	1
03/29/2020 20:00	0.0	0	0	0	0	1
03/29/2020 21:00	0.0	0	0	0	0	1
03/29/2020 22:00	0.0	0	0	0	0	1
03/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/30/2020 00:00	0.0	0	0	0	0	1
03/30/2020 01:00	0.0	0	0	0	0	1
03/30/2020 02:00	0.0	0	0	0	0	1
03/30/2020 03:00	0.0	0	0	0	0	1
03/30/2020 04:00	0.0	0	0	0	0	1
03/30/2020 05:00	0.0	0	0	0	0	1
03/30/2020 06:00	0.0	0	0	0	0	1
03/30/2020 07:00	0.0	0	0	0	0	1
03/30/2020 08:00	0.0	0	0	0	0	1
03/30/2020 09:00	0.0	0	0	0	0	1
03/30/2020 10:00	0.0	0	0	0	0	1
03/30/2020 11:00	0.0	0	0	0	0	1
03/30/2020 12:00	0.0	0	0	0	0	1
03/30/2020 13:00	0.0	0	0	0	0	1
03/30/2020 14:00	0.0	0	0	0	0	1
03/30/2020 15:00	0.0	0	0	0	0	1
03/30/2020 16:00	0.0	0	0	0	0	1
03/30/2020 17:00	0.0	0	0	0	0	1
03/30/2020 18:00	0.0	0	0	0	0	1
03/30/2020 19:00	0.0	0	0	0	0	1
03/30/2020 20:00	0.0	0	0	0	0	1
03/30/2020 21:00	0.0	0	0	0	0	1
03/30/2020 22:00	0.0	0	0	0	0	1
03/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
03/31/2020 00:00	0.0	0	0	0	0	1
03/31/2020 01:00	0.0	0	0	0	0	1
03/31/2020 02:00	0.0	0	0	0	0	1
03/31/2020 03:00	0.0	0	0	0	0	1
03/31/2020 04:00	0.0	0	0	0	0	1
03/31/2020 05:00	0.0	0	0	0	0	1
03/31/2020 06:00	0.0	0	0	0	0	1
03/31/2020 07:00	1.5	0	0	0	1	0
03/31/2020 08:00	0.0	0	0	0	0	0
03/31/2020 09:00	0.0	0	0	0	0	0
03/31/2020 10:00	0.0	0	0	0	0	0
03/31/2020 11:00	0.0	0	0	0	0	0
03/31/2020 12:00	0.0	0	0	0	0	0
03/31/2020 13:00	0.0	0	0	0	0	0
03/31/2020 14:00	0.0	0	0	0	0	0
03/31/2020 15:00	0.0	0	0	0	0	0
03/31/2020 16:00	0.0	0	0	0	0	0
03/31/2020 17:00	0.0	0	0	0	0	0
03/31/2020 18:00	61.3	0	1	0	0	0
03/31/2020 19:00	47.7	0	1	0	0	0
03/31/2020 20:00	0.0	0	0	0	0	1
03/31/2020 21:00	0.0	0	0	0	0	1
03/31/2020 22:00	0.0	0	0	0	0	1
03/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	110.5 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	61.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:10 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	1.0	483.5		
01/02/2020 01:22 01/02/2020 03:47 Warm Start - Gas	146	148.6	790.5		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	0.8	483.5		
01/06/2020 04:32 01/06/2020 06:57 Warm Start - Gas	146	150.2	790.5		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	0.3	483.5		
01/08/2020 21:18 01/08/2020 23:49 Warm Start - Gas	152	124.0	790.5		
01/11/2020 08:26 01/11/2020 08:30 Shut Down - Gas	5	0.3	483.5		
01/12/2020 23:33 01/13/2020 01:48 Warm Start - Gas	136	158.4	790.5		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	1.0	483.5		
01/27/2020 18:12 01/27/2020 20:53 Warm Start - Gas	162	153.8	790.5		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	1.0	483.5		
01/29/2020 17:18 01/29/2020 19:29 Warm Start - Gas	132	89.8	790.5		
01/31/2020 23:25 01/31/2020 23:30 Shut Down - Gas	6	0.8	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:10 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/02/2020 23:13 02/03/2020 02:04 Warm Start - Gas	172	152.4	790.5		
02/07/2020 23:24 02/07/2020 23:29 Shut Down - Gas	6	0.9	483.5		
02/09/2020 23:18 02/10/2020 01:47 Warm Start - Gas	150	152.8	790.5		
02/14/2020 00:53 02/14/2020 00:57 Shut Down - Gas	5	0.4	483.5		
02/17/2020 09:11 02/17/2020 12:47 Cold Start - Gas	217	177.7	1,355.6		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	0.3	483.5		
02/24/2020 13:17 02/24/2020 15:54 Warm Start - Gas	158	128.7	790.5		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	1.0	483.5		
02/26/2020 15:24 02/26/2020 16:23 Hot Start - Gas	60	29.1	679.6		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	1.0	483.5		
03/03/2020 08:49 03/03/2020 12:31 Cold Start - Gas	223	191.7	1,355.6		
03/07/2020 00:24 03/07/2020 00:29 Shut Down - Gas	6	0.7	483.5		
03/08/2020 20:17 03/08/2020 22:30 Warm Start - Gas	134	115.3	790.5		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	0.9	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:10 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/22/2020 17:16 03/22/2020 19:48 Warm Start - Gas	153	104.8	790.5		
03/23/2020 02:04 03/23/2020 02:09 Shut Down - Gas	6	0.4	483.5		
03/23/2020 17:18 03/23/2020 19:52 Warm Start - Gas	155	84.3	790.5		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	0.9	483.5		
03/27/2020 17:04 03/27/2020 19:51 Warm Start - Gas	168	134.5	790.5		
03/31/2020 07:24 03/31/2020 07:29 Shut Down - Gas	6	0.9	483.5		
03/31/2020 18:08 03/31/2020 19:50 Warm Start - Gas	103	56.3	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:10 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:10 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,331.73 Hours

Non-Operating Time: 852.27 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:11 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours
Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
01/01/2020 02:20 01/01/2020 02:25 Shut Down - Gas	6	0.68	115.00		
01/02/2020 01:22 01/02/2020 03:47 Warm Start - Gas	146	149.73	456.20		
01/03/2020 23:55 01/04/2020 00:00 Shut Down - Gas	6	0.44	115.00		
01/06/2020 04:32 01/06/2020 06:57 Warm Start - Gas	146	167.55	456.20		
01/07/2020 22:24 01/07/2020 22:28 Shut Down - Gas	5	0.31	115.00		
01/08/2020 21:18 01/08/2020 23:49 Warm Start - Gas	152	113.36	456.20		
01/11/2020 08:26 01/11/2020 08:30 Shut Down - Gas	5	0.30	115.00		
01/12/2020 23:33 01/13/2020 01:48 Warm Start - Gas	136	137.48	456.20		
01/24/2020 23:24 01/24/2020 23:29 Shut Down - Gas	6	0.75	115.00		
01/27/2020 18:12 01/27/2020 20:53 Warm Start - Gas	162	127.21	456.20		
01/28/2020 22:25 01/28/2020 22:30 Shut Down - Gas	6	0.69	115.00		
01/29/2020 17:18 01/29/2020 19:29 Warm Start - Gas	132	140.56	456.20		
01/31/2020 23:25 01/31/2020 23:30 Shut Down - Gas	6	0.45	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
02/02/2020 23:13 02/03/2020 02:04 Warm Start - Gas	172	158.42	456.20		
02/07/2020 23:24 02/07/2020 23:29 Shut Down - Gas	6	0.48	115.00		
02/09/2020 23:18 02/10/2020 01:47 Warm Start - Gas	150	196.46	456.20		
02/14/2020 00:53 02/14/2020 00:57 Shut Down - Gas	5	0.34	115.00		
02/17/2020 09:11 02/17/2020 12:47 Cold Start - Gas	217	224.63	779.10		
02/21/2020 23:24 02/21/2020 23:28 Shut Down - Gas	5	0.33	115.00		
02/24/2020 13:17 02/24/2020 15:54 Warm Start - Gas	158	207.80	456.20		
02/26/2020 08:22 02/26/2020 08:27 Shut Down - Gas	6	0.87	115.00		
02/26/2020 15:24 02/26/2020 16:23 Hot Start - Gas	60	78.05	259.90		
02/28/2020 23:25 02/28/2020 23:30 Shut Down - Gas	6	0.51	115.00		
03/03/2020 08:49 03/03/2020 12:31 Cold Start - Gas	223	231.70	779.10		
03/07/2020 00:24 03/07/2020 00:29 Shut Down - Gas	6	0.42	115.00		
03/08/2020 20:17 03/08/2020 22:30 Warm Start - Gas	134	116.63	456.20		
03/21/2020 07:22 03/21/2020 07:27 Shut Down - Gas	6	0.75	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
03/22/2020 17:16 03/22/2020 19:48 Warm Start - Gas	153	144.69	456.20		
03/23/2020 02:04 03/23/2020 02:09 Shut Down - Gas	6	0.38	115.00		
03/23/2020 17:18 03/23/2020 19:52 Warm Start - Gas	155	144.42	456.20		
03/24/2020 23:23 03/24/2020 23:28 Shut Down - Gas	6	0.82	115.00		
03/27/2020 17:04 03/27/2020 19:51 Warm Start - Gas	168	173.86	456.20		
03/31/2020 07:24 03/31/2020 07:29 Shut Down - Gas	6	0.45	115.00		
03/31/2020 18:08 03/31/2020 19:50 Warm Start - Gas	103	110.75	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,466.43 Hours

Non-Operating Time: 717.57 Hours Report Time: 2,184.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
01/01/2020 03:00	01/02/2020 06:00	28
01/04/2020 01:00	01/06/2020 06:00	54
01/07/2020 23:00	01/09/2020 01:00	27
01/11/2020 09:00	01/13/2020 02:00	42
01/25/2020 00:00	01/28/2020 02:00	75
01/28/2020 23:00	01/30/2020 01:00	27
01/31/2020 01:00	01/31/2020 04:00	4
02/01/2020 00:00	02/03/2020 02:00	51
02/08/2020 00:00	02/10/2020 02:00	51
02/14/2020 01:00	02/17/2020 14:00	86
02/22/2020 00:00	02/25/2020 13:00	86
02/26/2020 09:00	02/27/2020 01:00	17
02/29/2020 00:00	03/03/2020 14:00	87
03/07/2020 01:00	03/09/2020 00:00	48
03/21/2020 08:00	03/24/2020 01:00	66
03/25/2020 00:00	03/27/2020 22:00	71
03/31/2020 08:00	03/31/2020 23:00	16

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	836.00 Hour(s)
Offline Percentage:	38.28 %
Total Online:	1,348.00 Hour(s)
Online Percentage:	61.72 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/02/2020 07:00	01/02/2020 08:00	Warm Startup	2
2	01/06/2020 07:00	01/06/2020 09:00	Warm Startup	3
3	01/09/2020 02:00	01/09/2020 03:00	Warm Startup	2
4	01/13/2020 03:00	01/13/2020 06:00	Warm Startup	4
5	01/28/2020 03:00	01/28/2020 04:00	Cold Startup	2
6	01/30/2020 02:00	01/30/2020 03:00	Warm Startup	2
7	01/31/2020 05:00	01/31/2020 06:00	Hot Startup	2
8	02/03/2020 03:00	02/03/2020 05:00	Warm Startup	3
9	02/10/2020 03:00	02/10/2020 05:00	Warm Startup	3
10	02/17/2020 15:00	02/17/2020 16:00	Cold Startup	2
11	02/25/2020 14:00	02/25/2020 15:00	Cold Startup	2
12	02/27/2020 02:00	02/27/2020 03:00	Warm Startup	2
13	03/03/2020 15:00	03/03/2020 16:00	Cold Startup	2
14	03/09/2020 01:00	03/09/2020 03:00	Warm Startup	3
15	03/24/2020 02:00	03/24/2020 03:00	Warm Startup	2
16	03/27/2020 23:00	03/28/2020 00:00	Warm Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:11 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	8	0.59
Hot Startup/Startup Shutdown Event Text 02 Add	1	2	0.15
Warm Startup	11	28	2.08
Total Process Events:	16	38	2.82

Total Report Time:	2,184 Hour(s)
Total Operating Time:	1,348 Hour(s)
Total Startup Time:	38 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	38 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.82 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:12 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
01/01/2020 03:00	01/02/2020 00:00	22
01/04/2020 01:00	01/06/2020 03:00	51
01/07/2020 23:00	01/08/2020 20:00	22
01/11/2020 09:00	01/12/2020 22:00	38
01/25/2020 00:00	01/27/2020 17:00	66
01/28/2020 23:00	01/29/2020 16:00	18
02/01/2020 00:00	02/02/2020 22:00	47
02/08/2020 00:00	02/09/2020 22:00	47
02/14/2020 01:00	02/17/2020 08:00	80
02/22/2020 00:00	02/24/2020 12:00	61
02/26/2020 09:00	02/26/2020 14:00	6
02/29/2020 00:00	03/03/2020 07:00	80
03/07/2020 01:00	03/08/2020 19:00	43
03/21/2020 08:00	03/22/2020 16:00	33
03/23/2020 03:00	03/23/2020 16:00	14
03/25/2020 00:00	03/27/2020 16:00	65
03/31/2020 08:00	03/31/2020 17:00	10

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:12 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	703.00 Hour(s)
Offline Percentage:	32.19 %
Total Online:	1,481.00 Hour(s)
Online Percentage:	67.81 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:12 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/02/2020 01:00	01/02/2020 03:00	Warm startup	3
2	01/06/2020 04:00	01/06/2020 06:00	Warm startup	3
3	01/08/2020 21:00	01/08/2020 23:00	Warm startup	3
4	01/12/2020 23:00	01/13/2020 01:00	Warm startup	3
5	01/27/2020 18:00	01/27/2020 20:00	Warm startup	3
6	01/29/2020 17:00	01/29/2020 19:00	Warm startup	3
7	02/02/2020 23:00	02/03/2020 02:00	Warm startup	4
8	02/09/2020 23:00	02/10/2020 01:00	Warm startup	3
9	02/17/2020 09:00	02/17/2020 12:00	Cold Startup	4
10	02/24/2020 13:00	02/24/2020 15:00	Warm startup	3
11	02/26/2020 15:00	02/26/2020 16:00	Hot Startup	2
12	03/03/2020 08:00	03/03/2020 12:00	Cold Startup	5
13	03/08/2020 20:00	03/08/2020 22:00	Warm startup	3
14	03/22/2020 17:00	03/22/2020 19:00	Warm startup	3
15	03/23/2020 17:00	03/23/2020 19:00	Warm startup	3
16	03/27/2020 17:00	03/27/2020 19:00	Warm startup	3
17	03/31/2020 18:00	03/31/2020 19:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 01/01/2020 00:00 **To:** 03/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 04/08/2020 10:12 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	9	0.61
Hot Startup	1	2	0.14
Warm startup	14	42	2.84
Total Process Events:	17	53	3.58

Total Report Time:	2,184 Hour(s)
Total Operating Time:	1,481 Hour(s)
Total Startup Time:	53 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	53 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	3.58 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 1st Quarter of 2020.