

## DOCKETED

|                         |                                        |
|-------------------------|----------------------------------------|
| <b>Docket Number:</b>   | 13-AFC-01                              |
| <b>Project Title:</b>   | Alamitos Energy Center                 |
| <b>TN #:</b>            | 201620-34                              |
| <b>Document Title:</b>  | AEC AFC Appendix 2A Heat Balance Cases |
| <b>Description:</b>     | Previously TN# 201493-7                |
| <b>Filer:</b>           | Tiffani Winter                         |
| <b>Organization:</b>    | CH2M Hill                              |
| <b>Submitter Role:</b>  | Applicant Consultant                   |
| <b>Submission Date:</b> | 2/3/2014 12:47:11 PM                   |
| <b>Docketed Date:</b>   | 2/3/2014                               |

**Appendix 2A**  
**Heat Balances**

---

## Alamitos Energy Center (AEC) AFC Heat Balance Cases for CCGT Blocks 2 and 4 with Reduced Noise Air Cooled Condenser

An additional seventeen heat balance studies were performed to characterize various operating conditions of the AEC Blocks 2 and 4 equipment performance which include a reduced noise Air Cooled Condenser.

Case 1 represents the base case full load operating information for three combustion turbines and one steam turbine operating at full load without evaporative cooling operation at Site Ambient Average Temperature (SAAT) conditions.

Cases 2 through 17 represent alternate scenarios used to develop expected plant output, heat rate, and operating conditions at various equipment configurations and ambient temperatures.

| Case | Heat Balance Number | Description                                                                                                                             | Ambient Temp Data Set | Dry Bulb (°F) | Wet Bulb (°F) | Relative Humidity (%) | Case |
|------|---------------------|-----------------------------------------------------------------------------------------------------------------------------------------|-----------------------|---------------|---------------|-----------------------|------|
| 1    | 1a                  | Three combustion turbines (at max. heat input) w.o. Evap. Cooling Operation                                                             | SAAT                  | 65.3          | 62.7          | 86.6                  | 1    |
| 2    | 1b                  | Two combustion turbines (at max. heat input) w.o. Evap. Cooling Operation                                                               | SAAT                  | 65.3          | 62.7          | 86.6                  | 2    |
| 3    | 1c                  | One combustion turbine (at max. heat input) w.o. Evap. Cooling Operation                                                                | SAAT                  | 65.3          | 62.7          | 86.6                  | 3    |
| 4    | 2a                  | Three combustion turbines (at max. heat input) w. Evap. Cooling Operation                                                               | SAAT                  | 65.3          | 62.7          | 86.6                  | 4    |
| 5    | 2b                  | Two combustion turbines (at max. heat input) w. Evap. Cooling Operation                                                                 | SAAT                  | 65.3          | 62.7          | 86.6                  | 5    |
| 6    | 2c                  | One combustion turbine (at max. heat input) w. Evap. Cooling Operation                                                                  | SAAT                  | 65.3          | 62.7          | 86.6                  | 6    |
| 7    | 3a                  | Three combustion turbines (at max. heat input) w. Evap. Cooling Operation                                                               | SMMAAT                | 84.6          | 69.4          | 45.83                 | 7    |
| 8    | 3b                  | Two combustion turbines (at max. heat input) w. Evap. Cooling Operation                                                                 | SMMAAT                | 84.6          | 69.4          | 45.83                 | 8    |
| 9    | 3b(1)               | Two combustion turbines (at max. heat input) w. Evap. Cooling and Duct Burner Operation                                                 | SMMAAT                | 84.6          | 69.4          | 45.83                 | 9    |
| 10   | 3c                  | One combustion turbine (at max. heat input) w. Evap. Cooling Operation                                                                  | SMMAAT                | 84.6          | 69.4          | 45.83                 | 10   |
| 11   | 3c(1)               | One combustion turbine (at max. heat input) w. Evap. Cooling and Duct Burner Operation                                                  | SMMAAT                | 84.6          | 69.4          | 45.83                 | 11   |
| 12   | 4a                  | Three combustion turbines (at min. heat input) w.o. Evap. Cooling Operation                                                             | SMMAAT                | 84.6          | 69.4          | 45.83                 | 12   |
| 13   | 4b                  | Two combustion turbines (at min. heat input) w.o. Evap. Cooling Operation                                                               | SMMAAT                | 84.6          | 69.4          | 45.83                 | 13   |
| 14   | 4b(1)               | Two combustion turbines (at min. heat input) w.o. Evap. Cooling Operation w. portion of HRSG steam sent to ACC                          | SMMAAT                | 84.6          | 69.4          | 45.83                 | 14   |
| 15   | 4c                  | One combustion turbine (at min. heat input) w.o. Evap. Cooling Operation                                                                | SMMAAT                | 84.6          | 69.4          | 45.83                 | 15   |
| 16   | 5                   | Three combustion turbines (at max. heat input) w.o. Evap. Cooling Operation (Site Minimum Winter Ambient temperature of 1 hr. duration) | SMWAT                 | 28            | 26            | 78.07                 | 16   |
| 17   | 6                   | Three combustion turbines (at max. heat input) w. Evap. Cooling Operation (Site Peak Summer Ambient Temperature of 1 hr. duration)      | SPSAT                 | 107           | 67.5          | 9.97                  | 17   |



## Information Sources Used for Developing Heat Balance Cases

Heat balances information was obtained inputting manufacturer design information for combustion turbines (CT), heat recovery steam generators (HRSG) and steam turbine (ST) into the GT Pro Heat Balance Software Program. The centerline of the air intake is assumed to be 30ft. elevation.

The weather data used for the heat balances use Long Beach CA Weather Data (Dry Bulb, Wet Bulb, Relative Humidity). The Long Beach weather data was obtained from the following internet websites:

|                      |                                                                                                                                                                                                                                                     |
|----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Average Dry Bulb     | <a href="http://www.weather.com/weather/wxclimatology/monthly/USCA0632">http://www.weather.com/weather/wxclimatology/monthly/USCA0632</a>                                                                                                           |
| Average Wet Bulb     | <a href="http://www.opc.ca.gov/webmaster/ftp/project_pages/OTC/engineering%20study/Chapter_7F_Haynes_Generating_Station.pdf">http://www.opc.ca.gov/webmaster/ftp/project_pages/OTC/engineering%20study/Chapter_7F_Haynes_Generating_Station.pdf</a> |
| Daily Max Dry Bulb   | <a href="http://hurricane.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl">http://hurricane.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl</a>                                                                                       |
| Daily Min Dry Bulb   | <a href="http://hurricane.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl">http://hurricane.ncdc.noaa.gov/cgi-bin/climatenormals/climatenormals.pl</a>                                                                                       |
| MCWB                 | <a href="http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf">http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf</a>                                                   |
| 30 Year Max Dry Bulb | <a href="http://weather-warehouse.com/WeatherHistory/PastWeatherData_LongBeachDaughertyField_LongBeach_CA_July.html">http://weather-warehouse.com/WeatherHistory/PastWeatherData_LongBeachDaughertyField_LongBeach_CA_July.html</a>                 |
| 30 Year Max Wet Bulb | <a href="http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf">http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf</a>                                                   |
| 30 Year Min Dry Bulb | <a href="http://weather-warehouse.com/WeatherHistory/PastWeatherData_LongBeachDaughertyField_LongBeach_CA_December.html">http://weather-warehouse.com/WeatherHistory/PastWeatherData_LongBeachDaughertyField_LongBeach_CA_December.html</a>         |
| 30 Year Min Wet Bulb | <a href="http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf">http://web.utk.edu/~archinfo/EcoDesign/escriculum/weather_data/reports/los_angeles_ca.pdf</a>                                                   |


Various analytical methods were used to determine the dry and wet bulb temperatures and relative humidity data for four temperature cases:

1. Site Average Ambient Temperature (SAAT) is 65.3 °F (Dry Bulb) and 62.7 °F (Wet Bulb) and relative humidity (RH) of 86.62%.
2. Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%.
3. The 30 year, one hour duration, Site Peak Summer Ambient Temperature (SPSAT) is 107 °F (Dry Bulb) and 67.5 °F (Wet Bulb) and relative humidity (RH) of 9.97%.
4. The 30 year, one hour duration, Site Minimum Winter Ambient Temperature (SMWAT) is 28 °F (Dry Bulb) and 26 °F (Wet Bulb) and relative humidity (RH) of 78.1%.




### Legend for Typical Equipment Configuration for AEC Heat Balance Cases

(If more than one combustion turbine is installed then the estimated operating information shown represents the sum of the number of combustion turbines modeled. Every combustion turbine represented is paired with its own HRSG)




# Case 1

Case 1 Heat Balance Number 1a Three Combustion Turbines Operating at Maximum Heat Input without Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%




## Case 2

Case 2 Heat Balance Number 1b Two Combustion Turbines Operating at Maximum Heat Input without Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%



### Case 3


Case 3 Heat Balance Number 1c One Combustion Turbine Operating at Maximum Heat Input without Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%






# Case 4

Case 4 Heat Balance Number 2a Three Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%




## Case 5

Case 5 Heat Balance Number 2b      Two Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%




## Case 6

Case 6 Heat Balance Number 2c One Combustion Turbine Operating at Maximum Heat Input with Evaporative Cooling  
 Site Average Annual Temperature (SAAT), Dry Bulb 65.3 F, Wet Bulb 62.7 F, Relative Humidity 86.62%




## Case 7

Case 7 Heat Balance Number 3a      Three Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




## Case 8

Case 8 Heat Balance Number 3b      Two Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




## Case 9

Case 9 Heat Balance Number 3b(1) Two Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling and Duct Burner  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




# Case 10

Case 10 Heat Balance Number 3c One Combustion Turbine Operating at Maximum Heat Input with Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%



# Case 11


Case 11 Heat Balance Number 3c(1) One Combustion Turbine Operating at Maximum Heat Input with Evaporative Cooling and Duct Burning  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%






## Case 12

Case 12 Heat Balance Number 4a Three Combustion Turbines Operating at Minimum Heat Input without Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




# Case 13

Case 13 Heat Balance Number 4b Two Combustion Turbines Operating at Minimum Heat Input without Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




# Case 14

Case 14 Heat Balance Number 4b(1) Two Combustion Turbines Operating at Minimum Heat Input without Evaporative Cooling w. portion of HRSG steam sent to ACC  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%




# Case 15

Case 15 Heat Balance Number 4c One Combustion Turbine Operating at Minimum Heat Input without Evaporative Cooling  
 Site Monthly Maximum Average Ambient Temperature (SMMAAT) is 84.6 °F (Dry Bulb) and 69.4 °F (Wet Bulb) and relative humidity (RH) of 45.83%



# Case 16

Case 16 Heat Balance Number 5 Three Combustion Turbines Operating at Maximum Heat Input without Evaporative Cooling  
 Site Minimum Winter Ambient Temperature (SMWAT) is 28 °F (Dry Bulb) and 26 °F (Wet Bulb) and relative humidity (RH) of 78.1%



# Case 17

Case 17 Heat Balance Number 6 Three Combustion Turbines Operating at Maximum Heat Input with Evaporative Cooling  
 Site Peak Summer Ambient Temperature (SPSAT) is 107 °F (Dry Bulb) and 67.5 °F (Wet Bulb) and relative humidity (RH) of 9.97%

