

DOCKETED

Docket Number:	08-AFC-07C
Project Title:	GWF Tracy (Compliance)
TN #:	234554
Document Title:	Quarterly Monitoring Report Q2 2020
Description:	Quarterly Monitoring Report
Filer:	Neftali Nevarez
Organization:	MRP San Joaquin Energy, LLC
Submitter Role:	Applicant
Submission Date:	9/2/2020 10:48:03 AM
Docketed Date:	9/2/2020

MRP San Joaquin Energy, LLC

July 23, 2020

Mr. Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA. 95814

Reference: MRP- San Joaquin Energy, LLC. Tracy Combined Cycle Power Plant
Facility No. 08-AFC-07

Subject: CEC Conditions of Certification AQ-16 – AQ-170
Quarterly Compliance Report Second Quarter 2020.

Dear Mr. Ali,

Enclosed please find the Quarterly Compliance Report for the Second Quarter of 2020 as required per the Conditions of Certification as set forth in the California Energy Commission's Final Decision for MRP- San Joaquin Energy, LLC - Tracy Combined Cycle Power Plant Project (No. 08-AFC-07).

If you have any questions regarding this report, please contact Neftali Nevarez at (925) 597-2905.

Sincerely,



Claude Couvillion
Vice President of Operations

**MRP-San Joaquin Energy Inc.
Tracy Power Plant**

Quarterly Air Compliance Report

2nd Quarter 2020

This report documents compliance with the California Energy Commission's Conditions of Certification.

Attached are summaries of relevant permit conditions and compliance status as required documentation.

Attachment 1: Summary table identifying each condition, compliance status, reference to compliance documents.

Attachment 2: Rolling Year Emissions Mass Summary

Attachment 3: Breakdown/Deviation Reports filed this quarter.

Attachment 4: Breakdown follow up reports filed this quarter.

Attachment 5: Daily Emissions Report for this quarter.

Attachment 6: Gas Sulfur content 12 month rolling average.

Attachment 7: Start up and shutdown summaries.

Attachment 8: Fuel usage.

Attachment 9: Fuel sulfur analysis completed this quarter.

Attachment 10: CEM run/down time reports

Attachment 11: Emergency Generator Run Log

Attachment 12: Aux Boiler Run Log

Attachment 13: Emergency Fire Pump Run Log.

Attachment 14: Aux Boiler Compliance

Attachment 15: Dust Suppression Control Measures

Attachment 16: Annual WSAC PM10 – (Submitted in Fourth Quarter Report only)

Attachment 1
Compliance Summary

COMPLIANCE SUMMARY

Condition Number	Permit Condition	Status	Document
AQ- SC9,16,41, 73	Annual Total Mass Emissions	In Compliance	A-2, A-16 – Submitted Q4 2019
AQ-20	Report Breakdowns	In Compliance	A-3
AQ-21	Breakdown Follow up Reporting	In Compliance	A-4
AQ-26,38,39,73	Ammonia Slip	In Compliance	A-5
AQ-29,52,53,54,132,144,145	Fuel Sulfur	In Compliance	A-6, A-8, A-9
AQ-30,31,40,63,73,74	Emissions Rates	In Compliance	A-2, A-5
AQ-32,33	Startup and Shutdown Mass Emissions	In Compliance	A-2, A-7
AQ-34,35,36,74	Startup and Shutdown Time	In Compliance	A-7
AQ-44,73	Annual Fuel Usage	In Compliance	A-8
AQ-59	CEMs Audits	In Compliance	Results submitted separately
AQ-60	CEMs Annual RATA	In Compliance	Results submitted separately
AQ-70	CEMs Operation/Downtime	In Compliance	A-10
AQ-71	Formula if CEMs is not operating properly	In Compliance	Formula is provided in the ACC submitted to the CEC annually
AQ-72	Records if CEMs is not working properly	In Compliance	Same as above
AQ-75	All Records Five Years	In Compliance	All Attachments
AQ-110,111,113,115,116,117,118	Emergency Diesel Generator	In Compliance	A-11
AQ-131,149,150,151	Aux Boiler	In Compliance	A-12
AQ-133	Aux Boiler Emissions	In compliance	A-14
AQ-166,167,168,169,170	Emergency Fire Pump	In Compliance	A-13
AQ-101	Dust Suppression	I-C	A-15

ATTACHMENT 2
ROLLING YEAR EMISSIONS MASS SUMMARY

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

Unit 1 - Annual Mass Emissions

June 2020 12-Month Rolling

ROLLING ANNUAL LBS LIMIT: CO = 74,598 NOx = 88,881 PM10= 32,250 SOx = 7,084 VOC = 15,145

Month	CO lbs		NOx lbs		PM lbs		SO2 lbs		VOC lbs	
	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total
Jul 2019	275	2504	4457	45170	355	3853	214	2347	35	373
Aug 2019	318	2713	4537	46291	368	3695	223	2248	36	360
Sep 2019	280	2746	3203	46489	243	3736	145	2273	25	364
Oct 2019	378	2904	4657	46686	285	3561	171	2164	29	349
Nov 2019	331	3108	3163	47093	379	3669	226	2224	37	361
Dec 2019	542	3523	4067	47992	705	4037	411	2427	65	395
Jan 2020	860	4157	3035	47098	514	4195	308	2518	48	409
Feb 2020	Down	4004	Down	42870	Down	3740	Down	2240	0	367
Mar 2020	137	3888	520	39345	55	3478	33	2079	6	342
Apr 2020	27	3627	137	35502	7	3304	4	1973	1	323
May 2020	225	3673	847	34162	128	3371	77	2013	13	329
Jun 2020	305	3678	1583	30206	149	3188	86	1898	15	310

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

Unit 2 - Annual Mass Emissions

June 2020 12-Month Rolling

ROLLING ANNUAL LBS LIMIT: CO = 74,598 NOx = 88,881 PM10= 32,250 SOx = 7,084 VOC = 15,145

Month	CO lbs		NOx lbs		PM lbs		SO2 lbs		VOC lbs	
	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total
Jul 2019	167	8297	1727	30482	429	6758	127	2045	54	797
Aug 2019	207	7783	2305	29438	542	6254	163	1884	70	741
Sep 2019	226	7647	2015	29803	355	6338	106	1910	42	748
Oct 2019	321	6545	2619	28341	451	5727	134	1723	53	660
Nov 2019	311	6032	2661	28806	580	5821	173	1750	61	660
Dec 2019	442	5405	3664	30027	1139	6303	326	1877	129	697
Jan 2020	60	4600	425	27812	101	5793	29	1721	9	647
Feb 2020	Down	3436	Down	24032	Down	4894	Down	1448	0	554
Mar 2020	182	2713	1302	22109	170	4464	50	1318	15	501
Apr 2020	198	2447	1405	21445	182	4417	56	1305	9	490
May 2020	154	2498	2948	23923	751	5140	228	1525	64	552
Jun 2020	120	2388	3114	24185	541	5241	160	1552	53	559

ATTACHMENT 3
BREAKDOWN/DEVIATION REPORTS

Initial report was called in using dedicated Air District (SJVAPCD) phone line therefore no reports are included in this section.

ATTACHMENT 4
BREAKDOWN FOLLOW UP REPORTS

MRP San Joaquin Energy

June 24, 2020

Mr. Taylor Leach
San Joaquin Valley Unified APCD
4800 Enterprise Way
Modesto, CA 95356-8718

**Subject: Title V Deviation/Follow-up Report
MRP San Joaquin Energy, LLC – Tracy Combined Cycle Power Plant
Facility ID N-4597**

Dear Mr. Leach

In accordance with Condition 2 of the Facility Wide Requirements of the Title V Permit for Facility ID N-4597, please find enclosed the Title V Deviation/Follow-up Report. This deviation/breakdown was initially reported on June 18, 2020.

Please call Neftali Nevarez at (925) 597-2905 or e-mail (Neftali.Nevarez@naes.com) if you require additional information or if you have any questions regarding this report.

Respectfully,



Claude Couvillion
Vice President of Operation
MRP San Joaquin Energy, LLC

BREAKDOWN / TITLE V - DEVIATION REPORTING FORM

Check the appropriate box if using this form to submit/report a:

- Breakdown Notification (must be reported within 1 hour)
 Title V Deviation
 Breakdown Follow-up Report
 Title V Deviation/Breakdown Follow-up Report

This form can be used to file the initial report of an equipment breakdown, and as the follow-up report for both a breakdown and/or deviation from a Federal Title V permit condition. The required reports must be submitted to the nearest District regional office as follows:

- Breakdown follow-up reports no later than 10 days after returning to compliance
- Deviation reports no later than 10 days after discovery

Company Name: MRP San Joaquin Energy, LLC – Tracy Combined Cycle Power Plant Facility ID: N-4597

Breakdown - Initial Notification:

Reported by: Greg Gresham Date: 06/18/20
 Reported to: Northern Region Office – Breakdown Phone Line Time: 15:39 pm PST

BREAKDOWN / DEVIATION INFORMATION

1.	Permit unit and condition number(s): N-4597-1-10 Condition #21 and N-4597-0-3 Condition #5.
2.	Equipment involved: Continuous Emissions Monitoring System (CEMS) – Inlet O2 analyzer used in the ammonia slip calculation.
3.	Location of operation: 14950 W. Schulte Road, Tracy, CA 95377
4.	Description of permit condition: Conditon # 21 of Permit Unit N-4597-1-10. Compliance with the ammonia emission limits shall be demonstrated utilizing one of the following procedures: 1) calculate the daily ammonia emissions using the following equation: $(ppmvd@15\%O_2 = ((a - (b \times c/1,000,000)) \times (1,000,000 / b)) \times d$, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NOx concentration ppmvd @ 15% O2 across the catalyst, and d = correction factor..... Condition #5 of Facility Wide Permit N-4597-0-3. The permittee must comply with all conditions....
5.	Date, time, and duration of breakdown/deviation: 06/18/20 13:00 PST thru 06/18/20 14:59 PST. Duration of the breakdown/deviation was 2 hrs.

Northern Region Office
(Merced, San Joaquin, & Stanislaus Counties)
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 ♦ FAX: (209) 557-6475

Central Region Office
(Fresno, Kings, & Madera Counties)
1990 E Gettysburg Ave
Fresno, CA 93726-0244
Tel: (559) 230-5950 ♦ FAX: (559) 230-6062

Southern Region Office
(Tulare County & Valley portion of Kern County)
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 ♦ FAX: (661) 392-5585

<p>6. Description of breakdown/deviation (include excess and visible emissions, if applicable):</p> <p>The O2 inlet analyzer failed the daily calibration check. We believe no excess emissions occurred since all operating parameters were within normal ranges and the NOx emission control system (SCR) experienced no deviations from normal operating ranges (NH3 injection rate, NOx emissions in the stack, etc.).</p> <p>Note: Upon review of the TV Permit conditions relevant to NH3 emission limit averaging periods and the monitoring requirements for NH3 slip, Tracy believes that no deviation from monitoring requirements actually occurred.</p> <p>First, there doesn't appear to be any performance specifications for the inlet NOx monitors listed in the Title V Permit. Even so, Tracy maintains the inlet analyzers in accordance with 40 CFR Part 60, Appendix B and F. When the daily calibration failed to meet the relevant performance specifications of 40 CFR Part 60, the DAHS invalidated the data the same as it would for a stack monitor.</p> <p>Second, the DAHS is programmed to validate/invalidate monitoring data in accordance with criteria listed in 40 CFR 60.13 at the hourly level, but the averaging period for the NH3 slip limit is based on a 24-hour rolling average. Two hours of invalid data would not necessarily invalidate the 24-hour average calculation. Data availability for the 24-hour average calculation is 92%.</p>
<p>7. Date and time when breakdown/deviation was discovered:</p> <p>06/18/20 at 15:04 PST when failed calibration alarm was received.</p>
<p>8. Date and time compliance was achieved:</p> <p>06/18/20 15:40 PST after a follow-up O2 calibration check passed.</p>
<p>9. Probable cause of breakdown/deviation:</p> <p>Probable cause was not determined. Troubleshooting of the CEMS by the I&E Technician did not reveal any possible causes for the failed calibration. A new calibration following the failed calibration passed within the same hour, and the results were within range of other calibrations completed prior to the failed calibration.</p>
<p>10. Measures taken to correct this occurrence and prevent recurrence:</p> <p>A new calibration following the failed calibration passed within the same hour. The I&E Technician checked the CEMS equipment and did not find any issues with the system components or the overall performance of the sample extraction and analysis for the inlet monitoring system.</p>
<ul style="list-style-type: none"> • Attach photographs of defective equipment. • Provide any additional information necessary to establish that this occurrence was the result of an unavoidable failure or malfunction; Rule 1100 – <i>Equipment Breakdown</i> assigns the burden of proof to the source owner/operator seeking relief.

CERTIFICATION:

I declare, under penalty of perjury under the laws of the state of California, that based on information and belief formed after reasonable inquiry, all information provided in this report is true, accurate, and addresses all deviations that resulted from this event:



6/24/2020

Signature of Responsible Official

(Responsible Official only required for Title V Permit Holders)

Date

Claude Couvillion

Name of Responsible

312.766.8716

Telephone

Official Vice President of

Title of Responsible Official
Operations

Jcouvillion@mrpgenco.com

Email

NH3 SLIP – Lbs 1 hr

Edit Data Points

Long period data Short period data

Unit:

Parameter:

From: ... To: ...

Timestamp	Value	Monitor Code
6/18/2020 10:00 AM	0.00	13 - Down
6/18/2020 11:00 AM	0.00	13 - Down
6/18/2020 12:00 PM	0.00	13 - Down
6/18/2020 1:00 PM	40.89	74 - Monitor Out Of Control 4x PS
6/18/2020 2:00 PM	1.59	74 - Monitor Out Of Control 4x PS
6/18/2020 3:00 PM	0.83	75 - Valid
6/18/2020 4:00 PM	2.18	00 - Valid

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	<i>ppm @15% O2</i>	<i>lbs</i>	<i>ppm @15% O2</i>	<i>lbs</i>	<i>ppm @15% O2</i>	<i>lbs</i>
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.17	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.4	3.24	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.4	4.19	8.28	NSD	NSD	4.08	0.0	0.03	9.40	On	1.00	Normal
16	1.4	5.46	10.30	0.6	1.07	6.00	0.1	0.13	9.40	On	1.00	Normal
17	1.5	5.50	10.30	0.6	1.27	6.00	0.1	0.17	9.40	On	1.00	Normal
18	1.5	5.29	10.30	0.6	1.44	6.00	0.2	0.21	9.40	On	1.00	Normal
19	1.5	5.39	10.30	0.7	1.55	6.00	0.2	0.25	9.40	On	1.00	Normal
20	1.5	5.32	10.30	0.7	1.48	6.00	0.2	0.33	9.40	On	1.00	Normal
21	1.4	1.56	8.54	0.7	1.09	6.00	0.2	0.33	9.40	On	0.60	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.33	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.32	0.2	0.33	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Turbine 1 Calibration Checks

Tracy Combined Cycle Power Plant
Cal Checks for 6/18/2020 thru 6/19/2020

Date/Time	Parameter	Analyzer Scale	Test Level	Reference Value	Measured Value	Actual Drift	Allowable Drift	Instrument Span	Results
6/18/2020 2:42 PM	60-NOx ppm	High	Zero	0.00 ppm	0.01 ppm	0.01 ppm	±5 ppm	100 ppm	Unit online; Passed
6/18/2020 2:42 PM	60-NOx ppm	High	Span	89.93 ppm	89.37 ppm	-0.56 ppm	±5 ppm	100 ppm	Unit online; Passed
6/18/2020 2:42 PM	60-NOx ppm	Low	Zero	0.00 ppm	0.01 ppm	0.01 ppm	±0.5 ppm	10 ppm	Unit online; Passed
6/18/2020 2:42 PM	60-NOx ppm	Low	Span	9.08 ppm	8.87 ppm	-0.21 ppm	±0.5 ppm	10 ppm	Unit online; Passed
6/18/2020 2:42 PM	Inlet O2%	Single	Zero	0.000%	0.000%	0%	±1%	25%	Unit online; Passed
6/18/2020 2:42 PM	Inlet O2%	Single	Span	22.250%	24.874%	2.624%	±1%	25%	Unit online; Fail Above; Fail OOC
6/18/2020 3:18 PM	60-NOx ppm	High	Zero	0.00 ppm	0.00 ppm	0 ppm	±5 ppm	100 ppm	Unit online; Passed; Manual
6/18/2020 3:18 PM	60-NOx ppm	High	Span	89.93 ppm	89.64 ppm	-0.29 ppm	±5 ppm	100 ppm	Unit online; Passed; Manual
6/18/2020 3:18 PM	60-NOx ppm	Low	Zero	0.00 ppm	0.00 ppm	0 ppm	±0.5 ppm	10 ppm	Unit online; Passed; Manual
6/18/2020 3:18 PM	60-NOx ppm	Low	Span	9.08 ppm	9.12 ppm	0.04 ppm	±0.5 ppm	10 ppm	Unit online; Passed; Manual
6/18/2020 3:18 PM	Inlet O2%	Single	Zero	0.000%	0.000%	0%	±1%	25%	Unit online; Passed; Manual
6/18/2020 3:18 PM	Inlet O2%	Single	Span	22.250%	22.058%	-0.192%	±1%	25%	Unit online; Passed; Manual
6/19/2020 6:32 AM	60-NOx ppm	High	Zero	0.00 ppm	-0.02 ppm	-0.02 ppm	±5 ppm	100 ppm	Unit offline; Passed; Manual
6/19/2020 6:32 AM	60-NOx ppm	High	Span	89.93 ppm	90.00 ppm	0.07 ppm	±5 ppm	100 ppm	Unit offline; Passed; Manual
6/19/2020 6:32 AM	60-NOx ppm	Low	Zero	0.00 ppm	-0.02 ppm	-0.02 ppm	±0.5 ppm	10 ppm	Unit offline; Passed; Manual
6/19/2020 6:32 AM	60-NOx ppm	Low	Span	9.08 ppm	9.07 ppm	-0.01 ppm	±0.5 ppm	10 ppm	Unit offline; Passed; Manual
6/19/2020 6:32 AM	Inlet O2%	Single	Zero	0.000%	0.000%	0%	±1%	25%	Unit offline; Passed; Manual
6/19/2020 6:32 AM	Inlet O2%	Single	Span	22.250%	22.044%	-0.206%	±1%	25%	Unit offline; Passed; Manual

ATTACHMENT 5
DAILY EMISSIONS REPORTS

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.90	Startup
15	1.4	0.56	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.3	3.91	8.10	NSD	NSD	3.90	0.1	0.10	9.40	Off	1.00	Normal
17	1.5	4.89	8.10	0.5	0.71	3.90	0.1	0.10	9.40	Off	1.00	Normal
18	1.5	4.88	8.10	0.5	1.02	3.90	0.1	0.10	9.40	Off	1.00	Normal
19	1.5	6.11	9.86	0.4	0.90	5.58	0.2	0.37	9.40	On	1.00	Normal
20	1.5	6.57	10.30	0.3	0.73	6.00	0.4	0.66	9.40	On	1.00	Normal
21	1.4	3.93	9.24	0.2	0.48	6.00	0.4	0.66	9.40	On	0.93	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.4	0.66	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.99	0.4	0.66	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.56	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.56	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.56	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
April 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 April 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Mass Emissions Report
 April - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	Down	Down	Down	Down	Down	0.0	0.0
02	Down	Down	Down	Down	Down	0.0	0.0
03	Down	Down	Down	Down	Down	0.0	0.0
04	Down	Down	Down	Down	Down	0.0	0.0
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	133.2	3.1	26.3	6.6	62.2	0.7	7.8
09	Down	Down	Down	Down	Down	0.0	0.0
10	Down	Down	Down	Down	Down	0.0	0.0
11	Down	Down	Down	Down	Down	0.0	0.0
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	Down	Down	Down	Down	Down	0.0	0.0
23	Down	Down	Down	Down	Down	0.0	0.0
24	Down	Down	Down	Down	Down	0.0	0.0
25	Down	Down	Down	Down	Down	0.0	0.0
26	Down	Down	Down	Down	Down	0.0	0.0
27	Down	Down	Down	Down	Down	0.0	0.0
28	Down	Down	Down	Down	Down	0.0	0.0
29	Down	Down	Down	Down	Down	0.0	0.0
30	Down	Down	Down	Down	Down	0.0	0.0
Total 12-Mo Rlng	133 35498	3 1537	26 3626	7 3304	62.2 9784	1 323	8

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 April - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
04	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	6122.6	6416.5	7.83	376.9	395.1	2.32	6812	2429.7	7.45	267.0	6.99	503	7.8
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
26	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average	6122.6	6416.5		376.9	395.1		6812	2429.7		267.0		503	
Total	6122.6	6417	7.8	376.9	395	2.3	6812	2429.7	7.5	267.0	7.0	503	8

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.43	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.15	Startup
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
11	1.6	3.12	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
12	1.5	5.29	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	1.00	Normal
13	1.5	5.58	8.10	0.7	1.45	3.90	0.3	0.37	9.40	Off	1.00	Normal
14	1.5	5.02	8.10	0.9	2.03	3.90	0.3	0.37	9.40	Off	1.00	Normal
15	1.5	4.60	8.10	1.0	2.12	3.90	0.3	0.40	9.40	Off	1.00	Normal
16	1.5	4.48	8.10	1.2	2.25	3.90	0.3	0.40	9.40	Off	1.00	Normal
17	1.6	5.02	8.10	1.2	2.33	3.90	0.3	0.47	9.40	Off	1.00	Normal
18	1.4	2.59	8.10	1.2	2.00	3.90	0.3	0.47	9.40	Off	0.80	Shutdown
19	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.47	9.40	Off	0.00	Down
20	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.47	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.27	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.11	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.11	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.07	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.07	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.33	Startup
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
13	1.4	3.27	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	Maint	Maint	8.10	Maint	Maint	3.90	0.0	0.00	9.40	Off	1.00	Normal
15	1.3	5.04	9.57	Maint	Maint	5.30	0.1	0.13	9.40	On	1.00	Normal
16	1.5	5.41	10.30	Maint	Maint	6.00	0.1	0.17	9.40	On	1.00	Normal
17	1.5	5.46	10.30	0.5	1.10	6.00	0.1	0.22	9.40	On	1.00	Normal
18	1.5	5.69	10.30	0.6	1.25	6.00	0.2	0.31	9.40	On	1.00	Normal
19	1.5	5.64	10.30	0.5	1.19	6.00	0.2	0.35	9.40	On	1.00	Normal
20	1.5	5.84	10.30	0.5	1.10	6.00	0.3	0.39	9.40	On	1.00	Normal
21	1.5	5.57	10.30	0.5	1.12	6.00	0.3	0.44	9.40	On	1.00	Normal
22	1.5	5.47	10.30	0.5	1.11	6.00	0.3	0.48	9.40	On	1.00	Normal
23	1.5	5.30	8.87	0.5	1.15	6.00	0.4	0.52	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.56	8.10	0.6	1.17	6.00	0.4	0.56	9.40	Off	1.00	Normal
01	1.5	0.23	8.10	0.6	0.82	4.64	0.4	0.56	9.40	Off	0.28	Shutdown
02	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.56	9.40	Off	0.00	Down
03	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.56	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.15	Startup
09	1.4	2.05	8.10	NSD	NSD	3.90	0.4	0.56	9.40	Off	1.00	Startup
10	1.6	5.29	8.10	NSD	NSD	3.90	0.4	0.56	9.40	Off	1.00	Normal
11	1.5	4.60	8.10	0.6	0.95	3.90	0.4	0.59	9.40	Off	1.00	Normal
12	1.7	5.89	9.79	0.6	1.19	5.51	0.4	0.67	9.40	On	1.00	Normal
13	1.6	7.47	10.30	0.4	0.85	6.00	0.6	1.00	9.40	On	1.00	Normal
14	1.6	7.59	10.30	0.2	0.56	6.00	0.7	1.27	9.40	On	1.00	Normal
15	1.6	7.58	10.30	0.1	0.26	6.00	0.8	1.46	9.40	On	1.00	Normal
16	1.6	7.54	10.30	0.1	0.26	6.00	1.0	1.68	9.40	On	1.00	Normal
17	1.6	7.55	10.30	0.1	0.26	6.00	1.1	1.90	9.40	On	1.00	Normal
18	1.6	6.09	10.30	0.1	0.35	6.00	1.1	1.91	9.40	On	1.00	Normal
19	1.6	6.02	10.30	0.2	0.54	6.00	1.1	1.91	9.40	On	1.00	Normal
20	1.6	6.10	10.30	0.3	0.69	6.00	1.1	1.90	9.40	On	1.00	Normal
21	1.6	5.95	10.30	0.4	0.82	6.00	1.1	1.90	9.40	On	1.00	Normal
22	1.6	5.66	10.30	0.4	0.84	6.00	1.1	1.90	9.40	On	1.00	Normal
23	1.6	5.86	9.75	0.4	0.93	6.00	1.1	1.91	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.73	8.14	0.5	1.00	6.00	1.1	1.91	9.40	On	1.00	Normal
01	1.5	4.57	8.10	0.5	1.03	5.48	1.1	1.94	9.40	Off	1.00	Normal
02	1.5	4.47	8.10	0.6	1.02	3.94	1.1	1.94	9.40	Off	1.00	Normal
03	1.5	4.47	8.10	0.6	1.03	3.90	1.1	1.94	9.40	Off	1.00	Normal
04	1.5	4.47	8.10	0.6	1.11	3.90	1.1	1.94	9.40	Off	1.00	Normal
05	1.6	4.62	8.10	0.7	1.19	3.90	1.1	1.94	9.40	Off	1.00	Normal
06	1.5	4.44	8.10	0.7	1.24	3.90	1.2	1.97	9.40	Off	1.00	Normal
07	1.5	4.45	8.10	0.7	1.32	3.90	1.2	1.97	9.40	Off	1.00	Normal
08	1.5	4.48	8.10	0.8	1.43	3.90	1.2	1.97	9.40	Off	1.00	Normal
09	1.5	4.50	8.10	0.8	1.52	3.90	1.2	1.97	9.40	Off	1.00	Normal
10	1.5	4.57	8.10	0.9	1.55	3.90	1.2	1.97	9.40	Off	1.00	Normal
11	1.6	6.77	10.26	0.7	1.34	5.97	1.2	2.13	9.40	On	1.00	Normal
12	1.5	5.38	10.30	0.6	1.26	6.00	1.2	2.09	9.40	On	1.00	Normal
13	1.5	5.75	10.30	0.5	1.09	6.00	1.1	1.86	9.40	On	1.00	Normal
14	1.5	5.90	10.30	0.5	1.06	6.00	1.0	1.63	9.40	On	1.00	Normal
15	1.5	5.85	10.30	0.4	0.87	6.00	0.9	1.40	9.40	On	1.00	Normal
16	1.3	5.87	10.30	0.3	0.66	6.00	0.9	1.51	9.40	On	1.00	Normal
17	1.5	7.16	10.30	0.2	0.51	6.00	1.0	1.56	9.40	On	1.00	Normal
18	1.3	4.90	10.30	0.2	0.51	6.00	1.0	1.60	9.40	On	1.00	Normal
19	1.5	5.55	10.30	0.3	0.68	6.00	1.0	1.60	9.40	On	1.00	Normal
20	1.5	5.58	10.30	0.4	0.86	6.00	1.0	1.64	9.40	On	1.00	Normal
21	1.5	5.33	10.30	0.4	0.98	6.00	1.0	1.64	9.40	On	1.00	Normal
22	1.5	5.33	10.30	0.5	1.04	6.00	1.0	1.68	9.40	On	1.00	Normal
23	1.5	5.39	10.30	0.5	1.09	6.00	1.0	1.68	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.51	8.28	0.5	1.09	6.00	1.0	1.65	9.40	On	1.00	Normal
01	1.5	4.51	8.10	0.5	1.05	6.00	1.0	1.65	9.40	Off	1.00	Normal
02	1.5	4.51	8.10	0.6	1.00	4.08	1.0	1.68	9.40	Off	1.00	Normal
03	1.5	4.43	8.10	0.6	1.00	3.90	1.0	1.68	9.40	Off	1.00	Normal
04	1.5	4.50	8.10	0.6	1.02	3.90	1.0	1.71	9.40	Off	1.00	Normal
05	1.5	4.43	8.10	0.6	1.07	3.90	1.0	1.75	9.40	Off	1.00	Normal
06	1.5	4.50	8.10	0.6	1.10	3.90	1.0	1.75	9.40	Off	1.00	Normal
07	1.5	4.51	8.10	0.6	1.18	3.90	1.0	1.78	9.40	Off	1.00	Normal
08	1.5	4.45	8.10	0.7	1.26	3.90	1.0	1.81	9.40	Off	1.00	Normal
09	1.5	4.45	8.10	0.7	1.35	3.90	1.0	1.81	9.40	Off	1.00	Normal
10	1.5	4.46	8.10	0.8	1.40	3.90	1.0	1.81	9.40	Off	1.00	Normal
11	1.5	4.79	8.61	0.8	1.46	4.39	0.9	1.62	9.40	On	1.00	Normal
12	1.5	5.59	10.30	0.8	1.57	6.00	0.9	1.62	9.40	On	1.00	Normal
13	1.5	5.49	10.30	0.8	1.61	6.00	0.9	1.58	9.40	On	1.00	Normal
14	1.5	5.58	10.30	0.7	1.60	6.00	0.9	1.53	9.40	On	1.00	Normal
15	1.5	5.59	10.30	0.7	1.50	6.00	0.9	1.49	9.40	On	1.00	Normal
16	1.5	5.50	10.30	0.6	1.43	6.00	0.7	1.16	9.40	On	1.00	Normal
17	1.5	5.72	10.30	0.6	1.38	6.00	0.6	0.94	9.40	On	1.00	Normal
18	1.5	5.38	10.30	0.6	1.26	6.00	0.6	0.89	9.40	On	1.00	Normal
19	1.5	5.37	10.30	0.6	1.25	6.00	0.5	0.89	9.40	On	1.00	Normal
20	1.5	5.34	10.30	0.6	1.28	6.00	0.5	0.84	9.40	On	1.00	Normal
21	1.5	5.49	10.30	0.7	1.40	6.00	0.5	0.84	9.40	On	1.00	Normal
22	1.5	5.41	10.30	0.6	1.37	6.00	0.5	0.84	9.40	On	1.00	Normal
23	1.5	5.40	9.79	0.6	1.37	6.00	0.5	0.84	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
May 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.45	8.10	0.7	1.35	6.00	0.5	0.84	9.40	Off	1.00	Normal
01	1.5	5.15	8.43	0.8	1.62	5.51	0.5	0.81	9.40	On	1.00	Normal
02	1.5	5.47	10.30	0.8	1.72	6.00	0.6	0.82	9.40	On	1.00	Normal
03	1.5	5.38	10.30	0.9	1.91	6.00	0.6	0.86	9.40	On	1.00	Normal
04	1.5	5.47	10.30	0.8	1.79	6.00	0.6	0.90	9.40	On	1.00	Normal
05	1.5	5.39	10.30	0.8	1.79	6.00	0.7	0.91	9.40	On	1.00	Normal
06	1.5	5.56	10.30	0.8	1.80	6.00	0.7	0.92	9.40	On	1.00	Normal
07	1.5	5.43	10.30	0.9	1.90	6.00	0.7	0.92	9.40	On	1.00	Normal
08	1.5	5.35	10.30	0.9	1.99	6.00	0.7	0.93	9.40	On	1.00	Normal
09	1.5	5.46	10.30	0.9	2.05	6.00	0.7	0.97	9.40	On	1.00	Normal
10	1.5	5.49	10.30	1.0	2.05	6.00	0.7	1.01	9.40	On	1.00	Normal
11	1.5	5.42	10.30	0.9	2.06	6.00	0.7	1.05	9.40	On	1.00	Normal
12	1.5	6.08	10.30	0.8	1.88	6.00	0.8	1.10	9.40	On	1.00	Normal
13	1.5	5.40	10.30	0.8	1.81	6.00	0.8	1.10	9.40	On	1.00	Normal
14	1.5	5.35	10.30	0.8	1.77	6.00	0.7	1.09	9.40	On	1.00	Normal
15	1.5	6.55	10.30	0.7	1.54	6.00	0.8	1.24	9.40	On	1.00	Normal
16	1.5	5.84	10.30	0.5	1.28	6.00	0.8	1.33	9.40	On	1.00	Normal
17	1.5	5.43	10.30	0.5	1.12	6.00	0.8	1.29	9.40	On	1.00	Normal
18	1.5	5.42	10.30	0.6	1.35	6.00	0.8	1.25	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.7	1.48	6.00	0.8	1.25	9.40	On	1.00	Normal
20	1.5	5.43	10.30	0.7	1.52	6.00	0.8	1.25	9.40	On	1.00	Normal
21	1.5	5.42	10.30	0.7	1.55	6.00	0.8	1.25	9.40	On	1.00	Normal
22	1.5	5.41	10.30	0.7	1.58	6.00	0.8	1.21	9.40	On	1.00	Normal
23	1.5	5.34	9.13	0.8	1.69	6.00	0.8	1.21	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.45	10.30	0.8	1.79	6.00	0.8	1.25	9.40	On	1.00	Normal
01	1.5	5.33	10.30	0.9	1.91	6.00	0.8	1.29	9.40	On	1.00	Normal
02	1.5	5.34	10.30	1.0	2.11	6.00	0.8	1.28	9.40	On	1.00	Normal
03	1.5	5.34	10.30	1.1	2.33	6.00	0.8	1.28	9.40	On	1.00	Normal
04	1.5	5.34	10.30	1.2	2.59	6.00	0.8	1.24	9.40	On	1.00	Normal
05	1.5	5.33	10.30	1.2	2.62	6.00	0.8	1.24	9.40	On	1.00	Normal
06	1.5	5.32	10.30	1.2	2.62	6.00	0.8	1.24	9.40	On	1.00	Normal
07	1.5	5.35	10.30	1.2	2.52	6.00	0.8	1.24	9.40	On	1.00	Normal
08	1.5	5.42	10.30	1.1	2.39	6.00	0.8	1.24	9.40	On	1.00	Normal
09	1.5	5.35	10.30	1.0	2.27	6.00	0.8	1.24	9.40	On	1.00	Normal
10	1.5	5.37	10.30	1.0	2.14	6.00	0.8	1.24	9.40	On	1.00	Normal
11	1.5	5.35	10.30	1.0	2.04	6.00	0.8	1.24	9.40	On	1.00	Normal
12	1.5	5.36	10.30	0.9	2.01	6.00	0.8	1.20	9.40	On	1.00	Normal
13	1.5	5.43	10.30	0.9	2.01	6.00	0.8	1.19	9.40	On	1.00	Normal
14	1.5	5.48	10.30	0.9	2.08	6.00	0.8	1.20	9.40	On	1.00	Normal
15	1.4	5.33	10.30	0.9	1.92	6.00	0.7	1.09	9.40	On	1.00	Normal
16	1.5	5.38	10.30	0.8	1.83	6.00	0.7	1.00	9.40	On	1.00	Normal
17	1.5	5.50	10.30	0.8	1.69	6.00	0.7	1.00	9.40	On	1.00	Normal
18	1.5	5.40	10.30	0.8	1.73	6.00	0.7	1.00	9.40	On	1.00	Normal
19	1.5	5.41	10.30	0.8	1.70	6.00	0.7	1.00	9.40	On	1.00	Normal
20	1.5	5.26	10.01	0.8	1.73	6.00	0.6	1.00	9.40	On	1.00	Normal
21	1.4	4.99	8.10	0.9	1.91	6.00	0.6	1.00	9.40	Off	1.00	Normal
22	1.5	5.35	8.10	1.0	2.15	5.72	0.6	1.00	9.40	Off	1.00	Normal
23	1.5	5.26	8.10	1.1	2.33	3.90	0.6	1.00	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 May 31, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	0.37	8.10	1.1	1.65	3.90	0.6	0.96	9.40	Off	0.35	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.6	0.92	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.88	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.84	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.80	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.76	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.72	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.68	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.64	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.56	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.52	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.40	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Mass Emissions Report
 May - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	Down	Down	Down	Down	Down	0.0	0.0
02	Down	Down	Down	Down	Down	0.0	0.0
03	Down	Down	Down	Down	Down	0.0	0.0
04	Down	Down	Down	Down	Down	0.0	0.0
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	Down	Down	Down	Down	Down	0.0	0.0
09	Down	Down	Down	Down	Down	0.0	0.0
10	Down	Down	Down	Down	Down	0.0	0.0
11	Down	Down	Down	Down	Down	0.0	0.0
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	66.1	3.5	34.7	7.4	19.0	0.7	9.0
23	Down	Down	Down	Down	Down	0.0	0.0
24	Down	Down	Down	Down	Down	0.0	0.0
25	143.6	5.3	26.0	11.2	49.5	1.2	12.3
26	124.0	7.9	12.6	16.6	60.6	1.6	16.4
27	121.9	10.7	24.9	22.5	40.4	2.2	24.0
28	117.4	10.1	30.6	21.2	20.2	2.2	24.0
29	128.4	11.0	40.1	23.2	28.9	2.4	24.0
30	125.7	10.9	49.9	22.9	23.9	2.3	24.0
31	2.2	0.1	1.5	0.2	1.2	0.0	0.4
Total	829	60	220	125	243.7	13	134
12-Mo Ring	34140	1569	3667	3368	9639	329	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 May - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
04	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	7234.7	7538.8	8.95	Down	Down	0.00	7539	2509.7	8.52	298.1	7.96	604	9.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	10283.0	10714.8	12.33	676.7	705.2	8.02	11420	4077.3	11.97	440.5	11.67	868	12.3
26	14116.2	14709.3	16.43	2170.5	2261.7	11.52	16971	6480.1	16.43	711.5	16.13	1203	16.4
27	20351.4	21206.1	24.00	1643.2	1712.5	13.00	22919	8466.1	24.00	908.3	23.93	1729	24.0
28	19962.5	20800.8	24.00	844.9	880.6	12.08	21681	7811.7	24.00	806.3	24.00	1690	24.0
29	21102.1	21988.3	24.00	1637.8	1706.5	21.62	23695	8554.8	24.00	913.6	24.00	1831	24.0
30	21227.3	22118.6	24.00	1220.3	1271.6	20.87	23390	8295.6	24.00	881.3	24.00	1853	24.0
31	189.5	197.4	0.35	Down	Down	0.00	197	79.5	0.35	11.1	0.27	14	0.4
Average Total	14308.3 114466.7	14909.3 119274	134.1	1365.6 8193.4	1423.0 8538	87.1	15977 127812	5784.4 46274.8	133.3	621.3 4970.7	132.0	1224 9792	134

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.30	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.3	3.11	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	5.11	10.04	NSD	NSD	5.76	0.0	0.04	9.40	On	1.00	Normal
17	1.5	5.38	10.30	0.5	1.05	6.00	0.0	0.08	9.40	On	1.00	Normal
18	1.5	5.40	10.30	0.6	1.37	6.00	0.1	0.12	9.40	On	1.00	Normal
19	1.5	5.32	10.30	0.7	1.48	6.00	0.1	0.16	9.40	On	1.00	Normal
20	1.4	4.92	8.98	0.7	1.59	6.00	0.1	0.16	9.40	On	1.00	Normal
21	1.5	5.74	10.12	0.7	1.49	6.00	0.1	0.20	9.40	On	1.00	Normal
22	1.7	0.29	8.10	0.7	1.00	5.83	0.1	0.20	9.40	Off	0.33	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.83	0.1	0.20	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.42	Startup
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	1.00	Startup
12	1.4	3.63	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	1.00	Startup
13	1.4	4.97	8.10	NSD	NSD	3.90	0.2	0.28	9.40	Off	1.00	Normal
14	1.5	5.28	8.39	0.5	1.06	4.18	0.2	0.32	9.40	On	1.00	Normal
15	1.5	5.47	10.30	0.6	1.22	6.00	0.2	0.36	9.40	On	1.00	Normal
16	1.4	5.28	10.30	0.6	1.20	6.00	0.3	0.37	9.40	On	1.00	Normal
17	1.5	5.68	10.30	0.5	1.16	6.00	0.3	0.41	9.40	On	1.00	Normal
18	1.4	5.16	10.30	0.5	1.10	6.00	0.3	0.41	9.40	On	1.00	Normal
19	1.5	5.47	10.30	0.5	1.16	6.00	0.4	0.41	9.40	On	1.00	Normal
20	1.5	5.37	10.30	0.6	1.28	6.00	0.4	0.45	9.40	On	1.00	Normal
21	1.5	5.36	10.30	0.6	1.37	6.00	0.4	0.45	9.40	On	1.00	Normal
22	1.5	5.54	10.30	0.6	1.44	6.00	0.4	0.49	9.40	On	1.00	Normal
23	1.5	5.39	10.30	0.7	1.50	6.00	0.5	0.53	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.25	9.53	0.7	1.56	6.00	0.5	0.57	9.40	On	1.00	Normal
01	1.5	4.65	8.10	0.8	1.54	6.00	0.5	0.57	9.40	Off	1.00	Normal
02	1.5	4.41	8.10	0.8	1.55	5.27	0.5	0.61	9.40	Off	1.00	Normal
03	1.5	5.27	8.10	1.0	1.92	3.90	0.6	0.68	9.40	Off	1.00	Normal
04	1.5	5.15	8.10	1.2	2.44	3.90	0.6	0.72	9.40	Off	1.00	Normal
05	1.5	5.10	8.10	1.4	2.99	3.90	0.7	0.76	9.40	Off	1.00	Normal
06	1.5	4.79	8.10	1.5	3.10	3.90	0.7	0.76	9.40	Off	1.00	Normal
07	1.5	4.84	8.10	1.6	3.21	3.90	0.7	0.80	9.40	Off	1.00	Normal
08	1.5	4.49	8.10	1.6	3.11	3.90	0.7	0.80	9.40	Off	1.00	Normal
09	1.4	4.51	8.94	1.5	2.92	4.71	0.7	0.83	9.40	On	1.00	Normal
10	1.5	5.47	10.30	1.4	2.78	6.00	0.7	0.87	9.40	On	1.00	Normal
11	1.5	5.38	10.30	1.3	2.71	6.00	0.8	0.92	9.40	On	1.00	Normal
12	1.5	5.48	10.30	1.2	2.71	6.00	0.8	0.96	9.40	On	1.00	Normal
13	1.5	5.50	10.30	1.1	2.42	6.00	0.8	0.92	9.40	On	1.00	Normal
14	1.5	5.51	10.30	1.0	2.10	6.00	0.8	0.96	9.40	On	1.00	Normal
15	1.5	5.43	10.30	0.9	1.90	6.00	0.8	0.96	9.40	On	1.00	Normal
16	1.4	6.10	10.30	0.7	1.64	6.00	0.9	1.11	9.40	On	1.00	Normal
17	1.5	7.02	10.30	0.5	1.17	6.00	1.0	1.34	9.40	On	1.00	Normal
18	1.5	7.01	10.30	0.2	0.68	6.00	1.2	1.62	9.40	On	1.00	Normal
19	1.5	5.30	10.30	0.3	0.69	6.00	1.2	1.66	9.40	On	1.00	Normal
20	1.5	5.55	10.30	0.5	1.02	6.00	1.2	1.66	9.40	On	1.00	Normal
21	1.5	5.32	10.30	0.6	1.38	6.00	1.2	1.71	9.40	On	1.00	Normal
22	1.5	5.35	10.30	0.7	1.44	6.00	1.2	1.75	9.40	On	1.00	Normal
23	1.5	5.41	10.30	0.7	1.48	6.00	1.2	1.75	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.4	0.23	8.10	0.8	1.02	6.00	1.2	1.71	9.40	Off	0.33	Shutdown
01	N/A	N/A	8.10	NSD	NSD	6.00	1.1	1.71	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	1.1	1.68	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	1.1	1.60	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	1.0	1.56	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	1.0	1.52	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	1.0	1.52	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	1.0	1.48	9.40	Off	0.32	Startup
08	1.4	0.08	8.10	NSD	NSD	3.90	1.0	1.48	9.40	Off	1.00	Startup
09	1.1	3.14	8.10	NSD	NSD	3.90	1.0	1.48	9.40	Off	1.00	Normal
10	1.4	4.89	9.71	0.7	1.03	5.44	1.0	1.48	9.40	On	1.00	Normal
11	1.5	5.38	10.30	0.8	1.61	6.00	1.0	1.44	9.40	On	1.00	Normal
12	1.5	5.48	10.30	0.8	1.71	6.00	1.0	1.44	9.40	On	1.00	Normal
13	1.5	5.41	10.30	0.8	1.67	6.00	1.0	1.44	9.40	On	1.00	Normal
14	1.5	5.52	10.30	0.7	1.57	6.00	0.9	1.40	9.40	On	1.00	Normal
15	1.5	5.60	10.30	0.6	1.42	6.00	0.9	1.40	9.40	On	1.00	Normal
16	1.5	5.46	10.30	0.6	1.36	6.00	0.8	1.25	9.40	On	1.00	Normal
17	1.5	5.40	10.30	0.7	1.45	6.00	0.7	0.97	9.40	On	1.00	Normal
18	1.5	5.48	10.30	0.8	1.67	6.00	0.5	0.69	9.40	On	1.00	Normal
19	1.5	5.48	10.30	0.8	1.77	6.00	0.5	0.65	9.40	On	1.00	Normal
20	1.5	5.29	10.30	0.7	1.64	6.00	0.5	0.65	9.40	On	1.00	Normal
21	1.5	5.38	10.30	0.7	1.51	6.00	0.5	0.61	9.40	On	1.00	Normal
22	1.5	4.72	8.65	0.7	1.44	6.00	0.4	0.56	9.40	On	1.00	Normal
23	1.5	1.41	8.10	0.8	1.17	6.00	0.4	0.52	9.40	Off	0.55	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	4.43	0.4	0.52	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.52	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.52	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.36	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.13	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.3	2.65	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.4	4.90	9.27	NSD	NSD	5.02	0.1	0.12	9.40	On	1.00	Normal
16	1.3	4.68	10.30	0.6	1.09	6.00	0.2	0.20	9.40	On	1.00	Normal
17	1.4	5.49	10.30	0.6	1.34	6.00	0.2	0.25	9.40	On	1.00	Normal
18	1.5	5.80	10.30	0.6	1.31	6.00	0.2	0.33	9.40	On	1.00	Normal
19	1.5	5.74	10.30	0.5	1.22	6.00	0.3	0.38	9.40	On	1.00	Normal
20	1.5	5.54	10.30	0.5	1.28	6.00	0.3	0.42	9.40	On	1.00	Normal
21	1.5	5.46	10.30	0.6	1.41	6.00	0.3	0.46	9.40	On	1.00	Normal
22	1.4	2.64	8.72	0.7	1.29	6.00	0.3	0.46	9.40	On	0.82	Shutdown
23	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.46	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	4.50	0.3	0.46	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.75	Startup
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	1.00	Startup
11	1.3	3.23	8.10	NSD	NSD	3.90	0.3	0.46	9.40	Off	1.00	Startup
12	1.5	5.24	9.97	NSD	NSD	5.69	0.4	0.50	9.40	On	1.00	Normal
13	1.5	5.30	10.30	0.8	1.52	6.00	0.4	0.54	9.40	On	1.00	Normal
14	1.5	5.45	10.30	0.8	1.71	6.00	0.4	0.58	9.40	On	1.00	Normal
15	1.5	5.43	10.30	0.7	1.61	6.00	0.4	0.51	9.40	On	1.00	Normal
16	1.6	6.02	10.30	0.6	1.41	6.00	0.4	0.51	9.40	On	1.00	Normal
17	1.5	7.31	10.30	0.5	1.04	6.00	0.5	0.85	9.40	On	1.00	Normal
18	1.5	7.17	10.30	0.3	0.64	6.00	0.7	1.14	9.40	On	1.00	Normal
19	1.5	5.34	10.30	0.3	0.61	6.00	0.7	1.14	9.40	On	1.00	Normal
20	1.5	5.39	10.30	0.4	0.88	6.00	0.7	1.13	9.40	On	1.00	Normal
21	1.5	5.47	10.30	0.5	1.18	6.00	0.7	1.13	9.40	On	1.00	Normal
22	1.5	5.48	10.30	0.5	1.17	6.00	0.7	1.17	9.40	On	1.00	Normal
23	1.5	5.31	9.79	0.5	1.20	6.00	0.8	1.21	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	0.38	8.10	0.6	0.84	6.00	0.8	1.21	9.40	Off	0.35	Shutdown
01	N/A	N/A	8.10	NSD	NSD	5.51	0.8	1.21	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.8	1.21	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	0.07	Startup
07	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	1.00	Startup
08	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.21	9.40	Off	1.00	Startup
09	1.5	4.16	8.10	NSD	NSD	3.90	0.8	1.21	9.40	Off	1.00	Startup
10	1.5	4.79	8.61	NSD	NSD	4.39	0.8	1.21	9.40	On	1.00	Normal
11	1.5	5.52	10.30	0.6	1.18	6.00	0.8	1.26	9.40	On	1.00	Normal
12	1.5	5.42	10.30	0.6	1.35	6.00	0.8	1.26	9.40	On	1.00	Normal
13	1.5	5.56	10.30	0.6	1.39	6.00	0.8	1.26	9.40	On	1.00	Normal
14	1.5	5.49	10.30	0.6	1.39	6.00	0.8	1.26	9.40	On	1.00	Normal
15	1.5	5.41	10.30	0.6	1.39	6.00	0.8	1.26	9.40	On	1.00	Normal
16	1.5	5.48	10.30	0.7	1.44	6.00	0.8	1.21	9.40	On	1.00	Normal
17	1.5	5.55	10.30	0.7	1.45	6.00	0.7	0.91	9.40	On	1.00	Normal
18	1.3	5.79	10.30	0.5	1.12	6.00	0.6	0.84	9.40	On	1.00	Normal
19	1.4	5.35	10.30	0.5	1.07	6.00	0.7	0.84	9.40	On	1.00	Normal
20	1.5	5.46	10.30	0.5	1.04	6.00	0.6	0.84	9.40	On	1.00	Normal
21	1.5	5.29	9.75	0.6	1.42	6.00	0.6	0.84	9.40	On	1.00	Normal
22	1.4	3.99	8.10	0.8	1.51	6.00	0.6	0.80	9.40	Off	1.00	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.48	0.6	0.76	9.40	Off	0.07	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.6	0.76	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.76	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.72	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.68	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.64	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.52	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.43	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.17	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.4	3.29	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.4	4.25	8.28	NSD	NSD	4.08	0.0	0.04	9.40	On	1.00	Normal
16	1.4	5.53	10.30	0.6	1.08	6.00	0.1	0.13	9.40	On	1.00	Normal
17	1.5	5.58	10.30	0.6	1.29	6.00	0.1	0.17	9.40	On	1.00	Normal
18	1.5	5.36	10.30	0.6	1.45	6.00	0.1	0.21	9.40	On	1.00	Normal
19	1.5	5.46	10.30	0.7	1.57	6.00	0.2	0.25	9.40	On	1.00	Normal
20	1.5	5.40	10.30	0.7	1.50	6.00	0.2	0.29	9.40	On	1.00	Normal
21	1.4	1.58	8.54	0.7	1.10	6.00	0.2	0.29	9.40	On	0.60	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.29	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.32	0.2	0.29	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.62	Startup
13	1.0	0.55	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.0	3.40	8.58	NSD	NSD	4.36	0.1	0.08	9.40	On	1.00	Normal
15	1.5	5.48	10.30	0.7	1.07	6.00	0.1	0.08	9.40	On	1.00	Normal
16	1.5	5.58	10.30	0.7	1.49	6.00	0.1	0.12	9.40	On	1.00	Normal
17	1.5	5.46	10.30	0.7	1.50	6.00	0.1	0.16	9.40	On	1.00	Normal
18	1.5	5.45	10.30	0.7	1.61	6.00	0.2	0.20	9.40	On	1.00	Normal
19	1.5	5.36	10.30	0.8	1.70	6.00	0.2	0.24	9.40	On	1.00	Normal
20	1.5	5.26	10.30	0.8	1.75	6.00	0.2	0.28	9.40	On	1.00	Normal
21	1.5	5.30	8.80	0.8	1.65	6.00	0.2	0.32	9.40	On	1.00	Normal
22	1.5	4.41	8.10	0.8	1.57	6.00	0.3	0.32	9.40	Off	1.00	Normal
23	1.5	0.32	8.10	0.9	1.06	4.57	0.3	0.32	9.40	Off	0.30	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.20	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	1.00	Startup
14	1.4	2.72	8.25	NSD	NSD	4.04	0.2	0.24	9.40	On	1.00	Startup
15	1.6	6.21	9.93	NSD	NSD	5.65	0.2	0.33	9.40	On	1.00	Normal
16	1.5	5.47	10.08	0.7	1.25	5.79	0.3	0.33	9.40	On	1.00	Normal
17	1.5	5.39	8.94	0.6	1.30	5.79	0.2	0.33	9.40	On	1.00	Normal
18	1.5	5.46	10.30	0.7	1.49	6.00	0.2	0.33	9.40	On	1.00	Normal
19	1.5	5.25	10.30	0.8	1.68	6.00	0.2	0.33	9.40	On	1.00	Normal
20	1.5	5.39	10.30	0.8	1.82	6.00	0.2	0.33	9.40	On	1.00	Normal
21	1.5	1.70	8.54	0.9	1.43	6.00	0.2	0.29	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.29	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.32	0.2	0.29	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.13	Startup
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	1.00	Startup
12	1.4	3.37	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Startup
13	1.4	4.97	10.12	NSD	NSD	5.83	0.2	0.33	9.40	On	1.00	Normal
14	1.5	5.52	10.30	0.8	1.67	6.00	0.3	0.37	9.40	On	1.00	Normal
15	1.5	5.50	10.30	0.9	1.93	6.00	0.2	0.33	9.40	On	1.00	Normal
16	1.5	5.49	10.30	0.9	1.96	6.00	0.2	0.33	9.40	On	1.00	Normal
17	1.5	5.42	10.30	0.9	1.97	6.00	0.2	0.33	9.40	On	1.00	Normal
18	1.5	5.36	10.30	0.9	2.03	6.00	0.2	0.33	9.40	On	1.00	Normal
19	1.5	5.48	10.30	0.9	1.96	6.00	0.2	0.33	9.40	On	1.00	Normal
20	1.5	5.40	10.30	0.9	1.95	6.00	0.2	0.33	9.40	On	1.00	Normal
21	1.3	1.43	8.54	0.8	1.43	6.00	0.2	0.33	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.33	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.32	0.2	0.33	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.23	Startup
12	1.1	0.33	8.10	NSD	NSD	3.90	0.2	0.33	9.40	Off	1.00	Startup
13	1.4	4.18	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Normal
14	1.3	3.98	8.98	0.9	1.21	4.74	0.2	0.32	9.40	On	1.00	Normal
15	1.4	4.94	10.30	0.9	1.81	6.00	0.2	0.32	9.40	On	1.00	Normal
16	1.5	5.46	10.30	0.9	1.85	6.00	0.2	0.32	9.40	On	1.00	Normal
17	1.5	5.44	10.30	0.9	1.95	6.00	0.2	0.32	9.40	On	1.00	Normal
18	1.5	5.57	10.30	0.9	1.89	6.00	0.2	0.32	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.9	1.98	6.00	0.2	0.32	9.40	On	1.00	Normal
20	1.5	5.44	10.30	0.9	1.94	6.00	0.2	0.32	9.40	On	1.00	Normal
21	1.5	1.70	8.65	0.9	1.54	6.00	0.2	0.32	9.40	On	0.60	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.32	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.43	0.2	0.32	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.13	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	1.00	Startup
14	1.5	2.91	8.10	NSD	NSD	3.90	0.2	0.25	9.40	Off	1.00	Startup
15	1.3	4.74	9.53	NSD	NSD	5.27	0.2	0.29	9.40	On	1.00	Normal
16	1.5	5.45	10.30	0.8	1.31	6.00	0.3	0.37	9.40	On	1.00	Normal
17	1.5	5.41	10.30	0.7	1.55	6.00	0.3	0.37	9.40	On	1.00	Normal
18	1.5	5.55	10.30	0.7	1.65	6.00	0.2	0.37	9.40	On	1.00	Normal
19	1.5	5.66	10.30	0.8	1.76	6.00	0.3	0.37	9.40	On	1.00	Normal
20	1.5	5.49	10.30	0.8	1.69	6.00	0.3	0.37	9.40	On	1.00	Normal
21	1.5	5.41	10.30	0.8	1.69	6.00	0.3	0.41	9.40	On	1.00	Normal
22	1.5	5.26	10.26	0.8	1.80	6.00	0.3	0.45	9.40	On	1.00	Normal
23	1.4	0.34	8.10	0.9	1.26	6.00	0.3	0.45	9.40	Off	0.33	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	5.97	0.3	0.45	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.45	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.45	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.37	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.21	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 June 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
June 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Mass Emissions Report
 June - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	117.8	3.5	29.7	7.4	39.3	0.8	8.6
02	141.8	5.8	16.0	12.3	44.9	1.3	13.4
03	128.3	11.0	48.4	23.4	42.0	2.2	24.0
04	136.0	6.9	26.1	14.6	36.7	1.5	16.2
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	Down	Down	Down	Down	Down	0.0	0.0
09	147.4	4.3	23.6	9.1	71.4	0.9	10.0
10	125.9	6.6	16.4	14.0	86.8	1.4	14.8
11	177.7	7.0	21.8	14.9	67.5	1.6	16.5
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	112.5	3.6	21.8	7.7	7.4	0.8	8.8
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	102.1	4.5	30.9	9.6	25.1	1.0	10.9
23	101.2	3.7	14.4	7.9	30.1	0.8	8.8
24	96.7	4.6	20.4	9.8	28.3	1.0	10.7
25	93.8	4.1	18.2	8.6	33.0	0.9	9.8
26	101.5	4.5	17.7	9.5	33.5	1.0	10.5
27	Down	Down	Down	Down	Down	0.0	0.0
28	Down	Down	Down	Down	Down	0.0	0.0
29	Down	Down	Down	Down	Down	0.0	0.0
30	Down	Down	Down	Down	Down	0.0	0.0
Total	1583	70	305	149	546.0	15	163
12-Mo Ring	30206	1483	3678	3188	8898	310	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 June - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	6899.3	7133.8	8.63	268.2	277.3	5.20	7411	2593.6	8.30	276.5	7.93	575	8.6
02	11207.0	11587.8	13.42	729.2	753.9	9.13	12342	4479.2	13.20	472.4	13.05	951	13.4
03	20936.6	21648.3	24.00	1656.9	1713.2	15.03	23362	8641.7	24.00	899.5	24.00	1812	24.0
04	13384.0	13839.3	16.20	763.7	789.6	11.98	14629	5338.9	16.20	547.8	16.02	1132	16.2
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	8242.8	8523.2	9.95	535.5	553.7	6.81	9077	3228.9	9.57	372.7	9.05	693	10.0
10	12181.4	12595.5	14.75	1400.7	1448.3	11.62	14044	5247.2	14.58	675.9	14.35	1025	14.8
11	13438.1	13895.1	16.49	963.7	996.3	10.98	14891	5472.2	16.49	619.1	16.24	1128	16.5
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	7071.9	7312.3	8.77	398.9	412.5	5.28	7725	2740.7	8.42	291.1	8.09	590	8.8
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	8811.8	9111.5	10.92	462.9	478.8	6.54	9590	3428.6	10.52	329.7	10.10	738	10.9
23	7230.9	7476.7	8.78	430.9	445.5	5.38	7922	2885.9	8.58	275.0	8.40	608	8.8
24	8966.1	9270.9	10.71	488.6	505.3	8.12	9776	3539.9	10.51	339.5	10.31	759	10.7
25	7990.1	8261.7	9.83	372.8	385.6	6.65	8647	3125.0	9.62	309.1	9.30	668	9.8
26	8565.5	8856.5	10.46	635.4	656.8	7.63	9513	3505.0	10.26	337.0	10.05	721	10.5
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average	10378.9	10731.7		700.6	724.4		11456	4171.3		441.9		877	
Total	134925.5	139513	162.9	9107.4	9417	110.4	148929	54226.8	160.3	5745.3	156.9	11400	163

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.87	Startup
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.4	0.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
18	1.5	5.06	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	1.00	Normal
19	1.5	4.49	8.10	0.1	0.20	3.90	0.0	0.04	9.40	Off	1.00	Normal
20	1.5	0.13	8.10	0.2	0.20	3.90	0.0	0.04	9.40	Off	0.27	Shutdown
21	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.08	Startup
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
19	1.4	3.98	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
20	1.5	5.34	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
21	1.5	5.24	8.10	0.3	0.60	3.90	0.0	0.00	9.40	Off	1.00	Normal
22	1.5	2.72	8.10	0.4	0.74	3.90	0.0	0.00	9.40	Off	0.78	Shutdown
23	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.40	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.3	3.72	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.6	5.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
18	1.5	5.37	8.47	0.3	0.53	4.25	0.0	0.04	9.40	On	1.00	Normal
19	1.4	5.49	10.19	0.3	0.55	5.90	0.1	0.13	9.40	On	1.00	Normal
20	1.4	5.75	10.30	0.2	0.48	6.00	0.2	0.31	9.40	On	1.00	Normal
21	1.4	2.63	9.02	0.2	0.32	6.00	0.2	0.31	9.40	On	0.73	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.31	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.78	0.2	0.31	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.27	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.18	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.70	Startup
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
19	1.3	0.45	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
20	1.2	4.33	8.94	NSD	NSD	4.71	0.1	0.12	9.40	On	1.00	Normal
21	1.3	4.47	8.32	0.2	0.39	4.71	0.1	0.12	9.40	On	1.00	Normal
22	1.4	0.13	8.10	0.2	0.38	4.71	0.1	0.12	9.40	Off	0.27	Shutdown
23	N/A	N/A	8.10	NSD	NSD	4.11	0.1	0.12	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.90	Startup
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
21	1.4	1.01	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
22	1.3	3.89	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
23	1.4	4.15	8.10	0.1	0.13	3.90	0.0	0.00	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.4	0.13	8.10	0.1	0.14	3.90	0.0	0.00	9.40	Off	0.25	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
April 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.68	Startup
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.4	3.99	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.4	4.18	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
16	1.4	4.62	8.10	0.2	0.31	3.90	0.0	0.00	9.40	Off	1.00	Normal
17	1.4	4.80	9.38	0.2	0.47	5.13	0.0	0.04	9.40	On	1.00	Normal
18	1.4	5.06	10.30	0.2	0.46	6.00	0.1	0.08	9.40	On	1.00	Normal
19	1.4	4.97	8.80	0.2	0.48	6.00	0.1	0.08	9.40	On	1.00	Normal
20	1.4	5.07	8.10	0.3	0.56	6.00	0.1	0.08	9.40	Off	1.00	Normal
21	1.2	1.18	8.10	0.3	0.49	4.57	0.1	0.08	9.40	Off	0.60	Startup
22	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Startup
23	1.5	3.55	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Startup

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.49	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Normal
01	1.5	4.47	8.10	0.2	0.38	3.90	0.1	0.08	9.40	Off	1.00	Normal
02	1.5	4.45	8.10	0.2	0.41	3.90	0.1	0.08	9.40	Off	1.00	Normal
03	1.5	4.46	8.10	0.2	0.43	3.90	0.1	0.08	9.40	Off	1.00	Normal
04	1.5	4.70	8.10	0.3	0.50	3.90	0.1	0.11	9.40	Off	1.00	Normal
05	1.5	4.49	8.10	0.3	0.56	3.90	0.1	0.11	9.40	Off	1.00	Normal
06	0.6	1.85	8.10	0.3	0.61	3.90	0.2	0.24	9.40	Off	1.00	Normal
07	1.4	4.19	8.10	0.4	0.62	3.90	0.2	0.24	9.40	Off	1.00	Normal
08	1.5	4.44	8.10	0.4	0.67	3.90	0.2	0.24	9.40	Off	1.00	Normal
09	1.5	4.46	8.10	0.4	0.70	3.90	0.2	0.24	9.40	Off	1.00	Normal
10	1.5	4.48	8.10	0.4	0.73	3.90	0.2	0.24	9.40	Off	1.00	Normal
11	1.5	4.47	8.10	0.4	0.73	3.90	0.2	0.24	9.40	Off	1.00	Normal
12	1.5	4.48	8.10	0.4	0.73	3.90	0.2	0.24	9.40	Off	1.00	Normal
13	1.5	4.50	8.10	0.4	0.70	3.90	0.2	0.24	9.40	Off	1.00	Normal
14	1.5	4.50	8.10	0.4	0.68	3.90	0.2	0.24	9.40	Off	1.00	Normal
15	1.5	4.50	8.10	0.3	0.62	3.90	0.2	0.24	9.40	Off	1.00	Normal
16	1.5	4.67	8.10	0.3	0.63	3.90	0.2	0.24	9.40	Off	1.00	Normal
17	1.5	5.89	8.80	0.3	0.60	4.57	0.3	0.34	9.40	On	1.00	Normal
18	1.4	5.14	8.36	0.3	0.64	4.57	0.2	0.30	9.40	On	1.00	Normal
19	1.5	5.24	8.10	0.3	0.66	4.57	0.2	0.30	9.40	Off	1.00	Normal
20	1.5	5.23	8.10	0.4	0.77	4.15	0.2	0.30	9.40	Off	1.00	Normal
21	1.5	5.22	8.10	0.4	0.82	3.90	0.2	0.30	9.40	Off	1.00	Normal
22	1.5	5.17	8.10	0.4	0.85	3.90	0.2	0.30	9.40	Off	1.00	Normal
23	1.5	5.19	8.10	0.4	0.88	3.90	0.2	0.30	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.43	8.10	0.4	0.78	3.90	0.2	0.30	9.40	Off	1.00	Normal
01	1.5	4.38	8.10	0.3	0.69	3.90	0.2	0.30	9.40	Off	1.00	Normal
02	1.5	4.38	8.10	0.3	0.56	3.90	0.2	0.30	9.40	Off	1.00	Normal
03	1.5	4.38	8.10	0.3	0.56	3.90	0.2	0.30	9.40	Off	1.00	Normal
04	1.5	4.39	8.10	0.3	0.59	3.90	0.2	0.26	9.40	Off	1.00	Normal
05	1.5	4.46	8.10	0.3	0.61	3.90	0.2	0.26	9.40	Off	1.00	Normal
06	1.5	4.40	8.10	0.3	0.61	3.90	0.1	0.13	9.40	Off	1.00	Normal
07	1.5	4.41	8.10	0.3	0.59	3.90	0.1	0.13	9.40	Off	1.00	Normal
08	1.5	4.43	8.10	0.3	0.53	3.90	0.1	0.13	9.40	Off	1.00	Normal
09	1.5	4.43	8.10	0.3	0.51	3.90	0.1	0.13	9.40	Off	1.00	Normal
10	1.5	4.49	8.10	0.3	0.51	3.90	0.1	0.13	9.40	Off	1.00	Normal
11	1.5	4.50	8.10	0.3	0.54	3.90	0.1	0.13	9.40	Off	1.00	Normal
12	1.5	4.47	8.10	0.3	0.57	3.90	0.1	0.16	9.40	Off	1.00	Normal
13	1.5	4.48	8.10	0.3	0.55	3.90	0.1	0.16	9.40	Off	1.00	Normal
14	1.5	4.49	8.10	0.3	0.52	3.90	0.1	0.16	9.40	Off	1.00	Normal
15	1.5	4.85	8.10	0.3	0.57	3.90	0.1	0.16	9.40	Off	1.00	Normal
16	1.5	5.24	8.10	0.3	0.66	3.90	0.1	0.16	9.40	Off	1.00	Normal
17	1.5	5.22	8.10	0.4	0.75	3.90	0.0	0.03	9.40	Off	1.00	Normal
18	1.5	5.21	8.10	0.4	0.76	3.90	0.0	0.03	9.40	Off	1.00	Normal
19	1.5	5.21	8.10	0.4	0.76	3.90	0.0	0.03	9.40	Off	1.00	Normal
20	1.5	5.19	8.10	0.4	0.76	3.90	0.0	0.03	9.40	Off	1.00	Normal
21	1.5	4.46	8.10	0.3	0.64	3.90	0.0	0.03	9.40	Off	1.00	Normal
22	1.5	4.44	8.10	0.3	0.52	3.90	0.0	0.03	9.40	Off	1.00	Normal
23	1.5	4.44	8.10	0.2	0.40	3.90	0.0	0.03	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 April 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.40	8.10	0.2	0.37	3.90	0.0	0.03	9.40	Off	1.00	Normal
01	1.5	4.40	8.10	0.2	0.37	3.90	0.0	0.03	9.40	Off	1.00	Normal
02	1.5	4.40	8.10	0.2	0.37	3.90	0.0	0.03	9.40	Off	1.00	Normal
03	1.5	4.41	8.10	0.2	0.40	3.90	0.0	0.03	9.40	Off	1.00	Normal
04	1.5	4.43	8.10	0.2	0.40	3.90	0.0	0.03	9.40	Off	1.00	Normal
05	1.5	4.44	8.10	0.2	0.40	3.90	0.0	0.03	9.40	Off	1.00	Normal
06	1.5	4.44	8.10	0.2	0.43	3.90	0.0	0.03	9.40	Off	1.00	Normal
07	1.5	4.44	8.10	0.3	0.45	3.90	0.0	0.03	9.40	Off	1.00	Normal
08	1.5	4.46	8.10	0.3	0.48	3.90	0.0	0.03	9.40	Off	1.00	Normal
09	1.5	4.47	8.10	0.3	0.49	3.90	0.0	0.03	9.40	Off	1.00	Normal
10	1.5	4.48	8.10	0.3	0.49	3.90	0.0	0.03	9.40	Off	1.00	Normal
11	1.5	4.44	8.10	0.3	0.49	3.90	0.0	0.03	9.40	Off	1.00	Normal
12	1.5	4.42	8.10	0.3	0.48	3.90	0.0	0.00	9.40	Off	1.00	Normal
13	1.5	4.46	8.10	0.3	0.48	3.90	0.0	0.00	9.40	Off	1.00	Normal
14	1.5	4.48	8.10	0.3	0.51	3.90	0.0	0.00	9.40	Off	1.00	Normal
15	1.5	4.47	8.10	0.3	0.52	3.90	0.0	0.00	9.40	Off	1.00	Normal
16	1.5	4.47	8.10	0.3	0.52	3.90	0.0	0.00	9.40	Off	1.00	Normal
17	1.5	4.46	8.10	0.3	0.52	3.90	0.0	0.00	9.40	Off	1.00	Normal
18	1.5	5.14	8.10	0.3	0.67	3.90	0.0	0.04	9.40	Off	1.00	Normal
19	1.5	5.21	8.10	0.4	0.82	3.90	0.0	0.04	9.40	Off	1.00	Normal
20	1.5	5.19	8.10	0.5	0.95	3.90	0.0	0.04	9.40	Off	1.00	Normal
21	1.5	5.19	8.10	0.5	0.94	3.90	0.0	0.04	9.40	Off	1.00	Normal
22	1.5	5.23	8.10	0.5	0.94	3.90	0.0	0.04	9.40	Off	1.00	Normal
23	1.5	5.23	8.10	0.5	0.95	3.90	0.0	0.04	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 April - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	Down	Down	Down	Down	Down	0.0	0.0
02	171.6	1.5	24.3	6.1	20.0	0.4	5.1
03	Down	Down	Down	Down	Down	0.0	0.0
04	134.9	2.1	20.2	8.8	20.0	0.4	5.9
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	164.8	3.2	30.3	13.1	27.1	1.2	8.1
08	Down	Down	Down	Down	Down	0.0	0.0
09	Down	Down	Down	Down	Down	0.0	0.0
10	159.7	1.5	27.9	6.3	17.1	0.5	5.0
11	Down	Down	Down	Down	Down	0.0	0.0
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	154.8	1.4	19.2	5.8	15.3	0.3	4.9
16	1.4	0.1	2.2	0.2	0.7	0.0	0.3
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	Down	Down	Down	Down	Down	0.0	0.0
23	Down	Down	Down	Down	Down	0.0	0.0
24	Down	Down	Down	Down	Down	0.0	0.0
25	Down	Down	Down	Down	Down	0.0	0.0
26	Down	Down	Down	Down	Down	0.0	0.0
27	256.1	4.4	25.6	18.2	17.4	1.3	12.3
28	107.7	9.7	15.5	40.3	7.1	1.8	24.0
29	107.8	9.5	13.7	39.3	0.8	1.7	24.0
30	108.2	9.5	13.6	39.4	0.9	1.7	24.0
Total	1367	43	193	178	126.4	9	114
12-Mo Ring	21407	1043	2442	4413	4053	490	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 April - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	2977.9	3121.0	5.14	Down	Down	0.00	3121	1127.9	4.76	134.8	4.39	214	5.1
03	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
04	4301.9	4508.3	5.86	Down	Down	0.00	4508	1694.1	5.57	163.6	5.13	350	5.9
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	6200.0	6497.7	8.13	207.7	217.7	2.54	6715	2584.5	7.78	288.6	7.30	511	8.1
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	3070.2	3217.6	4.97	35.5	37.2	0.48	3255	1192.7	4.61	122.6	4.09	228	5.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	2857.0	2994.1	4.90	Down	Down	0.00	2994	1069.8	4.55	106.8	4.13	204	4.9
16	117.1	122.7	0.25	Down	Down	0.00	123	41.3	0.20	8.5	0.18	8	0.3
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
26	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
27	8744.4	9164.2	12.28	161.5	169.3	1.90	9334	3635.6	11.84	279.5	9.77	696	12.3
28	19637.7	20580.3	24.00	119.8	125.6	0.44	20706	7980.0	24.00	629.1	23.35	1656	24.0
29	19252.0	20176.1	24.00	Down	Down	0.00	20176	7853.5	24.00	666.3	24.00	1606	24.0
30	19304.2	20230.9	24.00	Down	Down	0.00	20231	7839.5	24.00	704.3	24.00	1613	24.0
Average	8646.2	9061.3		131.1	137.5		9116	3501.9		310.4		709	
Total	86462.4	90613	113.5	524.5	550	5.4	91163	35018.9	111.3	3104.1	106.3	7086	114

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.40	8.10	0.4	0.79	3.90	0.0	0.04	9.40	Off	1.00	Normal
01	1.5	4.38	8.10	0.3	0.64	3.90	0.0	0.04	9.40	Off	1.00	Normal
02	1.5	4.38	8.10	0.3	0.48	3.90	0.0	0.04	9.40	Off	1.00	Normal
03	1.5	4.40	8.10	0.3	0.48	3.90	0.0	0.04	9.40	Off	1.00	Normal
04	1.5	4.40	8.10	0.3	0.48	3.90	0.0	0.04	9.40	Off	1.00	Normal
05	1.5	4.45	8.10	0.3	0.48	3.90	0.0	0.04	9.40	Off	1.00	Normal
06	1.5	4.38	8.10	0.3	0.48	3.90	0.0	0.04	9.40	Off	1.00	Normal
07	1.5	4.39	8.10	0.3	0.51	3.90	0.0	0.04	9.40	Off	1.00	Normal
08	1.5	4.80	8.10	0.3	0.58	3.90	0.1	0.07	9.40	Off	1.00	Normal
09	1.5	4.93	8.10	0.4	0.72	3.90	0.1	0.07	9.40	Off	1.00	Normal
10	1.5	4.38	8.10	0.4	0.72	3.90	0.1	0.07	9.40	Off	1.00	Normal
11	1.5	4.33	8.10	0.4	0.67	3.90	0.1	0.07	9.40	Off	1.00	Normal
12	1.5	4.32	8.10	0.3	0.55	3.90	0.1	0.07	9.40	Off	1.00	Normal
13	1.5	4.39	8.10	0.3	0.55	3.90	0.1	0.07	9.40	Off	1.00	Normal
14	1.5	4.60	8.10	0.3	0.59	3.90	0.1	0.07	9.40	Off	1.00	Normal
15	1.5	4.41	8.10	0.3	0.60	3.90	0.1	0.07	9.40	Off	1.00	Normal
16	1.5	4.67	8.10	0.3	0.63	3.90	0.1	0.07	9.40	Off	1.00	Normal
17	1.6	5.42	8.43	0.4	0.70	4.22	0.1	0.15	9.40	On	1.00	Normal
18	1.3	4.74	9.20	0.4	0.78	4.95	0.1	0.19	9.40	On	1.00	Normal
19	1.5	5.29	8.10	0.4	0.87	4.95	0.1	0.19	9.40	Off	1.00	Normal
20	1.4	5.04	8.10	0.4	0.90	4.95	0.1	0.19	9.40	Off	1.00	Normal
21	1.5	5.29	8.10	0.5	0.95	3.90	0.1	0.19	9.40	Off	1.00	Normal
22	1.5	5.20	8.10	0.5	0.95	3.90	0.1	0.19	9.40	Off	1.00	Normal
23	1.5	5.13	8.10	0.5	0.97	3.90	0.1	0.19	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.39	8.10	0.4	0.85	3.90	0.1	0.19	9.40	Off	1.00	Normal
01	1.5	4.38	8.10	0.4	0.72	3.90	0.1	0.19	9.40	Off	1.00	Normal
02	1.5	4.38	8.10	0.3	0.56	3.90	0.1	0.19	9.40	Off	1.00	Normal
03	1.5	4.38	8.10	0.3	0.53	3.90	0.1	0.19	9.40	Off	1.00	Normal
04	1.5	4.37	8.10	0.3	0.53	3.90	0.1	0.19	9.40	Off	1.00	Normal
05	1.5	4.44	8.10	0.3	0.51	3.90	0.1	0.19	9.40	Off	1.00	Normal
06	1.5	4.36	8.10	0.3	0.51	3.90	0.1	0.19	9.40	Off	1.00	Normal
07	1.5	4.41	8.10	0.3	0.51	3.90	0.1	0.19	9.40	Off	1.00	Normal
08	1.5	4.41	8.10	0.3	0.53	3.90	0.1	0.16	9.40	Off	1.00	Normal
09	1.5	4.39	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
10	1.5	4.41	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
11	1.5	4.42	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
12	1.5	4.39	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
13	1.5	4.40	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
14	1.5	4.38	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
15	1.5	4.37	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
16	1.5	4.43	8.10	0.3	0.56	3.90	0.1	0.16	9.40	Off	1.00	Normal
17	1.5	4.52	8.10	0.3	0.59	3.90	0.1	0.08	9.40	Off	1.00	Normal
18	1.5	5.05	8.10	0.4	0.74	3.90	0.0	0.00	9.40	Off	1.00	Normal
19	1.5	5.12	8.10	0.5	0.93	3.90	0.0	0.00	9.40	Off	1.00	Normal
20	1.5	4.75	8.10	0.5	0.97	3.90	0.0	0.00	9.40	Off	1.00	Normal
21	1.5	4.66	8.10	0.4	0.89	3.90	0.0	0.00	9.40	Off	1.00	Normal
22	1.5	4.37	8.10	0.4	0.67	3.90	0.0	0.00	9.40	Off	1.00	Normal
23	1.5	4.36	8.10	0.3	0.60	3.90	0.0	0.00	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.35	8.10	0.3	0.50	3.90	0.0	0.00	9.40	Off	1.00	Normal
01	1.5	4.36	8.10	0.3	0.50	3.90	0.0	0.00	9.40	Off	1.00	Normal
02	1.5	4.37	8.10	0.3	0.50	3.90	0.0	0.00	9.40	Off	1.00	Normal
03	1.5	4.39	8.10	0.3	0.53	3.90	0.0	0.00	9.40	Off	1.00	Normal
04	1.5	4.38	8.10	0.3	0.56	3.90	0.0	0.00	9.40	Off	1.00	Normal
05	1.5	4.38	8.10	0.3	0.56	3.90	0.0	0.00	9.40	Off	1.00	Normal
06	1.5	4.35	8.10	0.3	0.58	3.90	0.0	0.00	9.40	Off	1.00	Normal
07	1.5	4.39	8.10	0.4	0.64	3.90	0.0	0.00	9.40	Off	1.00	Normal
08	1.5	4.41	8.10	0.4	0.69	3.90	0.0	0.00	9.40	Off	1.00	Normal
09	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
10	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
11	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
12	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
13	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
14	1.5	4.41	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
15	1.5	4.39	8.10	0.4	0.72	3.90	0.0	0.00	9.40	Off	1.00	Normal
16	1.5	4.68	8.10	0.4	0.76	3.90	0.0	0.00	9.40	Off	1.00	Normal
17	1.5	5.02	8.58	0.5	0.89	4.36	0.0	0.00	9.40	On	1.00	Normal
18	1.6	6.60	10.30	0.4	0.84	6.00	0.2	0.28	9.40	On	1.00	Normal
19	1.6	7.31	10.30	0.3	0.68	6.00	0.4	0.58	9.40	On	1.00	Normal
20	1.4	5.42	10.30	0.2	0.59	6.00	0.5	0.66	9.40	On	1.00	Normal
21	1.7	5.44	9.16	0.3	0.66	6.00	0.5	0.66	9.40	On	1.00	Normal
22	1.7	5.06	8.10	0.4	0.79	6.00	0.5	0.66	9.40	Off	1.00	Normal
23	1.7	4.91	8.10	0.4	0.73	4.92	0.5	0.66	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.7	4.86	8.10	0.4	0.65	3.90	0.4	0.66	9.40	Off	1.00	Normal
01	1.7	4.83	8.10	0.3	0.58	3.90	0.4	0.66	9.40	Off	1.00	Normal
02	1.7	4.85	8.10	0.3	0.58	3.90	0.4	0.66	9.40	Off	1.00	Normal
03	1.7	4.87	8.10	0.3	0.61	3.90	0.4	0.66	9.40	Off	1.00	Normal
04	1.6	4.68	8.10	0.4	0.67	3.90	0.4	0.66	9.40	Off	1.00	Normal
05	1.5	4.42	8.10	0.4	0.70	3.90	0.4	0.66	9.40	Off	1.00	Normal
06	1.6	4.78	8.10	0.4	0.76	3.90	0.4	0.66	9.40	Off	1.00	Normal
07	1.6	4.68	8.10	0.4	0.82	3.90	0.4	0.66	9.40	Off	1.00	Normal
08	1.6	4.71	8.10	0.5	0.85	3.90	0.4	0.66	9.40	Off	1.00	Normal
09	1.6	4.73	8.10	0.4	0.83	3.90	0.4	0.66	9.40	Off	1.00	Normal
10	1.6	4.72	8.10	0.4	0.80	3.90	0.4	0.66	9.40	Off	1.00	Normal
11	1.6	4.70	8.10	0.4	0.77	3.90	0.4	0.66	9.40	Off	1.00	Normal
12	1.6	4.72	8.10	0.4	0.77	3.90	0.4	0.66	9.40	Off	1.00	Normal
13	1.6	4.73	8.10	0.4	0.77	3.90	0.4	0.66	9.40	Off	1.00	Normal
14	1.6	4.70	8.10	0.4	0.77	3.90	0.4	0.66	9.40	Off	1.00	Normal
15	1.6	4.73	8.10	0.4	0.75	3.90	0.4	0.66	9.40	Off	1.00	Normal
16	1.7	5.64	8.61	0.4	0.79	4.39	0.5	0.78	9.40	On	1.00	Normal
17	1.5	5.77	10.30	0.4	0.83	6.00	0.6	0.95	9.40	On	1.00	Normal
18	1.6	7.23	10.30	0.3	0.72	6.00	0.6	0.97	9.40	On	1.00	Normal
19	1.6	7.26	10.30	0.2	0.53	6.00	0.6	0.98	9.40	On	1.00	Normal
20	1.5	5.60	9.86	0.2	0.52	6.00	0.5	0.93	9.40	On	1.00	Normal
21	1.6	5.61	8.10	0.3	0.74	6.00	0.5	0.93	9.40	Off	1.00	Normal
22	1.6	5.60	8.10	0.4	0.96	5.58	0.5	0.93	9.40	Off	1.00	Normal
23	1.6	3.92	8.10	0.5	0.94	3.90	0.5	0.93	9.40	Off	1.00	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlmg Avg)		NH3 (24 Hr Rlmg Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlmg	Normal Op CO lbs 3-Hr Rlmg	Normal Op CO lbs 3-Hr Rlmg Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlmg	Normal Ops NH3 lbs 24-Hr Rlmg	Normal Ops NH3 lbs 24-Hr Rlmg Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.93	9.40	Off	0.03	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.93	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.82	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.65	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.34	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.98	Startup
22	1.5	0.35	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
23	1.6	4.68	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	4.75	8.10	0.1	0.04	3.90	0.0	0.00	9.40	Off	1.00	Normal
01	1.6	4.75	8.10	0.0	0.03	3.90	0.0	0.00	9.40	Off	1.00	Normal
02	1.6	4.73	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
03	1.6	4.74	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
04	1.6	4.76	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
05	1.6	4.82	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
06	1.6	4.75	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
07	1.6	4.76	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
08	1.6	4.75	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
09	1.6	4.77	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
10	1.6	4.78	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
11	1.6	4.79	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
12	1.6	4.80	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
13	1.6	4.83	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
14	1.6	4.83	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
15	1.6	4.91	8.47	0.0	0.00	4.25	0.0	0.03	9.40	On	1.00	Normal
16	1.6	5.60	10.30	0.0	0.00	6.00	0.0	0.07	9.40	On	1.00	Normal
17	1.6	5.74	10.30	0.0	0.00	6.00	0.1	0.11	9.40	On	1.00	Normal
18	1.6	5.73	10.30	0.0	0.00	6.00	0.1	0.15	9.40	On	1.00	Normal
19	1.6	5.72	10.30	0.0	0.00	6.00	0.1	0.19	9.40	On	1.00	Normal
20	1.5	5.55	10.30	0.0	0.00	6.00	0.1	0.23	9.40	On	1.00	Normal
21	1.6	5.72	10.30	0.0	0.00	6.00	0.1	0.27	9.40	On	1.00	Normal
22	1.5	5.54	10.30	0.0	0.00	6.00	0.2	0.31	9.40	On	1.00	Normal
23	1.6	5.72	10.08	0.0	0.00	6.00	0.2	0.35	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	4.94	8.10	0.0	0.00	6.00	0.2	0.35	9.40	Off	1.00	Normal
01	1.6	4.78	8.10	0.0	0.00	5.79	0.2	0.35	9.40	Off	1.00	Normal
02	1.6	4.78	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
03	1.6	4.77	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
04	1.6	4.75	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
05	1.6	4.82	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
06	1.6	4.73	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
07	1.6	4.74	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
08	1.6	4.74	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
09	1.6	4.76	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
10	1.6	4.77	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
11	1.6	4.78	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
12	1.6	4.76	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
13	1.6	4.82	8.10	0.0	0.00	3.90	0.2	0.35	9.40	Off	1.00	Normal
14	1.5	4.92	9.05	0.0	0.00	4.81	0.2	0.39	9.40	On	1.00	Normal
15	1.6	5.87	10.30	0.0	0.00	6.00	0.2	0.35	9.40	On	1.00	Normal
16	1.6	5.88	10.30	0.0	0.00	6.00	0.2	0.35	9.40	On	1.00	Normal
17	1.6	5.91	10.30	0.0	0.00	6.00	0.2	0.35	9.40	On	1.00	Normal
18	1.6	5.90	10.30	0.0	0.00	6.00	0.2	0.36	9.40	On	1.00	Normal
19	1.6	5.82	10.30	0.0	0.00	6.00	0.2	0.36	9.40	On	1.00	Normal
20	1.6	5.85	10.30	0.0	0.00	6.00	0.2	0.36	9.40	On	1.00	Normal
21	1.6	5.82	10.30	0.0	0.00	6.00	0.2	0.36	9.40	On	1.00	Normal
22	1.6	5.79	10.30	0.0	0.00	6.00	0.2	0.36	9.40	On	1.00	Normal
23	1.6	5.77	9.27	0.0	0.00	6.00	0.2	0.32	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	4.81	8.10	0.0	0.00	6.00	0.2	0.32	9.40	Off	1.00	Normal
01	1.6	4.79	8.10	0.0	0.00	5.02	0.2	0.32	9.40	Off	1.00	Normal
02	1.6	4.71	8.10	0.0	0.00	3.90	0.2	0.32	9.40	Off	1.00	Normal
03	1.6	4.70	8.10	0.0	0.00	3.90	0.2	0.32	9.40	Off	1.00	Normal
04	1.6	4.71	8.10	0.0	0.00	3.90	0.2	0.32	9.40	Off	1.00	Normal
05	1.6	4.64	8.10	0.0	0.00	3.90	0.2	0.32	9.40	Off	1.00	Normal
06	1.6	4.71	8.10	0.0	0.03	3.90	0.2	0.32	9.40	Off	1.00	Normal
07	1.6	4.72	8.10	0.0	0.08	3.90	0.2	0.32	9.40	Off	1.00	Normal
08	1.6	4.72	8.10	0.1	0.11	3.90	0.2	0.32	9.40	Off	1.00	Normal
09	1.6	4.74	8.10	0.1	0.11	3.90	0.2	0.32	9.40	Off	1.00	Normal
10	1.6	4.76	8.10	0.0	0.08	3.90	0.2	0.32	9.40	Off	1.00	Normal
11	1.6	4.77	8.10	0.0	0.08	3.90	0.2	0.32	9.40	Off	1.00	Normal
12	1.6	4.78	8.10	0.0	0.08	3.90	0.2	0.32	9.40	Off	1.00	Normal
13	1.6	4.78	8.10	0.1	0.08	3.90	0.2	0.32	9.40	Off	1.00	Normal
14	1.5	5.13	8.10	0.1	0.08	3.90	0.2	0.28	9.40	Off	1.00	Normal
15	1.7	7.52	10.08	0.0	0.06	5.79	0.3	0.58	9.40	On	1.00	Normal
16	1.6	7.73	10.30	0.0	0.03	6.00	0.5	0.85	9.40	On	1.00	Normal
17	1.6	7.77	10.30	0.0	0.00	6.00	0.6	1.13	9.40	On	1.00	Normal
18	1.6	7.11	10.30	0.0	0.00	6.00	0.8	1.39	9.40	On	1.00	Normal
19	1.6	6.00	10.30	0.0	0.00	6.00	0.8	1.39	9.40	On	1.00	Normal
20	1.6	5.97	10.30	0.0	0.00	6.00	0.8	1.39	9.40	On	1.00	Normal
21	1.6	5.88	10.30	0.0	0.00	6.00	0.8	1.39	9.40	On	1.00	Normal
22	1.6	5.84	10.30	0.0	0.00	6.00	0.8	1.39	9.40	On	1.00	Normal
23	1.6	5.73	10.08	0.0	0.00	6.00	0.8	1.43	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	4.80	8.10	0.0	0.00	6.00	0.8	1.43	9.40	Off	1.00	Normal
01	1.6	4.73	8.10	0.0	0.00	5.79	0.8	1.43	9.40	Off	1.00	Normal
02	1.6	4.70	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
03	1.6	4.69	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
04	1.6	4.68	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
05	1.6	4.66	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
06	1.6	4.68	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
07	1.6	4.68	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
08	1.6	4.71	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
09	1.6	4.73	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
10	1.6	4.75	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
11	1.6	4.78	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
12	1.6	4.79	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
13	1.6	4.80	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
14	1.6	4.80	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
15	1.6	5.10	8.10	0.0	0.03	3.90	0.7	1.14	9.40	Off	1.00	Normal
16	1.6	5.78	8.76	0.0	0.03	4.53	0.5	0.86	9.40	On	1.00	Normal
17	1.6	5.92	10.30	0.0	0.06	6.00	0.4	0.58	9.40	On	1.00	Normal
18	1.6	5.90	10.30	0.0	0.07	6.00	0.2	0.32	9.40	On	1.00	Normal
19	1.6	5.83	10.30	0.0	0.10	6.00	0.2	0.32	9.40	On	1.00	Normal
20	1.6	5.75	10.30	0.1	0.10	6.00	0.2	0.32	9.40	On	1.00	Normal
21	1.6	5.81	10.30	0.1	0.13	6.00	0.2	0.32	9.40	On	1.00	Normal
22	1.6	5.76	10.30	0.1	0.16	6.00	0.2	0.32	9.40	On	1.00	Normal
23	1.6	5.68	10.30	0.1	0.19	6.00	0.2	0.32	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	5.52	9.57	0.1	0.22	6.00	0.2	0.36	9.40	On	1.00	Normal
01	1.6	4.72	8.10	0.1	0.18	6.00	0.2	0.36	9.40	Off	1.00	Normal
02	1.6	4.68	8.10	0.1	0.15	5.30	0.2	0.36	9.40	Off	1.00	Normal
03	1.6	4.70	8.10	0.1	0.11	3.90	0.2	0.36	9.40	Off	1.00	Normal
04	1.6	4.69	8.10	0.1	0.13	3.90	0.2	0.36	9.40	Off	1.00	Normal
05	1.6	4.69	8.10	0.1	0.16	3.90	0.2	0.36	9.40	Off	1.00	Normal
06	1.6	4.67	8.10	0.1	0.11	3.90	0.2	0.36	9.40	Off	1.00	Normal
07	1.6	4.71	8.10	0.1	0.08	3.90	0.2	0.36	9.40	Off	1.00	Normal
08	1.6	4.74	8.10	0.0	0.05	3.90	0.2	0.36	9.40	Off	1.00	Normal
09	1.6	4.75	8.10	0.0	0.08	3.90	0.2	0.36	9.40	Off	1.00	Normal
10	1.6	4.79	8.10	0.1	0.11	3.90	0.2	0.36	9.40	Off	1.00	Normal
11	1.6	4.80	8.10	0.1	0.13	3.90	0.2	0.36	9.40	Off	1.00	Normal
12	1.6	4.81	8.10	0.1	0.16	3.90	0.2	0.36	9.40	Off	1.00	Normal
13	1.6	4.80	8.10	0.1	0.13	3.90	0.2	0.36	9.40	Off	1.00	Normal
14	1.6	4.78	8.10	0.0	0.08	3.90	0.2	0.36	9.40	Off	1.00	Normal
15	1.6	4.77	8.10	0.0	0.03	3.90	0.2	0.36	9.40	Off	1.00	Normal
16	1.6	4.79	8.10	0.0	0.03	3.90	0.2	0.32	9.40	Off	1.00	Normal
17	1.6	5.14	8.91	0.1	0.09	4.67	0.2	0.31	9.40	On	1.00	Normal
18	1.6	5.85	10.30	0.1	0.19	6.00	0.2	0.31	9.40	On	1.00	Normal
19	1.6	5.78	10.30	0.1	0.29	6.00	0.2	0.31	9.40	On	1.00	Normal
20	1.6	5.65	10.30	0.2	0.36	6.00	0.2	0.31	9.40	On	1.00	Normal
21	1.6	5.52	10.30	0.2	0.42	6.00	0.2	0.31	9.40	On	1.00	Normal
22	1.5	5.54	10.30	0.2	0.42	6.00	0.2	0.31	9.40	On	1.00	Normal
23	1.6	5.71	9.71	0.2	0.45	6.00	0.2	0.31	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	4.98	8.10	0.2	0.35	6.00	0.2	0.28	9.40	Off	1.00	Normal
01	1.6	4.72	8.10	0.1	0.22	5.44	0.2	0.28	9.40	Off	1.00	Normal
02	1.6	4.72	8.10	0.0	0.06	3.90	0.2	0.28	9.40	Off	1.00	Normal
03	1.6	4.70	8.10	0.0	0.00	3.90	0.2	0.28	9.40	Off	1.00	Normal
04	1.6	4.70	8.10	0.0	0.00	3.90	0.2	0.28	9.40	Off	1.00	Normal
05	1.6	4.71	8.10	0.0	0.00	3.90	0.2	0.28	9.40	Off	1.00	Normal
06	1.6	4.71	8.10	0.0	0.03	3.90	0.2	0.28	9.40	Off	1.00	Normal
07	1.6	4.69	8.10	0.0	0.08	3.90	0.2	0.28	9.40	Off	1.00	Normal
08	1.6	4.72	8.10	0.1	0.13	3.90	0.2	0.28	9.40	Off	1.00	Normal
09	1.6	4.71	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
10	1.6	4.72	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
11	1.6	4.71	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
12	1.6	4.74	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
13	1.6	4.83	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
14	1.6	4.90	8.10	0.1	0.19	3.90	0.2	0.28	9.40	Off	1.00	Normal
15	1.6	4.85	8.10	0.1	0.16	3.90	0.2	0.28	9.40	Off	1.00	Normal
16	1.6	4.83	8.72	0.1	0.17	4.50	0.2	0.31	9.40	On	1.00	Normal
17	1.6	6.33	10.30	0.1	0.12	6.00	0.3	0.55	9.40	On	1.00	Normal
18	1.5	6.46	10.30	0.0	0.09	6.00	0.5	0.85	9.40	On	1.00	Normal
19	1.5	6.98	10.30	0.0	0.04	6.00	0.7	1.12	9.40	On	1.00	Normal
20	1.5	5.95	10.30	0.0	0.00	6.00	0.7	1.26	9.40	On	1.00	Normal
21	1.6	5.89	10.19	0.0	0.00	6.00	0.8	1.30	9.40	On	1.00	Normal
22	1.6	5.71	8.10	0.0	0.10	6.00	0.8	1.26	9.40	Off	1.00	Normal
23	1.6	0.16	8.10	0.1	0.10	5.90	0.7	1.22	9.40	Off	0.30	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.92	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.57	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.43	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	4.22	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.07	Startup
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
12	1.0	0.95	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
13	0.9	3.30	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Normal
14	0.8	2.73	8.10	0.0	0.00	3.90	0.1	0.16	9.40	Off	1.00	Normal
15	1.1	3.73	8.10	0.0	0.00	3.90	0.1	0.16	9.40	Off	1.00	Normal
16	1.1	3.44	8.10	0.0	0.00	3.90	0.1	0.16	9.40	Off	1.00	Normal
17	1.1	3.07	8.10	0.0	0.00	3.90	0.1	0.16	9.40	Off	1.00	Normal
18	1.1	3.57	8.10	0.0	0.00	3.90	0.1	0.19	9.40	Off	1.00	Normal
19	1.0	1.48	8.10	0.0	0.00	3.90	0.1	0.19	9.40	Off	0.63	Shutdown
20	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down
21	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.11	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.85	Startup
16	1.2	0.11	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.3	4.00	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
18	1.5	6.06	9.16	0.0	0.00	4.92	0.1	0.18	9.40	On	1.00	Normal
19	1.4	5.16	9.31	0.0	0.00	5.06	0.1	0.22	9.40	On	1.00	Normal
20	1.5	5.23	8.10	0.0	0.00	5.06	0.1	0.22	9.40	Off	1.00	Normal
21	1.5	5.23	8.10	0.0	0.00	5.06	0.1	0.22	9.40	Off	1.00	Normal
22	1.5	5.23	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
23	1.5	5.24	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.56	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
01	1.5	4.41	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
02	1.5	4.38	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
03	1.5	4.40	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
04	1.5	4.40	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
05	1.5	4.36	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
06	1.5	0.23	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	0.28	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.22	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.22	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	0.03	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	1.00	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	1.00	Startup
15	1.5	3.51	8.10	NSD	NSD	3.90	0.1	0.22	9.40	Off	1.00	Startup
16	1.5	4.56	8.10	NSD	NSD	3.90	0.1	0.22	9.40	Off	1.00	Normal
17	1.5	4.70	8.10	0.0	0.00	3.90	0.1	0.22	9.40	Off	1.00	Normal
18	1.5	5.44	8.10	0.0	0.00	3.90	0.0	0.08	9.40	Off	1.00	Normal
19	1.5	5.33	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
20	1.5	5.32	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
21	1.5	5.31	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
22	1.5	5.32	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
23	1.5	5.31	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.32	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
01	1.4	4.44	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
02	1.5	4.49	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
03	1.5	4.45	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
04	1.5	4.41	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
05	1.5	4.38	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
06	1.5	4.38	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
07	1.5	4.50	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
08	1.5	0.23	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	0.28	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.35	Startup
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	1.00	Startup
13	1.5	3.46	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	1.00	Startup
14	1.5	4.44	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	1.00	Normal
15	1.4	5.22	9.57	0.0	0.00	5.30	0.1	0.12	9.40	On	1.00	Normal
16	1.5	5.44	10.30	0.0	0.00	6.00	0.1	0.12	9.40	On	1.00	Normal
17	1.5	5.50	10.30	0.0	0.00	6.00	0.1	0.12	9.40	On	1.00	Normal
18	1.5	5.61	10.30	0.0	0.00	6.00	0.1	0.17	9.40	On	1.00	Normal
19	1.5	5.54	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
20	1.5	5.73	10.30	0.0	0.00	6.00	0.2	0.25	9.40	On	1.00	Normal
21	1.5	5.56	10.30	0.0	0.00	6.00	0.2	0.30	9.40	On	1.00	Normal
22	1.5	5.47	10.30	0.0	0.00	6.00	0.2	0.34	9.40	On	1.00	Normal
23	1.5	5.43	9.57	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.55	8.10	0.0	0.00	6.00	0.2	0.38	9.40	Off	1.00	Normal
01	1.5	0.22	8.10	0.0	0.00	5.30	0.2	0.38	9.40	Off	0.28	Shutdown
02	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.38	9.40	Off	0.00	Down
03	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.38	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.38	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.38	9.40	Off	0.22	Startup
06	1.6	1.09	8.10	NSD	NSD	3.90	0.2	0.38	9.40	Off	1.00	Startup
07	1.6	4.68	8.10	NSD	NSD	3.90	0.2	0.38	9.40	Off	1.00	Normal
08	1.6	4.77	8.10	0.0	0.00	3.90	0.2	0.38	9.40	Off	1.00	Normal
09	1.6	5.30	8.10	0.0	0.00	3.90	0.2	0.38	9.40	Off	1.00	Normal
10	1.6	5.48	8.10	0.0	0.00	3.90	0.2	0.38	9.40	Off	1.00	Normal
11	1.6	4.75	8.10	0.0	0.00	3.90	0.2	0.38	9.40	Off	1.00	Normal
12	1.6	5.79	9.79	0.0	0.00	5.51	0.2	0.41	9.40	On	1.00	Normal
13	1.6	7.34	10.30	0.0	0.00	6.00	0.4	0.68	9.40	On	1.00	Normal
14	1.6	7.59	10.30	0.0	0.00	6.00	0.5	0.94	9.40	On	1.00	Normal
15	1.6	7.55	10.30	0.0	0.00	6.00	0.6	1.12	9.40	On	1.00	Normal
16	1.6	7.55	10.30	0.0	0.00	6.00	0.7	1.38	9.40	On	1.00	Normal
17	1.6	7.62	10.30	0.0	0.00	6.00	0.8	1.64	9.40	On	1.00	Normal
18	1.6	5.99	10.30	0.0	0.00	6.00	0.8	1.60	9.40	On	1.00	Normal
19	1.6	6.02	10.30	0.0	0.00	6.00	0.8	1.56	9.40	On	1.00	Normal
20	1.6	5.87	10.30	0.0	0.00	6.00	0.8	1.56	9.40	On	1.00	Normal
21	1.4	5.24	10.30	0.0	0.00	6.00	0.8	1.52	9.40	On	1.00	Normal
22	1.6	5.86	10.30	0.0	0.00	6.00	0.8	1.47	9.40	On	1.00	Normal
23	1.6	5.78	9.35	0.0	0.00	6.00	0.8	1.43	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.71	8.10	0.0	0.00	6.00	0.8	1.43	9.40	Off	1.00	Normal
01	1.5	4.48	8.10	0.0	0.00	5.09	0.8	1.43	9.40	Off	1.00	Normal
02	1.5	4.46	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
03	1.5	4.46	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
04	1.5	4.46	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
05	1.5	4.37	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
06	1.5	4.43	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
07	1.5	4.44	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
08	1.5	4.48	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
09	1.5	4.48	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
10	1.5	4.48	8.10	0.0	0.00	3.90	0.8	1.43	9.40	Off	1.00	Normal
11	1.6	6.64	10.26	0.0	0.00	5.97	0.9	1.58	9.40	On	1.00	Normal
12	1.5	5.42	10.30	0.0	0.00	6.00	0.8	1.58	9.40	On	1.00	Normal
13	1.5	5.67	10.30	0.0	0.00	6.00	0.7	1.36	9.40	On	1.00	Normal
14	1.5	5.77	10.30	0.0	0.00	6.00	0.6	1.14	9.40	On	1.00	Normal
15	1.5	5.81	10.30	0.0	0.00	6.00	0.6	0.92	9.40	On	1.00	Normal
16	1.5	6.95	10.30	0.0	0.00	6.00	0.6	0.98	9.40	On	1.00	Normal
17	1.5	7.14	10.30	0.0	0.00	6.00	0.6	1.03	9.40	On	1.00	Normal
18	1.5	5.64	10.30	0.0	0.00	6.00	0.6	1.03	9.40	On	1.00	Normal
19	1.5	5.54	10.30	0.0	0.00	6.00	0.6	1.07	9.40	On	1.00	Normal
20	1.5	5.56	10.30	0.0	0.00	6.00	0.6	1.07	9.40	On	1.00	Normal
21	1.5	5.43	10.30	0.0	0.00	6.00	0.6	1.11	9.40	On	1.00	Normal
22	1.5	5.43	10.30	0.0	0.00	6.00	0.6	1.15	9.40	On	1.00	Normal
23	1.5	5.34	9.53	0.0	0.00	6.00	0.6	1.15	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.48	8.10	0.0	0.00	6.00	0.6	1.15	9.40	Off	1.00	Normal
01	1.5	4.42	8.10	0.0	0.00	5.27	0.6	1.15	9.40	Off	1.00	Normal
02	1.5	4.42	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
03	1.5	4.42	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
04	1.5	4.41	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
05	1.5	4.42	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
06	1.5	4.41	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
07	1.5	4.42	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
08	1.5	4.44	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
09	1.5	4.45	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
10	1.5	4.45	8.10	0.0	0.00	3.90	0.6	1.15	9.40	Off	1.00	Normal
11	1.5	4.79	8.61	0.0	0.00	4.39	0.5	1.01	9.40	On	1.00	Normal
12	1.5	5.61	10.30	0.0	0.00	6.00	0.5	1.01	9.40	On	1.00	Normal
13	1.5	5.53	10.30	0.0	0.00	6.00	0.5	1.01	9.40	On	1.00	Normal
14	1.5	5.54	10.30	0.0	0.00	6.00	0.5	0.97	9.40	On	1.00	Normal
15	1.5	5.51	10.30	0.0	0.00	6.00	0.5	0.92	9.40	On	1.00	Normal
16	1.5	5.53	10.30	0.0	0.00	6.00	0.3	0.65	9.40	On	1.00	Normal
17	1.5	5.71	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
18	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
19	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
20	1.5	5.38	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
21	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
22	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal
23	1.5	5.29	9.16	0.0	0.00	6.00	0.2	0.37	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 May 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.44	8.10	0.0	0.00	6.00	0.2	0.37	9.40	Off	1.00	Normal
01	1.4	5.07	8.58	0.0	0.00	4.92	0.2	0.37	9.40	On	1.00	Normal
02	1.5	5.38	10.30	0.0	0.00	6.00	0.2	0.41	9.40	On	1.00	Normal
03	1.5	5.38	10.30	0.0	0.00	6.00	0.2	0.45	9.40	On	1.00	Normal
04	1.5	5.36	10.30	0.0	0.00	6.00	0.3	0.49	9.40	On	1.00	Normal
05	1.5	5.28	10.30	0.0	0.00	6.00	0.3	0.53	9.40	On	1.00	Normal
06	1.5	5.51	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
07	1.5	5.40	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
08	1.5	5.41	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
09	1.5	5.43	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
10	1.5	5.36	10.30	0.0	0.00	6.00	0.3	0.61	9.40	On	1.00	Normal
11	1.5	5.39	10.30	0.0	0.00	6.00	0.3	0.61	9.40	On	1.00	Normal
12	1.5	6.01	10.30	0.0	0.00	6.00	0.4	0.65	9.40	On	1.00	Normal
13	1.5	5.37	10.30	0.0	0.00	6.00	0.4	0.61	9.40	On	1.00	Normal
14	1.5	5.42	10.30	0.0	0.00	6.00	0.3	0.61	9.40	On	1.00	Normal
15	1.5	6.44	10.30	0.0	0.00	6.00	0.4	0.75	9.40	On	1.00	Normal
16	1.5	5.83	10.30	0.0	0.00	6.00	0.5	0.80	9.40	On	1.00	Normal
17	1.5	5.44	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
18	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
20	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
21	1.5	5.42	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
22	1.5	5.41	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
23	1.5	5.29	8.80	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.41	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
01	1.5	5.39	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
02	1.5	5.40	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
03	1.5	5.39	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
04	1.5	5.39	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
05	1.5	5.38	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
06	1.5	5.49	10.30	0.0	0.00	6.00	0.4	0.76	9.40	On	1.00	Normal
07	1.5	5.41	10.30	0.0	0.00	6.00	0.4	0.80	9.40	On	1.00	Normal
08	1.5	5.39	10.30	0.0	0.00	6.00	0.4	0.84	9.40	On	1.00	Normal
09	1.5	5.41	10.30	0.0	0.00	6.00	0.4	0.88	9.40	On	1.00	Normal
10	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.88	9.40	On	1.00	Normal
11	1.5	5.41	10.30	0.0	0.00	6.00	0.4	0.92	9.40	On	1.00	Normal
12	1.5	5.42	10.30	0.0	0.00	6.00	0.4	0.83	9.40	On	1.00	Normal
13	1.5	5.40	10.30	0.0	0.00	6.00	0.4	0.87	9.40	On	1.00	Normal
14	1.5	5.44	10.30	0.0	0.00	6.00	0.4	0.87	9.40	On	1.00	Normal
15	1.3	5.13	10.30	0.0	0.00	6.00	0.4	0.81	9.40	On	1.00	Normal
16	1.5	5.28	10.30	0.0	0.00	6.00	0.3	0.73	9.40	On	1.00	Normal
17	1.5	5.40	10.30	0.0	0.00	6.00	0.3	0.77	9.40	On	1.00	Normal
18	1.5	5.40	10.30	0.0	0.00	6.00	0.3	0.77	9.40	On	1.00	Normal
19	1.5	5.41	10.30	0.0	0.00	6.00	0.3	0.77	9.40	On	1.00	Normal
20	1.5	5.39	10.19	0.0	0.00	6.00	0.4	0.77	9.40	On	1.00	Normal
21	1.5	5.27	8.10	0.0	0.00	6.00	0.3	0.73	9.40	Off	1.00	Normal
22	1.5	5.25	8.10	0.0	0.00	5.90	0.3	0.69	9.40	Off	1.00	Normal
23	1.5	5.26	8.10	0.0	0.00	3.90	0.3	0.69	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
May 31, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	0.37	8.10	0.0	0.00	3.90	0.3	0.69	9.40	Off	0.33	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.69	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.65	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.61	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.57	9.40	Off	0.10	Startup
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	1.00	Startup
06	1.5	3.58	8.10	NSD	NSD	3.90	0.2	0.49	9.40	Off	1.00	Startup
07	1.4	4.23	8.10	NSD	NSD	3.90	0.2	0.45	9.40	Off	1.00	Normal
08	1.5	0.22	8.10	0.0	0.00	3.90	0.2	0.41	9.40	Off	0.28	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.37	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.33	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.08	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	1.00	Startup
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	1.00	Startup
17	1.5	3.64	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	1.00	Startup
18	1.5	4.64	8.10	NSD	NSD	3.90	0.0	0.08	9.40	Off	1.00	Normal
19	1.5	5.19	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
20	1.5	5.18	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
21	1.5	0.26	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	0.32	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 May - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	109.8	9.7	15.8	40.0	4.6	1.9	24.0
02	105.3	9.3	14.3	38.3	0.0	1.7	24.0
03	112.2	9.7	15.9	40.0	16.0	2.6	24.0
04	121.5	10.0	21.8	41.1	22.4	2.6	24.0
05	121.5	0.9	14.7	3.6	20.5	0.2	3.0
06	119.3	9.8	0.0	40.6	8.4	3.6	24.0
07	121.8	10.0	0.0	41.4	7.6	3.8	24.0
08	128.3	10.5	0.8	43.4	34.4	3.8	24.0
09	119.9	9.8	1.1	40.7	7.7	3.4	24.0
10	118.0	9.7	4.3	40.3	7.5	3.3	24.0
11	117.7	9.8	6.2	40.2	29.3	2.9	23.3
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	185.7	3.5	26.1	14.4	24.3	0.7	9.7
22	Down	Down	Down	Down	Down	0.0	0.0
23	165.2	3.6	19.3	14.9	22.2	0.9	8.9
24	214.9	6.8	2.1	27.9	25.6	1.2	17.3
25	168.6	8.6	3.0	35.7	21.4	3.4	20.6
26	153.3	9.2	2.0	38.1	42.6	4.1	19.5
27	122.9	10.8	0.0	44.8	27.7	4.7	24.0
28	116.7	10.2	0.0	42.4	8.8	4.5	24.0
29	127.6	11.3	0.0	46.5	18.2	6.9	24.0
30	126.2	11.1	0.0	46.1	16.5	6.7	24.0
31	209.0	3.4	3.8	14.0	27.5	0.7	10.1
Total	2885	178	151	734	393.2	64	424
12-Mo Rlng	23822	1214	2490	5119	4347	552	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 May - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	19532.2	20352.4	24.00	93.2	97.1	0.65	20450	7975.4	24.00	730.6	24.00	1635	24.0
02	18751.7	19539.0	24.00	Down	Down	0.00	19539	7685.1	24.00	661.0	24.00	1544	24.0
03	19122.2	19925.3	24.00	490.1	510.6	3.70	20436	8114.5	24.00	769.4	24.00	1591	24.0
04	19443.7	20260.5	24.00	715.7	745.8	4.03	21006	8317.1	23.95	788.1	24.00	1631	24.0
05	1766.0	1840.3	3.01	Down	Down	0.00	1840	667.6	2.78	66.9	2.33	123	3.0
06	19414.7	20229.9	24.00	484.3	504.5	8.07	20734	8088.2	24.00	693.5	24.00	1629	24.0
07	19751.1	20580.4	24.00	538.7	561.1	8.96	21142	8240.3	24.00	696.9	24.00	1671	24.0
08	19800.6	20632.0	24.00	1484.6	1546.8	8.80	22179	9085.4	24.00	822.5	24.00	1676	24.0
09	19499.5	20318.4	24.00	453.9	473.0	7.30	20791	8287.9	24.00	674.9	24.00	1647	24.0
10	19332.4	20144.6	24.00	405.5	422.6	6.77	20567	8146.5	24.00	666.2	24.00	1626	24.0
11	18752.1	19539.3	23.30	979.8	1020.9	5.23	20560	8313.1	23.23	795.1	23.25	1567	23.3
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	7032.0	7327.3	9.70	Down	Down	0.00	7327	2689.2	9.31	268.9	8.71	561	9.7
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	7128.9	7428.3	8.85	187.7	195.5	1.03	7624	2952.5	8.55	258.1	7.42	595	8.9
24	13686.8	14261.6	17.31	Down	Down	0.00	14262	5522.4	17.12	464.7	17.03	1135	17.3
25	16772.6	17476.8	20.63	717.2	747.3	8.34	18224	7093.9	20.37	615.5	20.50	1409	20.6
26	16501.4	17194.4	19.50	2164.4	2255.2	11.34	19450	7946.8	19.30	700.0	19.29	1401	19.5
27	20292.3	21144.6	24.00	1678.3	1749.0	12.63	22894	9134.8	24.00	783.2	23.93	1729	24.0
28	19962.7	20800.9	24.00	837.1	872.3	11.71	21673	8407.5	24.00	674.2	24.00	1694	24.0
29	21087.7	21973.5	24.00	1734.4	1807.4	21.54	23781	9299.8	24.00	787.0	24.00	1832	24.0
30	21220.1	22111.3	24.00	1388.2	1446.7	20.95	23558	9074.6	24.00	761.7	24.00	1853	24.0
31	6879.8	7168.7	10.11	Down	Down	0.00	7169	2739.2	9.79	245.5	9.61	530	10.1
Average	16463.4	17154.7		897.1	934.7		17867	7037.2		615.4		1385	
Total	345730.5	360250	424.4	14353.1	14956	141.1	375206	147781.8	422.4	12923.9	420.1	29079	424

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 1, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.07	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	1.0	2.48	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.2	3.56	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
06	1.5	4.46	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
07	1.5	4.34	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
08	1.5	4.34	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
09	1.5	4.39	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
10	1.5	4.40	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
11	1.5	4.39	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
12	1.5	4.34	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
13	1.5	4.63	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
14	1.5	4.58	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
15	1.5	4.34	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
16	1.5	5.25	10.04	0.0	0.00	5.76	0.0	0.00	9.40	On	1.00	Normal
17	1.5	5.44	10.30	0.0	0.00	6.00	0.0	0.00	9.40	On	1.00	Normal
18	1.5	5.35	10.30	0.0	0.00	6.00	0.0	0.00	9.40	On	1.00	Normal
19	1.5	5.36	10.30	0.0	0.00	6.00	0.1	0.00	9.40	On	1.00	Normal
20	1.5	5.42	10.30	0.0	0.00	6.00	0.1	0.04	9.40	On	1.00	Normal
21	1.5	5.66	10.12	0.0	0.00	6.00	0.1	0.08	9.40	On	1.00	Normal
22	1.7	0.29	8.10	0.0	0.00	6.00	0.1	0.08	9.40	Off	0.33	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.83	0.1	0.08	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 2, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.13	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	1.00	Startup
04	1.5	3.48	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Startup
05	1.5	4.40	8.10	NSD	NSD	3.90	0.1	0.08	9.40	Off	1.00	Normal
06	1.5	4.35	8.10	0.0	0.00	3.90	0.1	0.08	9.40	Off	1.00	Normal
07	1.5	4.36	8.10	0.0	0.00	3.90	0.1	0.08	9.40	Off	1.00	Normal
08	1.5	4.35	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
09	1.3	3.80	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
10	1.5	4.55	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
11	1.5	4.24	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
12	1.5	4.68	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
13	1.5	5.25	8.10	0.0	0.00	3.90	0.1	0.12	9.40	Off	1.00	Normal
14	1.5	5.28	8.39	0.0	0.00	4.18	0.1	0.12	9.40	On	1.00	Normal
15	1.5	5.42	10.30	0.0	0.00	6.00	0.1	0.12	9.40	On	1.00	Normal
16	1.4	5.28	10.30	0.0	0.00	6.00	0.2	0.16	9.40	On	1.00	Normal
17	1.5	5.68	10.30	0.0	0.00	6.00	0.2	0.20	9.40	On	1.00	Normal
18	1.4	5.16	10.30	0.0	0.00	6.00	0.2	0.24	9.40	On	1.00	Normal
19	1.5	5.37	10.30	0.0	0.00	6.00	0.2	0.28	9.40	On	1.00	Normal
20	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.28	9.40	On	1.00	Normal
21	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.28	9.40	On	1.00	Normal
22	1.5	5.45	10.30	0.0	0.00	6.00	0.3	0.32	9.40	On	1.00	Normal
23	1.5	5.39	10.30	0.0	0.00	6.00	0.3	0.36	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 3, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.40	10.30	0.0	0.00	6.00	0.3	0.40	9.40	On	1.00	Normal
01	1.5	4.57	8.14	0.0	0.00	6.00	0.3	0.40	9.40	On	1.00	Normal
02	1.5	1.22	8.10	0.0	0.00	6.00	0.3	0.40	9.40	Off	0.52	Shutdown
03	N/A	N/A	8.10	NSD	NSD	3.94	0.3	0.40	9.40	Off	0.00	Down
04	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.40	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.40	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.40	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.40	9.40	Off	0.82	Startup
08	1.5	2.41	8.10	NSD	NSD	3.90	0.3	0.37	9.40	Off	1.00	Startup
09	1.4	4.35	8.83	NSD	NSD	4.60	0.3	0.37	9.40	On	1.00	Normal
10	1.5	5.44	10.30	0.0	0.00	6.00	0.3	0.37	9.40	On	1.00	Normal
11	1.5	5.43	10.30	0.0	0.00	6.00	0.3	0.37	9.40	On	1.00	Normal
12	1.5	5.43	10.30	0.0	0.00	6.00	0.3	0.37	9.40	On	1.00	Normal
13	1.5	5.41	10.30	0.0	0.00	6.00	0.3	0.41	9.40	On	1.00	Normal
14	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.45	9.40	On	1.00	Normal
15	1.5	5.44	10.30	0.0	0.00	6.00	0.4	0.49	9.40	On	1.00	Normal
16	1.4	5.98	10.30	0.0	0.00	6.00	0.4	0.60	9.40	On	1.00	Normal
17	1.5	7.00	10.30	0.0	0.00	6.00	0.6	0.82	9.40	On	1.00	Normal
18	1.5	6.99	10.30	0.0	0.00	6.00	0.7	1.04	9.40	On	1.00	Normal
19	1.4	5.35	10.30	0.0	0.00	6.00	0.7	1.04	9.40	On	1.00	Normal
20	1.5	5.46	10.30	0.0	0.00	6.00	0.7	1.04	9.40	On	1.00	Normal
21	1.5	5.33	10.30	0.0	0.00	6.00	0.7	1.05	9.40	On	1.00	Normal
22	1.5	5.45	10.30	0.0	0.00	6.00	0.7	1.05	9.40	On	1.00	Normal
23	1.5	5.41	10.30	0.0	0.00	6.00	0.7	1.05	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 4, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	<i>ppm @15% O2</i>	<i>lbs</i>	<i>ppm @15% O2</i>	<i>lbs</i>	<i>ppm @15% O2</i>	<i>lbs</i>
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.3	0.22	8.10	0.0	0.00	6.00	0.7	1.00	9.40	Off	0.32	Shutdown
01	N/A	N/A	8.10	NSD	NSD	6.00	0.7	1.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.00	9.40	Off	0.17	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.00	9.40	Off	1.00	Startup
04	1.5	3.06	8.10	NSD	NSD	3.90	0.7	1.00	9.40	Off	1.00	Startup
05	1.4	4.70	8.10	NSD	NSD	3.90	0.7	1.00	9.40	Off	1.00	Normal
06	1.5	4.39	8.10	0.0	0.00	3.90	0.7	1.00	9.40	Off	1.00	Normal
07	1.5	4.76	8.10	0.0	0.00	3.90	0.7	1.04	9.40	Off	1.00	Normal
08	1.5	4.49	8.10	0.0	0.00	3.90	0.7	1.04	9.40	Off	1.00	Normal
09	1.5	4.42	8.10	0.0	0.00	3.90	0.7	1.04	9.40	Off	1.00	Normal
10	1.4	5.07	10.15	0.0	0.00	5.86	0.7	1.08	9.40	On	1.00	Normal
11	1.5	5.41	10.30	0.0	0.00	6.00	0.7	1.08	9.40	On	1.00	Normal
12	1.5	5.40	10.30	0.0	0.00	6.00	0.7	1.12	9.40	On	1.00	Normal
13	1.5	5.42	10.30	0.0	0.00	6.00	0.7	1.12	9.40	On	1.00	Normal
14	1.5	5.45	10.30	0.0	0.00	6.00	0.7	1.12	9.40	On	1.00	Normal
15	1.5	5.54	10.30	0.0	0.00	6.00	0.7	1.12	9.40	On	1.00	Normal
16	1.5	5.47	10.30	0.0	0.00	6.00	0.6	1.02	9.40	On	1.00	Normal
17	1.5	5.48	10.30	0.0	0.00	6.00	0.5	0.80	9.40	On	1.00	Normal
18	1.5	5.44	10.30	0.0	0.00	6.00	0.4	0.57	9.40	On	1.00	Normal
19	1.5	5.39	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
20	1.5	5.39	10.30	0.0	0.00	6.00	0.4	0.57	9.40	On	1.00	Normal
21	1.5	5.38	10.30	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
22	1.5	4.62	8.65	0.0	0.00	6.00	0.3	0.57	9.40	On	1.00	Normal
23	1.4	4.43	8.10	0.0	0.00	6.00	0.3	0.56	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 5, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.52	8.10	0.0	0.00	4.43	0.3	0.56	9.40	Off	1.00	Normal
01	1.5	0.22	8.10	0.0	0.00	3.90	0.3	0.56	9.40	Off	0.47	Startup
02	1.5	2.13	8.10	0.0	0.00	3.90	0.3	0.56	9.40	Off	1.00	Startup
03	1.5	4.34	8.10	0.0	0.00	3.90	0.3	0.56	9.40	Off	1.00	Normal
04	1.5	4.32	8.10	0.0	0.00	3.90	0.4	0.56	9.40	Off	1.00	Normal
05	1.3	4.26	8.10	0.0	0.00	3.90	0.4	0.67	9.40	Off	1.00	Normal
06	1.3	3.86	8.10	0.0	0.00	3.90	0.4	0.67	9.40	Off	1.00	Normal
07	1.5	4.40	8.10	0.0	0.00	3.90	0.4	0.63	9.40	Off	1.00	Normal
08	1.4	4.54	8.10	0.0	0.00	3.90	0.4	0.63	9.40	Off	1.00	Normal
09	1.5	4.44	8.10	0.0	0.00	3.90	0.4	0.63	9.40	Off	1.00	Normal
10	1.5	4.45	8.10	0.0	0.00	3.90	0.4	0.59	9.40	Off	1.00	Normal
11	1.5	4.49	8.10	0.0	0.00	3.90	0.4	0.59	9.40	Off	1.00	Normal
12	1.5	4.51	8.10	0.0	0.00	3.90	0.4	0.55	9.40	Off	1.00	Normal
13	1.5	4.50	8.10	0.0	0.00	3.90	0.4	0.51	9.40	Off	1.00	Normal
14	1.5	4.47	8.10	0.0	0.00	3.90	0.3	0.47	9.40	Off	1.00	Normal
15	1.5	4.44	8.10	0.0	0.00	3.90	0.3	0.43	9.40	Off	1.00	Normal
16	1.5	4.40	8.10	0.0	0.00	3.90	0.3	0.39	9.40	Off	1.00	Normal
17	1.5	4.40	8.10	0.0	0.00	3.90	0.3	0.35	9.40	Off	1.00	Normal
18	1.5	4.39	8.10	0.0	0.00	3.90	0.3	0.30	9.40	Off	1.00	Normal
19	1.5	4.37	8.10	0.0	0.00	3.90	0.3	0.26	9.40	Off	1.00	Normal
20	1.5	4.36	8.10	0.0	0.00	3.90	0.2	0.22	9.40	Off	1.00	Normal
21	1.5	4.36	8.10	0.0	0.00	3.90	0.2	0.18	9.40	Off	1.00	Normal
22	1.5	4.37	8.10	0.0	0.00	3.90	0.2	0.15	9.40	Off	1.00	Normal
23	1.5	4.38	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 6, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.38	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal
01	1.5	4.39	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal
02	1.5	4.38	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal
03	1.5	4.39	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal
04	1.5	4.38	8.10	0.0	0.00	3.90	0.2	0.11	9.40	Off	1.00	Normal
05	1.5	4.44	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
06	1.5	4.40	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
07	1.5	4.41	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
08	1.5	4.42	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
09	1.5	4.43	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
10	1.5	4.43	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
11	1.5	4.43	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	1.00	Normal
12	1.5	2.44	8.10	0.0	0.00	3.90	0.1	0.00	9.40	Off	0.78	Shutdown
13	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 7, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 8, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.37	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.4	4.29	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
06	1.5	4.46	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
07	1.5	4.46	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
08	1.5	4.46	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
09	1.5	4.49	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
10	1.5	4.48	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
11	1.5	4.76	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
12	1.5	4.92	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
13	1.5	4.51	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
14	1.5	4.53	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
15	1.5	4.53	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
16	1.5	4.55	8.10	0.0	0.00	3.90	0.0	0.04	9.40	Off	1.00	Normal
17	1.5	4.85	8.39	0.0	0.00	4.18	0.0	0.04	9.40	On	1.00	Normal
18	1.6	6.46	10.30	0.0	0.00	6.00	0.2	0.22	9.40	On	1.00	Normal
19	1.4	6.23	10.30	0.0	0.00	6.00	0.4	0.52	9.40	On	1.00	Normal
20	1.5	6.39	10.30	0.0	0.00	6.00	0.5	0.77	9.40	On	1.00	Normal
21	1.5	5.17	8.87	0.0	0.00	6.00	0.5	0.77	9.40	On	1.00	Normal
22	1.5	4.47	8.10	0.0	0.00	6.00	0.5	0.77	9.40	Off	1.00	Normal
23	1.5	5.16	8.10	0.0	0.00	4.64	0.5	0.77	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 9, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlmg Avg)		NH3 (24 Hr Rlmg Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlmg	Normal Op CO lbs 3-Hr Rlmg	Normal Op CO lbs 3-Hr Rlmg Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlmg	Normal Ops NH3 lbs 24-Hr Rlmg	Normal Ops NH3 lbs 24-Hr Rlmg Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.22	8.10	0.0	0.00	3.90	0.5	0.77	9.40	Off	1.00	Normal
01	1.5	5.21	8.10	0.0	0.00	3.90	0.5	0.77	9.40	Off	1.00	Normal
02	1.5	5.21	8.10	0.0	0.00	3.90	0.5	0.77	9.40	Off	1.00	Normal
03	1.5	5.14	8.10	0.0	0.06	3.90	0.6	0.77	9.40	Off	1.00	Normal
04	1.5	5.10	8.10	0.1	0.13	3.90	0.6	0.77	9.40	Off	1.00	Normal
05	1.5	5.11	8.10	0.1	0.16	3.90	0.6	0.77	9.40	Off	1.00	Normal
06	1.5	4.34	8.10	0.0	0.09	3.90	0.6	0.77	9.40	Off	1.00	Normal
07	1.5	4.33	8.10	0.0	0.03	3.90	0.6	0.77	9.40	Off	1.00	Normal
08	1.5	4.34	8.10	0.0	0.00	3.90	0.6	0.77	9.40	Off	1.00	Normal
09	1.5	4.34	8.10	0.0	0.00	3.90	0.6	0.77	9.40	Off	1.00	Normal
10	1.5	4.35	8.10	0.0	0.00	3.90	0.6	0.77	9.40	Off	1.00	Normal
11	1.5	4.37	8.10	0.0	0.00	3.90	0.6	0.73	9.40	Off	1.00	Normal
12	1.5	4.84	8.10	0.0	0.00	3.90	0.6	0.77	9.40	Off	1.00	Normal
13	1.5	4.74	8.10	0.0	0.00	3.90	0.6	0.80	9.40	Off	1.00	Normal
14	1.5	4.43	8.10	0.0	0.00	3.90	0.6	0.80	9.40	Off	1.00	Normal
15	1.5	5.18	9.38	0.0	0.00	5.13	0.6	0.84	9.40	On	1.00	Normal
16	1.5	5.52	10.30	0.0	0.00	6.00	0.7	0.88	9.40	On	1.00	Normal
17	1.4	5.39	10.30	0.0	0.00	6.00	0.7	0.93	9.40	On	1.00	Normal
18	1.5	5.78	10.30	0.0	0.00	6.00	0.6	0.79	9.40	On	1.00	Normal
19	1.5	5.72	10.30	0.0	0.00	6.00	0.4	0.53	9.40	On	1.00	Normal
20	1.4	5.42	10.30	0.0	0.00	6.00	0.3	0.33	9.40	On	1.00	Normal
21	1.5	5.36	10.30	0.0	0.00	6.00	0.3	0.37	9.40	On	1.00	Normal
22	1.5	2.75	8.72	0.0	0.00	6.00	0.3	0.37	9.40	On	0.82	Shutdown
23	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.37	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 10, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	4.50	0.3	0.37	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.37	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.37	9.40	Off	0.15	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.37	9.40	Off	1.00	Startup
04	1.4	3.16	8.10	NSD	NSD	3.90	0.3	0.37	9.40	Off	1.00	Startup
05	1.5	4.26	8.10	NSD	NSD	3.90	0.3	0.37	9.40	Off	1.00	Normal
06	1.5	4.34	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
07	1.5	5.13	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
08	1.5	5.25	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
09	1.5	4.84	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
10	1.5	4.25	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
11	1.5	4.30	8.10	0.0	0.00	3.90	0.3	0.37	9.40	Off	1.00	Normal
12	1.5	5.36	9.97	0.0	0.00	5.69	0.2	0.37	9.40	On	1.00	Normal
13	1.4	5.30	10.30	0.0	0.00	6.00	0.3	0.38	9.40	On	1.00	Normal
14	1.5	5.45	10.30	0.0	0.00	6.00	0.3	0.42	9.40	On	1.00	Normal
15	1.5	5.44	10.30	0.0	0.00	6.00	0.3	0.42	9.40	On	1.00	Normal
16	1.6	6.02	10.30	0.0	0.00	6.00	0.3	0.42	9.40	On	1.00	Normal
17	1.5	7.16	10.30	0.0	0.00	6.00	0.4	0.70	9.40	On	1.00	Normal
18	1.5	7.15	10.30	0.0	0.00	6.00	0.6	0.98	9.40	On	1.00	Normal
19	1.4	5.27	10.30	0.0	0.00	6.00	0.6	0.98	9.40	On	1.00	Normal
20	1.5	5.38	10.30	0.0	0.00	6.00	0.6	0.98	9.40	On	1.00	Normal
21	1.5	5.37	10.30	0.0	0.00	6.00	0.6	0.98	9.40	On	1.00	Normal
22	1.5	5.38	10.30	0.0	0.00	6.00	0.6	1.02	9.40	On	1.00	Normal
23	1.5	5.31	9.79	0.0	0.00	6.00	0.6	1.06	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 11, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.6	0.40	8.10	0.0	0.00	6.00	0.6	1.06	9.40	Off	0.33	Shutdown
01	N/A	N/A	8.10	NSD	NSD	5.51	0.6	1.06	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.6	1.06	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	0.05	Startup
07	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	1.00	Startup
08	1.3	0.12	8.10	NSD	NSD	3.90	0.6	1.06	9.40	Off	1.00	Startup
09	1.5	4.39	8.10	NSD	NSD	3.90	0.6	1.06	9.40	Off	1.00	Normal
10	1.5	4.78	8.61	0.0	0.00	4.39	0.6	1.06	9.40	On	1.00	Normal
11	1.5	5.42	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
12	1.5	5.43	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
13	1.5	5.57	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
14	1.5	5.41	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
15	1.5	5.41	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
16	1.5	5.39	10.30	0.0	0.00	6.00	0.6	1.10	9.40	On	1.00	Normal
17	1.5	5.55	10.30	0.0	0.00	6.00	0.5	0.86	9.40	On	1.00	Normal
18	1.2	5.63	10.30	0.0	0.00	6.00	0.5	0.79	9.40	On	1.00	Normal
19	1.5	5.55	10.30	0.0	0.00	6.00	0.5	0.79	9.40	On	1.00	Normal
20	1.5	5.56	10.30	0.0	0.00	6.00	0.5	0.79	9.40	On	1.00	Normal
21	1.5	5.40	10.26	0.0	0.00	6.00	0.4	0.79	9.40	On	1.00	Normal
22	1.5	4.06	8.10	0.0	0.00	6.00	0.4	0.75	9.40	Off	1.00	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.97	0.4	0.71	9.40	Off	0.05	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 12, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.71	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.71	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.67	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.63	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.59	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.55	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.38	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.13	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 13, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 14, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 15, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 16, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 17, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.77	Startup
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
19	1.5	4.44	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
20	1.5	5.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
21	1.5	1.76	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 18, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.02	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	1.5	3.07	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.5	4.53	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
06	1.5	0.22	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	0.28	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.18	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
14	1.4	3.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.4	4.41	8.28	NSD	NSD	4.08	0.1	0.04	9.40	On	1.00	Normal
16	1.3	5.45	10.30	0.0	0.00	6.00	0.1	0.13	9.40	On	1.00	Normal
17	1.5	5.65	10.30	0.0	0.00	6.00	0.1	0.17	9.40	On	1.00	Normal
18	1.5	5.42	10.30	0.0	0.00	6.00	0.2	0.17	9.40	On	1.00	Normal
19	1.5	5.38	10.30	0.0	0.00	6.00	0.2	0.21	9.40	On	1.00	Normal
20	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.25	9.40	On	1.00	Normal
21	1.5	1.69	8.58	0.0	0.00	6.00	0.2	0.25	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.25	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.36	0.2	0.25	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 19, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.22	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 20, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 21, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.88	Startup
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
11	1.5	0.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
12	1.5	4.58	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
13	1.5	4.55	8.10	0.0	0.00	3.90	0.0	0.00	9.40	Off	1.00	Normal
14	1.5	4.62	8.25	0.0	0.00	4.04	0.0	0.00	9.40	On	1.00	Normal
15	1.5	5.28	10.30	0.0	0.00	6.00	0.0	0.04	9.40	On	1.00	Normal
16	1.5	5.46	10.30	0.0	0.00	6.00	0.1	0.08	9.40	On	1.00	Normal
17	1.5	5.46	10.30	0.0	0.00	6.00	0.1	0.12	9.40	On	1.00	Normal
18	1.5	5.46	10.30	0.0	0.00	6.00	0.1	0.16	9.40	On	1.00	Normal
19	1.5	5.31	10.30	0.0	0.00	6.00	0.1	0.20	9.40	On	1.00	Normal
20	1.5	5.31	10.30	0.0	0.00	6.00	0.2	0.24	9.40	On	1.00	Normal
21	1.5	5.35	10.30	0.0	0.00	6.00	0.2	0.24	9.40	On	1.00	Normal
22	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.24	9.40	On	1.00	Normal
23	1.5	5.32	10.26	0.0	0.00	6.00	0.2	0.29	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 22, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.3	0.23	8.10	0.0	0.00	6.00	0.2	0.29	9.40	Off	0.32	Shutdown
01	N/A	N/A	8.10	NSD	NSD	5.97	0.2	0.29	9.40	Off	0.00	Down
02	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.17	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	1.00	Startup
05	1.4	4.10	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Startup
06	1.5	4.37	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Normal
07	1.5	4.37	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Normal
08	1.5	4.39	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Normal
09	1.5	4.39	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Normal
10	1.5	4.41	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Normal
11	1.5	4.45	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Normal
12	1.5	0.31	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	0.67	Startup
13	1.0	0.31	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	1.00	Startup
14	1.3	4.66	9.27	0.0	0.00	5.02	0.2	0.32	9.40	On	1.00	Normal
15	1.5	5.48	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
16	1.5	5.49	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
17	1.5	5.46	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
18	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
19	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
20	1.5	5.36	10.30	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
21	1.5	5.30	8.80	0.0	0.00	6.00	0.2	0.33	9.40	On	1.00	Normal
22	1.5	4.40	8.10	0.0	0.00	6.00	0.2	0.33	9.40	Off	1.00	Normal
23	1.5	0.32	8.10	0.0	0.00	4.57	0.2	0.29	9.40	Off	0.30	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 23, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.12	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	1.00	Startup
04	1.5	2.04	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Startup
05	1.5	4.32	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	1.00	Normal
06	1.6	0.32	8.10	0.0	0.00	3.90	0.2	0.29	9.40	Off	0.28	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.29	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	0.22	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.29	9.40	Off	1.00	Startup
14	1.4	3.01	8.17	NSD	NSD	3.97	0.1	0.25	9.40	On	1.00	Startup
15	1.4	5.65	9.93	NSD	NSD	5.65	0.2	0.34	9.40	On	1.00	Normal
16	1.5	5.47	10.08	0.0	0.00	5.79	0.2	0.34	9.40	On	1.00	Normal
17	1.5	5.38	8.94	0.0	0.00	5.79	0.2	0.30	9.40	On	1.00	Normal
18	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.26	9.40	On	1.00	Normal
19	1.5	5.38	10.30	0.0	0.00	6.00	0.2	0.26	9.40	On	1.00	Normal
20	1.5	5.41	10.30	0.0	0.00	6.00	0.2	0.22	9.40	On	1.00	Normal
21	1.5	1.71	8.54	0.0	0.00	6.00	0.2	0.22	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.22	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.32	0.2	0.22	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 24, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	0.20	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	1.00	Startup
04	1.5	2.98	8.10	NSD	NSD	3.90	0.2	0.22	9.40	Off	1.00	Startup
05	1.5	4.45	8.10	NSD	NSD	3.90	0.2	0.22	9.40	Off	1.00	Normal
06	1.5	0.29	8.10	0.0	0.00	3.90	0.2	0.22	9.40	Off	0.28	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.22	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.22	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	0.12	Startup
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.22	9.40	Off	1.00	Startup
12	1.4	3.35	8.10	NSD	NSD	3.90	0.2	0.22	9.40	Off	1.00	Startup
13	1.5	5.26	10.12	NSD	NSD	5.83	0.2	0.26	9.40	On	1.00	Normal
14	1.5	5.43	10.30	0.0	0.00	6.00	0.2	0.30	9.40	On	1.00	Normal
15	1.5	5.46	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
16	1.5	5.48	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
17	1.5	5.48	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
18	1.5	5.43	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
19	1.5	5.39	10.30	0.0	0.00	6.00	0.1	0.21	9.40	On	1.00	Normal
20	1.5	5.39	10.30	0.0	0.00	6.00	0.1	0.25	9.40	On	1.00	Normal
21	1.5	1.62	8.61	0.0	0.00	6.00	0.1	0.25	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.1	0.25	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.39	0.1	0.25	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 25, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.17	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	1.00	Startup
04	1.4	2.87	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	1.00	Startup
05	1.5	4.36	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	1.00	Normal
06	1.5	0.31	8.10	0.0	0.00	3.90	0.1	0.25	9.40	Off	0.30	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	0.23	Startup
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.25	9.40	Off	1.00	Startup
13	1.4	4.17	8.10	NSD	NSD	3.90	0.1	0.21	9.40	Off	1.00	Startup
14	1.3	4.07	8.83	NSD	NSD	4.60	0.1	0.20	9.40	On	1.00	Normal
15	1.3	4.84	10.30	0.0	0.00	6.00	0.1	0.20	9.40	On	1.00	Normal
16	1.5	5.49	10.30	0.0	0.00	6.00	0.1	0.20	9.40	On	1.00	Normal
17	1.5	5.50	10.30	0.0	0.00	6.00	0.1	0.24	9.40	On	1.00	Normal
18	1.5	5.51	10.30	0.0	0.00	6.00	0.1	0.28	9.40	On	1.00	Normal
19	1.5	5.52	10.30	0.0	0.00	6.00	0.2	0.28	9.40	On	1.00	Normal
20	1.5	5.36	10.30	0.0	0.00	6.00	0.1	0.28	9.40	On	1.00	Normal
21	1.5	1.67	8.65	0.0	0.00	6.00	0.1	0.28	9.40	On	0.58	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.1	0.28	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.43	0.1	0.28	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 26, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.20	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	1.00	Startup
04	1.3	2.52	8.10	NSD	NSD	3.90	0.1	0.28	9.40	Off	1.00	Startup
05	1.5	4.33	8.10	NSD	NSD	3.90	0.1	0.28	9.40	Off	1.00	Normal
06	1.5	0.31	8.10	0.0	0.00	3.90	0.1	0.28	9.40	Off	0.28	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.28	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.28	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	0.13	Startup
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.28	9.40	Off	1.00	Startup
14	1.5	2.85	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	1.00	Startup
15	1.4	5.17	9.53	NSD	NSD	5.27	0.2	0.29	9.40	On	1.00	Normal
16	1.5	5.70	10.30	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal
17	1.5	5.47	10.30	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal
18	1.5	5.47	10.30	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal
19	1.5	5.56	10.30	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal
20	1.5	5.40	10.30	0.0	0.00	6.00	0.2	0.38	9.40	On	1.00	Normal
21	1.5	5.42	10.30	0.0	0.00	6.00	0.3	0.42	9.40	On	1.00	Normal
22	1.5	5.36	10.26	0.0	0.00	6.00	0.3	0.46	9.40	On	1.00	Normal
23	1.3	0.33	8.10	0.0	0.00	6.00	0.3	0.46	9.40	Off	0.33	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 27, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	5.97	0.3	0.46	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.46	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.37	Startup
15	1.3	0.66	8.10	NSD	NSD	3.90	0.2	0.38	9.40	Off	1.00	Startup
16	1.5	4.74	8.10	NSD	NSD	3.90	0.1	0.25	9.40	Off	1.00	Normal
17	1.5	5.42	10.23	0.0	0.00	5.93	0.2	0.33	9.40	On	1.00	Normal
18	1.5	5.52	10.30	0.0	0.00	6.00	0.3	0.41	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.0	0.00	6.00	0.4	0.49	9.40	On	1.00	Normal
20	1.5	5.32	10.30	0.0	0.00	6.00	0.4	0.53	9.40	On	1.00	Normal
21	1.5	4.86	9.42	0.0	0.00	6.00	0.4	0.53	9.40	On	1.00	Normal
22	1.5	4.66	8.10	0.0	0.00	6.00	0.4	0.49	9.40	Off	1.00	Normal
23	1.5	0.23	8.10	0.0	0.00	5.16	0.4	0.49	9.40	Off	0.30	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 28, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.49	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.49	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.49	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.37	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 June 29, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
June 30, 2020

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Rlng Avg)		NH3 (24 Hr Rlng Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng	Normal Op CO lbs 3-Hr Rlng Limit**	Normal Op NH3 ppm @15% O2 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng	Normal Ops NH3 lbs 24-Hr Rlng Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 June - 2020

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	152.4	7.8	1.2	32.6	15.4	2.8	19.4
02	172.5	8.9	0.2	37.2	21.9	3.7	21.1
03	154.6	8.9	3.3	37.3	32.9	5.1	19.3
04	180.0	9.3	1.7	38.9	25.8	4.4	21.5
05	107.9	9.0	2.8	37.6	2.7	1.6	23.5
06	56.9	4.8	4.0	20.3	0.0	0.9	12.8
07	Down	Down	Down	Down	Down	0.0	0.0
08	238.7	8.7	26.2	36.4	41.2	2.3	21.4
09	114.9	9.8	2.4	41.3	9.5	3.3	22.8
10	160.2	9.4	0.2	39.5	32.6	4.3	21.2
11	178.8	7.1	2.4	29.8	36.7	3.8	16.4
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	189.3	1.7	21.1	7.1	23.0	0.4	5.4
18	196.4	4.7	2.7	20.0	32.7	2.1	12.1
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	218.7	5.9	25.2	25.1	24.6	3.2	14.9
22	190.7	7.7	6.7	32.3	24.9	3.0	19.5
23	170.1	4.9	5.1	20.4	23.8	2.2	12.2
24	171.0	5.8	3.9	24.2	21.6	3.0	14.2
25	167.6	5.2	3.5	21.9	25.0	2.5	13.3
26	171.5	5.7	3.3	23.8	29.3	2.8	13.9
27	122.1	3.6	4.4	15.0	24.6	1.7	8.7
28	Down	Down	Down	Down	Down	0.0	0.0
29	Down	Down	Down	Down	Down	0.0	0.0
30	Down	Down	Down	Down	Down	0.0	0.0
Total	3114	129	120	541	448.2	53	314
12-Mo Ring	24185	1238	2388	5241	4027	559	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 June - 2020

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	15408.5	15932.4	19.40	352.5	364.4	5.80	16297	6280.9	19.28	530.3	18.95	1280	19.4
02	17272.7	17859.9	21.13	738.8	763.9	9.13	18624	7266.6	21.08	619.1	21.00	1452	21.1
03	16336.3	16891.6	19.34	1730.7	1789.6	15.35	18681	7546.5	19.13	689.6	19.11	1396	19.3
04	17990.8	18602.5	21.49	818.2	845.9	12.18	19448	7618.1	21.44	631.5	21.23	1531	21.5
05	18205.8	18824.6	23.47	Down	Down	0.00	18825	7198.5	23.30	608.6	23.23	1513	23.5
06	9804.9	10138.2	12.78	Down	Down	0.00	10138	3877.1	12.67	336.6	12.78	811	12.8
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	16989.5	17567.4	21.37	604.4	624.9	3.48	18192	7101.6	21.03	694.0	20.57	1409	21.4
09	19458.2	20119.6	22.82	528.7	546.6	6.86	20666	8057.2	22.77	720.1	22.61	1666	22.8
10	17644.7	18244.3	21.15	1445.3	1494.5	11.62	19739	7870.0	21.08	713.2	21.15	1492	21.2
11	13420.7	13877.0	16.43	994.3	1027.9	11.21	14905	5883.3	16.17	562.8	16.18	1128	16.4
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	3424.4	3540.7	5.35	Down	Down	0.00	3541	1319.6	4.92	123.3	4.50	257	5.4
18	9238.4	9552.6	12.06	431.2	445.6	5.30	9998	3847.2	11.68	360.5	11.42	754	12.1
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	11521.8	11913.7	14.88	628.2	649.7	9.05	12563	5046.8	14.58	416.3	14.15	955	14.9
22	15081.5	15594.2	19.46	505.9	523.0	6.85	16117	6318.0	19.09	542.6	19.15	1244	19.5
23	9406.3	9726.1	12.20	442.3	457.3	5.34	10183	3995.4	11.96	329.9	11.62	769	12.2
24	11192.4	11573.1	14.18	531.0	549.0	8.15	12122	4700.4	13.79	395.3	13.74	927	14.2
25	10210.6	10557.8	13.28	409.5	423.4	6.58	10981	4243.7	12.89	368.9	12.79	837	13.3
26	10793.7	11160.7	13.94	710.2	734.6	7.63	11895	4695.5	13.57	398.5	13.30	889	13.9
27	6619.9	6845.1	8.67	638.0	659.5	4.57	7505	3127.7	8.31	274.1	8.10	549	8.7
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average	13159.0	13606.4		719.3	743.7		14233	5578.6		490.3		1098	
Total	250021.1	258522	313.4	11509.2	11900	129.1	270420	105994.1	308.7	9315.2	305.6	20859	314

ATTACHMENT 6
FUEL SULFUR ROLLING AVG.

FUEL SULFUR - Tracy Combined Cycle Power Plant

Daily Average Limit = 0.66 gr/100scf

12-Month Rolling Average Limit = 0.25 gr/100scf

Units = gr/100 scf

Samplet No.	1	2	3	Daily Average
Jul-19	0.08	0.10	0.08	0.09
Aug-19	0.17	0.16	0.17	0.17
Sep-19	0.13	0.16	0.16	0.15
Oct-19	0.21	0.21	0.20	0.21
Nov-19	0.11	0.12	0.13	0.12
Dec-19	0.13	0.17	0.18	0.16
Jan-20	0.19	0.20	0.15	0.18
Feb-20	0.15	0.16	0.17	0.16
Mar-20	0.20	0.20	0.20	0.20
Apr-20	0.12	0.14	0.16	0.14
May-20	NA	0.19	0.19	0.13
Jun-20	0.20	0.23	0.22	0.22

12 Month Rolling Average = **0.16**

Note: Three samples are collected once per month to increase the chances that at least one of the samples will reach the lab in good condition. When more than one samples are analyzed, the results are averaged for reporting the daily results. Results of the average of the daily are averaged over a 12-month period to obtain the 12-month rolling average.

ATTACHMENT 7
STARTUP/SHUTDOWN SUMMARIES

Events

Tracy Combined Cycle Power Plant for 4/1/2020 thru 6/30/2020

Limits

Turbine 1: NOx lbs/Startup Event	390.5	Turbine 1: PM lbs/Shutdown Event	3.0	Turbine 2: CO lbs/Startup Event	562.5
Turbine 1: NOx lbs/Shutdown Event	104.0	Turbine 1: VOC lbs/Startup Event	10.5	Turbine 2: CO lbs/Shutdown Event	148.0
Turbine 1: SOx lbs/Startup Event	4.1	Turbine 1: VOC lbs/Shutdown Event	2.6	Turbine 2: PM lbs/Startup Event	11.0
Turbine 1: SOx lbs/Shutdown Event	1.1	Turbine 2: NOx lbs/Startup Event	390.5	Turbine 2: PM lbs/Shutdown Event	3.0
Turbine 1: CO lbs/Startup Event	562.5	Turbine 2: NOx lbs/Shutdown Event	104.0	Turbine 2: VOC lbs/Startup Event	10.5
Turbine 1: CO lbs/Shutdown Event	148.0	Turbine 2: SOx lbs/Startup Event	4.1	Turbine 2: VOC lbs/Shutdown Event	2.6
Turbine 1: PM lbs/Startup Event	11.0	Turbine 2: SOx lbs/Shutdown Event	1.1		

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 2 Startup Event	4/2/2020 3:08 PM	5:56 PM	2:49	161.90	0.10	16.40	2.20	0.00
Turbine 2 Shutdown Event	4/2/2020 8:02 PM	8:15 PM	0:14	1.10	0.00	2.00	0.20	0.00
Turbine 2 Startup Event	4/4/2020 4:55 PM	7:11 PM	2:17	117.00	0.20	17.10	2.80	0.00
Turbine 2 Shutdown Event	4/4/2020 10:32 PM	10:46 PM	0:15	1.10	0.10	1.40	0.20	0.00
Turbine 2 Startup Event	4/7/2020 1:36 PM	4:09 PM	2:34	137.30	0.30	21.30	2.50	0.00
Turbine 2 Shutdown Event	4/7/2020 9:28 PM	9:43 PM	0:16	0.60	0.10	1.00	0.30	0.00
Turbine 1 Startup Event	4/8/2020 2:06 PM	3:51 PM	1:46	98.70	0.20	18.40	1.00	0.00
Turbine 1 Shutdown Event	4/8/2020 9:39 PM	9:55 PM	0:17	0.80	0.10	0.70	0.10	0.00
Turbine 2 Startup Event	4/10/2020 5:18 PM	7:53 PM	2:36	148.90	0.10	18.90	2.20	0.00
Turbine 2 Shutdown Event	4/10/2020 10:02 PM	10:15 PM	0:14	1.00	0.00	1.30	0.20	0.00
Turbine 2 Startup Event	4/15/2020 7:06 PM	9:46 PM	2:41	145.60	0.20	15.40	2.20	0.00
Turbine 2 Shutdown Event	4/16/2020 12:02 AM	12:14 AM	0:13	1.00	0.00	1.50	0.20	0.00
Turbine 2 Startup Event	4/27/2020 11:19 AM	2:02 PM	2:44	183.80	0.10	15.60	2.50	0.00
Turbine 2 Shutdown Event	4/27/2020 9:18 PM	9:30 PM	0:13	0.80	0.00	1.90	0.20	0.00
Turbine 2 Startup Event	4/27/2020 9:55 PM	11:11 PM	1:17	34.70	0.30	0.90	1.70	0.00
		5/5/2020						
Turbine 2 Shutdown Event	5/4/2020 11:47 PM	12:01 AM	0:15	1.30	0.00	2.50	0.20	0.00
Turbine 2 Startup Event	5/5/2020 9:01 PM	10:54 PM	1:54	115.50	0.10	12.10	2.30	0.00
Turbine 2 Shutdown Event	5/11/2020 11:02 PM	11:17 PM	0:16	1.40	0.10	2.50	0.30	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 2 Startup Event	5/21/2020 9:57 AM	12:39 PM	2:43	159.60	0.10	19.30	2.30	0.00
Turbine 2 Shutdown Event	5/21/2020 7:25 PM	7:37 PM	0:13	1.20	0.00	1.80	0.20	0.00
Turbine 1 Startup Event	5/22/2020 9:51 AM	11:26 AM	1:36	30.50	0.30	19.80	1.00	0.00
Turbine 1 Shutdown Event	5/22/2020 6:34 PM	6:47 PM	0:14	1.00	0.00	1.20	0.10	0.00
Turbine 2 Startup Event	5/23/2020 3:09 PM	4:57 PM	1:49	127.30	0.10	14.80	2.20	0.00
Turbine 2 Shutdown Event	5/24/2020 6:03 AM	6:16 AM	0:14	1.20	0.00	1.20	0.20	0.00
Turbine 2 Startup Event	5/24/2020 12:58 PM	3:13 PM	2:16	144.40	0.20	0.30	2.80	0.00
Turbine 2 Shutdown Event	5/25/2020 8:03 AM	8:16 AM	0:14	1.30	0.00	1.80	0.20	0.00
Turbine 2 Startup Event	5/25/2020 11:39 AM	1:12 PM	1:34	72.70	0.20	0.30	2.00	0.00
Turbine 1 Startup Event	5/25/2020 11:40 AM	1:12 PM	1:33	90.00	0.20	13.70	0.90	0.00
Turbine 1 Shutdown Event	5/26/2020 1:03 AM	1:16 AM	0:14	1.30	0.00	0.70	0.10	0.00
Turbine 2 Shutdown Event	5/26/2020 1:03 AM	1:16 AM	0:14	1.50	0.00	1.10	0.20	0.00
Turbine 2 Startup Event	5/26/2020 5:47 AM	6:45 AM	0:59	40.20	0.20	0.20	1.20	0.00
Turbine 1 Startup Event	5/26/2020 8:51 AM	9:35 AM	0:45	22.60	0.10	0.50	0.40	0.00
Turbine 1 Shutdown Event	5/31/2020 12:04 AM	12:20 AM	0:17	1.50	0.10	0.90	0.10	0.00
Turbine 2 Shutdown Event	5/31/2020 12:04 AM	12:19 AM	0:16	1.60	0.10	0.70	0.30	0.00
Turbine 2 Startup Event	5/31/2020 4:54 AM	6:10 AM	1:17	56.20	0.20	0.20	1.60	0.00
Turbine 2 Shutdown Event	5/31/2020 8:03 AM	8:16 AM	0:14	1.40	0.00	0.60	0.20	0.00
Turbine 2 Startup Event	5/31/2020 2:55 PM	5:08 PM	2:14	119.20	0.20	0.30	2.70	0.00
Turbine 2 Shutdown Event	5/31/2020 9:03 PM	9:18 PM	0:16	1.50	0.10	0.70	0.30	0.00
Turbine 2 Startup Event	6/1/2020 2:56 AM	4:08 AM	1:13	61.00	0.20	0.30	1.50	0.00
Turbine 1 Startup Event	6/1/2020 1:42 PM	3:11 PM	1:30	79.40	0.20	16.70	0.80	0.00
Turbine 1 Shutdown Event	6/1/2020 10:03 PM	10:19 PM	0:17	1.50	0.10	0.70	0.10	0.00
Turbine 2 Shutdown Event	6/1/2020 10:03 PM	10:19 PM	0:17	1.70	0.10	0.60	0.30	0.00
Turbine 2 Startup Event	6/2/2020 2:52 AM	4:11 AM	1:20	72.10	0.20	0.30	1.70	0.00
Turbine 1 Startup Event	6/2/2020 10:35 AM	12:13 PM	1:39	77.30	0.20	0.90	0.90	0.00
Turbine 2 Shutdown Event	6/3/2020 2:17 AM	2:30 AM	0:14	1.40	0.00	1.80	0.20	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 2 Startup Event	6/3/2020 7:11 AM	8:26 AM	1:16	51.10	0.20	0.20	1.50	0.00
Turbine 1 Shutdown Event	6/4/2020 12:03 AM	12:19 AM	0:17	1.50	0.10	0.90	0.10	0.00
Turbine 2 Shutdown Event	6/4/2020 12:03 AM	12:18 AM	0:16	1.70	0.10	0.80	0.30	0.00
Turbine 2 Startup Event	6/4/2020 2:50 AM	4:23 AM	1:34	74.90	0.30	0.20	2.10	0.00
Turbine 1 Startup Event	6/4/2020 7:41 AM	8:58 AM	1:18	53.80	0.20	0.80	0.70	0.00
Turbine 1 Shutdown Event	6/4/2020 11:19 PM	11:32 PM	0:14	1.30	0.00	0.90	0.10	0.00
Turbine 2 Shutdown Event	6/5/2020 1:03 AM	1:16 AM	0:14	1.20	0.00	1.70	0.20	0.00
Turbine 2 Startup Event	6/5/2020 1:49 AM	2:30 AM	0:42	7.20	0.30	0.20	1.00	0.00
Turbine 2 Shutdown Event	6/6/2020 12:33 PM	12:46 PM	0:14	1.10	0.00	2.20	0.20	0.00
Turbine 2 Startup Event	6/8/2020 2:38 AM	5:01 AM	2:24	140.30	0.20	20.60	2.90	0.00
Turbine 1 Startup Event	6/9/2020 12:52 PM	2:16 PM	1:25	96.90	0.10	11.80	0.80	0.00
Turbine 1 Shutdown Event	6/9/2020 10:32 PM	10:48 PM	0:17	1.60	0.10	0.80	0.10	0.00
Turbine 2 Shutdown Event	6/9/2020 10:32 PM	10:48 PM	0:17	1.70	0.10	0.90	0.30	0.00
Turbine 2 Startup Event	6/10/2020 2:51 AM	4:13 AM	1:23	54.20	0.20	0.20	1.70	0.00
Turbine 1 Startup Event	6/10/2020 9:15 AM	11:10 AM	1:56	52.10	0.10	1.10	1.10	0.00
Turbine 1 Shutdown Event	6/11/2020 12:04 AM	12:20 AM	0:17	1.50	0.10	0.70	0.10	0.00
Turbine 2 Shutdown Event	6/11/2020 12:04 AM	12:19 AM	0:16	1.60	0.10	0.70	0.30	0.00
Turbine 1 Startup Event	6/11/2020 6:56 AM	9:03 AM	2:08	96.70	0.20	0.90	1.20	0.00
Turbine 2 Startup Event	6/11/2020 6:57 AM	8:57 AM	2:01	97.40	0.10	0.20	2.40	0.00
Turbine 1 Shutdown Event	6/11/2020 10:48 PM	11:03 PM	0:16	1.60	0.00	0.80	0.10	0.00
Turbine 2 Shutdown Event	6/11/2020 10:48 PM	11:02 PM	0:15	1.40	0.10	0.50	0.20	0.00
Turbine 2 Startup Event	6/17/2020 4:14 PM	7:07 PM	2:54	173.70	0.20	13.90	2.60	0.00
Turbine 2 Shutdown Event	6/17/2020 9:19 PM	9:34 PM	0:16	1.10	0.10	1.60	0.30	0.00
Turbine 2 Startup Event	6/18/2020 2:59 AM	4:17 AM	1:19	69.20	0.30	0.30	1.70	0.00
Turbine 2 Shutdown Event	6/18/2020 6:03 AM	6:16 AM	0:14	1.30	0.00	0.70	0.20	0.00
Turbine 2 Startup Event	6/18/2020 12:49 PM	2:11 PM	1:23	74.10	0.20	0.20	1.70	0.00
Turbine 1 Startup Event	6/18/2020 12:50 PM	2:11 PM	1:22	71.10	0.20	10.20	0.80	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 1 Shutdown Event	6/18/2020 9:19 PM	9:35 PM	0:17	1.50	0.10	0.70	0.10	0.00
Turbine 2 Shutdown Event	6/18/2020 9:19 PM	9:34 PM	0:16	1.70	0.10	0.50	0.30	0.00
Turbine 2 Startup Event	6/21/2020 9:07 AM	11:56 AM	2:50	153.50	0.10	19.00	2.40	0.00
Turbine 2 Shutdown Event	6/22/2020 12:03 AM	12:18 AM	0:16	1.50	0.10	0.60	0.30	0.00
Turbine 2 Startup Event	6/22/2020 3:50 AM	5:03 AM	1:14	36.90	0.20	0.30	1.60	0.00
Turbine 2 Shutdown Event	6/22/2020 12:04 PM	12:17 PM	0:14	1.40	0.00	2.30	0.20	0.00
Turbine 1 Startup Event	6/22/2020 12:23 PM	1:48 PM	1:26	50.30	0.10	13.00	0.80	0.00
Turbine 2 Startup Event	6/22/2020 12:38 PM	1:53 PM	1:16	60.20	0.10	0.30	1.50	0.00
Turbine 1 Shutdown Event	6/22/2020 11:04 PM	11:17 PM	0:14	1.40	0.00	0.80	0.10	0.00
Turbine 2 Shutdown Event	6/22/2020 11:04 PM	11:17 PM	0:14	1.50	0.00	1.00	0.20	0.00
Turbine 2 Startup Event	6/23/2020 2:53 AM	4:30 AM	1:38	50.50	0.40	0.20	2.20	0.00
Turbine 2 Shutdown Event	6/23/2020 6:04 AM	6:16 AM	0:13	1.10	0.00	1.80	0.20	0.00
Turbine 2 Startup Event	6/23/2020 12:47 PM	2:18 PM	1:32	63.10	0.40	0.30	2.00	0.00
Turbine 1 Startup Event	6/23/2020 12:48 PM	2:23 PM	1:36	56.10	0.40	1.70	1.00	0.00
Turbine 1 Shutdown Event	6/23/2020 9:19 PM	9:34 PM	0:16	1.40	0.10	0.90	0.10	0.00
Turbine 2 Shutdown Event	6/23/2020 9:19 PM	9:34 PM	0:16	1.50	0.10	0.80	0.30	0.00
Turbine 2 Startup Event	6/24/2020 2:48 AM	4:17 AM	1:30	55.50	0.20	0.30	1.90	0.00
Turbine 2 Shutdown Event	6/24/2020 6:04 AM	6:16 AM	0:13	1.10	0.00	1.50	0.20	0.00
Turbine 1 Startup Event	6/24/2020 10:52 AM	12:17 PM	1:26	43.00	0.30	1.50	0.90	0.00
Turbine 2 Startup Event	6/24/2020 10:53 AM	12:17 PM	1:25	49.80	0.30	0.30	1.90	0.00
Turbine 1 Shutdown Event	6/24/2020 9:18 PM	9:34 PM	0:17	1.40	0.10	0.90	0.10	0.00
Turbine 2 Shutdown Event	6/24/2020 9:18 PM	9:34 PM	0:17	1.60	0.10	0.60	0.30	0.00
Turbine 2 Startup Event	6/25/2020 2:50 AM	4:16 AM	1:27	54.90	0.20	0.30	1.80	0.00
Turbine 2 Shutdown Event	6/25/2020 6:04 AM	6:17 AM	0:14	1.10	0.00	1.20	0.20	0.00
Turbine 1 Startup Event	6/25/2020 11:46 AM	12:53 PM	1:08	45.80	0.10	0.80	0.60	0.00
Turbine 2 Startup Event	6/25/2020 11:46 AM	1:00 PM	1:15	53.40	0.20	0.30	1.50	0.00
Turbine 1 Shutdown Event	6/25/2020 9:19 PM	9:35 PM	0:17	1.50	0.10	0.90	0.10	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 2 Shutdown Event	6/25/2020 9:19 PM	9:34 PM	0:16	1.60	0.10	0.50	0.30	0.00
Turbine 2 Startup Event	6/26/2020 2:48 AM	4:18 AM	1:31	55.40	0.30	0.30	1.90	0.00
Turbine 2 Shutdown Event	6/26/2020 6:04 AM	6:16 AM	0:13	1.10	0.00	1.10	0.20	0.00
Turbine 1 Startup Event	6/26/2020 12:52 PM	2:20 PM	1:29	48.50	0.40	1.70	0.90	0.00
Turbine 2 Startup Event	6/26/2020 12:52 PM	2:20 PM	1:29	51.80	0.40	0.30	2.00	0.00
Turbine 1 Shutdown Event	6/26/2020 11:04 PM	11:19 PM	0:16	1.50	0.10	0.90	0.10	0.00
Turbine 2 Shutdown Event	6/26/2020 11:04 PM	11:19 PM	0:16	1.60	0.10	0.60	0.30	0.00
Turbine 2 Startup Event	6/27/2020 2:38 PM	3:50 PM	1:13	73.30	0.20	0.70	1.50	0.00
Turbine 2 Shutdown Event	6/27/2020 11:03 PM	11:17 PM	0:15	1.20	0.00	2.20	0.20	0.00
Total (108 Events)			105:16	4483.10	14.10	387.40	100.70	0.00

ATTACHMENT 8
FUEL USAGE

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

12 Month Rolling - Combined Annual Gas Usage

June 2020 12-Month Rolling

Limit - 20,454 MMscf/year

Month	Unit 1 - Total Gas Flow kscf Monthly Total	Unit 2 - Total Gas Flow kscf Monthly Total	Total Gas Plant (U1+U2) Flow kscf Monthly Total	Total Plant Gas Flow mmscf Monthly Total	Total Plant Gas Flow mmscf 12 Month Rolling
Jul 2019	340655	205373	546028	546	6960
Aug 2019	352084	259298	611382	611	6566
Sep 2019	232184	169733	401917	402	6642
Oct 2019	270379	213851	484230	484	6176
Nov 2019	361609	276559	638168	638	6319
Dec 2019	675869	546128	1221997	1222	6898
Jan 2020	492761	48397	541158	541	6801
Feb 2020	Down	Down	Down	Down	5929
Mar 2020	53970	83506	137476	137	5470
Apr 2020	6500	86988	93488	93	5279
May 2020	122662	360084	482746	483	5690
Jun 2020	144035	261531	405566	406	5564

ATTACHMENT 9
FUEL SULFUR ANALYSIS



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

April 14, 2020

Richard Vogler
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:


Project ID: Master
RE: 2004047

Dear Richard Vogler:

Zalco Laboratories, Inc. received 3 samples on 4/7/2020 for the analyses presented in the following report.

We appreciate your business and look forward to serving you in the future . Please feel free to call our office if you have any questions regarding these test results.

Sincerely,




Juan Magana
Project Manager

CC: Neftali Nevarez & Wayne Toumbs

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic
Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Richard Vogler	Work Order No.: 2004047 Reported: 04/14/2020 Received: 04/07/2020 11:01
--	---	--

Lab Sample ID: 2004047-01	Collected By: Wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 4/6/2020 8:00:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.115	0.060	gr/100 scf		ASTM D3246-11	4/8/20	4/8/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	1.92	1.00	ppm		ASTM D 3246/M	4/8/20	4/8/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Richard Vogler	Work Order No.: 2004047 Reported: 04/14/2020 Received: 04/07/2020 11:01
--	---	--


Lab Sample ID: 2004047-02	Collected By: Wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 4/6/2020 8:02:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.139	0.060	gr/100 scf		ASTM D3246-11	4/8/20	4/8/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.31	1.00	ppm		ASTM D 3246/M	4/8/20	4/8/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Richard Vogler	Work Order No.: 2004047 Reported: 04/14/2020 Received: 04/07/2020 11:01
--	---	---

Lab Sample ID: 2004047-03 Client Sample ID: Natural Gas	Collected By: Wayne Toumbs Date Collected: 4/6/2020 8:05:00AM
--	--

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.156	0.060	gr/100 scf		ASTM D3246-11	4/8/20	4/8/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.60	1.00	ppm		ASTM D 3246/M	4/8/20	4/8/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

CHAIN OF CUSTODY, ID#

2004047

4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
2186 Eastman Avenue, Suite103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

Page 1 of 1

Zalco Lab #

Client PO #

PROJECT ID:

QUOTE ID:

REPORT INFO
Client: MRP San Joaquin Energy LLC
Address: 14950 W. SHULTE RD.
City, State, Zip: TRACY, CA 95377
Attention: Richard.Vogler@naes.com
Phone: Neftali.Nevarez@naes.com
Fax: Wayne.Toumbs@naes.com
Email: Results X

INVOICE INFO
Invoice To: Same as Client
Address:
City, State, Zip:
Attention:
Phone:
Fax:
Email:

ANALYSIS table with columns for sample numbers and analysis results. Includes vertical text 'TOTAL SULFUR ASTM D3' and 'TEMPERATURE (C)'.

COMMENTS:
Turnaround Time: Routine 5 working days X
Rush By working days
Send Copy to State of CA? Yes No X
Attention To:
Send Copy to County? Yes No X
County:

SAMPLED BY: Wayne Toumbs EMPLOYED BY: MRP San Joaquin Energy LLC

Main data table with columns: Sample No., Sample Description, Date, Sample Time, Type, and analysis results. Contains 3 rows of data for Natural Gas samples.

Signature and receipt table with columns: RELINQUISHED By: Signature, PRINT, COMPANY, Date, Time, RECEIVED By: Signature, PRINT. Includes handwritten signatures and dates.

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.

*Sample Type Key: AO-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil; O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater
*Sample No.: FOR OFFICE USE ONLY



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

May 13, 2020

Neftali Nevarez
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:


Project ID: Master
RE: 2005040

Dear Neftali Nevarez:

Zalco Laboratories, Inc. received 3 samples on 5/6/2020 for the analyses presented in the following report.

We appreciate your business and look forward to serving you in the future. Please feel free to call our office if you have any questions regarding these test results.

Sincerely,


Juan Magana
Project Manager
CC:

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Neftali Nevarez	Work Order No.: 2005040 Reported: 05/13/2020 Received: 05/06/2020 11:19
--	--	--

Lab Sample ID: 2005040-01	Collected By: wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 5/5/2020 7:00:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
No Sample Obtained								
Analysis: None	0		N/A		No Method	5/5/20	5/5/20	BLS

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Nefali Nevarez	Work Order No.: 2005040 Reported: 05/13/2020 Received: 05/06/2020 11:19
--	---	--

Lab Sample ID: 2005040-02	Collected By: wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 5/5/2020 7:02:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.190	0.060	gr/100 scf		ASTM D3246-11	5/6/20	5/6/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.17	1.00	ppm		ASTM D 3246/M	5/6/20	5/6/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Nefali Nevarez	Work Order No.: 2005040 Reported: 05/13/2020 Received: 05/06/2020 11:19
--	---	--

Lab Sample ID: 2005040-03	Collected By: wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 5/5/2020 7:05:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.190	0.060	gr/100 scf		ASTM D3246-11	5/6/20	5/6/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.17	1.00	ppm		ASTM D 3246/M	5/6/20	5/6/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

CHAIN OF CUSTODY, ID#

4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
2186 Eastman Avenue, Suite 103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

2005040

Zalco Lab #

Client PO #

PROJECT ID:

QUOTE ID:

COMMENTS:

Turnaround Time:
Routine 5 working days X
Rush By working days
Send Copy to State of CA?
Yes No X
Attention To:
Send Copy to County?
Yes No X
County

REPORT INFO
Client: MRP San Joaquin Energy LLC.
Address: 14950 W. SHULTE RD.
City, State, Zip: TRACY, CA 95377
Attention: Richard.Vogler@naes.com
Phone: Neftali.Nevarez@naes.com
Fax: Wayne.Toumbs@naes.com
Email: Results X

INVOICE INFO
Invoice To: Same as Client
Address:
City, State, Zip:
Attention:
Phone:
Fax:
Email:

ANALYSIS table with columns for CONTAINERS, TOTAL SULFUR ASTM D3, and TEMPERATURE (C). Includes handwritten 'X' marks in the CONTAINERS column for samples 1, 2, and 3.

SAMPLED BY: Wayne Toumbs EMPLOYED BY: MRP San Joaquin Energy LLC


Table with columns: Sample No., Sample Description, Date, Sample Time, Type. Contains 3 rows of sample data.

-1 empty - BS
(No sample)

Signature and receipt table with columns: RELINQUISHED By: Signature, PRINT, COMPANY, Date, Time, RECEIVED By: Signature, PRINT. Includes handwritten signatures and dates.

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.

*Sample Type Key: AQ-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater
*Sample No.: FOR OFFICE USE ONLY



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

June 9, 2020

Neftali Nevarez
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:


Project ID: Master
RE: 2006017

Dear Neftali Nevarez:

Zalco Laboratories, Inc. received 3 samples on 6/2/2020 for the analyses presented in the following report.


We appreciate your business and look forward to serving you in the future . Please feel free to call our office if you have any questions regarding these test results.

Sincerely,


Juan Magana
Project Manager
CC:Wayne Toumbs

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069


San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Neftali Nevarez	Work Order No.: 2006017 Reported: 06/09/2020 Received: 06/02/2020 11:11
--	--	---

Lab Sample ID: 2006017-01 Client Sample ID: Natural Gas	Collected By: Wayne Toumbs Date Collected: 6/1/2020 7:00:00AM
--	--

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.198	0.060	gr/100 scf		ASTM D3246-11	6/3/20	6/3/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.26	1.00	ppm		ASTM D 3246/M	6/3/20	6/3/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Neftali Nevarez	Work Order No.: 2006017 Reported: 06/09/2020 Received: 06/02/2020 11:11
--	--	---

Lab Sample ID: 2006017-02 Client Sample ID: Natural Gas	Collected By: Wayne Toumbs Date Collected: 6/1/2020 7:02:00AM
--	--

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.228	0.060	gr/100 scf		ASTM D3246-11	6/3/20	6/3/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.75	1.00	ppm		ASTM D 3246/M	6/3/20	6/3/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Neftali Nevarez	Work Order No.: 2006017 Reported: 06/09/2020 Received: 06/02/2020 11:11
--	--	--

Lab Sample ID: 2006017-03	Collected By: Wayne Toumbs
Client Sample ID: Natural Gas	Date Collected: 6/1/2020 7:05:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.222	0.060	gr/100 scf		ASTM D3246-11	6/3/20	6/3/20	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.65	1.00	ppm		ASTM D 3246/M	6/3/20	6/3/20	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC. CHAIN OF CUSTODY, ID# 2006017
 4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
 2186 Eastman Avenue, Suite103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

Page 1 of 1
 Zalco Lab # _____
 Client PO # _____

REPORT INFO		INVOICE INFO		ANALYSIS		PROJECT ID: _____	
Client: MRP San Joaquin Energy LLC.		Invoice To: Same as Client <input type="checkbox"/>		# O F C O N T A I N E R S T O T A L S U L F U R A S T M D 3	T E M P E R A T U R E (C)	PROJECT ID: _____	
Address: 14950 W. SHULTE RD.		Address: _____				QUOTE ID: _____	
City, State, Zip: TRACY, CA 95377		City, State, Zip: _____				COMMENTS:	
Attention: _____		Attention: _____				Turnaround Time:	
Phone: Neftali.Nevarez@naes.com		Phone: _____				Routine <u>5</u> working days <input checked="" type="checkbox"/>	
Fax: Wayne.Toumbs@naes.com		Fax: _____				Rush By _____ working days	
Email: _____		Email: _____				Send Copy to State of CA? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
SAMPLED BY: Wayne Toumbs		EMPLOYED BY: MRP San Joaquin Energy LLC		Attention To: _____			
Sample No. *	Sample Description	Date	Sample Time	Type*		Send Copy to County? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	County _____
1	NATURAL GAS	6/1/20	07:00	G	X		
2	NATURAL GAS	6/1/20	07:02	G	X		
3	NATURAL GAS	6/1/20	07:05	G	X		
RELINQUISHED By: Signature		PRINT	COMPANY	Date	Time	RECEIVED By: Signature	PRINT
		Wayne Toumbs	San Joaquin Energy	6/1/20	0830		6-2-20 11:11

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.

*Sample Type Key: AO-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil; O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater

*Sample No.: FOR OFFICE USE ONLY

ATTACHMENT 10
CEMS OPERATION REPORTS

Northern Region Central Region Southern Region

QUARTERLY CEMS EXCESS EMISSION AND DOWNTIME SUMMARY

1ST JAN - MAR 2020 3RD JULY - SEPT 2020
 2ND APR - JUNE 2020 4TH OCT - DEC 2019

Facility Name: MRP- San Joaquin Energy - TCCPP Permit #: N-4597-1-10

Location: 14950 W. Schulte Rd. City: Tracy

AIRS #: 06 077 N4597 NSPS Source ? : Yes No

Equipment Description: Electrical Power Generating System #1

Pollutants Monitored NOx SOx CO Opacity O₂ CO₂ NH₃
 Other NH3 slip

Total Hours Operated This Quarter: 324

CEM Unit Information

Pollutant	Manufacturer / Model	Serial #	Date Installed	Total Hrs Operated This Qtr.
NOx	Horiba/ENDA - 7420-CL	P-4702-NOX-S	07-17-2017	2184
SOx				
CO	Horiba/ENDA - 7420-CL	P-4702-CO	07-17-2017	2184
Opacity				
O ₂	Horiba/ENDA - 7420-CL	P-4702-O2-S	07-17-2017	2184
CO ₂				
NH ₃				
Other	Horiba/ENDA - 7420-CL	P-4702-NOX-I P-4702-O2-I	07-17-2017	2184

Date of Last Performance Specification Test

Pollutant	NOx	SOx	CO	Opacity	O ₂	CO ₂	NH ₃	Other
Date	04/08/20		04/08/20		04/08/20			04/08/20
Type	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA

Emission Limits (From Operating Permits)

Pollutant	ppm @ O ₂ % DB off	lb/hr DB off	ppm @ O ₂ % DB on	lb/hr DB on	lb/Day	ppm @ O ₂
NOx	2.0	8.10	2.0	10.30	814.9	15%
SOx		2.03		2.63	58.7	
CO	2.0	3.90	2.0	6.00	1071.6	15%
VOC	1.5	1.13	2.0	3.22	78.6	15%
O ₂						
PM10		4.40		5.80	132.0	
NH ₃ (24 hr avg)	5	9.40	5	9.40		15%

Excess Emissions Information (Report in Hours)

Pollutant	Start-Up / Shutdown	Cleaning	Breakdown	Other Known	Unknown	Total Hrs Excess	% Excess
NOx	0	0	0	0	0	0	0
SOx							
CO	0	0	0	0	0	0	0
Opacity							
O ₂	0	0	0	0	0	0	0
CO ₂							
NH ₃	0	0	0	0	0	0	0
	0	0	0	0	0	0	0

Include copies or a summary of: 1. All excess emissions notifications made in the quarter, 2. Equipment (non-instrument) breakdown reports associated with excess emission periods, 3. CEM equipment breakdown reports.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown.. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

CEM Downtime Information (Report in Hours)

Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total	% Downtime
NOx	0	0	1	0	0	1	0.3
SOX							
CO	0	0	1	0	0	1	0.3
Opacity							
O ₂	0	0	1	0	0	1	0.3
CO ₂							
NH ₃							
Other	2	0	1	0	0	3	0.9

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

Northern Region Central Region Southern Region

QUARTERLY CEMS EXCESS EMISSION AND DOWNTIME SUMMARY

1ST JAN - MAR 2020 3RD JULY - SEPT 2020
 2ND APR - JUNE 2020 4TH OCT - DEC 2020

Facility Name: MRP- San Joaquin Energy-TCCPP Permit #: N-4597-2-10

Location: 14950 W. Schulte Rd. City: Tracy

AIRS #: 06 077 N4597 NSPS Source ? : Yes No

Equipment Description: Electrical Power Generating System #2

Pollutants Monitored NOx SOx CO Opacity O₂ CO₂ NH₃
 Other Inlet NOx, O2

Total Hours Operated This Quarter: 897

CEM Unit Information

Pollutant	Manufacturer / Model	Serial #	Date Installed	Total Hrs Operated This Qtr.
NOx	Horiba/ENDA-7420-CL	P-4701-NOX-S	07-18-2017	2184
SOx				
CO	Horiba/ENDA - 7420-CL	P-4701-CO	07/18/2017	2184
Opacity				
O ₂	Horiba/ENDA-7420-CL	P-4701-O2-S	07/18/2017	2184
CO ₂				
NH ₃				
Other	Horiba/ENDA-7420-CL	P-4701-NOX-I P-4701-O2-I	07/18/2017	2184

Date of Last Performance Specification Test

Pollutant	NOx	SOx	CO	Opacity	O ₂	CO ₂	NH ₃	Other
Date	04/08/20		04/08/20		04/08/20			04/08/20
Type	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input type="checkbox"/> CGA	<input type="checkbox"/> RATA <input checked="" type="checkbox"/> CGA

Emission Limits (From Operating Permits)

Pollutant	ppm @ O ₂ % DB off	lb/hr DB off	ppm @ O ₂ % DB on	lb/hr DB on	lb/Day	ppm @ O ₂
NOx	2.0	8.10	2.0	10.30	814.9	15%
SOx		2.03		2.63	58.7	
CO	2.0	3.90	2.0	6.00	1071.6	15%
VOC	1.5	1.13	2.0	3.22	78.6	15%
O ₂						
PM10		4.40		5.80	132.0	
NH ₃ (24 hr avg)	5	9.40	5	9.40		15%

Excess Emissions Information (Report in Hours)

Pollutant	Start-Up / Shutdown	Cleaning	Breakdown	Other Known	Unknown	Total Hrs Excess	% Excess
NOx	0	0	0	0	0	0	0
SOx							
CO	0	0	0	0	0	0	0
Opacity							
O ₂	0	0	0	0	0	0	0
CO ₂							
NH ₃	0	0	0	0	0	0	0
Other	0	0	0	0	0	0	0

Include copies or a summary of: 1. All excess emissions notifications made in the quarter, 2. Equipment (non-instrument) breakdown reports associated with excess emission periods, 3. CEM equipment breakdown reports.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown.. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

CEM Downtime Information (Report in Hours)

Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total	% Downtime
NOx	0	0	0	0	0	0	0
SOX							
CO	0	0	0	0	0	0	0
Opacity							
O ₂	0	0	0	0	0	0	0
CO ₂							
NH ₃							
Other	0	0	0	0	0	0	0

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

Reports must be submitted within 30 days of the end of the quarter for which the report was generated.

ATTACHMENT 11
EDG LOG

Tracy EDG Run Log - 2020

Meter Begin	299	Meter End	306					Total Meter	7
Date	Test/Maint Run Time (min)	Emergency Run Time (min)	Meter YTD	Volts	Hertz	Oil Pressure	Comments		
1/1/20	5	0	299	482	60.1	80	Weekly Test		
1/7/20	5	0	299	482	60.2	80	Weekly Test		
1/14/20	5	0	299	482	60.1	79	Weekly Test		
1/21/20	5	0	299	482	60.1	80	Weekly Test		
1/28/20	30	0	299	482	60.1	74	Monthly Test		
2/4/20	5	0	299	482	60.1	80	Weekly Test		
2/11/20	5	0	300	482	60.1	80	Weekly Test		
2/18/20	5	0	300	482	60.1	80	Weekly Test		
2/25/20	30	0	300	482	60.1	73	Monthly Test		
3/3/20	5	0	300	482	60.1	80	Weekly Test		
3/10/20	5	0	300	482	60.1	80	Weekly Test		
3/17/20	5	0	300	482	60.1	80	Weekly Test		
3/24/20	5	0	300	482	60.1	80	Weekly Test		
3/31/20	30	0	301	482	60.1	72	Monthly Test		
4/7/20	5	0	301	480	60	80	Weekly Test		
4/14/20	5	0	301	482	60.1	80	Weekly Test		
4/21/20	5	0	301	482	60.1	82	Weekly Test		
4/28/20	30	0	302	482	60.1	81	Monthly Test		
5/5/20	120	0	304	480	60.1	70	Quarterly PM by Holt		
5/12/20	5	0	304	482	60.1	82	Weekly Test		
5/19/20	5	0	304	480	60	80	Weekly Test		
5/26/20	30	0	305	482	60.1	74	Monthly Test		
6/1/20	6	0	305				Testing following replacemnet of control panel		
6/2/20	5	0	305	479	60.1	78	Weekly Test		
6/9/20	5	0	305	479	60.1	78	Weekly Test		
6/16/20	5	0	305	479	60.1	81	Weekly Test		
6/23/20	5	0	305	479	60.1	82	Weekly Test		
6/30/20	30	0	306	479	60.1	74	Monthly Test		

Total Minutes **406** **0** **406**

Total Hours **6.77** **0.00** **6.77**
 Test/Maint **Emergency** **Total Run**
 Run Time **Run Time** **Time**

Run Times Per Reason:	Time (Min)	Time (Hours)
Weekly Test Run/Service	406	6.77
		0.00
		0.00
		0.00
		0.00
		0.00

ATTACHMENT 12
AUX BOILER LOG

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 April - 2020

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	3.3	11.9	12.5	9940.8	1.41	Down	1.6	Down	0.0
02	3.7	46.2	48.4	44640.6	4.29	Down	4.4	95	3.9
03	3.6	148.9	156.0	145164.4	17.77	Down	17.8	Down	0.0
04	3.3	25.3	26.4	24160.0	2.38	Down	2.6	154	4.7
05	3.3	150.2	157.1	140861.8	18.73	Down	18.8	Down	0.0
06	3.0	196.8	205.1	188430.8	24.00	Down	24.0	Down	0.0
07	3.5	210.4	219.9	215500.0	24.00	Down	24.0	270	7.2
08	3.7	123.5	129.2	126926.3	15.23	21.4	15.2	302	6.8
09	3.7	138.7	145.4	134978.4	17.21	Down	17.4	Down	0.0
10	3.7	35.1	36.9	34295.7	3.10	Down	3.3	105	3.7
11	3.8	130.4	136.8	129984.3	16.25	Down	16.4	Down	0.0
12	4.0	10.8	11.2	9579.5	1.28	Down	1.4	Down	0.0
13	4.1	14.0	14.7	12130.4	1.70	Down	1.8	Down	0.0
14	3.8	12.2	12.9	10605.6	1.43	Down	1.6	Down	0.0
15	3.9	48.6	50.8	49483.9	4.84	Down	5.0	88	4.0
16	3.8	144.6	151.6	152114.9	16.10	Down	16.2	4	0.1
17	3.9	11.0	11.6	10462.0	1.29	Down	1.4	Down	0.0
18	3.7	16.3	17.0	14410.8	1.95	Down	2.1	Down	0.0
19	3.6	18.2	19.0	16293.2	2.18	Down	2.3	Down	0.0
20	3.6	16.3	17.0	15335.6	1.97	Down	2.1	Down	0.0
21	3.7	15.5	16.3	13906.8	1.88	Down	2.0	Down	0.0
22	4.0	16.8	17.7	15465.3	2.03	Down	2.2	Down	0.0
23	4.3	15.7	16.5	14197.3	1.91	Down	2.1	Down	0.0
24	4.1	6.4	6.7	5826.8	0.76	Down	0.9	Down	0.0
25	4.1	25.2	26.5	25328.3	3.07	Down	3.2	Down	0.0
26	4.2	19.4	20.2	18059.4	2.24	Down	2.4	Down	0.0
27	3.9	32.1	33.6	32215.0	2.96	Down	3.1	351	10.5
28	4.1	14.4	15.0	13109.6	1.67	Down	1.9	923	24.0
29	4.1	11.4	11.9	9972.7	1.37	Down	1.5	901	24.0
30	4.1	10.8	11.2	9215.7	1.24	Down	1.4	891	24.0
Average	3.8	55.9	1755	54753.2	196.2	21.4	200	371	113
Total		1677.1		1642595.9				4084	

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 May - 2020

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	4.0	11.6	12.1	9971.7	1.36	Down	1.5	921	24.0
02	4.0	11.3	11.8	9864.1	1.33	Down	1.5	873	24.0
03	4.0	10.6	11.1	9008.2	1.23	Down	1.4	936	24.0
04	3.9	10.4	10.8	8947.6	1.23	Down	1.4	970	23.9
05	4.0	133.4	139.4	134908.7	15.87	Down	15.9	60	2.2
06	4.0	9.6	10.0	8120.7	1.09	Down	1.3	908	24.0
07	4.3	7.0	7.2	6025.4	0.78	Down	1.0	932	24.0
08	4.9	11.1	11.5	10199.9	1.33	Down	1.5	1047	24.0
09	4.1	17.5	18.2	15320.2	2.08	Down	2.3	932	24.0
10	4.0	11.4	12.0	9890.6	1.41	Down	1.6	911	24.0
11	3.9	12.7	13.4	10751.4	1.55	Down	1.8	950	23.2
12	4.0	127.2	132.6	121692.5	16.32	Down	16.4	Down	0.0
13	3.9	186.3	194.3	178426.3	24.00	Down	24.0	Down	0.0
14	3.9	185.7	194.4	178861.9	24.00	Down	24.0	Down	0.0
15	4.0	186.6	194.4	183532.3	24.00	Down	24.0	Down	0.0
16	4.0	186.4	194.4	191446.3	24.00	Down	24.0	Down	0.0
17	4.1	171.3	178.6	172840.8	22.08	Down	22.1	Down	0.0
18	Down	Down	Down	Down	0.00	Down	0.0	Down	0.0
19	Down	Down	Down	Down	0.00	Down	0.0	Down	0.0
20	5.4	1.7	1.8	Down	0.00	Down	0.5	Down	0.0
21	3.4	116.5	121.4	114791.1	9.22	Down	10.7	202	8.4
22	4.3	115.2	120.2	116818.0	13.66	19.5	13.9	221	8.0
23	4.2	146.9	152.6	148541.0	17.50	Down	17.5	321	8.1
24	4.1	11.6	12.1	10579.7	1.37	Down	1.6	589	16.5
25	4.1	11.6	12.2	10098.6	1.38	18.1	1.6	1412	19.9
26	4.5	13.0	13.5	10546.2	1.40	17.7	2.0	1941	18.8
27	5.2	11.5	11.9	10779.9	1.42	18.1	1.6	2379	24.0
28	4.2	12.7	13.3	10915.3	1.52	18.1	1.8	2182	24.0
29	4.4	11.8	12.4	9789.4	1.38	18.1	1.7	2444	24.0
30	5.1	21.8	22.8	19211.0	2.64	19.0	3.0	2387	24.0
31	4.3	13.4	14.1	10571.5	1.45	17.0	2.0	277	8.3
Average Total	4.2	61.3 1777.8	1855	61873.2 1732450.3	216.6	18.2	224	1082 23795	425

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 June - 2020

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	4.2	13.0	13.5	10673.2	1.49	18.4	1.9	1107	18.8
02	4.0	13.1	13.6	12383.8	1.58	17.9	1.7	1496	20.5
03	4.2	12.4	12.8	10217.6	1.45	18.1	1.8	2179	24.0
04	4.6	12.8	13.2	10145.7	1.42	18.4	1.9	1675	20.8
05	5.2	12.1	12.5	10499.1	1.49	Down	1.7	827	23.1
06	4.1	89.5	92.6	87152.6	11.39	Down	11.8	449	12.7
07	4.0	112.3	116.0	112495.8	14.46	Down	14.5	Down	0.0
08	3.1	41.2	42.5	41827.5	3.62	Down	3.6	805	20.6
09	Down	Down	Down	Down	0.00	17.0	0.0	1434	22.7
10	Down	Down	Down	Down	0.00	17.0	0.0	1731	20.5
11	Down	Down	Down	Down	0.00	17.0	0.0	1501	15.6
12	4.0	41.5	43.1	39023.1	3.75	Down	4.7	Down	0.0
13	4.2	186.8	193.4	202054.1	24.00	Down	24.0	Down	0.0
14	4.2	187.8	193.4	188334.6	23.78	Down	23.9	Down	0.0
15	4.4	189.4	194.4	186026.0	24.00	Down	24.0	Down	0.0
16	4.3	189.5	194.4	184807.4	24.00	Down	24.0	Down	0.0
17	4.5	156.6	160.8	156339.8	19.85	Down	19.9	115	4.5
18	4.3	11.1	11.4	10070.6	1.34	18.2	1.5	824	10.7
19	4.9	129.9	134.1	134830.1	16.32	Down	16.4	Down	0.0
20	4.1	230.0	237.4	242895.1	24.00	Down	24.0	Down	0.0
21	4.3	114.3	118.4	119650.7	12.47	Down	12.5	558	14.1
22	4.4	11.8	12.1	10105.5	1.45	18.2	1.6	1193	18.0
23	5.0	5.1	5.3	4627.6	0.61	17.0	0.7	793	10.7
24	4.2	11.8	12.2	10622.3	1.46	18.3	1.6	1043	12.7
25	4.6	5.2	5.4	4812.7	0.62	18.1	0.7	923	11.8
26	4.0	21.9	22.8	19956.4	2.48	17.0	2.7	1044	12.5
27	4.8	58.9	60.6	59376.3	7.36	Down	7.5	358	7.8
28	4.5	114.0	118.4	110130.1	14.40	Down	14.5	Down	0.0
29	4.2	189.6	196.7	189209.3	24.00	Down	24.0	Down	0.0
30	4.5	189.6	196.2	208683.7	24.00	Down	24.0	Down	0.0
Average Total	4.3	87.1 2351.2	2427	88035.2 2376950.7	286.8	17.7	291	1056 20055	302

Tracy Combined Cycle Power Plant
Tracy, CA
Aux Boiler Operating Time
2020

Limit- 4000 Hr

Month	Aux Boiler Operating Time (Hrs)
Jan	124
Feb	51
Mar	224
Apr	200
May	224
Jun	291
Jul	121
Aug	Inval
Sep	Inval
Oct	Inval
Nov	Inval
Dec	Inval
Year-To-Month Total	1235

ATTACHMENT 13
EMERGENCY FIRE PUMP LOG

Tracy Diesel Fire pump Run Log - 2020

Meter Begin	27.6	Meter End	31.0			
Date	Test/Maint Run Time (min)	Emergency Run Time (min)	Total run time Control panel (Hrs: Min)	Total Engine Run Time (HRs)	Total Engine Starts	Comments
1/1/2020	5	0	28:43	27.6	407	Weekly Test
1/7/2020	2	0	28:45	27.7	408	Weekly Test
1/14/2020	5	0	28:50	27.8	409	Weekly Test
1/21/2020	3	0	28:53	27.8	410	Weekly Test
1/28/2020	30	0	29:23	28.3	411	Monthly Test
2/4/2020	2	0	29:25	28.3	412	Weekly Test
2/11/2020	2	0	29:27	28.4	413	Weekly Test
2/18/2020	2	0	29:28	28.4	414	Weekly Test
2/25/2020	30	0	29:57	28.9	415	Monthly Test
3/3/2020	5	0	29:58	28.9	416	Weekly Test
3/10/2020	3	0	30:01	28.9	417	Weekly Test
3/17/2020	5	0	30:06	29.0	418	Weekly Test
3/24/2020	2		30:08	29.0	419	Weekly Test
3/31/2020	30	0	30:38	29.5	420	Monthly Test
4/7/2020	5	0	30:39	29.5	421	Weekly Test
4/14/2020	5	0	30:44	29.6	422	Weekly Test
4/21/2020	2	0	30:46	29.6	423	Weekly Test
4/28/2020	7	0	30:52	29.7	424	Jorgensen Test
5/4/2020	3	0	30:55	29.8	425	Holt Maintenance
5/12/2020	5	0	31:00	29.8	426	Weekly Test
5/19/2020	3	0	31:00	29.8	426	Emergency Start Test
5/26/2020	30	0	31:30	30.3	427	Monthly Test
6/2/2020	2	0	31:32	30.4	428	Weekly Test
6/9/2020	2	0	31:34	30.4	429	Weekly Test
6/16/2020	3	0	31:37	30.4	430	Weekly Test
6/23/2020	2	0	31:39	30.4	431	Weekly Test
6/30/2020	30	0	32:10	31.0	432	Monthly Test
Total Time	225	0	225		25	

Total Hours **3.75** **0.00** **3.75**
 Test/Maint **Emergency** **Total Run**
 Run Time **Run Time** **Time**

	Time (Min)	No. of Starts	Time (Hours)
Run Times Per Reason:			
Weekly Reliability Test Run	225	25	3.75
Emergency Run	0	0	0

ATTACHMENT 14
Aux Boiler Compliance

April 2, 2020

Mr. Claude Couvillion
Mrp San Joaquin Energy, LLC
14950 W. Schulte Rd
Tracy, CA 95377

RE: DETERMINATION OF COMPLIANCE EMISSION TESTING

Dear Mr. Couvillion,

District staff have received the test report submitted for the permitted equipment listed below for compliance determination with permitted emission limits. Review of the test result(s) reveal the equipment appears to be **operating in full compliance** with permitted emission limits.

If the permitted equipment has annual source testing requirements, then the next required test must be conducted within thirty days (+/- 30) of the next test date as shown below. If an ATC has been issued for modifications to the permitted equipment then the testing requirements must follow the ATC.

Permit Number	Unit ID	Test Date	Next Test Date
N-4597-5-1	Boiler	1/31/2020	1/18/2023

If the equipment is under dormant status, you must contact the District before restarting unit. If you have any questions please call this office at (209) 557-6400.

Sincerely,



Lisa D Middleton
Supervising Air Quality Inspector

ATTACHMENT 15
Dust Suppression Control Measures

No construction occurred during Q2 2020, therefore no additional dust suppression control measures were put in place.