DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	235544
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2020
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	11/10/2020 8:44:46 AM
Docketed Date:	11/10/2020

City of Roseville

Roseville Energy Park

(03-AFC-1)

California Energy Commission

Quarterly Operational Report

Third Quarter 2020

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly SOx AQ-SC6

AQ34 – Startups and Shutdowns

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12-month summary

AQ47 – All nuisance violations

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOx, PM-10, SOx, and VOC

AQ59 – Emission limit exceedances – NOx, CO, VOC, PM-10, SO_2

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PMO, SOx

AQ63 – Total facility emission exceedances – NOx, CO, VOC, PM-10, SO_2

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built deigns or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ20 ROSEVILLE ENERGY PARK

3Q20

Fuel Quality Analysis BTU values http://www.pge.com/pi

	JUL	AUG	SEP
1	1034.99	1036.19	1038.99
2	1033.19	1043.02	1042.51
3	1032.02	1039.06	1043.69
4	1034.31	1037.54	1042.01
5	1032.42	1039.01	1041.70
6	1032.13	1040.66	1038.84
7	1027.58	1043.00	1038.06
8	1028.47	1038.17	1040.14
9	1030.64	1038.63	1039.00
10	1029.92	1037.09	1036.04
11	1030.37	1039.78	1038.13
12	1034.89	1040.32	1038.13
13	1033.14	1,036.11	1038.13
14	1034.53	1038.92	1038.13
15	1033.13	1039.99	1038.13
16	1032.46	1041.66	1038.13
17	1032.11	1037.73	1038.13
18	1031.70	1037.54	1044.56
19	1033.04	1037.77	1044.56
20	1032.34	1038.12	1044.56
21	1034.56	1040.59	1035.48
22	1034.02	1042.83	1030.77
23	1034.15	1042.68	1037.92
24	1034.31	1041.43	1038.28
25	1034.86	1041.47	1040.25
26	1033.53	1043.57	1041.31
27	1033.46	1043.29	1040.99
28	1033.65	1042.69	1040.42
29	1033.05	1041.76	1039.08
30	1033.16	1040.15	1039.61
31	1032.54	1042.77	X

ɔeline/operations/gas_quality/p01_2_weeks.shtml

https://www.pge.com/pipeline/operations/sulfur/sulfur_info_values/index.page

Gas System Sulfur Survey R...

California Gas Transmission

Pipe Ranger

Search Go Log in

About CGT | Products | Tools & Services | Operating Data | Reference/Library

- Current Pipeline Status
- Forecasts
- Historical Archives
- Gas Quality/Heating Values

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2020				
Second Quarter	4.7	0.29	3.5	0.22
First Quarter	4.8	0.30	4.0	0.25

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/13/2020 05:00	294
07/21/2020 06:00	07/26/2020 00:00	115
08/06/2020 00:00	08/08/2020 21:00	70
09/24/2020 00:00	09/28/2020 03:00	100

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	579.00 Hour(s)
Offline Percentage:	26.22 %
Total Online:	1,629.00 Hour(s)
Online Percentage:	73.78 %

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/13/2020 06:44	07/13/2020 07:48	Cold Startup	65
2	07/21/2020 04:54	07/21/2020 05:02	Shutdown	9
3	07/26/2020 01:43	07/26/2020 02:38	Cold Startup	56
4	08/05/2020 22:57	08/05/2020 23:05	Shutdown	9
5	08/08/2020 22:44	08/08/2020 23:38	Cold Startup	55
6	09/23/2020 22:54	09/23/2020 23:02	Shutdown	9
7	09/28/2020 04:44	09/28/2020 05:35	Cold Startup	52

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	228	0.23
Warm Startup	0		0.00
Shutdown	3	27	0.03
Total Process Events:	7	255	0.26

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,623.28 Hour(s)
Total Startup Time:	228 Minute(s)
Total Shutdown Time:	27 Minute(s)
Total Startup/Shutdown Time:	255 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.26 %

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/13/2020 02:00	291
07/21/2020 06:00	07/25/2020 21:00	112
08/05/2020 23:00	08/08/2020 06:00	56
08/31/2020 00:00	08/31/2020 13:00	14

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	473.00 Hour(s)
Offline Percentage:	21.42 %
Total Online:	1,735.00 Hour(s)
Online Percentage:	78.58 %

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/13/2020 03:44	07/13/2020 04:38	Cold Startup	55
2	07/21/2020 04:59	07/21/2020 05:08	Shutdown	10
3	07/25/2020 22:43	07/25/2020 23:33	Cold Startup	51
4	08/05/2020 21:55	08/05/2020 22:03	Shutdown	9
5	08/08/2020 07:44	08/08/2020 08:33	Cold Startup	50
6	08/30/2020 22:54	08/30/2020 23:02	Shutdown	9
7	08/31/2020 14:44	08/31/2020 15:31	Cold Startup	48

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	204	0.20
Warm Startup	0		0.00
Shutdown	3	28	0.03
Total Process Events:	7	232	0.22

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,729.35 Hour(s)
Total Startup Time:	204 Minute(s)
Total Shutdown Time:	28 Minute(s)
Total Startup/Shutdown Time:	232 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.22 %

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.00	0.00	0.00
07/02/2020	0.00	0.00	0.00	0.00	0.00
07/03/2020	0.00	0.00	0.00	0.00	0.00
07/04/2020	0.00	0.00	0.00	0.00	0.00
07/05/2020	0.00	0.00	0.00	0.00	0.00
07/06/2020	0.00	0.00	0.00	0.00	0.00
07/07/2020	0.00	0.00	0.00	0.00	0.00
07/08/2020	0.00	0.00	0.00	0.00	0.00
07/09/2020	0.00	0.00	0.00	0.00	0.00
07/10/2020	0.00	0.00	0.00	0.00	0.00
07/11/2020	0.00	0.00	0.00	0.00	0.00
07/12/2020	0.00	0.00	0.00	0.00	0.00
07/13/2020	71.49	120.71	9.39	18.82	31.33
07/14/2020	24.97	118.82	11.66	23.31	38.81
07/15/2020	21.18	122.64	11.73	23.50	39.08
07/16/2020	22.90	119.88	11.44	22.88	38.10
07/17/2020	24.35	112.72	10.79	21.56	35.91
07/18/2020	24.25	125.15	11.97	23.93	39.86
07/19/2020	24.50	121.49	11.60	23.21	38.57
07/20/2020	24.25	118.81	11.32	22.60	37.68
07/21/2020	31.92	20.68	1.82	3.62	6.02
07/22/2020	0.00	0.00	0.00	0.00	0.00
07/23/2020	0.00	0.00	0.00	0.00	0.00
07/24/2020	0.00	0.00	0.00	0.00	0.00
07/25/2020	23.50	13.62	0.26	0.52	0.86
07/26/2020	49.67	129.61	11.49	23.00	38.28
07/27/2020	23.35	130.52	12.40	24.84	41.37
07/28/2020	22.42	126.78	12.07	24.15	40.15
07/29/2020	22.69	126.26	12.05	24.14	40.11
07/30/2020	21.45	121.89	11.91	23.86	39.62
07/31/2020	22.11	122.78	11.68	23.34	38.78
Monthly Avg/Sum*:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
Daily Min:	21.18	13.62	0.26	0.52	0.86
Daily Max:	71.49	130.52	12.40	24.84	41.37
Jul 2020 - Jul 2020	455.00	1,752.36	163.58	327.28	544.53
QTD:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
YTD 2020:	1,510.06 *	4,027.76 *	372.07 *	744.45 *	1,239.38 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2020	25.18	117.17	11.17	22.35	37.13
08/02/2020	22.36	117.79	11.37	22.74	37.91
08/03/2020	22.84	120.40	11.55	23.13	38.44
08/04/2020	23.43	119.41	11.37	22.78	37.86
08/05/2020	47.39	107.35	10.05	20.08	33.39
08/06/2020	0.00	0.00	0.00	0.00	0.00
08/07/2020	0.00	0.00	0.00	0.00	0.00
08/08/2020	61.48	69.74	4.76	9.53	15.87
08/09/2020	20.51	135.52	12.91	25.83	43.03
08/10/2020	23.58	128.58	12.23	24.50	40.79
08/11/2020	29.79	113.63	10.91	21.85	36.22
08/12/2020	22.48	130.64	12.43	24.94	41.51
08/13/2020	22.89	132.42	12.62	25.25	42.17
08/14/2020	23.70	144.67	13.90	27.73	46.27
08/15/2020	18.53	146.66	14.02	28.03	46.74
08/16/2020	26.49	137.72	13.18	26.35	43.90
08/17/2020	30.86	138.62	13.35	26.82	44.65
08/18/2020	30.29	130.87	12.51	25.01	41.67
08/19/2020	30.56	140.89	13.46	26.87	44.88
08/20/2020	39.34	105.45	10.05	20.14	33.60
08/21/2020	28.60	124.96	11.96	23.91	39.90
08/22/2020	35.35	120.76	11.53	22.98	38.41
08/23/2020	29.84	123.32	11.74	23.55	39.29
08/24/2020	31.42	130.26	12.41	24.82	41.31
08/25/2020	28.55	124.20	11.88	23.74	39.56
08/26/2020	26.91	126.00	12.04	24.07	40.09
08/27/2020	29.02	116.33	11.13	22.21	36.99
08/28/2020	26.75	124.05	11.82	23.63	39.43
08/29/2020	27.11	115.63	10.99	21.99	36.62
08/30/2020	32.86	114.55	10.86	21.66	36.00
08/31/2020	33.19	108.91	9.49	19.01	31.65
Monthly Avg/Sum*:	851.30 *	3,566.50 *	337.69 *	675.50 *	1,125.28 *
Daily Min:	18.53	69.74	4.76	9.53	15.87
Daily Max:	61.48	146.66	14.02	28.03	46.74
Jul 2020 - Aug 2020	1,306.30	5,318.86	501.27	1,002.78	1,669.81
QTD:	1,306.30 *	5,318.86 *	501.27 *	1,002.78 *	1,669.81 *
YTD 2020:	2,361.36 *	7,594.26 *	709.76 *	1,419.95 *	2,364.66 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2020	28.01	131.26	12.54	25.07	41.78
09/02/2020	28.93	121.27	11.65	23.25	38.80
09/03/2020	19.91	135.75	12.87	25.79	43.01
09/04/2020	20.04	138.63	13.20	26.31	43.89
09/05/2020	21.31	134.48	12.86	25.71	42.86
09/06/2020	23.30	132.06	12.59	25.14	41.90
09/07/2020	30.08	126.35	12.07	24.14	40.16
09/08/2020	27.86	110.84	10.64	21.25	35.40
09/09/2020	19.49	133.30	12.76	25.54	42.51
09/10/2020	36.57	110.01	10.52	20.99	35.03
09/11/2020	37.20	109.93	10.50	21.03	35.06
09/12/2020	38.49	113.22	10.83	21.67	36.10
09/13/2020	38.53	115.70	11.16	22.27	37.18
09/14/2020	27.93	121.94	11.65	23.27	38.85
09/15/2020	26.76	124.51	11.90	23.78	39.67
09/16/2020	25.52	132.95	12.74	25.48	42.49
09/17/2020	29.77	128.93	12.30	24.59	40.97
09/18/2020	30.70	121.91	11.66	23.34	38.87
09/19/2020	30.63	117.17	11.12	22.25	37.10
09/20/2020	27.21	115.89	11.05	22.14	36.89
09/21/2020	25.51	130.86	12.58	25.13	41.90
09/22/2020	26.71	127.89	12.20	24.39	40.66
09/23/2020	33.97	125.68	11.96	23.87	39.84
09/24/2020	15.83	62.42	6.14	12.31	20.53
09/25/2020	17.37	55.78	5.34	10.67	17.82
09/26/2020	15.02	50.38	4.79	9.53	15.93
09/27/2020	15.99	52.41	5.00	9.99	16.66
09/28/2020	51.02	115.72	10.15	20.30	33.86
09/29/2020	32.79	122.88	11.78	23.56	39.29
09/30/2020	32.11	125.24	11.99	24.00	40.01
Monthly Avg/Sum*:	834.56 *	3,445.36 *	328.54 *	656.76 *	1,095.02 *
Daily Min:	15.02	50.38	4.79	9.53	15.93
Daily Max:	51.02	138.63	13.20	26.31	43.89
Jul 2020 - Sep 2020	2,140.86	8,764.22	829.81	1,659.54	2,764.83
QTD:	2,140.86 *	8,764.22 *	829.81 *	1,659.54 *	2,764.83 *
YTD 2020:	3,195.92 *	11,039.62 *	1,038.30 *	2,076.71 *	3,459.68 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
07/01/2020	0.0	0.0	0.0	0.0
07/02/2020	0.0	0.0	0.0	0.0
07/03/2020	0.0	0.0	0.0	0.0
07/04/2020	0.0	0.0	0.0	0.0
07/05/2020	0.0	0.0	0.0	0.0
07/06/2020	0.0	0.0	0.0	0.0
07/07/2020	0.0	0.0	0.0	0.0
07/08/2020	0.0	0.0	0.0	0.0
07/09/2020	0.0	0.0	0.0	0.0
07/10/2020	0.0	0.0	0.0	0.0
07/11/2020	0.0	0.0	0.0	0.0
07/12/2020	0.0	0.0	0.0	0.0
07/13/2020	28.8	12.7	22.8	13.7
07/14/2020	0.0	0.0	0.0	0.0
07/15/2020	0.0	0.0	0.0	0.0
07/16/2020	0.0	0.0	0.0	0.0
07/17/2020	0.0	0.0	0.0	0.0
07/18/2020	0.0	0.0	0.0	0.0
07/19/2020	0.0	0.0	0.0	0.0
07/20/2020	0.0	0.0	0.0	0.0
07/21/2020	6.9	0.8	9.1	0.9
07/22/2020	0.0	0.0	0.0	0.0
07/23/2020	0.0	0.0	0.0	0.0
07/24/2020	0.0	0.0	0.0	0.0
07/25/2020	0.0	0.0	23.5	12.3
07/26/2020	26.2	11.3	0.0	0.0
07/27/2020	0.0	0.0	0.0	0.0
07/28/2020	0.0	0.0	0.0	0.0
07/29/2020	0.0	0.0	0.0	0.0
07/30/2020	0.0	0.0	0.0	0.0
07/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	61.9 *	24.8 *	55.4 *	26.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	28.8	12.7	23.5	13.7
Jul 2020 - Jul 2020	61.9	24.8	55.4	26.9
QTD:	61.9 *	24.8 *	55.4 *	26.9 *
YTD 2020:	416.3 *	104.6 *	203.1 *	89.4 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
08/01/2020	0.0	0.0	0.0	0.0
08/02/2020	0.0	0.0	0.0	0.0
08/03/2020	0.0	0.0	0.0	0.0
08/04/2020	0.0	0.0	0.0	0.0
08/05/2020	7.9	0.9	8.0	1.1
08/06/2020	0.0	0.0	0.0	0.0
08/07/2020	0.0	0.0	0.0	0.0
08/08/2020	24.9	10.7	26.1	12.6
08/09/2020	0.0	0.0	0.0	0.0
08/10/2020	0.0	0.0	0.0	0.0
08/11/2020	0.0	0.0	0.0	0.0
08/12/2020	0.0	0.0	0.0	0.0
08/13/2020	0.0	0.0	0.0	0.0
08/14/2020	0.0	0.0	0.0	0.0
08/15/2020	0.0	0.0	0.0	0.0
08/16/2020	0.0	0.0	0.0	0.0
08/17/2020	0.0	0.0	0.0	0.0
08/18/2020	0.0	0.0	0.0	0.0
08/19/2020	0.0	0.0	0.0	0.0
08/20/2020	0.0	0.0	0.0	0.0
08/21/2020	0.0	0.0	0.0	0.0
08/22/2020	0.0	0.0	0.0	0.0
08/23/2020	0.0	0.0	0.0	0.0
08/24/2020	0.0	0.0	0.0	0.0
08/25/2020	0.0	0.0	0.0	0.0
08/26/2020	0.0	0.0	0.0	0.0
08/27/2020	0.0	0.0	0.0	0.0
08/28/2020	0.0	0.0	0.0	0.0
08/29/2020	0.0	0.0	0.0	0.0
08/30/2020	0.0	0.0	5.7	1.2
08/31/2020	0.0	0.0	11.7	12.0
Monthly Avg/Sum*:	32.8 *	11.6 *	51.5 *	26.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	24.9	10.7	26.1	12.6
Jul 2020 - Aug 2020	94.7	36.4	106.9	53.8
QTD:	94.7 *	36.4 *	106.9 *	53.8 *
YTD 2020:	449.1 *	116.2 *	254.6 *	116.3 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
09/01/2020	0.0	0.0	0.0	0.0
09/02/2020	0.0	0.0	0.0	0.0
09/03/2020	0.0	0.0	0.0	0.0
09/04/2020	0.0	0.0	0.0	0.0
09/05/2020	0.0	0.0	0.0	0.0
09/06/2020	0.0	0.0	0.0	0.0
09/07/2020	0.0	0.0	0.0	0.0
09/08/2020	0.0	0.0	0.0	0.0
09/09/2020	0.0	0.0	0.0	0.0
09/10/2020	0.0	0.0	0.0	0.0
09/11/2020	0.0	0.0	0.0	0.0
09/12/2020	0.0	0.0	0.0	0.0
09/13/2020	0.0	0.0	0.0	0.0
09/14/2020	0.0	0.0	0.0	0.0
09/15/2020	0.0	0.0	0.0	0.0
09/16/2020	0.0	0.0	0.0	0.0
09/17/2020	0.0	0.0	0.0	0.0
09/18/2020	0.0	0.0	0.0	0.0
09/19/2020	0.0	0.0	0.0	0.0
09/20/2020	0.0	0.0	0.0	0.0
09/21/2020	0.0	0.0	0.0	0.0
09/22/2020	0.0	0.0	0.0	0.0
09/23/2020	5.5	0.8	0.0	0.0
09/24/2020	0.0	0.0	0.0	0.0
09/25/2020	0.0	0.0	0.0	0.0
09/26/2020	0.0	0.0	0.0	0.0
09/27/2020	0.0	0.0	0.0	0.0
09/28/2020	25.3	10.8	0.0	0.0
09/29/2020	0.0	0.0	0.0	0.0
09/30/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	30.8 *	11.6 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	25.3	10.8	0.0	0.0
Jul 2020 - Sep 2020	125.5	48.0	106.9	53.8
QTD:	125.5 *	48.0 *	106.9 *	53.8 *
YTD 2020:	479.9 *	127.8 *	254.6 *	116.3 *

CT1 SUSD EVENT 1

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 6:39	0			0			0			0			0			0		
07/13/20 6:40	0			0			0			0			0			0		
07/13/20 6:41	0			0			0			0			0			0		
07/13/20 6:42	0			0			0			0			0			0		
07/13/20 6:43	0			0			0			0			0			0		
07/13/20 6:44	0			0.1			0			0			0			1		
07/13/20 6:45	22026.6			0.1			0			0			0			1		
07/13/20 6:46	38122.9			40.5			20.23			4.92			4.05			1		
07/13/20 6:47	52370.9			551.2			16.46			85.13			4.18			1		
07/13/20 6:48	73088.2			369.5			21.35			74.84			7.12			1		
07/13/20 6:49	118758.6			203.2			24.63			62.62			12.49			1		
07/13/20 6:50	139167.9			87.4			40.64			31.09			23.79			1		
07/13/20 6:51	150104.1			276			47.92			105.23			30.06			1		
07/13/20 6:52	169358.1			1808			36.96			770.17			25.91			1		
07/13/20 6:53	191153.6			986.5			45.65			469.93			35.79			1		
07/13/20 6:54	216491.9			142.1			53.77			76.01			47.32			1		
07/13/20 6:55	237825.3			8.3			58.76			4.83			56.55			1		
07/13/20 6:56	263548.7			1.9			58.05			1.22			61.53			1		
07/13/20 6:57	287269.6			1.6			47.97			1.15			55.18			1		
07/13/20 6:58	308217.9			1.7			24.67			1.27			30.34			1		
07/13/20 6:59	317228.8			1.7			15.7			1.33			19.86			1		
07/13/20 7:00	317536.8			1.7			14.88			1.31			18.82			1		
07/13/20 7:01	317690.9			1.7			12.74			1.31			16.12			1		
07/13/20 7:02	316920.7			1.6			11.03			1.25			13.92			1		
07/13/20 7:03	316073.6			1.5			9.32			1.18			11.73			1		
07/13/20 7:04	319385.3			1.5			8.21			1.12			10.44			1		
07/13/20 7:05	327163.8			1.3			7.29			1.03			9.49			1		
07/13/20 7:06	330321.5			1.2			6.25			0.97			8.21			1		
07/13/20 7:07	339178.3			1.1			5.81			0.92			7.83			1		
07/13/20 7:08	340795.7			1.1			5.28			0.94			7.16			1		
07/13/20 7:09	341257.8			1.1			5.28			0.87			7.16			1		
07/13/20 7:10	341565.8			1			5.2			0.8			7.05			1		
07/13/20 7:11	341565.8			1			5.2			0.8			7.05			1		
07/13/20 7:12	341026.7			1			5.2			0.8			7.04			1		
07/13/20 7:13	339871.5			1			5.2			0.79			7.02			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 7:14	339871.5			0.9			5.2			0.72			7.01			1		
07/13/20 7:15	339332.4			0.9			5.28			0.72			7.13			1		
07/13/20 7:16	339255.3			0.9			5.28			0.72			7.12			1		
07/13/20 7:17	338947.3			0.9			5.37			0.72			7.24			1		
07/13/20 7:18	339178.3			0.9			5.46			0.72			7.36			1		
07/13/20 7:19	338716.3			0.9			5.46			0.72			7.35			1		
07/13/20 7:20	338331.2			0.8			5.46			0.65			7.34			1		
07/13/20 7:21	336482.8			0.8			5.64			0.64			7.54			1		
07/13/20 7:22	320540.5			0.8			5.9			0.62			7.54			1		
07/13/20 7:23	308449			0.9			6.43			0.66			7.92			1		
07/13/20 7:24	305599.4			0.9			6.52			0.65			7.95			1		
07/13/20 7:25	304752.2			0.9			6.69			0.65			8.15			1		
07/13/20 7:26	305137.3			0.8			6.79			0.6			8.28			1		
07/13/20 7:27	316227.6			0.8			6.79			0.62			8.57			1		
07/13/20 7:28	317690.9			0.8			7.22			0.61			9.15			1		
07/13/20 7:29	317921.9			0.8			6.87			0.61			8.71			1		
07/13/20 7:30	317998.9			0.8			6.87			0.61			8.71			1		
07/13/20 7:31	317998.9			0.8			6.96			0.61			8.83			1		
07/13/20 7:32	318538.1			0.8			7.13			0.61			9.07			1		
07/13/20 7:33	318076			0.8			7.22			0.61			9.17			1		
07/13/20 7:34	318538.1			0.8			5.81			0.61			7.39			1		
07/13/20 7:35	317921.9			0.8			3.26			0.61			4.13			1		
07/13/20 7:36	317844.9			0.8			2.64			0.61			3.35			1		
07/13/20 7:37	317921.9			0.8			2.64			0.61			3.35			1		
07/13/20 7:38	317459.8			0.8			2.82			0.61			3.57			1		
07/13/20 7:39	317767.9			0.8			2.99			0.61			3.8			1		
07/13/20 7:40	317382.8			0.8			3.17			0.61			4.01			1		
07/13/20 7:41	317459.8			0.8			3.17			0.61			4.02			1		
07/13/20 7:42	317459.8			0.8			2.73			0.61			3.46			1		
07/13/20 7:43	316997.8			0.8			2.38			0.61			3.01			1		
07/13/20 7:44	316535.7			0.8			2.29			0.61			2.89			1		
07/13/20 7:45	305522.4			0.8			2.2			0.59			2.69			1		
07/13/20 7:46	303828			0.8			2.03			0.59			2.46			1		
07/13/20 7:47	303828			0.8			1.97			0.59			2.39			1		
07/13/20 7:48	303597			0.7			1.88			0.53			2.28			1		
07/13/20 7:49	303519.9			0.7			1.79			0.53			2.17			0		
07/13/20 7:50	303057.8			0.7			1.79			0.53			2.17			0		
07/13/20 7:51	303211.9			0.7			1.7			0.53			2.06			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 7:52	303442.9			0.7			1.61			0.53			1.95			0		
07/13/20 7:53	308680			0.7			1.61			0.54			1.99			0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 4:49	382307.3			0.7			1.75			0.65			2.55			0		
07/21/20 4:50	367520.2			0.7			1.72			0.62			2.41			0		
07/21/20 4:51	345647.7			0.7			1.82			0.58			2.39			0		
07/21/20 4:52	322234.8			0.8			1.94			0.59			2.38			0		
07/21/20 4:53	300054.2			0.8			1.94			0.55			2.21			0		
07/21/20 4:54	285344.2			0.9			1.85			0.58			2.01			1		
07/21/20 4:55	264703.9			0.8			1.82			0.5			1.83			1		
07/21/20 4:56	241368.1			0.7			3.87			0.41			3.56			1		
07/21/20 4:57	220958.8			0.7			7.71			0.34			6.49			1		
07/21/20 4:58	194696.4			0.5			12.52			0.23			9.29			1		
07/21/20 4:59	172053.7			2.3			14.64			0.9			9.59			1		
07/21/20 5:00	150797.3			125.6			16.52			43.83			9.49			1		
07/21/20 5:01	131851.3			925.4			16.52			282.35			8.3			1		
07/21/20 5:02	21487.5			1816.5			17.87			90.27			1.46			1		
07/21/20 5:03	0			0			20.06			0			0			0		
07/21/20 5:04	0			0			0.1			0			0			0		
07/21/20 5:05	0			0			0.1			0			0			0		
07/21/20 5:06	0			0			0.1			0			0			0		
07/21/20 5:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 1:38	0			0	X		59	X		0	X		0	X		0		
07/26/20 1:39	0			0	X		53.1	X		0	X		0	X		0		
07/26/20 1:40	0			0	X		35.4	X		0	X		0	X		0		
07/26/20 1:41	0			0			0.5			0			0			0		
07/26/20 1:42	0			0			0.4			0			0			0		
07/26/20 1:43	0			0.4			0.3			0			0			1		
07/26/20 1:44	3927.8			0.4			0.2			0			0			1		
07/26/20 1:45	27648.7			41.3			26.55			2.64			2.8			1		
07/26/20 1:46	43514			553.1			16.96			55.72			2.81			1		
07/26/20 1:47	58070			457.5			19.18			61.45			4.24			1		
07/26/20 1:48	91726			263.6			24.14			55.94			8.43			1		
07/26/20 1:49	134161.8			130.7			21.24			40.59			10.85			1		
07/26/20 1:50	140092			49.5			46.82			16.05			24.99			1		
07/26/20 1:51	156650.5			1012.2			42.69			367.05			25.48			1		
07/26/20 1:52	178060.9			1655.2			45.68			682.11			30.98			1		
07/26/20 1:53	201242.7			488.4			57.56			227.51			44.13			1		
07/26/20 1:54	225656.8			55.2			65.54			28.8			56.33			1		
07/26/20 1:55	247221.3			3.3			63.99			1.88			60.26			1		
07/26/20 1:56	273560.7			1.8			54.02			1.16			56.29			1		
07/26/20 1:57	296126.4			1.8			37.24			1.2			42.01			1		
07/26/20 1:58	316381.6			1.8			19.61			1.33			23.63			1		
07/26/20 1:59	335327.5			1.9			14.45			1.46			18.46			1		
07/26/20 2:00	346032.8			1.9			12.67			1.53			16.7			1		
07/26/20 2:01	347881.2			1.8			9.77			1.42			12.95			1		
07/26/20 2:02	348112.2			1.6			8.89			1.28			11.79			1		
07/26/20 2:03	356121.8			1.4			7.66			1.16			10.39			1		
07/26/20 2:04	360588.8			1.3			6.7			1.12			9.21			1		
07/26/20 2:05	361513			1.3			6.35			1.05			8.74			1		
07/26/20 2:06	363669.4			1.1			6.17			0.9			8.54			1		
07/26/20 2:07	362591.2			1.1			6.08			0.91			8.4			1		
07/26/20 2:08	360973.9			1			5.99			0.83			8.24			1		
07/26/20 2:09	359510.6			1			5.81			0.83			7.95			1		
07/26/20 2:10	358971.4			1			5.72			0.83			7.82			1		
07/26/20 2:11	358894.4			0.9			5.72			0.75			7.82			1		
07/26/20 2:12	358817.4			0.9			5.72			0.75			7.82			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 2:13	359356.5			0.9			5.72			0.76			7.83			1		
07/26/20 2:14	357970.3			0.9			5.72			0.75			7.8			1		
07/26/20 2:15	358201.3			0.8			5.72			0.68			7.8			1		
07/26/20 2:16	357277.1			0.8			5.72			0.68			7.78			1		
07/26/20 2:17	357508.2			0.8			5.63			0.68			7.66			1		
07/26/20 2:18	357277.1			0.8			5.63			0.68			7.66			1		
07/26/20 2:19	357277.1			0.8			5.72			0.68			7.78			1		
07/26/20 2:20	356815			0.8			5.81			0.67			7.9			1		
07/26/20 2:21	357046.1			0.8			5.99			0.68			8.15			1		
07/26/20 2:22	361513			0.8			6.08			0.68			8.37			1		
07/26/20 2:23	363130.3			0.8			6.08			0.7			8.42			1		
07/26/20 2:24	363977.5			0.7			4.08			0.61			5.66			1		
07/26/20 2:25	363592.4			0.7			2.72			0.61			3.77			1		
07/26/20 2:26	349575.5			0.7			2.63			0.59			3.51			1		
07/26/20 2:27	339255.3			0.8			2.68			0.63			3.47			1		
07/26/20 2:28	339871.5			0.8			2.73			0.62			3.53			1		
07/26/20 2:29	340718.7			0.8			2.77			0.63			3.6			1		
07/26/20 2:30	341488.8			0.8			2.68			0.64			3.49			1		
07/26/20 2:31	341565.8			0.8			2.59			0.64			3.37			1		
07/26/20 2:32	341565.8			0.8			2.5			0.64			3.26			1		
07/26/20 2:33	341334.8			0.8			2.41			0.64			3.14			1		
07/26/20 2:34	341334.8			0.8			2.23			0.64			2.91			1		
07/26/20 2:35	341334.8			0.8			2.15			0.64			2.79			1		
07/26/20 2:36	337715			0.8			2.06			0.63			2.65			1		
07/26/20 2:37	332555			0.8			1.97			0.62			2.49			1		
07/26/20 2:38	328627.2			0.8			1.85			0.6			2.31			1		
07/26/20 2:39	328396.1			0.8			1.85			0.6			2.31			0		
07/26/20 2:40	327703			0.8			1.79			0.61			2.23			0		
07/26/20 2:41	327548.9			0.8			1.79			0.61			2.23			0		
07/26/20 2:42	327703			0.8			1.7			0.61			2.12			0		
07/26/20 2:43	323621.1			0.8			1.7			0.6			2.09			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 22:52	339409.4			0.8			1.7			0.63			2.19			0		
08/05/20 22:53	324391.3			0.8			1.7			0.6			2.1			0		
08/05/20 22:54	301517.5			0.8			1.7			0.56			1.95			0		
08/05/20 22:55	287885.7			0.8			1.76			0.53			1.93			0		
08/05/20 22:56	286268.4			0.8			1.72			0.54			1.88			0		
08/05/20 22:57	286345.4			0.7			1.72			0.48			1.88			1		
08/05/20 22:58	274330.9			0.7			1.63			0.46			1.71			1		
08/05/20 22:59	252227.3			0.6			2.49			0.38			2.39			1		
08/05/20 23:00	230893.9			0.7			6.09			0.35			5.35			1		
08/05/20 23:01	207866.1			0.6			9.4			0.29			7.43			1		
08/05/20 23:02	181988.8			0.5			13.88			0.23			9.61			1		
08/05/20 23:03	159654.1			7.5			15.86			2.77			9.63			1		
08/05/20 23:04	141709.4			443.1			16.72			145.2			9.02			1		
08/05/20 23:05	92188.1			1519.5			17.38			323.81			6.1			1		
08/05/20 23:06	0			0			18.75			0			0			0		
08/05/20 23:07	0			0			23.6			0			0			0		
08/05/20 23:08	0			0			0.1			0			0			0		
08/05/20 23:09	0			0			0.1			0			0			0		
08/05/20 23:10	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 22:39	0			0			0			0			0			0		
08/08/20 22:40	0			0			0			0			0			0		
08/08/20 22:41	0			0			0			0			0			0		
08/08/20 22:42	0			0			0			0			0			0		
08/08/20 22:43	0			0			0			0			0			0		
08/08/20 22:44	2541.5			0.2			0			0			0			1		
08/08/20 22:45	24568.1			0.4			0			0			0			1		
08/08/20 22:46	39740.2			45.5			21.91			4.19			3.32			1		
08/08/20 22:47	53064			533.2			15.53			65.4			3.13			1		
08/08/20 22:48	73242.2			340.2			20.51			57.65			5.72			1		
08/08/20 22:49	118373.5			177.5			23.86			48.6			10.75			1		
08/08/20 22:50	139013.8			69.7			38.14			22.42			20.18			1		
08/08/20 22:51	149411			259.8			47.2			89.72			26.83			1		
08/08/20 22:52	168665			1781.8			44.42			694.8			28.51			1		
08/08/20 22:53	190922.6			925.1			57.29			408.34			41.62			1		
08/08/20 22:54	216337.9			123.1			64.5			61.58			53.11			1		
08/08/20 22:55	236901.1			6.7			61.6			3.68			55.53			1		
08/08/20 22:56	263471.7			1.8			55.73			1.09			55.89			1		
08/08/20 22:57	286499.4			1.6			41.97			1.07			45.76			1		
08/08/20 22:58	306677.6			1.7			25.01			1.19			29.19			1		
08/08/20 22:59	327240.9			1.8			14.14			1.38			17.61			1		
08/08/20 23:00	342721.1			1.8			13.1			1.44			17.09			1		
08/08/20 23:01	347419.1			1.7			9.77			1.34			12.92			1		
08/08/20 23:02	348266.2			1.6			8.76			1.3			11.61			1		
08/08/20 23:03	355274.7			1.4			7.51			1.18			10.15			1		
08/08/20 23:04	358355.3			1.3			6.53			1.04			8.9			1		
08/08/20 23:05	358586.4			1.2			6.26			0.96			8.54			1		
08/08/20 23:06	358355.3			1.1			6.17			0.9			8.42			1		
08/08/20 23:07	357970.3			1.1			5.63			0.9			7.67			1		
08/08/20 23:08	357662.2			1			5.45			0.83			7.41			1		
08/08/20 23:09	356738			1			5.45			0.82			7.39			1		
08/08/20 23:10	356275.9			1			5.36			0.82			7.26			1		
08/08/20 23:11	355967.8			0.9			5.26			0.75			7.13			1		
08/08/20 23:12	355505.7			0.9			5.26			0.75			7.12			1		
08/08/20 23:13	355197.7			0.9			5.26			0.75			7.12			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 23:14	354658.6			0.9			5.26			0.74			7.11			1		
08/08/20 23:15	353965.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:16	353965.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:17	354042.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:18	353426.3			0.8			5.36			0.67			7.2			1		
08/08/20 23:19	353888.4			0.8			5.45			0.67			7.34			1		
08/08/20 23:20	353041.2			0.8			5.54			0.67			7.44			1		
08/08/20 23:21	346725.9			0.8			5.72			0.67			7.54			1		
08/08/20 23:22	326547.7			0.8			6.08			0.62			7.56			1		
08/08/20 23:23	314918.3			0.8			6.26			0.59			7.5			1		
08/08/20 23:24	317305.8			0.9			4.47			0.66			5.4			1		
08/08/20 23:25	324391.3			0.9			2.86			0.67			3.53			1		
08/08/20 23:26	318692.1			0.9			2.68			0.66			3.25			1		
08/08/20 23:27	308217.9			0.9			2.68			0.64			3.15			1		
08/08/20 23:28	307447.8			0.9			2.68			0.64			3.14			1		
08/08/20 23:29	307216.7			0.9			2.77			0.64			3.24			1		
08/08/20 23:30	304752.2			0.9			2.77			0.63			3.21			1		
08/08/20 23:31	303519.9			0.9			2.77			0.63			3.2			1		
08/08/20 23:32	303828			0.8			2.59			0.57			3			1		
08/08/20 23:33	303288.9			0.8			2.41			0.56			2.79			1		
08/08/20 23:34	303828			0.8			2.23			0.57			2.58			1		
08/08/20 23:35	304521.2			0.8			2.09			0.58			2.42			1		
08/08/20 23:36	304598.2			0.8			1.88			0.57			2.18			1		
08/08/20 23:37	304675.2			0.8			1.79			0.57			2.07			1		
08/08/20 23:38	304598.2			0.8			1.7			0.57			1.97			1		
08/08/20 23:39	304752.2			0.8			1.7			0.57			1.97			0		
08/08/20 23:40	304675.2			0.8			1.61			0.57			1.87			0		
08/08/20 23:41	304136.1			0.8			1.61			0.57			1.86			0		
08/08/20 23:42	304059.1			0.8			1.61			0.57			1.86			0		
08/08/20 23:43	304829.2			0.8			1.63			0.58			1.9			0		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/23/20 22:49	320848.5			0.7			1.61			0.53			1.98			0		
09/23/20 22:50	310297.3			0.7			1.67			0.51			1.99			0		
09/23/20 22:51	306061.5			0.8			1.76			0.56			2.07			0		
09/23/20 22:52	295433.3			0.8			1.79			0.55			2.02			0		
09/23/20 22:53	289426			0.7			1.79			0.48			1.98			0		
09/23/20 22:54	288116.8			0.7			1.82			0.49			2			1		
09/23/20 22:55	276641.4			0.6			1.63			0.41			1.73			1		
09/23/20 22:56	254306.7			0.6			2.21			0.38			2.16			1		
09/23/20 22:57	232742.3			0.6			5.24			0.3			4.68			1		
09/23/20 22:58	210099.6			0.5			8.46			0.24			6.81			1		
09/23/20 22:59	185146.4			0.4			12.96			0.18			9.19			1		
09/23/20 23:00	161656.5			4.1			15.05			1.54			9.32			1		
09/23/20 23:01	142402.5			317.1			16.05			105.12			8.76			1		
09/23/20 23:02	69545.4			1383.6			16.3			223.91			4.34			1		
09/23/20 23:03	0			0			17.7			0			0			0		
09/23/20 23:04	0			0			11.8			0			0			0		
09/23/20 23:05	0			0			0.1			0			0			0		
09/23/20 23:06	0			0			0.1			0			0			0		
09/23/20 23:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 7

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/28/20 4:39	0			0			0			0			0			0		
09/28/20 4:40	0			0			0			0			0			0		
09/28/20 4:41	0			0			0			0			0			0		
09/28/20 4:42	0			0			0			0			0			0		
09/28/20 4:43	0			0			0			0			0			0		
09/28/20 4:44	0			0.1			0			0			0			1		
09/28/20 4:45	0			0.1			0			0			0			1		
09/28/20 4:46	10166.1			10.3			20.65			0.24			0.81			1		
09/28/20 4:47	36659.6			571.6			14.75			48.75			2.07			1		
09/28/20 4:48	55451.5			421.3			19.47			54.41			4.14			1		
09/28/20 4:49	97579.2			230.9			24.14			52.46			9.03			1		
09/28/20 4:50	136318.3			102.3			34.04			32.48			17.78			1		
09/28/20 4:51	141940.4			41.5			50.33			13.71			27.37			1		
09/28/20 4:52	160424.3			1356			41.99			506.28			25.8			1		
09/28/20 4:53	182758.9			1407.2			51.03			598.82			35.74			1		
09/28/20 4:54	206710.9			349			66.34			167.95			52.54			1		
09/28/20 4:55	230277.8			31			68.79			16.62			60.7			1		
09/28/20 4:56	252381.3			2.2			61.84			1.28			59.8			1		
09/28/20 4:57	279028.9			1.6			55.5			1.04			59.33			1		
09/28/20 4:58	301748.6			1.5			38.4			1.08			44.39			1		
09/28/20 4:59	314918.3			1.7			19.15			1.25			23.11			1		
09/28/20 5:00	315919.5			1.8			14.54			1.32			17.6			1		
09/28/20 5:01	315457.4			1.7			13.08			1.26			15.81			1		
09/28/20 5:02	315688.5			1.6			11.63			1.21			14.06			1		
09/28/20 5:03	316997.8			1.6			9.89			1.15			12.01			1		
09/28/20 5:04	326008.6			1.5			8.94			1.12			11.16			1		
09/28/20 5:05	326701.8			1.4			7.75			1.07			9.7			1		
09/28/20 5:06	326855.8			1.3			7.13			1.01			8.93			1		
09/28/20 5:07	326855.8			1.2			7.04			0.94			8.82			1		
09/28/20 5:08	326239.7			1.1			6.87			0.87			8.59			1		
09/28/20 5:09	325084.4			1.1			6.69			0.87			8.34			1		
09/28/20 5:10	324391.3			1.1			6.52			0.8			8.1			1		
09/28/20 5:11	324237.3			1.1			6.44			0.81			8			1		
09/28/20 5:12	333017.1			1			6.26			0.76			7.98			1		
09/28/20 5:13	336328.8			1			5.9			0.77			7.6			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/28/20 5:14	337175.9			0.9			6.08			0.71			7.86			1		
09/28/20 5:15	337561			0.9			6.08			0.7			7.86			1		
09/28/20 5:16	336790.8			0.9			6.17			0.7			7.96			1		
09/28/20 5:17	336790.8			0.9			6.26			0.7			8.08			1		
09/28/20 5:18	338408.2			0.9			6.35			0.72			8.24			1		
09/28/20 5:19	338562.2			0.8			6.26			0.64			8.12			1		
09/28/20 5:20	338639.2			1.2	X		6.35	X		0.95	X		8.24	X		1		
09/28/20 5:21	338562.2			3	X		6.53	X		2.33	X		8.47	X		1		
09/28/20 5:22	337869.1			0.9	X		6.82	X		0.73	X		8.83	X		1		
09/28/20 5:23	321926.8			0.8	X		6.99	X		0.61	X		8.62	X		1		
09/28/20 5:24	309142.1			0.8	X		7.51	X		0.58	X		8.89	X		1		
09/28/20 5:25	308217.9			0.8	X		7.33	X		0.58	X		8.65	X		1		
09/28/20 5:26	307832.8			0.8			4.56			0.58			5.38			1		
09/28/20 5:27	307755.8			0.8			3.4			0.58			4.01			1		
09/28/20 5:28	308217.9			0.8			3.31			0.58			3.91			1		
09/28/20 5:29	308294.9			0.8			3.22			0.58			3.8			1		
09/28/20 5:30	303905			0.8			3.04			0.57			3.54			1		
09/28/20 5:31	288655.9			0.8			2.95			0.54			3.26			1		
09/28/20 5:32	286576.4			0.8			2.27			0.54			2.49			1		
09/28/20 5:33	286653.4			0.7			2.12			0.49			2.33			1		
09/28/20 5:34	288501.8			0.6			2.12			0.43			2.34			1		
09/28/20 5:35	291120.4			0.6			2.12			0.44			2.37			1		
09/28/20 5:36	290966.3			0.6			2.09			0.43			2.33			0		
09/28/20 5:37	290812.3			0.6			2			0.43			2.22			0		
09/28/20 5:38	290658.3			0.7			1.91			0.49			2.12			0		
09/28/20 5:39	290735.3			0.7			1.82			0.49			2.02			0		
09/28/20 5:40	290658.3			0.7			1.72			0.49			1.92			0		

CT2 SUSD EVENT 1

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 3:39	0			0			0			0			0			0		
07/13/20 3:40	0			0			0			0			0			0		
07/13/20 3:41	0			0			0			0			0			0		
07/13/20 3:42	0			0			0			0			0			0		
07/13/20 3:43	0			0			0			0			0			0		
07/13/20 3:44	15403.2			0			0			0			0			1		
07/13/20 3:45	32731.8			41.3			17.7			3.12			2.2			1		
07/13/20 3:46	42897.9			480.4			17.28			47.75			2.83			1		
07/13/20 3:47	53449.1			457.7			16.86			56.65			3.43			1		
07/13/20 3:48	72164			306.3			21.99			51.14			6.04			1		
07/13/20 3:49	115061.9			181.4			23.85			48.33			10.45			1		
07/13/20 3:50	133699.7			74.9			40.49			23.16			20.61			1		
07/13/20 3:51	142787.6			333			42.69			110.02			23.21			1		
07/13/20 3:52	160270.2			1562.8			33.04			579.67			20.17			1		
07/13/20 3:53	181526.6			822.2			41.75			345.46			28.87			1		
07/13/20 3:54	203861.3			131.7			51.36			62.13			39.88			1		
07/13/20 3:55	225502.8			7			56.17			3.63			48.25			1		
07/13/20 3:56	246143			1.7			60.9			0.96			57.09			1		
07/13/20 3:57	270249			1.5			52.04			0.97			53.56			1		
07/13/20 3:58	280954.3			1.6			31.88			1.03			34.12			1		
07/13/20 3:59	281339.3			1.7			19.18			1.13			20.55			1		
07/13/20 4:00	279028.9			1.7			17.79			1.12			18.9			1		
07/13/20 4:01	281878.5			1.7			16.47			1.09			17.68			1		
07/13/20 4:02	294817.2			1.5			15.5			1.02			17.4			1		
07/13/20 4:03	301286.5			1.4			14.88			0.98			17.08			1		
07/13/20 4:04	312453.8			1.4			13.71			1			16.32			1		
07/13/20 4:05	319000.2			1.4			11.01			1.04			13.37			1		
07/13/20 4:06	335866.7			1.3			10.21			1.03			13.07			1		
07/13/20 4:07	351038.8			1.2			9.21			0.94			12.31			1		
07/13/20 4:08	367982.3			1.1			9.17			0.93			12.85			1		
07/13/20 4:09	389238.7			1			9.22	X		0.91			13.67	X		1		
07/13/20 4:10	395014.9			0.9			9.77			0.84			14.7			1		
07/13/20 4:11	393397.6			0.8			10.42			0.76			15.61			1		
07/13/20 4:12	393320.6			0.8			10.33			0.76			15.47			1		
07/13/20 4:13	393243.6			0.8			10.23			0.76			15.33			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 4:14	392242.3			0.8			10.42			0.75			15.57			1		
07/13/20 4:15	393243.6			0.8			10.51			0.76			15.74			1		
07/13/20 4:16	393397.6			0.8			10.51			0.76			15.75			1		
07/13/20 4:17	392165.3			0.8			10.79			0.75			16.11			1		
07/13/20 4:18	392088.3			0.8			11.15			0.75			16.66			1		
07/13/20 4:19	393166.5			0.7			11.34			0.67			16.98			1		
07/13/20 4:20	392781.5			0.7			11.43			0.67			17.1			1		
07/13/20 4:21	393166.5			0.7			11.62			0.67			17.39			1		
07/13/20 4:22	393243.6			0.7			11.8			0.67			17.68			1		
07/13/20 4:23	392319.4			0.7			10.42			0.67			15.57			1		
07/13/20 4:24	393089.5			0.7			6.91			0.67			10.35			1		
07/13/20 4:25	393320.6			0.7			6.18			0.67			9.25			1		
07/13/20 4:26	392935.5			0.7			5.9			0.67			8.83			1		
07/13/20 4:27	394629.8			0.7			5.72			0.67			8.59			1		
07/13/20 4:28	393320.6			0.7			5.44			0.67			8.15			1		
07/13/20 4:29	392242.3			0.7			5.16			0.67			7.71			1		
07/13/20 4:30	392473.4			0.7			4.52			0.67			6.75			1		
07/13/20 4:31	390933.1			0.7			3.69			0.67			5.49			1		
07/13/20 4:32	392704.4			0.7			2.86			0.67			4.28			1		
07/13/20 4:33	391857.3			0.7			2.58			0.67			3.85			1		
07/13/20 4:34	391241.1			0.7			2.3			0.67			3.43			1		
07/13/20 4:35	393243.6			0.7			2.03			0.67			3.04			1		
07/13/20 4:36	391780.3			0.7			1.75			0.67			2.61			1		
07/13/20 4:37	393089.5			0.7			1.57			0.67			2.35			1		
07/13/20 4:38	393628.6			0.7			1.48			0.67			2.21			1		
07/13/20 4:39	392242.3			0.7			1.38			0.67			2.07			0		
07/13/20 4:40	391780.3			0.7			1.29			0.67			1.93			0		
07/13/20 4:41	393166.5			0.7			1.2			0.67			1.79			0		
07/13/20 4:42	393397.6			0.7			1.2			0.67			1.8			0		
07/13/20 4:43	393243.6			0.7			1.2			0.67			1.8			0		

CT2 SUSD EVENT 2

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 4:54	363361.3			0.7			1.72			0.61			2.39			0		
07/21/20 4:55	360973.9			0.7			1.63			0.61			2.25			0		
07/21/20 4:56	346109.8			0.7			1.72			0.58			2.27			0		
07/21/20 4:57	324237.3			0.7			1.7			0.54			2.1			0		
07/21/20 4:58	299746.2			0.8			1.59			0.55			1.81			0		
07/21/20 4:59	279568			0.8			1.56			0.51			1.66			1		
07/21/20 5:00	259851.9			0.8			1.61			0.48			1.59			1		
07/21/20 5:01	239211.6			0.8			1.91			0.45			1.74			1		
07/21/20 5:02	222730.2			0.7			4.78			0.34			4.05			1		
07/21/20 5:03	200010.5			0.5			8.8			0.23			6.7			1		
07/21/20 5:04	175981.5			0.3			15.73			0.13			10.55			1		
07/21/20 5:05	154494			5.3			17.46			1.89			10.27			1		
07/21/20 5:06	138089.6			490			19.95			156.62			10.49			1		
07/21/20 5:07	111288.1			1493.2			21.69			384.71			9.2			1		
07/21/20 5:08	0			2023.7			24.78			0			0			1		
07/21/20 5:09	0			0			11.8			0			0			0		
07/21/20 5:10	0			0			5.9			0			0			0		
07/21/20 5:11	0			0			5.9			0			0			0		
07/21/20 5:12	0			0			5.9			0			0			0		
07/21/20 5:13	0			0			0			0			0			0		

CT2 SUSD EVENT 3

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/25/20 22:38	0			0			0			0			0			0		
07/25/20 22:39	0			0			0			0			0			0		
07/25/20 22:40	0			0			0			0			0			0		
07/25/20 22:41	0			0			0			0			0			0		
07/25/20 22:42	0			0			0			0			0			0		
07/25/20 22:43	1925.4			0			0			0			0			1		
07/25/20 22:44	17636.7			0			0			0			0			1		
07/25/20 22:45	33887			29.5			14.75			2.31			1.9			1		
07/25/20 22:46	45208.4			456.9			16.23			47.76			2.79			1		
07/25/20 22:47	54912.4			415.2			17.7			52.8			3.7			1		
07/25/20 22:48	77093			239.3			22.57			42.7			6.63			1		
07/25/20 22:49	119528.8			133.1			20.77			36.83			9.46			1		
07/25/20 22:50	130773.1			50			44.05			15.12			21.94			1		
07/25/20 22:51	139784			482.8			43.49			156.16			23.15			1		
07/25/20 22:52	157266.6			1675.8			41.3			609.94			24.74			1		
07/25/20 22:53	178677.1			851			52.63			352.03			35.83			1		
07/25/20 22:54	201550.8			129.9			59.54			60.61			45.71			1		
07/25/20 22:55	223038.3			6.1			61.24			3.17			52.03			1		
07/25/20 22:56	244525.7			1.7			62.58			0.95			58.28			1		
07/25/20 22:57	268862.8			1.5			50.63			0.95			51.85			1		
07/25/20 22:58	289272			1.6			30.73			1.06			33.86			1		
07/25/20 22:59	298590.9			1.7			18.74			1.2			21.31			1		
07/25/20 23:00	308603			1.7			17.7			1.24			20.81			1		
07/25/20 23:01	322619.9			1.6			14.92			1.23			18.34			1		
07/25/20 23:02	327780			1.6			11.8			1.2			14.73			1		
07/25/20 23:03	328858.2			1.4			11.26			1.09			14.11			1		
07/25/20 23:04	328704.2			1.3			10.28			0.95			12.87			1		
07/25/20 23:05	327625.9			1.3			9.65			0.95			12.05			1		
07/25/20 23:06	327703			1.2			9.21			0.88			11.49			1		
07/25/20 23:07	326470.7			1.2			9.21	X		0.88			11.45	X		1		
07/25/20 23:08	333633.2			1.1			9.03	X		0.83			11.48	X		1		
07/25/20 23:09	348959.4			1			8.76			0.79			11.64			1		
07/25/20 23:10	370138.8			0.9			8.67			0.79			12.22			1		
07/25/20 23:11	385850			0.9			8.71			0.84			12.8			1		
07/25/20 23:12	381383.1			0.8			9.83			0.74			14.28			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/25/20 23:13	381383.1			0.8			9.5			0.73			13.79			1		
07/25/20 23:14	383385.5			0.8			9.55			0.75			13.95			1		
07/25/20 23:15	382846.4			0.8			9.65			0.75			14.07			1		
07/25/20 23:16	383000.4			0.8			9.68			0.74			14.12			1		
07/25/20 23:17	384617.8			0.8			9.77			0.74			14.32			1		
07/25/20 23:18	384309.7			0.7			10.11			0.67			14.81			1		
07/25/20 23:19	382538.3			0.7			10.3			0.66			15.01			1		
07/25/20 23:20	383077.4			0.7			10.58			0.66			15.44			1		
07/25/20 23:21	384540.8			0.7			10.77			0.67			15.78			1		
07/25/20 23:22	384232.7			0.7			10.3			0.67			15.08			1		
07/25/20 23:23	384001.6			0.7			4.79			0.66			7.01			1		
07/25/20 23:24	385156.9			0.7			3.47			0.67			5.08			1		
07/25/20 23:25	384078.7			0.7			3.28			0.67			4.8			1		
07/25/20 23:26	384463.7			0.7			3.04			0.66			4.45			1		
07/25/20 23:27	383924.6			0.7			2.95			0.66			4.31			1		
07/25/20 23:28	383231.5			0.8			2.72			0.75			3.97			1		
07/25/20 23:29	385464.9			0.7			2.4			0.66			3.52			1		
07/25/20 23:30	384925.8			0.7			2.21			0.66			3.24			1		
07/25/20 23:31	385619			0.7			1.94			0.66			2.84			1		
07/25/20 23:32	384771.8			0.7			1.75			0.66			2.57			1		
07/25/20 23:33	385773			0.7			1.57			0.66			2.3			1		
07/25/20 23:34	386158.1			0.7			1.48			0.66			2.17			0		
07/25/20 23:35	385079.9			0.7			1.38			0.66			2.03			0		
07/25/20 23:36	385233.9			0.7			1.29			0.66			1.89			0		
07/25/20 23:37	385156.9			0.7			1.29			0.66			1.89			0		
07/25/20 23:38	385002.8			0.7			1.29			0.66			1.89			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 21:50	311067.5			0.9			1.7			0.64			2.01			0		
08/05/20 21:51	293970			0.8			1.7			0.55			1.9			0		
08/05/20 21:52	275332.1			0.9			1.76			0.56			1.85			0		
08/05/20 21:53	270711.2			0.8			1.79			0.5			1.84			0		
08/05/20 21:54	270942.2			0.7			1.82			0.45			1.87			0		
08/05/20 21:55	263933.8			0.6			1.91			0.39			1.91			1		
08/05/20 21:56	245449.9			0.6			2.4			0.37			2.24			1		
08/05/20 21:57	226812			0.7			5.9			0.34			5.09			1		
08/05/20 21:58	206633.9			0.6			9.58			0.28			7.53			1		
08/05/20 21:59	181988.8			0.4			17.91			0.18			12.4			1		
08/05/20 22:00	159577.1			3.3			20.41			1.22			12.39			1		
08/05/20 22:01	141632.4			258.3			22.66			84.58			12.21			1		
08/05/20 22:02	125382			1194			24.84			346.11			11.85			1		
08/05/20 22:03	11244.3			1872.9			26.2			48.63			1.12			1		
08/05/20 22:04	0			0			24.91			0			0			0		
08/05/20 22:05	0			0			2.95			0			0			0		
08/05/20 22:06	0			0			5.9			0			0			0		
08/05/20 22:07	0			0			5.9			0			0			0		
08/05/20 22:08	0			0			5.9			0			0			0		

CT2 SUSD EVENT 5

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 7:39	0			0			0			0			0			0		
08/08/20 7:40	0			0			0			0			0			0		
08/08/20 7:41	0			0			0			0			0			0		
08/08/20 7:42	0			0			0			0			0			0		
08/08/20 7:43	0			0			0			0			0			0		
08/08/20 7:44	5853.2			0			0			0			0			1		
08/08/20 7:45	24106			0			0			0			0			1		
08/08/20 7:46	36351.5			18.9			21.24			1.58			2.93			1		
08/08/20 7:47	48212			495			13.87			55.18			2.54			1		
08/08/20 7:48	59225.3			390			18.54			53.42			4.18			1		
08/08/20 7:49	87952.2			225.2			22.57			45.83			7.56			1		
08/08/20 7:50	129078.8			125.3			20.77			37.39			10.2			1		
08/08/20 7:51	131235.2			43.3			45.54			13.15			22.75			1		
08/08/20 7:52	141632.4			893			43.56			292.44			23.48			1		
08/08/20 7:53	157189.6			1671.7			45.51			607.72			27.23			1		
08/08/20 7:54	178908.1			851.4			54.16			352.2			36.87			1		
08/08/20 7:55	200934.7			150.9			57.12			70.1			43.69			1		
08/08/20 7:56	223654.4			7.3			55.93			3.78			47.6			1		
08/08/20 7:57	244294.7			1.8			58.47			1.01			54.37			1		
08/08/20 7:58	269247.8			1.6			49.39			1.01			50.6			1		
08/08/20 7:59	289734.1			1.6			29.15			1.06			32.14			1		
08/08/20 8:00	309142.1			1.7			17.7			1.24			20.82			1		
08/08/20 8:01	324622.3			1.8			15.48			1.35			19.12			1		
08/08/20 8:02	343722.3			1.7			11.54			1.38			15.1			1		
08/08/20 8:03	361050.9			1.6			10.21			1.32			14.04			1		
08/08/20 8:04	384540.8			1.3			9.48			1.19			13.87			1		
08/08/20 8:05	403178.6			1.2			9.44			1.1			14.48			1		
08/08/20 8:06	398788.7			1.1			10.53			1			15.98			1		
08/08/20 8:07	399943.9			1			10.08			0.92			15.33			1		
08/08/20 8:08	398249.6			0.9			9.8			0.84			14.86			1		
08/08/20 8:09	397402.4			0.9			9.71			0.83			14.69			1		
08/08/20 8:10	398249.6			0.9			9.8			0.84			14.86			1		
08/08/20 8:11	398788.7			0.9			9.89			0.84			15.02			1		
08/08/20 8:12	398172.6			0.9			9.98			0.84			15.13			1		
08/08/20 8:13	397479.4			0.8			9.98			0.75			15.1			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 8:14	396016.1			0.8			10.08			0.75			15.18			1		
08/08/20 8:15	397094.3			0.8			10.17			0.75			15.36			1		
08/08/20 8:16	396709.3			0.8			10.23			0.76			15.45			1		
08/08/20 8:17	396247.2			0.7			10.33			0.68			15.57			1		
08/08/20 8:18	395400			0.7			10.51			0.67			15.81			1		
08/08/20 8:19	395631.1			0.7			10.69			0.67			16.1			1		
08/08/20 8:20	397017.3			0.7			10.97			0.68			16.57			1		
08/08/20 8:21	395939.1			0.8			10.33			0.76			15.56			1		
08/08/20 8:22	396478.2			0.8			4.89			0.76			7.37			1		
08/08/20 8:23	395862.1			0.7			3.32			0.68			5			1		
08/08/20 8:24	396555.3			0.7			3.13			0.68			4.73			1		
08/08/20 8:25	396093.2			0.7			2.95			0.68			4.45			1		
08/08/20 8:26	396786.3			0.7			2.86			0.68			4.32			1		
08/08/20 8:27	395323			0.7			2.77			0.67			4.16			1		
08/08/20 8:28	396401.2			0.7			2.58			0.68			3.89			1		
08/08/20 8:29	396093.2			0.7			2.21			0.68			3.34			1		
08/08/20 8:30	394629.8			0.7			2.03			0.67			3.05			1		
08/08/20 8:31	395477			0.7			1.84			0.67			2.77			1		
08/08/20 8:32	394783.9			0.7			1.66			0.67			2.49			1		
08/08/20 8:33	395400			0.7			1.54			0.66			2.32			1		
08/08/20 8:34	395323			0.7			1.48			0.67			2.22			0		
08/08/20 8:35	395477			0.7			1.38			0.67			2.08			0		
08/08/20 8:36	395400			0.7			1.29			0.67			1.94			0		
08/08/20 8:37	396478.2			0.7			1.29			0.68			1.95			0		
08/08/20 8:38	396247.2			0.7			1.29			0.68			1.95			0		

CT2 SUSD EVENT 6

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 22:49	271789.4			0.8			1.75			0.52			1.81			0		
08/30/20 22:50	270326.1			0.8			1.84			0.52			1.9			0		
08/30/20 22:51	270788.2			0.8			1.84			0.52			1.9			0		
08/30/20 22:52	270095			0.8			1.94			0.52			1.99			0		
08/30/20 22:53	270788.2			0.8			1.94			0.52			1.99			0		
08/30/20 22:54	267630.5			0.8			1.94			0.51			1.97			1		
08/30/20 22:55	253767.6			0.8			1.94			0.49			1.87			1		
08/30/20 22:56	232511.2			0.7			3.47			0.4			3.07			1		
08/30/20 22:57	216183.8			0.7			7.52			0.33			6.18			1		
08/30/20 22:58	192848			0.6			16.6			0.27			12.18			1		
08/30/20 22:59	168125.9			0.5			21.09			0.21			13.49			1		
08/30/20 23:00	147485.6			5.8			23.72			1.97			13.32			1		
08/30/20 23:01	130388			397.7			26.41			119.91			13.11			1		
08/30/20 23:02	69237.4			1392.6			26.79			222.88			7.06			1		
08/30/20 23:03	0			0			28.73			0			0			0		
08/30/20 23:04	0			0			5.9			0			0			0		
08/30/20 23:05	0			0			11.8			0			0			0		
08/30/20 23:06	0			0			5.9			0			0			0		
08/30/20 23:07	0			0			5.9			0			0			0		

CT2 SUSD EVENT 7

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 14:39	0			0			0			0			0			0		
08/31/20 14:40	0			0			0			0			0			0		
08/31/20 14:41	0			0			0			0			0			0		
08/31/20 14:42	0			0			0			0			0			0		
08/31/20 14:43	0			0			0			0			0			0		
08/31/20 14:44	8856.8			17.7			0			0.36			0			1		
08/31/20 14:45	23489.9			17.7			0			0.96			0			1		
08/31/20 14:46	36197.5			32.5			26.55			2.72			3.66			1		
08/31/20 14:47	46671.7			414.7			18.54			44.74			3.29			1		
08/31/20 14:48	57993			282.4			23.87			37.86			5.27			1		
08/31/20 14:49	85564.7			142.3			30.73			28.17			10.01			1		
08/31/20 14:50	126075.1			61.8			40.86			18.02			19.6			1		
08/31/20 14:51	130388			18.2			57.79			5.49			28.67			1		
08/31/20 14:52	141632.4			17.2			53.43			5.64			28.8			1		
08/31/20 14:53	159885.2			1063.9			51.82			393.43			31.54			1		
08/31/20 14:54	183067			302.8			55.69			128.16			38.8			1		
08/31/20 14:55	205632.6			20			57.49			9.49			44.99			1		
08/31/20 14:56	225502.8			1.9			59.78			0.99			51.29			1		
08/31/20 14:57	249839.8			1.3			60.1			0.75			57.15			1		
08/31/20 14:58	272944.6			1.4			37.67			0.86			39.12			1		
08/31/20 14:59	292506.7			1.6			17.07			1.09			19.01			1		
08/31/20 15:00	309604.2			1.7			15.67			1.2			18.47			1		
08/31/20 15:01	326624.8			1.7			12.15			1.26			15.1			1		
08/31/20 15:02	346109.8			1.5			9.98			1.23			13.15			1		
08/31/20 15:03	362514.2			1.4			9.8			1.14			13.52			1		
08/31/20 15:04	368521.4			1.1			9.5			0.94			13.32			1		
08/31/20 15:05	380767			1.1			9.5			0.97			13.76			1		
08/31/20 15:06	378995.6			1			10.44			0.88			15.06			1		
08/31/20 15:07	378841.6			1			10.44			0.87			15.05			1		
08/31/20 15:08	377224.2			1			10.33			0.88			14.82			1		
08/31/20 15:09	377455.3			1			10.42			0.89			14.96			1		
08/31/20 15:10	376839.2			0.9			10.42			0.8			14.94			1		
08/31/20 15:11	376993.2			0.9			10.51			0.8			15.08			1		
08/31/20 15:12	378225.4			0.9			10.51			0.81			15.13			1		
08/31/20 15:13	376608.1			0.9			10.69			0.8			15.32			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:14	377378.3			0.9			10.79			0.8			15.49			1		
08/31/20 15:15	379765.8			0.9			10.79			0.81			15.59			1		
08/31/20 15:16	377763.3			0.9			11.06			0.81			15.9			1		
08/31/20 15:17	376454.1			0.9			11.25			0.8			16.11			1		
08/31/20 15:18	377532.3			0.9			10.69			0.8			15.36			1		
08/31/20 15:19	378533.5			0.8			5.53			0.73			7.97			1		
08/31/20 15:20	377378.3			0.8			3.41			0.72			4.9			1		
08/31/20 15:21	376146			0.8			3.13			0.72			4.49			1		
08/31/20 15:22	377070.2			0.8			2.95			0.72			4.23			1		
08/31/20 15:23	377378.3			0.8			2.86			0.72			4.1			1		
08/31/20 15:24	377686.3			0.8			2.77			0.72			3.98			1		
08/31/20 15:25	376454.1			0.8			2.58			0.72			3.7			1		
08/31/20 15:26	376223			0.8			2.49			0.72			3.56			1		
08/31/20 15:27	376377.1			0.8			2.21			0.72			3.17			1		
08/31/20 15:28	376300			0.8			2.03			0.72			2.9			1		
08/31/20 15:29	377147.2			0.8			1.84			0.72			2.65			1		
08/31/20 15:30	377070.2			0.8			1.66			0.72			2.38			1		
08/31/20 15:31	378071.4			0.8			1.48			0.73			2.12			1		
08/31/20 15:32	370061.8			0.8			1.38			0.71			1.95			0		
08/31/20 15:33	363669.4			0.8			1.2			0.7			1.66			0		
08/31/20 15:34	348112.2			0.8			1.11			0.67			1.47			0		
08/31/20 15:35	337330			0.8			1.01			0.65			1.3			0		
08/31/20 15:36	325238.4			0.8			0.91			0.61			1.12			0		

AQ-32

AQ-32 The Project owner shall maintain hourly records of NOx and CO emission concentrations (ppmv @ 15% O2), and hourly, daily, and quarterly records of NOx and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NOx and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:49 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2020	0.2276	2.3663	0.8761	5.1800	0.1638	0.9456	0.0817	0.4726	0.2723	1.5762
Aug 2020	0.4257	2.4817	1.7833	5.9949	0.3379	1.1020	0.1690	0.5507	0.5626	1.8361
Sep 2020	0.4176	2.5642	1.7227	7.1656	0.3285	1.3362	0.1645	0.6681	0.5474	2.2261
Sum/Avg	2.5642		7.1656		1.3362		0.6681		2.2261	
Limit Value										

AQ32 DAILY NOX CO

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/01/20 0:00	0			0			0			0								
07/02/20 0:00	0			0			0			0								
07/03/20 0:00	0			0			0			0								
07/04/20 0:00	0			0			0			0								
07/05/20 0:00	0			0			0			0								
07/06/20 0:00	0			0			0			0								
07/07/20 0:00	0			0			0			0								
07/08/20 0:00	0			0			0			0								
07/09/20 0:00	0			0			0			0								
07/10/20 0:00	0			0			0			0								
07/11/20 0:00	0			0			0			0								
07/12/20 0:00	0			0			0			0								
07/13/20 0:00	36.55			56.55			34.94			64.16								
07/14/20 0:00	13.38			62.85			11.59			55.97								
07/15/20 0:00	10.76			62.9			10.42			59.74								
07/16/20 0:00	11.77			61.73			11.13			58.15								
07/17/20 0:00	12.17			57.18			12.18			55.54								
07/18/20 0:00	12.14			63.96			12.11			61.19								
07/19/20 0:00	12.58			62.11			11.92			59.38								
07/20/20 0:00	12.2			60.64			12.05			58.17								
07/21/20 0:00	12.72			10.36			19.2			10.32								
07/22/20 0:00	0			0			0			0								
07/23/20 0:00	0			0			0			0								
07/24/20 0:00	0			0			0			0								
07/25/20 0:00	0			0			23.5			13.62								
07/26/20 0:00	36.67			68.45			13			61.16								
07/27/20 0:00	11.29			66.06			12.06			64.46								
07/28/20 0:00	11.31			64.6			11.11			62.18								
07/29/20 0:00	11.58			64.35			11.11			61.91								
07/30/20 0:00	10.29			60.18			10.88			60.65								
07/31/20 0:00	11.29			62.66			10.82			60.12								
08/01/20 0:00	12.9			60.06			12.28			57.11								
08/02/20 0:00	11.22			60			11.14			57.79								
08/03/20 0:00	11.51			61.26			11.33			59.14								
08/04/20 0:00	12.01			61.12			11.42			58.29								

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 0:00	22.67			55.87			24.72			51.48								
08/06/20 0:00	0			0			0			0								
08/07/20 0:00	0			0			0			0								
08/08/20 0:00	25.71			11.34			35.77			58.4								
08/09/20 0:00	10.3			69.3			10.21			66.22								
08/10/20 0:00	11.88			64.98			11.7			63.6								
08/11/20 0:00	15.4			58.05			14.39			55.58								
08/12/20 0:00	11.68			66.88			10.8			63.76								
08/13/20 0:00	11.56			67.5			11.33			64.92								
08/14/20 0:00	11.87			73.59			11.83			71.08								
08/15/20 0:00	9.21			74.68			9.32			71.98								
08/16/20 0:00	13.12			69.95			13.37			67.77								
08/17/20 0:00	15.38			71.1			15.48			67.52								
08/18/20 0:00	15.44			67.01			14.85			63.86								
08/19/20 0:00	15.72			71.49			14.84			69.4								
08/20/20 0:00	19.84			53.16			19.5			52.29								
08/21/20 0:00	14.3			63.7			14.3			61.26								
08/22/20 0:00	17.84			61.64			17.51			59.12								
08/23/20 0:00	15.16			63.01			14.68			60.31								
08/24/20 0:00	16.01			66.25			15.41			64.01								
08/25/20 0:00	14.77			63.12			13.78			61.08								
08/26/20 0:00	13.75			63.99			13.16			62.01								
08/27/20 0:00	14.82			59.5			14.2			56.83								
08/28/20 0:00	13.65			63.12			13.1			60.93								
08/29/20 0:00	14.07			58.71			13.04			56.92								
08/30/20 0:00	13.54			59.4			19.32			55.15								
08/31/20 0:00	15.05			75.77			18.14			33.14								
09/01/20 0:00	14.35			66.65			13.66			64.61								
09/02/20 0:00	13.96			60.57			14.97			60.7								
09/03/20 0:00	8.69			68.03			11.22			67.72								
09/04/20 0:00	8.97			70.01			11.07			68.62								
09/05/20 0:00	9.47			68.44			11.84			66.04								
09/06/20 0:00	10.69			67.37			12.61			64.69								
09/07/20 0:00	14.07			64.51			16.01			61.84								
09/08/20 0:00	12.75			55.74			15.11			55.1								
09/09/20 0:00	8.42			67.46			11.07			65.84								
09/10/20 0:00	17.1			56.19			19.47			53.82								
09/11/20 0:00	17.45			55.46			19.75			54.47								

	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D								
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/12/20 0:00	18.09			57.18			20.4			56.04								
09/13/20 0:00	18.28			59.72			20.25			55.98								
09/14/20 0:00	12.44			61.64			15.49			60.3								
09/15/20 0:00	11.47			63.26			15.29			61.25								
09/16/20 0:00	10.56			66.84			14.96			66.11								
09/17/20 0:00	12.64			64.39			17.13			64.54								
09/18/20 0:00	13.57			61.25			17.13			60.66								
09/19/20 0:00	13.6			59.12			17.03			58.05								
09/20/20 0:00	12.07			59.17			15.14			56.72								
09/21/20 0:00	11.2			65.95			14.31			64.91								
09/22/20 0:00	11.74			64.66			14.97			63.23								
09/23/20 0:00	19.3			62.94			14.67			62.74								
09/24/20 0:00	0			0			15.83			62.42								
09/25/20 0:00	0			0			17.37			55.78								
09/26/20 0:00	0			0			15.02			50.38								
09/27/20 0:00	0			0			15.99			52.41								
09/28/20 0:00	35.58			58.54			15.44			57.18								
09/29/20 0:00	14.48			62.52			18.31			60.36								
09/30/20 0:00	14.59			64.07			17.52			61.17								

AQ32 HOURLY NOX CO

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**
07/01/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/01/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/02/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/03/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/04/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/05/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/06/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/07/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/07/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/08/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/08/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/09/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/10/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/11/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/12/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/13/20 3:00	0	X		0	X		0	X	1	0			0			17.4		1
07/13/20 4:00	0	X		0	X		0	X	1	0.7			1.4			14.5		1
07/13/20 5:00	0	X		0	X		0	X	1	0.7			1.7			14.4		1
07/13/20 6:00	0			0			17.5		1	0.7			1.7			14.4		1
07/13/20 7:00	0.7			1.6			14.2		1	0.8			1.7			14.2		1
07/13/20 8:00	0.8			1.7			14.2		1	0.8			1.7			14.2		1
07/13/20 9:00	0.7			1.7			14.3		1	0.7			1.7			14.4		1
07/13/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
07/13/20 11:00	0.7			1.7			13.5		1	0.8			1.7			13.5		1
07/13/20 12:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 13:00	0.8			1.7			13.6		1	0.7			1.7			13.5		1
07/13/20 14:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1
07/13/20 15:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1
07/13/20 16:00	0.8			1.7			13.7		1	0.8			1.7			13.6		1
07/13/20 17:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
07/13/20 18:00	0.2			1.7			12.1		1	0.2			1.7			12.2		1
07/13/20 19:00	0.5			1.7			13.2		1	0.5			1.7			13.1		1
07/13/20 20:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/13/20 21:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/13/20 22:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/13/20 23:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/14/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/14/20 1:00	0.7			1.7			14.4		1	0.8			1.7			14.3		1
07/14/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/14/20 3:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/14/20 4:00	0.7			1.6			14.4		1	0.7			1.7			14.4		1
07/14/20 5:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/14/20 6:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/14/20 7:00	0.7			1.7			14.4		1	0.8			1.7			14.3		1
07/14/20 8:00	0.8			1.7			14.3		1	0.8			1.6			14.3		1
07/14/20 9:00	0.8			1.7			14.4		1	0.7			1.7			14.5		1
07/14/20 10:00	0.7			1.7			14.5		1	0.7			1.5			14.5		1
07/14/20 11:00	1.1			1.7			14		1	1.1			1.6			13.7		1
07/14/20 12:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
07/14/20 13:00	1			1.7			13.9		1	0	X		0	X		0	X	0
07/14/20 14:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1
07/14/20 15:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
07/14/20 16:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/14/20 17:00	0.1			1.7			11.9		1	0.2			1.7			12		1
07/14/20 18:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
07/14/20 19:00	1			1.7			13.8		1	0.9			1.7			13.8		1
07/14/20 20:00	0.8			1.7			14.5		1	0.7			1.7			14.3		1
07/14/20 21:00	0.7			1.7			14.4		1	0.7			1.7			14.3		1
07/14/20 22:00	0.7			1.7			14.4		1	0.7			1.7			14.3		1
07/14/20 23:00	0.8			1.7			14.3		1	0.7			1.7			14.4		1
07/15/20 0:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 1:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 2:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/15/20 3:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 4:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 5:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 6:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 7:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 8:00	0.8			1.7			14.3		1	0.8			1.7			14.2		1
07/15/20 9:00	0.7			1.7			14.3		1	0.7			1.7			14.3		1
07/15/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/15/20 11:00	0.7			1.7			13.5		1	0.8			1.7			13.5		1
07/15/20 12:00	0.2			1.7			12.5		1	0.3			1.7			12.5		1
07/15/20 13:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/15/20 14:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
07/15/20 15:00	0.1			1.7			11.8		1	0.2			1.7			11.8		1
07/15/20 16:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
07/15/20 17:00	0.1			1.7			11.8		1	0.2			1.7			11.8		1
07/15/20 18:00	0.1			1.7			12.3		1	0.2			1.7			12.3		1
07/15/20 19:00	1			1.7			13.9		1	1			1.7			13.9		1
07/15/20 20:00	0.8			1.7			14.4		1	0.7			1.7			14.3		1
07/15/20 21:00	0.7			1.7			14.3		1	0.6			1.7			14.4		1
07/15/20 22:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/15/20 23:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 0:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 1:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 2:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 3:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 4:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 5:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 6:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 7:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 8:00	0.8			1.7			14.2		1	0.8			1.7			14.2		1
07/16/20 9:00	0.7			1.7			14.3		1	0.7			1.7			14.3		1
07/16/20 10:00	0.7			1.7			14.4		1	0.6			1.7			14.5		1
07/16/20 11:00	1.1			1.7			14		1	1.2			1.7			13.9		1
07/16/20 12:00	0.2			1.7			12.5		1	0.3			1.7			12.5		1
07/16/20 13:00	0.4			1.7			13		1	0.4			1.7			13		1
07/16/20 14:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/16/20 15:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
07/16/20 16:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/16/20 17:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
07/16/20 18:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/16/20 19:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/16/20 20:00	0.8			1.7			14.3		1	0.8			1.7			14.2		1
07/16/20 21:00	0.8			1.7			14.3		1	0.8			1.7			14.2		1
07/16/20 22:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/16/20 23:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 0:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 1:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 2:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 3:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 4:00	0.6			1.6			14.4		1	0.6			1.7			14.4		1
07/17/20 5:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 6:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 7:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/17/20 8:00	0.8			1.7			14.3		1	0.8			1.7			14.2		1
07/17/20 9:00	0.8			1.7			14.3		1	0.7			1.7			14.4		1
07/17/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.6		1
07/17/20 11:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/17/20 12:00	0.7			1.7			14.3		1	0.7			1.7			14.3		1
07/17/20 13:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/17/20 14:00	0.7			1.7			13.4		1	1.1			1.7			13.9		1
07/17/20 15:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/17/20 16:00	0.1			1.7			11.9		1	0.2			1.7			12		1
07/17/20 17:00	0.2			1.7			12.4		1	0.2			1.7			12.5		1
07/17/20 18:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
07/17/20 19:00	0.7			1.8			14.3		1	0.7			1.7			14.3		1
07/17/20 20:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/17/20 21:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/17/20 22:00	0.8			1.7			14.4		1	0.7			1.7			14.5		1
07/17/20 23:00	0.6			1.7			14.5		1	0.8			1.7			14.3		1
07/18/20 0:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 1:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 2:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 3:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 4:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 6:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/18/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/18/20 8:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
07/18/20 9:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
07/18/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/18/20 11:00	0.7			1.7			13.4		1	0.8			1.7			13.4		1
07/18/20 12:00	0.7			1.7			14.5		1	0.7			1.8			14.4		1
07/18/20 13:00	0.8			1.7			13.5		1	0.8			1.6			13.5		1
07/18/20 14:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
07/18/20 15:00	0.2			1.7			11.6		1	0.3			1.7			11.7		1
07/18/20 16:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
07/18/20 17:00	0.1			1.7			12		1	0.2			1.7			12		1
07/18/20 18:00	0.1			1.7			11.9		1	0.2			1.7			12		1
07/18/20 19:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
07/18/20 20:00	0.8			1.8			14.4		1	0.7			1.7			14.4		1
07/18/20 21:00	0.8			1.7			14.6		1	0.8			1.7			14.5		1
07/18/20 22:00	0.8			1.7			13.6		1	0.9			1.7			13.6		1
07/18/20 23:00	0.7			1.8			14.4		1	0.7			1.7			14.4		1
07/19/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 6:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/19/20 10:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1
07/19/20 11:00	1.1			1.7			13.8		1	1.3			1.7			13.8		1
07/19/20 12:00	0.5			1.7			13.1		1	0.5			1.7			13.1		1
07/19/20 13:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
07/19/20 14:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
07/19/20 15:00	0.2			1.7			11.6		1	0.2			1.7			11.7		1
07/19/20 16:00	0.1			1.7			12.3		1	0.2			1.7			12.3		1
07/19/20 17:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
07/19/20 18:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
07/19/20 19:00	1.2			1.8			14.2		1	1.3			1.7			14.1		1
07/19/20 20:00	0.8			1.7			14.5		1	0.7			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/19/20 21:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
07/19/20 22:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/19/20 23:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/20/20 0:00	0.7			1.7			14.4		1	0.8			1.7			14.3		1
07/20/20 1:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/20/20 2:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/20/20 3:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/20/20 4:00	0.7			1.7			14.4		1	0.7			1.6			14.3		1
07/20/20 5:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
07/20/20 6:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/20/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/20/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/20/20 9:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
07/20/20 10:00	0.6			1.7			14.5		1	0.7			1.7			14.5		1
07/20/20 11:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/20/20 12:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
07/20/20 13:00	0.6			1.7			13.2		1	0.6			1.7			13.3		1
07/20/20 14:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/20/20 15:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
07/20/20 16:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
07/20/20 17:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/20/20 18:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
07/20/20 19:00	0.8			1.7			13.6		1	0.8			1.7			13.6		1
07/20/20 20:00	0.8			1.8			14.1		1	0.8			1.7			14.2		1
07/20/20 21:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
07/20/20 22:00	0.6			1.7			14.5		1	0.7			1.7			14.5		1
07/20/20 23:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
07/21/20 0:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
07/21/20 1:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/21/20 2:00	0.6			1.7			14.4		1	0.6			1.7			14.4		1
07/21/20 3:00	0.7			1.7			14.4		1	0.7			1.7			14.3		1
07/21/20 4:00	0.6			1.7			14.4		1	0.7			1.7			14.4		1
07/21/20 5:00	0			0			16.9		1	0			0			15.7		1
07/21/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/21/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/22/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/23/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/23/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/24/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/24/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
07/25/20 22:00	0	X		0	X		0	X	1	0			0			17.5		1
07/25/20 23:00	0	X		0	X		0	X	1	0.7			1.5			14.5		1
07/26/20 0:00	0	X		0	X		0	X	1	0.7			1.7			14.4		1
07/26/20 1:00	0			0			17.5		1	0.8			1.7			14.4		1
07/26/20 2:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
07/26/20 3:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/26/20 4:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 5:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/26/20 6:00	0.7			1.7			14.4		1	0.7			1.7			14.3		1
07/26/20 7:00	0.6			1.7			14.4		1	0.8			1.7			14.2		1
07/26/20 8:00	0.6			1.7			14.4		1	0.8			1.7			14.2		1
07/26/20 9:00	0.6			1.7			14.4		1	0.8			1.7			14.2		1
07/26/20 10:00	0.6			1.7			14.4		1	0.8			1.7			14.2		1
07/26/20 11:00	0.6			1.7			14.4		1	0.8			1.7			14.2		1
07/26/20 12:00	1.2			1.7			14.2		1	1.6			1.7			14.3		1
07/26/20 13:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
07/26/20 14:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
07/26/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
07/26/20 16:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
07/26/20 17:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
07/26/20 18:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
07/26/20 19:00	0.1			1.7			11.9		1	0.2			1.7			12		1
07/26/20 20:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1
07/26/20 21:00	0.8			1.8			14.3		1	0.8			1.7			14.3		1
07/26/20 22:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
07/26/20 23:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/27/20 0:00	0.8			1.7			14.4		1	0.7			1.7			14.5		1
07/27/20 1:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/27/20 2:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
07/27/20 3:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/27/20 4:00	0.7			1.6			14.5		1	0.8			1.7			14.3		1
07/27/20 5:00	0.7			1.7			14.4		1	0.8			1.7			14.4		1
07/27/20 6:00	0.7			1.7			14.5		1	0.8			1.7			14.3		1
07/27/20 7:00	0.6			1.7			14.5		1	0.8			1.7			14.3		1
07/27/20 8:00	0.6			1.7			14.5		1	0.8			1.7			14.3		1
07/27/20 9:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/27/20 10:00	1.2			1.7			14.1		1	1.4			1.7			14.1		1
07/27/20 11:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
07/27/20 12:00	0.1			1.7			12.4		1	0.2			1.7			12.4		1
07/27/20 13:00	0.5			1.7			13.1		1	0.5			1.7			13.1		1
07/27/20 14:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
07/27/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
07/27/20 16:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
07/27/20 17:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
07/27/20 18:00	0.1			1.7			11.8		1	0.2			1.7			11.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/27/20 19:00	0.2			1.7			12.5		1	0.2			1.7			12.5		1
07/27/20 20:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/27/20 21:00	0.8			1.8			14.4		1	0.8			1.7			14.4		1
07/27/20 22:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/27/20 23:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
07/28/20 0:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/28/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/28/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/28/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/28/20 4:00	0.7			1.6			14.5		1	0.6			1.7			14.5		1
07/28/20 5:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/28/20 6:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/28/20 7:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
07/28/20 8:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/28/20 9:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
07/28/20 10:00	0.5			1.7			13		1	0.5			1.7			13.1		1
07/28/20 11:00	0.3			1.7			12.6		1	0.3			1.7			12.7		1
07/28/20 12:00	0.2			1.7			12.5		1	0.2			1.7			12.5		1
07/28/20 13:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
07/28/20 14:00	0.1			1.7			12		1	0.2			1.7			12		1
07/28/20 15:00	0.1			1.7			12.2		1	0.2			1.7			12.2		1
07/28/20 16:00	0.1			1.7			12.3		1	0.2			1.7			12.4		1
07/28/20 17:00	0.1			1.7			12.4		1	0.2			1.7			12.4		1
07/28/20 18:00	0.6			1.7			13.5		1	0.6			1.7			13.5		1
07/28/20 19:00	0.7			1.7			13.6		1	0.7			1.7			13.6		1
07/28/20 20:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1
07/28/20 21:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
07/28/20 22:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/28/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
07/29/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/29/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 2:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/29/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 7:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/29/20 8:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/29/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
07/29/20 10:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
07/29/20 11:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
07/29/20 12:00	0.2			1.7			12.3		1	0.2			1.7			12.4		1
07/29/20 13:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
07/29/20 14:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/29/20 15:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/29/20 16:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/29/20 17:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/29/20 18:00	0.1			1.7			11.9		1	0.1			1.7			12		1
07/29/20 19:00	1.1			1.7			14		1	1			1.7			14		1
07/29/20 20:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/29/20 21:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
07/29/20 22:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/29/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
07/30/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 2:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 4:00	0	X		0	X		0	X	0	0.6			1.7			14.5		1
07/30/20 5:00	0	X		0	X		0	X	0	0.6			1.7			14.5		1
07/30/20 6:00	0.8			1.6			14.5		1	0.6			1.7			14.5		1
07/30/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/30/20 9:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/30/20 10:00	0.7			1.7			14.6		1	0.7			1.7			14.5		1
07/30/20 11:00	0.6			1.7			13.2		1	0.6			1.6			13.3		1
07/30/20 12:00	0.8			1.7			13.6		1	0.8			1.7			13.6		1
07/30/20 13:00	0.4			1.7			13		1	0.4			1.7			13		1
07/30/20 14:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/30/20 15:00	0.1			1.7			12.2		1	0.2			1.7			12.2		1
07/30/20 16:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/30/20 17:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/30/20 18:00	0.1			1.7			12.3		1	0.2			1.7			12.3		1
07/30/20 19:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/30/20 20:00	0.5			1.7			13.1		1	0.5			1.7			13.1		1
07/30/20 21:00	0.7			1.8			14.5		1	0.8			1.7			14.4		1
07/30/20 22:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/30/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
07/31/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 7:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
07/31/20 9:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
07/31/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
07/31/20 11:00	0.4			1.7			12.8		1	0.5			1.6			12.8		1
07/31/20 12:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
07/31/20 13:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/31/20 14:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
07/31/20 15:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
07/31/20 16:00	0.4			1.7			13		1	0.4			1.7			13		1
07/31/20 17:00	0.2			1.7			12.4		1	0.2			1.7			12.4		1
07/31/20 18:00	0.2			1.7			12.6		1	0.3			1.7			12.6		1
07/31/20 19:00	0.3			1.7			12.7		1	0.3			1.7			12.7		1
07/31/20 20:00	0.7			1.7			13.5		1	0.7			1.7			13.5		1
07/31/20 21:00	0.7			1.8			14.3		1	0.7			1.7			14.3		1
07/31/20 22:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
07/31/20 23:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 2:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 8:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/01/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/01/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/01/20 11:00	0.7			1.7			14.5		1	0.7			1.7			14.6		1
08/01/20 12:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/01/20 13:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1
08/01/20 14:00	0.7			1.7			14.5		1	0.8			1.8			14.5		1
08/01/20 15:00	0.3			1.7			11.8		1	0.4			1.6			11.9		1
08/01/20 16:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/01/20 17:00	0.1			1.7			12		1	0.2			1.7			12		1
08/01/20 18:00	0.1			1.7			12.3		1	0.2			1.7			12.3		1
08/01/20 19:00	0.3			1.7			12.7		1	0.3			1.7			12.7		1
08/01/20 20:00	1			1.7			13.8		1	0.9			1.7			13.7		1
08/01/20 21:00	1.4			1.7			14.2		1	1.3			1.7			14.1		1
08/01/20 22:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/01/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/02/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/02/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/02/20 2:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/02/20 3:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/02/20 4:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/02/20 5:00	0.9			1.7			14.3		1	0.8			1.7			14.2		1
08/02/20 6:00	0.8			1.7			14.4		1	0.8			1.7			14.2		1
08/02/20 7:00	0.7			1.7			14.4		1	0.8			1.7			14.3		1
08/02/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/02/20 9:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/02/20 10:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1
08/02/20 11:00	0.7			1.7			14.6		1	0.7			1.7			14.5		1
08/02/20 12:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/02/20 13:00	0.4			1.7			12.7		1	0.4			1.6			12.7		1
08/02/20 14:00	0.3			1.7			12.7		1	0.4			1.6			12.8		1
08/02/20 15:00	0.1			1.7			11.8		1	0.2			1.7			11.8		1
08/02/20 16:00	0.2			1.7			12.5		1	0.2			1.7			12.5		1
08/02/20 17:00	0.1			1.7			12		1	0.2			1.7			12		1
08/02/20 18:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
08/02/20 19:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
08/02/20 20:00	0.5			1.7			13.2		1	0.5			1.7			13.2		1
08/02/20 21:00	0.7			1.8			14.4		1	0.8			1.7			14.4		1
08/02/20 22:00	0.8			1.6			14.4		1	0.8			1.7			14.3		1
08/02/20 23:00	0.7			1.6			14.5		1	0.7			1.7			14.5		1
08/03/20 0:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/03/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/03/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/03/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/03/20 4:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/03/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/03/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/03/20 7:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/03/20 8:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/03/20 9:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1
08/03/20 10:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/03/20 11:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/03/20 12:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/03/20 13:00	0.5			1.7			13.3		1	0.6			1.7			13.3		1
08/03/20 14:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/03/20 15:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
08/03/20 16:00	0.1			1.7			12.2		1	0.2			1.7			12.2		1
08/03/20 17:00	0.1			1.7			12.1		1	0.2			1.7			12.1		1
08/03/20 18:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
08/03/20 19:00	0.4			1.7			13.1		1	0.4			1.7			13		1
08/03/20 20:00	0.8			1.8			14.4		1	0.8			1.7			14.4		1
08/03/20 21:00	0.7			1.7			14.5		1	0.7			1.7			14.6		1
08/03/20 22:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/03/20 23:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/04/20 0:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/04/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 7:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 8:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/04/20 9:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/04/20 10:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
08/04/20 11:00	0.9			1.7			14.5		1	1			1.7			14.4		1
08/04/20 12:00	0.5			1.7			13.2		1	0.5			1.7			13.2		1
08/04/20 13:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/04/20 14:00	0.2			1.7			12.3		1	0.2			1.7			12.3		1
08/04/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
08/04/20 16:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/04/20 17:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
08/04/20 18:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
08/04/20 19:00	1.1			1.8			14.1		1	1			1.7			14		1
08/04/20 20:00	0.7			1.8			14.4		1	0.7			1.7			14.4		1
08/04/20 21:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/04/20 22:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/04/20 23:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/05/20 0:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/05/20 1:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/05/20 2:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/05/20 3:00	0.6			1.7			14.5		1	0.6			1.7			14.4		1
08/05/20 4:00	0.6			1.7			14.5		1	0.6			1.7			14.4		1
08/05/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/05/20 6:00	0.6			1.7			14.5		1	0.6			1.7			14.4		1
08/05/20 7:00	0.6			1.7			14.5		1	0.6			1.7			14.4		1
08/05/20 8:00	0.6			1.7			14.5		1	0.6			1.7			14.5		1
08/05/20 9:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/05/20 10:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/05/20 11:00	0.9			1.7			14.4		1	1			1.7			14.4		1
08/05/20 12:00	0.7			1.7			13.5		1	0.8			1.7			13.5		1
08/05/20 13:00	0.5			1.7			13.2		1	0.5			1.7			13.2		1
08/05/20 14:00	0.4			1.7			13		1	0.4			1.7			13		1
08/05/20 15:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
08/05/20 16:00	0.4			1.7			13		1	0.5			1.7			13.1		1
08/05/20 17:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
08/05/20 18:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/05/20 19:00	0.8			1.8			14.3		1	0.8			1.7			14.2		1
08/05/20 20:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/05/20 21:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/05/20 22:00	0.8			1.7			14.3		1	0			0			16.8		1
08/05/20 23:00	0			0			15.9		1	0	X		0	X		0	X	1
08/06/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/06/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/06/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/07/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/07/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
08/08/20 7:00	0	X		0	X		0	X	1	0			0			17.7		1
08/08/20 8:00	0	X		0	X		0	X	1	0.7			1.6			14.4		1
08/08/20 9:00	0	X		0	X		0	X	1	0.7			1.7			14.4		1
08/08/20 10:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
08/08/20 11:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
08/08/20 12:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
08/08/20 13:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
08/08/20 14:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
08/08/20 15:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
08/08/20 16:00	0	X		0	X		0	X	1	0.2			1.7			12.1		1
08/08/20 17:00	0	X		0	X		0	X	1	0.3			1.7			12.7		1
08/08/20 18:00	0	X		0	X		0	X	1	0.4			1.7			13		1
08/08/20 19:00	0	X		0	X		0	X	1	0.8			1.7			13.6		1
08/08/20 20:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
08/08/20 21:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
08/08/20 22:00	0			0			17.5		1	1.5			1.7			14.4		1
08/08/20 23:00	0.8			1.6			14.4		1	0.8			1.7			14.3		1
08/09/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/09/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/09/20 2:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/09/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/09/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/09/20 5:00	0.6			1.7			14.5		1	0.7			1.7			14.5		1
08/09/20 6:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/09/20 7:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/09/20 8:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/09/20 9:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
08/09/20 10:00	0.6			1.7			13.1		1	0.5			1.7			13.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/09/20 11:00	0.3			1.7			12.5		1	0.3			1.7			12.5		1
08/09/20 12:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
08/09/20 13:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
08/09/20 14:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
08/09/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
08/09/20 16:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/09/20 17:00	0.1			1.7			11.7		1	0.2			1.7			11.7		1
08/09/20 18:00	0.4			1.7			12.7		1	0.5			1.7			12.7		1
08/09/20 19:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/09/20 20:00	0.2			1.7			12.3		1	0.2			1.7			12.4		1
08/09/20 21:00	0.5			1.7			13.2		1	0.5			1.7			13.2		1
08/09/20 22:00	0.6			1.7			13.5		1	0.6			1.7			13.5		1
08/09/20 23:00	0.8			1.8			14.4		1	0.7			1.7			14.4		1
08/10/20 0:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/10/20 1:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/10/20 2:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/10/20 3:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 4:00	0.8			1.6			14.5		1	0.8			1.6			14.4		1
08/10/20 5:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 6:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 7:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/10/20 8:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 9:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/10/20 10:00	0.6			1.7			13.2		1	0.7			1.7			13.2		1
08/10/20 11:00	0.2			1.7			12.3		1	0.2			1.7			12.3		1
08/10/20 12:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/10/20 13:00	0.2			1.7			11.6		1	0.2			1.7			11.7		1
08/10/20 14:00	0.2			1.7			11.6		1	0.2			1.7			11.7		1
08/10/20 15:00	0.2			1.7			11.6		1	0.2			1.7			11.7		1
08/10/20 16:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/10/20 17:00	0.2			1.7			11.8		1	0.2			1.7			11.9		1
08/10/20 18:00	0.5			1.7			13.2		1	0.5			1.7			13.2		1
08/10/20 19:00	0.7			1.8			14.5		1	0.7			1.7			14.5		1
08/10/20 20:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 21:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 22:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/10/20 23:00	0.8			1.7			14.4		1	0.7			1.7			14.5		1
08/11/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/11/20 1:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/11/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/11/20 3:00	0.7			1.7			14.4		1	0.6			1.7			14.5		1
08/11/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/11/20 5:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
08/11/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/11/20 7:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/11/20 8:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/11/20 9:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/11/20 10:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
08/11/20 11:00	1.2			1.7			14.1		1	1.4			1.7			14.1		1
08/11/20 12:00	0.4			1.7			13		1	0.4			1.7			13		1
08/11/20 13:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
08/11/20 14:00	0.7			1.7			13.5		1	0.7			1.7			13.5		1
08/11/20 15:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
08/11/20 16:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1
08/11/20 17:00	0.8			1.7			13.6		1	0.7			1.7			13.6		1
08/11/20 18:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
08/11/20 19:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/11/20 20:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/11/20 21:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/11/20 22:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/11/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/12/20 0:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/12/20 1:00	0.8			1.7			14.5		1	0.6			1.7			14.5		1
08/12/20 2:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/12/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/12/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/12/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/12/20 6:00	0.7			1.7			14.5		1	0.6			1.7			14.4		1
08/12/20 7:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/12/20 8:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/12/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/12/20 10:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/12/20 11:00	0.4			1.7			12.9		1	0.6			1.6			12.9		1
08/12/20 12:00	0.1			1.7			12.1		1	0.2			1.7			12.1		1
08/12/20 13:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
08/12/20 14:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/12/20 15:00	0.1			1.7			11.8		1	0.2			1.7			11.8		1
08/12/20 16:00	0.1			1.7			11.8		1	0.1			1.7			11.9		1
08/12/20 17:00	0.1			1.7			11.8		1	0.1			1.7			11.9		1
08/12/20 18:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
08/12/20 19:00	0.2			1.7			12.5		1	0.2			1.7			12.6		1
08/12/20 20:00	0.8			1.7			13.6		1	0.8			1.7			13.6		1
08/12/20 21:00	0.7			1.7			13.6		1	0.7			1.7			13.6		1
08/12/20 22:00	1.4			1.7			14.2		1	1.1			1.7			14.1		1
08/12/20 23:00	0.9			1.8			14.5		1	0.8			1.7			14.5		1
08/13/20 0:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/13/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/13/20 2:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/13/20 3:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/13/20 4:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/13/20 5:00	0.7			1.7			14.5		1	0.6			1.7			14.5		1
08/13/20 6:00	0.8			1.7			14.5		1	0.7			1.7			14.4		1
08/13/20 7:00	0.7			1.7			14.5		1	0.8			1.7			14.4		1
08/13/20 8:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/13/20 9:00	0.7			1.7			14.6		1	0.7			1.7			14.6		1
08/13/20 10:00	1			1.7			13.9		1	1			1.7			13.9		1
08/13/20 11:00	0.2			1.7			12.2		1	0.2			1.7			12.2		1
08/13/20 12:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/13/20 13:00	0.1			1.7			11.9		1	0.2			1.7			11.9		1
08/13/20 14:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
08/13/20 15:00	0.1			1.7			12.2		1	0.2			1.7			12.3		1
08/13/20 16:00	0.1			1.7			12.4		1	0.2			1.7			12.5		1
08/13/20 17:00	0.1			1.7			12		1	0.2			1.7			12		1
08/13/20 18:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
08/13/20 19:00	0.9			1.7			13.8		1	0.9			1.7			13.8		1
08/13/20 20:00	1.3			1.7			14.3		1	1.2			1.7			14.2		1
08/13/20 21:00	0.3			1.7			12.4		1	0.3			1.7			12.5		1
08/13/20 22:00	0.2			1.7			12.3		1	0.2			1.7			12.4		1
08/13/20 23:00	0.8			1.8			14.4		1	0.7			1.7			14.4		1
08/14/20 0:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/14/20 1:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/14/20 2:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/14/20 3:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/14/20 4:00	0.9			1.7			14.4		1	0.9			1.6			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/14/20 5:00	1.1			1.7			14.4		1	1			1.7			14.4		1
08/14/20 6:00	1.2			1.7			14.6		1	1.2			1.7			14.5		1
08/14/20 7:00	1.2			1.7			13.9		1	1.2			1.7			13.8		1
08/14/20 8:00	0.2			1.7			12		1	0.2			1.7			12.1		1
08/14/20 9:00	0.2			1.7			11.9		1	0.2			1.7			11.9		1
08/14/20 10:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/14/20 11:00	0.3			1.7			12.4		1	0.3			1.7			12.5		1
08/14/20 12:00	0.4			1.7			13		1	0.4			1.7			12.9		1
08/14/20 13:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
08/14/20 14:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
08/14/20 15:00	0.2			1.7			11.8		1	0.2			1.7			11.9		1
08/14/20 16:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/14/20 17:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/14/20 18:00	0.1			1.7			12		1	0.2			1.7			12		1
08/14/20 19:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/14/20 20:00	0.2			1.7			12.3		1	0.3			1.7			12.3		1
08/14/20 21:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/14/20 22:00	0.5			1.7			13		1	0.5			1.7			13		1
08/14/20 23:00	0.9			1.8			14.2		1	0.9			1.7			14.2		1
08/15/20 0:00	0.8			1.7			14.3		1	0.9			1.7			14.2		1
08/15/20 1:00	0.9			1.7			14.3		1	0.8			1.7			14.3		1
08/15/20 2:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/15/20 3:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
08/15/20 4:00	0.7			1.7			14.4		1	0.6			1.7			14.4		1
08/15/20 5:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/15/20 6:00	0.8			1.7			14.3		1	0.8			1.7			14.3		1
08/15/20 7:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/15/20 8:00	0.4			1.7			12.5		1	0.5			1.7			12.5		1
08/15/20 9:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
08/15/20 10:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
08/15/20 11:00	0.2			1.7			11.7		1	0.2			1.7			11.7		1
08/15/20 12:00	0.2			1.7			12.4		1	0.3			1.7			12.5		1
08/15/20 13:00	0.3			1.7			12.8		1	0.3			1.7			12.9		1
08/15/20 14:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/15/20 15:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
08/15/20 16:00	0.1			1.7			12.3		1	0.2			1.7			12.4		1
08/15/20 17:00	0.1			1.7			12.2		1	0.2			1.7			12.2		1
08/15/20 18:00	0.2			1.7			12.2		1	0.2			1.7			12.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/15/20 19:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
08/15/20 20:00	0.1			1.7			11.9		1	0.1			1.7			12		1
08/15/20 21:00	0.1			1.7			12.1		1	0.2			1.7			12.1		1
08/15/20 22:00	0.2			1.7			11.9		1	0.2			1.7			11.9		1
08/15/20 23:00	0.9			1.7			13.6		1	0.8			1.7			13.5		1
08/16/20 0:00	0.9			1.7			14.5		1	0.9			1.7			14.4		1
08/16/20 1:00	0.8			1.8			14.5		1	0.7			1.7			14.5		1
08/16/20 2:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
08/16/20 3:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/16/20 4:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/16/20 5:00	0.9			1.7			14.4		1	0.7			1.7			14.5		1
08/16/20 6:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/16/20 7:00	0.7			1.7			14.4		1	0.7			1.7			14.4		1
08/16/20 8:00	0.7			1.7			14.3		1	0.7			1.7			14.4		1
08/16/20 9:00	0.8			1.6			13.7		1	0.9			1.6			13.7		1
08/16/20 10:00	0.7			1.7			13.5		1	0.7			1.6			13.4		1
08/16/20 11:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
08/16/20 12:00	0.8			1.7			13.9		1	0.9			1.7			13.8		1
08/16/20 13:00	0.4			1.7			13		1	0.4			1.7			13		1
08/16/20 14:00	0.1			1.7			11.7		1	0.2			1.7			11.8		1
08/16/20 15:00	0.1			1.7			11.9		1	0.2			1.7			12		1
08/16/20 16:00	0.1			1.7			12.1		1	0.2			1.7			12.1		1
08/16/20 17:00	0.3			1.7			12.5		1	0.4			1.7			12.5		1
08/16/20 18:00	0.7			1.7			13.4		1	0.7			1.7			13.3		1
08/16/20 19:00	0.5			1.7			12.9		1	0.5			1.7			12.9		1
08/16/20 20:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/16/20 21:00	0.2			1.7			12.3		1	0.2			1.7			12.4		1
08/16/20 22:00	0.2			1.7			12.4		1	0.3			1.7			12.4		1
08/16/20 23:00	0.8			1.8			13.8		1	0.9			1.7			13.5		1
08/17/20 0:00	0.9			1.7			14.4		1	0.9			1.7			14.5		1
08/17/20 1:00	1			1.7			14.4		1	1			1.7			14.4		1
08/17/20 2:00	1.3			1.7			14.3		1	1.2			1.7			14.4		1
08/17/20 3:00	1.3			1.7			14.3		1	1.2			1.7			14.4		1
08/17/20 4:00	1.2			1.7			14.3		1	1.1			1.7			14.4		1
08/17/20 5:00	1.1			1.7			14.4		1	1			1.7			14.4		1
08/17/20 6:00	1			1.7			14.5		1	1			1.7			14.5		1
08/17/20 7:00	0.6			1.7			13		1	0.6			1.5			13		1
08/17/20 8:00	0.2			1.7			11.8		1	0.3			1.6			11.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/17/20 9:00	0.2			1.7			11.7		1	0.3			1.6			11.7		1
08/17/20 10:00	0.2			1.7			11.6		1	0.3			1.6			11.7		1
08/17/20 11:00	0.2			1.7			11.6		1	0.3			1.6			11.7		1
08/17/20 12:00	0.2			1.7			12.1		1	0.2			1.6			12.2		1
08/17/20 13:00	0.4			1.7			12.9		1	0.4			1.6			12.9		1
08/17/20 14:00	0.6			1.7			13.2		1	0.6			1.6			13.2		1
08/17/20 15:00	0.7			1.7			14.3		1	0.8			1.7			14.3		1
08/17/20 16:00	0.7			1.7			13.6		1	0.8			1.7			13.6		1
08/17/20 17:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1
08/17/20 18:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1
08/17/20 19:00	0.2			1.7			12.5		1	0.3			1.7			12.5		1
08/17/20 20:00	0.9			1.7			13.3		1	0.9			1.7			13.3		1
08/17/20 21:00	1.2			1.7			13.9		1	1.1			1.7			13.9		1
08/17/20 22:00	1			1.7			14.4		1	1			1.7			14.3		1
08/17/20 23:00	1			1.7			14.2		1	1.1			1.7			14.2		1
08/18/20 0:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/18/20 1:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/18/20 2:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/18/20 3:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/18/20 4:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/18/20 5:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/18/20 6:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/18/20 7:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/18/20 8:00	1.3			1.7			14.1		1	1.5			1.7			14		1
08/18/20 9:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/18/20 10:00	0.3			1.7			12.7		1	0.3			1.7			12.7		1
08/18/20 11:00	0.2			1.7			12.2		1	0.2			1.7			12.3		1
08/18/20 12:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/18/20 13:00	0.2			1.7			12.1		1	0.2			1.7			12.1		1
08/18/20 14:00	0.2			1.7			12.3		1	0.2			1.7			12.3		1
08/18/20 15:00	0.8			1.7			13.8		1	0.8			1.7			13.8		1
08/18/20 16:00	0.5			1.7			13.3		1	0.5			1.7			13.3		1
08/18/20 17:00	0.9			1.7			13.8		1	0.9			1.7			13.8		1
08/18/20 18:00	0.7			1.7			13.5		1	0.7			1.7			13.4		1
08/18/20 19:00	0.7			1.7			13.5		1	0.7			1.7			13.5		1
08/18/20 20:00	0.8			1.7			14.3		1	0.8			1.8			14.3		1
08/18/20 21:00	0.7			1.6			13.4		1	0.7			1.7			13.4		1
08/18/20 22:00	1.1			1.7			13.8		1	1			1.7			13.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/18/20 23:00	1			1.7			13.7		1	0.9			1.7			13.6		1
08/19/20 0:00	0.8			1.8			14.5		1	0.7			1.7			14.5		1
08/19/20 1:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/19/20 2:00	0.8			1.7			14.3		1	0.7			1.7			14.4		1
08/19/20 3:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/19/20 4:00	0.8			1.7			14.5		1	0.7			1.7			14.6		1
08/19/20 5:00	0.9			1.7			14.4		1	0.7			1.7			14.6		1
08/19/20 6:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/19/20 7:00	1.3			1.7			14.1		1	1.3			1.7			14		1
08/19/20 8:00	0.3			1.7			12.7		1	0.4			1.7			12.7		1
08/19/20 9:00	0.5			1.7			13		1	0.5			1.7			13		1
08/19/20 10:00	0.2			1.7			11.9		1	0.2			1.7			12		1
08/19/20 11:00	0.2			1.7			11.8		1	0.2			1.7			11.9		1
08/19/20 12:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/19/20 13:00	0.2			1.7			12.3		1	0.3			1.7			12.3		1
08/19/20 14:00	0.9			1.8			13.8		1	0.9			1.7			13.7		1
08/19/20 15:00	1			1.7			13.9		1	1			1.7			13.8		1
08/19/20 16:00	0.6			1.7			13.2		1	0.6			1.7			13.2		1
08/19/20 17:00	0.2			1.7			12		1	0.3			1.7			12		1
08/19/20 18:00	0.3			1.7			12.5		1	0.3			1.7			12.5		1
08/19/20 19:00	0.7			1.7			13.5		1	0.7			1.7			13.4		1
08/19/20 20:00	0.8			1.7			13.5		1	0.8			1.7			13.5		1
08/19/20 21:00	0.9			1.7			13.6		1	0.9			1.7			13.6		1
08/19/20 22:00	1			1.7			14.4		1	1			1.7			14.4		1
08/19/20 23:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/20/20 0:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/20/20 1:00	0.8			1.7			14.5		1	0.9			1.7			14.4		1
08/20/20 2:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/20/20 3:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/20/20 4:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/20/20 5:00	0.9			1.7			14.5		1	0.9			1.7			14.4		1
08/20/20 6:00	0.8			1.7			14.5		1	0.9			1.7			14.3		1
08/20/20 7:00	0.9			1.7			14.5		1	1			1.7			14.4		1
08/20/20 8:00	1.1			1.7			14.5		1	1.1			1.7			14.4		1
08/20/20 9:00	1.1			1.7			14.5		1	1			1.7			14.5		1
08/20/20 10:00	1.1			1.7			14.6		1	1.1			1.7			14.6		1
08/20/20 11:00	1.6			1.7			14.1		1	1.7			1.7			14.1		1
08/20/20 12:00	1.1			1.8			14.4		1	1.1			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/20/20 13:00	1			1.7			14.5		1	1			1.7			14.5		1
08/20/20 14:00	1.1			1.7			14.3		1	1.1			1.7			14.3		1
08/20/20 15:00	1.1			1.7			13.9		1	1.2			1.7			13.7		1
08/20/20 16:00	1.3			1.8			14.4		1	1.2			1.7			14.4		1
08/20/20 17:00	1.2			1.7			14.5		1	1.2			1.7			14.5		1
08/20/20 18:00	1.3			1.7			13.8		1	1.3			1.7			13.7		1
08/20/20 19:00	1.1			1.7			14.4		1	1.2			1.7			14.4		1
08/20/20 20:00	1.1			1.7			14.4		1	1			1.7			14.4		1
08/20/20 21:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/20/20 22:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/20/20 23:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/21/20 0:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/21/20 1:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/21/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/21/20 3:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/21/20 4:00	0.8			1.7			14.4		1	0.9			1.7			14.3		1
08/21/20 5:00	0.8			1.7			14.5		1	0.7			1.7			14.4		1
08/21/20 6:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/21/20 7:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/21/20 8:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/21/20 9:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/21/20 10:00	0.8			1.7			14.4		1	1			1.7			14.4		1
08/21/20 11:00	1.2			1.7			14.4		1	1.4			1.7			14.4		1
08/21/20 12:00	1.1			1.7			14.4		1	1.2			1.7			14.4		1
08/21/20 13:00	0.4			1.7			12.3		1	0.4			1.6			12.3		1
08/21/20 14:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
08/21/20 15:00	0.2			1.7			12.2		1	0.3			1.7			12.2		1
08/21/20 16:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/21/20 17:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/21/20 18:00	0.3			1.7			11.7		1	0.3			1.7			11.8		1
08/21/20 19:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/21/20 20:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/21/20 21:00	0.5			1.7			12.9		1	0.6			1.7			12.9		1
08/21/20 22:00	0.4			1.7			12.8		1	0.5			1.7			12.9		1
08/21/20 23:00	0.9			1.8			14.4		1	0.8			1.7			14.4		1
08/22/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/22/20 1:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1
08/22/20 2:00	1			1.7			14.4		1	0.9			1.7			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/22/20 3:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
08/22/20 4:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
08/22/20 5:00	1			1.7			14.5		1	0.9			1.7			14.5		1
08/22/20 6:00	1			1.7			14.5		1	1			1.7			14.4		1
08/22/20 7:00	1			1.7			14.4		1	1			1.7			14.3		1
08/22/20 8:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1
08/22/20 9:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/22/20 10:00	0.8			1.7			14.6		1	0.9			1.7			14.5		1
08/22/20 11:00	1.1			1.7			13.8		1	1.1			1.7			13.7		1
08/22/20 12:00	1.4			1.7			14.2		1	1.4			1.7			14.2		1
08/22/20 13:00	1.2			1.7			14.3		1	1.5			1.7			14.3		1
08/22/20 14:00	1.2			1.7			14.2		1	1.4			1.7			14.2		1
08/22/20 15:00	0.8			1.7			13.5		1	0.8			1.7			13.5		1
08/22/20 16:00	0.2			1.7			12.2		1	0.3			1.7			12.2		1
08/22/20 17:00	0.2			1.7			11.6		1	0.3			1.7			11.7		1
08/22/20 18:00	0.2			1.7			11.7		1	0.3			1.7			11.8		1
08/22/20 19:00	0.5			1.7			13		1	0.5			1.7			13.1		1
08/22/20 20:00	0.7			1.7			13.3		1	0.7			1.7			13.3		1
08/22/20 21:00	1.1			1.7			13.8		1	1.1			1.7			13.8		1
08/22/20 22:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
08/22/20 23:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
08/23/20 0:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/23/20 1:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/23/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/23/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/23/20 4:00	0.8			1.6			14.5		1	0.7			1.7			14.5		1
08/23/20 5:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/23/20 6:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/23/20 7:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/23/20 8:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/23/20 9:00	0.8			1.7			14.6		1	0.8			1.7			14.6		1
08/23/20 10:00	1.4			1.7			14.3		1	1.7			1.7			14.2		1
08/23/20 11:00	0.5			1.7			12.8		1	0.4			1.7			12.8		1
08/23/20 12:00	0.2			1.7			12.2		1	0.3			1.7			12.2		1
08/23/20 13:00	0.2			1.7			12.2		1	0.2			1.7			12.2		1
08/23/20 14:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/23/20 15:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
08/23/20 16:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/23/20 17:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
08/23/20 18:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/23/20 19:00	1.1			1.7			14.2		1	1.2			1.7			14.2		1
08/23/20 20:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/23/20 21:00	0.8			1.7			13.5		1	0.8			1.7			13.4		1
08/23/20 22:00	1.1			1.7			14.1		1	1.2			1.7			14.1		1
08/23/20 23:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/24/20 0:00	1			1.7			14.4		1	0.9			1.7			14.4		1
08/24/20 1:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/24/20 2:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/24/20 3:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/24/20 4:00	1			1.7			14.4		1	1			1.6			14.3		1
08/24/20 5:00	1			1.7			14.4		1	1			1.7			14.3		1
08/24/20 6:00	1			1.7			14.4		1	0.9			1.7			14.4		1
08/24/20 7:00	1			1.7			14.5		1	0.9			1.7			14.6		1
08/24/20 8:00	1.2			1.7			14		1	1.2			1.7			13.9		1
08/24/20 9:00	0.5			1.7			13		1	0.5			1.7			13		1
08/24/20 10:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
08/24/20 11:00	0.2			1.7			11.8		1	0.3			1.7			11.9		1
08/24/20 12:00	0.3			1.7			12.4		1	0.3			1.7			12.4		1
08/24/20 13:00	0.5			1.7			13		1	0.5			1.7			13		1
08/24/20 14:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/24/20 15:00	0.5			1.7			13.1		1	0.6			1.7			13.1		1
08/24/20 16:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/24/20 17:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/24/20 18:00	0.5			1.7			13.1		1	0.5			1.7			13.1		1
08/24/20 19:00	1.1			1.7			14.1		1	1.1			1.7			14.1		1
08/24/20 20:00	0.8			1.7			14.5		1	0.7			1.7			14.4		1
08/24/20 21:00	1.1			1.7			14		1	1.2			1.7			13.9		1
08/24/20 22:00	0.9			1.7			13.7		1	0.9			1.7			13.7		1
08/24/20 23:00	0.9			1.8			14.4		1	0.8			1.7			14.4		1
08/25/20 0:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/25/20 1:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/25/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/25/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/25/20 4:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/25/20 5:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/25/20 6:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/25/20 7:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/25/20 8:00	0.8			1.7			14.5		1	0.8			1.7			14.6		1
08/25/20 9:00	1			1.7			14.5		1	1			1.7			14.5		1
08/25/20 10:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/25/20 11:00	0.3			1.7			12.5		1	0.3			1.7			12.6		1
08/25/20 12:00	0.6			1.7			13.4		1	0.7			1.7			13.4		1
08/25/20 13:00	0.6			1.7			13.4		1	0.6			1.7			13.4		1
08/25/20 14:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/25/20 15:00	0.4			1.7			12.7		1	0.4			1.7			12.7		1
08/25/20 16:00	0.3			1.7			12.5		1	0.3			1.7			12.5		1
08/25/20 17:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/25/20 18:00	0.4			1.7			12.8		1	0.3			1.7			12.8		1
08/25/20 19:00	0.7			1.7			13.3		1	0.6			1.7			13.3		1
08/25/20 20:00	1			1.8			14.4		1	1			1.7			14.3		1
08/25/20 21:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/25/20 22:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
08/25/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/26/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/26/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/26/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/26/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/26/20 4:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/26/20 5:00	0.9			1.7			14.5		1	0.9			1.7			14.3		1
08/26/20 6:00	0.8			1.7			14.5		1	0.9			1.7			14.3		1
08/26/20 7:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/26/20 8:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/26/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
08/26/20 10:00	1.2			1.7			13.9		1	1.3			1.7			13.9		1
08/26/20 11:00	0.3			1.7			12.7		1	0.4			1.7			12.7		1
08/26/20 12:00	0.2			1.7			12		1	0.2			1.7			12		1
08/26/20 13:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/26/20 14:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/26/20 15:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/26/20 16:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/26/20 17:00	0.2			1.7			11.8		1	0.2			1.7			11.9		1
08/26/20 18:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/26/20 19:00	1.2			1.7			14.3		1	1.1			1.7			14.3		1
08/26/20 20:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/26/20 21:00	0.8			1.7			14.6		1	0.7			1.7			14.5		1
08/26/20 22:00	0.9			1.7			14.4		1	0.8			1.7			14.3		1
08/26/20 23:00	0.8			1.7			14.4		1	0.9			1.7			14.3		1
08/27/20 0:00	0.7			1.7			14.5		1	0.7			1.7			14.5		1
08/27/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/27/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/27/20 3:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/27/20 4:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/27/20 5:00	0.8			1.7			14.5		1	0.7			1.7			14.4		1
08/27/20 6:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/27/20 7:00	0.7			1.7			14.5		1	0.7			1.7			14.4		1
08/27/20 8:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
08/27/20 9:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/27/20 10:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/27/20 11:00	1			1.7			13.9		1	1.2			1.7			13.9		1
08/27/20 12:00	1			1.7			14		1	1			1.7			13.9		1
08/27/20 13:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
08/27/20 14:00	0.3			1.7			12.7		1	0.4			1.7			12.8		1
08/27/20 15:00	0.4			1.7			13		1	0.5			1.7			13		1
08/27/20 16:00	0.3			1.7			12.6		1	0.3			1.7			12.7		1
08/27/20 17:00	0.2			1.7			12.5		1	0.2			1.7			12.5		1
08/27/20 18:00	0.6			1.7			13.3		1	0.6			1.7			13.3		1
08/27/20 19:00	1.1			1.7			13.9		1	1.1			1.7			13.9		1
08/27/20 20:00	0.9			1.7			14.5		1	0.8			1.7			14.4		1
08/27/20 21:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/27/20 22:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/27/20 23:00	0.8			1.7			14.5		1	0.9			1.7			14.3		1
08/28/20 0:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/28/20 2:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 3:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 4:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 5:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 6:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 7:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1
08/28/20 8:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/28/20 9:00	0.9			1.7			14.4		1	0.8			1.7			14.5		1
08/28/20 10:00	0.9			1.7			14.5		1	1			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/28/20 11:00	0.5			1.7			13		1	0.5			1.7			13		1
08/28/20 12:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/28/20 13:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/28/20 14:00	0.3			1.7			12.6		1	0.3			1.7			12.6		1
08/28/20 15:00	0.2			1.7			12.5		1	0.3			1.7			12.5		1
08/28/20 16:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/28/20 17:00	0.2			1.7			12		1	0.2			1.7			12		1
08/28/20 18:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/28/20 19:00	0.9			1.7			14.5		1	0.9			1.7			14.4		1
08/28/20 20:00	0.8			1.7			14.6		1	0.8			1.7			14.5		1
08/28/20 21:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/28/20 22:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/28/20 23:00	0.9			1.6			14.4		1	0.8			1.7			14.4		1
08/29/20 0:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
08/29/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 4:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 5:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 6:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 7:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 8:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1
08/29/20 9:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/29/20 10:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/29/20 11:00	0.9			1.7			14.5		1	0.9			1.7			14.5		1
08/29/20 12:00	0.6			1.7			13.3		1	0.7			1.7			13.3		1
08/29/20 13:00	0.2			1.7			11.9		1	0.2			1.7			12		1
08/29/20 14:00	0.2			1.7			12.3		1	0.2			1.7			12.4		1
08/29/20 15:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
08/29/20 16:00	0.3			1.7			12.8		1	0.3			1.7			12.8		1
08/29/20 17:00	0.6			1.7			13.5		1	0.6			1.7			13.5		1
08/29/20 18:00	1			1.8			14.4		1	1			1.7			14.3		1
08/29/20 19:00	0.8			1.6			14.4		1	0.8			1.7			14.4		1
08/29/20 20:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/29/20 21:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/29/20 22:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/29/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/30/20 0:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 1:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 4:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 5:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 6:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 7:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
08/30/20 8:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/30/20 9:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
08/30/20 10:00	0.9			1.7			14.5		1	0.8			1.7			14.5		1
08/30/20 11:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
08/30/20 12:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/30/20 13:00	0.2			1.7			12		1	0.3			1.7			12.1		1
08/30/20 14:00	0.2			1.7			11.7		1	0.2			1.7			11.8		1
08/30/20 15:00	0.2			1.7			12.1		1	0.2			1.7			12.2		1
08/30/20 16:00	0.4			1.7			12.9		1	0.4			1.7			12.9		1
08/30/20 17:00	0.4			1.7			13		1	0.4			1.7			13		1
08/30/20 18:00	0.8			1.8			14.4		1	0.8			1.8			14.3		1
08/30/20 19:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
08/30/20 20:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/30/20 21:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
08/30/20 22:00	0.9			1.6			14.3		1	0.9			1.7			14.4		1
08/30/20 23:00	0.4			1.6			12.3		1	0			0			16.7		1
08/31/20 0:00	0.2			1.7			12.1		1	0	X		0	X		0	X	1
08/31/20 1:00	0.4			1.7			12.9		1	0	X		0	X		0	X	1
08/31/20 2:00	1			1.7			13.6		1	0	X		0	X		0	X	1
08/31/20 3:00	1.1			1.7			13.6		1	0	X		0	X		0	X	1
08/31/20 4:00	0.6			1.6			13.1		1	0	X		0	X		0	X	1
08/31/20 5:00	1			1.7			13.5		1	0	X		0	X		0	X	1
08/31/20 6:00	0.6			1.7			13.1		1	0	X		0	X		0	X	1
08/31/20 7:00	0.4			1.7			12.7		1	0	X		0	X		0	X	1
08/31/20 8:00	0.3			1.7			12.4		1	0	X		0	X		0	X	1
08/31/20 9:00	0.4			1.7			12.9		1	0	X		0	X		0	X	1
08/31/20 10:00	0.4			1.7			12.9		1	0	X		0	X		0	X	1
08/31/20 11:00	0.3			1.7			12.4		1	0	X		0	X		0	X	1
08/31/20 12:00	0.2			1.7			12		1	0	X		0	X		0	X	1
08/31/20 13:00	0.2			1.7			12		1	0	X		0	X		0	X	1
08/31/20 14:00	0.3			1.7			12.6		1	0			0			17.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:00	1.1			1.8			14		1	0.8			1.4			14.4		1
08/31/20 16:00	0.6			1.7			13.3		1	0.7			1.7			13.3		1
08/31/20 17:00	0.4			1.7			12.8		1	0.4			1.7			12.9		1
08/31/20 18:00	0.5			1.7			13.2		1	0.6			1.7			13.2		1
08/31/20 19:00	0.7			1.7			13.4		1	0.7			1.7			13.4		1
08/31/20 20:00	0.9			1.7			14.4		1	0.9			1.7			14.4		1
08/31/20 21:00	0.8			1.7			14.5		1	0.8			1.6			14.5		1
08/31/20 22:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
08/31/20 23:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
09/01/20 0:00	0.9			1.7			14.4		1	0.9			1.7			14.3		1
09/01/20 1:00	0.8			1.7			14.5		1	0.8			1.7			14.4		1
09/01/20 2:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
09/01/20 3:00	0.8			1.7			14.5		1	0.7			1.7			14.5		1
09/01/20 4:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
09/01/20 5:00	1			1.7			14.4		1	0.8			1.7			14.4		1
09/01/20 6:00	0.9			1.7			14.4		1	0.8			1.7			14.4		1
09/01/20 7:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
09/01/20 8:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
09/01/20 9:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
09/01/20 10:00	0.8			1.7			14.5		1	0.8			1.7			14.5		1
09/01/20 11:00	1.3			1.7			14.1		1	1.5			1.6			14		1
09/01/20 12:00	0.2			1.7			12.1		1	0.2			1.7			12.1		1
09/01/20 13:00	0.2			1.7			12		1	0.2			1.7			12		1
09/01/20 14:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
09/01/20 15:00	0.2			1.7			11.8		1	0.2			1.7			11.8		1
09/01/20 16:00	0.2			1.7			11.8		1	0.2			1.7			11.9		1
09/01/20 17:00	0.3			1.7			12.4		1	0.3			1.7			12.4		1
09/01/20 18:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
09/01/20 19:00	0.5			1.7			13.1		1	0.5			1.7			13.1		1
09/01/20 20:00	0.4			1.7			12.8		1	0.4			1.7			12.8		1
09/01/20 21:00	1.1			1.8			14.2		1	1.1			1.7			14.2		1
09/01/20 22:00	0.9			1.7			14.3		1	0.8			1.7			14.3		1
09/01/20 23:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
09/02/20 0:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
09/02/20 1:00	0.9			1.7			14.3		1	0.8			1.7			14.3		1
09/02/20 2:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
09/02/20 3:00	0.8			1.7			14.4		1	0.8			1.7			14.3		1
09/02/20 4:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/02/20 5:00	0.9			1.7			14.3		1	0.9			1.7			14.3		1
09/02/20 6:00	0.9			1.7			14.3		1	0.8			1.7			14.3		1
09/02/20 7:00	0.8			1.7			14.4		1	0.7			1.7			14.4		1
09/02/20 8:00	0.8			1.7			14.4		1	0.7			1.7			14.5		1
09/02/20 9:00	0.8			1.7			14.4		1	0.8			1.7			14.4		1
09/02/20 10:00	0.8			1.7			14.5		1	0.7			1.7			14.6		1
09/02/20 11:00	0.8			1.7			14.5		1	0.7			1.7			14.6		1
09/02/20 12:00	0.8			1.7			14.4		1	0.7			1.7			14.6		1
09/02/20 13:00	1			1.4			13.9		1	1.3			1.7			14.3		1
09/02/20 14:00	0.1			1.7			12.7		1	0.3			1.7			12.8		1
09/02/20 15:00	0.1			1.7			12.6		1	0.3			1.7			12.8		1
09/02/20 16:00	0.1			1.7			12.6		1	0.2			1.7			12.8		1
09/02/20 17:00	0.1			1.7			12.6		1	0.2			1.7			12.7		1
09/02/20 18:00	0.3			1.7			13.1		1	0.5			1.7			13.2		1
09/02/20 19:00	0.9			1.7			14		1	1			1.7			14.1		1
09/02/20 20:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/02/20 21:00	0.8			1.7			13.9		1	0.9			1.7			13.9		1
09/02/20 22:00	0.6			1.8			14.5		1	0.7			1.7			14.6		1
09/02/20 23:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 0:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 1:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.4		1
09/03/20 3:00	0.6			1.7			14.5		1	0.8			1.7			14.4		1
09/03/20 4:00	0.6			1.6			14.4		1	0.7			1.7			14.5		1
09/03/20 5:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 6:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 7:00	0.6			1.7			14.5		1	0.7			1.7			14.5		1
09/03/20 8:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/03/20 9:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/03/20 10:00	0.6			1.7			14.4		1	0.7			1.7			14.6		1
09/03/20 11:00	0.9			1.7			14.3		1	1.1			1.7			14.4		1
09/03/20 12:00	0.1			1.7			12.5		1	0.2			1.7			12.6		1
09/03/20 13:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/03/20 14:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/03/20 15:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/03/20 16:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/03/20 17:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/03/20 18:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/03/20 19:00	0.1			1.7			12.1		1	0.1			1.7			12.2		1
09/03/20 20:00	0.1			1.7			12.3		1	0.2			1.7			12.4		1
09/03/20 21:00	0.1			1.7			12.5		1	0.2			1.7			12.6		1
09/03/20 22:00	1.1			1.8			14.2		1	1.2			1.7			14.3		1
09/03/20 23:00	0.6			1.7			14.5		1	0.7			1.7			14.5		1
09/04/20 0:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/04/20 1:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/04/20 2:00	0.7			1.7			14.3		1	0.7			1.7			14.5		1
09/04/20 3:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/04/20 4:00	0.7			1.7			14.3		1	0.7			1.6			14.5		1
09/04/20 5:00	0.8			1.7			14.3		1	0.8			1.7			14.4		1
09/04/20 6:00	0.7			1.7			14.3		1	0.8			1.7			14.4		1
09/04/20 7:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/04/20 8:00	0.7			1.7			14.4		1	0.7			1.7			14.6		1
09/04/20 9:00	0.7			1.7			14.4		1	0.7			1.7			14.6		1
09/04/20 10:00	0.6			1.7			14.4		1	0.7			1.7			14.6		1
09/04/20 11:00	0.9			1.7			13.8		1	1.1			1.7			13.9		1
09/04/20 12:00	0.2			1.7			12.8		1	0.3			1.7			12.9		1
09/04/20 13:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
09/04/20 14:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/04/20 15:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/04/20 16:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/04/20 17:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/04/20 18:00	0.1			1.7			11.6		1	0.2			1.7			11.8		1
09/04/20 19:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/04/20 20:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/04/20 21:00	0.1			1.7			11.9		1	0.1			1.7			12.1		1
09/04/20 22:00	0.4			1.7			13.1		1	0.5			1.7			13.2		1
09/04/20 23:00	0.8			1.8			14.4		1	0.8			1.7			14.5		1
09/05/20 0:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
09/05/20 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/05/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/05/20 3:00	0.7			1.7			14.5		1	1			1.7			14.4		1
09/05/20 4:00	0.8			1.7			14.5		1	1.1			1.6			14.4		1
09/05/20 5:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/05/20 6:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/05/20 7:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/05/20 8:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/20 9:00	0.7			1.7			14.6		1	0.8			1.7			14.7		1
09/05/20 10:00	0.9			1.7			13.8		1	1.1			1.6			13.9		1
09/05/20 11:00	0.1			1.7			12.6		1	0.2			1.7			12.7		1
09/05/20 12:00	0.1			1.7			11.9		1	0.1			1.7			12.1		1
09/05/20 13:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/05/20 14:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/05/20 15:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/05/20 16:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/05/20 17:00	0.1			1.7			11.7		1	0.1			1.7			12		1
09/05/20 18:00	0.2			1.7			12.8		1	0.3			1.7			12.9		1
09/05/20 19:00	0.1			1.7			12.4		1	0.2			1.7			12.5		1
09/05/20 20:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/05/20 21:00	0.1			1.7			12.5		1	0.2			1.7			12.6		1
09/05/20 22:00	1.1			1.7			14		1	1.3			1.7			14.1		1
09/05/20 23:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/06/20 0:00	0.9			1.7			14.4		1	1			1.7			14.6		1
09/06/20 1:00	1.1			1.7			14.5		1	1.3			1.7			14.5		1
09/06/20 2:00	1			1.7			14.5		1	1			1.7			14.6		1
09/06/20 3:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/06/20 4:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/06/20 5:00	0.9			1.8			14.5		1	0.9			1.8			14.6		1
09/06/20 6:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/06/20 7:00	0.8			1.7			14.4		1	1			1.7			14.4		1
09/06/20 8:00	0.9			1.7			14.4		1	0.9			1.7			14.5		1
09/06/20 9:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/06/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/06/20 11:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/06/20 12:00	0.7			1.7			13.6		1	0.8			1.6			13.7		1
09/06/20 13:00	0.2			1.7			12.7		1	0.3			1.7			12.8		1
09/06/20 14:00	0.1			1.7			12		1	0.1			1.7			12.2		1
09/06/20 15:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/06/20 16:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/06/20 17:00	0.1			1.7			11.7		1	0.1			1.7			11.8		1
09/06/20 18:00	0.1			1.7			11.8		1	0.1			1.7			12		1
09/06/20 19:00	0.1			1.7			12.2		1	0.2			1.7			12.3		1
09/06/20 20:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
09/06/20 21:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
09/06/20 22:00	0.4			1.7			13		1	0.5			1.7			13.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/06/20 23:00	0.7			1.8			14.3		1	0.9			1.7			14.4		1
09/07/20 0:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/07/20 1:00	0.9			1.7			14.3		1	1.1			1.7			14.4		1
09/07/20 2:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/07/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/07/20 4:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/07/20 5:00	0.9			1.7			14.5		1	0.9			1.7			14.6		1
09/07/20 6:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/07/20 7:00	1.2			1.7			14.4		1	1.3			1.7			14.5		1
09/07/20 8:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/07/20 9:00	0.7			1.7			13.5		1	0.8			1.6			13.6		1
09/07/20 10:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/07/20 11:00	0.1			1.7			12		1	0.1			1.7			12.2		1
09/07/20 12:00	0.4			1.7			13.1		1	0.5			1.7			13.2		1
09/07/20 13:00	0.1			1.7			11.9		1	0.1			1.7			12		1
09/07/20 14:00	0.3			1.7			13		1	0.4			1.7			13.2		1
09/07/20 15:00	0.5			1.7			13.4		1	0.6			1.7			13.5		1
09/07/20 16:00	0.1			1.7			12.5		1	0.2			1.7			12.7		1
09/07/20 17:00	0.5			1.7			13.4		1	0.6			1.7			13.5		1
09/07/20 18:00	1			1.7			14.1		1	1.1			1.7			14.1		1
09/07/20 19:00	1.4			1.7			14.4		1	1.7			1.7			14.5		1
09/07/20 20:00	1.7			1.7			14.1		1	1.8			1.7			14.1		1
09/07/20 21:00	0.4			1.7			13		1	0.5			1.7			13.1		1
09/07/20 22:00	0.7			1.8			14.4		1	0.8			1.8			14.5		1
09/07/20 23:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
09/08/20 0:00	0.8			1.7			14.3		1	0.8			1.7			14.4		1
09/08/20 1:00	0.9			1.7			14.3		1	0.9			1.7			14.5		1
09/08/20 2:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
09/08/20 3:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/08/20 4:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
09/08/20 5:00	0.7			1.7			14.5		1	0.8			1.7			14.7		1
09/08/20 6:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/08/20 7:00	0.8			1.7			13.8		1	1			1.7			13.9		1
09/08/20 8:00	0.5			1.7			13.3		1	0.6			1.7			13.4		1
09/08/20 9:00	0.1			1.7			12.6		1	0.3			1.7			12.8		1
09/08/20 10:00	0.6			1.7			13.6		1	0.7			1.7			13.7		1
09/08/20 11:00	0.6			1.8			14.5		1	0.7			1.8			14.6		1
09/08/20 12:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/08/20 13:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/08/20 14:00	0.6			1.7			14.4		1	0.8			1.7			14.5		1
09/08/20 15:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/08/20 16:00	0.7			1.7			14.6		1	0.7			1.7			14.7		1
09/08/20 17:00	0.6			1.7			14.6		1	0.8			1.7			14.7		1
09/08/20 18:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/08/20 19:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/08/20 20:00	0.6			1.7			14.5		1	0.8			1.7			14.7		1
09/08/20 21:00	0.6			1.7			14.6		1	0.7			1.7			14.6		1
09/08/20 22:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
09/08/20 23:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
09/09/20 0:00	0.7			1.7			14.6		1	0.8			1.7			14.7		1
09/09/20 1:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
09/09/20 2:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/09/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/09/20 4:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/09/20 5:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/09/20 6:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/09/20 7:00	0.3			1.7			12		1	0.5			1.6			12.1		1
09/09/20 8:00	0.1			1.7			11.6		1	0.2			1.7			11.8		1
09/09/20 9:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
09/09/20 10:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/09/20 11:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/09/20 12:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/09/20 13:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/09/20 14:00	0.1			1.7			11.7		1	0.1			1.7			11.9		1
09/09/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/09/20 16:00	0			1.7			11.8		1	0.1			1.7			11.9		1
09/09/20 17:00	0.7			1.8			14.2		1	0.8			1.8			14.4		1
09/09/20 18:00	0.7			1.7			14.3		1	0.7			1.7			14.5		1
09/09/20 19:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
09/09/20 20:00	0.6			1.7			14.4		1	0.8			1.7			14.4		1
09/09/20 21:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
09/09/20 22:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
09/09/20 23:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
09/10/20 0:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/10/20 1:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/10/20 2:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/10/20 3:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/10/20 4:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/10/20 5:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/10/20 6:00	1.1			1.7			14.5		1	1.2			1.7			14.6		1
09/10/20 7:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/10/20 8:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/10/20 9:00	0.8			1.7			14.4		1	0.9			1.7			14.4		1
09/10/20 10:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/10/20 11:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/10/20 12:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/10/20 13:00	1.1			1.7			14.2		1	1.4			1.7			14.2		1
09/10/20 14:00	0.8			1.7			14.3		1	1			1.7			14.4		1
09/10/20 15:00	1.2			1.7			14.3		1	1.7			1.7			14.4		1
09/10/20 16:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/10/20 17:00	1.3			1.7			14.2		1	2			1.7			14.3		1
09/10/20 18:00	0.9			1.7			14.5		1	1.1			1.7			14.5		1
09/10/20 19:00	0.4			1.7			12.8		1	0.5			1.7			13		1
09/10/20 20:00	1.2			1.8			14		1	1.2			1.7			14.1		1
09/10/20 21:00	1.2			1.7			14.2		1	1.3			1.7			14.3		1
09/10/20 22:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
09/10/20 23:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
09/11/20 0:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
09/11/20 1:00	0.7			1.7			14.5		1	1			1.7			14.4		1
09/11/20 2:00	0.8			1.7			14.5		1	0.8			1.7			14.6		1
09/11/20 3:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/11/20 4:00	1			1.6			14.3		1	1.1			1.6			14.4		1
09/11/20 5:00	1			1.7			14.4		1	1			1.7			14.5		1
09/11/20 6:00	0.9			1.7			14.4		1	1			1.7			14.6		1
09/11/20 7:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/11/20 8:00	1			1.7			14.3		1	1.1			1.7			14.4		1
09/11/20 9:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/11/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/11/20 11:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
09/11/20 12:00	1.3			1.7			14.2		1	1.6			1.7			14.2		1
09/11/20 13:00	1.1			1.7			13.8		1	1.2			1.7			13.9		1
09/11/20 14:00	0.5			1.7			13.1		1	0.6			1.7			13.2		1
09/11/20 15:00	0.9			1.8			14.4		1	1.1			1.8			14.6		1
09/11/20 16:00	0.8			1.7			14.5		1	1			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/11/20 17:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/11/20 18:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/11/20 19:00	0.8			1.7			14.4		1	1			1.7			14.4		1
09/11/20 20:00	0.8			1.7			14.4		1	1			1.7			14.5		1
09/11/20 21:00	0.8			1.7			14.5		1	1			1.7			14.6		1
09/11/20 22:00	1			1.7			14.4		1	1.2			1.7			14.5		1
09/11/20 23:00	1.2			1.7			14.4		1	1.2			1.7			14.5		1
09/12/20 0:00	1.1			1.7			14.4		1	1.4			1.7			14.4		1
09/12/20 1:00	1			1.7			14.4		1	1.1			1.7			14.5		1
09/12/20 2:00	1			1.7			14.4		1	1.1			1.7			14.5		1
09/12/20 3:00	1.4			1.7			14.4		1	1.4			1.7			14.5		1
09/12/20 4:00	1.7			1.6			14.4		1	1.8			1.7			14.5		1
09/12/20 5:00	1.4			1.7			14.4		1	1.6			1.7			14.5		1
09/12/20 6:00	1.5			1.7			14.4		1	1.6			1.7			14.4		1
09/12/20 7:00	1.3			1.7			14.4		1	1.4			1.7			14.5		1
09/12/20 8:00	1.1			1.7			14.4		1	1.2			1.7			14.4		1
09/12/20 9:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
09/12/20 10:00	0.8			1.7			14.4		1	0.8			1.7			14.5		1
09/12/20 11:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
09/12/20 12:00	0.9			1.7			14.4		1	1.1			1.7			14.5		1
09/12/20 13:00	0.3			1.7			12.8		1	0.5			1.7			12.9		1
09/12/20 14:00	0.1			1.7			12		1	0.2			1.7			12.2		1
09/12/20 15:00	0.9			1.7			14		1	1.1			1.7			14		1
09/12/20 16:00	0.9			1.7			13.8		1	1.1			1.7			13.9		1
09/12/20 17:00	0.1			1.7			12.3		1	0.3			1.7			12.4		1
09/12/20 18:00	0.8			1.8			14.4		1	0.9			1.7			14.4		1
09/12/20 19:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/12/20 20:00	0.9			1.7			14.3		1	1			1.7			14.5		1
09/12/20 21:00	1.2			1.7			14.4		1	1.6			1.7			14.5		1
09/12/20 22:00	1			1.7			14.4		1	1.2			1.7			14.5		1
09/12/20 23:00	1			1.7			14.3		1	1.1			1.7			14.5		1
09/13/20 0:00	1			1.7			14.3		1	1.2			1.7			14.4		1
09/13/20 1:00	0.9			1.7			14.4		1	1.2			1.7			14.4		1
09/13/20 2:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/13/20 3:00	1			1.7			14.4		1	1.1			1.7			14.5		1
09/13/20 4:00	1			1.7			14.4		1	1.1			1.7			14.5		1
09/13/20 5:00	1.1			1.7			14.4		1	1.2			1.7			14.5		1
09/13/20 6:00	1			1.7			14.5		1	1.1			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/13/20 7:00	1			1.7			14.5		1	1.1			1.7			14.6		1
09/13/20 8:00	1.1			1.7			14.4		1	1.2			1.7			14.4		1
09/13/20 9:00	0.9			1.7			14.4		1	1			1.7			14.6		1
09/13/20 10:00	1.2			1.7			14.5		1	1			1.7			14.6		1
09/13/20 11:00	1.1			1.7			13.9		1	1.3			1.7			14		1
09/13/20 12:00	0.9			1.7			13.6		1	0.9			1.7			13.7		1
09/13/20 13:00	0.4			1.7			13		1	0.5			0.8			13		1
09/13/20 14:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
09/13/20 15:00	0.3			1.7			12.9		1	0.4			1.7			13		1
09/13/20 16:00	1.1			1.7			14.1		1	1.4			1.7			14.2		1
09/13/20 17:00	1			1.7			14		1	1.2			1.7			14.1		1
09/13/20 18:00	1			1.7			14		1	1.2			1.7			14.1		1
09/13/20 19:00	0.8			1.7			14.5		1	1			1.7			14.6		1
09/13/20 20:00	0.6			1.6			13.4		1	0.8			1.6			13.5		1
09/13/20 21:00	1.1			1.7			14.1		1	1.3			1.7			14.2		1
09/13/20 22:00	0.9			1.7			14.4		1	1.1			1.7			14.5		1
09/13/20 23:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/14/20 0:00	0.7			1.7			14.5		1	1			1.7			14.5		1
09/14/20 1:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/14/20 2:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/14/20 3:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/14/20 4:00	0.7			1.7			14.4		1	0.9			1.7			14.6		1
09/14/20 5:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
09/14/20 6:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
09/14/20 7:00	0.9			1.7			14.3		1	1			1.7			14.4		1
09/14/20 8:00	0.9			1.7			14.3		1	1			1.7			14.5		1
09/14/20 9:00	0.8			1.7			14.4		1	0.9			1.7			14.6		1
09/14/20 10:00	0.8			1.7			14.5		1	1			1.7			14.7		1
09/14/20 11:00	0.7			1.7			14.5		1	1			1.7			14.6		1
09/14/20 12:00	1			1.7			13.8		1	1			1.7			13.8		1
09/14/20 13:00	0.1			1.7			12.5		1	0.3			1.7			12.7		1
09/14/20 14:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/14/20 15:00	0.2			1.7			12.5		1	0.3			1.7			12.7		1
09/14/20 16:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
09/14/20 17:00	0.1			1.7			11.8		1	0.2			1.7			11.9		1
09/14/20 18:00	0.2			1.7			12.3		1	0.3			1.7			12.5		1
09/14/20 19:00	0.7			1.8			14.5		1	0.9			1.7			14.6		1
09/14/20 20:00	0.7			1.7			14.6		1	1			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/14/20 21:00	1			1.7			14.3		1	1.3			1.7			14.4		1
09/14/20 22:00	0.7			1.8			14.5		1	0.9			1.7			14.6		1
09/14/20 23:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/15/20 0:00	0.7			1.7			14.5		1	1			1.7			14.4		1
09/15/20 1:00	0.7			1.7			14.5		1	1			1.7			14.5		1
09/15/20 2:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/15/20 3:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/15/20 4:00	0.7			1.7			14.5		1	0.9			1.6			14.6		1
09/15/20 5:00	0.8			1.7			14.4		1	1			1.7			14.4		1
09/15/20 6:00	0.7			1.7			14.5		1	1			1.7			14.4		1
09/15/20 7:00	0.8			1.7			14.3		1	1			1.7			14.4		1
09/15/20 8:00	0.7			1.7			14.4		1	0.9			1.7			14.6		1
09/15/20 9:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
09/15/20 10:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/15/20 11:00	1.1			1.7			14.1		1	1.7			1.7			14.2		1
09/15/20 12:00	0.2			1.7			12.8		1	0.4			1.7			12.9		1
09/15/20 13:00	0.1			1.7			12		1	0.2			1.7			12.1		1
09/15/20 14:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/15/20 15:00	0.1			1.7			11.9		1	0.2			1.7			12.1		1
09/15/20 16:00	0.1			1.7			12.4		1	0.3			1.7			12.6		1
09/15/20 17:00	0.1			1.7			12.3		1	0.2			1.7			12.5		1
09/15/20 18:00	0.4			1.7			13.3		1	0.6			1.7			13.4		1
09/15/20 19:00	0.8			1.8			14.1		1	1			1.7			14.2		1
09/15/20 20:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/15/20 21:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/15/20 22:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/15/20 23:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/16/20 0:00	0.8			1.7			14.3		1	0.9			1.7			14.5		1
09/16/20 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/16/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/16/20 3:00	0.6			1.7			14.5		1	0.9			1.7			14.4		1
09/16/20 4:00	0.7			1.7			14.3		1	0.9			1.6			14.4		1
09/16/20 5:00	0.8			1.7			14.3		1	0.8			1.7			14.5		1
09/16/20 6:00	0.8			1.7			14.3		1	0.8			1.7			14.5		1
09/16/20 7:00	0.7			1.7			14.3		1	0.8			1.7			14.6		1
09/16/20 8:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/16/20 9:00	0.7			1.7			14.5		1	1			1.7			14.6		1
09/16/20 10:00	1			1.7			14		1	1.2			1.7			14.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/20 11:00	0.3			1.7			13		1	0.5			1.7			13.2		1
09/16/20 12:00	0.1			1.7			12.1		1	0.2			1.5			12.2		1
09/16/20 13:00	0.1			1.7			12.4		1	0.3			1.7			12.6		1
09/16/20 14:00	0			1.7			11.9		1	0.2			1.7			12		1
09/16/20 15:00	0			1.7			11.8		1	0.2			1.7			12		1
09/16/20 16:00	0			1.7			11.8		1	0.2			1.7			12		1
09/16/20 17:00	0			1.7			11.9		1	0.2			1.7			12		1
09/16/20 18:00	0.1			1.7			12.5		1	0.3			1.7			12.6		1
09/16/20 19:00	0.6			1.7			13.5		1	0.7			1.7			13.6		1
09/16/20 20:00	0.9			1.7			14		1	1.1			1.7			14		1
09/16/20 21:00	0.9			1.7			13.9		1	1.1			1.7			14		1
09/16/20 22:00	0.6			1.8			14.4		1	0.8			1.7			14.5		1
09/16/20 23:00	0.6			1.7			14.3		1	0.7			1.7			14.5		1
09/17/20 0:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/17/20 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/17/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/17/20 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/17/20 4:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/17/20 5:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/17/20 6:00	0.7			1.7			14.3		1	0.8			1.7			14.6		1
09/17/20 7:00	0.8			1.7			14.3		1	0.8			1.7			14.6		1
09/17/20 8:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/17/20 9:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/17/20 10:00	1.1			1.7			14.1		1	1.6			1.7			14.2		1
09/17/20 11:00	0.8			1.7			13.9		1	1			1.7			14		1
09/17/20 12:00	0.7			1.7			13.7		1	0.9			1.7			13.8		1
09/17/20 13:00	0.4			1.7			13.4		1	0.6			1.7			13.5		1
09/17/20 14:00	0.3			1.7			12.9		1	0.5			1.7			13.1		1
09/17/20 15:00	0			1.7			11.8		1	0.2			1.7			12		1
09/17/20 16:00	0			1.7			11.7		1	0.2			1.7			11.9		1
09/17/20 17:00	0.1			1.7			12.7		1	0.3			1.7			12.8		1
09/17/20 18:00	0.3			1.7			13.1		1	0.5			1.7			13.2		1
09/17/20 19:00	0.8			1.7			13.9		1	1			1.7			14		1
09/17/20 20:00	0.7			1.7			13.7		1	0.9			1.7			13.8		1
09/17/20 21:00	0.6			1.7			13.4		1	0.7			1.7			13.5		1
09/17/20 22:00	0.6			1.8			14.4		1	0.8			1.7			14.5		1
09/17/20 23:00	0.7			1.7			14.3		1	0.8			1.7			14.4		1
09/18/20 0:00	0.5			1.7			14.4		1	0.8			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/18/20 1:00	0.5			1.7			14.4		1	0.8			1.7			14.4		1
09/18/20 2:00	0.5			1.7			14.4		1	0.7			1.7			14.4		1
09/18/20 3:00	0.5			1.7			14.4		1	0.7			1.7			14.5		1
09/18/20 4:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
09/18/20 5:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/18/20 6:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/18/20 7:00	0.6			1.7			14.3		1	0.7			1.7			14.6		1
09/18/20 8:00	1.1			1.7			14.2		1	1.2			1.7			14.2		1
09/18/20 9:00	0.9			1.7			14.1		1	1.1			1.7			14.2		1
09/18/20 10:00	0.7			1.7			13.7		1	0.8			1.7			13.8		1
09/18/20 11:00	0.5			1.7			13.4		1	0.6			1.7			13.5		1
09/18/20 12:00	0.4			1.7			13.2		1	0.6			1.7			13.3		1
09/18/20 13:00	0.2			1.7			12.7		1	0.4			1.7			12.9		1
09/18/20 14:00	0.1			1.7			12.8		1	0.3			1.7			12.9		1
09/18/20 15:00	0.9			1.8			14.1		1	1.1			1.7			14.1		1
09/18/20 16:00	0.8			1.7			13.9		1	1			1.7			14		1
09/18/20 17:00	0.3			1.7			13.2		1	0.5			1.7			13.3		1
09/18/20 18:00	1			1.8			14.1		1	1.1			1.7			14.2		1
09/18/20 19:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/18/20 20:00	0.6			1.6			13.6		1	0.8			1.7			13.7		1
09/18/20 21:00	0.7			1.8			14.4		1	0.8			1.7			14.6		1
09/18/20 22:00	0.6			1.7			14.3		1	0.8			1.7			14.5		1
09/18/20 23:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/19/20 0:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/19/20 1:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/19/20 2:00	0.6			1.7			14.4		1	0.7			1.7			14.6		1
09/19/20 3:00	0.6			1.7			14.4		1	0.7			1.7			14.6		1
09/19/20 4:00	0.5			1.6			14.4		1	0.7			1.7			14.6		1
09/19/20 5:00	0.7			1.7			14.4		1	0.8			1.7			14.4		1
09/19/20 6:00	0.6			1.7			14.4		1	0.9			1.7			14.4		1
09/19/20 7:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/19/20 8:00	0.6			1.7			14.3		1	0.7			1.7			14.6		1
09/19/20 9:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/19/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/19/20 11:00	1			1.7			14		1	1.2			1.7			14.1		1
09/19/20 12:00	0.4			1.7			13.3		1	0.6			1.7			13.4		1
09/19/20 13:00	0.4			1.7			13.2		1	0.5			1.7			13.3		1
09/19/20 14:00	0.5			1.7			13.4		1	0.7			1.7			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/19/20 15:00	0.4			1.7			13.3		1	0.6			1.7			13.4		1
09/19/20 16:00	1			1.7			14.3		1	1.5			1.7			14.4		1
09/19/20 17:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/19/20 18:00	0.9			1.7			14.2		1	1.1			1.7			14.3		1
09/19/20 19:00	0.4			1.7			13.2		1	0.6			1.7			13.4		1
09/19/20 20:00	0.7			1.8			14.5		1	0.9			1.7			14.6		1
09/19/20 21:00	0.6			1.7			14.4		1	0.8			1.7			14.6		1
09/19/20 22:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/19/20 23:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
09/20/20 0:00	0.7			1.7			14.5		1	1			1.7			14.5		1
09/20/20 1:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 3:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 4:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 5:00	0.7			1.7			14.4		1	0.8			1.7			14.6		1
09/20/20 6:00	0.6			1.7			14.4		1	0.8			1.7			14.6		1
09/20/20 7:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/20/20 8:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/20/20 9:00	0.7			1.7			14.4		1	0.9			1.7			14.5		1
09/20/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 11:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
09/20/20 12:00	0.6			1.7			13.4		1	0.8			1.7			13.5		1
09/20/20 13:00	0.2			1.7			12.7		1	0.4			1.7			12.8		1
09/20/20 14:00	0.1			1.7			12		1	0.2			1.7			12.2		1
09/20/20 15:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/20/20 16:00	0.3			1.7			13		1	0.5			1.7			13.1		1
09/20/20 17:00	0.9			1.8			14.3		1	1.1			1.8			14.3		1
09/20/20 18:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/20/20 19:00	0.7			1.7			14.5		1	0.9			1.8			14.6		1
09/20/20 20:00	0.8			1.7			13.7		1	1			1.7			13.7		1
09/20/20 21:00	0.8			1.8			14.5		1	0.9			1.7			14.6		1
09/20/20 22:00	0.8			1.7			14.3		1	0.9			1.7			14.5		1
09/20/20 23:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
09/21/20 0:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
09/21/20 1:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/21/20 2:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/21/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
09/21/20 4:00	0.6			1.7			14.5		1	1			1.6			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/21/20 5:00	0.8			1.7			14.3		1	0.9			1.7			14.5		1
09/21/20 6:00	0.8			1.7			14.3		1	0.9			1.7			14.6		1
09/21/20 7:00	0.7			1.7			14.4		1	0.9			1.7			14.6		1
09/21/20 8:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
09/21/20 9:00	0.7			1.2			14.5		1	0.9			1.7			14.6		1
09/21/20 10:00	1.1			1.7			14.1		1	1.4			1.7			14.2		1
09/21/20 11:00	0.2			1.7			12.5		1	0.3			1.7			12.7		1
09/21/20 12:00	0.1			1.7			12.2		1	0.2			1.7			12.3		1
09/21/20 13:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/21/20 14:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/21/20 15:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/21/20 16:00	0.1			1.7			12		1	0.2			1.7			12.2		1
09/21/20 17:00	0.1			1.7			12		1	0.2			1.7			12.1		1
09/21/20 18:00	0.1			1.7			12.1		1	0.2			1.7			12.3		1
09/21/20 19:00	0.7			1.7			13.7		1	0.8			1.7			13.8		1
09/21/20 20:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/21/20 21:00	1.1			1.7			14.2		1	1.3			1.7			14.3		1
09/21/20 22:00	0.7			1.7			14.4		1	0.7			1.7			14.5		1
09/21/20 23:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/22/20 0:00	0.7			1.7			14.4		1	0.9			1.7			14.4		1
09/22/20 1:00	0.6			1.7			14.5		1	0.9			1.7			14.4		1
09/22/20 2:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/22/20 3:00	0.6			1.7			14.5		1	0.8			1.7			14.5		1
09/22/20 4:00	0.7			1.6			14.4		1	0.9			1.6			14.4		1
09/22/20 5:00	0.8			1.7			14.3		1	0.8			1.7			14.5		1
09/22/20 6:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/22/20 7:00	0.7			1.7			14.4		1	0.7			1.7			14.6		1
09/22/20 8:00	0.6			1.7			14.5		1	0.8			1.7			14.7		1
09/22/20 9:00	1.1			1.7			14.3		1	1.8			1.7			14.3		1
09/22/20 10:00	0.6			1.7			13.4		1	0.7			1.7			13.5		1
09/22/20 11:00	0.4			1.7			13.2		1	0.5			1.7			13.3		1
09/22/20 12:00	0.1			1.7			12.5		1	0.3			1.7			12.6		1
09/22/20 13:00	0.1			1.7			12.4		1	0.2			1.7			12.5		1
09/22/20 14:00	0.2			1.7			12.7		1	0.3			1.7			12.8		1
09/22/20 15:00	0.3			1.7			13		1	0.4			1.7			13.1		1
09/22/20 16:00	0.1			1.7			12.5		1	0.3			1.7			12.7		1
09/22/20 17:00	0.2			1.7			12.9		1	0.4			1.7			13		1
09/22/20 18:00	0.5			1.7			13.4		1	0.6			1.7			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/22/20 19:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/22/20 20:00	0.5			1.7			13.5		1	0.7			1.7			13.5		1
09/22/20 21:00	0.6			1.8			14.5		1	0.8			1.7			14.5		1
09/22/20 22:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/22/20 23:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/23/20 0:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/23/20 1:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/23/20 2:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/23/20 3:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/23/20 4:00	0.6			1.7			14.5		1	0.7			1.6			14.6		1
09/23/20 5:00	0.8			1.7			14.3		1	0.9			1.7			14.4		1
09/23/20 6:00	0.8			1.7			14.3		1	0.8			1.7			14.5		1
09/23/20 7:00	0.8			1.7			14.4		1	0.8			1.7			14.6		1
09/23/20 8:00	0.6			1.7			14.5		1	0.8			1.7			14.7		1
09/23/20 9:00	0.6			1.7			14.5		1	0.7			1.7			14.6		1
09/23/20 10:00	0.6			1.7			14.5		1	0.8			1.7			14.6		1
09/23/20 11:00	0.9			1.7			13.9		1	1			1.7			14		1
09/23/20 12:00	0.6			1.7			13.6		1	0.8			1.7			13.7		1
09/23/20 13:00	0.5			1.7			13.4		1	0.6			1.7			13.5		1
09/23/20 14:00	0.1			1.7			12.5		1	0.2			1.7			12.6		1
09/23/20 15:00	0.3			1.7			13		1	0.5			1.7			13.1		1
09/23/20 16:00	0.1			1.7			12.4		1	0.2			1.7			12.5		1
09/23/20 17:00	0.1			1.7			11.8		1	0.2			1.7			12		1
09/23/20 18:00	0.1			1.7			11.9		1	0.2			1.7			12.1		1
09/23/20 19:00	0.3			1.7			13		1	0.4			1.7			13.1		1
09/23/20 20:00	0.9			1.7			13.9		1	1			1.7			14		1
09/23/20 21:00	1			1.7			14.2		1	1.2			1.7			14.3		1
09/23/20 22:00	0.6			1.7			14.4		1	0.7			1.7			14.5		1
09/23/20 23:00	0			0			16.6		1	0.7			1.7			14.6		1
09/24/20 0:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/24/20 1:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/24/20 2:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/24/20 3:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/24/20 4:00	0	X		0	X		0	X	1	0.7			1.6			14.5		1
09/24/20 5:00	0	X		0	X		0	X	1	0.8			1.6			14.4		1
09/24/20 6:00	0	X		0	X		0	X	1	0.8			1.6			14.4		1
09/24/20 7:00	0	X		0	X		0	X	1	0.8			1.6			14.4		1
09/24/20 8:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/24/20 9:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
09/24/20 10:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
09/24/20 11:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
09/24/20 12:00	0	X		0	X		0	X	1	1.2			1.6			14		1
09/24/20 13:00	0	X		0	X		0	X	1	0.9			1.6			13.9		1
09/24/20 14:00	0	X		0	X		0	X	1	0.9			1.6			13.9		1
09/24/20 15:00	0	X		0	X		0	X	1	0.5			1.6			12.7		1
09/24/20 16:00	0	X		0	X		0	X	1	0.2			1.6			11.9		1
09/24/20 17:00	0	X		0	X		0	X	1	0.2			1.7			11.9		1
09/24/20 18:00	0	X		0	X		0	X	1	0.2			1.7			11.9		1
09/24/20 19:00	0	X		0	X		0	X	1	0.6			1.7			13.4		1
09/24/20 20:00	0	X		0	X		0	X	1	1			1.7			14		1
09/24/20 21:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/24/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
09/24/20 23:00	0	X		0	X		0	X	1	1			1.7			14.6		1
09/25/20 0:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 1:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/25/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/25/20 3:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/25/20 4:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/25/20 5:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/25/20 6:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/25/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/25/20 8:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 9:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 10:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 11:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 12:00	0	X		0	X		0	X	1	1			1.7			14.6		1
09/25/20 13:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 14:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 15:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 16:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 17:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 18:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/25/20 19:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/25/20 20:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
09/25/20 21:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
09/25/20 22:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/25/20 23:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
09/26/20 0:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/26/20 1:00	0	X		0	X		0	X	1	0.9			1.7			14.3		1
09/26/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/26/20 3:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/26/20 4:00	0	X		0	X		0	X	1	0.8			1.6			14.4		1
09/26/20 5:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
09/26/20 6:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
09/26/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
09/26/20 8:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/26/20 9:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/26/20 10:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/26/20 11:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/26/20 12:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 13:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/26/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/26/20 15:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 16:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 17:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 18:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/26/20 20:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/26/20 21:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/26/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/26/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/27/20 0:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 1:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 3:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 4:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 5:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 6:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/27/20 7:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 8:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/27/20 9:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
09/27/20 10:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
09/27/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
09/27/20 12:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/27/20 13:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/27/20 14:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/27/20 15:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/27/20 16:00	0	X		0	X		0	X	1	1.2			1.7			14.2		1
09/27/20 17:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
09/27/20 18:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
09/27/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
09/27/20 20:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
09/27/20 21:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
09/27/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
09/27/20 23:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
09/28/20 0:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
09/28/20 1:00	0	X		0	X		0	X	1	1			1.7			14.4		1
09/28/20 2:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/28/20 3:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
09/28/20 4:00	0			0			17.6		1	0.9			1.8			14.4		1
09/28/20 5:00	0.7			1.7			14.3		1	0.8			1.7			14.5		1
09/28/20 6:00	0.7			1.7			14.4		1	0.9			1.7			14.5		1
09/28/20 7:00	0.7			1.7			14.4		1	0.8			1.7			14.5		1
09/28/20 8:00	0.7			1.7			14.5		1	0.8			1.7			14.7		1
09/28/20 9:00	0.7			1.7			14.6		1	0.9			1.7			14.8		1
09/28/20 10:00	0.7			1.7			14.6		1	0.9			1.7			14.8		1
09/28/20 11:00	0.7			1.7			14.6		1	0.8			1.7			14.7		1
09/28/20 12:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/28/20 13:00	0.2			1.7			11.9		1	0.3			1.7			12.1		1
09/28/20 14:00	0.1			1.7			11.9		1	0.2			1.7			12.1		1
09/28/20 15:00	0.1			1.7			12		1	0.2			1.7			12.1		1
09/28/20 16:00	0.4			1.7			13.3		1	0.6			1.7			13.4		1
09/28/20 17:00	0.7			1.7			13.8		1	0.8			1.7			13.8		1
09/28/20 18:00	0.9			1.7			14.2		1	1.2			1.7			14.2		1
09/28/20 19:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
09/28/20 20:00	0.8			1.7			14.5		1	1			1.7			14.7		1
09/28/20 21:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
09/28/20 22:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
09/28/20 23:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
09/29/20 0:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/29/20 1:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
09/29/20 2:00	0.6			1.7			14.5		1	0.9			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/29/20 3:00	0.6			1.7			14.5		1	0.9			1.7			14.6		1
09/29/20 4:00	0.7			1.6			14.4		1	1			1.7			14.5		1
09/29/20 5:00	0.7			1.7			14.5		1	1			1.7			14.6		1
09/29/20 6:00	1			1.7			14.5		1	1.2			1.7			14.6		1
09/29/20 7:00	1.1			1.7			14.4		1	1.4			1.7			14.5		1
09/29/20 8:00	1			1.7			14.5		1	1.1			1.7			14.7		1
09/29/20 9:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
09/29/20 10:00	0.7			1.7			14.5		1	0.8			1.7			14.6		1
09/29/20 11:00	1.1			1.7			14.2		1	1.3			1.7			14.2		1
09/29/20 12:00	0.2			1.7			12.6		1	0.3			1.7			12.7		1
09/29/20 13:00	0.1			1.7			12.3		1	0.3			1.7			12.4		1
09/29/20 14:00	0.1			1.7			12.1		1	0.2			1.7			12.3		1
09/29/20 15:00	0.1			1.7			12.3		1	0.3			1.7			12.5		1
09/29/20 16:00	0.2			1.7			12.7		1	0.4			1.7			12.8		1
09/29/20 17:00	0.2			1.7			12.5		1	0.4			1.7			12.7		1
09/29/20 18:00	0.9			1.7			13.9		1	1.1			1.7			14		1
09/29/20 19:00	1.1			1.7			14.4		1	1.3			1.7			14.6		1
09/29/20 20:00	1.6			1.7			14.3		1	2.3			1.7			14.4		1
09/29/20 21:00	0.6			1.7			13.4		1	0.8			1.7			13.5		1
09/29/20 22:00	0.9			1.8			14.5		1	1			1.7			14.6		1
09/29/20 23:00	0.8			1.7			14.5		1	1			1.7			14.6		1
09/30/20 0:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/30/20 1:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/30/20 2:00	0.8			1.7			14.4		1	1			1.7			14.5		1
09/30/20 3:00	0.7			1.7			14.5		1	1.1			1.7			14.4		1
09/30/20 4:00	0.8			1.7			14.5		1	1.1			1.7			14.4		1
09/30/20 5:00	1			1.7			14.4		1	1			1.7			14.6		1
09/30/20 6:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/30/20 7:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/30/20 8:00	0.9			1.7			14.4		1	1			1.7			14.5		1
09/30/20 9:00	0.9			1.7			14.5		1	1			1.7			14.6		1
09/30/20 10:00	1.1			1.7			14.3		1	1.5			1.7			14.4		1
09/30/20 11:00	1.1			1.7			14.1		1	1.4			1.7			14.2		1
09/30/20 12:00	0.4			1.7			13		1	0.6			1.7			13.1		1
09/30/20 13:00	0.1			1.7			11.8		1	0.3			1.7			12		1
09/30/20 14:00	0.1			1.7			11.7		1	0.2			1.7			11.9		1
09/30/20 15:00	0.1			1.7			12.1		1	0.2			1.7			12.3		1
09/30/20 16:00	0.1			1.7			11.9		1	0.2			1.7			12.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/30/20 17:00	0.2			1.7			12.7		1	0.4			1.7			12.8		1
09/30/20 18:00	0.4			1.7			13.1		1	0.5			1.7			13.2		1
09/30/20 19:00	0.9			1.7			13.9		1	1.1			1.7			14		1
09/30/20 20:00	1.1			1.7			14.2		1	1.2			1.7			14.2		1
09/30/20 21:00	0.6			1.7			13.4		1	0.7			1.7			13.5		1
09/30/20 22:00	1.1			1.7			14.3		1	1.4			1.7			14.4		1
09/30/20 23:00	0.8			1.7			14.5		1	1			1.7			14.7		1

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:49 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2020	0.2276	2.3663	0.8761	5.1800	0.1638	0.9456	0.0817	0.4726	0.2723	1.5762
Aug 2020	0.4257	2.4817	1.7833	5.9949	0.3379	1.1020	0.1690	0.5507	0.5626	1.8361
Sep 2020	0.4176	2.5642	1.7227	7.1656	0.3285	1.3362	0.1645	0.6681	0.5474	2.2261
Sum/Avg	2.5642		7.1656		1.3362		0.6681		2.2261	
Limit Value										

AQ33 DAILY SOX

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/01/20 0:00	0			0														
07/02/20 0:00	0			0														
07/03/20 0:00	0			0														
07/04/20 0:00	0			0														
07/05/20 0:00	0			0														
07/06/20 0:00	0			0														
07/07/20 0:00	0			0														
07/08/20 0:00	0			0														
07/09/20 0:00	0			0														
07/10/20 0:00	0			0														
07/11/20 0:00	0			0														
07/12/20 0:00	0			0														
07/13/20 0:00	4.5			4.9														
07/14/20 0:00	6.1			6														
07/15/20 0:00	6.3			6.1														
07/16/20 0:00	6			5.9														
07/17/20 0:00	5.6			5.4														
07/18/20 0:00	6.4			6.2														
07/19/20 0:00	6.1			6														
07/20/20 0:00	6.3			5.5														
07/21/20 0:00	1			1														
07/22/20 0:00	0			0														
07/23/20 0:00	0			0														
07/24/20 0:00	0			0														
07/25/20 0:00	0			0.2														
07/26/20 0:00	5.8			6.1														
07/27/20 0:00	6.5			6.4														
07/28/20 0:00	6.3			6														
07/29/20 0:00	6.5			6.4														
07/30/20 0:00	6.3			6														
07/31/20 0:00	6			5.9														
08/01/20 0:00	5.9			5.8														
08/02/20 0:00	5.8			5.7														
08/03/20 0:00	6.2			5.8														
08/04/20 0:00	6.2			6														

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 0:00	5.3			5.1														
08/06/20 0:00	0			0														
08/07/20 0:00	0			0														
08/08/20 0:00	0.2			4.1														
08/09/20 0:00	6.8			6.7														
08/10/20 0:00	6.4			6.2														
08/11/20 0:00	5.7			5.6														
08/12/20 0:00	6.7			6.6														
08/13/20 0:00	6.7			6.3														
08/14/20 0:00	7.2			7.1														
08/15/20 0:00	7.3			6.9														
08/16/20 0:00	6.6			6.4														
08/17/20 0:00	6.8			6.6														
08/18/20 0:00	6.5			6.4														
08/19/20 0:00	6.7			6.5														
08/20/20 0:00	5.2			5.1														
08/21/20 0:00	6.2			5.9														
08/22/20 0:00	6.1			5.7														
08/23/20 0:00	6.3			5.7														
08/24/20 0:00	6.3			6.2														
08/25/20 0:00	6			5.8														
08/26/20 0:00	6.4			6.1														
08/27/20 0:00	5.7			5.7														
08/28/20 0:00	6.2			5.9														
08/29/20 0:00	5.7			5.4														
08/30/20 0:00	5.7			5.3														
08/31/20 0:00	7.1			2.2														
09/01/20 0:00	6.6			6														
09/02/20 0:00	5.6			5.5														
09/03/20 0:00	6.7			6.5														
09/04/20 0:00	6.9			6.8														
09/05/20 0:00	6.8			6.6														
09/06/20 0:00	6.5			5.9														
09/07/20 0:00	6.3			5.8														
09/08/20 0:00	5.2			5.2														
09/09/20 0:00	6.8			6.8														
09/10/20 0:00	5.6			5.3														
09/11/20 0:00	5.4			5.1														

	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/12/20 0:00	5.6			5.3														
09/13/20 0:00	5.8			5.8														
09/14/20 0:00	6			5.8														
09/15/20 0:00	6.1			5.8														
09/16/20 0:00	6.6			6.4														
09/17/20 0:00	6.3			6.2														
09/18/20 0:00	6.1			6														
09/19/20 0:00	5.8			5.4														
09/20/20 0:00	5.7			5.5														
09/21/20 0:00	6.7			6.2														
09/22/20 0:00	5.9			5.9														
09/23/20 0:00	6.1			6.1														
09/24/20 0:00	0			6														
09/25/20 0:00	0			4.9														
09/26/20 0:00	0			4.8														
09/27/20 0:00	0			4.8														
09/28/20 0:00	4.7			5.4														
09/29/20 0:00	5.9			5.7														
09/30/20 0:00	6.5			6.1														

AQ33 HOURLY SOX

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/01/20 0:00	0	X		0	X		0											
07/01/20 1:00	0	X		0	X		0											
07/01/20 2:00	0	X		0	X		0											
07/01/20 3:00	0	X		0	X		0											
07/01/20 4:00	0	X		0	X		0											
07/01/20 5:00	0	X		0	X		0											
07/01/20 6:00	0	X		0	X		0											
07/01/20 7:00	0	X		0	X		0											
07/01/20 8:00	0	X		0	X		0											
07/01/20 9:00	0	X		0	X		0											
07/01/20 10:00	0	X		0	X		0											
07/01/20 11:00	0	X		0	X		0											
07/01/20 12:00	0	X		0	X		0											
07/01/20 13:00	0	X		0	X		0											
07/01/20 14:00	0	X		0	X		0											
07/01/20 15:00	0	X		0	X		0											
07/01/20 16:00	0	X		0	X		0											
07/01/20 17:00	0	X		0	X		0											
07/01/20 18:00	0	X		0	X		0											
07/01/20 19:00	0	X		0	X		0											
07/01/20 20:00	0	X		0	X		0											
07/01/20 21:00	0	X		0	X		0											
07/01/20 22:00	0	X		0	X		0											
07/01/20 23:00	0	X		0	X		0											
07/02/20 0:00	0	X		0	X		0											
07/02/20 1:00	0	X		0	X		0											
07/02/20 2:00	0	X		0	X		0											
07/02/20 3:00	0	X		0	X		0											
07/02/20 4:00	0	X		0	X		0											
07/02/20 5:00	0	X		0	X		0											
07/02/20 6:00	0	X		0	X		0											
07/02/20 7:00	0	X		0	X		0											
07/02/20 8:00	0	X		0	X		0											
07/02/20 9:00	0	X		0	X		0											
07/02/20 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/20 11:00	0	X		0	X		0											
07/02/20 12:00	0	X		0	X		0											
07/02/20 13:00	0	X		0	X		0											
07/02/20 14:00	0	X		0	X		0											
07/02/20 15:00	0	X		0	X		0											
07/02/20 16:00	0	X		0	X		0											
07/02/20 17:00	0	X		0	X		0											
07/02/20 18:00	0	X		0	X		0											
07/02/20 19:00	0	X		0	X		0											
07/02/20 20:00	0	X		0	X		0											
07/02/20 21:00	0	X		0	X		0											
07/02/20 22:00	0	X		0	X		0											
07/02/20 23:00	0	X		0	X		0											
07/03/20 0:00	0	X		0	X		0											
07/03/20 1:00	0	X		0	X		0											
07/03/20 2:00	0	X		0	X		0											
07/03/20 3:00	0	X		0	X		0											
07/03/20 4:00	0	X		0	X		0											
07/03/20 5:00	0	X		0	X		0											
07/03/20 6:00	0	X		0	X		0											
07/03/20 7:00	0	X		0	X		0											
07/03/20 8:00	0	X		0	X		0											
07/03/20 9:00	0	X		0	X		0											
07/03/20 10:00	0	X		0	X		0											
07/03/20 11:00	0	X		0	X		0											
07/03/20 12:00	0	X		0	X		0											
07/03/20 13:00	0	X		0	X		0											
07/03/20 14:00	0	X		0	X		0											
07/03/20 15:00	0	X		0	X		0											
07/03/20 16:00	0	X		0	X		0											
07/03/20 17:00	0	X		0	X		0											
07/03/20 18:00	0	X		0	X		0											
07/03/20 19:00	0	X		0	X		0											
07/03/20 20:00	0	X		0	X		0											
07/03/20 21:00	0	X		0	X		0											
07/03/20 22:00	0	X		0	X		0											
07/03/20 23:00	0	X		0	X		0											
07/04/20 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/20 1:00	0	X		0	X		0											
07/04/20 2:00	0	X		0	X		0											
07/04/20 3:00	0	X		0	X		0											
07/04/20 4:00	0	X		0	X		0											
07/04/20 5:00	0	X		0	X		0											
07/04/20 6:00	0	X		0	X		0											
07/04/20 7:00	0	X		0	X		0											
07/04/20 8:00	0	X		0	X		0											
07/04/20 9:00	0	X		0	X		0											
07/04/20 10:00	0	X		0	X		0											
07/04/20 11:00	0	X		0	X		0											
07/04/20 12:00	0	X		0	X		0											
07/04/20 13:00	0	X		0	X		0											
07/04/20 14:00	0	X		0	X		0											
07/04/20 15:00	0	X		0	X		0											
07/04/20 16:00	0	X		0	X		0											
07/04/20 17:00	0	X		0	X		0											
07/04/20 18:00	0	X		0	X		0											
07/04/20 19:00	0	X		0	X		0											
07/04/20 20:00	0	X		0	X		0											
07/04/20 21:00	0	X		0	X		0											
07/04/20 22:00	0	X		0	X		0											
07/04/20 23:00	0	X		0	X		0											
07/05/20 0:00	0	X		0	X		0											
07/05/20 1:00	0	X		0	X		0											
07/05/20 2:00	0	X		0	X		0											
07/05/20 3:00	0	X		0	X		0											
07/05/20 4:00	0	X		0	X		0											
07/05/20 5:00	0	X		0	X		0											
07/05/20 6:00	0	X		0	X		0											
07/05/20 7:00	0	X		0	X		0											
07/05/20 8:00	0	X		0	X		0											
07/05/20 9:00	0	X		0	X		0											
07/05/20 10:00	0	X		0	X		0											
07/05/20 11:00	0	X		0	X		0											
07/05/20 12:00	0	X		0	X		0											
07/05/20 13:00	0	X		0	X		0											
07/05/20 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/20 15:00	0	X		0	X		0											
07/05/20 16:00	0	X		0	X		0											
07/05/20 17:00	0	X		0	X		0											
07/05/20 18:00	0	X		0	X		0											
07/05/20 19:00	0	X		0	X		0											
07/05/20 20:00	0	X		0	X		0											
07/05/20 21:00	0	X		0	X		0											
07/05/20 22:00	0	X		0	X		0											
07/05/20 23:00	0	X		0	X		0											
07/06/20 0:00	0	X		0	X		0											
07/06/20 1:00	0	X		0	X		0											
07/06/20 2:00	0	X		0	X		0											
07/06/20 3:00	0	X		0	X		0											
07/06/20 4:00	0	X		0	X		0											
07/06/20 5:00	0	X		0	X		0											
07/06/20 6:00	0	X		0	X		0											
07/06/20 7:00	0	X		0	X		0											
07/06/20 8:00	0	X		0	X		0											
07/06/20 9:00	0	X		0	X		0											
07/06/20 10:00	0	X		0	X		0											
07/06/20 11:00	0	X		0	X		0											
07/06/20 12:00	0	X		0	X		0											
07/06/20 13:00	0	X		0	X		0											
07/06/20 14:00	0	X		0	X		0											
07/06/20 15:00	0	X		0	X		0											
07/06/20 16:00	0	X		0	X		0											
07/06/20 17:00	0	X		0	X		0											
07/06/20 18:00	0	X		0	X		0											
07/06/20 19:00	0	X		0	X		0											
07/06/20 20:00	0	X		0	X		0											
07/06/20 21:00	0	X		0	X		0											
07/06/20 22:00	0	X		0	X		0											
07/06/20 23:00	0	X		0	X		0											
07/07/20 0:00	0	X		0	X		0											
07/07/20 1:00	0	X		0	X		0											
07/07/20 2:00	0	X		0	X		0											
07/07/20 3:00	0	X		0	X		0											
07/07/20 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/07/20 5:00	0	X		0	X		0											
07/07/20 6:00	0	X		0	X		0											
07/07/20 7:00	0	X		0	X		0											
07/07/20 8:00	0	X		0	X		0											
07/07/20 9:00	0	X		0	X		0											
07/07/20 10:00	0	X		0	X		0											
07/07/20 11:00	0	X		0	X		0											
07/07/20 12:00	0	X		0	X		0											
07/07/20 13:00	0	X		0	X		0											
07/07/20 14:00	0	X		0	X		0											
07/07/20 15:00	0	X		0	X		0											
07/07/20 16:00	0	X		0	X		0											
07/07/20 17:00	0	X		0	X		0											
07/07/20 18:00	0	X		0	X		0											
07/07/20 19:00	0	X		0	X		0											
07/07/20 20:00	0	X		0	X		0											
07/07/20 21:00	0	X		0	X		0											
07/07/20 22:00	0	X		0	X		0											
07/07/20 23:00	0	X		0	X		0											
07/08/20 0:00	0	X		0	X		0											
07/08/20 1:00	0	X		0	X		0											
07/08/20 2:00	0	X		0	X		0											
07/08/20 3:00	0	X		0	X		0											
07/08/20 4:00	0	X		0	X		0											
07/08/20 5:00	0	X		0	X		0											
07/08/20 6:00	0	X		0	X		0											
07/08/20 7:00	0	X		0	X		0											
07/08/20 8:00	0	X		0	X		0											
07/08/20 9:00	0	X		0	X		0											
07/08/20 10:00	0	X		0	X		0											
07/08/20 11:00	0	X		0	X		0											
07/08/20 12:00	0	X		0	X		0											
07/08/20 13:00	0	X		0	X		0											
07/08/20 14:00	0	X		0	X		0											
07/08/20 15:00	0	X		0	X		0											
07/08/20 16:00	0	X		0	X		0											
07/08/20 17:00	0	X		0	X		0											
07/08/20 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/08/20 19:00	0	X		0	X		0											
07/08/20 20:00	0	X		0	X		0											
07/08/20 21:00	0	X		0	X		0											
07/08/20 22:00	0	X		0	X		0											
07/08/20 23:00	0	X		0	X		0											
07/09/20 0:00	0	X		0	X		0											
07/09/20 1:00	0	X		0	X		0											
07/09/20 2:00	0	X		0	X		0											
07/09/20 3:00	0	X		0	X		0											
07/09/20 4:00	0	X		0	X		0											
07/09/20 5:00	0	X		0	X		0											
07/09/20 6:00	0	X		0	X		0											
07/09/20 7:00	0	X		0	X		0											
07/09/20 8:00	0	X		0	X		0											
07/09/20 9:00	0	X		0	X		0											
07/09/20 10:00	0	X		0	X		0											
07/09/20 11:00	0	X		0	X		0											
07/09/20 12:00	0	X		0	X		0											
07/09/20 13:00	0	X		0	X		0											
07/09/20 14:00	0	X		0	X		0											
07/09/20 15:00	0	X		0	X		0											
07/09/20 16:00	0	X		0	X		0											
07/09/20 17:00	0	X		0	X		0											
07/09/20 18:00	0	X		0	X		0											
07/09/20 19:00	0	X		0	X		0											
07/09/20 20:00	0	X		0	X		0											
07/09/20 21:00	0	X		0	X		0											
07/09/20 22:00	0	X		0	X		0											
07/09/20 23:00	0	X		0	X		0											
07/10/20 0:00	0	X		0	X		0											
07/10/20 1:00	0	X		0	X		0											
07/10/20 2:00	0	X		0	X		0											
07/10/20 3:00	0	X		0	X		0											
07/10/20 4:00	0	X		0	X		0											
07/10/20 5:00	0	X		0	X		0											
07/10/20 6:00	0	X		0	X		0											
07/10/20 7:00	0	X		0	X		0											
07/10/20 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/20 9:00	0	X		0	X		0											
07/10/20 10:00	0	X		0	X		0											
07/10/20 11:00	0	X		0	X		0											
07/10/20 12:00	0	X		0	X		0											
07/10/20 13:00	0	X		0	X		0											
07/10/20 14:00	0	X		0	X		0											
07/10/20 15:00	0	X		0	X		0											
07/10/20 16:00	0	X		0	X		0											
07/10/20 17:00	0	X		0	X		0											
07/10/20 18:00	0	X		0	X		0											
07/10/20 19:00	0	X		0	X		0											
07/10/20 20:00	0	X		0	X		0											
07/10/20 21:00	0	X		0	X		0											
07/10/20 22:00	0	X		0	X		0											
07/10/20 23:00	0	X		0	X		0											
07/11/20 0:00	0	X		0	X		0											
07/11/20 1:00	0	X		0	X		0											
07/11/20 2:00	0	X		0	X		0											
07/11/20 3:00	0	X		0	X		0											
07/11/20 4:00	0	X		0	X		0											
07/11/20 5:00	0	X		0	X		0											
07/11/20 6:00	0	X		0	X		0											
07/11/20 7:00	0	X		0	X		0											
07/11/20 8:00	0	X		0	X		0											
07/11/20 9:00	0	X		0	X		0											
07/11/20 10:00	0	X		0	X		0											
07/11/20 11:00	0	X		0	X		0											
07/11/20 12:00	0	X		0	X		0											
07/11/20 13:00	0	X		0	X		0											
07/11/20 14:00	0	X		0	X		0											
07/11/20 15:00	0	X		0	X		0											
07/11/20 16:00	0	X		0	X		0											
07/11/20 17:00	0	X		0	X		0											
07/11/20 18:00	0	X		0	X		0											
07/11/20 19:00	0	X		0	X		0											
07/11/20 20:00	0	X		0	X		0											
07/11/20 21:00	0	X		0	X		0											
07/11/20 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/20 23:00	0	X		0	X		0											
07/12/20 0:00	0	X		0	X		0											
07/12/20 1:00	0	X		0	X		0											
07/12/20 2:00	0	X		0	X		0											
07/12/20 3:00	0	X		0	X		0											
07/12/20 4:00	0	X		0	X		0											
07/12/20 5:00	0	X		0	X		0											
07/12/20 6:00	0	X		0	X		0											
07/12/20 7:00	0	X		0	X		0											
07/12/20 8:00	0	X		0	X		0											
07/12/20 9:00	0	X		0	X		0											
07/12/20 10:00	0	X		0	X		0											
07/12/20 11:00	0	X		0	X		0											
07/12/20 12:00	0	X		0	X		0											
07/12/20 13:00	0	X		0	X		0											
07/12/20 14:00	0	X		0	X		0											
07/12/20 15:00	0	X		0	X		0											
07/12/20 16:00	0	X		0	X		0											
07/12/20 17:00	0	X		0	X		0											
07/12/20 18:00	0	X		0	X		0											
07/12/20 19:00	0	X		0	X		0											
07/12/20 20:00	0	X		0	X		0											
07/12/20 21:00	0	X		0	X		0											
07/12/20 22:00	0	X		0	X		0											
07/12/20 23:00	0	X		0	X		0											
07/13/20 0:00	0	X		0	X		0											
07/13/20 1:00	0	X		0	X		0											
07/13/20 2:00	0	X		0	X		0											
07/13/20 3:00	0	X		0.09534			0.03											
07/13/20 4:00	0	X		0.23664			0.24											
07/13/20 5:00	0	X		0.24666			0.25											
07/13/20 6:00	0.1002			0.24516			0.27											
07/13/20 7:00	0.19896			0.18582			0.38											
07/13/20 8:00	0.20082			0.19116			0.39											
07/13/20 9:00	0.22002			0.21558			0.44											
07/13/20 10:00	0.2523			0.24336			0.5											
07/13/20 11:00	0.30552			0.2886			0.59											
07/13/20 12:00	0.3099			0.29388			0.6											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 13:00	0.2988			0.2826			0.58											
07/13/20 14:00	0.30996			0.29388			0.6											
07/13/20 15:00	0.30924			0.29352			0.6											
07/13/20 16:00	0.29346			0.27798			0.57											
07/13/20 17:00	0.30876			0.29202			0.6											
07/13/20 18:00	0.3597			0.34416			0.7											
07/13/20 19:00	0.3144			0.29796			0.61											
07/13/20 20:00	0.22224			0.17034			0.39											
07/13/20 21:00	0.17826			0.16854			0.35											
07/13/20 22:00	0.17862			0.16872			0.35											
07/13/20 23:00	0.17892			0.16896			0.35											
07/14/20 0:00	0.17886			0.17196			0.35											
07/14/20 1:00	0.18456			0.18102			0.37											
07/14/20 2:00	0.17796			0.16836			0.35											
07/14/20 3:00	0.17808			0.16854			0.35											
07/14/20 4:00	0.1809			0.1743			0.36											
07/14/20 5:00	0.17832			0.1686			0.35											
07/14/20 6:00	0.17862			0.16854			0.35											
07/14/20 7:00	0.186			0.1782			0.36											
07/14/20 8:00	0.19686			0.19512			0.39											
07/14/20 9:00	0.2133			0.21546			0.43											
07/14/20 10:00	0.2457			0.23922			0.48											
07/14/20 11:00	0.28776			0.27018			0.56											
07/14/20 12:00	0.33342			0.31734			0.65											
07/14/20 13:00	0.28518			0.26904			0.55											
07/14/20 14:00	0.3399			0.32364			0.66											
07/14/20 15:00	0.37158			0.35508			0.73											
07/14/20 16:00	0.3732			0.35694			0.73											
07/14/20 17:00	0.37008			0.3537			0.72											
07/14/20 18:00	0.33222			0.3165			0.65											
07/14/20 19:00	0.28776			0.26976			0.56											
07/14/20 20:00	0.2523			0.21444			0.47											
07/14/20 21:00	0.2355			0.20406			0.44											
07/14/20 22:00	0.22728			0.20166			0.43											
07/14/20 23:00	0.19476			0.17448			0.37											
07/15/20 0:00	0.18174			0.17148			0.35											
07/15/20 1:00	0.17904			0.1692			0.35											
07/15/20 2:00	0.17874			0.16854			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/15/20 3:00	0.17874			0.16842			0.35											
07/15/20 4:00	0.1788			0.16884			0.35											
07/15/20 5:00	0.17892			0.16878			0.35											
07/15/20 6:00	0.17904			0.16878			0.35											
07/15/20 7:00	0.17994			0.16902			0.35											
07/15/20 8:00	0.20142			0.19422			0.4											
07/15/20 9:00	0.21726			0.21516			0.43											
07/15/20 10:00	0.24558			0.24486			0.49											
07/15/20 11:00	0.30438			0.2874			0.59											
07/15/20 12:00	0.34806			0.33138			0.68											
07/15/20 13:00	0.35076			0.33384			0.68											
07/15/20 14:00	0.36978			0.3534			0.72											
07/15/20 15:00	0.37476			0.35814			0.73											
07/15/20 16:00	0.37536			0.35898			0.73											
07/15/20 17:00	0.37416			0.35772			0.73											
07/15/20 18:00	0.3543			0.3384			0.69											
07/15/20 19:00	0.28164			0.26436			0.55											
07/15/20 20:00	0.2406			0.19806			0.44											
07/15/20 21:00	0.1926			0.17286			0.37											
07/15/20 22:00	0.17976			0.16866			0.35											
07/15/20 23:00	0.17934			0.16872			0.35											
07/16/20 0:00	0.17928			0.16872			0.35											
07/16/20 1:00	0.17916			0.16878			0.35											
07/16/20 2:00	0.1791			0.16884			0.35											
07/16/20 3:00	0.1791			0.16896			0.35											
07/16/20 4:00	0.17904			0.16908			0.35											
07/16/20 5:00	0.17904			0.1689			0.35											
07/16/20 6:00	0.17946			0.1692			0.35											
07/16/20 7:00	0.18048			0.1698			0.35											
07/16/20 8:00	0.19572			0.18762			0.38											
07/16/20 9:00	0.2172			0.21354			0.43											
07/16/20 10:00	0.24036			0.24102			0.48											
07/16/20 11:00	0.28506			0.26694			0.55											
07/16/20 12:00	0.3465			0.3297			0.68											
07/16/20 13:00	0.32322			0.3069			0.63											
07/16/20 14:00	0.32868			0.31236			0.64											
07/16/20 15:00	0.37722			0.36126			0.74											
07/16/20 16:00	0.37704			0.36108			0.74											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/16/20 17:00	0.37956			0.36144			0.74											
07/16/20 18:00	0.32346			0.30846			0.63											
07/16/20 19:00	0.258			0.23124			0.49											
07/16/20 20:00	0.21522			0.19308			0.41											
07/16/20 21:00	0.20466			0.1893			0.39											
07/16/20 22:00	0.18006			0.1695			0.35											
07/16/20 23:00	0.18276			0.17328			0.36											
07/17/20 0:00	0.17928			0.16968			0.35											
07/17/20 1:00	0.17928			0.16908			0.35											
07/17/20 2:00	0.17916			0.16908			0.35											
07/17/20 3:00	0.17916			0.16902			0.35											
07/17/20 4:00	0.17898			0.16908			0.35											
07/17/20 5:00	0.17898			0.16914			0.35											
07/17/20 6:00	0.1794			0.16914			0.35											
07/17/20 7:00	0.17874			0.16944			0.35											
07/17/20 8:00	0.19356			0.18606			0.38											
07/17/20 9:00	0.21234			0.20874			0.42											
07/17/20 10:00	0.22866			0.22926			0.46											
07/17/20 11:00	0.25932			0.24378			0.5											
07/17/20 12:00	0.21726			0.2046			0.42											
07/17/20 13:00	0.24678			0.23916			0.49											
07/17/20 14:00	0.30246			0.2634			0.57											
07/17/20 15:00	0.3525			0.3366			0.69											
07/17/20 16:00	0.37176			0.3558			0.73											
07/17/20 17:00	0.34794			0.33204			0.68											
07/17/20 18:00	0.30834			0.2928			0.6											
07/17/20 19:00	0.24174			0.23742			0.48											
07/17/20 20:00	0.19734			0.20232			0.4											
07/17/20 21:00	0.1932			0.20436			0.4											
07/17/20 22:00	0.1962			0.21342			0.41											
07/17/20 23:00	0.17934			0.18492			0.36											
07/18/20 0:00	0.17862			0.16848			0.35											
07/18/20 1:00	0.17868			0.1683			0.35											
07/18/20 2:00	0.17868			0.16836			0.35											
07/18/20 3:00	0.17862			0.16842			0.35											
07/18/20 4:00	0.17856			0.16842			0.35											
07/18/20 5:00	0.17856			0.16836			0.35											
07/18/20 6:00	0.17868			0.16848			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/18/20 7:00	0.17988			0.16902			0.35											
07/18/20 8:00	0.195			0.18828			0.38											
07/18/20 9:00	0.21432			0.21168			0.43											
07/18/20 10:00	0.25224			0.24126			0.49											
07/18/20 11:00	0.3054			0.28998			0.6											
07/18/20 12:00	0.24636			0.23394			0.48											
07/18/20 13:00	0.30366			0.2874			0.59											
07/18/20 14:00	0.37698			0.36012			0.74											
07/18/20 15:00	0.37956			0.3633			0.74											
07/18/20 16:00	0.36864			0.35286			0.72											
07/18/20 17:00	0.36636			0.35064			0.72											
07/18/20 18:00	0.36726			0.3519			0.72											
07/18/20 19:00	0.32862			0.31398			0.64											
07/18/20 20:00	0.25776			0.2442			0.5											
07/18/20 21:00	0.24792			0.23682			0.48											
07/18/20 22:00	0.2946			0.28164			0.58											
07/18/20 23:00	0.18198			0.1734			0.36											
07/19/20 0:00	0.17856			0.16812			0.35											
07/19/20 1:00	0.17862			0.16818			0.35											
07/19/20 2:00	0.17844			0.1683			0.35											
07/19/20 3:00	0.1785			0.16836			0.35											
07/19/20 4:00	0.17832			0.16836			0.35											
07/19/20 5:00	0.17844			0.16842			0.35											
07/19/20 6:00	0.1788			0.16848			0.35											
07/19/20 7:00	0.17922			0.16836			0.35											
07/19/20 8:00	0.18024			0.16932			0.35											
07/19/20 9:00	0.20304			0.19362			0.4											
07/19/20 10:00	0.23766			0.23148			0.47											
07/19/20 11:00	0.28968			0.27342			0.56											
07/19/20 12:00	0.31854			0.30318			0.62											
07/19/20 13:00	0.32892			0.3138			0.64											
07/19/20 14:00	0.37614			0.36066			0.74											
07/19/20 15:00	0.37632			0.3615			0.74											
07/19/20 16:00	0.35058			0.336			0.69											
07/19/20 17:00	0.36852			0.35334			0.72											
07/19/20 18:00	0.33726			0.32256			0.66											
07/19/20 19:00	0.26916			0.25428			0.52											
07/19/20 20:00	0.249			0.23826			0.49											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/19/20 21:00	0.216			0.21114			0.43											
07/19/20 22:00	0.18456			0.17622			0.36											
07/19/20 23:00	0.20802			0.19974			0.41											
07/20/20 0:00	0.1824			0.18264			0.37											
07/20/20 1:00	0.17862			0.1707			0.35											
07/20/20 2:00	0.17886			0.16878			0.35											
07/20/20 3:00	0.18222			0.1728			0.36											
07/20/20 4:00	0.18312			0.17814			0.36											
07/20/20 5:00	0.17874			0.16878			0.35											
07/20/20 6:00	0.17886			0.16878			0.35											
07/20/20 7:00	0.17922			0.1686			0.35											
07/20/20 8:00	0.17964			0.16914			0.35											
07/20/20 9:00	0.2112			0.20208			0.41											
07/20/20 10:00	0.25662			0.24504			0.5											
07/20/20 11:00	0.261			0.24564			0.51											
07/20/20 12:00	0.26064			0.24486			0.51											
07/20/20 13:00	0.31542			0.29886			0.61											
07/20/20 14:00	0.35064			0.3345			0.69											
07/20/20 15:00	0.35946			0.34416			0.7											
07/20/20 16:00	0.35928			0.34398			0.7											
07/20/20 17:00	0.35046			0.33504			0.69											
07/20/20 18:00	0.3057			0.2916			0.6											
07/20/20 19:00	0.29736			0.28278			0.58											
07/20/20 20:00	0.25272			0.24474			0.5											
07/20/20 21:00	0.19134			0.19404			0.39											
07/20/20 22:00	0.17922			0.17148			0.35											
07/20/20 23:00	0.19944			0.19188			0.39											
07/21/20 0:00	0.18168			0.17412			0.36											
07/21/20 1:00	0.17928			0.17082			0.35											
07/21/20 2:00	0.1788			0.16926			0.35											
07/21/20 3:00	0.18084			0.17514			0.36											
07/21/20 4:00	0.18894			0.1893			0.38											
07/21/20 5:00	0.06288			0.1035			0.02											
07/21/20 6:00	0	X		0	X		0											
07/21/20 7:00	0	X		0	X		0											
07/21/20 8:00	0	X		0	X		0											
07/21/20 9:00	0	X		0	X		0											
07/21/20 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 11:00	0	X		0	X		0											
07/21/20 12:00	0	X		0	X		0											
07/21/20 13:00	0	X		0	X		0											
07/21/20 14:00	0	X		0	X		0											
07/21/20 15:00	0	X		0	X		0											
07/21/20 16:00	0	X		0	X		0											
07/21/20 17:00	0	X		0	X		0											
07/21/20 18:00	0	X		0	X		0											
07/21/20 19:00	0	X		0	X		0											
07/21/20 20:00	0	X		0	X		0											
07/21/20 21:00	0	X		0	X		0											
07/21/20 22:00	0	X		0	X		0											
07/21/20 23:00	0	X		0	X		0											
07/22/20 0:00	0	X		0	X		0											
07/22/20 1:00	0	X		0	X		0											
07/22/20 2:00	0	X		0	X		0											
07/22/20 3:00	0	X		0	X		0											
07/22/20 4:00	0	X		0	X		0											
07/22/20 5:00	0	X		0	X		0											
07/22/20 6:00	0	X		0	X		0											
07/22/20 7:00	0	X		0	X		0											
07/22/20 8:00	0	X		0	X		0											
07/22/20 9:00	0	X		0	X		0											
07/22/20 10:00	0	X		0	X		0											
07/22/20 11:00	0	X		0	X		0											
07/22/20 12:00	0	X		0	X		0											
07/22/20 13:00	0	X		0	X		0											
07/22/20 14:00	0	X		0	X		0											
07/22/20 15:00	0	X		0	X		0											
07/22/20 16:00	0	X		0	X		0											
07/22/20 17:00	0	X		0	X		0											
07/22/20 18:00	0	X		0	X		0											
07/22/20 19:00	0	X		0	X		0											
07/22/20 20:00	0	X		0	X		0											
07/22/20 21:00	0	X		0	X		0											
07/22/20 22:00	0	X		0	X		0											
07/22/20 23:00	0	X		0	X		0											
07/23/20 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/23/20 1:00	0	X		0	X		0											
07/23/20 2:00	0	X		0	X		0											
07/23/20 3:00	0	X		0	X		0											
07/23/20 4:00	0	X		0	X		0											
07/23/20 5:00	0	X		0	X		0											
07/23/20 6:00	0	X		0	X		0											
07/23/20 7:00	0	X		0	X		0											
07/23/20 8:00	0	X		0	X		0											
07/23/20 9:00	0	X		0	X		0											
07/23/20 10:00	0	X		0	X		0											
07/23/20 11:00	0	X		0	X		0											
07/23/20 12:00	0	X		0	X		0											
07/23/20 13:00	0	X		0	X		0											
07/23/20 14:00	0	X		0	X		0											
07/23/20 15:00	0	X		0	X		0											
07/23/20 16:00	0	X		0	X		0											
07/23/20 17:00	0	X		0	X		0											
07/23/20 18:00	0	X		0	X		0											
07/23/20 19:00	0	X		0	X		0											
07/23/20 20:00	0	X		0	X		0											
07/23/20 21:00	0	X		0	X		0											
07/23/20 22:00	0	X		0	X		0											
07/23/20 23:00	0	X		0	X		0											
07/24/20 0:00	0	X		0	X		0											
07/24/20 1:00	0	X		0	X		0											
07/24/20 2:00	0	X		0	X		0											
07/24/20 3:00	0	X		0	X		0											
07/24/20 4:00	0	X		0	X		0											
07/24/20 5:00	0	X		0	X		0											
07/24/20 6:00	0	X		0	X		0											
07/24/20 7:00	0	X		0	X		0											
07/24/20 8:00	0	X		0	X		0											
07/24/20 9:00	0	X		0	X		0											
07/24/20 10:00	0	X		0	X		0											
07/24/20 11:00	0	X		0	X		0											
07/24/20 12:00	0	X		0	X		0											
07/24/20 13:00	0	X		0	X		0											
07/24/20 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/24/20 15:00	0	X		0	X		0											
07/24/20 16:00	0	X		0	X		0											
07/24/20 17:00	0	X		0	X		0											
07/24/20 18:00	0	X		0	X		0											
07/24/20 19:00	0	X		0	X		0											
07/24/20 20:00	0	X		0	X		0											
07/24/20 21:00	0	X		0	X		0											
07/24/20 22:00	0	X		0	X		0											
07/24/20 23:00	0	X		0	X		0											
07/25/20 0:00	0	X		0	X		0											
07/25/20 1:00	0	X		0	X		0											
07/25/20 2:00	0	X		0	X		0											
07/25/20 3:00	0	X		0	X		0											
07/25/20 4:00	0	X		0	X		0											
07/25/20 5:00	0	X		0	X		0											
07/25/20 6:00	0	X		0	X		0											
07/25/20 7:00	0	X		0	X		0											
07/25/20 8:00	0	X		0	X		0											
07/25/20 9:00	0	X		0	X		0											
07/25/20 10:00	0	X		0	X		0											
07/25/20 11:00	0	X		0	X		0											
07/25/20 12:00	0	X		0	X		0											
07/25/20 13:00	0	X		0	X		0											
07/25/20 14:00	0	X		0	X		0											
07/25/20 15:00	0	X		0	X		0											
07/25/20 16:00	0	X		0	X		0											
07/25/20 17:00	0	X		0	X		0											
07/25/20 18:00	0	X		0	X		0											
07/25/20 19:00	0	X		0	X		0											
07/25/20 20:00	0	X		0	X		0											
07/25/20 21:00	0	X		0	X		0											
07/25/20 22:00	0	X		0.0906			0.03											
07/25/20 23:00	0	X		0.23358			0.23											
07/26/20 0:00	0	X		0.24708			0.25											
07/26/20 1:00	0.0996			0.21528			0.24											
07/26/20 2:00	0.21006			0.19668			0.41											
07/26/20 3:00	0.17952			0.17184			0.35											
07/26/20 4:00	0.17826			0.16884			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 5:00	0.17922			0.16944			0.35											
07/26/20 6:00	0.18432			0.17832			0.36											
07/26/20 7:00	0.18072			0.18162			0.36											
07/26/20 8:00	0.17922			0.18294			0.36											
07/26/20 9:00	0.17922			0.18312			0.36											
07/26/20 10:00	0.17958			0.18378			0.36											
07/26/20 11:00	0.18474			0.18798			0.37											
07/26/20 12:00	0.2664			0.24426			0.51											
07/26/20 13:00	0.2895			0.27366			0.56											
07/26/20 14:00	0.31104			0.29544			0.61											
07/26/20 15:00	0.3759			0.36036			0.74											
07/26/20 16:00	0.37608			0.36066			0.74											
07/26/20 17:00	0.37548			0.36018			0.74											
07/26/20 18:00	0.37614			0.3606			0.74											
07/26/20 19:00	0.36786			0.35292			0.72											
07/26/20 20:00	0.33846			0.32418			0.66											
07/26/20 21:00	0.21936			0.20928			0.43											
07/26/20 22:00	0.22998			0.22686			0.46											
07/26/20 23:00	0.22896			0.23256			0.46											
07/27/20 0:00	0.19974			0.21186			0.41											
07/27/20 1:00	0.183			0.20436			0.39											
07/27/20 2:00	0.20016			0.19332			0.39											
07/27/20 3:00	0.1968			0.19506			0.39											
07/27/20 4:00	0.17994			0.1818			0.36											
07/27/20 5:00	0.18402			0.17814			0.36											
07/27/20 6:00	0.18096			0.18126			0.36											
07/27/20 7:00	0.1791			0.18342			0.36											
07/27/20 8:00	0.18006			0.18648			0.37											
07/27/20 9:00	0.20316			0.20958			0.41											
07/27/20 10:00	0.26886			0.25776			0.53											
07/27/20 11:00	0.3111			0.29574			0.61											
07/27/20 12:00	0.35064			0.33498			0.69											
07/27/20 13:00	0.3159			0.30048			0.62											
07/27/20 14:00	0.37386			0.35838			0.73											
07/27/20 15:00	0.3747			0.3597			0.73											
07/27/20 16:00	0.37404			0.35958			0.73											
07/27/20 17:00	0.37548			0.36042			0.74											
07/27/20 18:00	0.3729			0.3582			0.73											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/27/20 19:00	0.34176			0.32802			0.67											
07/27/20 20:00	0.31902			0.30798			0.63											
07/27/20 21:00	0.19422			0.1974			0.39											
07/27/20 22:00	0.20088			0.20322			0.4											
07/27/20 23:00	0.20328			0.19548			0.4											
07/28/20 0:00	0.17838			0.1692			0.35											
07/28/20 1:00	0.17802			0.16806			0.35											
07/28/20 2:00	0.17814			0.16896			0.35											
07/28/20 3:00	0.17808			0.16896			0.35											
07/28/20 4:00	0.17814			0.16872			0.35											
07/28/20 5:00	0.17808			0.16836			0.35											
07/28/20 6:00	0.1785			0.16842			0.35											
07/28/20 7:00	0.18456			0.17742			0.36											
07/28/20 8:00	0.19848			0.1971			0.4											
07/28/20 9:00	0.25692			0.24426			0.5											
07/28/20 10:00	0.3225			0.30672			0.63											
07/28/20 11:00	0.33996			0.32406			0.66											
07/28/20 12:00	0.34302			0.3273			0.67											
07/28/20 13:00	0.37578			0.35964			0.74											
07/28/20 14:00	0.36168			0.34602			0.71											
07/28/20 15:00	0.35262			0.33756			0.69											
07/28/20 16:00	0.3447			0.32958			0.67											
07/28/20 17:00	0.34224			0.32742			0.67											
07/28/20 18:00	0.29676			0.28242			0.58											
07/28/20 19:00	0.29292			0.27894			0.57											
07/28/20 20:00	0.30762			0.29418			0.6											
07/28/20 21:00	0.21366			0.20658			0.42											
07/28/20 22:00	0.18372			0.17448			0.36											
07/28/20 23:00	0.20082			0.1932			0.39											
07/29/20 0:00	0.17844			0.16932			0.35											
07/29/20 1:00	0.17808			0.16788			0.35											
07/29/20 2:00	0.17778			0.168			0.35											
07/29/20 3:00	0.17796			0.16812			0.35											
07/29/20 4:00	0.17784			0.16812			0.35											
07/29/20 5:00	0.17796			0.16824			0.35											
07/29/20 6:00	0.1785			0.1683			0.35											
07/29/20 7:00	0.17898			0.16806			0.35											
07/29/20 8:00	0.18306			0.17268			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/29/20 9:00	0.19188			0.18516			0.38											
07/29/20 10:00	0.24972			0.23724			0.49											
07/29/20 11:00	0.29418			0.27852			0.57											
07/29/20 12:00	0.35466			0.33876			0.69											
07/29/20 13:00	0.37446			0.35796			0.73											
07/29/20 14:00	0.3747			0.35862			0.73											
07/29/20 15:00	0.37398			0.35886			0.73											
07/29/20 16:00	0.37446			0.3591			0.73											
07/29/20 17:00	0.37356			0.35838			0.73											
07/29/20 18:00	0.3699			0.35502			0.72											
07/29/20 19:00	0.27552			0.26214			0.54											
07/29/20 20:00	0.32556			0.3117			0.64											
07/29/20 21:00	0.20904			0.19818			0.41											
07/29/20 22:00	0.21456			0.20958			0.42											
07/29/20 23:00	0.18678			0.19134			0.38											
07/30/20 0:00	0.17814			0.16896			0.35											
07/30/20 1:00	0.17826			0.16812			0.35											
07/30/20 2:00	0.17838			0.16824			0.35											
07/30/20 3:00	0.17844			0.16848			0.35											
07/30/20 4:00	0.17838			0.16854			0.35											
07/30/20 5:00	0.17862			0.1689			0.35											
07/30/20 6:00	0.17904			0.16878			0.35											
07/30/20 7:00	0.17928			0.16836			0.35											
07/30/20 8:00	0.17874			0.16818			0.35											
07/30/20 9:00	0.18654			0.17658			0.36											
07/30/20 10:00	0.22662			0.21858			0.45											
07/30/20 11:00	0.31158			0.29436			0.61											
07/30/20 12:00	0.29856			0.28236			0.58											
07/30/20 13:00	0.32466			0.30792			0.63											
07/30/20 14:00	0.35328			0.33654			0.69											
07/30/20 15:00	0.35916			0.34296			0.7											
07/30/20 16:00	0.3741			0.35772			0.73											
07/30/20 17:00	0.37374			0.35754			0.73											
07/30/20 18:00	0.35484			0.3393			0.69											
07/30/20 19:00	0.32712			0.31224			0.64											
07/30/20 20:00	0.31896			0.3039			0.62											
07/30/20 21:00	0.2481			0.23844			0.49											
07/30/20 22:00	0.23442			0.22866			0.46											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/30/20 23:00	0.18822			0.19062			0.38											
07/31/20 0:00	0.1782			0.16968			0.35											
07/31/20 1:00	0.1785			0.16824			0.35											
07/31/20 2:00	0.17844			0.16842			0.35											
07/31/20 3:00	0.1782			0.16848			0.35											
07/31/20 4:00	0.17832			0.16854			0.35											
07/31/20 5:00	0.17832			0.16866			0.35											
07/31/20 6:00	0.17898			0.16878			0.35											
07/31/20 7:00	0.17928			0.16854			0.35											
07/31/20 8:00	0.17868			0.16812			0.35											
07/31/20 9:00	0.18648			0.1773			0.36											
07/31/20 10:00	0.22044			0.21402			0.43											
07/31/20 11:00	0.33432			0.32088			0.66											
07/31/20 12:00	0.309			0.2931			0.6											
07/31/20 13:00	0.33264			0.31626			0.65											
07/31/20 14:00	0.37572			0.3591			0.73											
07/31/20 15:00	0.32862			0.31314			0.64											
07/31/20 16:00	0.3237			0.30816			0.63											
07/31/20 17:00	0.35172			0.33594			0.69											
07/31/20 18:00	0.34062			0.32544			0.67											
07/31/20 19:00	0.33648			0.32172			0.66											
07/31/20 20:00	0.29388			0.2814			0.58											
07/31/20 21:00	0.21906			0.21648			0.44											
07/31/20 22:00	0.21252			0.21546			0.43											
07/31/20 23:00	0.18132			0.17478			0.36											
08/01/20 0:00	0.1782			0.16818			0.35											
08/01/20 1:00	0.1782			0.16818			0.35											
08/01/20 2:00	0.17802			0.1683			0.35											
08/01/20 3:00	0.17808			0.16842			0.35											
08/01/20 4:00	0.17796			0.16842			0.35											
08/01/20 5:00	0.17826			0.16854			0.35											
08/01/20 6:00	0.17862			0.16854			0.35											
08/01/20 7:00	0.1791			0.16842			0.35											
08/01/20 8:00	0.17922			0.16908			0.35											
08/01/20 9:00	0.19674			0.18948			0.39											
08/01/20 10:00	0.21276			0.20964			0.42											
08/01/20 11:00	0.21432			0.2154			0.43											
08/01/20 12:00	0.22272			0.22602			0.45											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/01/20 13:00	0.23652			0.22002			0.46											
08/01/20 14:00	0.2289			0.213			0.44											
08/01/20 15:00	0.37428			0.35712			0.73											
08/01/20 16:00	0.37158			0.3552			0.73											
08/01/20 17:00	0.3696			0.35358			0.72											
08/01/20 18:00	0.35388			0.33828			0.69											
08/01/20 19:00	0.3357			0.32064			0.66											
08/01/20 20:00	0.28776			0.27432			0.56											
08/01/20 21:00	0.26748			0.25464			0.52											
08/01/20 22:00	0.22074			0.21186			0.43											
08/01/20 23:00	0.1968			0.19488			0.39											
08/02/20 0:00	0.17766			0.16944			0.35											
08/02/20 1:00	0.17724			0.1674			0.34											
08/02/20 2:00	0.17724			0.16728			0.34											
08/02/20 3:00	0.17724			0.1674			0.34											
08/02/20 4:00	0.17778			0.1683			0.35											
08/02/20 5:00	0.18996			0.1845			0.37											
08/02/20 6:00	0.18768			0.1884			0.38											
08/02/20 7:00	0.18408			0.1905			0.37											
08/02/20 8:00	0.17754			0.1686			0.35											
08/02/20 9:00	0.17766			0.16668			0.34											
08/02/20 10:00	0.17778			0.16668			0.34											
08/02/20 11:00	0.21294			0.2022			0.42											
08/02/20 12:00	0.23544			0.22596			0.46											
08/02/20 13:00	0.33354			0.31722			0.65											
08/02/20 14:00	0.33204			0.31596			0.65											
08/02/20 15:00	0.3723			0.35622			0.73											
08/02/20 16:00	0.34152			0.32616			0.67											
08/02/20 17:00	0.3627			0.34758			0.71											
08/02/20 18:00	0.33552			0.32052			0.66											
08/02/20 19:00	0.32946			0.31512			0.64											
08/02/20 20:00	0.31122			0.29718			0.61											
08/02/20 21:00	0.2394			0.22836			0.47											
08/02/20 22:00	0.1956			0.1926			0.39											
08/02/20 23:00	0.21786			0.2181			0.44											
08/03/20 0:00	0.1791			0.18216			0.36											
08/03/20 1:00	0.17766			0.1683			0.35											
08/03/20 2:00	0.17766			0.16758			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/03/20 3:00	0.1776			0.1677			0.35											
08/03/20 4:00	0.17742			0.16776			0.35											
08/03/20 5:00	0.1779			0.168			0.35											
08/03/20 6:00	0.17838			0.16794			0.35											
08/03/20 7:00	0.17922			0.16824			0.35											
08/03/20 8:00	0.18372			0.17538			0.36											
08/03/20 9:00	0.17904			0.16974			0.35											
08/03/20 10:00	0.24048			0.23016			0.47											
08/03/20 11:00	0.25884			0.243			0.5											
08/03/20 12:00	0.30618			0.29022			0.6											
08/03/20 13:00	0.31416			0.29796			0.61											
08/03/20 14:00	0.36996			0.35364			0.72											
08/03/20 15:00	0.35922			0.34362			0.7											
08/03/20 16:00	0.357			0.3417			0.7											
08/03/20 17:00	0.35922			0.3441			0.7											
08/03/20 18:00	0.37464			0.35928			0.73											
08/03/20 19:00	0.31518			0.30336			0.62											
08/03/20 20:00	0.21906			0.21078			0.43											
08/03/20 21:00	0.22992			0.22794			0.46											
08/03/20 22:00	0.18654			0.19416			0.38											
08/03/20 23:00	0.19884			0.2103			0.41											
08/04/20 0:00	0.17784			0.1722			0.35											
08/04/20 1:00	0.17778			0.16752			0.35											
08/04/20 2:00	0.1776			0.16758			0.35											
08/04/20 3:00	0.17748			0.16782			0.35											
08/04/20 4:00	0.1776			0.16782			0.35											
08/04/20 5:00	0.17784			0.16788			0.35											
08/04/20 6:00	0.17808			0.16788			0.35											
08/04/20 7:00	0.17874			0.168			0.35											
08/04/20 8:00	0.19266			0.18588			0.38											
08/04/20 9:00	0.21294			0.21042			0.42											
08/04/20 10:00	0.21384			0.21636			0.43											
08/04/20 11:00	0.25578			0.24192			0.5											
08/04/20 12:00	0.3156			0.2991			0.61											
08/04/20 13:00	0.30756			0.29124			0.6											
08/04/20 14:00	0.3528			0.336			0.69											
08/04/20 15:00	0.37494			0.35868			0.73											
08/04/20 16:00	0.37392			0.3579			0.73											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/04/20 17:00	0.37452			0.35868			0.73											
08/04/20 18:00	0.36756			0.3519			0.72											
08/04/20 19:00	0.26628			0.25836			0.52											
08/04/20 20:00	0.2271			0.21744			0.44											
08/04/20 21:00	0.17856			0.1689			0.35											
08/04/20 22:00	0.17808			0.16788			0.35											
08/04/20 23:00	0.19068			0.18246			0.37											
08/05/20 0:00	0.1776			0.16776			0.35											
08/05/20 1:00	0.17754			0.1677			0.35											
08/05/20 2:00	0.17754			0.16782			0.35											
08/05/20 3:00	0.17748			0.16776			0.35											
08/05/20 4:00	0.17748			0.168			0.35											
08/05/20 5:00	0.17748			0.16794			0.35											
08/05/20 6:00	0.1779			0.16794			0.35											
08/05/20 7:00	0.1779			0.16782			0.35											
08/05/20 8:00	0.17784			0.16776			0.35											
08/05/20 9:00	0.17958			0.17142			0.35											
08/05/20 10:00	0.19116			0.1869			0.38											
08/05/20 11:00	0.24822			0.2358			0.48											
08/05/20 12:00	0.3039			0.28734			0.59											
08/05/20 13:00	0.31788			0.3015			0.62											
08/05/20 14:00	0.32622			0.30978			0.64											
08/05/20 15:00	0.32952			0.31344			0.64											
08/05/20 16:00	0.32166			0.30588			0.63											
08/05/20 17:00	0.29376			0.27822			0.57											
08/05/20 18:00	0.30672			0.29136			0.6											
08/05/20 19:00	0.20124			0.19152			0.39											
08/05/20 20:00	0.20304			0.20064			0.4											
08/05/20 21:00	0.19338			0.18894			0.38											
08/05/20 22:00	0.21318			0.06786			0.22											
08/05/20 23:00	0.10476			0	X		0.01											
08/06/20 0:00	0	X		0	X		0											
08/06/20 1:00	0	X		0	X		0											
08/06/20 2:00	0	X		0	X		0											
08/06/20 3:00	0	X		0	X		0											
08/06/20 4:00	0	X		0	X		0											
08/06/20 5:00	0	X		0	X		0											
08/06/20 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/06/20 7:00	0	X		0	X		0											
08/06/20 8:00	0	X		0	X		0											
08/06/20 9:00	0	X		0	X		0											
08/06/20 10:00	0	X		0	X		0											
08/06/20 11:00	0	X		0	X		0											
08/06/20 12:00	0	X		0	X		0											
08/06/20 13:00	0	X		0	X		0											
08/06/20 14:00	0	X		0	X		0											
08/06/20 15:00	0	X		0	X		0											
08/06/20 16:00	0	X		0	X		0											
08/06/20 17:00	0	X		0	X		0											
08/06/20 18:00	0	X		0	X		0											
08/06/20 19:00	0	X		0	X		0											
08/06/20 20:00	0	X		0	X		0											
08/06/20 21:00	0	X		0	X		0											
08/06/20 22:00	0	X		0	X		0											
08/06/20 23:00	0	X		0	X		0											
08/07/20 0:00	0	X		0	X		0											
08/07/20 1:00	0	X		0	X		0											
08/07/20 2:00	0	X		0	X		0											
08/07/20 3:00	0	X		0	X		0											
08/07/20 4:00	0	X		0	X		0											
08/07/20 5:00	0	X		0	X		0											
08/07/20 6:00	0	X		0	X		0											
08/07/20 7:00	0	X		0	X		0											
08/07/20 8:00	0	X		0	X		0											
08/07/20 9:00	0	X		0	X		0											
08/07/20 10:00	0	X		0	X		0											
08/07/20 11:00	0	X		0	X		0											
08/07/20 12:00	0	X		0	X		0											
08/07/20 13:00	0	X		0	X		0											
08/07/20 14:00	0	X		0	X		0											
08/07/20 15:00	0	X		0	X		0											
08/07/20 16:00	0	X		0	X		0											
08/07/20 17:00	0	X		0	X		0											
08/07/20 18:00	0	X		0	X		0											
08/07/20 19:00	0	X		0	X		0											
08/07/20 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/07/20 21:00	0	X		0	X		0											
08/07/20 22:00	0	X		0	X		0											
08/07/20 23:00	0	X		0	X		0											
08/08/20 0:00	0	X		0	X		0											
08/08/20 1:00	0	X		0	X		0											
08/08/20 2:00	0	X		0	X		0											
08/08/20 3:00	0	X		0	X		0											
08/08/20 4:00	0	X		0	X		0											
08/08/20 5:00	0	X		0	X		0											
08/08/20 6:00	0	X		0	X		0											
08/08/20 7:00	0	X		0.08628			0.02											
08/08/20 8:00	0	X		0.2427			0.24											
08/08/20 9:00	0	X		0.22716			0.23											
08/08/20 10:00	0	X		0.24348			0.24											
08/08/20 11:00	0	X		0.3399			0.34											
08/08/20 12:00	0	X		0.3402			0.34											
08/08/20 13:00	0	X		0.34002			0.34											
08/08/20 14:00	0	X		0.33936			0.34											
08/08/20 15:00	0	X		0.33894			0.34											
08/08/20 16:00	0	X		0.34104			0.34											
08/08/20 17:00	0	X		0.31536			0.32											
08/08/20 18:00	0	X		0.30408			0.3											
08/08/20 19:00	0	X		0.27492			0.27											
08/08/20 20:00	0	X		0.19662			0.2											
08/08/20 21:00	0	X		0.23832			0.24											
08/08/20 22:00	0.10056			0.2403			0.27											
08/08/20 23:00	0.20004			0.18822			0.39											
08/09/20 0:00	0.17772			0.17112			0.35											
08/09/20 1:00	0.17748			0.1671			0.34											
08/09/20 2:00	0.17754			0.16722			0.34											
08/09/20 3:00	0.17754			0.16734			0.34											
08/09/20 4:00	0.17754			0.16734			0.34											
08/09/20 5:00	0.17772			0.1674			0.35											
08/09/20 6:00	0.17766			0.1674			0.35											
08/09/20 7:00	0.17934			0.16884			0.35											
08/09/20 8:00	0.19554			0.18846			0.38											
08/09/20 9:00	0.24378			0.23892			0.48											
08/09/20 10:00	0.31416			0.29868			0.61											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/09/20 11:00	0.3417			0.32568			0.67											
08/09/20 12:00	0.37008			0.35382			0.72											
08/09/20 13:00	0.37404			0.35736			0.73											
08/09/20 14:00	0.37476			0.35802			0.73											
08/09/20 15:00	0.37128			0.35496			0.73											
08/09/20 16:00	0.3618			0.34608			0.71											
08/09/20 17:00	0.37122			0.35514			0.73											
08/09/20 18:00	0.32808			0.31338			0.64											
08/09/20 19:00	0.37278			0.35754			0.73											
08/09/20 20:00	0.34506			0.33054			0.68											
08/09/20 21:00	0.30978			0.29616			0.61											
08/09/20 22:00	0.29358			0.2817			0.58											
08/09/20 23:00	0.21018			0.20934			0.42											
08/10/20 0:00	0.1902			0.1983			0.39											
08/10/20 1:00	0.17826			0.19332			0.37											
08/10/20 2:00	0.17736			0.17838			0.36											
08/10/20 3:00	0.17784			0.17082			0.35											
08/10/20 4:00	0.18			0.17622			0.36											
08/10/20 5:00	0.17718			0.1671			0.34											
08/10/20 6:00	0.17754			0.16722			0.34											
08/10/20 7:00	0.183			0.17646			0.36											
08/10/20 8:00	0.20598			0.20442			0.41											
08/10/20 9:00	0.24384			0.23784			0.48											
08/10/20 10:00	0.31206			0.29604			0.61											
08/10/20 11:00	0.35286			0.33672			0.69											
08/10/20 12:00	0.37446			0.35802			0.73											
08/10/20 13:00	0.375			0.35808			0.73											
08/10/20 14:00	0.37392			0.3567			0.73											
08/10/20 15:00	0.37104			0.35496			0.73											
08/10/20 16:00	0.36972			0.35388			0.72											
08/10/20 17:00	0.36552			0.34938			0.71											
08/10/20 18:00	0.30072			0.28782			0.59											
08/10/20 19:00	0.23004			0.219			0.45											
08/10/20 20:00	0.22524			0.21978			0.45											
08/10/20 21:00	0.2331			0.23172			0.46											
08/10/20 22:00	0.22242			0.22086			0.44											
08/10/20 23:00	0.21432			0.2199			0.43											
08/11/20 0:00	0.17778			0.16878			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/11/20 1:00	0.17796			0.16776			0.35											
08/11/20 2:00	0.17796			0.16788			0.35											
08/11/20 3:00	0.1779			0.16794			0.35											
08/11/20 4:00	0.1779			0.16788			0.35											
08/11/20 5:00	0.1779			0.16788			0.35											
08/11/20 6:00	0.17826			0.168			0.35											
08/11/20 7:00	0.17916			0.16872			0.35											
08/11/20 8:00	0.19254			0.18546			0.38											
08/11/20 9:00	0.2016			0.19416			0.4											
08/11/20 10:00	0.23976			0.23718			0.48											
08/11/20 11:00	0.27294			0.25698			0.53											
08/11/20 12:00	0.32334			0.30768			0.63											
08/11/20 13:00	0.30336			0.28806			0.59											
08/11/20 14:00	0.29778			0.28248			0.58											
08/11/20 15:00	0.30246			0.28776			0.59											
08/11/20 16:00	0.30342			0.28896			0.59											
08/11/20 17:00	0.29268			0.27792			0.57											
08/11/20 18:00	0.2883			0.27414			0.56											
08/11/20 19:00	0.23862			0.2286			0.47											
08/11/20 20:00	0.23304			0.22332			0.46											
08/11/20 21:00	0.25392			0.24312			0.5											
08/11/20 22:00	0.20958			0.20268			0.41											
08/11/20 23:00	0.18354			0.1815			0.37											
08/12/20 0:00	0.17724			0.16734			0.34											
08/12/20 1:00	0.17736			0.16746			0.34											
08/12/20 2:00	0.17772			0.16788			0.35											
08/12/20 3:00	0.17784			0.168			0.35											
08/12/20 4:00	0.1776			0.168			0.35											
08/12/20 5:00	0.1776			0.16806			0.35											
08/12/20 6:00	0.17838			0.16824			0.35											
08/12/20 7:00	0.17988			0.1719			0.35											
08/12/20 8:00	0.1788			0.17028			0.35											
08/12/20 9:00	0.19542			0.18924			0.38											
08/12/20 10:00	0.2277			0.22362			0.45											
08/12/20 11:00	0.32904			0.31284			0.64											
08/12/20 12:00	0.3624			0.34608			0.71											
08/12/20 13:00	0.37062			0.35412			0.72											
08/12/20 14:00	0.3705			0.35406			0.72											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/12/20 15:00	0.37032			0.35454			0.72											
08/12/20 16:00	0.36978			0.3543			0.72											
08/12/20 17:00	0.36996			0.35424			0.72											
08/12/20 18:00	0.36768			0.35238			0.72											
08/12/20 19:00	0.33864			0.32424			0.66											
08/12/20 20:00	0.29298			0.27936			0.57											
08/12/20 21:00	0.297			0.28302			0.58											
08/12/20 22:00	0.27048			0.2574			0.53											
08/12/20 23:00	0.23646			0.22662			0.46											
08/13/20 0:00	0.18846			0.18684			0.38											
08/13/20 1:00	0.1773			0.1689			0.35											
08/13/20 2:00	0.17766			0.16716			0.34											
08/13/20 3:00	0.17748			0.16716			0.34											
08/13/20 4:00	0.17724			0.16716			0.34											
08/13/20 5:00	0.1773			0.16722			0.34											
08/13/20 6:00	0.1833			0.174			0.36											
08/13/20 7:00	0.18198			0.1785			0.36											
08/13/20 8:00	0.18942			0.19098			0.38											
08/13/20 9:00	0.22056			0.2214			0.44											
08/13/20 10:00	0.27696			0.26406			0.54											
08/13/20 11:00	0.35568			0.3396			0.7											
08/13/20 12:00	0.36636			0.35064			0.72											
08/13/20 13:00	0.36792			0.35178			0.72											
08/13/20 14:00	0.3678			0.35178			0.72											
08/13/20 15:00	0.34974			0.3345			0.68											
08/13/20 16:00	0.34194			0.32694			0.67											
08/13/20 17:00	0.36246			0.34734			0.71											
08/13/20 18:00	0.3342			0.31926			0.65											
08/13/20 19:00	0.2844			0.27018			0.55											
08/13/20 20:00	0.26622			0.24768			0.51											
08/13/20 21:00	0.34872			0.33408			0.68											
08/13/20 22:00	0.3528			0.33792			0.69											
08/13/20 23:00	0.22518			0.22422			0.45											
08/14/20 0:00	0.1821			0.19458			0.38											
08/14/20 1:00	0.17826			0.19656			0.37											
08/14/20 2:00	0.17778			0.17106			0.35											
08/14/20 3:00	0.1776			0.1671			0.34											
08/14/20 4:00	0.18486			0.17628			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/14/20 5:00	0.20574			0.20166			0.41											
08/14/20 6:00	0.24408			0.23484			0.48											
08/14/20 7:00	0.28524			0.26988			0.56											
08/14/20 8:00	0.36612			0.3504			0.72											
08/14/20 9:00	0.37056			0.3549			0.73											
08/14/20 10:00	0.37164			0.35628			0.73											
08/14/20 11:00	0.3423			0.32676			0.67											
08/14/20 12:00	0.32232			0.30654			0.63											
08/14/20 13:00	0.32466			0.3093			0.63											
08/14/20 14:00	0.3231			0.30756			0.63											
08/14/20 15:00	0.36954			0.35292			0.72											
08/14/20 16:00	0.3717			0.35544			0.73											
08/14/20 17:00	0.3666			0.35046			0.72											
08/14/20 18:00	0.35934			0.34386			0.7											
08/14/20 19:00	0.36846			0.35346			0.72											
08/14/20 20:00	0.34428			0.3309			0.68											
08/14/20 21:00	0.3057			0.29238			0.6											
08/14/20 22:00	0.315			0.3012			0.62											
08/14/20 23:00	0.2109			0.20568			0.42											
08/15/20 0:00	0.18864			0.19254			0.38											
08/15/20 1:00	0.19542			0.20574			0.4											
08/15/20 2:00	0.1806			0.17508			0.36											
08/15/20 3:00	0.1785			0.1677			0.35											
08/15/20 4:00	0.17844			0.16746			0.35											
08/15/20 5:00	0.1785			0.16824			0.35											
08/15/20 6:00	0.21216			0.2028			0.41											
08/15/20 7:00	0.24042			0.23616			0.48											
08/15/20 8:00	0.34068			0.32586			0.67											
08/15/20 9:00	0.37254			0.35766			0.73											
08/15/20 10:00	0.3717			0.3564			0.73											
08/15/20 11:00	0.3705			0.35436			0.72											
08/15/20 12:00	0.3378			0.32166			0.66											
08/15/20 13:00	0.32166			0.30516			0.63											
08/15/20 14:00	0.35892			0.342			0.7											
08/15/20 15:00	0.32802			0.31152			0.64											
08/15/20 16:00	0.34362			0.32736			0.67											
08/15/20 17:00	0.34986			0.33378			0.68											
08/15/20 18:00	0.35094			0.33534			0.69											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/15/20 19:00	0.37128			0.35688			0.73											
08/15/20 20:00	0.36426			0.34932			0.71											
08/15/20 21:00	0.35946			0.3441			0.7											
08/15/20 22:00	0.36648			0.3504			0.72											
08/15/20 23:00	0.28518			0.279			0.56											
08/16/20 0:00	0.22224			0.21084			0.43											
08/16/20 1:00	0.21666			0.2106			0.43											
08/16/20 2:00	0.20268			0.20226			0.4											
08/16/20 3:00	0.18894			0.19638			0.39											
08/16/20 4:00	0.18288			0.198			0.38											
08/16/20 5:00	0.20538			0.21258			0.42											
08/16/20 6:00	0.21444			0.2031			0.42											
08/16/20 7:00	0.22674			0.22122			0.45											
08/16/20 8:00	0.2187			0.21942			0.44											
08/16/20 9:00	0.28326			0.26886			0.55											
08/16/20 10:00	0.29598			0.28128			0.58											
08/16/20 11:00	0.29802			0.28278			0.58											
08/16/20 12:00	0.27702			0.26148			0.54											
08/16/20 13:00	0.31428			0.29784			0.61											
08/16/20 14:00	0.36678			0.34902			0.72											
08/16/20 15:00	0.3573			0.34062			0.7											
08/16/20 16:00	0.34776			0.33168			0.68											
08/16/20 17:00	0.33054			0.31464			0.65											
08/16/20 18:00	0.29544			0.2808			0.58											
08/16/20 19:00	0.3207			0.30618			0.63											
08/16/20 20:00	0.3693			0.35322			0.72											
08/16/20 21:00	0.34434			0.32958			0.67											
08/16/20 22:00	0.34452			0.32904			0.67											
08/16/20 23:00	0.26904			0.27492			0.54											
08/17/20 0:00	0.21582			0.22488			0.44											
08/17/20 1:00	0.20076			0.19896			0.4											
08/17/20 2:00	0.19998			0.2046			0.4											
08/17/20 3:00	0.19518			0.2064			0.4											
08/17/20 4:00	0.1917			0.2106			0.4											
08/17/20 5:00	0.22026			0.22332			0.44											
08/17/20 6:00	0.2481			0.2355			0.48											
08/17/20 7:00	0.3201			0.30396			0.62											
08/17/20 8:00	0.36852			0.35304			0.72											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/17/20 9:00	0.37482			0.35916			0.73											
08/17/20 10:00	0.37482			0.3585			0.73											
08/17/20 11:00	0.37368			0.357			0.73											
08/17/20 12:00	0.35202			0.33594			0.69											
08/17/20 13:00	0.31788			0.30264			0.62											
08/17/20 14:00	0.29796			0.28464			0.58											
08/17/20 15:00	0.20364			0.19494			0.4											
08/17/20 16:00	0.28134			0.2667			0.55											
08/17/20 17:00	0.33318			0.3183			0.65											
08/17/20 18:00	0.33318			0.31866			0.65											
08/17/20 19:00	0.33966			0.32448			0.66											
08/17/20 20:00	0.29934			0.28452			0.58											
08/17/20 21:00	0.27408			0.25902			0.53											
08/17/20 22:00	0.2562			0.2415			0.5											
08/17/20 23:00	0.23316			0.21936			0.45											
08/18/20 0:00	0.21366			0.20076			0.41											
08/18/20 1:00	0.20214			0.1947			0.4											
08/18/20 2:00	0.19188			0.18342			0.38											
08/18/20 3:00	0.1917			0.18528			0.38											
08/18/20 4:00	0.19638			0.1956			0.39											
08/18/20 5:00	0.17856			0.16908			0.35											
08/18/20 6:00	0.18318			0.17454			0.36											
08/18/20 7:00	0.2148			0.20934			0.42											
08/18/20 8:00	0.26844			0.25428			0.52											
08/18/20 9:00	0.32868			0.3141			0.64											
08/18/20 10:00	0.33036			0.31554			0.65											
08/18/20 11:00	0.34782			0.3324			0.68											
08/18/20 12:00	0.37062			0.35448			0.73											
08/18/20 13:00	0.35262			0.3369			0.69											
08/18/20 14:00	0.3435			0.3279			0.67											
08/18/20 15:00	0.2778			0.2631			0.54											
08/18/20 16:00	0.29766			0.28314			0.58											
08/18/20 17:00	0.27696			0.26262			0.54											
08/18/20 18:00	0.29232			0.27834			0.57											
08/18/20 19:00	0.2835			0.27216			0.56											
08/18/20 20:00	0.2013			0.19146			0.39											
08/18/20 21:00	0.28644			0.27474			0.56											
08/18/20 22:00	0.27918			0.26724			0.55											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/18/20 23:00	0.27732			0.2697			0.55											
08/19/20 0:00	0.24222			0.23274			0.47											
08/19/20 1:00	0.22656			0.22122			0.45											
08/19/20 2:00	0.2109			0.21222			0.42											
08/19/20 3:00	0.1935			0.20238			0.4											
08/19/20 4:00	0.21192			0.22338			0.44											
08/19/20 5:00	0.21102			0.22842			0.44											
08/19/20 6:00	0.23274			0.23568			0.47											
08/19/20 7:00	0.27516			0.2616			0.54											
08/19/20 8:00	0.3336			0.32046			0.65											
08/19/20 9:00	0.31626			0.30234			0.62											
08/19/20 10:00	0.36498			0.34992			0.71											
08/19/20 11:00	0.36906			0.35376			0.72											
08/19/20 12:00	0.37176			0.35646			0.73											
08/19/20 13:00	0.34722			0.33198			0.68											
08/19/20 14:00	0.28236			0.2685			0.55											
08/19/20 15:00	0.28002			0.26712			0.55											
08/19/20 16:00	0.30804			0.29424			0.6											
08/19/20 17:00	0.36			0.34536			0.71											
08/19/20 18:00	0.33732			0.32358			0.66											
08/19/20 19:00	0.29712			0.28392			0.58											
08/19/20 20:00	0.29532			0.28152			0.58											
08/19/20 21:00	0.2919			0.27834			0.57											
08/19/20 22:00	0.23856			0.22806			0.47											
08/19/20 23:00	0.23046			0.22134			0.45											
08/20/20 0:00	0.19644			0.1941			0.39											
08/20/20 1:00	0.18084			0.18384			0.36											
08/20/20 2:00	0.1779			0.1671			0.35											
08/20/20 3:00	0.17754			0.16728			0.34											
08/20/20 4:00	0.17742			0.16734			0.34											
08/20/20 5:00	0.17964			0.1731			0.35											
08/20/20 6:00	0.17976			0.17988			0.36											
08/20/20 7:00	0.17844			0.1749			0.35											
08/20/20 8:00	0.18732			0.1833			0.37											
08/20/20 9:00	0.20682			0.20604			0.41											
08/20/20 10:00	0.22968			0.22752			0.46											
08/20/20 11:00	0.2727			0.25662			0.53											
08/20/20 12:00	0.2472			0.23736			0.48											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/20/20 13:00	0.25104			0.2388			0.49											
08/20/20 14:00	0.20862			0.20226			0.41											
08/20/20 15:00	0.2709			0.26526			0.54											
08/20/20 16:00	0.22428			0.21708			0.44											
08/20/20 17:00	0.24174			0.23994			0.48											
08/20/20 18:00	0.27582			0.26892			0.54											
08/20/20 19:00	0.21534			0.21228			0.43											
08/20/20 20:00	0.21912			0.2217			0.44											
08/20/20 21:00	0.2229			0.23166			0.45											
08/20/20 22:00	0.18768			0.20562			0.39											
08/20/20 23:00	0.17802			0.16824			0.35											
08/21/20 0:00	0.17742			0.16746			0.34											
08/21/20 1:00	0.1773			0.1674			0.34											
08/21/20 2:00	0.17724			0.1674			0.34											
08/21/20 3:00	0.18354			0.17658			0.36											
08/21/20 4:00	0.1803			0.17832			0.36											
08/21/20 5:00	0.17724			0.16752			0.34											
08/21/20 6:00	0.19446			0.186			0.38											
08/21/20 7:00	0.21564			0.21138			0.43											
08/21/20 8:00	0.21024			0.21216			0.42											
08/21/20 9:00	0.22458			0.23124			0.46											
08/21/20 10:00	0.24408			0.2418			0.49											
08/21/20 11:00	0.25566			0.23796			0.49											
08/21/20 12:00	0.24504			0.22134			0.47											
08/21/20 13:00	0.35196			0.33642			0.69											
08/21/20 14:00	0.32754			0.31284			0.64											
08/21/20 15:00	0.35148			0.33678			0.69											
08/21/20 16:00	0.36966			0.35496			0.72											
08/21/20 17:00	0.37002			0.35556			0.73											
08/21/20 18:00	0.36948			0.3552			0.72											
08/21/20 19:00	0.24462			0.23646			0.48											
08/21/20 20:00	0.21474			0.21006			0.42											
08/21/20 21:00	0.31488			0.30486			0.62											
08/21/20 22:00	0.31302			0.30354			0.62											
08/21/20 23:00	0.20616			0.20364			0.41											
08/22/20 0:00	0.17772			0.1689			0.35											
08/22/20 1:00	0.19134			0.18246			0.37											
08/22/20 2:00	0.18654			0.1785			0.37											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/22/20 3:00	0.17814			0.16884			0.35											
08/22/20 4:00	0.17682			0.16728			0.34											
08/22/20 5:00	0.17694			0.16716			0.34											
08/22/20 6:00	0.18168			0.17298			0.35											
08/22/20 7:00	0.19554			0.19104			0.39											
08/22/20 8:00	0.19116			0.19158			0.38											
08/22/20 9:00	0.21888			0.2196			0.44											
08/22/20 10:00	0.2463			0.23298			0.48											
08/22/20 11:00	0.28428			0.26946			0.55											
08/22/20 12:00	0.26106			0.24624			0.51											
08/22/20 13:00	0.25014			0.23586			0.49											
08/22/20 14:00	0.2571			0.24126			0.5											
08/22/20 15:00	0.2913			0.27666			0.57											
08/22/20 16:00	0.34674			0.33126			0.68											
08/22/20 17:00	0.36696			0.3507			0.72											
08/22/20 18:00	0.36138			0.3465			0.71											
08/22/20 19:00	0.30714			0.29376			0.6											
08/22/20 20:00	0.30018			0.28698			0.59											
08/22/20 21:00	0.27492			0.26196			0.54											
08/22/20 22:00	0.24828			0.23568			0.48											
08/22/20 23:00	0.21828			0.21018			0.43											
08/23/20 0:00	0.18864			0.19002			0.38											
08/23/20 1:00	0.17868			0.17436			0.35											
08/23/20 2:00	0.17706			0.16698			0.34											
08/23/20 3:00	0.17718			0.16704			0.34											
08/23/20 4:00	0.17724			0.16716			0.34											
08/23/20 5:00	0.17724			0.16722			0.34											
08/23/20 6:00	0.1773			0.16728			0.34											
08/23/20 7:00	0.17778			0.16722			0.35											
08/23/20 8:00	0.18264			0.17226			0.35											
08/23/20 9:00	0.22368			0.21624			0.44											
08/23/20 10:00	0.25944			0.24384			0.5											
08/23/20 11:00	0.32976			0.31488			0.64											
08/23/20 12:00	0.35376			0.33834			0.69											
08/23/20 13:00	0.35064			0.33528			0.69											
08/23/20 14:00	0.32988			0.31494			0.64											
08/23/20 15:00	0.32388			0.3096			0.63											
08/23/20 16:00	0.33534			0.321			0.66											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/23/20 17:00	0.32778			0.31428			0.64											
08/23/20 18:00	0.30372			0.29034			0.59											
08/23/20 19:00	0.25896			0.24624			0.51											
08/23/20 20:00	0.252			0.23934			0.49											
08/23/20 21:00	0.2901			0.28326			0.57											
08/23/20 22:00	0.26472			0.24882			0.51											
08/23/20 23:00	0.21012			0.2022			0.41											
08/24/20 0:00	0.18678			0.18882			0.38											
08/24/20 1:00	0.17802			0.1698			0.35											
08/24/20 2:00	0.17778			0.1674			0.35											
08/24/20 3:00	0.17772			0.16752			0.35											
08/24/20 4:00	0.18792			0.1824			0.37											
08/24/20 5:00	0.18426			0.1872			0.37											
08/24/20 6:00	0.19602			0.2034			0.4											
08/24/20 7:00	0.21978			0.22932			0.45											
08/24/20 8:00	0.26874			0.26124			0.53											
08/24/20 9:00	0.31878			0.30366			0.62											
08/24/20 10:00	0.32754			0.31236			0.64											
08/24/20 11:00	0.36696			0.35148			0.72											
08/24/20 12:00	0.34206			0.327			0.67											
08/24/20 13:00	0.31482			0.29994			0.61											
08/24/20 14:00	0.32778			0.3129			0.64											
08/24/20 15:00	0.30906			0.29448			0.6											
08/24/20 16:00	0.32844			0.3141			0.64											
08/24/20 17:00	0.32808			0.31416			0.64											
08/24/20 18:00	0.30918			0.2961			0.61											
08/24/20 19:00	0.26172			0.24918			0.51											
08/24/20 20:00	0.23484			0.22536			0.46											
08/24/20 21:00	0.26904			0.2574			0.53											
08/24/20 22:00	0.276			0.264			0.54											
08/24/20 23:00	0.2199			0.21168			0.43											
08/25/20 0:00	0.19134			0.19284			0.38											
08/25/20 1:00	0.17778			0.17088			0.35											
08/25/20 2:00	0.17766			0.1674			0.35											
08/25/20 3:00	0.1776			0.16746			0.35											
08/25/20 4:00	0.17772			0.16746			0.35											
08/25/20 5:00	0.17772			0.16764			0.35											
08/25/20 6:00	0.19176			0.18552			0.38											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/25/20 7:00	0.20202			0.20262			0.4											
08/25/20 8:00	0.22884			0.23262			0.46											
08/25/20 9:00	0.25524			0.24114			0.5											
08/25/20 10:00	0.29994			0.28542			0.59											
08/25/20 11:00	0.33666			0.32142			0.66											
08/25/20 12:00	0.29904			0.28422			0.58											
08/25/20 13:00	0.29934			0.28446			0.58											
08/25/20 14:00	0.30072			0.28554			0.59											
08/25/20 15:00	0.32694			0.3117			0.64											
08/25/20 16:00	0.33516			0.3201			0.66											
08/25/20 17:00	0.36426			0.34872			0.71											
08/25/20 18:00	0.32202			0.30756			0.63											
08/25/20 19:00	0.29694			0.28356			0.58											
08/25/20 20:00	0.24534			0.23358			0.48											
08/25/20 21:00	0.24684			0.23562			0.48											
08/25/20 22:00	0.2337			0.22758			0.46											
08/25/20 23:00	0.18528			0.18936			0.37											
08/26/20 0:00	0.17772			0.16872			0.35											
08/26/20 1:00	0.17778			0.16776			0.35											
08/26/20 2:00	0.17742			0.16746			0.34											
08/26/20 3:00	0.17748			0.16776			0.35											
08/26/20 4:00	0.17928			0.17388			0.35											
08/26/20 5:00	0.17916			0.18132			0.36											
08/26/20 6:00	0.17994			0.1833			0.36											
08/26/20 7:00	0.1989			0.20544			0.4											
08/26/20 8:00	0.21684			0.22794			0.44											
08/26/20 9:00	0.2343			0.24144			0.48											
08/26/20 10:00	0.28038			0.26508			0.55											
08/26/20 11:00	0.33192			0.31692			0.65											
08/26/20 12:00	0.35982			0.34458			0.7											
08/26/20 13:00	0.36744			0.35268			0.72											
08/26/20 14:00	0.36732			0.35202			0.72											
08/26/20 15:00	0.36714			0.35196			0.72											
08/26/20 16:00	0.36774			0.35274			0.72											
08/26/20 17:00	0.36444			0.34992			0.71											
08/26/20 18:00	0.29526			0.28212			0.58											
08/26/20 19:00	0.25134			0.23544			0.49											
08/26/20 20:00	0.23802			0.23334			0.47											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/26/20 21:00	0.24186			0.23502			0.48											
08/26/20 22:00	0.19344			0.18876			0.38											
08/26/20 23:00	0.18246			0.1848			0.37											
08/27/20 0:00	0.1776			0.168			0.35											
08/27/20 1:00	0.1776			0.168			0.35											
08/27/20 2:00	0.17748			0.16794			0.35											
08/27/20 3:00	0.17742			0.16806			0.35											
08/27/20 4:00	0.17748			0.16818			0.35											
08/27/20 5:00	0.1776			0.1683			0.35											
08/27/20 6:00	0.17784			0.1689			0.35											
08/27/20 7:00	0.17874			0.16938			0.35											
08/27/20 8:00	0.18552			0.17898			0.36											
08/27/20 9:00	0.19962			0.19824			0.4											
08/27/20 10:00	0.24408			0.24066			0.48											
08/27/20 11:00	0.2799			0.2643			0.54											
08/27/20 12:00	0.27804			0.2643			0.54											
08/27/20 13:00	0.32664			0.31128			0.64											
08/27/20 14:00	0.32616			0.3111			0.64											
08/27/20 15:00	0.3147			0.29988			0.61											
08/27/20 16:00	0.33096			0.3165			0.65											
08/27/20 17:00	0.33612			0.32154			0.66											
08/27/20 18:00	0.30096			0.28686			0.59											
08/27/20 19:00	0.27528			0.26112			0.54											
08/27/20 20:00	0.23652			0.22494			0.46											
08/27/20 21:00	0.23616			0.22992			0.47											
08/27/20 22:00	0.19524			0.19236			0.39											
08/27/20 23:00	0.17766			0.1827			0.36											
08/28/20 0:00	0.17712			0.1677			0.34											
08/28/20 1:00	0.177			0.16716			0.34											
08/28/20 2:00	0.177			0.16722			0.34											
08/28/20 3:00	0.1773			0.16752			0.34											
08/28/20 4:00	0.17736			0.16746			0.34											
08/28/20 5:00	0.17718			0.16776			0.34											
08/28/20 6:00	0.17778			0.16824			0.35											
08/28/20 7:00	0.18552			0.17982			0.37											
08/28/20 8:00	0.20244			0.2022			0.4											
08/28/20 9:00	0.22482			0.23052			0.46											
08/28/20 10:00	0.25056			0.23904			0.49											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/28/20 11:00	0.31914			0.3042			0.62											
08/28/20 12:00	0.36936			0.3549			0.72											
08/28/20 13:00	0.36894			0.35322			0.72											
08/28/20 14:00	0.33102			0.3177			0.65											
08/28/20 15:00	0.33606			0.3222			0.66											
08/28/20 16:00	0.36654			0.35232			0.72											
08/28/20 17:00	0.3552			0.34122			0.7											
08/28/20 18:00	0.29436			0.28134			0.58											
08/28/20 19:00	0.24888			0.23754			0.49											
08/28/20 20:00	0.24732			0.23718			0.48											
08/28/20 21:00	0.25068			0.23856			0.49											
08/28/20 22:00	0.23604			0.2298			0.47											
08/28/20 23:00	0.2043			0.2046			0.41											
08/29/20 0:00	0.18018			0.17628			0.36											
08/29/20 1:00	0.17742			0.16794			0.35											
08/29/20 2:00	0.17766			0.16752			0.35											
08/29/20 3:00	0.17748			0.16746			0.34											
08/29/20 4:00	0.17736			0.16752			0.34											
08/29/20 5:00	0.1773			0.16776			0.35											
08/29/20 6:00	0.1776			0.16776			0.35											
08/29/20 7:00	0.17826			0.16812			0.35											
08/29/20 8:00	0.18786			0.18108			0.37											
08/29/20 9:00	0.20976			0.20724			0.42											
08/29/20 10:00	0.21606			0.2187			0.43											
08/29/20 11:00	0.25134			0.2385			0.49											
08/29/20 12:00	0.30312			0.28812			0.59											
08/29/20 13:00	0.36096			0.34614			0.71											
08/29/20 14:00	0.34272			0.32796			0.67											
08/29/20 15:00	0.36414			0.34956			0.71											
08/29/20 16:00	0.32172			0.3078			0.63											
08/29/20 17:00	0.29226			0.27924			0.57											
08/29/20 18:00	0.2442			0.23292			0.48											
08/29/20 19:00	0.2145			0.20946			0.42											
08/29/20 20:00	0.22212			0.22212			0.44											
08/29/20 21:00	0.2421			0.23952			0.48											
08/29/20 22:00	0.20616			0.20742			0.41											
08/29/20 23:00	0.18324			0.19386			0.38											
08/30/20 0:00	0.17772			0.168			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 1:00	0.1776			0.16752			0.35											
08/30/20 2:00	0.1776			0.16764			0.35											
08/30/20 3:00	0.17748			0.16776			0.35											
08/30/20 4:00	0.17742			0.16782			0.35											
08/30/20 5:00	0.17742			0.16788			0.35											
08/30/20 6:00	0.1782			0.16812			0.35											
08/30/20 7:00	0.1782			0.16818			0.35											
08/30/20 8:00	0.17814			0.16794			0.35											
08/30/20 9:00	0.18606			0.17718			0.36											
08/30/20 10:00	0.21042			0.20598			0.42											
08/30/20 11:00	0.2388			0.23694			0.48											
08/30/20 12:00	0.30042			0.28566			0.59											
08/30/20 13:00	0.35682			0.34176			0.7											
08/30/20 14:00	0.3684			0.35286			0.72											
08/30/20 15:00	0.34764			0.33282			0.68											
08/30/20 16:00	0.3156			0.30138			0.62											
08/30/20 17:00	0.31296			0.29874			0.61											
08/30/20 18:00	0.24936			0.23598			0.49											
08/30/20 19:00	0.22578			0.21462			0.44											
08/30/20 20:00	0.20118			0.1974			0.4											
08/30/20 21:00	0.24258			0.23532			0.48											
08/30/20 22:00	0.20484			0.17844			0.38											
08/30/20 23:00	0.3363			0.0717			0.34											
08/31/20 0:00	0.35448			0	X		0.35											
08/31/20 1:00	0.32292			0	X		0.32											
08/31/20 2:00	0.29376			0	X		0.29											
08/31/20 3:00	0.29298			0	X		0.29											
08/31/20 4:00	0.31818			0	X		0.32											
08/31/20 5:00	0.2982			0	X		0.3											
08/31/20 6:00	0.32286			0	X		0.32											
08/31/20 7:00	0.33684			0	X		0.34											
08/31/20 8:00	0.34914			0	X		0.35											
08/31/20 9:00	0.32328			0	X		0.32											
08/31/20 10:00	0.32328			0	X		0.32											
08/31/20 11:00	0.3408			0	X		0.34											
08/31/20 12:00	0.35982			0	X		0.36											
08/31/20 13:00	0.3546			0	X		0.35											
08/31/20 14:00	0.3246			0.087			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:00	0.26874			0.22074			0.49											
08/31/20 16:00	0.30138			0.28518			0.59											
08/31/20 17:00	0.3204			0.306			0.63											
08/31/20 18:00	0.30462			0.29088			0.6											
08/31/20 19:00	0.29592			0.28278			0.58											
08/31/20 20:00	0.18912			0.18006			0.37											
08/31/20 21:00	0.24498			0.23448			0.48											
08/31/20 22:00	0.21174			0.2037			0.42											
08/31/20 23:00	0.20502			0.20382			0.41											
09/01/20 0:00	0.18162			0.19188			0.37											
09/01/20 1:00	0.17778			0.1725			0.35											
09/01/20 2:00	0.17754			0.16764			0.35											
09/01/20 3:00	0.17796			0.1677			0.35											
09/01/20 4:00	0.1791			0.16944			0.35											
09/01/20 5:00	0.21198			0.2052			0.42											
09/01/20 6:00	0.2175			0.21522			0.43											
09/01/20 7:00	0.23274			0.2367			0.47											
09/01/20 8:00	0.25734			0.24384			0.5											
09/01/20 9:00	0.25548			0.24168			0.5											
09/01/20 10:00	0.24972			0.23832			0.49											
09/01/20 11:00	0.26994			0.2538			0.52											
09/01/20 12:00	0.3555			0.3408			0.7											
09/01/20 13:00	0.35712			0.34308			0.7											
09/01/20 14:00	0.36462			0.3507			0.72											
09/01/20 15:00	0.36594			0.35184			0.72											
09/01/20 16:00	0.36324			0.34926			0.71											
09/01/20 17:00	0.34098			0.32748			0.67											
09/01/20 18:00	0.32466			0.31164			0.64											
09/01/20 19:00	0.31302			0.29988			0.61											
09/01/20 20:00	0.32928			0.31662			0.65											
09/01/20 21:00	0.25962			0.24816			0.51											
09/01/20 22:00	0.2073			0.19764			0.4											
09/01/20 23:00	0.20898			0.20484			0.41											
09/02/20 0:00	0.2082			0.20994			0.42											
09/02/20 1:00	0.19548			0.20352			0.4											
09/02/20 2:00	0.1857			0.20046			0.39											
09/02/20 3:00	0.18474			0.2064			0.39											
09/02/20 4:00	0.1836			0.21378			0.4											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/02/20 5:00	0.19236			0.20544			0.4											
09/02/20 6:00	0.20976			0.2034			0.41											
09/02/20 7:00	0.22326			0.2232			0.45											
09/02/20 8:00	0.23556			0.24372			0.48											
09/02/20 9:00	0.2262			0.22434			0.45											
09/02/20 10:00	0.22728			0.22188			0.45											
09/02/20 11:00	0.21258			0.2145			0.43											
09/02/20 12:00	0.21216			0.22014			0.43											
09/02/20 13:00	0.2604			0.24972			0.51											
09/02/20 14:00	0.33006			0.31614			0.65											
09/02/20 15:00	0.33084			0.3168			0.65											
09/02/20 16:00	0.33072			0.31686			0.65											
09/02/20 17:00	0.3306			0.31692			0.65											
09/02/20 18:00	0.30864			0.2952			0.6											
09/02/20 19:00	0.27228			0.25896			0.53											
09/02/20 20:00	0.23694			0.22626			0.46											
09/02/20 21:00	0.27606			0.26742			0.54											
09/02/20 22:00	0.24558			0.23742			0.48											
09/02/20 23:00	0.21732			0.2154			0.43											
09/03/20 0:00	0.19716			0.2049			0.4											
09/03/20 1:00	0.18204			0.2013			0.38											
09/03/20 2:00	0.17802			0.19548			0.37											
09/03/20 3:00	0.17952			0.19908			0.38											
09/03/20 4:00	0.18498			0.20874			0.39											
09/03/20 5:00	0.18162			0.21216			0.39											
09/03/20 6:00	0.17892			0.21522			0.39											
09/03/20 7:00	0.18078			0.21552			0.4											
09/03/20 8:00	0.21462			0.20472			0.42											
09/03/20 9:00	0.2118			0.20874			0.42											
09/03/20 10:00	0.22896			0.23118			0.46											
09/03/20 11:00	0.25626			0.24216			0.5											
09/03/20 12:00	0.33918			0.32442			0.66											
09/03/20 13:00	0.36954			0.35442			0.72											
09/03/20 14:00	0.369			0.3534			0.72											
09/03/20 15:00	0.36882			0.35334			0.72											
09/03/20 16:00	0.3669			0.35166			0.72											
09/03/20 17:00	0.36702			0.35196			0.72											
09/03/20 18:00	0.36636			0.35244			0.72											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/03/20 19:00	0.35394			0.34038			0.69											
09/03/20 20:00	0.34752			0.33444			0.68											
09/03/20 21:00	0.3393			0.327			0.67											
09/03/20 22:00	0.26346			0.2505			0.51											
09/03/20 23:00	0.22968			0.21312			0.44											
09/04/20 0:00	0.21492			0.20388			0.42											
09/04/20 1:00	0.19932			0.19722			0.4											
09/04/20 2:00	0.19344			0.19992			0.39											
09/04/20 3:00	0.1908			0.20472			0.4											
09/04/20 4:00	0.19326			0.2136			0.41											
09/04/20 5:00	0.19782			0.20286			0.4											
09/04/20 6:00	0.19656			0.19734			0.39											
09/04/20 7:00	0.19326			0.20202			0.4											
09/04/20 8:00	0.2073			0.22008			0.43											
09/04/20 9:00	0.20538			0.22554			0.43											
09/04/20 10:00	0.22686			0.23946			0.47											
09/04/20 11:00	0.28086			0.2673			0.55											
09/04/20 12:00	0.32358			0.30948			0.63											
09/04/20 13:00	0.36624			0.35166			0.72											
09/04/20 14:00	0.36732			0.3525			0.72											
09/04/20 15:00	0.36678			0.35214			0.72											
09/04/20 16:00	0.366			0.35124			0.72											
09/04/20 17:00	0.36594			0.35142			0.72											
09/04/20 18:00	0.3663			0.35214			0.72											
09/04/20 19:00	0.3669			0.3531			0.72											
09/04/20 20:00	0.36702			0.35376			0.72											
09/04/20 21:00	0.36			0.34788			0.71											
09/04/20 22:00	0.30864			0.29724			0.61											
09/04/20 23:00	0.20112			0.20076			0.4											
09/05/20 0:00	0.18342			0.19314			0.38											
09/05/20 1:00	0.17922			0.1974			0.38											
09/05/20 2:00	0.17772			0.19728			0.38											
09/05/20 3:00	0.17922			0.18342			0.36											
09/05/20 4:00	0.17892			0.18168			0.36											
09/05/20 5:00	0.17862			0.16926			0.35											
09/05/20 6:00	0.17886			0.16932			0.35											
09/05/20 7:00	0.18144			0.17106			0.35											
09/05/20 8:00	0.19488			0.18858			0.38											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/20 9:00	0.23172			0.22632			0.46											
09/05/20 10:00	0.2823			0.26766			0.55											
09/05/20 11:00	0.33258			0.31782			0.65											
09/05/20 12:00	0.35712			0.34218			0.7											
09/05/20 13:00	0.36618			0.3507			0.72											
09/05/20 14:00	0.36552			0.35034			0.72											
09/05/20 15:00	0.36336			0.35076			0.71											
09/05/20 16:00	0.36234			0.34998			0.71											
09/05/20 17:00	0.35952			0.34716			0.71											
09/05/20 18:00	0.32238			0.30864			0.63											
09/05/20 19:00	0.33858			0.32478			0.66											
09/05/20 20:00	0.36528			0.35028			0.72											
09/05/20 21:00	0.33798			0.3234			0.66											
09/05/20 22:00	0.26838			0.2553			0.52											
09/05/20 23:00	0.23208			0.222			0.45											
09/06/20 0:00	0.20688			0.2052			0.41											
09/06/20 1:00	0.183			0.19116			0.37											
09/06/20 2:00	0.1794			0.16908			0.35											
09/06/20 3:00	0.17964			0.16914			0.35											
09/06/20 4:00	0.17946			0.1692			0.35											
09/06/20 5:00	0.18072			0.17022			0.35											
09/06/20 6:00	0.18516			0.17898			0.36											
09/06/20 7:00	0.18288			0.18378			0.37											
09/06/20 8:00	0.19698			0.20262			0.4											
09/06/20 9:00	0.22932			0.2364			0.47											
09/06/20 10:00	0.24426			0.2328			0.48											
09/06/20 11:00	0.22134			0.21366			0.44											
09/06/20 12:00	0.28872			0.27354			0.56											
09/06/20 13:00	0.32472			0.31182			0.64											
09/06/20 14:00	0.35076			0.33768			0.69											
09/06/20 15:00	0.36198			0.34848			0.71											
09/06/20 16:00	0.36102			0.34812			0.71											
09/06/20 17:00	0.36072			0.34746			0.71											
09/06/20 18:00	0.35778			0.34416			0.7											
09/06/20 19:00	0.3453			0.33174			0.68											
09/06/20 20:00	0.34992			0.33546			0.69											
09/06/20 21:00	0.36096			0.34614			0.71											
09/06/20 22:00	0.31074			0.29748			0.61											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/06/20 23:00	0.24738			0.23622			0.48											
09/07/20 0:00	0.2163			0.21102			0.43											
09/07/20 1:00	0.18972			0.19302			0.38											
09/07/20 2:00	0.17976			0.17544			0.36											
09/07/20 3:00	0.17958			0.17376			0.35											
09/07/20 4:00	0.17946			0.16872			0.35											
09/07/20 5:00	0.17904			0.16866			0.35											
09/07/20 6:00	0.17922			0.16926			0.35											
09/07/20 7:00	0.19122			0.18432			0.38											
09/07/20 8:00	0.22446			0.22008			0.44											
09/07/20 9:00	0.29334			0.27636			0.57											
09/07/20 10:00	0.36216			0.34788			0.71											
09/07/20 11:00	0.35268			0.3384			0.69											
09/07/20 12:00	0.3039			0.29028			0.59											
09/07/20 13:00	0.35754			0.34344			0.7											
09/07/20 14:00	0.30528			0.29352			0.6											
09/07/20 15:00	0.28938			0.27708			0.57											
09/07/20 16:00	0.32544			0.312			0.64											
09/07/20 17:00	0.28914			0.27672			0.57											
09/07/20 18:00	0.26016			0.24744			0.51											
09/07/20 19:00	0.24732			0.23388			0.48											
09/07/20 20:00	0.26226			0.24852			0.51											
09/07/20 21:00	0.31104			0.29754			0.61											
09/07/20 22:00	0.24756			0.23634			0.48											
09/07/20 23:00	0.22794			0.2199			0.45											
09/08/20 0:00	0.19392			0.19668			0.39											
09/08/20 1:00	0.21462			0.22302			0.44											
09/08/20 2:00	0.21396			0.2289			0.44											
09/08/20 3:00	0.18816			0.20718			0.4											
09/08/20 4:00	0.1869			0.21144			0.4											
09/08/20 5:00	0.21804			0.22266			0.44											
09/08/20 6:00	0.24738			0.24318			0.49											
09/08/20 7:00	0.28338			0.27228			0.56											
09/08/20 8:00	0.3108			0.29664			0.61											
09/08/20 9:00	0.33774			0.32382			0.66											
09/08/20 10:00	0.29478			0.28176			0.58											
09/08/20 11:00	0.23892			0.2298			0.47											
09/08/20 12:00	0.2346			0.2322			0.47											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/08/20 13:00	0.23274			0.23706			0.47											
09/08/20 14:00	0.18924			0.20184			0.39											
09/08/20 15:00	0.17946			0.16848			0.35											
09/08/20 16:00	0.1785			0.1677			0.35											
09/08/20 17:00	0.17874			0.16806			0.35											
09/08/20 18:00	0.18282			0.177			0.36											
09/08/20 19:00	0.18666			0.18786			0.37											
09/08/20 20:00	0.18204			0.1734			0.36											
09/08/20 21:00	0.24792			0.23622			0.48											
09/08/20 22:00	0.22716			0.22002			0.45											
09/08/20 23:00	0.1827			0.17478			0.36											
09/09/20 0:00	0.17856			0.16848			0.35											
09/09/20 1:00	0.17814			0.1686			0.35											
09/09/20 2:00	0.1782			0.16896			0.35											
09/09/20 3:00	0.1785			0.16896			0.35											
09/09/20 4:00	0.1785			0.16902			0.35											
09/09/20 5:00	0.17976			0.17028			0.35											
09/09/20 6:00	0.21894			0.21036			0.43											
09/09/20 7:00	0.37872			0.36228			0.74											
09/09/20 8:00	0.38886			0.37152			0.76											
09/09/20 9:00	0.37476			0.3675			0.74											
09/09/20 10:00	0.38016			0.36498			0.75											
09/09/20 11:00	0.38184			0.36444			0.75											
09/09/20 12:00	0.38022			0.36336			0.74											
09/09/20 13:00	0.37914			0.3624			0.74											
09/09/20 14:00	0.37884			0.36246			0.74											
09/09/20 15:00	0.37944			0.36276			0.74											
09/09/20 16:00	0.36438			0.35916			0.72											
09/09/20 17:00	0.21666			0.21534			0.43											
09/09/20 18:00	0.20556			0.21372			0.42											
09/09/20 19:00	0.21768			0.23022			0.45											
09/09/20 20:00	0.18108			0.20028			0.38											
09/09/20 21:00	0.18036			0.18558			0.37											
09/09/20 22:00	0.18678			0.19476			0.38											
09/09/20 23:00	0.18342			0.1983			0.38											
09/10/20 0:00	0.18012			0.1734			0.35											
09/10/20 1:00	0.18096			0.17418			0.36											
09/10/20 2:00	0.18006			0.1704			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/10/20 3:00	0.18			0.1704			0.35											
09/10/20 4:00	0.18528			0.17718			0.36											
09/10/20 5:00	0.17958			0.17034			0.35											
09/10/20 6:00	0.18042			0.17136			0.35											
09/10/20 7:00	0.18402			0.1785			0.36											
09/10/20 8:00	0.18024			0.17004			0.35											
09/10/20 9:00	0.19686			0.18912			0.39											
09/10/20 10:00	0.20004			0.19908			0.4											
09/10/20 11:00	0.23736			0.24126			0.48											
09/10/20 12:00	0.23682			0.23934			0.48											
09/10/20 13:00	0.26118			0.25428			0.52											
09/10/20 14:00	0.25122			0.24588			0.5											
09/10/20 15:00	0.26106			0.2469			0.51											
09/10/20 16:00	0.25248			0.24192			0.49											
09/10/20 17:00	0.26676			0.25056			0.52											
09/10/20 18:00	0.24582			0.2364			0.48											
09/10/20 19:00	0.33318			0.31842			0.65											
09/10/20 20:00	0.2775			0.2637			0.54											
09/10/20 21:00	0.26736			0.25032			0.52											
09/10/20 22:00	0.23772			0.21948			0.46											
09/10/20 23:00	0.20436			0.19254			0.4											
09/11/20 0:00	0.19752			0.19392			0.39											
09/11/20 1:00	0.17952			0.18138			0.36											
09/11/20 2:00	0.17934			0.16992			0.35											
09/11/20 3:00	0.18018			0.17094			0.35											
09/11/20 4:00	0.19908			0.19494			0.39											
09/11/20 5:00	0.17964			0.17136			0.35											
09/11/20 6:00	0.17952			0.1701			0.35											
09/11/20 7:00	0.18456			0.17832			0.36											
09/11/20 8:00	0.19776			0.19674			0.39											
09/11/20 9:00	0.2286			0.23232			0.46											
09/11/20 10:00	0.24636			0.24162			0.49											
09/11/20 11:00	0.2502			0.24522			0.5											
09/11/20 12:00	0.2655			0.25656			0.52											
09/11/20 13:00	0.2895			0.27468			0.56											
09/11/20 14:00	0.31308			0.30102			0.61											
09/11/20 15:00	0.21366			0.22854			0.44											
09/11/20 16:00	0.21696			0.22722			0.44											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/11/20 17:00	0.2523			0.24288			0.5											
09/11/20 18:00	0.23838			0.23142			0.47											
09/11/20 19:00	0.189			0.18744			0.38											
09/11/20 20:00	0.22926			0.22272			0.45											
09/11/20 21:00	0.24996			0.24612			0.5											
09/11/20 22:00	0.22428			0.22452			0.45											
09/11/20 23:00	0.21714			0.22656			0.44											
09/12/20 0:00	0.18054			0.19746			0.38											
09/12/20 1:00	0.17994			0.17064			0.35											
09/12/20 2:00	0.18018			0.17058			0.35											
09/12/20 3:00	0.17976			0.17058			0.35											
09/12/20 4:00	0.17964			0.17058			0.35											
09/12/20 5:00	0.18012			0.17166			0.35											
09/12/20 6:00	0.18096			0.17826			0.36											
09/12/20 7:00	0.18132			0.17436			0.36											
09/12/20 8:00	0.18576			0.1836			0.37											
09/12/20 9:00	0.19254			0.19728			0.39											
09/12/20 10:00	0.20892			0.21828			0.43											
09/12/20 11:00	0.21972			0.23436			0.45											
09/12/20 12:00	0.25008			0.24132			0.49											
09/12/20 13:00	0.32928			0.31566			0.64											
09/12/20 14:00	0.35736			0.34362			0.7											
09/12/20 15:00	0.27354			0.26082			0.53											
09/12/20 16:00	0.28236			0.26838			0.55											
09/12/20 17:00	0.34584			0.33258			0.68											
09/12/20 18:00	0.24948			0.23922			0.49											
09/12/20 19:00	0.22452			0.2205			0.45											
09/12/20 20:00	0.2127			0.2172			0.43											
09/12/20 21:00	0.25374			0.24282			0.5											
09/12/20 22:00	0.23178			0.2211			0.45											
09/12/20 23:00	0.21786			0.21342			0.43											
09/13/20 0:00	0.1899			0.19572			0.39											
09/13/20 1:00	0.18132			0.18096			0.36											
09/13/20 2:00	0.17988			0.17178			0.35											
09/13/20 3:00	0.18054			0.17196			0.35											
09/13/20 4:00	0.18042			0.1719			0.35											
09/13/20 5:00	0.17952			0.17076			0.35											
09/13/20 6:00	0.17952			0.1704			0.35											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/13/20 7:00	0.18102			0.1713			0.35											
09/13/20 8:00	0.19734			0.19116			0.39											
09/13/20 9:00	0.21774			0.21666			0.43											
09/13/20 10:00	0.24876			0.23664			0.49											
09/13/20 11:00	0.28182			0.26646			0.55											
09/13/20 12:00	0.29286			0.27822			0.57											
09/13/20 13:00	0.32064			0.3063			0.63											
09/13/20 14:00	0.33504			0.3207			0.66											
09/13/20 15:00	0.31842			0.30462			0.62											
09/13/20 16:00	0.26514			0.25194			0.52											
09/13/20 17:00	0.27048			0.25734			0.53											
09/13/20 18:00	0.26784			0.25512			0.52											
09/13/20 19:00	0.21684			0.20868			0.43											
09/13/20 20:00	0.28794			0.27792			0.57											
09/13/20 21:00	0.2709			0.25974			0.53											
09/13/20 22:00	0.24246			0.23202			0.47											
09/13/20 23:00	0.20154			0.19872			0.4											
09/14/20 0:00	0.18036			0.1812			0.36											
09/14/20 1:00	0.17952			0.1701			0.35											
09/14/20 2:00	0.17958			0.17016			0.35											
09/14/20 3:00	0.17946			0.17028			0.35											
09/14/20 4:00	0.17964			0.17118			0.35											
09/14/20 5:00	0.17958			0.17076			0.35											
09/14/20 6:00	0.18126			0.17328			0.35											
09/14/20 7:00	0.18996			0.1866			0.38											
09/14/20 8:00	0.20382			0.20748			0.41											
09/14/20 9:00	0.21294			0.22344			0.44											
09/14/20 10:00	0.22662			0.23616			0.46											
09/14/20 11:00	0.25416			0.24246			0.5											
09/14/20 12:00	0.28434			0.27408			0.56											
09/14/20 13:00	0.34182			0.32766			0.67											
09/14/20 14:00	0.37044			0.3561			0.73											
09/14/20 15:00	0.33606			0.32208			0.66											
09/14/20 16:00	0.35724			0.3432			0.7											
09/14/20 17:00	0.37074			0.35688			0.73											
09/14/20 18:00	0.34602			0.33276			0.68											
09/14/20 19:00	0.23028			0.21954			0.45											
09/14/20 20:00	0.237			0.22728			0.46											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/14/20 21:00	0.26226			0.2505			0.51											
09/14/20 22:00	0.23268			0.2274			0.46											
09/14/20 23:00	0.19356			0.19992			0.39											
09/15/20 0:00	0.17994			0.18894			0.37											
09/15/20 1:00	0.17982			0.17868			0.36											
09/15/20 2:00	0.17988			0.17046			0.35											
09/15/20 3:00	0.17982			0.17046			0.35											
09/15/20 4:00	0.18108			0.17376			0.35											
09/15/20 5:00	0.18564			0.1842			0.37											
09/15/20 6:00	0.18138			0.18654			0.37											
09/15/20 7:00	0.19182			0.19986			0.39											
09/15/20 8:00	0.21174			0.22296			0.43											
09/15/20 9:00	0.22776			0.23832			0.47											
09/15/20 10:00	0.25404			0.24246			0.5											
09/15/20 11:00	0.27288			0.25728			0.53											
09/15/20 12:00	0.33102			0.31602			0.65											
09/15/20 13:00	0.36474			0.34998			0.71											
09/15/20 14:00	0.37032			0.35544			0.73											
09/15/20 15:00	0.36468			0.34968			0.71											
09/15/20 16:00	0.34638			0.33186			0.68											
09/15/20 17:00	0.34632			0.33264			0.68											
09/15/20 18:00	0.3057			0.29286			0.6											
09/15/20 19:00	0.26184			0.24918			0.51											
09/15/20 20:00	0.22392			0.21504			0.44											
09/15/20 21:00	0.24798			0.23946			0.49											
09/15/20 22:00	0.2223			0.21492			0.44											
09/15/20 23:00	0.21054			0.21174			0.42											
09/16/20 0:00	0.1938			0.20526			0.4											
09/16/20 1:00	0.18036			0.2016			0.38											
09/16/20 2:00	0.17946			0.19356			0.37											
09/16/20 3:00	0.1824			0.19272			0.38											
09/16/20 4:00	0.19758			0.19362			0.39											
09/16/20 5:00	0.20034			0.20508			0.41											
09/16/20 6:00	0.20052			0.21354			0.41											
09/16/20 7:00	0.20934			0.22902			0.44											
09/16/20 8:00	0.23064			0.24054			0.47											
09/16/20 9:00	0.25098			0.24156			0.49											
09/16/20 10:00	0.27774			0.26304			0.54											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/20 11:00	0.32064			0.30594			0.63											
09/16/20 12:00	0.35568			0.34104			0.7											
09/16/20 13:00	0.34344			0.32958			0.67											
09/16/20 14:00	0.366			0.35202			0.72											
09/16/20 15:00	0.3669			0.35274			0.72											
09/16/20 16:00	0.36888			0.35454			0.72											
09/16/20 17:00	0.36576			0.3516			0.72											
09/16/20 18:00	0.33876			0.32556			0.66											
09/16/20 19:00	0.29448			0.28212			0.58											
09/16/20 20:00	0.27552			0.26358			0.54											
09/16/20 21:00	0.27378			0.26364			0.54											
09/16/20 22:00	0.22242			0.2193			0.44											
09/16/20 23:00	0.2073			0.21612			0.42											
09/17/20 0:00	0.18696			0.20874			0.4											
09/17/20 1:00	0.17934			0.20088			0.38											
09/17/20 2:00	0.17922			0.19788			0.38											
09/17/20 3:00	0.17898			0.19746			0.38											
09/17/20 4:00	0.18888			0.20826			0.4											
09/17/20 5:00	0.1869			0.21504			0.4											
09/17/20 6:00	0.19338			0.22704			0.42											
09/17/20 7:00	0.2064			0.24144			0.45											
09/17/20 8:00	0.22914			0.24066			0.47											
09/17/20 9:00	0.25572			0.24282			0.5											
09/17/20 10:00	0.27072			0.25674			0.53											
09/17/20 11:00	0.28002			0.26622			0.55											
09/17/20 12:00	0.285			0.27138			0.56											
09/17/20 13:00	0.3015			0.28806			0.59											
09/17/20 14:00	0.3186			0.30492			0.62											
09/17/20 15:00	0.36582			0.35196			0.72											
09/17/20 16:00	0.36672			0.35346			0.72											
09/17/20 17:00	0.3279			0.315			0.64											
09/17/20 18:00	0.31362			0.30096			0.61											
09/17/20 19:00	0.27648			0.26448			0.54											
09/17/20 20:00	0.2877			0.27576			0.56											
09/17/20 21:00	0.30084			0.28926			0.59											
09/17/20 22:00	0.24264			0.24138			0.48											
09/17/20 23:00	0.20334			0.2094			0.41											
09/18/20 0:00	0.18138			0.19686			0.38											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/18/20 1:00	0.17964			0.18054			0.36											
09/18/20 2:00	0.17976			0.17826			0.36											
09/18/20 3:00	0.17946			0.17838			0.36											
09/18/20 4:00	0.18384			0.18564			0.37											
09/18/20 5:00	0.19476			0.20364			0.4											
09/18/20 6:00	0.20166			0.21756			0.42											
09/18/20 7:00	0.21324			0.23268			0.45											
09/18/20 8:00	0.26268			0.25428			0.52											
09/18/20 9:00	0.26718			0.25506			0.52											
09/18/20 10:00	0.28524			0.2736			0.56											
09/18/20 11:00	0.2937			0.28176			0.58											
09/18/20 12:00	0.30894			0.29604			0.6											
09/18/20 13:00	0.33084			0.31722			0.65											
09/18/20 14:00	0.32934			0.31554			0.64											
09/18/20 15:00	0.27168			0.25932			0.53											
09/18/20 16:00	0.28284			0.26958			0.55											
09/18/20 17:00	0.31038			0.29712			0.61											
09/18/20 18:00	0.26766			0.25506			0.52											
09/18/20 19:00	0.21582			0.20574			0.42											
09/18/20 20:00	0.28044			0.27402			0.55											
09/18/20 21:00	0.25014			0.24186			0.49											
09/18/20 22:00	0.2133			0.21366			0.43											
09/18/20 23:00	0.19092			0.2034			0.39											
09/19/20 0:00	0.17952			0.18366			0.36											
09/19/20 1:00	0.17934			0.17664			0.36											
09/19/20 2:00	0.17928			0.16992			0.35											
09/19/20 3:00	0.17904			0.16986			0.35											
09/19/20 4:00	0.17898			0.1698			0.35											
09/19/20 5:00	0.18342			0.1803			0.36											
09/19/20 6:00	0.1818			0.18786			0.37											
09/19/20 7:00	0.19992			0.21024			0.41											
09/19/20 8:00	0.21174			0.228			0.44											
09/19/20 9:00	0.23214			0.24048			0.47											
09/19/20 10:00	0.25686			0.2442			0.5											
09/19/20 11:00	0.27762			0.26334			0.54											
09/19/20 12:00	0.30792			0.29358			0.6											
09/19/20 13:00	0.31122			0.29736			0.61											
09/19/20 14:00	0.2988			0.28524			0.58											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/19/20 15:00	0.30456			0.2913			0.6											
09/19/20 16:00	0.25626			0.24144			0.5											
09/19/20 17:00	0.24606			0.23796			0.48											
09/19/20 18:00	0.26154			0.24774			0.51											
09/19/20 19:00	0.30876			0.29568			0.6											
09/19/20 20:00	0.25266			0.2409			0.49											
09/19/20 21:00	0.23484			0.23028			0.47											
09/19/20 22:00	0.21066			0.21438			0.43											
09/19/20 23:00	0.18726			0.20094			0.39											
09/20/20 0:00	0.17946			0.17934			0.36											
09/20/20 1:00	0.17934			0.1698			0.35											
09/20/20 2:00	0.17934			0.16986			0.35											
09/20/20 3:00	0.17934			0.16986			0.35											
09/20/20 4:00	0.17934			0.1701			0.35											
09/20/20 5:00	0.17976			0.17094			0.35											
09/20/20 6:00	0.1797			0.17088			0.35											
09/20/20 7:00	0.17946			0.16998			0.35											
09/20/20 8:00	0.18192			0.17238			0.35											
09/20/20 9:00	0.19764			0.19284			0.39											
09/20/20 10:00	0.21402			0.21612			0.43											
09/20/20 11:00	0.23364			0.23202			0.47											
09/20/20 12:00	0.30258			0.28788			0.59											
09/20/20 13:00	0.33456			0.32064			0.66											
09/20/20 14:00	0.3618			0.34782			0.71											
09/20/20 15:00	0.36966			0.35532			0.72											
09/20/20 16:00	0.31626			0.30354			0.62											
09/20/20 17:00	0.2511			0.23958			0.49											
09/20/20 18:00	0.24984			0.23886			0.49											
09/20/20 19:00	0.23916			0.23334			0.47											
09/20/20 20:00	0.28632			0.27762			0.56											
09/20/20 21:00	0.2403			0.23802			0.48											
09/20/20 22:00	0.20904			0.21576			0.42											
09/20/20 23:00	0.18684			0.20394			0.39											
09/21/20 0:00	0.17958			0.18186			0.36											
09/21/20 1:00	0.17892			0.1695			0.35											
09/21/20 2:00	0.17964			0.17028			0.35											
09/21/20 3:00	0.18084			0.1782			0.36											
09/21/20 4:00	0.18078			0.18498			0.37											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/21/20 5:00	0.19014			0.20154			0.39											
09/21/20 6:00	0.19356			0.21348			0.41											
09/21/20 7:00	0.19104			0.21954			0.41											
09/21/20 8:00	0.23592			0.23484			0.47											
09/21/20 9:00	0.2502			0.24078			0.49											
09/21/20 10:00	0.27438			0.2568			0.53											
09/21/20 11:00	0.34074			0.32688			0.67											
09/21/20 12:00	0.3534			0.33936			0.69											
09/21/20 13:00	0.37182			0.3576			0.73											
09/21/20 14:00	0.37236			0.35736			0.73											
09/21/20 15:00	0.37242			0.35766			0.73											
09/21/20 16:00	0.3576			0.3441			0.7											
09/21/20 17:00	0.36168			0.34848			0.71											
09/21/20 18:00	0.35406			0.34128			0.7											
09/21/20 19:00	0.28794			0.276			0.56											
09/21/20 20:00	0.24228			0.23394			0.48											
09/21/20 21:00	0.26766			0.25596			0.52											
09/21/20 22:00	0.22704			0.2286			0.46											
09/21/20 23:00	0.2022			0.20424			0.41											
09/22/20 0:00	0.18732			0.18576			0.37											
09/22/20 1:00	0.17988			0.18564			0.37											
09/22/20 2:00	0.17976			0.17946			0.36											
09/22/20 3:00	0.17994			0.17934			0.36											
09/22/20 4:00	0.18702			0.18912			0.38											
09/22/20 5:00	0.20352			0.21006			0.41											
09/22/20 6:00	0.21			0.20568			0.42											
09/22/20 7:00	0.22392			0.22242			0.45											
09/22/20 8:00	0.23424			0.23928			0.47											
09/22/20 9:00	0.26346			0.25146			0.51											
09/22/20 10:00	0.30474			0.29094			0.6											
09/22/20 11:00	0.31392			0.30018			0.61											
09/22/20 12:00	0.3447			0.33108			0.68											
09/22/20 13:00	0.34584			0.33264			0.68											
09/22/20 14:00	0.3324			0.31962			0.65											
09/22/20 15:00	0.31974			0.30696			0.63											
09/22/20 16:00	0.3411			0.32838			0.67											
09/22/20 17:00	0.32568			0.31302			0.64											
09/22/20 18:00	0.2991			0.2904			0.59											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/22/20 19:00	0.2436			0.2337			0.48											
09/22/20 20:00	0.29166			0.28932			0.58											
09/22/20 21:00	0.24972			0.2409			0.49											
09/22/20 22:00	0.21384			0.20904			0.42											
09/22/20 23:00	0.18912			0.19482			0.38											
09/23/20 0:00	0.18018			0.17262			0.35											
09/23/20 1:00	0.17976			0.1704			0.35											
09/23/20 2:00	0.17982			0.17034			0.35											
09/23/20 3:00	0.17982			0.17022			0.35											
09/23/20 4:00	0.18078			0.17136			0.35											
09/23/20 5:00	0.1959			0.19122			0.39											
09/23/20 6:00	0.19698			0.20058			0.4											
09/23/20 7:00	0.20244			0.21264			0.42											
09/23/20 8:00	0.22692			0.23694			0.46											
09/23/20 9:00	0.25578			0.24678			0.5											
09/23/20 10:00	0.25884			0.2448			0.5											
09/23/20 11:00	0.2808			0.26748			0.55											
09/23/20 12:00	0.29538			0.28224			0.58											
09/23/20 13:00	0.30216			0.28962			0.59											
09/23/20 14:00	0.34296			0.32982			0.67											
09/23/20 15:00	0.31674			0.30414			0.62											
09/23/20 16:00	0.34464			0.33168			0.68											
09/23/20 17:00	0.37044			0.35724			0.73											
09/23/20 18:00	0.36414			0.35106			0.72											
09/23/20 19:00	0.31776			0.30564			0.62											
09/23/20 20:00	0.27942			0.26808			0.55											
09/23/20 21:00	0.26514			0.25362			0.52											
09/23/20 22:00	0.22176			0.23496			0.46											
09/23/20 23:00	0.0777			0.24624			0.25											
09/24/20 0:00	0	X		0.24582			0.25											
09/24/20 1:00	0	X		0.23388			0.23											
09/24/20 2:00	0	X		0.21804			0.22											
09/24/20 3:00	0	X		0.21774			0.22											
09/24/20 4:00	0	X		0.2316			0.23											
09/24/20 5:00	0	X		0.19338			0.19											
09/24/20 6:00	0	X		0.19182			0.19											
09/24/20 7:00	0	X		0.19956			0.2											
09/24/20 8:00	0	X		0.24162			0.24											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/24/20 9:00	0	X		0.24264			0.24											
09/24/20 10:00	0	X		0.24204			0.24											
09/24/20 11:00	0	X		0.24096			0.24											
09/24/20 12:00	0	X		0.26574			0.27											
09/24/20 13:00	0	X		0.27006			0.27											
09/24/20 14:00	0	X		0.26856			0.27											
09/24/20 15:00	0	X		0.32346			0.32											
09/24/20 16:00	0	X		0.35388			0.35											
09/24/20 17:00	0	X		0.35598			0.36											
09/24/20 18:00	0	X		0.35748			0.36											
09/24/20 19:00	0	X		0.29418			0.29											
09/24/20 20:00	0	X		0.2628			0.26											
09/24/20 21:00	0	X		0.2253			0.23											
09/24/20 22:00	0	X		0.23286			0.23											
09/24/20 23:00	0	X		0.24012			0.24											
09/25/20 0:00	0	X		0.22128			0.22											
09/25/20 1:00	0	X		0.20592			0.21											
09/25/20 2:00	0	X		0.19188			0.19											
09/25/20 3:00	0	X		0.19158			0.19											
09/25/20 4:00	0	X		0.20436			0.2											
09/25/20 5:00	0	X		0.17418			0.17											
09/25/20 6:00	0	X		0.17928			0.18											
09/25/20 7:00	0	X		0.1878			0.19											
09/25/20 8:00	0	X		0.2244			0.22											
09/25/20 9:00	0	X		0.2466			0.25											
09/25/20 10:00	0	X		0.2439			0.24											
09/25/20 11:00	0	X		0.23616			0.24											
09/25/20 12:00	0	X		0.23814			0.24											
09/25/20 13:00	0	X		0.2421			0.24											
09/25/20 14:00	0	X		0.24126			0.24											
09/25/20 15:00	0	X		0.2409			0.24											
09/25/20 16:00	0	X		0.23742			0.24											
09/25/20 17:00	0	X		0.22536			0.23											
09/25/20 18:00	0	X		0.22044			0.22											
09/25/20 19:00	0	X		0.21678			0.22											
09/25/20 20:00	0	X		0.25056			0.25											
09/25/20 21:00	0	X		0.2445			0.24											
09/25/20 22:00	0	X		0.24504			0.25											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/25/20 23:00	0	X		0.23454			0.23											
09/26/20 0:00	0	X		0.2061			0.21											
09/26/20 1:00	0	X		0.18966			0.19											
09/26/20 2:00	0	X		0.17598			0.18											
09/26/20 3:00	0	X		0.17526			0.18											
09/26/20 4:00	0	X		0.18102			0.18											
09/26/20 5:00	0	X		0.17682			0.18											
09/26/20 6:00	0	X		0.17748			0.18											
09/26/20 7:00	0	X		0.18768			0.19											
09/26/20 8:00	0	X		0.20682			0.21											
09/26/20 9:00	0	X		0.22134			0.22											
09/26/20 10:00	0	X		0.21354			0.21											
09/26/20 11:00	0	X		0.23628			0.24											
09/26/20 12:00	0	X		0.21366			0.21											
09/26/20 13:00	0	X		0.22158			0.22											
09/26/20 14:00	0	X		0.20028			0.2											
09/26/20 15:00	0	X		0.20112			0.2											
09/26/20 16:00	0	X		0.20442			0.2											
09/26/20 17:00	0	X		0.2016			0.2											
09/26/20 18:00	0	X		0.195			0.2											
09/26/20 19:00	0	X		0.19248			0.19											
09/26/20 20:00	0	X		0.18528			0.19											
09/26/20 21:00	0	X		0.21366			0.21											
09/26/20 22:00	0	X		0.20958			0.21											
09/26/20 23:00	0	X		0.19188			0.19											
09/27/20 0:00	0	X		0.1809			0.18											
09/27/20 1:00	0	X		0.1797			0.18											
09/27/20 2:00	0	X		0.17928			0.18											
09/27/20 3:00	0	X		0.1794			0.18											
09/27/20 4:00	0	X		0.17958			0.18											
09/27/20 5:00	0	X		0.17994			0.18											
09/27/20 6:00	0	X		0.17922			0.18											
09/27/20 7:00	0	X		0.18024			0.18											
09/27/20 8:00	0	X		0.2223			0.22											
09/27/20 9:00	0	X		0.21156			0.21											
09/27/20 10:00	0	X		0.19596			0.2											
09/27/20 11:00	0	X		0.24006			0.24											
09/27/20 12:00	0	X		0.2322			0.23											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/27/20 13:00	0	X		0.21888			0.22											
09/27/20 14:00	0	X		0.21804			0.22											
09/27/20 15:00	0	X		0.2232			0.22											
09/27/20 16:00	0	X		0.24708			0.25											
09/27/20 17:00	0	X		0.22974			0.23											
09/27/20 18:00	0	X		0.22932			0.23											
09/27/20 19:00	0	X		0.22116			0.22											
09/27/20 20:00	0	X		0.22242			0.22											
09/27/20 21:00	0	X		0.23052			0.23											
09/27/20 22:00	0	X		0.2082			0.21											
09/27/20 23:00	0	X		0.2088			0.21											
09/28/20 0:00	0	X		0.18204			0.18											
09/28/20 1:00	0	X		0.1812			0.18											
09/28/20 2:00	0	X		0.1812			0.18											
09/28/20 3:00	0	X		0.18306			0.18											
09/28/20 4:00	0.09384			0.1854			0.21											
09/28/20 5:00	0.1926			0.18228			0.37											
09/28/20 6:00	0.18486			0.18102			0.37											
09/28/20 7:00	0.1974			0.1989			0.4											
09/28/20 8:00	0.22176			0.22806			0.45											
09/28/20 9:00	0.22188			0.22644			0.45											
09/28/20 10:00	0.21732			0.21138			0.43											
09/28/20 11:00	0.22842			0.21354			0.44											
09/28/20 12:00	0.24084			0.2331			0.47											
09/28/20 13:00	0.36612			0.34992			0.72											
09/28/20 14:00	0.36342			0.3486			0.71											
09/28/20 15:00	0.35964			0.34506			0.7											
09/28/20 16:00	0.30246			0.28818			0.59											
09/28/20 17:00	0.28158			0.26748			0.55											
09/28/20 18:00	0.26412			0.25032			0.51											
09/28/20 19:00	0.2406			0.22968			0.47											
09/28/20 20:00	0.21894			0.21516			0.43											
09/28/20 21:00	0.18546			0.19158			0.38											
09/28/20 22:00	0.17976			0.17052			0.35											
09/28/20 23:00	0.21684			0.20976			0.43											
09/29/20 0:00	0.1875			0.19368			0.38											
09/29/20 1:00	0.17982			0.19518			0.38											
09/29/20 2:00	0.17928			0.18042			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/29/20 3:00	0.17964			0.17724			0.36											
09/29/20 4:00	0.18612			0.18792			0.37											
09/29/20 5:00	0.17916			0.17412			0.35											
09/29/20 6:00	0.17856			0.17172			0.35											
09/29/20 7:00	0.18834			0.18468			0.37											
09/29/20 8:00	0.20754			0.20982			0.42											
09/29/20 9:00	0.22008			0.22788			0.45											
09/29/20 10:00	0.24528			0.24126			0.49											
09/29/20 11:00	0.26928			0.25776			0.53											
09/29/20 12:00	0.34068			0.32568			0.67											
09/29/20 13:00	0.34866			0.33384			0.68											
09/29/20 14:00	0.35616			0.34128			0.7											
09/29/20 15:00	0.3453			0.33048			0.68											
09/29/20 16:00	0.3315			0.31704			0.65											
09/29/20 17:00	0.33708			0.32226			0.66											
09/29/20 18:00	0.27828			0.26388			0.54											
09/29/20 19:00	0.23076			0.22386			0.45											
09/29/20 20:00	0.26322			0.2469			0.51											
09/29/20 21:00	0.30498			0.29094			0.6											
09/29/20 22:00	0.24372			0.24054			0.48											
09/29/20 23:00	0.18162			0.17316			0.35											
09/30/20 0:00	0.17982			0.16986			0.35											
09/30/20 1:00	0.18036			0.17022			0.35											
09/30/20 2:00	0.18594			0.18102			0.37											
09/30/20 3:00	0.1803			0.18336			0.36											
09/30/20 4:00	0.1797			0.1839			0.36											
09/30/20 5:00	0.17982			0.17004			0.35											
09/30/20 6:00	0.1797			0.17016			0.35											
09/30/20 7:00	0.17982			0.1701			0.35											
09/30/20 8:00	0.19974			0.19302			0.39											
09/30/20 9:00	0.21018			0.21			0.42											
09/30/20 10:00	0.25578			0.24456			0.5											
09/30/20 11:00	0.27306			0.258			0.53											
09/30/20 12:00	0.3192			0.30468			0.62											
09/30/20 13:00	0.36642			0.35112			0.72											
09/30/20 14:00	0.36966			0.35346			0.72											
09/30/20 15:00	0.35142			0.33696			0.69											
09/30/20 16:00	0.35916			0.34398			0.7											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/30/20 17:00	0.33006			0.31542			0.65											
09/30/20 18:00	0.31068			0.29646			0.61											
09/30/20 19:00	0.2748			0.26178			0.54											
09/30/20 20:00	0.26634			0.25404			0.52											
09/30/20 21:00	0.30264			0.28884			0.59											
09/30/20 22:00	0.2607			0.2376			0.5											
09/30/20 23:00	0.22968			0.22146			0.45											

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/01/20 0:00	0			0			0											
07/01/20 1:00	0			0			0											
07/01/20 2:00	0			0			0											
07/01/20 3:00	0			0			0											
07/01/20 4:00	0			0			0											
07/01/20 5:00	0			0			0											
07/01/20 6:00	0			0			0											
07/01/20 7:00	0			0			0											
07/01/20 8:00	0			0			0											
07/01/20 9:00	0			0			0											
07/01/20 10:00	0			0			0											
07/01/20 11:00	0			0			0											
07/01/20 12:00	0			0			0											
07/01/20 13:00	0			0			0											
07/01/20 14:00	0			0			0											
07/01/20 15:00	0			0			0											
07/01/20 16:00	0			0			0											
07/01/20 17:00	0			0			0											
07/01/20 18:00	0			0			0											
07/01/20 19:00	0			0			0											
07/01/20 20:00	0			0			0											
07/01/20 21:00	0			0			0											
07/01/20 22:00	0			0			0											
07/01/20 23:00	0			0			0											
07/02/20 0:00	0			0			0											
07/02/20 1:00	0			0			0											
07/02/20 2:00	0			0			0											
07/02/20 3:00	0			0			0											
07/02/20 4:00	0			0			0											
07/02/20 5:00	0			0			0											
07/02/20 6:00	0			0			0											
07/02/20 7:00	0			0			0											
07/02/20 8:00	0			0			0											
07/02/20 9:00	0			0			0											
07/02/20 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/20 11:00	0			0			0											
07/02/20 12:00	0			0			0											
07/02/20 13:00	0			0			0											
07/02/20 14:00	0			0			0											
07/02/20 15:00	0			0			0											
07/02/20 16:00	0			0			0											
07/02/20 17:00	0			0			0											
07/02/20 18:00	0			0			0											
07/02/20 19:00	0			0			0											
07/02/20 20:00	0			0			0											
07/02/20 21:00	0			0			0											
07/02/20 22:00	0			0			0											
07/02/20 23:00	0			0			0											
07/03/20 0:00	0			0			0											
07/03/20 1:00	0			0			0											
07/03/20 2:00	0			0			0											
07/03/20 3:00	0			0			0											
07/03/20 4:00	0			0			0											
07/03/20 5:00	0			0			0											
07/03/20 6:00	0			0			0											
07/03/20 7:00	0			0			0											
07/03/20 8:00	0			0			0											
07/03/20 9:00	0			0			0											
07/03/20 10:00	0			0			0											
07/03/20 11:00	0			0			0											
07/03/20 12:00	0			0			0											
07/03/20 13:00	0			0			0											
07/03/20 14:00	0			0			0											
07/03/20 15:00	0			0			0											
07/03/20 16:00	0			0			0											
07/03/20 17:00	0			0			0											
07/03/20 18:00	0			0			0											
07/03/20 19:00	0			0			0											
07/03/20 20:00	0			0			0											
07/03/20 21:00	0			0			0											
07/03/20 22:00	0			0			0											
07/03/20 23:00	0			0			0											
07/04/20 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/20 1:00	0			0			0											
07/04/20 2:00	0			0			0											
07/04/20 3:00	0			0			0											
07/04/20 4:00	0			0			0											
07/04/20 5:00	0			0			0											
07/04/20 6:00	0			0			0											
07/04/20 7:00	0			0			0											
07/04/20 8:00	0			0			0											
07/04/20 9:00	0			0			0											
07/04/20 10:00	0			0			0											
07/04/20 11:00	0			0			0											
07/04/20 12:00	0			0			0											
07/04/20 13:00	0			0			0											
07/04/20 14:00	0			0			0											
07/04/20 15:00	0			0			0											
07/04/20 16:00	0			0			0											
07/04/20 17:00	0			0			0											
07/04/20 18:00	0			0			0											
07/04/20 19:00	0			0			0											
07/04/20 20:00	0			0			0											
07/04/20 21:00	0			0			0											
07/04/20 22:00	0			0			0											
07/04/20 23:00	0			0			0											
07/05/20 0:00	0			0			0											
07/05/20 1:00	0			0			0											
07/05/20 2:00	0			0			0											
07/05/20 3:00	0			0			0											
07/05/20 4:00	0			0			0											
07/05/20 5:00	0			0			0											
07/05/20 6:00	0			0			0											
07/05/20 7:00	0			0			0											
07/05/20 8:00	0			0			0											
07/05/20 9:00	0			0			0											
07/05/20 10:00	0			0			0											
07/05/20 11:00	0			0			0											
07/05/20 12:00	0			0			0											
07/05/20 13:00	0			0			0											
07/05/20 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/20 15:00	0			0			0											
07/05/20 16:00	0			0			0											
07/05/20 17:00	0			0			0											
07/05/20 18:00	0			0			0											
07/05/20 19:00	0			0			0											
07/05/20 20:00	0			0			0											
07/05/20 21:00	0			0			0											
07/05/20 22:00	0			0			0											
07/05/20 23:00	0			0			0											
07/06/20 0:00	0			0			0											
07/06/20 1:00	0			0			0											
07/06/20 2:00	0			0			0											
07/06/20 3:00	0			0			0											
07/06/20 4:00	0			0			0											
07/06/20 5:00	0			0			0											
07/06/20 6:00	0			0			0											
07/06/20 7:00	0			0			0											
07/06/20 8:00	0			0			0											
07/06/20 9:00	0			0			0											
07/06/20 10:00	0			0			0											
07/06/20 11:00	0			0			0											
07/06/20 12:00	0			0			0											
07/06/20 13:00	0			0			0											
07/06/20 14:00	0			0			0											
07/06/20 15:00	0			0			0											
07/06/20 16:00	0			0			0											
07/06/20 17:00	0			0			0											
07/06/20 18:00	0			0			0											
07/06/20 19:00	0			0			0											
07/06/20 20:00	0			0			0											
07/06/20 21:00	0			0			0											
07/06/20 22:00	0			0			0											
07/06/20 23:00	0			0			0											
07/07/20 0:00	0			0			0											
07/07/20 1:00	0			0			0											
07/07/20 2:00	0			0			0											
07/07/20 3:00	0			0			0											
07/07/20 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/07/20 5:00	0			0			0											
07/07/20 6:00	0			0			0											
07/07/20 7:00	0			0			0											
07/07/20 8:00	0			0			0											
07/07/20 9:00	0			0			0											
07/07/20 10:00	0			0			0											
07/07/20 11:00	0			0			0											
07/07/20 12:00	0			0			0											
07/07/20 13:00	0			0			0											
07/07/20 14:00	0			0			0											
07/07/20 15:00	0			0			0											
07/07/20 16:00	0			0			0											
07/07/20 17:00	0			0			0											
07/07/20 18:00	0			0			0											
07/07/20 19:00	0			0			0											
07/07/20 20:00	0			0			0											
07/07/20 21:00	0			0			0											
07/07/20 22:00	0			0			0											
07/07/20 23:00	0			0			0											
07/08/20 0:00	0			0			0											
07/08/20 1:00	0			0			0											
07/08/20 2:00	0			0			0											
07/08/20 3:00	0			0			0											
07/08/20 4:00	0			0			0											
07/08/20 5:00	0			0			0											
07/08/20 6:00	0			0			0											
07/08/20 7:00	0			0			0											
07/08/20 8:00	0			0			0											
07/08/20 9:00	0			0			0											
07/08/20 10:00	0			0			0											
07/08/20 11:00	0			0			0											
07/08/20 12:00	0			0			0											
07/08/20 13:00	0			0			0											
07/08/20 14:00	0			0			0											
07/08/20 15:00	0			0			0											
07/08/20 16:00	0			0			0											
07/08/20 17:00	0			0			0											
07/08/20 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/08/20 19:00	0			0			0											
07/08/20 20:00	0			0			0											
07/08/20 21:00	0			0			0											
07/08/20 22:00	0			0			0											
07/08/20 23:00	0			0			0											
07/09/20 0:00	0			0			0											
07/09/20 1:00	0			0			0											
07/09/20 2:00	0			0			0											
07/09/20 3:00	0			0			0											
07/09/20 4:00	0			0			0											
07/09/20 5:00	0			0			0											
07/09/20 6:00	0			0			0											
07/09/20 7:00	0			0			0											
07/09/20 8:00	0			0			0											
07/09/20 9:00	0			0			0											
07/09/20 10:00	0			0			0											
07/09/20 11:00	0			0			0											
07/09/20 12:00	0			0			0											
07/09/20 13:00	0			0			0											
07/09/20 14:00	0			0			0											
07/09/20 15:00	0			0			0											
07/09/20 16:00	0			0			0											
07/09/20 17:00	0			0			0											
07/09/20 18:00	0			0			0											
07/09/20 19:00	0			0			0											
07/09/20 20:00	0			0			0											
07/09/20 21:00	0			0			0											
07/09/20 22:00	0			0			0											
07/09/20 23:00	0			0			0											
07/10/20 0:00	0			0			0											
07/10/20 1:00	0			0			0											
07/10/20 2:00	0			0			0											
07/10/20 3:00	0			0			0											
07/10/20 4:00	0			0			0											
07/10/20 5:00	0			0			0											
07/10/20 6:00	0			0			0											
07/10/20 7:00	0			0			0											
07/10/20 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/20 9:00	0			0			0											
07/10/20 10:00	0			0			0											
07/10/20 11:00	0			0			0											
07/10/20 12:00	0			0			0											
07/10/20 13:00	0			0			0											
07/10/20 14:00	0			0			0											
07/10/20 15:00	0			0			0											
07/10/20 16:00	0			0			0											
07/10/20 17:00	0			0			0											
07/10/20 18:00	0			0			0											
07/10/20 19:00	0			0			0											
07/10/20 20:00	0			0			0											
07/10/20 21:00	0			0			0											
07/10/20 22:00	0			0			0											
07/10/20 23:00	0			0			0											
07/11/20 0:00	0			0			0											
07/11/20 1:00	0			0			0											
07/11/20 2:00	0			0			0											
07/11/20 3:00	0			0			0											
07/11/20 4:00	0			0			0											
07/11/20 5:00	0			0			0											
07/11/20 6:00	0			0			0											
07/11/20 7:00	0			0			0											
07/11/20 8:00	0			0			0											
07/11/20 9:00	0			0			0											
07/11/20 10:00	0			0			0											
07/11/20 11:00	0			0			0											
07/11/20 12:00	0			0			0											
07/11/20 13:00	0			0			0											
07/11/20 14:00	0			0			0											
07/11/20 15:00	0			0			0											
07/11/20 16:00	0			0			0											
07/11/20 17:00	0			0			0											
07/11/20 18:00	0			0			0											
07/11/20 19:00	0			0			0											
07/11/20 20:00	0			0			0											
07/11/20 21:00	0			0			0											
07/11/20 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/20 23:00	0			0			0											
07/12/20 0:00	0			0			0											
07/12/20 1:00	0			0			0											
07/12/20 2:00	0			0			0											
07/12/20 3:00	0			0			0											
07/12/20 4:00	0			0			0											
07/12/20 5:00	0			0			0											
07/12/20 6:00	0			0			0											
07/12/20 7:00	0			0			0											
07/12/20 8:00	0			0			0											
07/12/20 9:00	0			0			0											
07/12/20 10:00	0			0			0											
07/12/20 11:00	0			0			0											
07/12/20 12:00	0			0			0											
07/12/20 13:00	0			0			0											
07/12/20 14:00	0			0			0											
07/12/20 15:00	0			0			0											
07/12/20 16:00	0			0			0											
07/12/20 17:00	0			0			0											
07/12/20 18:00	0			0			0											
07/12/20 19:00	0			0			0											
07/12/20 20:00	0			0			0											
07/12/20 21:00	0			0			0											
07/12/20 22:00	0			0			0											
07/12/20 23:00	0			0			0											
07/13/20 0:00	0			0			0											
07/13/20 1:00	0			0			0											
07/13/20 2:00	0			0			0											
07/13/20 3:00	1			0			3											
07/13/20 4:00	1			0			15											
07/13/20 5:00	1			0			29											
07/13/20 6:00	1			3			44											
07/13/20 7:00	1			15			43											
07/13/20 8:00	1			29			43											
07/13/20 9:00	1			42			42											
07/13/20 10:00	1			49			50											
07/13/20 11:00	1			57			58											
07/13/20 12:00	1			64			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 13:00	1			66			65											
07/13/20 14:00	1			66			65											
07/13/20 15:00	1			66			65											
07/13/20 16:00	1			66			65											
07/13/20 17:00	1			66			65											
07/13/20 18:00	1			69			68											
07/13/20 19:00	1			70			69											
07/13/20 20:00	1			64			59											
07/13/20 21:00	1			52			46											
07/13/20 22:00	1			41			36											
07/13/20 23:00	1			37			36											
07/14/20 0:00	1			37			36											
07/14/20 1:00	1			37			38											
07/14/20 2:00	1			37			38											
07/14/20 3:00	1			37			37											
07/14/20 4:00	1			37			37											
07/14/20 5:00	1			37			37											
07/14/20 6:00	1			37			37											
07/14/20 7:00	1			38			37											
07/14/20 8:00	1			39			40											
07/14/20 9:00	1			43			44											
07/14/20 10:00	1			48			50											
07/14/20 11:00	1			56			57											
07/14/20 12:00	1			64			63											
07/14/20 13:00	1			66			65											
07/14/20 14:00	1			69			68											
07/14/20 15:00	1			71			70											
07/14/20 16:00	1			76			74											
07/14/20 17:00	1			77			76											
07/14/20 18:00	1			75			74											
07/14/20 19:00	1			71			70											
07/14/20 20:00	1			65			61											
07/14/20 21:00	1			59			53											
07/14/20 22:00	1			54			48											
07/14/20 23:00	1			49			44											
07/15/20 0:00	1			44			40											
07/15/20 1:00	1			39			37											
07/15/20 2:00	1			37			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/15/20 3:00	1			37			36											
07/15/20 4:00	1			37			36											
07/15/20 5:00	1			37			36											
07/15/20 6:00	1			37			36											
07/15/20 7:00	1			37			36											
07/15/20 8:00	1			39			39											
07/15/20 9:00	1			43			43											
07/15/20 10:00	1			49			51											
07/15/20 11:00	1			57			58											
07/15/20 12:00	1			65			65											
07/15/20 13:00	1			71			70											
07/15/20 14:00	1			75			73											
07/15/20 15:00	1			76			74											
07/15/20 16:00	1			78			76											
07/15/20 17:00	1			78			76											
07/15/20 18:00	1			77			75											
07/15/20 19:00	1			72			71											
07/15/20 20:00	1			64			60											
07/15/20 21:00	1			53			48											
07/15/20 22:00	1			44			39											
07/15/20 23:00	1			38			36											
07/16/20 0:00	1			37			36											
07/16/20 1:00	1			37			36											
07/16/20 2:00	1			37			36											
07/16/20 3:00	1			37			36											
07/16/20 4:00	1			37			36											
07/16/20 5:00	1			37			36											
07/16/20 6:00	1			37			36											
07/16/20 7:00	1			37			36											
07/16/20 8:00	1			39			38											
07/16/20 9:00	1			42			43											
07/16/20 10:00	1			48			50											
07/16/20 11:00	1			55			56											
07/16/20 12:00	1			63			64											
07/16/20 13:00	1			68			67											
07/16/20 14:00	1			71			70											
07/16/20 15:00	1			72			71											
07/16/20 16:00	1			75			74											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/16/20 17:00	1			78			76											
07/16/20 18:00	1			75			74											
07/16/20 19:00	1			69			67											
07/16/20 20:00	1			59			56											
07/16/20 21:00	1			51			47											
07/16/20 22:00	1			43			41											
07/16/20 23:00	1			40			39											
07/17/20 0:00	1			37			36											
07/17/20 1:00	1			37			36											
07/17/20 2:00	1			37			36											
07/17/20 3:00	1			37			36											
07/17/20 4:00	1			37			36											
07/17/20 5:00	1			37			36											
07/17/20 6:00	1			37			36											
07/17/20 7:00	1			37			36											
07/17/20 8:00	1			38			38											
07/17/20 9:00	1			41			42											
07/17/20 10:00	1			46			48											
07/17/20 11:00	1			52			53											
07/17/20 12:00	1			53			53											
07/17/20 13:00	1			54			54											
07/17/20 14:00	1			57			56											
07/17/20 15:00	1			65			64											
07/17/20 16:00	1			72			71											
07/17/20 17:00	1			75			74											
07/17/20 18:00	1			73			72											
07/17/20 19:00	1			66			66											
07/17/20 20:00	1			55			57											
07/17/20 21:00	1			46			51											
07/17/20 22:00	1			42			48											
07/17/20 23:00	1			40			47											
07/18/20 0:00	1			39			43											
07/18/20 1:00	1			37			38											
07/18/20 2:00	1			37			36											
07/18/20 3:00	1			37			36											
07/18/20 4:00	1			37			36											
07/18/20 5:00	1			37			36											
07/18/20 6:00	1			37			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/18/20 7:00	1			37			36											
07/18/20 8:00	1			39			38											
07/18/20 9:00	1			42			42											
07/18/20 10:00	1			49			49											
07/18/20 11:00	1			57			57											
07/18/20 12:00	1			60			60											
07/18/20 13:00	1			63			62											
07/18/20 14:00	1			67			66											
07/18/20 15:00	1			74			73											
07/18/20 16:00	1			77			76											
07/18/20 17:00	1			77			76											
07/18/20 18:00	1			76			75											
07/18/20 19:00	1			74			73											
07/18/20 20:00	1			69			68											
07/18/20 21:00	1			62			62											
07/18/20 22:00	1			61			60											
07/18/20 23:00	1			54			53											
07/19/20 0:00	1			47			46											
07/19/20 1:00	1			37			37											
07/19/20 2:00	1			37			36											
07/19/20 3:00	1			37			36											
07/19/20 4:00	1			37			36											
07/19/20 5:00	1			37			36											
07/19/20 6:00	1			37			36											
07/19/20 7:00	1			37			36											
07/19/20 8:00	1			37			36											
07/19/20 9:00	1			39			39											
07/19/20 10:00	1			45			45											
07/19/20 11:00	1			54			54											
07/19/20 12:00	1			62			62											
07/19/20 13:00	1			68			67											
07/19/20 14:00	1			72			71											
07/19/20 15:00	1			75			74											
07/19/20 16:00	1			76			75											
07/19/20 17:00	1			76			75											
07/19/20 18:00	1			74			73											
07/19/20 19:00	1			70			69											
07/19/20 20:00	1			64			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/19/20 21:00	1			56			56											
07/19/20 22:00	1			48			48											
07/19/20 23:00	1			44			45											
07/20/20 0:00	1			41			42											
07/20/20 1:00	1			40			41											
07/20/20 2:00	1			37			38											
07/20/20 3:00	1			37			37											
07/20/20 4:00	1			38			37											
07/20/20 5:00	1			38			37											
07/20/20 6:00	1			37			37											
07/20/20 7:00	1			37			36											
07/20/20 8:00	1			37			36											
07/20/20 9:00	1			40			39											
07/20/20 10:00	1			47			47											
07/20/20 11:00	1			55			54											
07/20/20 12:00	1			59			59											
07/20/20 13:00	1			62			62											
07/20/20 14:00	1			67			66											
07/20/20 15:00	1			72			71											
07/20/20 16:00	1			75			74											
07/20/20 17:00	1			75			74											
07/20/20 18:00	1			72			71											
07/20/20 19:00	1			69			68											
07/20/20 20:00	1			64			64											
07/20/20 21:00	1			55			57											
07/20/20 22:00	1			46			47											
07/20/20 23:00	1			40			42											
07/21/20 0:00	1			39			40											
07/21/20 1:00	1			39			40											
07/21/20 2:00	1			37			37											
07/21/20 3:00	1			37			37											
07/21/20 4:00	1			36			37											
07/21/20 5:00	1			24			28											
07/21/20 6:00	0			12			15											
07/21/20 7:00	0			1			3											
07/21/20 8:00	0			0			0											
07/21/20 9:00	0			0			0											
07/21/20 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 11:00	0			0			0											
07/21/20 12:00	0			0			0											
07/21/20 13:00	0			0			0											
07/21/20 14:00	0			0			0											
07/21/20 15:00	0			0			0											
07/21/20 16:00	0			0			0											
07/21/20 17:00	0			0			0											
07/21/20 18:00	0			0			0											
07/21/20 19:00	0			0			0											
07/21/20 20:00	0			0			0											
07/21/20 21:00	0			0			0											
07/21/20 22:00	0			0			0											
07/21/20 23:00	0			0			0											
07/22/20 0:00	0			0			0											
07/22/20 1:00	0			0			0											
07/22/20 2:00	0			0			0											
07/22/20 3:00	0			0			0											
07/22/20 4:00	0			0			0											
07/22/20 5:00	0			0			0											
07/22/20 6:00	0			0			0											
07/22/20 7:00	0			0			0											
07/22/20 8:00	0			0			0											
07/22/20 9:00	0			0			0											
07/22/20 10:00	0			0			0											
07/22/20 11:00	0			0			0											
07/22/20 12:00	0			0			0											
07/22/20 13:00	0			0			0											
07/22/20 14:00	0			0			0											
07/22/20 15:00	0			0			0											
07/22/20 16:00	0			0			0											
07/22/20 17:00	0			0			0											
07/22/20 18:00	0			0			0											
07/22/20 19:00	0			0			0											
07/22/20 20:00	0			0			0											
07/22/20 21:00	0			0			0											
07/22/20 22:00	0			0			0											
07/22/20 23:00	0			0			0											
07/23/20 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/23/20 1:00	0			0			0											
07/23/20 2:00	0			0			0											
07/23/20 3:00	0			0			0											
07/23/20 4:00	0			0			0											
07/23/20 5:00	0			0			0											
07/23/20 6:00	0			0			0											
07/23/20 7:00	0			0			0											
07/23/20 8:00	0			0			0											
07/23/20 9:00	0			0			0											
07/23/20 10:00	0			0			0											
07/23/20 11:00	0			0			0											
07/23/20 12:00	0			0			0											
07/23/20 13:00	0			0			0											
07/23/20 14:00	0			0			0											
07/23/20 15:00	0			0			0											
07/23/20 16:00	0			0			0											
07/23/20 17:00	0			0			0											
07/23/20 18:00	0			0			0											
07/23/20 19:00	0			0			0											
07/23/20 20:00	0			0			0											
07/23/20 21:00	0			0			0											
07/23/20 22:00	0			0			0											
07/23/20 23:00	0			0			0											
07/24/20 0:00	0			0			0											
07/24/20 1:00	0			0			0											
07/24/20 2:00	0			0			0											
07/24/20 3:00	0			0			0											
07/24/20 4:00	0			0			0											
07/24/20 5:00	0			0			0											
07/24/20 6:00	0			0			0											
07/24/20 7:00	0			0			0											
07/24/20 8:00	0			0			0											
07/24/20 9:00	0			0			0											
07/24/20 10:00	0			0			0											
07/24/20 11:00	0			0			0											
07/24/20 12:00	0			0			0											
07/24/20 13:00	0			0			0											
07/24/20 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/24/20 15:00	0			0			0											
07/24/20 16:00	0			0			0											
07/24/20 17:00	0			0			0											
07/24/20 18:00	0			0			0											
07/24/20 19:00	0			0			0											
07/24/20 20:00	0			0			0											
07/24/20 21:00	0			0			0											
07/24/20 22:00	0			0			0											
07/24/20 23:00	0			0			0											
07/25/20 0:00	0			0			0											
07/25/20 1:00	0			0			0											
07/25/20 2:00	0			0			0											
07/25/20 3:00	0			0			0											
07/25/20 4:00	0			0			0											
07/25/20 5:00	0			0			0											
07/25/20 6:00	0			0			0											
07/25/20 7:00	0			0			0											
07/25/20 8:00	0			0			0											
07/25/20 9:00	0			0			0											
07/25/20 10:00	0			0			0											
07/25/20 11:00	0			0			0											
07/25/20 12:00	0			0			0											
07/25/20 13:00	0			0			0											
07/25/20 14:00	0			0			0											
07/25/20 15:00	0			0			0											
07/25/20 16:00	0			0			0											
07/25/20 17:00	0			0			0											
07/25/20 18:00	0			0			0											
07/25/20 19:00	0			0			0											
07/25/20 20:00	0			0			0											
07/25/20 21:00	0			0			0											
07/25/20 22:00	1			0			2											
07/25/20 23:00	1			0			15											
07/26/20 0:00	1			0			28											
07/26/20 1:00	1			3			41											
07/26/20 2:00	1			16			42											
07/26/20 3:00	1			29			40											
07/26/20 4:00	1			38			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 5:00	1			37			36											
07/26/20 6:00	1			37			37											
07/26/20 7:00	1			37			38											
07/26/20 8:00	1			37			40											
07/26/20 9:00	1			37			41											
07/26/20 10:00	1			37			41											
07/26/20 11:00	1			37			41											
07/26/20 12:00	1			45			47											
07/26/20 13:00	1			54			55											
07/26/20 14:00	1			64			63											
07/26/20 15:00	1			69			68											
07/26/20 16:00	1			74			73											
07/26/20 17:00	1			77			76											
07/26/20 18:00	1			77			76											
07/26/20 19:00	1			77			76											
07/26/20 20:00	1			75			74											
07/26/20 21:00	1			66			65											
07/26/20 22:00	1			57			58											
07/26/20 23:00	1			50			53											
07/27/20 0:00	1			48			53											
07/27/20 1:00	1			44			51											
07/27/20 2:00	1			41			47											
07/27/20 3:00	1			41			46											
07/27/20 4:00	1			41			43											
07/27/20 5:00	1			40			42											
07/27/20 6:00	1			38			41											
07/27/20 7:00	1			38			41											
07/27/20 8:00	1			37			41											
07/27/20 9:00	1			39			44											
07/27/20 10:00	1			47			51											
07/27/20 11:00	1			58			59											
07/27/20 12:00	1			68			67											
07/27/20 13:00	1			70			69											
07/27/20 14:00	1			73			72											
07/27/20 15:00	1			74			73											
07/27/20 16:00	1			77			76											
07/27/20 17:00	1			77			76											
07/27/20 18:00	1			76			76											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/27/20 19:00	1			75			75											
07/27/20 20:00	1			73			73											
07/27/20 21:00	1			61			63											
07/27/20 22:00	1			52			54											
07/27/20 23:00	1			44			46											
07/28/20 0:00	1			42			43											
07/28/20 1:00	1			40			39											
07/28/20 2:00	1			37			36											
07/28/20 3:00	1			37			36											
07/28/20 4:00	1			37			36											
07/28/20 5:00	1			37			36											
07/28/20 6:00	1			37			36											
07/28/20 7:00	1			38			37											
07/28/20 8:00	1			40			40											
07/28/20 9:00	1			47			48											
07/28/20 10:00	1			57			57											
07/28/20 11:00	1			67			66											
07/28/20 12:00	1			72			70											
07/28/20 13:00	1			74			73											
07/28/20 14:00	1			75			74											
07/28/20 15:00	1			75			74											
07/28/20 16:00	1			74			73											
07/28/20 17:00	1			73			72											
07/28/20 18:00	1			70			69											
07/28/20 19:00	1			67			67											
07/28/20 20:00	1			66			65											
07/28/20 21:00	1			60			60											
07/28/20 22:00	1			51			52											
07/28/20 23:00	1			44			44											
07/29/20 0:00	1			40			40											
07/29/20 1:00	1			40			40											
07/29/20 2:00	1			38			37											
07/29/20 3:00	1			38			37											
07/29/20 4:00	1			38			37											
07/29/20 5:00	1			38			37											
07/29/20 6:00	1			37			36											
07/29/20 7:00	1			37			36											
07/29/20 8:00	1			37			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/29/20 9:00	1			39			39											
07/29/20 10:00	1			45			46											
07/29/20 11:00	1			54			54											
07/29/20 12:00	1			65			65											
07/29/20 13:00	1			72			71											
07/29/20 14:00	1			77			75											
07/29/20 15:00	1			78			76											
07/29/20 16:00	1			78			76											
07/29/20 17:00	1			77			76											
07/29/20 18:00	1			77			76											
07/29/20 19:00	1			72			71											
07/29/20 20:00	1			70			69											
07/29/20 21:00	1			60			59											
07/29/20 22:00	1			55			55											
07/29/20 23:00	1			44			46											
07/30/20 0:00	1			41			43											
07/30/20 1:00	1			38			39											
07/30/20 2:00	1			37			36											
07/30/20 3:00	1			37			36											
07/30/20 4:00	1			37			36											
07/30/20 5:00	1			37			36											
07/30/20 6:00	1			37			36											
07/30/20 7:00	1			37			36											
07/30/20 8:00	1			37			36											
07/30/20 9:00	1			38			37											
07/30/20 10:00	1			42			42											
07/30/20 11:00	1			52			52											
07/30/20 12:00	1			61			61											
07/30/20 13:00	1			68			67											
07/30/20 14:00	1			70			69											
07/30/20 15:00	1			73			72											
07/30/20 16:00	1			76			74											
07/30/20 17:00	1			77			75											
07/30/20 18:00	1			77			75											
07/30/20 19:00	1			75			73											
07/30/20 20:00	1			72			71											
07/30/20 21:00	1			66			65											
07/30/20 22:00	1			60			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/30/20 23:00	1			50			51											
07/31/20 0:00	1			43			45											
07/31/20 1:00	1			38			39											
07/31/20 2:00	1			37			36											
07/31/20 3:00	1			37			36											
07/31/20 4:00	1			37			36											
07/31/20 5:00	1			37			36											
07/31/20 6:00	1			37			36											
07/31/20 7:00	1			37			36											
07/31/20 8:00	1			37			36											
07/31/20 9:00	1			38			37											
07/31/20 10:00	1			42			42											
07/31/20 11:00	1			53			53											
07/31/20 12:00	1			63			62											
07/31/20 13:00	1			70			69											
07/31/20 14:00	1			72			71											
07/31/20 15:00	1			73			72											
07/31/20 16:00	1			73			72											
07/31/20 17:00	1			72			71											
07/31/20 18:00	1			72			71											
07/31/20 19:00	1			73			72											
07/31/20 20:00	1			70			70											
07/31/20 21:00	1			62			63											
07/31/20 22:00	1			54			56											
07/31/20 23:00	1			45			47											
08/01/20 0:00	1			41			42											
08/01/20 1:00	1			37			37											
08/01/20 2:00	1			37			36											
08/01/20 3:00	1			37			36											
08/01/20 4:00	1			37			36											
08/01/20 5:00	1			37			36											
08/01/20 6:00	1			37			36											
08/01/20 7:00	1			37			36											
08/01/20 8:00	1			37			36											
08/01/20 9:00	1			39			38											
08/01/20 10:00	1			42			43											
08/01/20 11:00	1			46			48											
08/01/20 12:00	1			48			51											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/01/20 13:00	1			50			52											
08/01/20 14:00	1			51			52											
08/01/20 15:00	1			60			59											
08/01/20 16:00	1			69			67											
08/01/20 17:00	1			78			76											
08/01/20 18:00	1			77			75											
08/01/20 19:00	1			75			74											
08/01/20 20:00	1			71			70											
08/01/20 21:00	1			66			65											
08/01/20 22:00	1			59			58											
08/01/20 23:00	1			51			52											
08/02/20 0:00	1			43			44											
08/02/20 1:00	1			39			39											
08/02/20 2:00	1			37			36											
08/02/20 3:00	1			37			36											
08/02/20 4:00	1			37			36											
08/02/20 5:00	1			38			38											
08/02/20 6:00	1			39			40											
08/02/20 7:00	1			40			43											
08/02/20 8:00	1			39			41											
08/02/20 9:00	1			38			39											
08/02/20 10:00	1			37			36											
08/02/20 11:00	1			40			40											
08/02/20 12:00	1			46			45											
08/02/20 13:00	1			57			57											
08/02/20 14:00	1			65			64											
08/02/20 15:00	1			73			72											
08/02/20 16:00	1			74			73											
08/02/20 17:00	1			76			74											
08/02/20 18:00	1			74			73											
08/02/20 19:00	1			73			72											
08/02/20 20:00	1			71			70											
08/02/20 21:00	1			65			64											
08/02/20 22:00	1			55			55											
08/02/20 23:00	1			49			50											
08/03/20 0:00	1			43			46											
08/03/20 1:00	1			41			43											
08/03/20 2:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/03/20 3:00	1			37			36											
08/03/20 4:00	1			37			36											
08/03/20 5:00	1			37			36											
08/03/20 6:00	1			37			36											
08/03/20 7:00	1			37			36											
08/03/20 8:00	1			38			37											
08/03/20 9:00	1			38			37											
08/03/20 10:00	1			44			44											
08/03/20 11:00	1			51			50											
08/03/20 12:00	1			60			60											
08/03/20 13:00	1			65			64											
08/03/20 14:00	1			71			70											
08/03/20 15:00	1			73			72											
08/03/20 16:00	1			76			75											
08/03/20 17:00	1			75			74											
08/03/20 18:00	1			76			75											
08/03/20 19:00	1			74			73											
08/03/20 20:00	1			65			65											
08/03/20 21:00	1			57			57											
08/03/20 22:00	1			47			49											
08/03/20 23:00	1			45			49											
08/04/20 0:00	1			40			44											
08/04/20 1:00	1			39			41											
08/04/20 2:00	1			37			37											
08/04/20 3:00	1			37			36											
08/04/20 4:00	1			37			36											
08/04/20 5:00	1			37			36											
08/04/20 6:00	1			37			36											
08/04/20 7:00	1			37			36											
08/04/20 8:00	1			38			38											
08/04/20 9:00	1			42			42											
08/04/20 10:00	1			45			47											
08/04/20 11:00	1			51			53											
08/04/20 12:00	1			58			59											
08/04/20 13:00	1			65			64											
08/04/20 14:00	1			70			69											
08/04/20 15:00	1			73			72											
08/04/20 16:00	1			77			75											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/04/20 17:00	1			78			76											
08/04/20 18:00	1			78			76											
08/04/20 19:00	1			72			71											
08/04/20 20:00	1			63			63											
08/04/20 21:00	1			50			50											
08/04/20 22:00	1			42			41											
08/04/20 23:00	1			38			38											
08/05/20 0:00	1			38			38											
08/05/20 1:00	1			38			38											
08/05/20 2:00	1			37			36											
08/05/20 3:00	1			37			36											
08/05/20 4:00	1			37			36											
08/05/20 5:00	1			37			36											
08/05/20 6:00	1			37			36											
08/05/20 7:00	1			37			36											
08/05/20 8:00	1			37			36											
08/05/20 9:00	1			37			36											
08/05/20 10:00	1			38			38											
08/05/20 11:00	1			45			45											
08/05/20 12:00	1			55			55											
08/05/20 13:00	1			64			63											
08/05/20 14:00	1			69			68											
08/05/20 15:00	1			70			69											
08/05/20 16:00	1			71			69											
08/05/20 17:00	1			69			68											
08/05/20 18:00	1			68			67											
08/05/20 19:00	1			60			58											
08/05/20 20:00	1			52			52											
08/05/20 21:00	1			43			44											
08/05/20 22:00	1			43			31											
08/05/20 23:00	1			31			15											
08/06/20 0:00	0			17			1											
08/06/20 1:00	0			2			0											
08/06/20 2:00	0			0			0											
08/06/20 3:00	0			0			0											
08/06/20 4:00	0			0			0											
08/06/20 5:00	0			0			0											
08/06/20 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/06/20 7:00	0			0			0											
08/06/20 8:00	0			0			0											
08/06/20 9:00	0			0			0											
08/06/20 10:00	0			0			0											
08/06/20 11:00	0			0			0											
08/06/20 12:00	0			0			0											
08/06/20 13:00	0			0			0											
08/06/20 14:00	0			0			0											
08/06/20 15:00	0			0			0											
08/06/20 16:00	0			0			0											
08/06/20 17:00	0			0			0											
08/06/20 18:00	0			0			0											
08/06/20 19:00	0			0			0											
08/06/20 20:00	0			0			0											
08/06/20 21:00	0			0			0											
08/06/20 22:00	0			0			0											
08/06/20 23:00	0			0			0											
08/07/20 0:00	0			0			0											
08/07/20 1:00	0			0			0											
08/07/20 2:00	0			0			0											
08/07/20 3:00	0			0			0											
08/07/20 4:00	0			0			0											
08/07/20 5:00	0			0			0											
08/07/20 6:00	0			0			0											
08/07/20 7:00	0			0			0											
08/07/20 8:00	0			0			0											
08/07/20 9:00	0			0			0											
08/07/20 10:00	0			0			0											
08/07/20 11:00	0			0			0											
08/07/20 12:00	0			0			0											
08/07/20 13:00	0			0			0											
08/07/20 14:00	0			0			0											
08/07/20 15:00	0			0			0											
08/07/20 16:00	0			0			0											
08/07/20 17:00	0			0			0											
08/07/20 18:00	0			0			0											
08/07/20 19:00	0			0			0											
08/07/20 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/07/20 21:00	0			0			0											
08/07/20 22:00	0			0			0											
08/07/20 23:00	0			0			0											
08/08/20 0:00	0			0			0											
08/08/20 1:00	0			0			0											
08/08/20 2:00	0			0			0											
08/08/20 3:00	0			0			0											
08/08/20 4:00	0			0			0											
08/08/20 5:00	0			0			0											
08/08/20 6:00	0			0			0											
08/08/20 7:00	1			0			2											
08/08/20 8:00	1			0			15											
08/08/20 9:00	1			0			29											
08/08/20 10:00	1			0			46											
08/08/20 11:00	1			0			57											
08/08/20 12:00	1			0			67											
08/08/20 13:00	1			0			72											
08/08/20 14:00	1			0			72											
08/08/20 15:00	1			0			72											
08/08/20 16:00	1			0			72											
08/08/20 17:00	1			0			71											
08/08/20 18:00	1			0			70											
08/08/20 19:00	1			0			66											
08/08/20 20:00	1			0			57											
08/08/20 21:00	1			0			53											
08/08/20 22:00	1			3			51											
08/08/20 23:00	1			16			49											
08/09/20 0:00	1			28			43											
08/09/20 1:00	1			37			37											
08/09/20 2:00	1			37			36											
08/09/20 3:00	1			37			36											
08/09/20 4:00	1			37			36											
08/09/20 5:00	1			37			36											
08/09/20 6:00	1			37			36											
08/09/20 7:00	1			37			36											
08/09/20 8:00	1			39			39											
08/09/20 9:00	1			45			46											
08/09/20 10:00	1			55			56											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/09/20 11:00	1			65			65											
08/09/20 12:00	1			72			71											
08/09/20 13:00	1			75			74											
08/09/20 14:00	1			77			76											
08/09/20 15:00	1			77			76											
08/09/20 16:00	1			76			75											
08/09/20 17:00	1			76			75											
08/09/20 18:00	1			74			73											
08/09/20 19:00	1			75			74											
08/09/20 20:00	1			73			72											
08/09/20 21:00	1			72			71											
08/09/20 22:00	1			69			68											
08/09/20 23:00	1			60			60											
08/10/20 0:00	1			51			54											
08/10/20 1:00	1			41			47											
08/10/20 2:00	1			38			44											
08/10/20 3:00	1			37			41											
08/10/20 4:00	1			37			39											
08/10/20 5:00	1			37			37											
08/10/20 6:00	1			37			37											
08/10/20 7:00	1			37			37											
08/10/20 8:00	1			40			41											
08/10/20 9:00	1			46			48											
08/10/20 10:00	1			56			57											
08/10/20 11:00	1			66			65											
08/10/20 12:00	1			73			72											
08/10/20 13:00	1			76			75											
08/10/20 14:00	1			77			76											
08/10/20 15:00	1			77			76											
08/10/20 16:00	1			77			75											
08/10/20 17:00	1			76			75											
08/10/20 18:00	1			73			72											
08/10/20 19:00	1			65			64											
08/10/20 20:00	1			57			57											
08/10/20 21:00	1			52			53											
08/10/20 22:00	1			51			53											
08/10/20 23:00	1			50			53											
08/11/20 0:00	1			45			47											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/11/20 1:00	1			40			41											
08/11/20 2:00	1			37			36											
08/11/20 3:00	1			37			36											
08/11/20 4:00	1			37			36											
08/11/20 5:00	1			37			36											
08/11/20 6:00	1			37			36											
08/11/20 7:00	1			37			36											
08/11/20 8:00	1			38			38											
08/11/20 9:00	1			41			40											
08/11/20 10:00	1			46			47											
08/11/20 11:00	1			53			54											
08/11/20 12:00	1			62			62											
08/11/20 13:00	1			66			65											
08/11/20 14:00	1			68			67											
08/11/20 15:00	1			66			66											
08/11/20 16:00	1			66			66											
08/11/20 17:00	1			66			65											
08/11/20 18:00	1			66			65											
08/11/20 19:00	1			62			61											
08/11/20 20:00	1			58			57											
08/11/20 21:00	1			55			55											
08/11/20 22:00	1			52			53											
08/11/20 23:00	1			48			49											
08/12/20 0:00	1			41			41											
08/12/20 1:00	1			38			38											
08/12/20 2:00	1			37			36											
08/12/20 3:00	1			37			36											
08/12/20 4:00	1			37			36											
08/12/20 5:00	1			37			36											
08/12/20 6:00	1			37			36											
08/12/20 7:00	1			37			36											
08/12/20 8:00	1			37			37											
08/12/20 9:00	1			39			39											
08/12/20 10:00	1			43			44											
08/12/20 11:00	1			55			55											
08/12/20 12:00	1			66			65											
08/12/20 13:00	1			75			73											
08/12/20 14:00	1			77			75											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/12/20 15:00	1			77			76											
08/12/20 16:00	1			77			76											
08/12/20 17:00	1			77			76											
08/12/20 18:00	1			77			76											
08/12/20 19:00	1			76			75											
08/12/20 20:00	1			72			71											
08/12/20 21:00	1			68			67											
08/12/20 22:00	1			64			64											
08/12/20 23:00	1			61			60											
08/13/20 0:00	1			52			53											
08/13/20 1:00	1			44			45											
08/13/20 2:00	1			38			39											
08/13/20 3:00	1			37			36											
08/13/20 4:00	1			37			36											
08/13/20 5:00	1			37			36											
08/13/20 6:00	1			38			37											
08/13/20 7:00	1			38			38											
08/13/20 8:00	1			39			41											
08/13/20 9:00	1			42			45											
08/13/20 10:00	1			51			53											
08/13/20 11:00	1			62			62											
08/13/20 12:00	1			71			70											
08/13/20 13:00	1			76			74											
08/13/20 14:00	1			77			75											
08/13/20 15:00	1			76			74											
08/13/20 16:00	1			74			73											
08/13/20 17:00	1			74			73											
08/13/20 18:00	1			73			72											
08/13/20 19:00	1			70			69											
08/13/20 20:00	1			65			64											
08/13/20 21:00	1			66			65											
08/13/20 22:00	1			70			69											
08/13/20 23:00	1			67			67											
08/14/20 0:00	1			55			58											
08/14/20 1:00	1			42			48											
08/14/20 2:00	1			37			43											
08/14/20 3:00	1			37			40											
08/14/20 4:00	1			38			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/14/20 5:00	1			40			41											
08/14/20 6:00	1			47			47											
08/14/20 7:00	1			55			55											
08/14/20 8:00	1			66			65											
08/14/20 9:00	1			73			71											
08/14/20 10:00	1			78			76											
08/14/20 11:00	1			76			75											
08/14/20 12:00	1			73			72											
08/14/20 13:00	1			71			70											
08/14/20 14:00	1			69			68											
08/14/20 15:00	1			72			71											
08/14/20 16:00	1			74			73											
08/14/20 17:00	1			76			75											
08/14/20 18:00	1			76			75											
08/14/20 19:00	1			76			75											
08/14/20 20:00	1			75			74											
08/14/20 21:00	1			72			71											
08/14/20 22:00	1			69			68											
08/14/20 23:00	1			61			60											
08/15/20 0:00	1			52			53											
08/15/20 1:00	1			43			47											
08/15/20 2:00	1			40			44											
08/15/20 3:00	1			39			41											
08/15/20 4:00	1			37			37											
08/15/20 5:00	1			37			36											
08/15/20 6:00	1			40			40											
08/15/20 7:00	1			46			46											
08/15/20 8:00	1			58			58											
08/15/20 9:00	1			68			68											
08/15/20 10:00	1			76			74											
08/15/20 11:00	1			77			76											
08/15/20 12:00	1			75			74											
08/15/20 13:00	1			72			71											
08/15/20 14:00	1			71			70											
08/15/20 15:00	1			71			69											
08/15/20 16:00	1			72			71											
08/15/20 17:00	1			72			70											
08/15/20 18:00	1			73			72											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/15/20 19:00	1			74			73											
08/15/20 20:00	1			75			74											
08/15/20 21:00	1			76			75											
08/15/20 22:00	1			76			75											
08/15/20 23:00	1			73			71											
08/16/20 0:00	1			64			63											
08/16/20 1:00	1			54			55											
08/16/20 2:00	1			48			49											
08/16/20 3:00	1			44			47											
08/16/20 4:00	1			41			46											
08/16/20 5:00	1			41			47											
08/16/20 6:00	1			44			48											
08/16/20 7:00	1			48			50											
08/16/20 8:00	1			49			50											
08/16/20 9:00	1			55			56											
08/16/20 10:00	1			59			60											
08/16/20 11:00	1			65			64											
08/16/20 12:00	1			64			63											
08/16/20 13:00	1			65			64											
08/16/20 14:00	1			68			67											
08/16/20 15:00	1			72			71											
08/16/20 16:00	1			74			73											
08/16/20 17:00	1			72			71											
08/16/20 18:00	1			69			68											
08/16/20 19:00	1			68			67											
08/16/20 20:00	1			70			69											
08/16/20 21:00	1			73			71											
08/16/20 22:00	1			74			73											
08/16/20 23:00	1			70			69											
08/17/20 0:00	1			61			63											
08/17/20 1:00	1			52			54											
08/17/20 2:00	1			45			49											
08/17/20 3:00	1			43			47											
08/17/20 4:00	1			42			49											
08/17/20 5:00	1			44			50											
08/17/20 6:00	1			49			53											
08/17/20 7:00	1			58			59											
08/17/20 8:00	1			67			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/17/20 9:00	1			75			73											
08/17/20 10:00	1			77			76											
08/17/20 11:00	1			77			76											
08/17/20 12:00	1			76			75											
08/17/20 13:00	1			73			72											
08/17/20 14:00	1			69			68											
08/17/20 15:00	1			59			59											
08/17/20 16:00	1			58			57											
08/17/20 17:00	1			59			59											
08/17/20 18:00	1			68			67											
08/17/20 19:00	1			71			70											
08/17/20 20:00	1			70			69											
08/17/20 21:00	1			67			66											
08/17/20 22:00	1			62			61											
08/17/20 23:00	1			58			57											
08/18/20 0:00	1			53			52											
08/18/20 1:00	1			48			48											
08/18/20 2:00	1			44			44											
08/18/20 3:00	1			42			43											
08/18/20 4:00	1			42			43											
08/18/20 5:00	1			40			41											
08/18/20 6:00	1			39			40											
08/18/20 7:00	1			41			41											
08/18/20 8:00	1			49			49											
08/18/20 9:00	1			59			59											
08/18/20 10:00	1			67			66											
08/18/20 11:00	1			71			70											
08/18/20 12:00	1			73			72											
08/18/20 13:00	1			74			73											
08/18/20 14:00	1			74			73											
08/18/20 15:00	1			69			68											
08/18/20 16:00	1			66			65											
08/18/20 17:00	1			63			62											
08/18/20 18:00	1			64			63											
08/18/20 19:00	1			63			62											
08/18/20 20:00	1			57			56											
08/18/20 21:00	1			57			56											
08/18/20 22:00	1			56			56											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/18/20 23:00	1			63			63											
08/19/20 0:00	1			60			60											
08/19/20 1:00	1			56			57											
08/19/20 2:00	1			51			52											
08/19/20 3:00	1			46			50											
08/19/20 4:00	1			45			50											
08/19/20 5:00	1			45			51											
08/19/20 6:00	1			49			54											
08/19/20 7:00	1			54			57											
08/19/20 8:00	1			62			63											
08/19/20 9:00	1			67			67											
08/19/20 10:00	1			72			71											
08/19/20 11:00	1			74			73											
08/19/20 12:00	1			77			76											
08/19/20 13:00	1			76			75											
08/19/20 14:00	1			71			70											
08/19/20 15:00	1			66			66											
08/19/20 16:00	1			64			64											
08/19/20 17:00	1			68			67											
08/19/20 18:00	1			71			70											
08/19/20 19:00	1			71			70											
08/19/20 20:00	1			68			67											
08/19/20 21:00	1			65			65											
08/19/20 22:00	1			61			61											
08/19/20 23:00	1			57			57											
08/20/20 0:00	1			50			50											
08/20/20 1:00	1			44			46											
08/20/20 2:00	1			39			41											
08/20/20 3:00	1			37			38											
08/20/20 4:00	1			37			36											
08/20/20 5:00	1			37			37											
08/20/20 6:00	1			38			38											
08/20/20 7:00	1			38			39											
08/20/20 8:00	1			38			40											
08/20/20 9:00	1			41			43											
08/20/20 10:00	1			46			48											
08/20/20 11:00	1			53			54											
08/20/20 12:00	1			57			57											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/20/20 13:00	1			59			58											
08/20/20 14:00	1			53			54											
08/20/20 15:00	1			55			55											
08/20/20 16:00	1			53			53											
08/20/20 17:00	1			55			57											
08/20/20 18:00	1			55			57											
08/20/20 19:00	1			54			56											
08/20/20 20:00	1			52			54											
08/20/20 21:00	1			48			52											
08/20/20 22:00	1			45			52											
08/20/20 23:00	1			42			46											
08/21/20 0:00	1			38			40											
08/21/20 1:00	1			37			36											
08/21/20 2:00	1			37			36											
08/21/20 3:00	1			38			37											
08/21/20 4:00	1			38			38											
08/21/20 5:00	1			38			38											
08/21/20 6:00	1			39			39											
08/21/20 7:00	1			42			42											
08/21/20 8:00	1			45			47											
08/21/20 9:00	1			48			51											
08/21/20 10:00	1			50			54											
08/21/20 11:00	1			55			57											
08/21/20 12:00	1			57			56											
08/21/20 13:00	1			63			60											
08/21/20 14:00	1			66			64											
08/21/20 15:00	1			72			71											
08/21/20 16:00	1			73			72											
08/21/20 17:00	1			76			75											
08/21/20 18:00	1			77			76											
08/21/20 19:00	1			70			70											
08/21/20 20:00	1			61			61											
08/21/20 21:00	1			58			58											
08/21/20 22:00	1			62			62											
08/21/20 23:00	1			61			61											
08/22/20 0:00	1			50			51											
08/22/20 1:00	1			41			42											
08/22/20 2:00	1			39			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/22/20 3:00	1			39			39											
08/22/20 4:00	1			38			38											
08/22/20 5:00	1			37			36											
08/22/20 6:00	1			37			37											
08/22/20 7:00	1			39			39											
08/22/20 8:00	1			40			42											
08/22/20 9:00	1			44			46											
08/22/20 10:00	1			49			50											
08/22/20 11:00	1			56			56											
08/22/20 12:00	1			60			59											
08/22/20 13:00	1			60			59											
08/22/20 14:00	1			59			58											
08/22/20 15:00	1			60			59											
08/22/20 16:00	1			65			64											
08/22/20 17:00	1			71			69											
08/22/20 18:00	1			74			73											
08/22/20 19:00	1			73			71											
08/22/20 20:00	1			69			68											
08/22/20 21:00	1			65			64											
08/22/20 22:00	1			62			61											
08/22/20 23:00	1			56			55											
08/23/20 0:00	1			49			50											
08/23/20 1:00	1			42			44											
08/23/20 2:00	1			38			39											
08/23/20 3:00	1			37			37											
08/23/20 4:00	1			37			36											
08/23/20 5:00	1			37			36											
08/23/20 6:00	1			37			36											
08/23/20 7:00	1			37			36											
08/23/20 8:00	1			37			37											
08/23/20 9:00	1			42			42											
08/23/20 10:00	1			49			49											
08/23/20 11:00	1			60			60											
08/23/20 12:00	1			68			67											
08/23/20 13:00	1			73			71											
08/23/20 14:00	1			73			72											
08/23/20 15:00	1			72			70											
08/23/20 16:00	1			71			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/23/20 17:00	1			70			70											
08/23/20 18:00	1			69			69											
08/23/20 19:00	1			66			65											
08/23/20 20:00	1			61			61											
08/23/20 21:00	1			61			60											
08/23/20 22:00	1			61			60											
08/23/20 23:00	1			57			57											
08/24/20 0:00	1			48			50											
08/24/20 1:00	1			41			42											
08/24/20 2:00	1			38			39											
08/24/20 3:00	1			37			36											
08/24/20 4:00	1			38			38											
08/24/20 5:00	1			39			40											
08/24/20 6:00	1			40			43											
08/24/20 7:00	1			43			48											
08/24/20 8:00	1			50			54											
08/24/20 9:00	1			59			61											
08/24/20 10:00	1			67			66											
08/24/20 11:00	1			72			70											
08/24/20 12:00	1			73			72											
08/24/20 13:00	1			72			71											
08/24/20 14:00	1			70			68											
08/24/20 15:00	1			68			67											
08/24/20 16:00	1			69			68											
08/24/20 17:00	1			69			68											
08/24/20 18:00	1			69			68											
08/24/20 19:00	1			66			65											
08/24/20 20:00	1			60			60											
08/24/20 21:00	1			58			57											
08/24/20 22:00	1			59			58											
08/24/20 23:00	1			57			57											
08/25/20 0:00	1			51			52											
08/25/20 1:00	1			42			44											
08/25/20 2:00	1			38			39											
08/25/20 3:00	1			37			37											
08/25/20 4:00	1			37			36											
08/25/20 5:00	1			37			36											
08/25/20 6:00	1			38			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/25/20 7:00	1			41			42											
08/25/20 8:00	1			45			48											
08/25/20 9:00	1			51			53											
08/25/20 10:00	1			59			59											
08/25/20 11:00	1			65			64											
08/25/20 12:00	1			67			66											
08/25/20 13:00	1			67			66											
08/25/20 14:00	1			65			64											
08/25/20 15:00	1			66			65											
08/25/20 16:00	1			68			67											
08/25/20 17:00	1			72			70											
08/25/20 18:00	1			72			70											
08/25/20 19:00	1			70			69											
08/25/20 20:00	1			63			63											
08/25/20 21:00	1			59			59											
08/25/20 22:00	1			55			55											
08/25/20 23:00	1			49			51											
08/26/20 0:00	1			43			45											
08/26/20 1:00	1			38			39											
08/26/20 2:00	1			37			36											
08/26/20 3:00	1			37			36											
08/26/20 4:00	1			37			37											
08/26/20 5:00	1			37			38											
08/26/20 6:00	1			37			40											
08/26/20 7:00	1			39			43											
08/26/20 8:00	1			43			48											
08/26/20 9:00	1			48			53											
08/26/20 10:00	1			55			58											
08/26/20 11:00	1			62			63											
08/26/20 12:00	1			70			69											
08/26/20 13:00	1			74			73											
08/26/20 14:00	1			76			75											
08/26/20 15:00	1			76			75											
08/26/20 16:00	1			76			75											
08/26/20 17:00	1			76			75											
08/26/20 18:00	1			72			72											
08/26/20 19:00	1			66			66											
08/26/20 20:00	1			59			59											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/26/20 21:00	1			56			56											
08/26/20 22:00	1			50			52											
08/26/20 23:00	1			45			47											
08/27/20 0:00	1			39			40											
08/27/20 1:00	1			37			38											
08/27/20 2:00	1			37			36											
08/27/20 3:00	1			37			36											
08/27/20 4:00	1			37			36											
08/27/20 5:00	1			37			36											
08/27/20 6:00	1			37			36											
08/27/20 7:00	1			37			36											
08/27/20 8:00	1			38			37											
08/27/20 9:00	1			40			40											
08/27/20 10:00	1			46			47											
08/27/20 11:00	1			53			55											
08/27/20 12:00	1			60			60											
08/27/20 13:00	1			65			64											
08/27/20 14:00	1			67			66											
08/27/20 15:00	1			69			68											
08/27/20 16:00	1			70			68											
08/27/20 17:00	1			70			69											
08/27/20 18:00	1			69			68											
08/27/20 19:00	1			66			65											
08/27/20 20:00	1			61			60											
08/27/20 21:00	1			57			56											
08/27/20 22:00	1			50			51											
08/27/20 23:00	1			45			47											
08/28/20 0:00	1			39			41											
08/28/20 1:00	1			37			38											
08/28/20 2:00	1			37			36											
08/28/20 3:00	1			37			36											
08/28/20 4:00	1			37			36											
08/28/20 5:00	1			37			36											
08/28/20 6:00	1			37			36											
08/28/20 7:00	1			38			37											
08/28/20 8:00	1			40			41											
08/28/20 9:00	1			44			47											
08/28/20 10:00	1			50			53											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/28/20 11:00	1			58			59											
08/28/20 12:00	1			67			66											
08/28/20 13:00	1			73			72											
08/28/20 14:00	1			73			73											
08/28/20 15:00	1			71			71											
08/28/20 16:00	1			71			71											
08/28/20 17:00	1			73			72											
08/28/20 18:00	1			71			70											
08/28/20 19:00	1			65			65											
08/28/20 20:00	1			59			59											
08/28/20 21:00	1			57			57											
08/28/20 22:00	1			55			56											
08/28/20 23:00	1			52			53											
08/29/20 0:00	1			45			47											
08/29/20 1:00	1			40			41											
08/29/20 2:00	1			37			37											
08/29/20 3:00	1			37			36											
08/29/20 4:00	1			37			36											
08/29/20 5:00	1			37			36											
08/29/20 6:00	1			37			36											
08/29/20 7:00	1			37			36											
08/29/20 8:00	1			38			37											
08/29/20 9:00	1			41			41											
08/29/20 10:00	1			45			46											
08/29/20 11:00	1			51			52											
08/29/20 12:00	1			57			58											
08/29/20 13:00	1			66			65											
08/29/20 14:00	1			71			70											
08/29/20 15:00	1			74			73											
08/29/20 16:00	1			72			71											
08/29/20 17:00	1			69			69											
08/29/20 18:00	1			63			63											
08/29/20 19:00	1			56			56											
08/29/20 20:00	1			51			52											
08/29/20 21:00	1			51			53											
08/29/20 22:00	1			50			53											
08/29/20 23:00	1			46			50											
08/30/20 0:00	1			40			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 1:00	1			38			39											
08/30/20 2:00	1			37			36											
08/30/20 3:00	1			37			36											
08/30/20 4:00	1			37			36											
08/30/20 5:00	1			37			36											
08/30/20 6:00	1			37			36											
08/30/20 7:00	1			37			36											
08/30/20 8:00	1			37			36											
08/30/20 9:00	1			38			37											
08/30/20 10:00	1			41			41											
08/30/20 11:00	1			46			48											
08/30/20 12:00	1			55			56											
08/30/20 13:00	1			64			64											
08/30/20 14:00	1			72			71											
08/30/20 15:00	1			74			73											
08/30/20 16:00	1			72			71											
08/30/20 17:00	1			69			68											
08/30/20 18:00	1			64			63											
08/30/20 19:00	1			59			58											
08/30/20 20:00	1			51			51											
08/30/20 21:00	1			50			51											
08/30/20 22:00	1			48			47											
08/30/20 23:00	1			57			33											
08/31/20 0:00	1			63			14											
08/31/20 1:00	1			70			1											
08/31/20 2:00	1			67			0											
08/31/20 3:00	1			64			0											
08/31/20 4:00	1			63			0											
08/31/20 5:00	1			64			0											
08/31/20 6:00	1			65			0											
08/31/20 7:00	1			66			0											
08/31/20 8:00	1			69			0											
08/31/20 9:00	1			69			0											
08/31/20 10:00	1			68			0											
08/31/20 11:00	1			67			0											
08/31/20 12:00	1			69			0											
08/31/20 13:00	1			71			0											
08/31/20 14:00	1			69			3											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:00	1			63			19											
08/31/20 16:00	1			61			40											
08/31/20 17:00	1			63			60											
08/31/20 18:00	1			67			66											
08/31/20 19:00	1			67			66											
08/31/20 20:00	1			57			57											
08/31/20 21:00	1			54			54											
08/31/20 22:00	1			48			48											
08/31/20 23:00	1			49			50											
09/01/20 0:00	1			43			46											
09/01/20 1:00	1			40			43											
09/01/20 2:00	1			37			39											
09/01/20 3:00	1			37			37											
09/01/20 4:00	1			37			36											
09/01/20 5:00	1			40			40											
09/01/20 6:00	1			44			45											
09/01/20 7:00	1			49			51											
09/01/20 8:00	1			53			55											
09/01/20 9:00	1			56			57											
09/01/20 10:00	1			58			57											
09/01/20 11:00	1			59			58											
09/01/20 12:00	1			64			63											
09/01/20 13:00	1			70			69											
09/01/20 14:00	1			74			74											
09/01/20 15:00	1			75			74											
09/01/20 16:00	1			75			75											
09/01/20 17:00	1			74			73											
09/01/20 18:00	1			72			71											
09/01/20 19:00	1			70			69											
09/01/20 20:00	1			70			69											
09/01/20 21:00	1			66			66											
09/01/20 22:00	1			59			58											
09/01/20 23:00	1			50			51											
09/02/20 0:00	1			45			47											
09/02/20 1:00	1			44			48											
09/02/20 2:00	1			42			47											
09/02/20 3:00	1			40			47											
09/02/20 4:00	1			38			48											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/02/20 5:00	1			39			48											
09/02/20 6:00	1			41			48											
09/02/20 7:00	1			45			49											
09/02/20 8:00	1			49			52											
09/02/20 9:00	1			51			54											
09/02/20 10:00	1			51			54											
09/02/20 11:00	1			49			52											
09/02/20 12:00	1			48			51											
09/02/20 13:00	1			51			54											
09/02/20 14:00	1			59			60											
09/02/20 15:00	1			66			66											
09/02/20 16:00	1			70			69											
09/02/20 17:00	1			70			69											
09/02/20 18:00	1			69			68											
09/02/20 19:00	1			66			65											
09/02/20 20:00	1			61			60											
09/02/20 21:00	1			59			59											
09/02/20 22:00	1			57			57											
09/02/20 23:00	1			56			56											
09/03/20 0:00	1			49			51											
09/03/20 1:00	1			43			48											
09/03/20 2:00	1			39			47											
09/03/20 3:00	1			37			46											
09/03/20 4:00	1			38			47											
09/03/20 5:00	1			38			48											
09/03/20 6:00	1			38			50											
09/03/20 7:00	1			37			51											
09/03/20 8:00	1			41			50											
09/03/20 9:00	1			44			49											
09/03/20 10:00	1			49			50											
09/03/20 11:00	1			52			54											
09/03/20 12:00	1			60			61											
09/03/20 13:00	1			69			68											
09/03/20 14:00	1			74			73											
09/03/20 15:00	1			76			75											
09/03/20 16:00	1			76			75											
09/03/20 17:00	1			76			75											
09/03/20 18:00	1			76			75											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/03/20 19:00	1			75			74											
09/03/20 20:00	1			74			74											
09/03/20 21:00	1			73			73											
09/03/20 22:00	1			69			68											
09/03/20 23:00	1			62			60											
09/04/20 0:00	1			54			52											
09/04/20 1:00	1			48			47											
09/04/20 2:00	1			44			46											
09/04/20 3:00	1			42			46											
09/04/20 4:00	1			41			48											
09/04/20 5:00	1			42			48											
09/04/20 6:00	1			42			47											
09/04/20 7:00	1			42			46											
09/04/20 8:00	1			43			48											
09/04/20 9:00	1			44			51											
09/04/20 10:00	1			47			54											
09/04/20 11:00	1			52			57											
09/04/20 12:00	1			60			62											
09/04/20 13:00	1			69			68											
09/04/20 14:00	1			74			73											
09/04/20 15:00	1			76			75											
09/04/20 16:00	1			76			75											
09/04/20 17:00	1			75			74											
09/04/20 18:00	1			75			74											
09/04/20 19:00	1			75			74											
09/04/20 20:00	1			76			75											
09/04/20 21:00	1			76			75											
09/04/20 22:00	1			73			72											
09/04/20 23:00	1			62			63											
09/05/20 0:00	1			50			53											
09/05/20 1:00	1			40			46											
09/05/20 2:00	1			37			45											
09/05/20 3:00	1			37			44											
09/05/20 4:00	1			37			42											
09/05/20 5:00	1			37			39											
09/05/20 6:00	1			37			37											
09/05/20 7:00	1			37			36											
09/05/20 8:00	1			39			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/20 9:00	1			44			44											
09/05/20 10:00	1			52			52											
09/05/20 11:00	1			61			61											
09/05/20 12:00	1			68			67											
09/05/20 13:00	1			73			72											
09/05/20 14:00	1			74			73											
09/05/20 15:00	1			75			74											
09/05/20 16:00	1			74			74											
09/05/20 17:00	1			74			74											
09/05/20 18:00	1			72			71											
09/05/20 19:00	1			71			70											
09/05/20 20:00	1			71			70											
09/05/20 21:00	1			72			71											
09/05/20 22:00	1			69			68											
09/05/20 23:00	1			61			61											
09/06/20 0:00	1			53			53											
09/06/20 1:00	1			45			47											
09/06/20 2:00	1			40			42											
09/06/20 3:00	1			37			38											
09/06/20 4:00	1			37			36											
09/06/20 5:00	1			37			36											
09/06/20 6:00	1			37			37											
09/06/20 7:00	1			38			39											
09/06/20 8:00	1			39			42											
09/06/20 9:00	1			44			48											
09/06/20 10:00	1			49			52											
09/06/20 11:00	1			52			53											
09/06/20 12:00	1			55			55											
09/06/20 13:00	1			60			60											
09/06/20 14:00	1			67			67											
09/06/20 15:00	1			71			71											
09/06/20 16:00	1			73			72											
09/06/20 17:00	1			73			73											
09/06/20 18:00	1			73			73											
09/06/20 19:00	1			72			72											
09/06/20 20:00	1			72			72											
09/06/20 21:00	1			73			72											
09/06/20 22:00	1			71			70											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/06/20 23:00	1			66			65											
09/07/20 0:00	1			57			57											
09/07/20 1:00	1			48			49											
09/07/20 2:00	1			41			43											
09/07/20 3:00	1			38			40											
09/07/20 4:00	1			37			37											
09/07/20 5:00	1			37			37											
09/07/20 6:00	1			37			36											
09/07/20 7:00	1			38			38											
09/07/20 8:00	1			42			43											
09/07/20 9:00	1			51			52											
09/07/20 10:00	1			63			63											
09/07/20 11:00	1			71			70											
09/07/20 12:00	1			71			70											
09/07/20 13:00	1			70			69											
09/07/20 14:00	1			68			67											
09/07/20 15:00	1			67			66											
09/07/20 16:00	1			65			65											
09/07/20 17:00	1			64			64											
09/07/20 18:00	1			63			62											
09/07/20 19:00	1			59			58											
09/07/20 20:00	1			58			57											
09/07/20 21:00	1			60			59											
09/07/20 22:00	1			60			60											
09/07/20 23:00	1			58			57											
09/08/20 0:00	1			49			51											
09/08/20 1:00	1			46			49											
09/08/20 2:00	1			45			50											
09/08/20 3:00	1			44			51											
09/08/20 4:00	1			42			50											
09/08/20 5:00	1			42			50											
09/08/20 6:00	1			48			53											
09/08/20 7:00	1			56			57											
09/08/20 8:00	1			62			62											
09/08/20 9:00	1			68			67											
09/08/20 10:00	1			68			67											
09/08/20 11:00	1			64			63											
09/08/20 12:00	1			57			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/08/20 13:00	1			53			55											
09/08/20 14:00	1			48			53											
09/08/20 15:00	1			43			46											
09/08/20 16:00	1			38			40											
09/08/20 17:00	1			37			36											
09/08/20 18:00	1			37			37											
09/08/20 19:00	1			38			39											
09/08/20 20:00	1			39			40											
09/08/20 21:00	1			45			46											
09/08/20 22:00	1			48			48											
09/08/20 23:00	1			48			48											
09/09/20 0:00	1			42			42											
09/09/20 1:00	1			37			37											
09/09/20 2:00	1			37			36											
09/09/20 3:00	1			37			36											
09/09/20 4:00	1			37			36											
09/09/20 5:00	1			37			36											
09/09/20 6:00	1			41			40											
09/09/20 7:00	1			54			53											
09/09/20 8:00	1			68			67											
09/09/20 9:00	1			77			77											
09/09/20 10:00	1			78			77											
09/09/20 11:00	1			77			77											
09/09/20 12:00	1			78			77											
09/09/20 13:00	1			78			76											
09/09/20 14:00	1			77			76											
09/09/20 15:00	1			77			76											
09/09/20 16:00	1			76			76											
09/09/20 17:00	1			67			67											
09/09/20 18:00	1			56			59											
09/09/20 19:00	1			47			51											
09/09/20 20:00	1			43			50											
09/09/20 21:00	1			41			47											
09/09/20 22:00	1			38			44											
09/09/20 23:00	1			38			43											
09/10/20 0:00	1			38			42											
09/10/20 1:00	1			37			40											
09/10/20 2:00	1			37			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/10/20 3:00	1			37			36											
09/10/20 4:00	1			38			37											
09/10/20 5:00	1			38			37											
09/10/20 6:00	1			38			37											
09/10/20 7:00	1			37			37											
09/10/20 8:00	1			37			37											
09/10/20 9:00	1			39			39											
09/10/20 10:00	1			41			41											
09/10/20 11:00	1			46			48											
09/10/20 12:00	1			50			53											
09/10/20 13:00	1			55			58											
09/10/20 14:00	1			56			58											
09/10/20 15:00	1			58			59											
09/10/20 16:00	1			58			58											
09/10/20 17:00	1			59			58											
09/10/20 18:00	1			58			57											
09/10/20 19:00	1			62			62											
09/10/20 20:00	1			63			63											
09/10/20 21:00	1			65			64											
09/10/20 22:00	1			59			58											
09/10/20 23:00	1			53			51											
09/11/20 0:00	1			47			46											
09/11/20 1:00	1			41			42											
09/11/20 2:00	1			39			40											
09/11/20 3:00	1			37			38											
09/11/20 4:00	1			39			39											
09/11/20 5:00	1			39			39											
09/11/20 6:00	1			39			39											
09/11/20 7:00	1			38			37											
09/11/20 8:00	1			39			40											
09/11/20 9:00	1			44			46											
09/11/20 10:00	1			49			52											
09/11/20 11:00	1			54			56											
09/11/20 12:00	1			57			58											
09/11/20 13:00	1			59			60											
09/11/20 14:00	1			63			63											
09/11/20 15:00	1			59			61											
09/11/20 16:00	1			54			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/11/20 17:00	1			51			55											
09/11/20 18:00	1			53			55											
09/11/20 19:00	1			50			51											
09/11/20 20:00	1			48			49											
09/11/20 21:00	1			49			50											
09/11/20 22:00	1			52			54											
09/11/20 23:00	1			51			54											
09/12/20 0:00	1			44			50											
09/12/20 1:00	1			40			45											
09/12/20 2:00	1			37			39											
09/12/20 3:00	1			37			36											
09/12/20 4:00	1			37			36											
09/12/20 5:00	1			37			36											
09/12/20 6:00	1			37			37											
09/12/20 7:00	1			37			37											
09/12/20 8:00	1			37			38											
09/12/20 9:00	1			38			40											
09/12/20 10:00	1			41			45											
09/12/20 11:00	1			44			50											
09/12/20 12:00	1			50			54											
09/12/20 13:00	1			58			60											
09/12/20 14:00	1			66			66											
09/12/20 15:00	1			68			67											
09/12/20 16:00	1			65			65											
09/12/20 17:00	1			65			64											
09/12/20 18:00	1			63			63											
09/12/20 19:00	1			60			60											
09/12/20 20:00	1			51			53											
09/12/20 21:00	1			52			53											
09/12/20 22:00	1			52			54											
09/12/20 23:00	1			53			53											
09/13/20 0:00	1			47			49											
09/13/20 1:00	1			42			45											
09/13/20 2:00	1			38			41											
09/13/20 3:00	1			37			38											
09/13/20 4:00	1			37			37											
09/13/20 5:00	1			37			37											
09/13/20 6:00	1			37			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/13/20 7:00	1			37			36											
09/13/20 8:00	1			39			38											
09/13/20 9:00	1			42			43											
09/13/20 10:00	1			49			50											
09/13/20 11:00	1			55			56											
09/13/20 12:00	1			61			60											
09/13/20 13:00	1			65			64											
09/13/20 14:00	1			68			66											
09/13/20 15:00	1			69			68											
09/13/20 16:00	1			66			65											
09/13/20 17:00	1			63			62											
09/13/20 18:00	1			60			59											
09/13/20 19:00	1			56			55											
09/13/20 20:00	1			57			57											
09/13/20 21:00	1			58			58											
09/13/20 22:00	1			60			60											
09/13/20 23:00	1			53			54											
09/14/20 0:00	1			45			47											
09/14/20 1:00	1			39			40											
09/14/20 2:00	1			37			37											
09/14/20 3:00	1			37			36											
09/14/20 4:00	1			37			36											
09/14/20 5:00	1			37			36											
09/14/20 6:00	1			37			37											
09/14/20 7:00	1			38			38											
09/14/20 8:00	1			40			42											
09/14/20 9:00	1			43			47											
09/14/20 10:00	1			47			52											
09/14/20 11:00	1			51			55											
09/14/20 12:00	1			56			58											
09/14/20 13:00	1			63			63											
09/14/20 14:00	1			70			69											
09/14/20 15:00	1			73			72											
09/14/20 16:00	1			74			73											
09/14/20 17:00	1			74			73											
09/14/20 18:00	1			74			73											
09/14/20 19:00	1			67			66											
09/14/20 20:00	1			59			59											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/14/20 21:00	1			55			54											
09/14/20 22:00	1			55			55											
09/14/20 23:00	1			51			52											
09/15/20 0:00	1			43			47											
09/15/20 1:00	1			38			42											
09/15/20 2:00	1			37			39											
09/15/20 3:00	1			37			37											
09/15/20 4:00	1			37			36											
09/15/20 5:00	1			37			38											
09/15/20 6:00	1			37			39											
09/15/20 7:00	1			38			42											
09/15/20 8:00	1			41			46											
09/15/20 9:00	1			45			51											
09/15/20 10:00	1			51			55											
09/15/20 11:00	1			56			58											
09/15/20 12:00	1			63			62											
09/15/20 13:00	1			69			68											
09/15/20 14:00	1			74			73											
09/15/20 15:00	1			75			74											
09/15/20 16:00	1			75			74											
09/15/20 17:00	1			74			73											
09/15/20 18:00	1			71			70											
09/15/20 19:00	1			67			66											
09/15/20 20:00	1			59			59											
09/15/20 21:00	1			55			55											
09/15/20 22:00	1			51			52											
09/15/20 23:00	1			50			52											
09/16/20 0:00	1			45			49											
09/16/20 1:00	1			41			48											
09/16/20 2:00	1			38			46											
09/16/20 3:00	1			37			45											
09/16/20 4:00	1			39			44											
09/16/20 5:00	1			41			45											
09/16/20 6:00	1			43			47											
09/16/20 7:00	1			44			50											
09/16/20 8:00	1			46			54											
09/16/20 9:00	1			51			56											
09/16/20 10:00	1			57			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/20 11:00	1			63			62											
09/16/20 12:00	1			68			67											
09/16/20 13:00	1			72			70											
09/16/20 14:00	1			74			73											
09/16/20 15:00	1			75			73											
09/16/20 16:00	1			76			75											
09/16/20 17:00	1			76			75											
09/16/20 18:00	1			75			74											
09/16/20 19:00	1			71			70											
09/16/20 20:00	1			66			65											
09/16/20 21:00	1			62			62											
09/16/20 22:00	1			57			58											
09/16/20 23:00	1			52			54											
09/17/20 0:00	1			44			50											
09/17/20 1:00	1			40			48											
09/17/20 2:00	1			38			46											
09/17/20 3:00	1			37			45											
09/17/20 4:00	1			38			46											
09/17/20 5:00	1			38			48											
09/17/20 6:00	1			40			51											
09/17/20 7:00	1			41			54											
09/17/20 8:00	1			45			56											
09/17/20 9:00	1			51			57											
09/17/20 10:00	1			57			58											
09/17/20 11:00	1			60			59											
09/17/20 12:00	1			62			61											
09/17/20 13:00	1			63			62											
09/17/20 14:00	1			65			64											
09/17/20 15:00	1			69			68											
09/17/20 16:00	1			73			72											
09/17/20 17:00	1			73			73											
09/17/20 18:00	1			71			70											
09/17/20 19:00	1			67			66											
09/17/20 20:00	1			64			64											
09/17/20 21:00	1			63			63											
09/17/20 22:00	1			61			62											
09/17/20 23:00	1			55			57											
09/18/20 0:00	1			45			50											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/18/20 1:00	1			39			45											
09/18/20 2:00	1			37			41											
09/18/20 3:00	1			37			39											
09/18/20 4:00	1			37			40											
09/18/20 5:00	1			39			42											
09/18/20 6:00	1			41			46											
09/18/20 7:00	1			43			51											
09/18/20 8:00	1			49			55											
09/18/20 9:00	1			55			58											
09/18/20 10:00	1			60			60											
09/18/20 11:00	1			62			61											
09/18/20 12:00	1			64			64											
09/18/20 13:00	1			67			66											
09/18/20 14:00	1			69			68											
09/18/20 15:00	1			67			66											
09/18/20 16:00	1			64			64											
09/18/20 17:00	1			63			63											
09/18/20 18:00	1			63			63											
09/18/20 19:00	1			59			58											
09/18/20 20:00	1			57			56											
09/18/20 21:00	1			55			55											
09/18/20 22:00	1			55			56											
09/18/20 23:00	1			47			51											
09/19/20 0:00	1			41			46											
09/19/20 1:00	1			38			42											
09/19/20 2:00	1			37			38											
09/19/20 3:00	1			37			37											
09/19/20 4:00	1			37			36											
09/19/20 5:00	1			37			37											
09/19/20 6:00	1			38			39											
09/19/20 7:00	1			40			44											
09/19/20 8:00	1			42			48											
09/19/20 9:00	1			47			53											
09/19/20 10:00	1			52			56											
09/19/20 11:00	1			57			59											
09/19/20 12:00	1			62			61											
09/19/20 13:00	1			65			64											
09/19/20 14:00	1			66			65											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/19/20 15:00	1			66			65											
09/19/20 16:00	1			63			62											
09/19/20 17:00	1			60			60											
09/19/20 18:00	1			58			58											
09/19/20 19:00	1			61			60											
09/19/20 20:00	1			61			61											
09/19/20 21:00	1			59			59											
09/19/20 22:00	1			52			54											
09/19/20 23:00	1			46			50											
09/20/20 0:00	1			41			45											
09/20/20 1:00	1			38			40											
09/20/20 2:00	1			37			37											
09/20/20 3:00	1			37			36											
09/20/20 4:00	1			37			36											
09/20/20 5:00	1			37			36											
09/20/20 6:00	1			37			37											
09/20/20 7:00	1			37			37											
09/20/20 8:00	1			37			37											
09/20/20 9:00	1			39			39											
09/20/20 10:00	1			42			43											
09/20/20 11:00	1			47			49											
09/20/20 12:00	1			55			56											
09/20/20 13:00	1			62			62											
09/20/20 14:00	1			70			69											
09/20/20 15:00	1			74			73											
09/20/20 16:00	1			73			72											
09/20/20 17:00	1			67			66											
09/20/20 18:00	1			60			60											
09/20/20 19:00	1			56			56											
09/20/20 20:00	1			58			58											
09/20/20 21:00	1			57			58											
09/20/20 22:00	1			54			56											
09/20/20 23:00	1			46			51											
09/21/20 0:00	1			40			46											
09/21/20 1:00	1			38			41											
09/21/20 2:00	1			37			38											
09/21/20 3:00	1			37			37											
09/21/20 4:00	1			37			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/21/20 5:00	1			38			42											
09/21/20 6:00	1			39			46											
09/21/20 7:00	1			40			49											
09/21/20 8:00	1			45			52											
09/21/20 9:00	1			50			55											
09/21/20 10:00	1			57			57											
09/21/20 11:00	1			63			63											
09/21/20 12:00	1			69			68											
09/21/20 13:00	1			74			73											
09/21/20 14:00	1			75			74											
09/21/20 15:00	1			76			75											
09/21/20 16:00	1			75			74											
09/21/20 17:00	1			75			74											
09/21/20 18:00	1			74			73											
09/21/20 19:00	1			71			70											
09/21/20 20:00	1			64			64											
09/21/20 21:00	1			60			60											
09/21/20 22:00	1			55			56											
09/21/20 23:00	1			52			54											
09/22/20 0:00	1			44			48											
09/22/20 1:00	1			40			44											
09/22/20 2:00	1			38			41											
09/22/20 3:00	1			37			40											
09/22/20 4:00	1			38			40											
09/22/20 5:00	1			40			43											
09/22/20 6:00	1			43			46											
09/22/20 7:00	1			47			49											
09/22/20 8:00	1			49			52											
09/22/20 9:00	1			54			56											
09/22/20 10:00	1			59			60											
09/22/20 11:00	1			64			63											
09/22/20 12:00	1			68			67											
09/22/20 13:00	1			70			70											
09/22/20 14:00	1			71			71											
09/22/20 15:00	1			70			70											
09/22/20 16:00	1			70			70											
09/22/20 17:00	1			70			69											
09/22/20 18:00	1			69			69											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/22/20 19:00	1			63			63											
09/22/20 20:00	1			62			62											
09/22/20 21:00	1			59			59											
09/22/20 22:00	1			57			57											
09/22/20 23:00	1			48			50											
09/23/20 0:00	1			41			43											
09/23/20 1:00	1			38			39											
09/23/20 2:00	1			37			37											
09/23/20 3:00	1			37			37											
09/23/20 4:00	1			37			37											
09/23/20 5:00	1			39			39											
09/23/20 6:00	1			41			42											
09/23/20 7:00	1			42			46											
09/23/20 8:00	1			45			50											
09/23/20 9:00	1			50			54											
09/23/20 10:00	1			56			57											
09/23/20 11:00	1			60			59											
09/23/20 12:00	1			62			61											
09/23/20 13:00	1			65			64											
09/23/20 14:00	1			68			67											
09/23/20 15:00	1			69			68											
09/23/20 16:00	1			71			70											
09/23/20 17:00	1			72			71											
09/23/20 18:00	1			74			74											
09/23/20 19:00	1			73			73											
09/23/20 20:00	1			68			68											
09/23/20 21:00	1			63			63											
09/23/20 22:00	1			57			59											
09/23/20 23:00	1			37			58											
09/24/20 0:00	1			17			56											
09/24/20 1:00	1			1			55											
09/24/20 2:00	1			0			53											
09/24/20 3:00	1			0			50											
09/24/20 4:00	1			0			50											
09/24/20 5:00	1			0			48											
09/24/20 6:00	1			0			45											
09/24/20 7:00	1			0			42											
09/24/20 8:00	1			0			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/24/20 9:00	1			0			51											
09/24/20 10:00	1			0			55											
09/24/20 11:00	1			0			55											
09/24/20 12:00	1			0			56											
09/24/20 13:00	1			0			58											
09/24/20 14:00	1			0			60											
09/24/20 15:00	1			0			63											
09/24/20 16:00	1			0			68											
09/24/20 17:00	1			0			72											
09/24/20 18:00	1			0			74											
09/24/20 19:00	1			0			71											
09/24/20 20:00	1			0			67											
09/24/20 21:00	1			0			59											
09/24/20 22:00	1			0			55											
09/24/20 23:00	1			0			53											
09/25/20 0:00	1			0			53											
09/25/20 1:00	1			0			50											
09/25/20 2:00	1			0			45											
09/25/20 3:00	1			0			42											
09/25/20 4:00	1			0			42											
09/25/20 5:00	1			0			41											
09/25/20 6:00	1			0			39											
09/25/20 7:00	1			0			38											
09/25/20 8:00	1			0			42											
09/25/20 9:00	1			0			49											
09/25/20 10:00	1			0			54											
09/25/20 11:00	1			0			55											
09/25/20 12:00	1			0			54											
09/25/20 13:00	1			0			54											
09/25/20 14:00	1			0			55											
09/25/20 15:00	1			0			55											
09/25/20 16:00	1			0			55											
09/25/20 17:00	1			0			53											
09/25/20 18:00	1			0			52											
09/25/20 19:00	1			0			50											
09/25/20 20:00	1			0			52											
09/25/20 21:00	1			0			55											
09/25/20 22:00	1			0			57											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/25/20 23:00	1			0			56											
09/26/20 0:00	1			0			52											
09/26/20 1:00	1			0			47											
09/26/20 2:00	1			0			41											
09/26/20 3:00	1			0			38											
09/26/20 4:00	1			0			37											
09/26/20 5:00	1			0			37											
09/26/20 6:00	1			0			37											
09/26/20 7:00	1			0			37											
09/26/20 8:00	1			0			40											
09/26/20 9:00	1			0			44											
09/26/20 10:00	1			0			47											
09/26/20 11:00	1			0			50											
09/26/20 12:00	1			0			49											
09/26/20 13:00	1			0			50											
09/26/20 14:00	1			0			46											
09/26/20 15:00	1			0			45											
09/26/20 16:00	1			0			43											
09/26/20 17:00	1			0			44											
09/26/20 18:00	1			0			43											
09/26/20 19:00	1			0			42											
09/26/20 20:00	1			0			41											
09/26/20 21:00	1			0			42											
09/26/20 22:00	1			0			44											
09/26/20 23:00	1			0			45											
09/27/20 0:00	1			0			42											
09/27/20 1:00	1			0			39											
09/27/20 2:00	1			0			38											
09/27/20 3:00	1			0			37											
09/27/20 4:00	1			0			37											
09/27/20 5:00	1			0			37											
09/27/20 6:00	1			0			37											
09/27/20 7:00	1			0			37											
09/27/20 8:00	1			0			41											
09/27/20 9:00	1			0			44											
09/27/20 10:00	1			0			46											
09/27/20 11:00	1			0			48											
09/27/20 12:00	1			0			50											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/27/20 13:00	1			0			52											
09/27/20 14:00	1			0			50											
09/27/20 15:00	1			0			49											
09/27/20 16:00	1			0			52											
09/27/20 17:00	1			0			53											
09/27/20 18:00	1			0			54											
09/27/20 19:00	1			0			51											
09/27/20 20:00	1			0			51											
09/27/20 21:00	1			0			51											
09/27/20 22:00	1			0			49											
09/27/20 23:00	1			0			48											
09/28/20 0:00	1			0			43											
09/28/20 1:00	1			0			41											
09/28/20 2:00	1			0			38											
09/28/20 3:00	1			0			38											
09/28/20 4:00	1			3			37											
09/28/20 5:00	1			15			37											
09/28/20 6:00	1			28			37											
09/28/20 7:00	1			39			40											
09/28/20 8:00	1			43			46											
09/28/20 9:00	1			47			50											
09/28/20 10:00	1			49			52											
09/28/20 11:00	1			50			51											
09/28/20 12:00	1			51			51											
09/28/20 13:00	1			60			60											
09/28/20 14:00	1			68			68											
09/28/20 15:00	1			75			74											
09/28/20 16:00	1			72			71											
09/28/20 17:00	1			68			67											
09/28/20 18:00	1			63			62											
09/28/20 19:00	1			59			58											
09/28/20 20:00	1			54			54											
09/28/20 21:00	1			47			49											
09/28/20 22:00	1			41			44											
09/28/20 23:00	1			41			43											
09/29/20 0:00	1			42			43											
09/29/20 1:00	1			42			46											
09/29/20 2:00	1			38			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/29/20 3:00	1			37			41											
09/29/20 4:00	1			38			40											
09/29/20 5:00	1			38			40											
09/29/20 6:00	1			38			39											
09/29/20 7:00	1			38			39											
09/29/20 8:00	1			41			42											
09/29/20 9:00	1			45			48											
09/29/20 10:00	1			50			53											
09/29/20 11:00	1			55			57											
09/29/20 12:00	1			62			62											
09/29/20 13:00	1			68			67											
09/29/20 14:00	1			73			71											
09/29/20 15:00	1			73			71											
09/29/20 16:00	1			72			71											
09/29/20 17:00	1			71			70											
09/29/20 18:00	1			68			67											
09/29/20 19:00	1			62			61											
09/29/20 20:00	1			58			57											
09/29/20 21:00	1			60			59											
09/29/20 22:00	1			61			60											
09/29/20 23:00	1			53			53											
09/30/20 0:00	1			43			43											
09/30/20 1:00	1			37			36											
09/30/20 2:00	1			38			37											
09/30/20 3:00	1			38			39											
09/30/20 4:00	1			38			41											
09/30/20 5:00	1			37			39											
09/30/20 6:00	1			37			38											
09/30/20 7:00	1			37			36											
09/30/20 8:00	1			39			39											
09/30/20 9:00	1			42			43											
09/30/20 10:00	1			49			50											
09/30/20 11:00	1			55			55											
09/30/20 12:00	1			62			61											
09/30/20 13:00	1			68			67											
09/30/20 14:00	1			73			72											
09/30/20 15:00	1			75			73											
09/30/20 16:00	1			74			73											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/30/20 17:00	1			72			71											
09/30/20 18:00	1			70			69											
09/30/20 19:00	1			66			65											
09/30/20 20:00	1			63			62											
09/30/20 21:00	1			63			62											
09/30/20 22:00	1			62			60											
09/30/20 23:00	1			59			58											

CEMs Log

Date/Time	Operator	Description
09/14/20	Operator (ME)	CHANGED UNIT 2 LOW NOX / CO. CYLINDER #EB0020899. NOX 9.291 / CO 8.908
09/12/20	Operator (ME)	CHANGED OUT CT2 O2 BOTTLE. CYLINDER # EB0032563. NEW VALUE O2 =
09/12/20	Operator (ME)	CHANGED OUT CT2 HIGH NOX / CO BOTTLE. CYLINDER # EB0089603. NEW VALUES: CO = 181.3. NOX = 180.0.
09/09/20 0:55	Operator (LH)	CHANGED OUT UNIT #1 02 11.06% BOTTLE #EB0025051
09/09/20 0:53	Operator (LH)	CHANGED OUT UNIT #1 HI NOX 180.0PPM HI CO 181.3 PPM BOTTLE
09/09/20 0:51	Operator (LH)	CHANGED OUT UNIT#1 LOW NOX 9.291PPM LOW CO 9.157PPM BOTTLE
09/05/20 3:13	Operator (DWN)	UPDATED GCV VALUE TO 104000 FOR SEPTEMBER
09/02/20	Operator (BRB)	DID MONTHLY PMS ON CEMS UNIT 1 HRSG AND SCR, ZERROED H/L CO AND SPANED LOW CO.
09/02/20	Operator (BRB)	Spanned Inlet and Stack and performed Monthly PM on unit 2
08/05/20 7:15	Operator (RG)	MANUALLY CALIBRATED CT2 LOW SPAN STACK AND INLET NOX.
08/04/20	Operator (KRB)	CHANGED OUT UNIT #2 LOW NOX 8.991 LOW CO 9.045 CLY # EB 0100828
08/03/20 9:17	Operator (RLC)	BOTTLE NUMBER FOR HIGH NOX CHANGE OUT: EB0032565
08/03/20 9:15	Operator (RLC)	CHANGED OUT 02 BOTTLE UNIT-2. #SG9147999 NEW VALUES: 18.32
08/03/20 9:13	Operator (RLC)	CHANGED OUT HIGH NOX BOTTLE UNIT-2 NEW VALUES: NOX-180.0/CO-179.5
08/03/20 7:23	Operator (LHR)	UPDATED ALL 3 MONTHLY GCV VALUES TO 103300 FOR AUGUST
07/30/20 6:40	Operator (VRL)	CT1 FAILED CALIBRATIONS DUE TO INCORRECT PRESSURE SETTINGS AT REGULATOR. RAN CAL ERROR CHECKS ON SCR AND STACK TO VERIFY PROPER OPERATION.
07/30/20 4:53	Operator (LH)	CHANGED UNIT 1 LOW NOX / CO, EB0019103, NOX 8.991 / CO 9.072
07/29/20	Operator (LH)	CHANGED OUT 02 BOTTLE ON CT 1, NEW VALUE= 18.05 CYLINDER #
07/29/20	Operator (LH)	CHANGED OUT HIGH SPAN BOTTLE ON CT1, NEW VALUE = 180.4 CO, AND 180.5 NOX. CYLINDER # EB0043055 CHANGED OUT 02 BOTTLE ON CT 1, NEW VALUE= 18.05 CYLINDER #
07/15/20 8:50	Operator (VRL)	Adjust CT2 Stqck NOx high and low range. Performed cal error check.
07/08/20	Operator (DE)	GCV FUEL FACTOR UPDATED FOR JULY TO 103,400.
07/07/20	Operator (RG)	7/6/2020 REBUILT CO ANALYZER SAMPLE PUMPS BOTH CT1 AND CT2. RAN MANUAL CALIBRATION.

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	07:27	L	200	50.300	49.900	25.2 %
07/14/2020	07:32	M	200	112.800	114.300	56.4 %
07/14/2020	07:44	L	200	50.300	49.900	25.2 %
07/14/2020	07:49	M	200	112.800	114.200	56.4 %
07/14/2020	08:01	L	200	50.300	49.900	25.2 %
07/14/2020	08:06	M	200	112.800	114.200	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.900	Std	**0.8**
M	112.800	114.233	Std	**1.3**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	11:42	L	10	2.400	2.400	24.0 %
07/14/2020	11:46	M	10	5.700	5.700	57.0 %
07/14/2020	11:54	L	10	2.400	2.300	24.0 %
07/14/2020	11:59	M	10	5.700	5.700	57.0 %
07/14/2020	12:06	L	10	2.400	2.300	24.0 %
07/14/2020	12:11	M	10	5.700	5.800	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.333	Std	**2.8**
M	5.700	5.733	Std	**0.6**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	08:25	L	200	49.400	50.300	24.7 %
07/14/2020	08:30	M	200	112.700	117.600	56.4 %
07/14/2020	08:42	L	200	49.400	50.400	24.7 %
07/14/2020	08:47	M	200	112.700	117.400	56.4 %
07/14/2020	08:59	L	200	49.400	50.400	24.7 %
07/14/2020	09:04	M	200	112.700	117.500	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.367	Std	**2.0**
M	112.700	117.500	Std	**4.3**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	12:55	L	10	2.400	2.300	24.0 %
07/14/2020	13:00	M	10	5.700	5.700	57.0 %
07/14/2020	13:08	L	10	2.400	2.200	24.0 %
07/14/2020	13:13	M	10	5.700	5.700	57.0 %
07/14/2020	13:20	L	10	2.400	2.300	24.0 %
07/14/2020	13:25	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.267	Std	**5.6**
M	5.700	5.700	Std	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	102	Highest Error:	2.5
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0727	L	200.0	47.6	48.3		23.8 %
07/14/2020	0732	M	200.0	105.0	107.9		52.5 %
07/14/2020	0737	H	200.0	179.0	177.6		89.5 %
07/14/2020	0744	L	200.0	47.6	48.7		23.8 %
07/14/2020	0749	M	200.0	105.0	107.6		52.5 %
07/14/2020	0754	H	200.0	179.0	177.4		89.5 %
07/14/2020	0801	L	200.0	47.6	48.6		23.8 %
07/14/2020	0806	M	200.0	105.0	107.3		52.5 %
07/14/2020	0811	H	200.0	179.0	177.2		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.533	No	**2.0**
M	105.000	107.600	No	**2.5**
H	179.000	177.400	No	**0.9**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	103	Highest Error:	3.6
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0927	L	21.0	5.5	5.3		26.2 %
07/14/2020	0932	M	21.0	11.1	10.9		52.9 %
07/14/2020	0937	H	21.0	18.1	18.0		86.2 %
07/14/2020	0944	L	21.0	5.5	5.3		26.2 %
07/14/2020	0949	M	21.0	11.1	10.9		52.9 %
07/14/2020	0954	H	21.0	18.1	18.0		86.2 %
07/14/2020	1001	L	21.0	5.5	5.3		26.2 %
07/14/2020	1006	M	21.0	11.1	10.9		52.9 %
07/14/2020	1011	H	21.0	18.1	18.0		86.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	**3.6**
M	11.100	10.900	No	**1.8**
H	18.100	18.000	No	**0.6**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	102	Highest Error:	1.4
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0825	L	200.0	48.2	48.6		24.1 %
07/14/2020	0830	M	200.0	106.0	107.4		53.0 %
07/14/2020	0835	H	200.0	179.0	177.3		89.5 %
07/14/2020	0842	L	200.0	48.2	48.9		24.1 %
07/14/2020	0847	M	200.0	106.0	107.4		53.0 %
07/14/2020	0852	H	200.0	179.0	177.4		89.5 %
07/14/2020	0859	L	200.0	48.2	48.9		24.1 %
07/14/2020	0904	M	200.0	106.0	107.6		53.0 %
07/14/2020	0909	H	200.0	179.0	177.3		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	48.800	No	**1.2**
M	106.000	107.467	No	**1.4**
H	179.000	177.333	No	**0.9**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	103	Highest Error:	1.8
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	1027	L	21.0	5.6	5.5		26.7 %
07/14/2020	1031	M	21.0	11.2	11.1		53.3 %
07/14/2020	1036	H	21.0	18.0	17.9		85.7 %
07/14/2020	1044	L	21.0	5.6	5.5		26.7 %
07/14/2020	1049	M	21.0	11.2	11.1		53.3 %
07/14/2020	1054	H	21.0	18.0	17.9		85.7 %
07/14/2020	1101	L	21.0	5.6	5.5		26.7 %
07/14/2020	1106	M	21.0	11.2	11.1		53.3 %
07/14/2020	1111	H	21.0	18.0	17.9		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.500	No	**1.8**
M	11.200	11.100	No	**0.9**
H	18.000	17.900	No	**0.6**

Roseville Energy Park
Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.
Teledyne Monitor Labs, Inc.
35 Inverness Drive East
Englewood, CO 80112-5189
Telephone: (800) 846-6062
http://www.teledyne-ml.com/
http://www.regperfect.com/
©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.
RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

7/15,17/20 Taylor Sullivan
Q2 EDRs

7/9/20 Taylor Sullivan
Looking at GHG totals for 2019. Recalculated CO2_Year_Mton tag for Q4 2019

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/01/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/02/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/03/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/04/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/05/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/06/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/07/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
07/08/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/08/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,345.8	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/09/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/10/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/11/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/12/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/13/2020 06:00	1,615.5	145.5	1,615.5	103,400.0	167.0	0.00	0.0	0.0
07/13/2020 07:00	3,206.7	149.3	3,206.7	103,400.0	331.6	0.40	0.2	0.7
07/13/2020 08:00	3,236.8	152.5	3,236.8	103,400.0	334.7	0.42	0.2	0.7
07/13/2020 09:00	3,546.1	153.7	3,546.1	103,400.0	366.7	0.46	0.2	0.8
07/13/2020 10:00	4,059.0	163.4	4,067.2	103,400.0	420.5	0.52	0.3	0.9
07/13/2020 11:00	4,178.4	745.7	4,924.1	103,400.0	509.2	0.61	0.3	1.0
07/13/2020 12:00	4,159.5	836.0	4,995.5	103,400.0	516.5	0.62	0.3	1.0
07/13/2020 13:00	4,151.0	665.1	4,816.1	103,400.0	498.0	0.60	0.3	1.0
07/13/2020 14:00	4,143.4	852.3	4,995.7	103,400.0	516.6	0.62	0.3	1.0
07/13/2020 15:00	4,139.9	844.4	4,984.3	103,400.0	515.4	0.62	0.3	1.0
07/13/2020 16:00	4,144.5	585.3	4,729.8	103,400.0	489.1	0.59	0.3	1.0
07/13/2020 17:00	4,139.6	837.0	4,976.6	103,400.0	514.6	0.62	0.3	1.0
07/13/2020 18:00	4,135.2	1,662.3	5,797.5	103,400.0	599.5	0.72	0.4	1.2
07/13/2020 19:00	4,154.5	912.8	5,067.3	103,400.0	524.0	0.63	0.3	1.0
07/13/2020 20:00	3,561.7	161.1	3,582.6	103,400.0	370.4	0.46	0.2	0.8
07/13/2020 21:00	2,872.9	147.9	2,872.9	103,400.0	297.1	0.37	0.2	0.6
07/13/2020 22:00	2,878.7	146.7	2,878.7	103,400.0	297.7	0.38	0.2	0.6
07/13/2020 23:00	2,883.8	146.9	2,883.8	103,400.0	298.2	0.38	0.2	0.6
Average/Sum#:	3,622.6	517.1	4,065.4	103,400.0	420.4	0.53	0.3	0.9
Minimum:	1,615.5	145.5	1,615.5	103,400.0	167.0	0.37	0.2	0.6
Maximum:	4,178.4	1,662.3	5,797.5	103,400.0	599.5	0.72	0.4	1.2
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2020 00:00	2,882.7	147.0	2,882.7	103,400.0	298.1	0.38	0.2	0.6
07/14/2020 01:00	2,974.9	146.9	2,974.9	103,400.0	307.6	0.39	0.2	0.6
07/14/2020 02:00	2,868.4	147.6	2,868.4	103,400.0	296.6	0.37	0.2	0.6
07/14/2020 03:00	2,870.3	147.3	2,870.3	103,400.0	296.8	0.37	0.2	0.6
07/14/2020 04:00	2,915.9	147.2	2,915.9	103,400.0	301.5	0.38	0.2	0.6
07/14/2020 05:00	2,874.6	146.9	2,874.6	103,400.0	297.2	0.37	0.2	0.6
07/14/2020 06:00	2,878.8	146.7	2,878.8	103,400.0	297.7	0.38	0.2	0.6
07/14/2020 07:00	2,998.1	151.2	2,998.1	103,400.0	310.0	0.39	0.2	0.7
07/14/2020 08:00	3,173.5	156.2	3,173.5	103,400.0	328.1	0.41	0.2	0.7
07/14/2020 09:00	3,437.7	155.1	3,437.7	103,400.0	355.5	0.45	0.2	0.7
07/14/2020 10:00	3,960.6	153.2	3,960.6	103,400.0	409.5	0.51	0.3	0.9
07/14/2020 11:00	4,204.9	456.3	4,638.4	103,400.0	479.6	0.58	0.3	1.0
07/14/2020 12:00	4,181.1	1,193.5	5,374.6	103,400.0	555.7	0.67	0.3	1.1
07/14/2020 13:00	4,170.5	426.5	4,597.0	103,400.0	475.3	0.57	0.3	1.0
07/14/2020 14:00	4,148.4	1,330.0	5,478.4	103,400.0	566.5	0.68	0.3	1.1
07/14/2020 15:00	4,142.9	1,846.4	5,989.3	103,400.0	619.3	0.74	0.4	1.2
07/14/2020 16:00	4,144.5	1,871.1	6,015.6	103,400.0	622.0	0.75	0.4	1.2
07/14/2020 17:00	4,150.2	1,815.3	5,965.5	103,400.0	616.8	0.74	0.4	1.2
07/14/2020 18:00	4,162.9	1,191.8	5,354.7	103,400.0	553.7	0.67	0.3	1.1
07/14/2020 19:00	4,170.7	467.9	4,638.6	103,400.0	479.6	0.57	0.3	1.0
07/14/2020 20:00	4,054.6	156.3	4,067.1	103,400.0	420.5	0.52	0.3	0.9
07/14/2020 21:00	3,796.4	148.3	3,796.4	103,400.0	392.5	0.49	0.2	0.8
07/14/2020 22:00	3,663.7	148.1	3,663.7	103,400.0	378.8	0.47	0.2	0.8
07/14/2020 23:00	3,138.9	147.5	3,138.9	103,400.0	324.6	0.41	0.2	0.7
Average/Sum#:	3,581.9	535.2	4,023.1	103,400.0	416.0	0.51	0.3	0.8
Minimum:	2,868.4	146.7	2,868.4	103,400.0	296.6	0.37	0.2	0.6
Maximum:	4,204.9	1,871.1	6,015.6	103,400.0	622.0	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2020 00:00	2,929.3	147.7	2,929.3	103,400.0	302.9	0.38	0.2	0.6
07/15/2020 01:00	2,885.9	146.8	2,885.9	103,400.0	298.4	0.38	0.2	0.6
07/15/2020 02:00	2,880.6	147.2	2,880.6	103,400.0	297.9	0.38	0.2	0.6
07/15/2020 03:00	2,881.1	146.9	2,881.1	103,400.0	297.9	0.38	0.2	0.6
07/15/2020 04:00	2,882.1	147.7	2,882.1	103,400.0	298.0	0.38	0.2	0.6
07/15/2020 05:00	2,884.1	147.2	2,884.1	103,400.0	298.2	0.38	0.2	0.6
07/15/2020 06:00	2,885.9	145.5	2,885.9	103,400.0	298.4	0.38	0.2	0.6
07/15/2020 07:00	2,900.7	149.6	2,900.7	103,400.0	299.9	0.38	0.2	0.6
07/15/2020 08:00	3,247.0	154.1	3,247.0	103,400.0	335.7	0.42	0.2	0.7
07/15/2020 09:00	3,501.7	154.6	3,501.7	103,400.0	362.1	0.45	0.2	0.8
07/15/2020 10:00	3,958.3	152.0	3,958.3	103,400.0	409.3	0.51	0.3	0.9
07/15/2020 11:00	4,195.9	763.4	4,905.9	103,400.0	507.3	0.62	0.3	1.0
07/15/2020 12:00	4,167.1	1,443.1	5,610.2	103,400.0	580.1	0.70	0.3	1.2
07/15/2020 13:00	4,155.7	1,498.0	5,653.7	103,400.0	584.6	0.70	0.4	1.2
07/15/2020 14:00	4,132.7	1,827.6	5,960.3	103,400.0	616.3	0.74	0.4	1.2
07/15/2020 15:00	4,133.9	1,906.8	6,040.7	103,400.0	624.6	0.75	0.4	1.2
07/15/2020 16:00	4,120.5	1,929.6	6,050.1	103,400.0	625.6	0.75	0.4	1.3
07/15/2020 17:00	4,130.6	1,899.9	6,030.5	103,400.0	623.6	0.75	0.4	1.2
07/15/2020 18:00	4,157.4	1,553.6	5,711.0	103,400.0	590.5	0.71	0.4	1.2
07/15/2020 19:00	4,160.6	379.5	4,540.1	103,400.0	469.4	0.56	0.3	0.9
07/15/2020 20:00	3,850.1	165.0	3,878.2	103,400.0	401.0	0.50	0.2	0.8
07/15/2020 21:00	3,104.8	148.7	3,104.8	103,400.0	321.0	0.40	0.2	0.7
07/15/2020 22:00	2,897.2	148.0	2,897.2	103,400.0	299.6	0.38	0.2	0.6
07/15/2020 23:00	2,890.6	147.8	2,890.6	103,400.0	298.9	0.38	0.2	0.6
Average/Sum#:	3,497.2	643.8	4,046.3	103,400.0	418.4	0.52	0.3	0.8
Minimum:	2,880.6	145.5	2,880.6	103,400.0	297.9	0.38	0.2	0.6
Maximum:	4,195.9	1,929.6	6,050.1	103,400.0	625.6	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2020 00:00	2,889.4	147.6	2,889.4	103,400.0	298.8	0.38	0.2	0.6
07/16/2020 01:00	2,887.8	146.3	2,887.8	103,400.0	298.6	0.38	0.2	0.6
07/16/2020 02:00	2,886.8	146.6	2,886.8	103,400.0	298.5	0.38	0.2	0.6
07/16/2020 03:00	2,886.4	147.5	2,886.4	103,400.0	298.5	0.38	0.2	0.6
07/16/2020 04:00	2,885.6	147.2	2,885.6	103,400.0	298.4	0.38	0.2	0.6
07/16/2020 05:00	2,886.1	146.8	2,886.1	103,400.0	298.4	0.38	0.2	0.6
07/16/2020 06:00	2,892.7	145.5	2,892.7	103,400.0	299.1	0.38	0.2	0.6
07/16/2020 07:00	2,908.9	152.4	2,908.9	103,400.0	300.8	0.38	0.2	0.6
07/16/2020 08:00	3,154.3	154.5	3,154.3	103,400.0	326.2	0.41	0.2	0.7
07/16/2020 09:00	3,501.4	156.2	3,501.4	103,400.0	362.0	0.45	0.2	0.8
07/16/2020 10:00	3,874.2	151.3	3,874.2	103,400.0	400.6	0.50	0.2	0.8
07/16/2020 11:00	4,194.8	434.4	4,594.4	103,400.0	475.1	0.58	0.3	1.0
07/16/2020 12:00	4,178.3	1,406.7	5,585.0	103,400.0	577.5	0.69	0.3	1.2
07/16/2020 13:00	4,151.9	1,057.6	5,209.5	103,400.0	538.7	0.65	0.3	1.1
07/16/2020 14:00	4,138.9	1,159.3	5,298.2	103,400.0	547.8	0.66	0.3	1.1
07/16/2020 15:00	4,115.3	1,965.1	6,080.4	103,400.0	628.7	0.75	0.4	1.3
07/16/2020 16:00	4,116.4	1,961.1	6,077.5	103,400.0	628.4	0.75	0.4	1.3
07/16/2020 17:00	4,144.2	1,974.0	6,118.2	103,400.0	632.6	0.76	0.4	1.3
07/16/2020 18:00	4,151.7	1,061.7	5,213.4	103,400.0	539.1	0.65	0.3	1.1
07/16/2020 19:00	4,130.2	168.7	4,158.9	103,400.0	430.0	0.53	0.3	0.9
07/16/2020 20:00	3,468.6	149.6	3,468.6	103,400.0	358.7	0.45	0.2	0.7
07/16/2020 21:00	3,298.4	148.1	3,298.4	103,400.0	341.1	0.43	0.2	0.7
07/16/2020 22:00	2,902.7	148.2	2,902.7	103,400.0	300.1	0.38	0.2	0.6
07/16/2020 23:00	2,945.9	147.3	2,945.9	103,400.0	304.6	0.39	0.2	0.6
Average/Sum#:	3,483.0	559.3	3,941.9	103,400.0	407.6	0.50	0.3	0.8
Minimum:	2,885.6	145.5	2,885.6	103,400.0	298.4	0.38	0.2	0.6
Maximum:	4,194.8	1,974.0	6,118.2	103,400.0	632.6	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2020 00:00	2,889.4	146.9	2,889.4	103,400.0	298.8	0.38	0.2	0.6
07/17/2020 01:00	2,889.8	147.1	2,889.8	103,400.0	298.8	0.38	0.2	0.6
07/17/2020 02:00	2,888.2	147.4	2,888.2	103,400.0	298.6	0.38	0.2	0.6
07/17/2020 03:00	2,887.9	147.8	2,887.9	103,400.0	298.6	0.38	0.2	0.6
07/17/2020 04:00	2,885.3	147.8	2,885.3	103,400.0	298.3	0.38	0.2	0.6
07/17/2020 05:00	2,884.8	147.0	2,884.8	103,400.0	298.3	0.38	0.2	0.6
07/17/2020 06:00	2,891.4	145.8	2,891.4	103,400.0	299.0	0.38	0.2	0.6
07/17/2020 07:00	2,881.2	89.3	2,881.2	103,400.0	297.9	0.37	0.2	0.6
07/17/2020 08:00	3,120.3	0.0	3,120.3	103,400.0	322.6	0.39	0.2	0.6
07/17/2020 09:00	3,423.1	0.0	3,423.1	103,400.0	353.9	0.42	0.2	0.7
07/17/2020 10:00	3,686.1	0.0	3,686.1	103,400.0	381.1	0.46	0.2	0.8
07/17/2020 11:00	4,179.9	0.0	4,179.9	103,400.0	432.2	0.52	0.3	0.9
07/17/2020 12:00	3,502.3	0.0	3,502.3	103,400.0	362.1	0.44	0.2	0.7
07/17/2020 13:00	3,978.1	0.0	3,978.1	103,400.0	411.3	0.49	0.2	0.8
07/17/2020 14:00	4,181.7	770.7	4,875.3	103,400.0	504.1	0.61	0.3	1.0
07/17/2020 15:00	4,173.8	1,507.6	5,681.4	103,400.0	587.5	0.71	0.4	1.2
07/17/2020 16:00	4,169.3	1,823.3	5,992.6	103,400.0	619.6	0.74	0.4	1.2
07/17/2020 17:00	4,171.6	1,437.2	5,608.8	103,400.0	579.9	0.70	0.3	1.2
07/17/2020 18:00	4,184.7	784.9	4,969.6	103,400.0	513.9	0.62	0.3	1.0
07/17/2020 19:00	3,868.2	128.4	3,896.4	103,400.0	402.9	0.50	0.2	0.8
07/17/2020 20:00	3,180.4	0.0	3,180.4	103,400.0	328.9	0.40	0.2	0.7
07/17/2020 21:00	3,113.7	0.0	3,113.7	103,400.0	322.0	0.39	0.2	0.6
07/17/2020 22:00	3,162.4	0.0	3,162.4	103,400.0	327.0	0.39	0.2	0.7
07/17/2020 23:00	2,890.4	0.0	2,890.4	103,400.0	298.9	0.36	0.2	0.6
Average/Sum#:	3,420.2	315.5	3,681.6	103,400.0	380.7	0.47	0.2	0.8
Minimum:	2,881.2	0.0	2,881.2	103,400.0	297.9	0.36	0.2	0.6
Maximum:	4,184.7	1,823.3	5,992.6	103,400.0	619.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2020 00:00	2,878.7	0.0	2,878.7	103,400.0	297.7	0.36	0.2	0.6
07/18/2020 01:00	2,880.5	0.0	2,880.5	103,400.0	297.8	0.36	0.2	0.6
07/18/2020 02:00	2,879.9	0.0	2,879.9	103,400.0	297.8	0.36	0.2	0.6
07/18/2020 03:00	2,879.1	0.0	2,879.1	103,400.0	297.7	0.36	0.2	0.6
07/18/2020 04:00	2,878.0	0.0	2,878.0	103,400.0	297.6	0.36	0.2	0.6
07/18/2020 05:00	2,878.3	0.0	2,878.3	103,400.0	297.6	0.36	0.2	0.6
07/18/2020 06:00	2,880.2	0.0	2,880.2	103,400.0	297.8	0.36	0.2	0.6
07/18/2020 07:00	2,899.5	0.0	2,899.5	103,400.0	299.8	0.36	0.2	0.6
07/18/2020 08:00	3,142.8	0.0	3,142.8	103,400.0	325.0	0.39	0.2	0.7
07/18/2020 09:00	3,454.5	0.0	3,454.5	103,400.0	357.2	0.43	0.2	0.7
07/18/2020 10:00	4,065.6	0.0	4,065.6	103,400.0	420.4	0.50	0.3	0.8
07/18/2020 11:00	4,192.7	745.3	4,923.1	103,400.0	509.0	0.61	0.3	1.0
07/18/2020 12:00	3,970.9	0.8	3,970.9	103,400.0	410.6	0.49	0.2	0.8
07/18/2020 13:00	4,149.1	745.2	4,894.3	103,400.0	506.1	0.61	0.3	1.0
07/18/2020 14:00	4,145.3	1,931.3	6,076.6	103,400.0	628.3	0.75	0.4	1.3
07/18/2020 15:00	4,117.0	2,000.7	6,117.7	103,400.0	632.6	0.76	0.4	1.3
07/18/2020 16:00	4,117.6	1,824.8	5,942.4	103,400.0	614.4	0.74	0.4	1.2
07/18/2020 17:00	4,118.0	1,787.0	5,905.0	103,400.0	610.6	0.73	0.4	1.2
07/18/2020 18:00	4,116.0	1,803.7	5,919.7	103,400.0	612.1	0.74	0.4	1.2
07/18/2020 19:00	4,149.1	1,147.4	5,296.5	103,400.0	547.7	0.66	0.3	1.1
07/18/2020 20:00	4,147.9	45.4	4,154.7	103,400.0	429.6	0.52	0.3	0.9
07/18/2020 21:00	3,994.7	16.4	3,995.8	103,400.0	413.2	0.50	0.2	0.8
07/18/2020 22:00	4,166.4	612.3	4,748.1	103,400.0	491.0	0.59	0.3	1.0
07/18/2020 23:00	2,933.7	0.0	2,933.7	103,400.0	303.3	0.37	0.2	0.6
Average/Sum#:	3,584.8	527.5	4,108.2	103,400.0	424.8	0.51	0.3	0.9
Minimum:	2,878.0	0.0	2,878.0	103,400.0	297.6	0.36	0.2	0.6
Maximum:	4,192.7	2,000.7	6,117.7	103,400.0	632.6	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:11 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2020 00:00	2,878.5	0.0	2,878.5	103,400.0	297.6	0.36	0.2	0.6
07/19/2020 01:00	2,879.2	0.0	2,879.2	103,400.0	297.7	0.36	0.2	0.6
07/19/2020 02:00	2,876.2	0.0	2,876.2	103,400.0	297.4	0.36	0.2	0.6
07/19/2020 03:00	2,876.7	0.0	2,876.7	103,400.0	297.5	0.36	0.2	0.6
07/19/2020 04:00	2,874.7	0.0	2,874.7	103,400.0	297.2	0.36	0.2	0.6
07/19/2020 05:00	2,876.0	0.0	2,876.0	103,400.0	297.4	0.36	0.2	0.6
07/19/2020 06:00	2,882.2	0.0	2,882.2	103,400.0	298.0	0.36	0.2	0.6
07/19/2020 07:00	2,888.9	0.0	2,888.9	103,400.0	298.7	0.36	0.2	0.6
07/19/2020 08:00	2,905.3	0.0	2,905.3	103,400.0	300.4	0.36	0.2	0.6
07/19/2020 09:00	3,273.0	0.0	3,273.0	103,400.0	338.4	0.40	0.2	0.7
07/19/2020 10:00	3,831.2	2.2	3,831.2	103,400.0	396.1	0.47	0.2	0.8
07/19/2020 11:00	4,178.4	491.0	4,669.4	103,400.0	482.8	0.58	0.3	1.0
07/19/2020 12:00	4,141.0	993.6	5,134.6	103,400.0	530.9	0.64	0.3	1.1
07/19/2020 13:00	4,116.1	1,186.0	5,302.1	103,400.0	548.2	0.66	0.3	1.1
07/19/2020 14:00	4,102.7	1,959.7	6,062.4	103,400.0	626.9	0.75	0.4	1.3
07/19/2020 15:00	4,100.4	1,965.7	6,066.1	103,400.0	627.2	0.75	0.4	1.3
07/19/2020 16:00	4,106.9	1,543.9	5,650.8	103,400.0	584.3	0.70	0.4	1.2
07/19/2020 17:00	4,130.5	1,809.8	5,940.3	103,400.0	614.2	0.74	0.4	1.2
07/19/2020 18:00	4,153.7	1,282.9	5,436.6	103,400.0	562.1	0.67	0.3	1.1
07/19/2020 19:00	4,158.1	180.8	4,338.9	103,400.0	448.6	0.54	0.3	0.9
07/19/2020 20:00	4,013.5	5.4	4,013.8	103,400.0	415.0	0.50	0.2	0.8
07/19/2020 21:00	3,481.7	0.0	3,481.7	103,400.0	360.0	0.43	0.2	0.7
07/19/2020 22:00	2,974.4	0.0	2,974.4	103,400.0	307.6	0.37	0.2	0.6
07/19/2020 23:00	3,353.4	0.0	3,353.4	103,400.0	346.7	0.42	0.2	0.7
Average/Sum#:	3,502.2	475.9	3,977.8	103,400.0	411.3	0.49	0.3	0.8
Minimum:	2,874.7	0.0	2,874.7	103,400.0	297.2	0.36	0.2	0.6
Maximum:	4,178.4	1,965.7	6,066.1	103,400.0	627.2	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2020 00:00	2,940.1	0.0	2,940.1	103,400.0	304.0	0.36	0.2	0.6
07/20/2020 01:00	2,879.0	0.0	2,879.0	103,400.0	297.7	0.36	0.2	0.6
07/20/2020 02:00	2,883.1	0.0	2,883.1	103,400.0	298.1	0.36	0.2	0.6
07/20/2020 03:00	2,936.7	0.0	2,936.7	103,400.0	303.7	0.36	0.2	0.6
07/20/2020 04:00	2,951.5	0.0	2,951.5	103,400.0	305.2	0.37	0.2	0.6
07/20/2020 05:00	2,880.7	0.0	2,880.7	103,400.0	297.9	0.36	0.2	0.6
07/20/2020 06:00	2,883.2	0.0	2,883.2	103,400.0	298.1	0.36	0.2	0.6
07/20/2020 07:00	2,888.4	0.0	2,888.4	103,400.0	298.7	0.36	0.2	0.6
07/20/2020 08:00	2,895.3	0.0	2,895.3	103,400.0	299.4	0.36	0.2	0.6
07/20/2020 09:00	3,404.0	0.0	3,404.0	103,400.0	352.0	0.42	0.2	0.7
07/20/2020 10:00	4,136.2	0.0	4,136.2	103,400.0	427.7	0.51	0.3	0.9
07/20/2020 11:00	4,207.3	0.0	4,207.3	103,400.0	435.0	0.52	0.3	0.9
07/20/2020 12:00	4,199.8	15.3	4,200.9	103,400.0	434.4	0.52	0.3	0.9
07/20/2020 13:00	4,182.3	901.6	5,083.9	103,400.0	525.7	0.63	0.3	1.1
07/20/2020 14:00	4,158.4	1,493.0	5,651.4	103,400.0	584.4	0.70	0.4	1.2
07/20/2020 15:00	4,134.3	1,659.7	5,794.0	103,400.0	599.1	0.72	0.4	1.2
07/20/2020 16:00	4,134.2	1,657.1	5,791.3	103,400.0	598.8	0.72	0.4	1.2
07/20/2020 17:00	4,148.6	1,500.0	5,648.6	103,400.0	584.1	0.70	0.4	1.2
07/20/2020 18:00	4,147.5	779.6	4,927.1	103,400.0	509.5	0.61	0.3	1.0
07/20/2020 19:00	4,182.2	611.3	4,793.5	103,400.0	495.6	0.59	0.3	1.0
07/20/2020 20:00	4,001.4	193.9	4,073.1	103,400.0	421.2	0.52	0.3	0.9
07/20/2020 21:00	3,083.7	0.0	3,083.7	103,400.0	318.9	0.38	0.2	0.6
07/20/2020 22:00	2,889.0	0.0	2,889.0	103,400.0	298.7	0.36	0.2	0.6
07/20/2020 23:00	3,214.3	0.0	3,214.3	103,400.0	332.4	0.40	0.2	0.7
Average/Sum#:	3,515.1	367.1	3,876.5	103,400.0	400.8	0.48	0.3	0.8
Minimum:	2,879.0	0.0	2,879.0	103,400.0	297.7	0.36	0.2	0.6
Maximum:	4,207.3	1,659.7	5,794.0	103,400.0	599.1	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2020 00:00	2,928.8	0.0	2,928.8	103,400.0	302.8	0.37	0.2	0.6
07/21/2020 01:00	2,890.0	0.0	2,890.0	103,400.0	298.8	0.36	0.2	0.6
07/21/2020 02:00	2,881.9	0.0	2,881.9	103,400.0	298.0	0.36	0.2	0.6
07/21/2020 03:00	2,915.0	0.0	2,915.0	103,400.0	301.4	0.36	0.2	0.6
07/21/2020 04:00	3,045.2	0.0	3,045.2	103,400.0	314.9	0.39	0.2	0.6
07/21/2020 05:00	1,013.8	0.0	1,013.8	103,400.0	104.8	0.00	0.0	0.0
07/21/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/21/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,612.5	0.0	2,612.5	103,400.0	270.1	0.37	0.2	0.6
Minimum:	1,013.8	0.0	1,013.8	103,400.0	104.8	0.36	0.2	0.6
Maximum:	3,045.2	0.0	3,045.2	103,400.0	314.9	0.39	0.2	0.6
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/22/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/23/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/24/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/25/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.00	0.0	0.0
07/26/2020 01:00	1,605.5	0.0	1,605.5	103,400.0	166.0	0.00	0.0	0.0
07/26/2020 02:00	3,386.2	0.0	3,386.2	103,400.0	350.1	0.39	0.2	0.6
07/26/2020 03:00	2,893.6	0.0	2,893.6	103,400.0	299.2	0.36	0.2	0.6
07/26/2020 04:00	2,873.7	0.0	2,873.7	103,400.0	297.1	0.36	0.2	0.6
07/26/2020 05:00	2,889.2	0.0	2,889.2	103,400.0	298.7	0.36	0.2	0.6
07/26/2020 06:00	2,970.9	0.0	2,970.9	103,400.0	307.2	0.37	0.2	0.6
07/26/2020 07:00	2,913.3	0.0	2,913.3	103,400.0	301.2	0.36	0.2	0.6
07/26/2020 08:00	2,888.9	0.0	2,888.9	103,400.0	298.7	0.36	0.2	0.6
07/26/2020 09:00	2,888.7	0.0	2,888.7	103,400.0	298.7	0.36	0.2	0.6
07/26/2020 10:00	2,895.0	0.0	2,895.0	103,400.0	299.3	0.36	0.2	0.6
07/26/2020 11:00	2,977.9	0.0	2,977.9	103,400.0	307.9	0.37	0.2	0.6
07/26/2020 12:00	4,109.1	222.4	4,293.7	103,400.0	444.0	0.54	0.3	0.9
07/26/2020 13:00	4,126.7	539.6	4,666.3	103,400.0	482.5	0.58	0.3	1.0
07/26/2020 14:00	4,123.8	889.8	5,013.6	103,400.0	518.4	0.62	0.3	1.0
07/26/2020 15:00	4,100.0	1,958.7	6,058.7	103,400.0	626.5	0.75	0.4	1.3
07/26/2020 16:00	4,093.1	1,968.6	6,061.7	103,400.0	626.8	0.75	0.4	1.3
07/26/2020 17:00	4,083.1	1,968.8	6,051.9	103,400.0	625.8	0.75	0.4	1.3
07/26/2020 18:00	4,104.8	1,957.8	6,062.6	103,400.0	626.9	0.75	0.4	1.3
07/26/2020 19:00	4,138.2	1,791.2	5,929.4	103,400.0	613.1	0.73	0.4	1.2
07/26/2020 20:00	4,161.5	1,294.2	5,455.7	103,400.0	564.1	0.68	0.3	1.1
07/26/2020 21:00	3,535.8	0.0	3,535.8	103,400.0	365.6	0.44	0.2	0.7
07/26/2020 22:00	3,706.5	0.0	3,706.5	103,400.0	383.3	0.46	0.2	0.8
07/26/2020 23:00	3,690.7	0.0	3,690.7	103,400.0	381.6	0.46	0.2	0.8
Average/Sum#:	3,441.6	547.4	3,987.4	103,400.0	412.3	0.51	0.3	0.9
Minimum:	1,605.5	0.0	1,605.5	103,400.0	166.0	0.36	0.2	0.6
Maximum:	4,161.5	1,968.8	6,062.6	103,400.0	626.9	0.75	0.4	1.3
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2020 00:00	3,219.7	0.0	3,219.7	103,400.0	332.9	0.40	0.2	0.7
07/27/2020 01:00	2,950.1	0.0	2,950.1	103,400.0	305.0	0.37	0.2	0.6
07/27/2020 02:00	3,225.9	0.0	3,225.9	103,400.0	333.6	0.40	0.2	0.7
07/27/2020 03:00	3,172.4	0.0	3,172.4	103,400.0	328.0	0.39	0.2	0.7
07/27/2020 04:00	2,900.7	0.0	2,900.7	103,400.0	299.9	0.36	0.2	0.6
07/27/2020 05:00	2,965.8	0.0	2,965.8	103,400.0	306.7	0.37	0.2	0.6
07/27/2020 06:00	2,917.3	0.0	2,917.3	103,400.0	301.6	0.36	0.2	0.6
07/27/2020 07:00	2,887.1	0.0	2,887.1	103,400.0	298.5	0.36	0.2	0.6
07/27/2020 08:00	2,902.3	0.0	2,902.3	103,400.0	300.1	0.36	0.2	0.6
07/27/2020 09:00	3,274.3	0.0	3,274.3	103,400.0	338.6	0.40	0.2	0.7
07/27/2020 10:00	4,137.5	236.4	4,333.7	103,400.0	448.1	0.54	0.3	0.9
07/27/2020 11:00	4,157.6	856.6	5,014.2	103,400.0	518.5	0.62	0.3	1.0
07/27/2020 12:00	4,139.4	1,512.2	5,651.6	103,400.0	584.4	0.70	0.4	1.2
07/27/2020 13:00	4,108.5	983.1	5,091.6	103,400.0	526.5	0.63	0.3	1.1
07/27/2020 14:00	4,083.6	1,942.9	6,026.5	103,400.0	623.1	0.75	0.4	1.2
07/27/2020 15:00	4,068.4	1,971.1	6,039.5	103,400.0	624.5	0.75	0.4	1.3
07/27/2020 16:00	4,066.9	1,962.4	6,029.3	103,400.0	623.4	0.75	0.4	1.2
07/27/2020 17:00	4,078.1	1,974.1	6,052.2	103,400.0	625.8	0.75	0.4	1.3
07/27/2020 18:00	4,091.7	1,918.7	6,010.4	103,400.0	621.5	0.74	0.4	1.2
07/27/2020 19:00	4,120.4	1,388.5	5,508.9	103,400.0	569.6	0.68	0.3	1.1
07/27/2020 20:00	4,129.8	1,065.5	5,142.0	103,400.0	531.7	0.64	0.3	1.1
07/27/2020 21:00	3,130.7	0.0	3,130.7	103,400.0	323.7	0.39	0.2	0.6
07/27/2020 22:00	3,237.7	0.0	3,237.7	103,400.0	334.8	0.40	0.2	0.7
07/27/2020 23:00	3,276.6	0.0	3,276.6	103,400.0	338.8	0.41	0.2	0.7
Average/Sum#:	3,551.8	658.8	4,206.7	103,400.0	435.0	0.52	0.3	0.9
Minimum:	2,887.1	0.0	2,887.1	103,400.0	298.5	0.36	0.2	0.6
Maximum:	4,157.6	1,974.1	6,052.2	103,400.0	625.8	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2020 00:00	2,875.1	0.0	2,875.1	103,400.0	297.3	0.36	0.2	0.6
07/28/2020 01:00	2,869.3	0.0	2,869.3	103,400.0	296.7	0.36	0.2	0.6
07/28/2020 02:00	2,871.3	0.0	2,871.3	103,400.0	296.9	0.36	0.2	0.6
07/28/2020 03:00	2,870.4	0.0	2,870.4	103,400.0	296.8	0.36	0.2	0.6
07/28/2020 04:00	2,871.8	0.0	2,871.8	103,400.0	296.9	0.36	0.2	0.6
07/28/2020 05:00	2,870.3	0.0	2,870.3	103,400.0	296.8	0.36	0.2	0.6
07/28/2020 06:00	2,877.6	0.0	2,877.6	103,400.0	297.5	0.36	0.2	0.6
07/28/2020 07:00	2,974.7	0.0	2,974.7	103,400.0	307.6	0.37	0.2	0.6
07/28/2020 08:00	3,199.6	0.0	3,199.6	103,400.0	330.8	0.40	0.2	0.7
07/28/2020 09:00	4,138.5	30.9	4,141.6	103,400.0	428.2	0.52	0.3	0.9
07/28/2020 10:00	4,178.7	1,019.9	5,198.6	103,400.0	537.5	0.65	0.3	1.1
07/28/2020 11:00	4,159.7	1,320.0	5,479.7	103,400.0	566.6	0.68	0.3	1.1
07/28/2020 12:00	4,127.0	1,401.7	5,528.7	103,400.0	571.7	0.69	0.3	1.1
07/28/2020 13:00	4,102.3	1,955.0	6,057.3	103,400.0	626.3	0.75	0.4	1.3
07/28/2020 14:00	4,081.8	1,748.0	5,829.8	103,400.0	602.8	0.72	0.4	1.2
07/28/2020 15:00	4,068.3	1,615.2	5,683.5	103,400.0	587.7	0.71	0.4	1.2
07/28/2020 16:00	4,065.9	1,490.6	5,556.5	103,400.0	574.5	0.69	0.3	1.1
07/28/2020 17:00	4,072.1	1,444.1	5,516.2	103,400.0	570.4	0.69	0.3	1.1
07/28/2020 18:00	4,094.0	689.7	4,783.7	103,400.0	494.6	0.60	0.3	1.0
07/28/2020 19:00	4,107.9	613.6	4,721.5	103,400.0	488.2	0.59	0.3	1.0
07/28/2020 20:00	4,121.9	836.2	4,958.1	103,400.0	512.7	0.61	0.3	1.0
07/28/2020 21:00	3,444.0	6.2	3,444.2	103,400.0	356.1	0.43	0.2	0.7
07/28/2020 22:00	2,960.9	0.0	2,960.9	103,400.0	306.2	0.37	0.2	0.6
07/28/2020 23:00	3,236.9	0.0	3,236.9	103,400.0	334.7	0.40	0.2	0.7
Average/Sum#:	3,551.7	590.5	4,140.7	103,400.0	428.1	0.52	0.3	0.9
Minimum:	2,869.3	0.0	2,869.3	103,400.0	296.7	0.36	0.2	0.6
Maximum:	4,178.7	1,955.0	6,057.3	103,400.0	626.3	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2020 00:00	2,876.6	0.0	2,876.6	103,400.0	297.4	0.36	0.2	0.6
07/29/2020 01:00	2,870.0	0.0	2,870.0	103,400.0	296.8	0.36	0.2	0.6
07/29/2020 02:00	2,865.6	0.0	2,865.6	103,400.0	296.3	0.36	0.2	0.6
07/29/2020 03:00	2,868.6	0.0	2,868.6	103,400.0	296.6	0.36	0.2	0.6
07/29/2020 04:00	2,866.5	0.0	2,866.5	103,400.0	296.4	0.36	0.2	0.6
07/29/2020 05:00	2,868.5	0.0	2,868.5	103,400.0	296.6	0.36	0.2	0.6
07/29/2020 06:00	2,877.5	0.0	2,877.5	103,400.0	297.5	0.36	0.2	0.6
07/29/2020 07:00	2,884.8	0.0	2,884.8	103,400.0	298.3	0.36	0.2	0.6
07/29/2020 08:00	2,951.0	0.0	2,951.0	103,400.0	305.1	0.37	0.2	0.6
07/29/2020 09:00	3,093.1	0.0	3,093.1	103,400.0	319.8	0.38	0.2	0.6
07/29/2020 10:00	4,015.5	65.7	4,025.4	103,400.0	416.2	0.51	0.3	0.8
07/29/2020 11:00	4,174.9	566.8	4,741.7	103,400.0	490.3	0.59	0.3	1.0
07/29/2020 12:00	4,151.0	1,565.5	5,716.5	103,400.0	591.1	0.71	0.4	1.2
07/29/2020 13:00	4,151.5	1,884.0	6,035.5	103,400.0	624.1	0.75	0.4	1.2
07/29/2020 14:00	4,134.9	1,905.2	6,040.1	103,400.0	624.5	0.75	0.4	1.2
07/29/2020 15:00	4,116.8	1,911.1	6,027.9	103,400.0	623.3	0.75	0.4	1.2
07/29/2020 16:00	4,118.8	1,917.0	6,035.8	103,400.0	624.1	0.75	0.4	1.2
07/29/2020 17:00	4,127.2	1,894.3	6,021.5	103,400.0	622.6	0.75	0.4	1.2
07/29/2020 18:00	4,135.5	1,827.2	5,962.7	103,400.0	616.5	0.74	0.4	1.2
07/29/2020 19:00	4,147.4	293.3	4,440.7	103,400.0	459.2	0.55	0.3	0.9
07/29/2020 20:00	4,153.5	1,094.1	5,247.6	103,400.0	542.6	0.65	0.3	1.1
07/29/2020 21:00	3,369.4	0.0	3,369.4	103,400.0	348.4	0.42	0.2	0.7
07/29/2020 22:00	3,458.8	0.0	3,458.8	103,400.0	357.6	0.43	0.2	0.7
07/29/2020 23:00	3,011.0	0.0	3,011.0	103,400.0	311.3	0.37	0.2	0.6
Average/Sum#:	3,512.0	621.8	4,131.5	103,400.0	427.2	0.51	0.3	0.8
Minimum:	2,865.6	0.0	2,865.6	103,400.0	296.3	0.36	0.2	0.6
Maximum:	4,174.9	1,917.0	6,040.1	103,400.0	624.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2020 00:00	2,871.4	0.0	2,871.4	103,400.0	296.9	0.36	0.2	0.6
07/30/2020 01:00	2,873.7	0.0	2,873.7	103,400.0	297.1	0.36	0.2	0.6
07/30/2020 02:00	2,875.3	0.0	2,875.3	103,400.0	297.3	0.36	0.2	0.6
07/30/2020 03:00	2,876.4	0.0	2,876.4	103,400.0	297.4	0.36	0.2	0.6
07/30/2020 04:00	2,875.7	0.0	2,875.7	103,400.0	297.3	0.36	0.2	0.6
07/30/2020 05:00	2,878.9	0.0	2,878.9	103,400.0	297.7	0.36	0.2	0.6
07/30/2020 06:00	2,886.0	0.0	2,886.0	103,400.0	298.4	0.36	0.2	0.6
07/30/2020 07:00	2,889.8	0.0	2,889.8	103,400.0	298.8	0.36	0.2	0.6
07/30/2020 08:00	2,880.8	0.0	2,880.8	103,400.0	297.9	0.36	0.2	0.6
07/30/2020 09:00	3,007.0	0.0	3,007.0	103,400.0	310.9	0.38	0.2	0.6
07/30/2020 10:00	3,652.5	0.0	3,652.5	103,400.0	377.7	0.45	0.2	0.8
07/30/2020 11:00	4,185.9	909.4	5,022.5	103,400.0	519.3	0.63	0.3	1.1
07/30/2020 12:00	4,187.1	625.6	4,812.7	103,400.0	497.6	0.60	0.3	1.0
07/30/2020 13:00	4,171.9	1,061.3	5,233.2	103,400.0	541.1	0.65	0.3	1.1
07/30/2020 14:00	4,168.3	1,526.5	5,694.8	103,400.0	588.8	0.71	0.4	1.2
07/30/2020 15:00	4,147.5	1,642.0	5,789.5	103,400.0	598.6	0.72	0.4	1.2
07/30/2020 16:00	4,135.0	1,894.7	6,029.7	103,400.0	623.5	0.75	0.4	1.2
07/30/2020 17:00	4,138.4	1,885.3	6,023.7	103,400.0	622.9	0.75	0.4	1.2
07/30/2020 18:00	4,148.9	1,570.7	5,719.6	103,400.0	591.4	0.71	0.4	1.2
07/30/2020 19:00	4,164.5	1,108.3	5,272.8	103,400.0	545.2	0.65	0.3	1.1
07/30/2020 20:00	4,200.3	941.1	5,141.4	103,400.0	531.6	0.64	0.3	1.1
07/30/2020 21:00	3,999.3	0.0	3,999.3	103,400.0	413.5	0.50	0.2	0.8
07/30/2020 22:00	3,779.0	0.0	3,779.0	103,400.0	390.7	0.47	0.2	0.8
07/30/2020 23:00	3,034.1	0.0	3,034.1	103,400.0	313.7	0.37	0.2	0.6
Average/Sum#:	3,542.8	548.5	4,088.3	103,400.0	422.7	0.51	0.3	0.9
Minimum:	2,871.4	0.0	2,871.4	103,400.0	296.9	0.36	0.2	0.6
Maximum:	4,200.3	1,894.7	6,029.7	103,400.0	623.5	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2020 00:00	2,872.8	0.0	2,872.8	103,400.0	297.0	0.36	0.2	0.6
07/31/2020 01:00	2,877.1	0.0	2,877.1	103,400.0	297.5	0.36	0.2	0.6
07/31/2020 02:00	2,876.1	0.0	2,876.1	103,400.0	297.4	0.36	0.2	0.6
07/31/2020 03:00	2,872.7	0.0	2,872.7	103,400.0	297.0	0.36	0.2	0.6
07/31/2020 04:00	2,874.1	0.0	2,874.1	103,400.0	297.2	0.36	0.2	0.6
07/31/2020 05:00	2,874.7	0.0	2,874.7	103,400.0	297.2	0.36	0.2	0.6
07/31/2020 06:00	2,884.9	0.0	2,884.9	103,400.0	298.3	0.36	0.2	0.6
07/31/2020 07:00	2,889.3	0.0	2,889.3	103,400.0	298.8	0.36	0.2	0.6
07/31/2020 08:00	2,880.3	0.0	2,880.3	103,400.0	297.8	0.36	0.2	0.6
07/31/2020 09:00	3,005.4	0.0	3,005.4	103,400.0	310.8	0.37	0.2	0.6
07/31/2020 10:00	3,553.2	0.0	3,553.2	103,400.0	367.4	0.44	0.2	0.7
07/31/2020 11:00	4,205.5	1,207.5	5,388.9	103,400.0	557.2	0.67	0.3	1.1
07/31/2020 12:00	4,190.7	790.0	4,980.7	103,400.0	515.0	0.62	0.3	1.0
07/31/2020 13:00	4,179.7	1,181.9	5,361.6	103,400.0	554.4	0.67	0.3	1.1
07/31/2020 14:00	4,171.2	1,884.7	6,055.9	103,400.0	626.2	0.75	0.4	1.3
07/31/2020 15:00	4,154.2	1,143.1	5,297.3	103,400.0	547.7	0.66	0.3	1.1
07/31/2020 16:00	4,164.8	1,052.4	5,217.2	103,400.0	539.5	0.65	0.3	1.1
07/31/2020 17:00	4,157.9	1,511.8	5,669.7	103,400.0	586.2	0.70	0.4	1.2
07/31/2020 18:00	4,157.6	1,333.0	5,490.6	103,400.0	567.7	0.68	0.3	1.1
07/31/2020 19:00	4,167.7	1,256.2	5,423.9	103,400.0	560.8	0.68	0.3	1.1
07/31/2020 20:00	4,168.0	632.7	4,737.4	103,400.0	489.8	0.60	0.3	1.0
07/31/2020 21:00	3,531.1	0.0	3,531.1	103,400.0	365.1	0.44	0.2	0.7
07/31/2020 22:00	3,425.1	0.0	3,425.1	103,400.0	354.2	0.42	0.2	0.7
07/31/2020 23:00	2,922.2	0.0	2,922.2	103,400.0	302.2	0.37	0.2	0.6
Average/Sum#:	3,502.3	499.7	3,998.4	103,400.0	413.4	0.50	0.3	0.8
Minimum:	2,872.7	0.0	2,872.7	103,400.0	297.0	0.36	0.2	0.6
Maximum:	4,205.5	1,884.7	6,055.9	103,400.0	626.2	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2020 00:00	2,872.6	0.0	2,872.6	103,400.0	297.0	0.36	0.2	0.6
08/01/2020 01:00	2,872.4	0.0	2,872.4	103,400.0	297.0	0.36	0.2	0.6
08/01/2020 02:00	2,869.7	0.0	2,869.7	103,400.0	296.7	0.36	0.2	0.6
08/01/2020 03:00	2,870.4	0.0	2,870.4	103,400.0	296.8	0.36	0.2	0.6
08/01/2020 04:00	2,868.2	0.0	2,868.2	103,400.0	296.6	0.36	0.2	0.6
08/01/2020 05:00	2,873.0	0.0	2,873.0	103,400.0	297.1	0.36	0.2	0.6
08/01/2020 06:00	2,879.0	0.0	2,879.0	103,400.0	297.7	0.36	0.2	0.6
08/01/2020 07:00	2,887.3	0.0	2,887.3	103,400.0	298.5	0.36	0.2	0.6
08/01/2020 08:00	2,889.2	0.0	2,889.2	103,400.0	298.7	0.36	0.2	0.6
08/01/2020 09:00	3,170.8	0.0	3,170.8	103,400.0	327.9	0.39	0.2	0.7
08/01/2020 10:00	3,429.0	0.0	3,429.0	103,400.0	354.6	0.42	0.2	0.7
08/01/2020 11:00	3,454.8	0.0	3,454.8	103,400.0	357.2	0.43	0.2	0.7
08/01/2020 12:00	3,590.1	0.0	3,590.1	103,400.0	371.2	0.44	0.2	0.7
08/01/2020 13:00	3,812.5	0.0	3,812.5	103,400.0	394.2	0.47	0.2	0.8
08/01/2020 14:00	3,689.0	8.7	3,689.4	103,400.0	381.5	0.46	0.2	0.8
08/01/2020 15:00	4,136.5	1,896.8	6,033.3	103,400.0	623.8	0.75	0.4	1.2
08/01/2020 16:00	4,151.9	1,837.5	5,989.4	103,400.0	619.3	0.74	0.4	1.2
08/01/2020 17:00	4,161.9	1,795.9	5,957.8	103,400.0	616.0	0.74	0.4	1.2
08/01/2020 18:00	4,145.0	1,558.6	5,703.6	103,400.0	589.8	0.71	0.4	1.2
08/01/2020 19:00	4,157.1	1,253.8	5,410.9	103,400.0	559.5	0.67	0.3	1.1
08/01/2020 20:00	4,152.5	486.1	4,638.6	103,400.0	479.6	0.58	0.3	1.0
08/01/2020 21:00	4,136.3	190.0	4,311.1	103,400.0	445.8	0.54	0.3	0.9
08/01/2020 22:00	3,558.3	0.0	3,558.3	103,400.0	367.9	0.44	0.2	0.7
08/01/2020 23:00	3,172.4	0.0	3,172.4	103,400.0	328.0	0.39	0.2	0.7
Average/Sum#:	3,450.0	376.1	3,825.2	103,400.0	395.5	0.48	0.2	0.8
Minimum:	2,868.2	0.0	2,868.2	103,400.0	296.6	0.36	0.2	0.6
Maximum:	4,161.9	1,896.8	6,033.3	103,400.0	623.8	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2020 00:00	2,863.5	0.0	2,863.5	103,400.0	296.1	0.35	0.2	0.6
08/02/2020 01:00	2,857.3	0.0	2,857.3	103,400.0	295.4	0.35	0.2	0.6
08/02/2020 02:00	2,856.9	0.0	2,856.9	103,400.0	295.4	0.35	0.2	0.6
08/02/2020 03:00	2,857.2	0.0	2,857.2	103,400.0	295.4	0.35	0.2	0.6
08/02/2020 04:00	2,865.8	0.0	2,865.8	103,400.0	296.3	0.35	0.2	0.6
08/02/2020 05:00	3,062.2	0.0	3,062.2	103,400.0	316.6	0.38	0.2	0.6
08/02/2020 06:00	3,025.5	0.0	3,025.5	103,400.0	312.8	0.38	0.2	0.6
08/02/2020 07:00	2,966.7	0.0	2,966.7	103,400.0	306.8	0.37	0.2	0.6
08/02/2020 08:00	2,861.8	0.0	2,861.8	103,400.0	295.9	0.36	0.2	0.6
08/02/2020 09:00	2,864.1	0.0	2,864.1	103,400.0	296.1	0.36	0.2	0.6
08/02/2020 10:00	2,865.8	0.0	2,865.8	103,400.0	296.3	0.36	0.2	0.6
08/02/2020 11:00	3,432.6	0.0	3,432.6	103,400.0	354.9	0.43	0.2	0.7
08/02/2020 12:00	3,794.2	14.9	3,794.9	103,400.0	392.4	0.47	0.2	0.8
08/02/2020 13:00	4,120.2	1,255.9	5,376.1	103,400.0	555.9	0.67	0.3	1.1
08/02/2020 14:00	4,108.1	1,243.8	5,351.9	103,400.0	553.4	0.66	0.3	1.1
08/02/2020 15:00	4,100.6	1,900.8	6,001.4	103,400.0	620.5	0.74	0.4	1.2
08/02/2020 16:00	4,089.5	1,415.1	5,504.6	103,400.0	569.2	0.68	0.3	1.1
08/02/2020 17:00	4,091.8	1,754.8	5,846.6	103,400.0	604.5	0.73	0.4	1.2
08/02/2020 18:00	4,113.0	1,295.5	5,408.5	103,400.0	559.2	0.67	0.3	1.1
08/02/2020 19:00	4,120.7	1,189.6	5,310.3	103,400.0	549.1	0.66	0.3	1.1
08/02/2020 20:00	4,137.4	878.8	5,016.2	103,400.0	518.7	0.62	0.3	1.0
08/02/2020 21:00	3,858.7	1.2	3,858.7	103,400.0	399.0	0.48	0.2	0.8
08/02/2020 22:00	3,152.8	0.0	3,152.8	103,400.0	326.0	0.39	0.2	0.7
08/02/2020 23:00	3,512.0	0.0	3,512.0	103,400.0	363.1	0.44	0.2	0.7
Average/Sum#:	3,440.8	456.3	3,896.4	103,400.0	402.9	0.48	0.2	0.8
Minimum:	2,856.9	0.0	2,856.9	103,400.0	295.4	0.35	0.2	0.6
Maximum:	4,137.4	1,900.8	6,001.4	103,400.0	620.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2020 00:00	2,886.7	0.0	2,886.7	103,400.0	298.5	0.36	0.2	0.6
08/03/2020 01:00	2,863.5	0.0	2,863.5	103,400.0	296.1	0.36	0.2	0.6
08/03/2020 02:00	2,863.8	0.0	2,863.8	103,400.0	296.1	0.36	0.2	0.6
08/03/2020 03:00	2,862.6	0.0	2,862.6	103,400.0	296.0	0.36	0.2	0.6
08/03/2020 04:00	2,859.7	0.0	2,859.7	103,400.0	295.7	0.35	0.2	0.6
08/03/2020 05:00	2,867.7	0.0	2,867.7	103,400.0	296.5	0.36	0.2	0.6
08/03/2020 06:00	2,875.7	0.0	2,875.7	103,400.0	297.3	0.36	0.2	0.6
08/03/2020 07:00	2,891.3	0.0	2,891.3	103,300.0	298.7	0.36	0.2	0.6
08/03/2020 08:00	2,963.9	0.0	2,963.9	103,300.0	306.2	0.37	0.2	0.6
08/03/2020 09:00	2,888.5	0.0	2,888.5	103,300.0	298.4	0.36	0.2	0.6
08/03/2020 10:00	3,880.4	0.0	3,880.4	103,300.0	400.8	0.48	0.2	0.8
08/03/2020 11:00	4,175.8	11.7	4,176.4	103,300.0	431.4	0.52	0.3	0.9
08/03/2020 12:00	4,170.6	768.9	4,939.5	103,300.0	510.3	0.61	0.3	1.0
08/03/2020 13:00	4,164.3	904.9	5,069.2	103,300.0	523.6	0.63	0.3	1.0
08/03/2020 14:00	4,143.7	1,825.2	5,968.9	103,300.0	616.6	0.74	0.4	1.2
08/03/2020 15:00	4,120.7	1,675.2	5,795.9	103,300.0	598.7	0.72	0.4	1.2
08/03/2020 16:00	4,107.8	1,652.3	5,760.1	103,300.0	595.0	0.71	0.4	1.2
08/03/2020 17:00	4,098.3	1,697.9	5,796.2	103,300.0	598.7	0.72	0.4	1.2
08/03/2020 18:00	4,119.8	1,924.7	6,044.5	103,300.0	624.4	0.75	0.4	1.2
08/03/2020 19:00	4,143.4	970.5	5,084.8	103,300.0	525.3	0.63	0.3	1.1
08/03/2020 20:00	3,533.9	0.0	3,533.9	103,300.0	365.1	0.44	0.2	0.7
08/03/2020 21:00	3,709.7	0.0	3,709.7	103,300.0	383.2	0.46	0.2	0.8
08/03/2020 22:00	3,010.0	0.0	3,010.0	103,300.0	310.9	0.38	0.2	0.6
08/03/2020 23:00	3,207.9	0.0	3,207.9	103,300.0	331.4	0.40	0.2	0.7
Average/Sum#:	3,475.4	476.3	3,950.0	103,329.2	408.1	0.49	0.3	0.8
Minimum:	2,859.7	0.0	2,859.7	103,300.0	295.7	0.35	0.2	0.6
Maximum:	4,175.8	1,924.7	6,044.5	103,400.0	624.4	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2020 00:00	2,869.7	0.0	2,869.7	103,300.0	296.4	0.36	0.2	0.6
08/04/2020 01:00	2,867.9	0.0	2,867.9	103,300.0	296.3	0.36	0.2	0.6
08/04/2020 02:00	2,865.2	0.0	2,865.2	103,300.0	296.0	0.36	0.2	0.6
08/04/2020 03:00	2,863.5	0.0	2,863.5	103,300.0	295.8	0.35	0.2	0.6
08/04/2020 04:00	2,865.0	0.0	2,865.0	103,300.0	296.0	0.36	0.2	0.6
08/04/2020 05:00	2,869.1	0.0	2,869.1	103,300.0	296.4	0.36	0.2	0.6
08/04/2020 06:00	2,873.6	0.0	2,873.6	103,300.0	296.8	0.36	0.2	0.6
08/04/2020 07:00	2,884.2	0.0	2,884.2	103,300.0	297.9	0.36	0.2	0.6
08/04/2020 08:00	3,108.7	0.0	3,108.7	103,300.0	321.1	0.39	0.2	0.6
08/04/2020 09:00	3,436.0	0.0	3,436.0	103,300.0	354.9	0.43	0.2	0.7
08/04/2020 10:00	3,450.0	0.0	3,450.0	103,300.0	356.4	0.43	0.2	0.7
08/04/2020 11:00	4,117.9	50.4	4,127.0	103,300.0	426.3	0.52	0.3	0.9
08/04/2020 12:00	4,162.3	929.2	5,091.5	103,300.0	526.0	0.63	0.3	1.1
08/04/2020 13:00	4,145.9	815.9	4,961.8	103,300.0	512.6	0.62	0.3	1.0
08/04/2020 14:00	4,133.3	1,558.4	5,691.7	103,300.0	588.0	0.71	0.4	1.2
08/04/2020 15:00	4,116.3	1,932.8	6,049.1	103,300.0	624.9	0.75	0.4	1.3
08/04/2020 16:00	4,110.6	1,922.1	6,032.7	103,300.0	623.2	0.75	0.4	1.2
08/04/2020 17:00	4,106.8	1,935.9	6,042.7	103,300.0	624.2	0.75	0.4	1.2
08/04/2020 18:00	4,127.8	1,802.3	5,930.1	103,300.0	612.6	0.74	0.4	1.2
08/04/2020 19:00	4,126.2	217.6	4,295.9	103,300.0	443.8	0.54	0.3	0.9
08/04/2020 20:00	3,663.9	0.0	3,663.9	103,300.0	378.5	0.45	0.2	0.8
08/04/2020 21:00	2,881.2	0.0	2,881.2	103,300.0	297.6	0.36	0.2	0.6
08/04/2020 22:00	2,872.9	0.0	2,872.9	103,300.0	296.8	0.36	0.2	0.6
08/04/2020 23:00	3,076.3	0.0	3,076.3	103,300.0	317.8	0.38	0.2	0.6
Average/Sum#:	3,441.4	465.2	3,902.9	103,300.0	403.2	0.49	0.3	0.8
Minimum:	2,863.5	0.0	2,863.5	103,300.0	295.8	0.35	0.2	0.6
Maximum:	4,162.3	1,935.9	6,049.1	103,300.0	624.9	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2020 00:00	2,865.0	0.0	2,865.0	103,300.0	296.0	0.36	0.2	0.6
08/05/2020 01:00	2,864.3	0.0	2,864.3	103,300.0	295.9	0.36	0.2	0.6
08/05/2020 02:00	2,864.8	0.0	2,864.8	103,300.0	295.9	0.36	0.2	0.6
08/05/2020 03:00	2,863.2	0.0	2,863.2	103,300.0	295.8	0.35	0.2	0.6
08/05/2020 04:00	2,863.6	0.0	2,863.6	103,300.0	295.8	0.35	0.2	0.6
08/05/2020 05:00	2,863.2	0.0	2,863.2	103,300.0	295.8	0.35	0.2	0.6
08/05/2020 06:00	2,869.9	0.0	2,869.9	103,300.0	296.5	0.36	0.2	0.6
08/05/2020 07:00	2,870.0	0.0	2,870.0	103,300.0	296.5	0.36	0.2	0.6
08/05/2020 08:00	2,869.7	0.0	2,869.7	103,300.0	296.4	0.36	0.2	0.6
08/05/2020 09:00	2,897.8	0.0	2,897.8	103,300.0	299.3	0.36	0.2	0.6
08/05/2020 10:00	3,084.0	0.0	3,084.0	103,300.0	318.6	0.39	0.2	0.6
08/05/2020 11:00	4,000.9	29.7	4,004.8	103,300.0	413.7	0.50	0.2	0.8
08/05/2020 12:00	4,199.3	703.8	4,903.1	103,300.0	506.5	0.61	0.3	1.0
08/05/2020 13:00	4,195.0	933.5	5,128.5	103,300.0	529.8	0.63	0.3	1.1
08/05/2020 14:00	4,196.2	1,067.5	5,263.7	103,300.0	543.7	0.65	0.3	1.1
08/05/2020 15:00	4,185.0	1,131.4	5,316.4	103,300.0	549.2	0.66	0.3	1.1
08/05/2020 16:00	4,179.1	1,010.3	5,189.4	103,300.0	536.1	0.64	0.3	1.1
08/05/2020 17:00	4,191.3	548.7	4,740.0	103,300.0	489.6	0.59	0.3	1.0
08/05/2020 18:00	4,190.9	841.5	4,948.3	103,300.0	511.2	0.62	0.3	1.0
08/05/2020 19:00	3,247.3	0.0	3,247.3	103,300.0	335.4	0.40	0.2	0.7
08/05/2020 20:00	3,276.2	0.0	3,276.2	103,300.0	338.4	0.41	0.2	0.7
08/05/2020 21:00	3,119.9	0.0	3,119.9	103,300.0	322.3	0.39	0.2	0.6
08/05/2020 22:00	3,439.4	0.0	3,439.4	103,300.0	355.3	0.43	0.2	0.7
08/05/2020 23:00	1,690.5	0.0	1,690.5	103,300.0	174.6	0.00	0.0	0.0
Average/Sum#:	3,328.6	261.1	3,585.1	103,300.0	370.3	0.46	0.2	0.8
Minimum:	1,690.5	0.0	1,690.5	103,300.0	174.6	0.35	0.2	0.6
Maximum:	4,199.3	1,131.4	5,316.4	103,300.0	549.2	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/06/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/07/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.00	0.0	0.0
08/08/2020 22:00	1,622.9	0.0	1,622.9	103,300.0	167.6	0.00	0.0	0.0
08/08/2020 23:00	3,227.3	0.0	3,227.3	103,300.0	333.4	0.38	0.2	0.6
Average/Sum#:	2,425.1	0.0	2,425.1	103,300.0	250.5	0.38	0.2	0.6
Minimum:	1,622.9	0.0	1,622.9	103,300.0	167.6	0.38	0.2	0.6
Maximum:	3,227.3	0.0	3,227.3	103,300.0	333.4	0.38	0.2	0.6
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2020 00:00	2,867.7	0.0	2,867.7	103,300.0	296.2	0.36	0.2	0.6
08/09/2020 01:00	2,863.9	0.0	2,863.9	103,300.0	295.8	0.36	0.2	0.6
08/09/2020 02:00	2,864.4	0.0	2,864.4	103,300.0	295.9	0.36	0.2	0.6
08/09/2020 03:00	2,864.5	0.0	2,864.5	103,300.0	295.9	0.36	0.2	0.6
08/09/2020 04:00	2,864.3	0.0	2,864.3	103,300.0	295.9	0.36	0.2	0.6
08/09/2020 05:00	2,866.9	0.0	2,866.9	103,300.0	296.2	0.36	0.2	0.6
08/09/2020 06:00	2,866.4	0.0	2,866.4	103,300.0	296.1	0.36	0.2	0.6
08/09/2020 07:00	2,893.3	0.0	2,893.3	103,300.0	298.9	0.36	0.2	0.6
08/09/2020 08:00	3,155.3	0.0	3,155.3	103,300.0	325.9	0.39	0.2	0.7
08/09/2020 09:00	3,932.9	14.5	3,933.6	103,300.0	406.3	0.49	0.2	0.8
08/09/2020 10:00	4,123.7	944.9	5,068.6	103,300.0	523.6	0.63	0.3	1.0
08/09/2020 11:00	4,111.6	1,401.1	5,512.7	103,300.0	569.5	0.68	0.3	1.1
08/09/2020 12:00	4,089.9	1,880.7	5,970.6	103,300.0	616.8	0.74	0.4	1.2
08/09/2020 13:00	4,082.0	1,952.4	6,034.4	103,300.0	623.4	0.75	0.4	1.2
08/09/2020 14:00	4,078.6	1,967.5	6,046.1	103,300.0	624.6	0.75	0.4	1.3
08/09/2020 15:00	4,060.1	1,929.9	5,990.0	103,300.0	618.8	0.74	0.4	1.2
08/09/2020 16:00	4,043.3	1,793.9	5,837.2	103,300.0	603.0	0.72	0.4	1.2
08/09/2020 17:00	4,042.7	1,947.0	5,989.7	103,300.0	618.7	0.74	0.4	1.2
08/09/2020 18:00	4,063.7	1,229.8	5,293.5	103,300.0	546.8	0.66	0.3	1.1
08/09/2020 19:00	4,091.6	1,923.2	6,014.8	103,300.0	621.3	0.75	0.4	1.2
08/09/2020 20:00	4,098.8	1,468.0	5,566.8	103,300.0	575.1	0.69	0.3	1.2
08/09/2020 21:00	4,112.0	885.9	4,997.9	103,300.0	516.3	0.62	0.3	1.0
08/09/2020 22:00	4,101.0	690.8	4,736.5	103,300.0	489.3	0.60	0.3	1.0
08/09/2020 23:00	3,391.3	0.0	3,391.3	103,300.0	350.3	0.42	0.2	0.7
Average/Sum#:	3,605.4	834.6	4,437.1	103,300.0	458.4	0.55	0.3	0.9
Minimum:	2,863.9	0.0	2,863.9	103,300.0	295.8	0.36	0.2	0.6
Maximum:	4,123.7	1,967.5	6,046.1	103,300.0	624.6	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2020 00:00	3,069.2	0.0	3,069.2	103,300.0	317.0	0.38	0.2	0.6
08/10/2020 01:00	2,876.4	0.0	2,876.4	103,300.0	297.1	0.36	0.2	0.6
08/10/2020 02:00	2,861.4	0.0	2,861.4	103,300.0	295.6	0.35	0.2	0.6
08/10/2020 03:00	2,869.1	0.0	2,869.1	103,300.0	296.4	0.35	0.2	0.6
08/10/2020 04:00	2,903.9	0.0	2,903.9	103,300.0	300.0	0.36	0.2	0.6
08/10/2020 05:00	2,858.3	0.0	2,858.3	103,300.0	295.3	0.35	0.2	0.6
08/10/2020 06:00	2,864.2	0.0	2,864.2	103,300.0	295.9	0.36	0.2	0.6
08/10/2020 07:00	2,952.7	0.0	2,952.7	103,300.0	305.0	0.37	0.2	0.6
08/10/2020 08:00	3,322.9	0.0	3,322.9	103,300.0	343.3	0.41	0.2	0.7
08/10/2020 09:00	3,932.9	11.4	3,933.7	103,300.0	406.4	0.49	0.2	0.8
08/10/2020 10:00	4,133.5	900.9	5,034.4	103,300.0	520.1	0.63	0.3	1.0
08/10/2020 11:00	4,111.0	1,581.7	5,692.7	103,300.0	588.1	0.71	0.4	1.2
08/10/2020 12:00	4,086.5	1,955.0	6,041.5	103,300.0	624.1	0.75	0.4	1.2
08/10/2020 13:00	4,072.9	1,977.1	6,050.0	103,300.0	625.0	0.75	0.4	1.2
08/10/2020 14:00	4,063.6	1,969.4	6,033.0	103,300.0	623.2	0.75	0.4	1.2
08/10/2020 15:00	4,036.0	1,950.7	5,986.7	103,300.0	618.4	0.74	0.4	1.2
08/10/2020 16:00	4,037.9	1,926.9	5,964.8	103,300.0	616.2	0.74	0.4	1.2
08/10/2020 17:00	4,065.5	1,831.8	5,897.3	103,300.0	609.2	0.73	0.4	1.2
08/10/2020 18:00	4,084.4	852.3	4,851.5	103,300.0	501.2	0.61	0.3	1.0
08/10/2020 19:00	3,711.8	0.0	3,711.8	103,300.0	383.4	0.46	0.2	0.8
08/10/2020 20:00	3,633.7	0.0	3,633.7	103,300.0	375.4	0.45	0.2	0.8
08/10/2020 21:00	3,760.7	0.0	3,760.7	103,300.0	388.5	0.47	0.2	0.8
08/10/2020 22:00	3,589.0	0.0	3,589.0	103,300.0	370.7	0.45	0.2	0.7
08/10/2020 23:00	3,457.6	0.0	3,457.6	103,300.0	357.2	0.43	0.2	0.7
Average/Sum#:	3,556.5	623.2	4,175.7	103,300.0	431.4	0.52	0.3	0.9
Minimum:	2,858.3	0.0	2,858.3	103,300.0	295.3	0.35	0.2	0.6
Maximum:	4,133.5	1,977.1	6,050.0	103,300.0	625.0	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2020 00:00	2,868.3	0.0	2,868.3	103,300.0	296.3	0.36	0.2	0.6
08/11/2020 01:00	2,871.4	0.0	2,871.4	103,300.0	296.6	0.36	0.2	0.6
08/11/2020 02:00	2,870.9	0.0	2,870.9	103,300.0	296.6	0.36	0.2	0.6
08/11/2020 03:00	2,870.5	0.0	2,870.5	103,300.0	296.5	0.36	0.2	0.6
08/11/2020 04:00	2,870.1	0.0	2,870.1	103,300.0	296.5	0.36	0.2	0.6
08/11/2020 05:00	2,870.5	0.0	2,870.5	103,300.0	296.5	0.36	0.2	0.6
08/11/2020 06:00	2,876.2	0.0	2,876.2	103,300.0	297.1	0.36	0.2	0.6
08/11/2020 07:00	2,890.9	0.0	2,890.9	103,300.0	298.6	0.36	0.2	0.6
08/11/2020 08:00	3,106.5	0.0	3,106.5	103,300.0	320.9	0.39	0.2	0.6
08/11/2020 09:00	3,252.8	0.0	3,252.8	103,300.0	336.0	0.40	0.2	0.7
08/11/2020 10:00	3,868.8	0.0	3,868.8	103,300.0	399.6	0.48	0.2	0.8
08/11/2020 11:00	4,180.6	262.4	4,403.6	103,300.0	454.9	0.55	0.3	0.9
08/11/2020 12:00	4,153.4	1,063.3	5,216.7	103,300.0	538.9	0.65	0.3	1.1
08/11/2020 13:00	4,131.3	762.7	4,894.0	103,300.0	505.6	0.61	0.3	1.0
08/11/2020 14:00	4,118.4	685.8	4,804.2	103,300.0	496.3	0.60	0.3	1.0
08/11/2020 15:00	4,101.7	778.5	4,880.2	103,300.0	504.1	0.61	0.3	1.0
08/11/2020 16:00	4,090.2	804.9	4,895.1	103,300.0	505.7	0.61	0.3	1.0
08/11/2020 17:00	4,108.7	613.5	4,722.2	103,300.0	487.8	0.59	0.3	1.0
08/11/2020 18:00	4,120.8	530.8	4,651.6	103,300.0	480.5	0.58	0.3	1.0
08/11/2020 19:00	3,849.9	6.4	3,850.1	103,300.0	397.7	0.48	0.2	0.8
08/11/2020 20:00	3,759.5	0.0	3,759.5	103,300.0	388.4	0.47	0.2	0.8
08/11/2020 21:00	4,096.5	0.0	4,096.5	103,300.0	423.2	0.51	0.3	0.8
08/11/2020 22:00	3,381.0	0.0	3,381.0	103,300.0	349.3	0.42	0.2	0.7
08/11/2020 23:00	2,960.9	0.0	2,960.9	103,300.0	305.9	0.37	0.2	0.6
Average/Sum#:	3,511.2	229.5	3,738.9	103,300.0	386.2	0.47	0.2	0.8
Minimum:	2,868.3	0.0	2,868.3	103,300.0	296.3	0.36	0.2	0.6
Maximum:	4,180.6	1,063.3	5,216.7	103,300.0	538.9	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2020 00:00	2,860.1	0.0	2,860.1	103,300.0	295.4	0.35	0.2	0.6
08/12/2020 01:00	2,861.1	0.0	2,861.1	103,300.0	295.6	0.35	0.2	0.6
08/12/2020 02:00	2,867.2	0.0	2,867.2	103,300.0	296.2	0.36	0.2	0.6
08/12/2020 03:00	2,869.7	0.0	2,869.7	103,300.0	296.4	0.36	0.2	0.6
08/12/2020 04:00	2,865.5	0.0	2,865.5	103,300.0	296.0	0.36	0.2	0.6
08/12/2020 05:00	2,865.2	0.0	2,865.2	103,300.0	296.0	0.36	0.2	0.6
08/12/2020 06:00	2,877.6	0.0	2,877.6	103,300.0	297.3	0.36	0.2	0.6
08/12/2020 07:00	2,902.3	0.0	2,902.3	103,300.0	299.8	0.36	0.2	0.6
08/12/2020 08:00	2,884.4	0.0	2,884.4	103,300.0	298.0	0.36	0.2	0.6
08/12/2020 09:00	3,153.4	0.0	3,153.4	103,300.0	325.7	0.39	0.2	0.7
08/12/2020 10:00	3,674.1	0.0	3,674.1	103,300.0	379.5	0.46	0.2	0.8
08/12/2020 11:00	4,169.9	1,174.5	5,309.2	103,300.0	548.4	0.66	0.3	1.1
08/12/2020 12:00	4,129.0	1,717.6	5,846.6	103,300.0	604.0	0.72	0.4	1.2
08/12/2020 13:00	4,105.0	1,875.0	5,980.0	103,300.0	617.7	0.74	0.4	1.2
08/12/2020 14:00	4,096.0	1,881.6	5,977.6	103,300.0	617.5	0.74	0.4	1.2
08/12/2020 15:00	4,078.5	1,896.5	5,975.0	103,300.0	617.2	0.74	0.4	1.2
08/12/2020 16:00	4,075.1	1,891.4	5,966.5	103,300.0	616.3	0.74	0.4	1.2
08/12/2020 17:00	4,086.6	1,882.4	5,969.0	103,300.0	616.6	0.74	0.4	1.2
08/12/2020 18:00	4,099.1	1,832.8	5,931.9	103,300.0	612.8	0.74	0.4	1.2
08/12/2020 19:00	4,107.9	1,355.5	5,463.4	103,300.0	564.4	0.68	0.3	1.1
08/12/2020 20:00	4,126.3	601.1	4,727.4	103,300.0	488.3	0.58	0.3	1.0
08/12/2020 21:00	4,158.7	633.3	4,792.0	103,300.0	495.0	0.59	0.3	1.0
08/12/2020 22:00	4,154.9	209.5	4,364.4	103,300.0	450.8	0.54	0.3	0.9
08/12/2020 23:00	3,812.8	17.6	3,814.9	103,300.0	394.1	0.47	0.2	0.8
Average/Sum#:	3,578.4	707.0	4,283.3	103,300.0	442.5	0.53	0.3	0.9
Minimum:	2,860.1	0.0	2,860.1	103,300.0	295.4	0.35	0.2	0.6
Maximum:	4,169.9	1,896.5	5,980.0	103,300.0	617.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2020 00:00	3,040.9	0.0	3,040.9	103,300.0	314.1	0.38	0.2	0.6
08/13/2020 01:00	2,860.7	0.0	2,860.7	103,300.0	295.5	0.35	0.2	0.6
08/13/2020 02:00	2,866.3	0.0	2,866.3	103,300.0	296.1	0.36	0.2	0.6
08/13/2020 03:00	2,863.1	0.0	2,863.1	103,300.0	295.8	0.35	0.2	0.6
08/13/2020 04:00	2,860.1	0.0	2,860.1	103,300.0	295.4	0.35	0.2	0.6
08/13/2020 05:00	2,860.7	0.0	2,860.7	103,300.0	295.5	0.35	0.2	0.6
08/13/2020 06:00	2,957.8	0.0	2,957.8	103,300.0	305.5	0.37	0.2	0.6
08/13/2020 07:00	2,936.2	0.0	2,936.2	103,300.0	303.3	0.36	0.2	0.6
08/13/2020 08:00	3,056.1	0.0	3,056.1	103,300.0	315.7	0.38	0.2	0.6
08/13/2020 09:00	3,558.5	0.0	3,558.5	103,300.0	367.6	0.44	0.2	0.7
08/13/2020 10:00	4,114.3	442.8	4,468.5	103,300.0	461.6	0.57	0.3	0.9
08/13/2020 11:00	4,115.3	1,623.3	5,738.6	103,300.0	592.8	0.71	0.4	1.2
08/13/2020 12:00	4,099.1	1,811.6	5,910.7	103,300.0	610.6	0.73	0.4	1.2
08/13/2020 13:00	4,083.8	1,852.6	5,936.4	103,300.0	613.2	0.74	0.4	1.2
08/13/2020 14:00	4,074.4	1,859.3	5,933.7	103,300.0	613.0	0.74	0.4	1.2
08/13/2020 15:00	4,061.4	1,581.1	5,642.5	103,300.0	582.9	0.70	0.3	1.2
08/13/2020 16:00	4,056.7	1,460.3	5,517.0	103,300.0	569.9	0.68	0.3	1.1
08/13/2020 17:00	4,066.8	1,781.2	5,848.0	103,300.0	604.1	0.73	0.4	1.2
08/13/2020 18:00	4,089.2	1,302.4	5,391.6	103,300.0	557.0	0.67	0.3	1.1
08/13/2020 19:00	4,115.8	473.0	4,588.8	103,300.0	474.0	0.57	0.3	0.9
08/13/2020 20:00	4,136.1	159.1	4,295.2	103,300.0	443.7	0.53	0.3	0.9
08/13/2020 21:00	4,128.4	1,498.4	5,626.8	103,300.0	581.2	0.70	0.3	1.2
08/13/2020 22:00	4,147.7	1,544.9	5,692.6	103,300.0	588.0	0.71	0.4	1.2
08/13/2020 23:00	3,627.5	53.9	3,632.9	103,300.0	375.3	0.46	0.2	0.8
Average/Sum#:	3,615.7	726.8	4,336.8	103,300.0	448.0	0.54	0.3	0.9
Minimum:	2,860.1	0.0	2,860.1	103,300.0	295.4	0.35	0.2	0.6
Maximum:	4,147.7	1,859.3	5,936.4	103,300.0	613.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2020 00:00	2,937.8	0.0	2,937.8	103,300.0	303.5	0.36	0.2	0.6
08/14/2020 01:00	2,876.4	0.0	2,876.4	103,300.0	297.1	0.36	0.2	0.6
08/14/2020 02:00	2,868.7	0.0	2,868.7	103,300.0	296.3	0.36	0.2	0.6
08/14/2020 03:00	2,865.2	0.0	2,865.2	103,300.0	296.0	0.36	0.2	0.6
08/14/2020 04:00	2,982.6	0.0	2,982.6	103,300.0	308.1	0.37	0.2	0.6
08/14/2020 05:00	3,319.5	0.0	3,319.5	103,300.0	342.9	0.41	0.2	0.7
08/14/2020 06:00	3,938.2	0.0	3,938.2	103,300.0	406.8	0.49	0.2	0.8
08/14/2020 07:00	4,199.3	458.1	4,602.4	103,300.0	475.4	0.58	0.3	1.0
08/14/2020 08:00	4,167.3	1,739.8	5,907.1	103,300.0	610.2	0.73	0.4	1.2
08/14/2020 09:00	4,147.6	1,831.0	5,978.6	103,300.0	617.6	0.74	0.4	1.2
08/14/2020 10:00	4,112.7	1,883.5	5,996.2	103,300.0	619.4	0.74	0.4	1.2
08/14/2020 11:00	4,103.2	1,419.9	5,523.1	103,300.0	570.5	0.69	0.3	1.1
08/14/2020 12:00	4,085.5	1,115.3	5,200.8	103,300.0	537.2	0.65	0.3	1.1
08/14/2020 13:00	4,066.6	1,171.5	5,238.1	103,300.0	541.1	0.65	0.3	1.1
08/14/2020 14:00	4,061.7	1,151.2	5,212.9	103,300.0	538.5	0.65	0.3	1.1
08/14/2020 15:00	4,066.9	1,895.2	5,962.1	103,300.0	615.9	0.74	0.4	1.2
08/14/2020 16:00	4,044.0	1,952.7	5,996.7	103,300.0	619.5	0.74	0.4	1.2
08/14/2020 17:00	4,042.7	1,872.2	5,914.9	103,300.0	611.0	0.73	0.4	1.2
08/14/2020 18:00	4,047.9	1,749.7	5,797.6	103,300.0	598.9	0.72	0.4	1.2
08/14/2020 19:00	4,057.7	1,886.8	5,944.5	103,300.0	614.1	0.74	0.4	1.2
08/14/2020 20:00	4,061.8	1,492.9	5,554.7	103,300.0	573.8	0.69	0.3	1.1
08/14/2020 21:00	4,080.0	852.0	4,932.0	103,300.0	509.5	0.61	0.3	1.0
08/14/2020 22:00	4,088.3	994.3	5,082.6	103,300.0	525.0	0.63	0.3	1.1
08/14/2020 23:00	3,399.3	37.0	3,402.3	103,300.0	351.5	0.43	0.2	0.7
Average/Sum#:	3,775.9	979.3	4,751.5	103,300.0	490.8	0.59	0.3	1.0
Minimum:	2,865.2	0.0	2,865.2	103,300.0	296.0	0.36	0.2	0.6
Maximum:	4,199.3	1,952.7	5,996.7	103,300.0	619.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2020 00:00	3,043.2	0.0	3,043.2	103,300.0	314.4	0.38	0.2	0.6
08/15/2020 01:00	3,153.3	0.0	3,153.3	103,300.0	325.7	0.39	0.2	0.7
08/15/2020 02:00	2,914.0	0.0	2,914.0	103,300.0	301.0	0.36	0.2	0.6
08/15/2020 03:00	2,880.4	0.0	2,880.4	103,300.0	297.5	0.36	0.2	0.6
08/15/2020 04:00	2,879.3	0.0	2,879.3	103,300.0	297.4	0.36	0.2	0.6
08/15/2020 05:00	2,880.0	0.0	2,880.0	103,300.0	297.5	0.36	0.2	0.6
08/15/2020 06:00	3,423.2	0.0	3,423.2	103,300.0	353.6	0.43	0.2	0.7
08/15/2020 07:00	3,879.1	1.8	3,879.1	103,300.0	400.7	0.48	0.2	0.8
08/15/2020 08:00	4,087.4	1,409.0	5,496.4	103,300.0	567.8	0.68	0.3	1.1
08/15/2020 09:00	4,065.1	1,945.8	6,010.9	103,300.0	620.9	0.74	0.4	1.2
08/15/2020 10:00	4,049.7	1,947.7	5,997.4	103,300.0	619.5	0.74	0.4	1.2
08/15/2020 11:00	4,037.9	1,939.9	5,977.8	103,300.0	617.5	0.74	0.4	1.2
08/15/2020 12:00	4,036.1	1,414.4	5,450.5	103,300.0	563.0	0.68	0.3	1.1
08/15/2020 13:00	4,030.2	1,159.7	5,189.9	103,300.0	536.1	0.64	0.3	1.1
08/15/2020 14:00	4,022.4	1,768.9	5,791.3	103,300.0	598.2	0.72	0.4	1.2
08/15/2020 15:00	4,016.6	1,276.0	5,292.6	103,300.0	546.7	0.66	0.3	1.1
08/15/2020 16:00	4,024.6	1,519.7	5,544.3	103,300.0	572.7	0.69	0.3	1.1
08/15/2020 17:00	4,036.5	1,608.3	5,644.8	103,300.0	583.1	0.70	0.3	1.2
08/15/2020 18:00	4,048.4	1,613.3	5,661.7	103,300.0	584.9	0.70	0.4	1.2
08/15/2020 19:00	4,063.9	1,926.2	5,990.1	103,300.0	618.8	0.74	0.4	1.2
08/15/2020 20:00	4,087.4	1,789.4	5,876.8	103,300.0	607.1	0.73	0.4	1.2
08/15/2020 21:00	4,104.8	1,694.5	5,799.3	103,300.0	599.1	0.72	0.4	1.2
08/15/2020 22:00	4,103.3	1,809.4	5,912.7	103,300.0	610.8	0.73	0.4	1.2
08/15/2020 23:00	4,075.1	565.2	4,600.7	103,300.0	475.3	0.57	0.3	1.0
Average/Sum#:	3,747.6	1,057.9	4,803.7	103,300.0	496.2	0.60	0.3	1.0
Minimum:	2,879.3	0.0	2,879.3	103,300.0	297.4	0.36	0.2	0.6
Maximum:	4,104.8	1,947.7	6,010.9	103,300.0	620.9	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2020 00:00	3,585.1	13.4	3,586.0	103,300.0	370.4	0.44	0.2	0.7
08/16/2020 01:00	3,495.9	0.0	3,495.9	103,300.0	361.1	0.43	0.2	0.7
08/16/2020 02:00	3,270.4	0.0	3,270.4	103,300.0	337.8	0.41	0.2	0.7
08/16/2020 03:00	3,048.7	0.0	3,048.7	103,300.0	314.9	0.38	0.2	0.6
08/16/2020 04:00	2,951.1	0.0	2,951.1	103,300.0	304.8	0.37	0.2	0.6
08/16/2020 05:00	3,313.5	0.0	3,313.5	103,300.0	342.3	0.41	0.2	0.7
08/16/2020 06:00	3,460.1	0.0	3,460.1	103,300.0	357.4	0.43	0.2	0.7
08/16/2020 07:00	3,658.6	0.0	3,658.6	103,300.0	377.9	0.45	0.2	0.8
08/16/2020 08:00	3,528.9	0.0	3,528.9	103,300.0	364.5	0.44	0.2	0.7
08/16/2020 09:00	4,064.2	595.2	4,570.1	103,300.0	472.1	0.58	0.3	1.0
08/16/2020 10:00	4,056.8	718.5	4,775.3	103,300.0	493.3	0.59	0.3	1.0
08/16/2020 11:00	4,039.8	768.7	4,808.5	103,300.0	496.7	0.60	0.3	1.0
08/16/2020 12:00	4,031.9	438.0	4,469.9	103,300.0	461.7	0.55	0.3	0.9
08/16/2020 13:00	4,015.3	1,055.2	5,070.5	103,300.0	523.8	0.63	0.3	1.0
08/16/2020 14:00	4,005.7	1,911.6	5,917.3	103,300.0	611.3	0.74	0.4	1.2
08/16/2020 15:00	4,004.9	1,760.3	5,765.2	103,300.0	595.5	0.72	0.4	1.2
08/16/2020 16:00	3,987.8	1,622.9	5,610.7	103,300.0	579.6	0.70	0.3	1.2
08/16/2020 17:00	4,013.2	1,319.6	5,332.8	103,300.0	550.9	0.66	0.3	1.1
08/16/2020 18:00	4,028.9	738.0	4,766.9	103,300.0	492.4	0.59	0.3	1.0
08/16/2020 19:00	4,051.4	1,123.3	5,174.7	103,300.0	534.5	0.64	0.3	1.1
08/16/2020 20:00	4,071.3	1,886.7	5,958.0	103,300.0	615.5	0.74	0.4	1.2
08/16/2020 21:00	4,075.5	1,480.2	5,555.7	103,300.0	573.9	0.69	0.3	1.1
08/16/2020 22:00	4,094.4	1,464.0	5,558.4	103,300.0	574.2	0.69	0.3	1.1
08/16/2020 23:00	4,057.1	450.6	4,341.0	103,300.0	448.4	0.56	0.3	0.9
Average/Sum#:	3,787.9	722.8	4,499.5	103,300.0	464.8	0.56	0.3	0.9
Minimum:	2,951.1	0.0	2,951.1	103,300.0	304.8	0.37	0.2	0.6
Maximum:	4,094.4	1,911.6	5,958.0	103,300.0	615.5	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2020 00:00	3,482.4	0.0	3,482.4	103,300.0	359.7	0.43	0.2	0.7
08/17/2020 01:00	3,239.4	0.0	3,239.4	103,300.0	334.6	0.40	0.2	0.7
08/17/2020 02:00	3,226.6	0.0	3,226.6	103,300.0	333.3	0.40	0.2	0.7
08/17/2020 03:00	3,149.3	0.0	3,149.3	103,300.0	325.3	0.39	0.2	0.7
08/17/2020 04:00	3,093.3	0.0	3,093.3	103,300.0	319.5	0.38	0.2	0.6
08/17/2020 05:00	3,554.0	0.0	3,554.0	103,300.0	367.1	0.44	0.2	0.7
08/17/2020 06:00	4,002.0	9.9	4,002.5	103,300.0	413.5	0.50	0.2	0.8
08/17/2020 07:00	4,127.1	1,037.6	5,164.7	103,300.0	533.5	0.64	0.3	1.1
08/17/2020 08:00	4,106.0	1,839.7	5,945.7	103,300.0	614.2	0.74	0.4	1.2
08/17/2020 09:00	4,097.0	1,950.9	6,047.9	103,300.0	624.7	0.75	0.4	1.3
08/17/2020 10:00	4,078.7	1,969.1	6,047.8	103,300.0	624.7	0.75	0.4	1.3
08/17/2020 11:00	4,061.8	1,967.5	6,029.3	103,300.0	622.8	0.75	0.4	1.2
08/17/2020 12:00	4,063.5	1,615.6	5,679.1	103,300.0	586.7	0.70	0.4	1.2
08/17/2020 13:00	4,057.4	1,071.2	5,128.6	103,300.0	529.8	0.64	0.3	1.1
08/17/2020 14:00	4,038.3	827.1	4,807.5	103,300.0	496.6	0.61	0.3	1.0
08/17/2020 15:00	3,285.8	0.0	3,285.8	103,300.0	339.4	0.41	0.2	0.7
08/17/2020 16:00	4,030.5	620.1	4,539.0	103,300.0	468.9	0.58	0.3	1.0
08/17/2020 17:00	4,049.8	1,325.6	5,375.4	103,300.0	555.3	0.67	0.3	1.1
08/17/2020 18:00	4,065.9	1,309.9	5,375.8	103,300.0	555.3	0.67	0.3	1.1
08/17/2020 19:00	4,082.8	1,397.2	5,480.0	103,300.0	566.1	0.68	0.3	1.1
08/17/2020 20:00	4,097.3	732.6	4,829.9	103,300.0	498.9	0.60	0.3	1.0
08/17/2020 21:00	4,100.2	378.7	4,422.1	103,300.0	456.8	0.56	0.3	0.9
08/17/2020 22:00	4,121.2	49.3	4,133.5	103,300.0	427.0	0.52	0.3	0.9
08/17/2020 23:00	3,738.4	95.4	3,762.3	103,300.0	388.6	0.47	0.2	0.8
Average/Sum#:	3,831.2	758.2	4,575.1	103,300.0	472.6	0.57	0.3	1.0
Minimum:	3,093.3	0.0	3,093.3	103,300.0	319.5	0.38	0.2	0.6
Maximum:	4,127.1	1,969.1	6,047.9	103,300.0	624.7	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	3,447.2	0.0	3,447.2	103,300.0	356.1	0.43	0.2	0.7
08/18/2020 01:00	3,261.2	0.0	3,261.2	103,300.0	336.9	0.41	0.2	0.7
08/18/2020 02:00	3,095.4	0.0	3,095.4	103,300.0	319.8	0.38	0.2	0.6
08/18/2020 03:00	3,092.6	0.0	3,092.6	103,300.0	319.5	0.38	0.2	0.6
08/18/2020 04:00	3,168.4	0.0	3,168.4	103,300.0	327.3	0.39	0.2	0.7
08/18/2020 05:00	2,880.9	0.0	2,880.9	103,300.0	297.6	0.36	0.2	0.6
08/18/2020 06:00	2,955.4	0.0	2,955.4	103,300.0	305.3	0.37	0.2	0.6
08/18/2020 07:00	3,465.9	0.0	3,465.9	103,300.0	358.0	0.43	0.2	0.7
08/18/2020 08:00	4,095.2	287.9	4,331.3	103,300.0	447.4	0.54	0.3	0.9
08/18/2020 09:00	4,082.7	1,220.0	5,302.7	103,300.0	547.8	0.66	0.3	1.1
08/18/2020 10:00	4,067.7	1,262.6	5,330.3	103,300.0	550.6	0.66	0.3	1.1
08/18/2020 11:00	4,057.3	1,554.9	5,612.2	103,300.0	579.7	0.69	0.3	1.2
08/18/2020 12:00	4,043.7	1,935.7	5,979.4	103,300.0	617.7	0.74	0.4	1.2
08/18/2020 13:00	4,025.7	1,663.2	5,688.9	103,300.0	587.7	0.71	0.4	1.2
08/18/2020 14:00	4,018.9	1,523.4	5,542.3	103,300.0	572.5	0.69	0.3	1.1
08/18/2020 15:00	4,015.0	467.0	4,482.0	103,300.0	463.0	0.55	0.3	0.9
08/18/2020 16:00	4,011.7	790.4	4,802.1	103,300.0	496.1	0.60	0.3	1.0
08/18/2020 17:00	4,012.0	456.7	4,468.7	103,300.0	461.6	0.55	0.3	0.9
08/18/2020 18:00	4,008.4	708.1	4,716.5	103,300.0	487.2	0.59	0.3	1.0
08/18/2020 19:00	3,988.8	650.4	4,574.2	103,300.0	472.5	0.57	0.3	1.0
08/18/2020 20:00	3,248.3	0.0	3,248.3	103,300.0	335.5	0.40	0.2	0.7
08/18/2020 21:00	4,025.3	745.3	4,621.5	103,300.0	477.4	0.59	0.3	1.0
08/18/2020 22:00	4,044.5	459.8	4,504.3	103,300.0	465.3	0.56	0.3	0.9
08/18/2020 23:00	4,048.9	489.5	4,474.8	103,300.0	462.2	0.56	0.3	0.9
Average/Sum#:	3,715.0	592.3	4,293.6	103,300.0	443.5	0.53	0.3	0.9
Minimum:	2,880.9	0.0	2,880.9	103,300.0	297.6	0.36	0.2	0.6
Maximum:	4,095.2	1,935.7	5,979.4	103,300.0	617.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2020 00:00	3,907.9	0.0	3,907.9	103,300.0	403.7	0.49	0.2	0.8
08/19/2020 01:00	3,654.9	0.0	3,654.9	103,300.0	377.6	0.46	0.2	0.8
08/19/2020 02:00	3,402.7	0.0	3,402.7	103,300.0	351.5	0.42	0.2	0.7
08/19/2020 03:00	3,122.0	0.0	3,122.0	103,300.0	322.5	0.39	0.2	0.6
08/19/2020 04:00	3,419.1	0.0	3,419.1	103,300.0	353.2	0.43	0.2	0.7
08/19/2020 05:00	3,404.8	0.0	3,404.8	103,300.0	351.7	0.42	0.2	0.7
08/19/2020 06:00	3,755.3	0.0	3,755.3	103,300.0	387.9	0.46	0.2	0.8
08/19/2020 07:00	4,129.8	325.9	4,439.4	103,300.0	458.6	0.55	0.3	0.9
08/19/2020 08:00	4,100.5	1,281.9	5,382.4	103,300.0	556.0	0.67	0.3	1.1
08/19/2020 09:00	4,075.4	1,027.2	5,102.6	103,300.0	527.1	0.63	0.3	1.1
08/19/2020 10:00	4,074.6	1,814.5	5,889.1	103,300.0	608.3	0.73	0.4	1.2
08/19/2020 11:00	4,078.9	1,875.7	5,954.6	103,300.0	615.1	0.74	0.4	1.2
08/19/2020 12:00	4,083.8	1,914.0	5,997.8	103,300.0	619.6	0.74	0.4	1.2
08/19/2020 13:00	4,072.4	1,529.6	5,602.0	103,300.0	578.7	0.69	0.3	1.2
08/19/2020 14:00	4,063.8	491.9	4,555.7	103,300.0	470.6	0.56	0.3	0.9
08/19/2020 15:00	4,055.1	462.4	4,517.5	103,300.0	466.7	0.56	0.3	0.9
08/19/2020 16:00	4,048.6	921.2	4,969.8	103,300.0	513.4	0.62	0.3	1.0
08/19/2020 17:00	4,051.6	1,756.3	5,807.9	103,300.0	600.0	0.72	0.4	1.2
08/19/2020 18:00	4,057.8	1,384.8	5,442.6	103,300.0	562.2	0.67	0.3	1.1
08/19/2020 19:00	4,078.1	715.3	4,793.4	103,300.0	495.2	0.59	0.3	1.0
08/19/2020 20:00	4,101.3	663.2	4,764.5	103,300.0	492.2	0.59	0.3	1.0
08/19/2020 21:00	4,107.7	602.2	4,709.9	103,300.0	486.5	0.58	0.3	1.0
08/19/2020 22:00	3,848.6	7.4	3,849.1	103,300.0	397.6	0.48	0.2	0.8
08/19/2020 23:00	3,718.5	0.0	3,718.5	103,300.0	384.1	0.46	0.2	0.8
Average/Sum#:	3,892.2	698.9	4,590.1	103,300.0	474.2	0.57	0.3	0.9
Minimum:	3,122.0	0.0	3,122.0	103,300.0	322.5	0.39	0.2	0.6
Maximum:	4,129.8	1,914.0	5,997.8	103,300.0	619.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2020 00:00	3,169.6	0.0	3,169.6	103,300.0	327.4	0.39	0.2	0.7
08/20/2020 01:00	2,917.8	0.0	2,917.8	103,300.0	301.4	0.36	0.2	0.6
08/20/2020 02:00	2,870.2	0.0	2,870.2	103,300.0	296.5	0.36	0.2	0.6
08/20/2020 03:00	2,864.1	0.0	2,864.1	103,300.0	295.9	0.36	0.2	0.6
08/20/2020 04:00	2,862.9	0.0	2,862.9	103,300.0	295.7	0.35	0.2	0.6
08/20/2020 05:00	2,898.0	0.0	2,898.0	103,300.0	299.4	0.36	0.2	0.6
08/20/2020 06:00	2,900.3	0.0	2,900.3	103,300.0	299.6	0.36	0.2	0.6
08/20/2020 07:00	2,879.1	0.0	2,879.1	103,300.0	297.4	0.36	0.2	0.6
08/20/2020 08:00	3,022.3	0.0	3,022.3	103,300.0	312.2	0.37	0.2	0.6
08/20/2020 09:00	3,336.7	0.0	3,336.7	103,300.0	344.7	0.41	0.2	0.7
08/20/2020 10:00	3,706.1	0.0	3,706.1	103,300.0	382.8	0.46	0.2	0.8
08/20/2020 11:00	4,177.8	252.4	4,399.9	103,300.0	454.5	0.55	0.3	0.9
08/20/2020 12:00	3,973.4	67.0	3,988.1	103,300.0	412.0	0.50	0.3	0.8
08/20/2020 13:00	4,050.7	0.0	4,050.7	103,300.0	418.4	0.50	0.3	0.8
08/20/2020 14:00	3,365.5	0.0	3,365.5	103,300.0	347.7	0.42	0.2	0.7
08/20/2020 15:00	4,065.6	436.4	4,371.1	103,300.0	451.5	0.56	0.3	0.9
08/20/2020 16:00	3,618.6	0.0	3,618.6	103,300.0	373.8	0.45	0.2	0.7
08/20/2020 17:00	3,900.1	0.0	3,900.1	103,300.0	402.9	0.48	0.2	0.8
08/20/2020 18:00	4,077.4	454.9	4,450.4	103,300.0	459.7	0.56	0.3	0.9
08/20/2020 19:00	3,474.8	0.0	3,474.8	103,300.0	358.9	0.43	0.2	0.7
08/20/2020 20:00	3,535.6	0.0	3,535.6	103,300.0	365.2	0.44	0.2	0.7
08/20/2020 21:00	3,596.0	0.0	3,596.0	103,300.0	371.5	0.45	0.2	0.7
08/20/2020 22:00	3,027.9	0.0	3,027.9	103,300.0	312.8	0.38	0.2	0.6
08/20/2020 23:00	2,872.6	0.0	2,872.6	103,300.0	296.7	0.36	0.2	0.6
Average/Sum#:	3,381.8	50.4	3,419.9	103,300.0	353.3	0.43	0.2	0.7
Minimum:	2,862.9	0.0	2,862.9	103,300.0	295.7	0.35	0.2	0.6
Maximum:	4,177.8	454.9	4,450.4	103,300.0	459.7	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2020 00:00	2,862.3	0.0	2,862.3	103,300.0	295.7	0.35	0.2	0.6
08/21/2020 01:00	2,860.6	0.0	2,860.6	103,300.0	295.5	0.35	0.2	0.6
08/21/2020 02:00	2,859.3	0.0	2,859.3	103,300.0	295.4	0.35	0.2	0.6
08/21/2020 03:00	2,961.2	0.0	2,961.2	103,300.0	305.9	0.37	0.2	0.6
08/21/2020 04:00	2,909.0	0.0	2,909.0	103,300.0	300.5	0.36	0.2	0.6
08/21/2020 05:00	2,859.3	0.0	2,859.3	103,300.0	295.4	0.35	0.2	0.6
08/21/2020 06:00	3,137.1	0.0	3,137.1	103,300.0	324.1	0.39	0.2	0.6
08/21/2020 07:00	3,479.0	0.0	3,479.0	103,300.0	359.4	0.43	0.2	0.7
08/21/2020 08:00	3,391.6	0.0	3,391.6	103,300.0	350.4	0.42	0.2	0.7
08/21/2020 09:00	3,623.4	0.0	3,623.4	103,300.0	374.3	0.45	0.2	0.7
08/21/2020 10:00	3,937.6	5.8	3,937.8	103,300.0	406.8	0.49	0.2	0.8
08/21/2020 11:00	4,109.1	45.7	4,125.1	103,300.0	426.1	0.51	0.3	0.9
08/21/2020 12:00	3,944.7	37.5	3,953.3	103,300.0	408.4	0.50	0.2	0.8
08/21/2020 13:00	4,093.2	1,585.2	5,678.4	103,300.0	586.6	0.70	0.4	1.2
08/21/2020 14:00	4,077.0	1,207.7	5,284.7	103,300.0	545.9	0.66	0.3	1.1
08/21/2020 15:00	4,054.7	1,615.8	5,670.5	103,300.0	585.8	0.70	0.4	1.2
08/21/2020 16:00	4,041.1	1,923.4	5,964.5	103,300.0	616.1	0.74	0.4	1.2
08/21/2020 17:00	4,038.9	1,931.0	5,969.9	103,300.0	616.7	0.74	0.4	1.2
08/21/2020 18:00	4,039.7	1,921.2	5,960.9	103,300.0	615.8	0.74	0.4	1.2
08/21/2020 19:00	3,937.0	73.7	3,946.6	103,300.0	407.7	0.50	0.2	0.8
08/21/2020 20:00	3,464.3	0.0	3,464.3	103,300.0	357.9	0.43	0.2	0.7
08/21/2020 21:00	4,034.4	1,100.8	5,080.2	103,300.0	524.8	0.64	0.3	1.1
08/21/2020 22:00	4,037.6	1,088.7	5,050.1	103,300.0	521.7	0.64	0.3	1.1
08/21/2020 23:00	3,326.2	0.0	3,326.2	103,300.0	343.6	0.41	0.2	0.7
Average/Sum#:	3,586.6	522.4	4,098.1	103,300.0	423.4	0.51	0.3	0.8
Minimum:	2,859.3	0.0	2,859.3	103,300.0	295.4	0.35	0.2	0.6
Maximum:	4,109.1	1,931.0	5,969.9	103,300.0	616.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2020 00:00	2,867.3	0.0	2,867.3	103,300.0	296.2	0.35	0.2	0.6
08/22/2020 01:00	3,087.2	0.0	3,087.2	103,300.0	318.9	0.38	0.2	0.6
08/22/2020 02:00	3,009.9	0.0	3,009.9	103,300.0	310.9	0.37	0.2	0.6
08/22/2020 03:00	2,873.9	0.0	2,873.9	103,300.0	296.9	0.35	0.2	0.6
08/22/2020 04:00	2,852.4	0.0	2,852.4	103,300.0	294.7	0.35	0.2	0.6
08/22/2020 05:00	2,854.5	0.0	2,854.5	103,300.0	294.9	0.35	0.2	0.6
08/22/2020 06:00	2,931.2	0.0	2,931.2	103,300.0	302.8	0.36	0.2	0.6
08/22/2020 07:00	3,154.9	0.0	3,154.9	103,300.0	325.9	0.39	0.2	0.7
08/22/2020 08:00	3,083.8	0.0	3,083.8	103,300.0	318.6	0.38	0.2	0.6
08/22/2020 09:00	3,531.1	0.0	3,531.1	103,300.0	364.8	0.44	0.2	0.7
08/22/2020 10:00	3,974.3	1.4	3,974.3	103,300.0	410.5	0.49	0.2	0.8
08/22/2020 11:00	4,089.3	496.9	4,586.2	103,300.0	473.8	0.57	0.3	0.9
08/22/2020 12:00	4,068.8	196.6	4,212.3	103,300.0	435.1	0.53	0.3	0.9
08/22/2020 13:00	3,981.0	91.6	4,036.0	103,300.0	416.9	0.50	0.3	0.8
08/22/2020 14:00	4,004.5	211.5	4,148.3	103,300.0	428.5	0.52	0.3	0.9
08/22/2020 15:00	4,002.8	697.0	4,699.8	103,300.0	485.5	0.58	0.3	1.0
08/22/2020 16:00	3,994.8	1,599.4	5,594.2	103,300.0	577.9	0.69	0.3	1.2
08/22/2020 17:00	3,996.2	1,924.1	5,920.3	103,300.0	611.6	0.74	0.4	1.2
08/22/2020 18:00	3,983.2	1,847.2	5,830.4	103,300.0	602.3	0.72	0.4	1.2
08/22/2020 19:00	3,995.9	959.5	4,955.4	103,300.0	511.9	0.61	0.3	1.0
08/22/2020 20:00	4,035.2	807.7	4,842.9	103,300.0	500.3	0.60	0.3	1.0
08/22/2020 21:00	4,038.2	432.2	4,435.8	103,300.0	458.2	0.55	0.3	0.9
08/22/2020 22:00	4,006.0	0.0	4,006.0	103,300.0	413.8	0.50	0.2	0.8
08/22/2020 23:00	3,521.4	0.0	3,521.4	103,300.0	363.8	0.44	0.2	0.7
Average/Sum#:	3,580.7	386.0	3,958.7	103,300.0	408.9	0.49	0.3	0.8
Minimum:	2,852.4	0.0	2,852.4	103,300.0	294.7	0.35	0.2	0.6
Maximum:	4,089.3	1,924.1	5,920.3	103,300.0	611.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2020 00:00	3,043.5	0.0	3,043.5	103,300.0	314.4	0.38	0.2	0.6
08/23/2020 01:00	2,883.3	0.0	2,883.3	103,300.0	297.8	0.35	0.2	0.6
08/23/2020 02:00	2,856.8	0.0	2,856.8	103,300.0	295.1	0.35	0.2	0.6
08/23/2020 03:00	2,859.1	0.0	2,859.1	103,300.0	295.3	0.35	0.2	0.6
08/23/2020 04:00	2,859.7	0.0	2,859.7	103,300.0	295.4	0.35	0.2	0.6
08/23/2020 05:00	2,859.3	0.0	2,859.3	103,300.0	295.4	0.35	0.2	0.6
08/23/2020 06:00	2,860.4	0.0	2,860.4	103,300.0	295.5	0.35	0.2	0.6
08/23/2020 07:00	2,868.2	0.0	2,868.2	103,300.0	296.3	0.36	0.2	0.6
08/23/2020 08:00	2,946.5	0.0	2,946.5	103,300.0	304.4	0.37	0.2	0.6
08/23/2020 09:00	3,608.8	0.0	3,608.8	103,300.0	372.8	0.45	0.2	0.7
08/23/2020 10:00	4,089.3	113.6	4,185.9	103,300.0	432.4	0.52	0.3	0.9
08/23/2020 11:00	4,072.6	1,247.5	5,320.1	103,300.0	549.6	0.66	0.3	1.1
08/23/2020 12:00	4,061.7	1,645.5	5,707.2	103,300.0	589.6	0.71	0.4	1.2
08/23/2020 13:00	4,048.5	1,609.2	5,657.7	103,300.0	584.4	0.70	0.4	1.2
08/23/2020 14:00	4,051.0	1,271.2	5,322.2	103,300.0	549.8	0.66	0.3	1.1
08/23/2020 15:00	4,047.1	1,178.0	5,225.1	103,300.0	539.8	0.65	0.3	1.1
08/23/2020 16:00	4,053.9	1,356.9	5,410.8	103,300.0	558.9	0.67	0.3	1.1
08/23/2020 17:00	4,057.4	1,231.0	5,288.4	103,300.0	546.3	0.66	0.3	1.1
08/23/2020 18:00	4,056.8	843.5	4,900.3	103,300.0	506.2	0.61	0.3	1.0
08/23/2020 19:00	4,049.1	193.0	4,178.4	103,300.0	431.6	0.53	0.3	0.9
08/23/2020 20:00	4,065.9	0.0	4,065.9	103,300.0	420.0	0.50	0.3	0.8
08/23/2020 21:00	4,067.3	696.6	4,680.3	103,300.0	483.5	0.59	0.3	1.0
08/23/2020 22:00	4,071.5	242.8	4,270.6	103,300.0	441.2	0.54	0.3	0.9
08/23/2020 23:00	3,389.7	0.0	3,389.7	103,300.0	350.2	0.42	0.2	0.7
Average/Sum#:	3,576.1	484.5	4,052.0	103,300.0	418.6	0.50	0.3	0.8
Minimum:	2,856.8	0.0	2,856.8	103,300.0	295.1	0.35	0.2	0.6
Maximum:	4,089.3	1,645.5	5,707.2	103,300.0	589.6	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2020 00:00	3,013.7	0.0	3,013.7	103,300.0	311.3	0.37	0.2	0.6
08/24/2020 01:00	2,871.8	0.0	2,871.8	103,300.0	296.7	0.36	0.2	0.6
08/24/2020 02:00	2,868.1	0.0	2,868.1	103,300.0	296.3	0.36	0.2	0.6
08/24/2020 03:00	2,867.5	0.0	2,867.5	103,300.0	296.2	0.36	0.2	0.6
08/24/2020 04:00	3,031.5	0.0	3,031.5	103,300.0	313.2	0.38	0.2	0.6
08/24/2020 05:00	2,973.3	0.0	2,973.3	103,300.0	307.1	0.37	0.2	0.6
08/24/2020 06:00	3,162.2	0.0	3,162.2	103,300.0	326.7	0.39	0.2	0.7
08/24/2020 07:00	3,545.6	0.0	3,545.6	103,300.0	366.3	0.44	0.2	0.7
08/24/2020 08:00	4,063.4	340.7	4,336.0	103,300.0	447.9	0.55	0.3	0.9
08/24/2020 09:00	4,100.2	1,043.4	5,143.6	103,300.0	531.3	0.64	0.3	1.1
08/24/2020 10:00	4,092.4	1,192.5	5,284.9	103,300.0	545.9	0.65	0.3	1.1
08/24/2020 11:00	4,074.1	1,846.4	5,920.5	103,300.0	611.6	0.73	0.4	1.2
08/24/2020 12:00	4,055.3	1,463.2	5,518.5	103,300.0	570.1	0.69	0.3	1.1
08/24/2020 13:00	4,038.2	1,041.0	5,079.2	103,300.0	524.7	0.63	0.3	1.0
08/24/2020 14:00	4,018.8	1,270.0	5,288.8	103,300.0	546.3	0.66	0.3	1.1
08/24/2020 15:00	4,022.6	963.8	4,986.4	103,300.0	515.1	0.62	0.3	1.0
08/24/2020 16:00	4,030.5	1,268.9	5,299.4	103,300.0	547.4	0.66	0.3	1.1
08/24/2020 17:00	4,026.7	1,267.0	5,293.7	103,300.0	546.8	0.66	0.3	1.1
08/24/2020 18:00	4,030.1	958.4	4,988.5	103,300.0	515.3	0.62	0.3	1.0
08/24/2020 19:00	4,024.6	228.2	4,223.1	103,300.0	436.2	0.53	0.3	0.9
08/24/2020 20:00	3,789.3	0.0	3,789.3	103,300.0	391.4	0.47	0.2	0.8
08/24/2020 21:00	4,037.5	356.2	4,340.3	103,300.0	448.4	0.55	0.3	0.9
08/24/2020 22:00	4,035.1	503.8	4,453.3	103,300.0	460.0	0.56	0.3	0.9
08/24/2020 23:00	3,547.8	0.0	3,547.8	103,300.0	366.5	0.44	0.2	0.7
Average/Sum#:	3,680.0	572.6	4,242.8	103,300.0	438.3	0.53	0.3	0.9
Minimum:	2,867.5	0.0	2,867.5	103,300.0	296.2	0.36	0.2	0.6
Maximum:	4,100.2	1,846.4	5,920.5	103,300.0	611.6	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2020 00:00	3,086.8	0.0	3,086.8	103,300.0	318.9	0.38	0.2	0.6
08/25/2020 01:00	2,868.1	0.0	2,868.1	103,300.0	296.3	0.36	0.2	0.6
08/25/2020 02:00	2,866.1	0.0	2,866.1	103,300.0	296.1	0.36	0.2	0.6
08/25/2020 03:00	2,865.1	0.0	2,865.1	103,300.0	296.0	0.36	0.2	0.6
08/25/2020 04:00	2,867.4	0.0	2,867.4	103,300.0	296.2	0.36	0.2	0.6
08/25/2020 05:00	2,867.7	0.0	2,867.7	103,300.0	296.2	0.36	0.2	0.6
08/25/2020 06:00	3,093.7	0.0	3,093.7	103,300.0	319.6	0.38	0.2	0.6
08/25/2020 07:00	3,259.3	0.0	3,259.3	103,300.0	336.7	0.41	0.2	0.7
08/25/2020 08:00	3,692.4	0.0	3,692.4	103,300.0	381.4	0.46	0.2	0.8
08/25/2020 09:00	4,113.8	30.9	4,118.4	103,300.0	425.4	0.51	0.3	0.9
08/25/2020 10:00	4,082.2	756.7	4,838.9	103,300.0	499.9	0.60	0.3	1.0
08/25/2020 11:00	4,067.8	1,364.3	5,432.1	103,300.0	561.1	0.67	0.3	1.1
08/25/2020 12:00	4,062.4	762.2	4,824.6	103,300.0	498.4	0.60	0.3	1.0
08/25/2020 13:00	4,039.3	789.9	4,829.2	103,300.0	498.9	0.60	0.3	1.0
08/25/2020 14:00	4,026.2	825.4	4,851.6	103,300.0	501.2	0.60	0.3	1.0
08/25/2020 15:00	4,022.0	1,252.8	5,274.8	103,300.0	544.9	0.65	0.3	1.1
08/25/2020 16:00	4,014.5	1,393.4	5,407.9	103,300.0	558.6	0.67	0.3	1.1
08/25/2020 17:00	4,012.8	1,863.8	5,876.6	103,300.0	607.1	0.73	0.4	1.2
08/25/2020 18:00	4,017.4	1,177.8	5,195.2	103,300.0	536.7	0.64	0.3	1.1
08/25/2020 19:00	4,023.6	767.6	4,791.2	103,300.0	494.9	0.59	0.3	1.0
08/25/2020 20:00	3,955.4	21.0	3,958.1	103,300.0	408.9	0.49	0.2	0.8
08/25/2020 21:00	3,983.0	0.0	3,983.0	103,300.0	411.4	0.49	0.2	0.8
08/25/2020 22:00	3,770.4	0.0	3,770.4	103,300.0	389.5	0.47	0.2	0.8
08/25/2020 23:00	2,989.5	0.0	2,989.5	103,300.0	308.8	0.37	0.2	0.6
Average/Sum#:	3,610.3	458.6	4,067.0	103,300.0	420.1	0.50	0.3	0.8
Minimum:	2,865.1	0.0	2,865.1	103,300.0	296.0	0.36	0.2	0.6
Maximum:	4,113.8	1,863.8	5,876.6	103,300.0	607.1	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2020 00:00	2,866.9	0.0	2,866.9	103,300.0	296.2	0.36	0.2	0.6
08/26/2020 01:00	2,868.5	0.0	2,868.5	103,300.0	296.3	0.36	0.2	0.6
08/26/2020 02:00	2,862.6	0.0	2,862.6	103,300.0	295.7	0.35	0.2	0.6
08/26/2020 03:00	2,863.7	0.0	2,863.7	103,300.0	295.8	0.35	0.2	0.6
08/26/2020 04:00	2,892.7	0.0	2,892.7	103,300.0	298.8	0.36	0.2	0.6
08/26/2020 05:00	2,891.0	0.0	2,891.0	103,300.0	298.6	0.36	0.2	0.6
08/26/2020 06:00	2,902.8	0.0	2,902.8	103,300.0	299.9	0.36	0.2	0.6
08/26/2020 07:00	3,208.8	0.0	3,208.8	103,300.0	331.5	0.40	0.2	0.7
08/26/2020 08:00	3,498.3	0.0	3,498.3	103,300.0	361.4	0.43	0.2	0.7
08/26/2020 09:00	3,780.7	0.0	3,780.7	103,300.0	390.5	0.47	0.2	0.8
08/26/2020 10:00	4,100.5	423.4	4,523.9	103,300.0	467.3	0.56	0.3	0.9
08/26/2020 11:00	4,072.8	1,282.7	5,355.5	103,300.0	553.2	0.66	0.3	1.1
08/26/2020 12:00	4,032.8	1,772.2	5,805.0	103,300.0	599.7	0.72	0.4	1.2
08/26/2020 13:00	4,010.2	1,917.9	5,928.1	103,300.0	612.4	0.73	0.4	1.2
08/26/2020 14:00	4,001.7	1,924.5	5,926.2	103,300.0	612.2	0.73	0.4	1.2
08/26/2020 15:00	3,999.1	1,924.8	5,923.9	103,300.0	611.9	0.73	0.4	1.2
08/26/2020 16:00	4,011.4	1,922.0	5,933.4	103,300.0	612.9	0.74	0.4	1.2
08/26/2020 17:00	4,036.9	1,842.8	5,879.7	103,300.0	607.4	0.73	0.4	1.2
08/26/2020 18:00	4,038.1	726.1	4,764.2	103,300.0	492.1	0.59	0.3	1.0
08/26/2020 19:00	3,992.6	93.5	4,055.2	103,300.0	418.9	0.51	0.3	0.8
08/26/2020 20:00	3,840.5	0.0	3,840.5	103,300.0	396.7	0.48	0.2	0.8
08/26/2020 21:00	3,901.9	0.0	3,901.9	103,300.0	403.1	0.48	0.2	0.8
08/26/2020 22:00	3,120.9	0.0	3,120.9	103,300.0	322.4	0.39	0.2	0.6
08/26/2020 23:00	2,943.5	0.0	2,943.5	103,300.0	304.1	0.37	0.2	0.6
Average/Sum#:	3,530.8	576.2	4,105.7	103,300.0	424.1	0.51	0.3	0.8
Minimum:	2,862.6	0.0	2,862.6	103,300.0	295.7	0.35	0.2	0.6
Maximum:	4,100.5	1,924.8	5,933.4	103,300.0	612.9	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2020 00:00	2,865.0	0.0	2,865.0	103,300.0	296.0	0.36	0.2	0.6
08/27/2020 01:00	2,865.3	0.0	2,865.3	103,300.0	296.0	0.36	0.2	0.6
08/27/2020 02:00	2,863.5	0.0	2,863.5	103,300.0	295.8	0.35	0.2	0.6
08/27/2020 03:00	2,863.0	0.0	2,863.0	103,300.0	295.7	0.35	0.2	0.6
08/27/2020 04:00	2,863.4	0.0	2,863.4	103,300.0	295.8	0.35	0.2	0.6
08/27/2020 05:00	2,865.1	0.0	2,865.1	103,300.0	296.0	0.36	0.2	0.6
08/27/2020 06:00	2,869.6	0.0	2,869.6	103,300.0	296.4	0.36	0.2	0.6
08/27/2020 07:00	2,883.6	0.0	2,883.6	103,300.0	297.9	0.36	0.2	0.6
08/27/2020 08:00	2,993.1	0.0	2,993.1	103,300.0	309.2	0.37	0.2	0.6
08/27/2020 09:00	3,220.3	0.0	3,220.3	103,300.0	332.7	0.40	0.2	0.7
08/27/2020 10:00	3,936.9	15.5	3,938.1	103,300.0	406.8	0.49	0.2	0.8
08/27/2020 11:00	4,063.8	452.2	4,516.0	103,300.0	466.5	0.56	0.3	0.9
08/27/2020 12:00	4,080.9	404.8	4,485.7	103,300.0	463.4	0.56	0.3	0.9
08/27/2020 13:00	4,073.7	1,196.6	5,270.3	103,300.0	544.4	0.65	0.3	1.1
08/27/2020 14:00	4,050.4	1,212.2	5,262.6	103,300.0	543.6	0.65	0.3	1.1
08/27/2020 15:00	4,043.1	1,034.4	5,077.5	103,300.0	524.5	0.63	0.3	1.0
08/27/2020 16:00	4,027.7	1,312.5	5,340.2	103,300.0	551.6	0.66	0.3	1.1
08/27/2020 17:00	4,025.9	1,397.1	5,423.0	103,300.0	560.2	0.67	0.3	1.1
08/27/2020 18:00	4,041.5	814.2	4,855.7	103,300.0	501.6	0.60	0.3	1.0
08/27/2020 19:00	4,067.4	374.5	4,441.9	103,300.0	458.8	0.55	0.3	0.9
08/27/2020 20:00	3,815.9	3.7	3,816.0	103,300.0	394.2	0.47	0.2	0.8
08/27/2020 21:00	3,809.9	0.0	3,809.9	103,300.0	393.6	0.47	0.2	0.8
08/27/2020 22:00	3,150.1	0.0	3,150.1	103,300.0	325.4	0.39	0.2	0.6
08/27/2020 23:00	2,866.4	0.0	2,866.4	103,300.0	296.1	0.35	0.2	0.6
Average/Sum#:	3,466.9	342.4	3,808.6	103,300.0	393.4	0.47	0.2	0.8
Minimum:	2,863.0	0.0	2,863.0	103,300.0	295.7	0.35	0.2	0.6
Maximum:	4,080.9	1,397.1	5,423.0	103,300.0	560.2	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2020 00:00	2,857.9	0.0	2,857.9	103,300.0	295.2	0.35	0.2	0.6
08/28/2020 01:00	2,855.5	0.0	2,855.5	103,300.0	295.0	0.35	0.2	0.6
08/28/2020 02:00	2,855.3	0.0	2,855.3	103,300.0	295.0	0.35	0.2	0.6
08/28/2020 03:00	2,860.9	0.0	2,860.9	103,300.0	295.5	0.35	0.2	0.6
08/28/2020 04:00	2,861.2	0.0	2,861.2	103,300.0	295.6	0.35	0.2	0.6
08/28/2020 05:00	2,858.2	0.0	2,858.2	103,300.0	295.3	0.35	0.2	0.6
08/28/2020 06:00	2,868.7	0.0	2,868.7	103,300.0	296.3	0.35	0.2	0.6
08/28/2020 07:00	2,992.8	0.0	2,992.8	103,300.0	309.2	0.37	0.2	0.6
08/28/2020 08:00	3,265.9	0.0	3,265.9	103,300.0	337.4	0.40	0.2	0.7
08/28/2020 09:00	3,627.7	0.0	3,627.7	103,300.0	374.7	0.45	0.2	0.7
08/28/2020 10:00	4,040.7	24.0	4,042.6	103,300.0	417.6	0.50	0.3	0.8
08/28/2020 11:00	4,059.2	1,090.1	5,149.3	103,300.0	531.9	0.64	0.3	1.1
08/28/2020 12:00	4,036.3	1,923.4	5,959.7	103,300.0	615.6	0.74	0.4	1.2
08/28/2020 13:00	4,021.6	1,930.6	5,952.2	103,300.0	614.9	0.74	0.4	1.2
08/28/2020 14:00	4,000.2	1,340.6	5,340.8	103,300.0	551.7	0.66	0.3	1.1
08/28/2020 15:00	3,997.4	1,424.2	5,421.6	103,300.0	560.1	0.67	0.3	1.1
08/28/2020 16:00	3,999.1	1,915.2	5,914.3	103,300.0	610.9	0.73	0.4	1.2
08/28/2020 17:00	4,005.9	1,724.5	5,730.4	103,300.0	592.0	0.71	0.4	1.2
08/28/2020 18:00	4,007.9	741.6	4,749.5	103,300.0	490.6	0.59	0.3	1.0
08/28/2020 19:00	4,011.8	23.5	4,015.3	103,300.0	414.8	0.50	0.3	0.8
08/28/2020 20:00	3,990.7	0.0	3,990.7	103,300.0	412.2	0.50	0.2	0.8
08/28/2020 21:00	4,044.2	0.0	4,044.2	103,300.0	417.8	0.50	0.3	0.8
08/28/2020 22:00	3,808.6	0.0	3,808.6	103,300.0	393.4	0.47	0.2	0.8
08/28/2020 23:00	3,296.4	0.0	3,296.4	103,300.0	340.5	0.41	0.2	0.7
Average/Sum#:	3,551.0	505.7	4,055.0	103,300.0	418.9	0.50	0.3	0.8
Minimum:	2,855.3	0.0	2,855.3	103,300.0	295.0	0.35	0.2	0.6
Maximum:	4,059.2	1,930.6	5,959.7	103,300.0	615.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2020 00:00	2,907.1	0.0	2,907.1	103,300.0	300.3	0.36	0.2	0.6
08/29/2020 01:00	2,862.9	0.0	2,862.9	103,300.0	295.7	0.35	0.2	0.6
08/29/2020 02:00	2,866.8	0.0	2,866.8	103,300.0	296.1	0.36	0.2	0.6
08/29/2020 03:00	2,863.7	0.0	2,863.7	103,300.0	295.8	0.35	0.2	0.6
08/29/2020 04:00	2,861.3	0.0	2,861.3	103,300.0	295.6	0.35	0.2	0.6
08/29/2020 05:00	2,860.9	0.0	2,860.9	103,300.0	295.5	0.35	0.2	0.6
08/29/2020 06:00	2,865.2	0.0	2,865.2	103,300.0	296.0	0.36	0.2	0.6
08/29/2020 07:00	2,876.2	0.0	2,876.2	103,300.0	297.1	0.36	0.2	0.6
08/29/2020 08:00	3,031.2	0.0	3,031.2	103,300.0	313.1	0.38	0.2	0.6
08/29/2020 09:00	3,383.9	0.0	3,383.9	103,300.0	349.6	0.42	0.2	0.7
08/29/2020 10:00	3,486.0	0.0	3,486.0	103,300.0	360.1	0.43	0.2	0.7
08/29/2020 11:00	4,052.7	25.2	4,054.7	103,300.0	418.9	0.51	0.3	0.8
08/29/2020 12:00	4,051.3	839.6	4,890.9	103,300.0	505.2	0.61	0.3	1.0
08/29/2020 13:00	4,027.6	1,795.9	5,823.5	103,300.0	601.6	0.72	0.4	1.2
08/29/2020 14:00	4,015.1	1,514.1	5,529.2	103,300.0	571.2	0.69	0.3	1.1
08/29/2020 15:00	4,004.6	1,870.6	5,875.2	103,300.0	606.9	0.73	0.4	1.2
08/29/2020 16:00	4,007.7	1,182.7	5,190.4	103,300.0	536.2	0.64	0.3	1.1
08/29/2020 17:00	4,025.4	689.8	4,715.2	103,300.0	487.1	0.58	0.3	1.0
08/29/2020 18:00	3,901.9	87.6	3,939.6	103,300.0	407.0	0.49	0.2	0.8
08/29/2020 19:00	3,461.2	0.0	3,461.2	103,300.0	357.5	0.43	0.2	0.7
08/29/2020 20:00	3,583.5	0.0	3,583.5	103,300.0	370.2	0.44	0.2	0.7
08/29/2020 21:00	3,905.7	0.0	3,905.7	103,300.0	403.5	0.48	0.2	0.8
08/29/2020 22:00	3,325.9	0.0	3,325.9	103,300.0	343.6	0.41	0.2	0.7
08/29/2020 23:00	2,956.7	0.0	2,956.7	103,300.0	305.4	0.37	0.2	0.6
Average/Sum#:	3,424.4	333.6	3,754.9	103,300.0	387.9	0.47	0.2	0.8
Minimum:	2,860.9	0.0	2,860.9	103,300.0	295.5	0.35	0.2	0.6
Maximum:	4,052.7	1,870.6	5,875.2	103,300.0	606.9	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2020 00:00	2,867.5	0.0	2,867.5	103,300.0	296.2	0.36	0.2	0.6
08/30/2020 01:00	2,865.7	0.0	2,865.7	103,300.0	296.0	0.36	0.2	0.6
08/30/2020 02:00	2,865.6	0.0	2,865.6	103,300.0	296.0	0.36	0.2	0.6
08/30/2020 03:00	2,863.3	0.0	2,863.3	103,300.0	295.8	0.35	0.2	0.6
08/30/2020 04:00	2,862.7	0.0	2,862.7	103,300.0	295.7	0.35	0.2	0.6
08/30/2020 05:00	2,862.3	0.0	2,862.3	103,300.0	295.7	0.35	0.2	0.6
08/30/2020 06:00	2,875.4	0.0	2,875.4	103,300.0	297.0	0.36	0.2	0.6
08/30/2020 07:00	2,875.6	0.0	2,875.6	103,300.0	297.0	0.36	0.2	0.6
08/30/2020 08:00	2,874.3	0.0	2,874.3	103,300.0	296.9	0.36	0.2	0.6
08/30/2020 09:00	3,001.6	0.0	3,001.6	103,300.0	310.1	0.37	0.2	0.6
08/30/2020 10:00	3,395.0	0.0	3,395.0	103,300.0	350.7	0.42	0.2	0.7
08/30/2020 11:00	3,852.6	0.0	3,852.6	103,300.0	398.0	0.48	0.2	0.8
08/30/2020 12:00	4,056.4	791.1	4,847.5	103,300.0	500.7	0.60	0.3	1.0
08/30/2020 13:00	4,028.8	1,728.0	5,756.8	103,300.0	594.7	0.71	0.4	1.2
08/30/2020 14:00	4,008.1	1,935.4	5,943.5	103,300.0	614.0	0.74	0.4	1.2
08/30/2020 15:00	4,005.3	1,603.8	5,609.1	103,300.0	579.4	0.69	0.3	1.2
08/30/2020 16:00	4,010.4	1,081.3	5,091.7	103,300.0	526.0	0.63	0.3	1.1
08/30/2020 17:00	4,007.8	1,041.6	5,049.4	103,300.0	521.6	0.63	0.3	1.0
08/30/2020 18:00	4,007.6	86.4	4,023.2	103,300.0	415.6	0.51	0.3	0.8
08/30/2020 19:00	3,642.7	0.0	3,642.7	103,300.0	376.3	0.45	0.2	0.8
08/30/2020 20:00	3,245.9	0.0	3,245.9	103,300.0	335.3	0.40	0.2	0.7
08/30/2020 21:00	3,913.6	0.0	3,913.6	103,300.0	404.3	0.49	0.2	0.8
08/30/2020 22:00	3,305.1	0.0	3,305.1	103,300.0	341.4	0.41	0.2	0.7
08/30/2020 23:00	4,061.2	1,551.2	5,426.3	103,300.0	560.5	0.70	0.3	1.2
Average/Sum#:	3,431.4	409.1	3,829.9	103,300.0	395.6	0.48	0.2	0.8
Minimum:	2,862.3	0.0	2,862.3	103,300.0	295.7	0.35	0.2	0.6
Maximum:	4,061.2	1,935.4	5,943.5	103,300.0	614.0	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2020 00:00	4,071.7	1,647.9	5,719.6	103,300.0	590.8	0.71	0.4	1.2
08/31/2020 01:00	4,113.4	1,097.1	5,210.5	103,300.0	538.2	0.65	0.3	1.1
08/31/2020 02:00	4,138.3	601.6	4,739.9	103,300.0	489.6	0.58	0.3	1.0
08/31/2020 03:00	4,148.5	578.3	4,726.8	103,300.0	488.3	0.59	0.3	1.0
08/31/2020 04:00	4,171.9	961.8	5,133.7	103,300.0	530.3	0.64	0.3	1.1
08/31/2020 05:00	4,187.0	624.2	4,811.2	103,300.0	497.0	0.59	0.3	1.0
08/31/2020 06:00	4,188.4	1,020.5	5,208.9	103,300.0	538.1	0.65	0.3	1.1
08/31/2020 07:00	4,176.3	1,258.5	5,434.8	103,300.0	561.4	0.67	0.3	1.1
08/31/2020 08:00	4,147.8	1,485.2	5,633.0	103,300.0	581.9	0.70	0.3	1.2
08/31/2020 09:00	4,112.4	1,103.7	5,216.1	103,300.0	538.8	0.65	0.3	1.1
08/31/2020 10:00	4,081.6	1,133.9	5,215.5	103,300.0	538.8	0.65	0.3	1.1
08/31/2020 11:00	4,057.9	1,440.5	5,498.4	103,300.0	568.0	0.68	0.3	1.1
08/31/2020 12:00	4,044.7	1,761.0	5,805.7	103,300.0	599.7	0.72	0.4	1.2
08/31/2020 13:00	4,018.0	1,703.5	5,721.5	103,300.0	591.0	0.71	0.4	1.2
08/31/2020 14:00	3,999.1	1,237.7	5,236.8	103,300.0	541.0	0.65	0.3	1.1
08/31/2020 15:00	3,997.9	338.1	4,336.0	103,300.0	447.9	0.54	0.3	0.9
08/31/2020 16:00	4,010.1	852.2	4,862.3	103,300.0	502.3	0.60	0.3	1.0
08/31/2020 17:00	4,015.5	1,154.1	5,169.6	103,300.0	534.0	0.64	0.3	1.1
08/31/2020 18:00	4,029.4	885.7	4,915.1	103,300.0	507.7	0.61	0.3	1.0
08/31/2020 19:00	4,048.9	748.3	4,774.8	103,300.0	493.2	0.60	0.3	1.0
08/31/2020 20:00	3,050.9	0.0	3,050.9	103,300.0	315.2	0.38	0.2	0.6
08/31/2020 21:00	3,952.4	0.0	3,952.4	103,300.0	408.3	0.49	0.2	0.8
08/31/2020 22:00	3,416.7	0.0	3,416.7	103,300.0	352.9	0.42	0.2	0.7
08/31/2020 23:00	3,307.7	0.0	3,307.7	103,300.0	341.7	0.41	0.2	0.7
Average/Sum#:	3,978.6	901.4	4,879.1	103,300.0	504.0	0.61	0.3	1.0
Minimum:	3,050.9	0.0	3,050.9	103,300.0	315.2	0.38	0.2	0.6
Maximum:	4,188.4	1,761.0	5,805.7	103,300.0	599.7	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020 00:00	2,930.7	0.0	2,930.7	103,300.0	302.7	0.36	0.2	0.6
09/01/2020 01:00	2,868.0	0.0	2,868.0	103,300.0	296.3	0.36	0.2	0.6
09/01/2020 02:00	2,864.2	0.0	2,864.2	103,300.0	295.9	0.35	0.2	0.6
09/01/2020 03:00	2,871.0	0.0	2,871.0	103,300.0	296.6	0.36	0.2	0.6
09/01/2020 04:00	2,889.2	0.0	2,889.2	103,300.0	298.5	0.36	0.2	0.6
09/01/2020 05:00	3,420.3	0.0	3,420.3	103,300.0	353.3	0.43	0.2	0.7
09/01/2020 06:00	3,508.8	0.0	3,508.8	103,300.0	362.5	0.44	0.2	0.7
09/01/2020 07:00	3,755.2	0.0	3,755.2	103,300.0	387.9	0.47	0.2	0.8
09/01/2020 08:00	4,151.8	0.0	4,151.8	103,300.0	428.9	0.51	0.3	0.9
09/01/2020 09:00	4,122.1	0.0	4,122.1	103,300.0	425.8	0.51	0.3	0.9
09/01/2020 10:00	4,029.5	0.0	4,029.5	103,300.0	416.2	0.50	0.2	0.8
09/01/2020 11:00	4,087.4	275.9	4,355.0	103,300.0	449.9	0.54	0.3	0.9
09/01/2020 12:00	4,052.2	1,683.2	5,735.4	103,300.0	592.5	0.71	0.4	1.2
09/01/2020 13:00	4,028.5	1,733.5	5,762.0	103,300.0	595.2	0.71	0.4	1.2
09/01/2020 14:00	4,016.3	1,866.3	5,882.6	103,300.0	607.7	0.73	0.4	1.2
09/01/2020 15:00	4,014.1	1,890.1	5,904.2	103,300.0	609.9	0.73	0.4	1.2
09/01/2020 16:00	4,019.8	1,840.9	5,860.7	103,300.0	605.4	0.73	0.4	1.2
09/01/2020 17:00	4,041.8	1,460.1	5,501.9	103,300.0	568.3	0.68	0.3	1.1
09/01/2020 18:00	4,065.4	1,173.2	5,238.6	103,300.0	541.1	0.65	0.3	1.1
09/01/2020 19:00	4,110.7	940.0	5,050.7	103,300.0	521.7	0.63	0.3	1.0
09/01/2020 20:00	4,127.5	1,185.6	5,313.1	103,300.0	548.8	0.66	0.3	1.1
09/01/2020 21:00	4,106.6	158.8	4,189.2	103,300.0	432.7	0.53	0.3	0.9
09/01/2020 22:00	3,344.2	0.0	3,344.2	103,300.0	345.5	0.41	0.2	0.7
09/01/2020 23:00	3,371.7	0.0	3,371.7	103,300.0	348.3	0.42	0.2	0.7
Average/Sum#:	3,699.9	592.0	4,288.3	103,300.0	443.0	0.53	0.3	0.9
Minimum:	2,864.2	0.0	2,864.2	103,300.0	295.9	0.35	0.2	0.6
Maximum:	4,151.8	1,890.1	5,904.2	103,300.0	609.9	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2020 00:00	3,359.5	0.0	3,359.5	103,300.0	347.0	0.42	0.2	0.7
09/02/2020 01:00	3,154.4	0.0	3,154.4	103,300.0	325.8	0.39	0.2	0.7
09/02/2020 02:00	2,995.9	0.0	2,995.9	103,300.0	309.5	0.37	0.2	0.6
09/02/2020 03:00	2,980.4	0.0	2,980.4	103,300.0	307.9	0.37	0.2	0.6
09/02/2020 04:00	2,962.3	0.0	2,962.3	103,300.0	306.0	0.37	0.2	0.6
09/02/2020 05:00	3,103.2	0.0	3,103.2	103,300.0	320.6	0.38	0.2	0.6
09/02/2020 06:00	3,384.6	0.0	3,384.6	103,300.0	349.6	0.42	0.2	0.7
09/02/2020 07:00	3,601.7	0.0	3,601.7	103,300.0	372.1	0.45	0.2	0.7
09/02/2020 08:00	3,800.2	0.0	3,800.2	103,300.0	392.6	0.47	0.2	0.8
09/02/2020 09:00	3,649.9	0.0	3,649.9	103,300.0	377.0	0.45	0.2	0.8
09/02/2020 10:00	3,666.6	0.0	3,666.6	103,300.0	378.8	0.45	0.2	0.8
09/02/2020 11:00	3,429.7	0.0	3,429.7	103,300.0	354.3	0.42	0.2	0.7
09/02/2020 12:00	3,422.9	0.0	3,422.9	103,300.0	353.6	0.42	0.2	0.7
09/02/2020 13:00	4,048.8	227.3	4,201.1	103,300.0	434.0	0.53	0.3	0.9
09/02/2020 14:00	4,058.5	1,266.8	5,325.3	103,300.0	550.1	0.66	0.3	1.1
09/02/2020 15:00	4,047.3	1,290.4	5,337.7	103,300.0	551.4	0.66	0.3	1.1
09/02/2020 16:00	4,041.3	1,294.3	5,335.6	103,300.0	551.2	0.66	0.3	1.1
09/02/2020 17:00	4,037.7	1,296.4	5,334.1	103,300.0	551.0	0.66	0.3	1.1
09/02/2020 18:00	4,057.5	921.7	4,979.2	103,300.0	514.4	0.62	0.3	1.0
09/02/2020 19:00	4,087.9	314.7	4,393.2	103,300.0	453.8	0.54	0.3	0.9
09/02/2020 20:00	3,823.1	0.0	3,823.1	103,300.0	394.9	0.47	0.2	0.8
09/02/2020 21:00	4,116.1	422.6	4,454.2	103,300.0	460.1	0.56	0.3	0.9
09/02/2020 22:00	3,962.0	0.0	3,962.0	103,300.0	409.3	0.49	0.2	0.8
09/02/2020 23:00	3,506.5	0.0	3,506.5	103,300.0	362.2	0.44	0.2	0.7
Average/Sum#:	3,637.4	293.1	3,923.5	103,300.0	405.3	0.49	0.2	0.8
Minimum:	2,962.3	0.0	2,962.3	103,300.0	306.0	0.37	0.2	0.6
Maximum:	4,116.1	1,296.4	5,337.7	103,300.0	551.4	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2020 00:00	3,181.4	0.0	3,181.4	103,300.0	328.6	0.39	0.2	0.7
09/03/2020 01:00	2,936.8	0.0	2,936.8	103,300.0	303.4	0.36	0.2	0.6
09/03/2020 02:00	2,872.0	0.0	2,872.0	103,300.0	296.7	0.36	0.2	0.6
09/03/2020 03:00	2,896.5	0.0	2,896.5	103,300.0	299.2	0.36	0.2	0.6
09/03/2020 04:00	2,984.7	0.0	2,984.7	103,300.0	308.3	0.37	0.2	0.6
09/03/2020 05:00	2,930.7	0.0	2,930.7	103,300.0	302.7	0.36	0.2	0.6
09/03/2020 06:00	2,886.4	0.0	2,886.4	103,300.0	298.2	0.36	0.2	0.6
09/03/2020 07:00	2,917.0	0.0	2,917.0	103,300.0	301.3	0.36	0.2	0.6
09/03/2020 08:00	3,462.3	0.0	3,462.3	103,300.0	357.7	0.43	0.2	0.7
09/03/2020 09:00	3,417.3	0.0	3,417.3	103,300.0	353.0	0.42	0.2	0.7
09/03/2020 10:00	3,694.2	0.0	3,694.2	103,300.0	381.6	0.46	0.2	0.8
09/03/2020 11:00	4,088.6	125.1	4,134.9	103,300.0	427.1	0.52	0.3	0.9
09/03/2020 12:00	4,059.3	1,413.2	5,472.5	103,300.0	565.3	0.68	0.3	1.1
09/03/2020 13:00	4,020.5	1,941.9	5,962.4	103,300.0	615.9	0.74	0.4	1.2
09/03/2020 14:00	4,011.7	1,941.5	5,953.2	103,300.0	615.0	0.74	0.4	1.2
09/03/2020 15:00	4,007.5	1,942.7	5,950.2	103,300.0	614.7	0.74	0.4	1.2
09/03/2020 16:00	3,994.7	1,925.2	5,919.9	103,300.0	611.5	0.73	0.4	1.2
09/03/2020 17:00	4,006.8	1,915.0	5,921.8	103,300.0	611.7	0.73	0.4	1.2
09/03/2020 18:00	4,030.7	1,880.1	5,910.8	103,300.0	610.6	0.73	0.4	1.2
09/03/2020 19:00	4,055.9	1,654.3	5,710.2	103,300.0	589.9	0.71	0.4	1.2
09/03/2020 20:00	4,066.7	1,539.8	5,606.5	103,300.0	579.2	0.69	0.3	1.2
09/03/2020 21:00	4,085.8	1,388.6	5,474.4	103,300.0	565.5	0.68	0.3	1.1
09/03/2020 22:00	4,100.9	162.8	4,250.7	103,300.0	439.1	0.53	0.3	0.9
09/03/2020 23:00	3,705.8	0.0	3,705.8	103,300.0	382.8	0.46	0.2	0.8
Average/Sum#:	3,600.6	742.9	4,339.7	103,300.0	448.3	0.54	0.3	0.9
Minimum:	2,872.0	0.0	2,872.0	103,300.0	296.7	0.36	0.2	0.6
Maximum:	4,100.9	1,942.7	5,962.4	103,300.0	615.9	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2020 00:00	3,467.5	0.0	3,467.5	103,300.0	358.2	0.43	0.2	0.7
09/04/2020 01:00	3,215.4	0.0	3,215.4	103,300.0	332.2	0.40	0.2	0.7
09/04/2020 02:00	3,120.6	0.0	3,120.6	103,300.0	322.4	0.39	0.2	0.6
09/04/2020 03:00	3,078.4	0.0	3,078.4	103,300.0	318.0	0.38	0.2	0.6
09/04/2020 04:00	3,117.9	0.0	3,117.9	103,300.0	322.1	0.39	0.2	0.6
09/04/2020 05:00	3,191.7	0.0	3,191.7	103,300.0	329.7	0.40	0.2	0.7
09/04/2020 06:00	3,170.9	0.0	3,170.9	103,300.0	327.6	0.39	0.2	0.7
09/04/2020 07:00	3,118.1	0.0	3,118.1	103,300.0	322.1	0.39	0.2	0.6
09/04/2020 08:00	3,344.6	0.0	3,344.6	103,300.0	345.5	0.42	0.2	0.7
09/04/2020 09:00	3,313.9	0.0	3,313.9	103,300.0	342.3	0.41	0.2	0.7
09/04/2020 10:00	3,660.6	0.0	3,660.6	103,300.0	378.1	0.45	0.2	0.8
09/04/2020 11:00	4,063.0	483.4	4,531.9	103,300.0	468.1	0.56	0.3	0.9
09/04/2020 12:00	4,034.8	1,185.5	5,220.3	103,300.0	539.3	0.65	0.3	1.1
09/04/2020 13:00	4,012.9	1,895.7	5,908.6	103,300.0	610.4	0.73	0.4	1.2
09/04/2020 14:00	4,001.3	1,925.2	5,926.5	103,300.0	612.2	0.73	0.4	1.2
09/04/2020 15:00	3,995.4	1,922.5	5,917.9	103,300.0	611.3	0.73	0.4	1.2
09/04/2020 16:00	3,985.8	1,919.4	5,905.2	103,300.0	610.0	0.73	0.4	1.2
09/04/2020 17:00	3,981.8	1,922.4	5,904.2	103,300.0	609.9	0.73	0.4	1.2
09/04/2020 18:00	3,985.9	1,924.0	5,909.9	103,300.0	610.5	0.73	0.4	1.2
09/04/2020 19:00	3,995.2	1,924.0	5,919.2	103,300.0	611.5	0.73	0.4	1.2
09/04/2020 20:00	4,014.6	1,907.1	5,921.7	103,300.0	611.7	0.73	0.4	1.2
09/04/2020 21:00	4,042.7	1,765.6	5,808.3	103,300.0	600.0	0.72	0.4	1.2
09/04/2020 22:00	4,061.1	918.9	4,980.0	103,300.0	514.4	0.62	0.3	1.0
09/04/2020 23:00	3,245.0	0.0	3,245.0	103,300.0	335.2	0.40	0.2	0.7
Average/Sum#:	3,634.1	820.6	4,454.1	103,300.0	460.1	0.55	0.3	0.9
Minimum:	3,078.4	0.0	3,078.4	103,300.0	318.0	0.38	0.2	0.6
Maximum:	4,063.0	1,925.2	5,926.5	103,300.0	612.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2020 00:00	2,959.8	0.0	2,959.8	103,300.0	305.7	0.37	0.2	0.6
09/05/2020 01:00	2,891.7	0.0	2,891.7	103,300.0	298.7	0.36	0.2	0.6
09/05/2020 02:00	2,867.3	0.0	2,867.3	103,300.0	296.2	0.36	0.2	0.6
09/05/2020 03:00	2,872.0	0.0	2,872.0	104,000.0	298.7	0.36	0.2	0.6
09/05/2020 04:00	2,867.3	0.0	2,867.3	104,000.0	298.2	0.36	0.2	0.6
09/05/2020 05:00	2,862.6	0.0	2,862.6	104,000.0	297.7	0.36	0.2	0.6
09/05/2020 06:00	2,866.7	0.0	2,866.7	104,000.0	298.1	0.36	0.2	0.6
09/05/2020 07:00	2,907.6	0.0	2,907.6	104,000.0	302.4	0.36	0.2	0.6
09/05/2020 08:00	3,123.3	0.0	3,123.3	104,000.0	324.8	0.39	0.2	0.6
09/05/2020 09:00	3,712.9	8.7	3,713.3	104,000.0	386.2	0.47	0.2	0.8
09/05/2020 10:00	4,038.3	485.6	4,523.9	104,000.0	470.5	0.56	0.3	0.9
09/05/2020 11:00	4,010.8	1,318.8	5,329.6	104,000.0	554.3	0.67	0.3	1.1
09/05/2020 12:00	3,981.1	1,741.9	5,723.0	104,000.0	595.2	0.71	0.4	1.2
09/05/2020 13:00	3,956.9	1,911.8	5,868.7	104,000.0	610.3	0.73	0.4	1.2
09/05/2020 14:00	3,949.6	1,908.2	5,857.8	104,000.0	609.2	0.73	0.4	1.2
09/05/2020 15:00	3,947.1	1,876.0	5,823.1	104,000.0	605.6	0.73	0.4	1.2
09/05/2020 16:00	3,933.8	1,873.4	5,807.2	104,000.0	603.9	0.72	0.4	1.2
09/05/2020 17:00	3,939.6	1,822.3	5,761.9	104,000.0	599.2	0.72	0.4	1.2
09/05/2020 18:00	3,965.6	1,200.3	5,165.9	104,000.0	537.3	0.64	0.3	1.1
09/05/2020 19:00	3,992.6	1,433.7	5,426.3	104,000.0	564.3	0.68	0.3	1.1
09/05/2020 20:00	4,016.1	1,837.8	5,853.9	104,000.0	608.8	0.73	0.4	1.2
09/05/2020 21:00	4,035.3	1,381.0	5,416.3	104,000.0	563.3	0.68	0.3	1.1
09/05/2020 22:00	4,031.4	289.9	4,301.0	104,000.0	447.3	0.54	0.3	0.9
09/05/2020 23:00	3,719.7	0.0	3,719.7	104,000.0	386.8	0.46	0.2	0.8
Average/Sum#:	3,560.4	795.4	4,354.6	103,912.5	452.6	0.54	0.3	0.9
Minimum:	2,862.6	0.0	2,862.6	103,300.0	296.2	0.36	0.2	0.6
Maximum:	4,038.3	1,911.8	5,868.7	104,000.0	610.3	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2020 00:00	3,315.8	0.0	3,315.8	104,000.0	344.8	0.41	0.2	0.7
09/06/2020 01:00	2,932.5	0.0	2,932.5	104,000.0	305.0	0.36	0.2	0.6
09/06/2020 02:00	2,874.9	0.0	2,874.9	104,000.0	299.0	0.36	0.2	0.6
09/06/2020 03:00	2,878.6	0.0	2,878.6	104,000.0	299.4	0.36	0.2	0.6
09/06/2020 04:00	2,876.3	0.0	2,876.3	104,000.0	299.1	0.36	0.2	0.6
09/06/2020 05:00	2,896.0	0.0	2,896.0	104,000.0	301.2	0.36	0.2	0.6
09/06/2020 06:00	2,967.6	0.0	2,967.6	104,000.0	308.6	0.37	0.2	0.6
09/06/2020 07:00	2,931.2	0.0	2,931.2	104,000.0	304.8	0.36	0.2	0.6
09/06/2020 08:00	3,156.3	0.0	3,156.3	104,000.0	328.3	0.39	0.2	0.7
09/06/2020 09:00	3,675.3	0.0	3,675.3	104,000.0	382.2	0.46	0.2	0.8
09/06/2020 10:00	3,914.3	0.0	3,914.3	104,000.0	407.1	0.49	0.2	0.8
09/06/2020 11:00	3,546.8	0.0	3,546.8	104,000.0	368.9	0.44	0.2	0.7
09/06/2020 12:00	3,986.4	660.3	4,626.9	104,000.0	481.2	0.58	0.3	1.0
09/06/2020 13:00	3,959.5	1,244.3	5,203.8	104,000.0	541.2	0.65	0.3	1.1
09/06/2020 14:00	3,932.1	1,688.6	5,620.7	104,000.0	584.6	0.70	0.4	1.2
09/06/2020 15:00	3,914.8	1,885.9	5,800.7	104,000.0	603.3	0.72	0.4	1.2
09/06/2020 16:00	3,902.1	1,883.0	5,785.1	104,000.0	601.7	0.72	0.4	1.2
09/06/2020 17:00	3,912.8	1,867.7	5,780.5	104,000.0	601.2	0.72	0.4	1.2
09/06/2020 18:00	3,939.7	1,794.1	5,733.8	104,000.0	596.3	0.72	0.4	1.2
09/06/2020 19:00	3,978.0	1,555.6	5,533.6	104,000.0	575.5	0.69	0.3	1.2
09/06/2020 20:00	3,994.4	1,613.0	5,607.4	104,000.0	583.2	0.70	0.3	1.2
09/06/2020 21:00	3,982.0	1,802.9	5,784.9	104,000.0	601.6	0.72	0.4	1.2
09/06/2020 22:00	3,978.7	1,000.9	4,979.6	104,000.0	517.9	0.62	0.3	1.0
09/06/2020 23:00	3,929.8	127.7	3,964.3	104,000.0	412.3	0.51	0.3	0.8
Average/Sum#:	3,557.3	713.5	4,266.1	104,000.0	443.7	0.53	0.3	0.9
Minimum:	2,874.9	0.0	2,874.9	104,000.0	299.0	0.36	0.2	0.6
Maximum:	3,994.4	1,885.9	5,800.7	104,000.0	603.3	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2020 00:00	3,466.1	0.0	3,466.1	104,000.0	360.5	0.43	0.2	0.7
09/07/2020 01:00	3,040.7	0.0	3,040.7	104,000.0	316.2	0.38	0.2	0.6
09/07/2020 02:00	2,880.3	0.0	2,880.3	104,000.0	299.6	0.36	0.2	0.6
09/07/2020 03:00	2,878.0	0.0	2,878.0	104,000.0	299.3	0.36	0.2	0.6
09/07/2020 04:00	2,875.5	0.0	2,875.5	104,000.0	299.1	0.36	0.2	0.6
09/07/2020 05:00	2,869.7	0.0	2,869.7	104,000.0	298.4	0.36	0.2	0.6
09/07/2020 06:00	2,872.0	0.0	2,872.0	104,000.0	298.7	0.36	0.2	0.6
09/07/2020 07:00	3,064.0	0.0	3,064.0	104,000.0	318.7	0.38	0.2	0.6
09/07/2020 08:00	3,596.9	0.0	3,596.9	104,000.0	374.1	0.45	0.2	0.7
09/07/2020 09:00	4,019.1	717.7	4,700.9	104,000.0	488.9	0.59	0.3	1.0
09/07/2020 10:00	3,988.7	1,815.3	5,804.0	104,000.0	603.6	0.73	0.4	1.2
09/07/2020 11:00	3,978.0	1,674.3	5,652.3	104,000.0	587.8	0.71	0.4	1.2
09/07/2020 12:00	3,955.2	915.2	4,870.4	104,000.0	506.5	0.61	0.3	1.0
09/07/2020 13:00	3,941.7	1,788.4	5,730.1	104,000.0	595.9	0.72	0.4	1.2
09/07/2020 14:00	3,909.5	983.0	4,892.5	104,000.0	508.8	0.61	0.3	1.0
09/07/2020 15:00	3,909.4	727.9	4,637.3	104,000.0	482.3	0.58	0.3	1.0
09/07/2020 16:00	3,903.0	1,312.8	5,215.8	104,000.0	542.4	0.65	0.3	1.1
09/07/2020 17:00	3,905.8	728.1	4,633.9	104,000.0	481.9	0.58	0.3	1.0
09/07/2020 18:00	3,917.9	256.2	4,169.0	104,000.0	433.6	0.52	0.3	0.9
09/07/2020 19:00	3,963.3	0.0	3,963.3	104,000.0	412.2	0.49	0.2	0.8
09/07/2020 20:00	3,964.9	258.4	4,202.6	104,000.0	437.1	0.53	0.3	0.9
09/07/2020 21:00	3,971.4	1,012.8	4,984.2	104,000.0	518.4	0.62	0.3	1.0
09/07/2020 22:00	3,961.7	47.5	3,967.4	104,000.0	412.6	0.50	0.3	0.8
09/07/2020 23:00	3,653.1	0.0	3,653.1	104,000.0	379.9	0.46	0.2	0.8
Average/Sum#:	3,603.6	509.9	4,109.2	104,000.0	427.4	0.51	0.3	0.9
Minimum:	2,869.7	0.0	2,869.7	104,000.0	298.4	0.36	0.2	0.6
Maximum:	4,019.1	1,815.3	5,804.0	104,000.0	603.6	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2020 00:00	3,107.6	0.0	3,107.6	104,000.0	323.2	0.39	0.2	0.6
09/08/2020 01:00	3,439.9	0.0	3,439.9	104,000.0	357.7	0.43	0.2	0.7
09/08/2020 02:00	3,428.9	0.0	3,428.9	104,000.0	356.6	0.43	0.2	0.7
09/08/2020 03:00	3,015.5	0.0	3,015.5	104,000.0	313.6	0.38	0.2	0.6
09/08/2020 04:00	2,995.0	0.0	2,995.0	104,000.0	311.5	0.37	0.2	0.6
09/08/2020 05:00	3,494.5	0.0	3,494.5	104,000.0	363.4	0.44	0.2	0.7
09/08/2020 06:00	3,964.2	0.0	3,964.2	104,000.0	412.3	0.49	0.2	0.8
09/08/2020 07:00	4,134.4	508.9	4,541.5	104,000.0	472.3	0.58	0.3	1.0
09/08/2020 08:00	4,129.6	850.8	4,980.4	104,000.0	518.0	0.62	0.3	1.0
09/08/2020 09:00	4,107.7	1,304.8	5,412.5	104,000.0	562.9	0.68	0.3	1.1
09/08/2020 10:00	4,086.8	637.5	4,724.3	104,000.0	491.3	0.59	0.3	1.0
09/08/2020 11:00	3,829.3	0.0	3,829.3	104,000.0	398.2	0.48	0.2	0.8
09/08/2020 12:00	3,759.7	0.0	3,759.7	104,000.0	391.0	0.47	0.2	0.8
09/08/2020 13:00	3,729.9	0.0	3,729.9	104,000.0	387.9	0.47	0.2	0.8
09/08/2020 14:00	3,033.0	0.0	3,033.0	104,000.0	315.4	0.38	0.2	0.6
09/08/2020 15:00	2,876.4	0.0	2,876.4	104,000.0	299.1	0.36	0.2	0.6
09/08/2020 16:00	2,860.2	0.0	2,860.2	104,000.0	297.5	0.36	0.2	0.6
09/08/2020 17:00	2,864.5	0.0	2,864.5	104,000.0	297.9	0.36	0.2	0.6
09/08/2020 18:00	2,929.8	0.0	2,929.8	104,000.0	304.7	0.37	0.2	0.6
09/08/2020 19:00	2,991.7	0.0	2,991.7	104,000.0	311.1	0.37	0.2	0.6
09/08/2020 20:00	2,917.4	0.0	2,917.4	104,000.0	303.4	0.37	0.2	0.6
09/08/2020 21:00	3,973.4	0.0	3,973.4	104,000.0	413.2	0.50	0.2	0.8
09/08/2020 22:00	3,640.8	0.0	3,640.8	104,000.0	378.6	0.45	0.2	0.8
09/08/2020 23:00	2,928.2	0.0	2,928.2	104,000.0	304.5	0.37	0.2	0.6
Average/Sum#:	3,426.6	137.6	3,559.9	104,000.0	370.2	0.45	0.2	0.7
Minimum:	2,860.2	0.0	2,860.2	104,000.0	297.5	0.36	0.2	0.6
Maximum:	4,134.4	1,304.8	5,412.5	104,000.0	562.9	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2020 00:00	2,861.2	0.0	2,861.2	104,000.0	297.6	0.36	0.2	0.6
09/09/2020 01:00	2,854.5	0.0	2,854.5	104,000.0	296.9	0.36	0.2	0.6
09/09/2020 02:00	2,855.4	0.0	2,855.4	104,000.0	297.0	0.36	0.2	0.6
09/09/2020 03:00	2,861.0	0.0	2,861.0	104,000.0	297.5	0.36	0.2	0.6
09/09/2020 04:00	2,860.2	0.0	2,860.2	104,000.0	297.5	0.36	0.2	0.6
09/09/2020 05:00	2,880.6	0.0	2,880.6	104,000.0	299.6	0.36	0.2	0.6
09/09/2020 06:00	3,508.2	0.7	3,508.2	104,000.0	364.9	0.44	0.2	0.7
09/09/2020 07:00	4,224.5	1,845.1	6,069.6	104,000.0	631.2	0.76	0.4	1.3
09/09/2020 08:00	4,205.1	2,026.2	6,231.3	104,000.0	648.1	0.78	0.4	1.3
09/09/2020 09:00	4,063.2	1,942.2	6,005.4	104,000.0	624.6	0.75	0.4	1.2
09/09/2020 10:00	4,135.5	1,957.1	6,092.6	104,000.0	633.6	0.76	0.4	1.3
09/09/2020 11:00	4,135.7	1,983.9	6,119.6	104,000.0	636.4	0.76	0.4	1.3
09/09/2020 12:00	4,113.9	1,979.6	6,093.5	104,000.0	633.7	0.76	0.4	1.3
09/09/2020 13:00	4,096.1	1,979.9	6,076.0	104,000.0	631.9	0.76	0.4	1.3
09/09/2020 14:00	4,094.3	1,976.8	6,071.1	104,000.0	631.4	0.76	0.4	1.3
09/09/2020 15:00	4,101.2	1,979.4	6,080.6	104,000.0	632.4	0.76	0.4	1.3
09/09/2020 16:00	3,990.2	1,849.2	5,839.4	104,000.0	607.3	0.73	0.4	1.2
09/09/2020 17:00	3,464.2	64.8	3,472.0	104,000.0	361.1	0.44	0.2	0.7
09/09/2020 18:00	3,294.7	0.0	3,294.7	104,000.0	342.6	0.41	0.2	0.7
09/09/2020 19:00	3,488.1	0.0	3,488.1	104,000.0	362.8	0.44	0.2	0.7
09/09/2020 20:00	2,901.9	0.0	2,901.9	104,000.0	301.8	0.36	0.2	0.6
09/09/2020 21:00	2,890.8	0.0	2,890.8	104,000.0	300.6	0.36	0.2	0.6
09/09/2020 22:00	2,993.1	0.0	2,993.1	104,000.0	311.3	0.37	0.2	0.6
09/09/2020 23:00	2,939.6	0.0	2,939.6	104,000.0	305.7	0.37	0.2	0.6
Average/Sum#:	3,492.2	816.0	4,305.9	104,000.0	447.8	0.54	0.3	0.9
Minimum:	2,854.5	0.0	2,854.5	104,000.0	296.9	0.36	0.2	0.6
Maximum:	4,224.5	2,026.2	6,231.3	104,000.0	648.1	0.78	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2020 00:00	2,886.1	0.0	2,886.1	104,000.0	300.2	0.36	0.2	0.6
09/10/2020 01:00	2,899.8	0.0	2,899.8	104,000.0	301.6	0.36	0.2	0.6
09/10/2020 02:00	2,886.0	0.0	2,886.0	104,000.0	300.1	0.36	0.2	0.6
09/10/2020 03:00	2,884.2	0.0	2,884.2	104,000.0	300.0	0.36	0.2	0.6
09/10/2020 04:00	2,969.4	0.0	2,969.4	104,000.0	308.8	0.37	0.2	0.6
09/10/2020 05:00	2,877.8	0.0	2,877.8	104,000.0	299.3	0.36	0.2	0.6
09/10/2020 06:00	2,891.1	0.0	2,891.1	104,000.0	300.7	0.36	0.2	0.6
09/10/2020 07:00	2,948.7	0.0	2,948.7	104,000.0	306.7	0.37	0.2	0.6
09/10/2020 08:00	2,888.4	0.0	2,888.4	104,000.0	300.4	0.36	0.2	0.6
09/10/2020 09:00	3,154.4	0.0	3,154.4	104,000.0	328.1	0.39	0.2	0.7
09/10/2020 10:00	3,205.8	0.0	3,205.8	104,000.0	333.4	0.40	0.2	0.7
09/10/2020 11:00	3,803.9	0.0	3,803.9	104,000.0	395.6	0.48	0.2	0.8
09/10/2020 12:00	3,795.2	0.0	3,795.2	104,000.0	394.7	0.47	0.2	0.8
09/10/2020 13:00	3,944.6	274.2	4,185.9	104,000.0	435.3	0.53	0.3	0.9
09/10/2020 14:00	3,985.3	136.1	4,026.1	104,000.0	418.7	0.51	0.3	0.9
09/10/2020 15:00	4,115.4	97.2	4,183.4	104,000.0	435.1	0.52	0.3	0.9
09/10/2020 16:00	4,045.1	8.3	4,045.7	104,000.0	420.8	0.51	0.3	0.8
09/10/2020 17:00	4,135.3	139.7	4,275.0	104,000.0	444.6	0.53	0.3	0.9
09/10/2020 18:00	3,930.9	38.0	3,939.6	104,000.0	409.7	0.50	0.2	0.8
09/10/2020 19:00	4,177.9	1,161.2	5,339.1	104,000.0	555.3	0.67	0.3	1.1
09/10/2020 20:00	4,187.1	259.8	4,446.9	104,000.0	462.5	0.56	0.3	0.9
09/10/2020 21:00	4,170.9	137.1	4,284.7	104,000.0	445.6	0.54	0.3	0.9
09/10/2020 22:00	3,809.4	0.0	3,809.4	104,000.0	396.2	0.48	0.2	0.8
09/10/2020 23:00	3,275.1	0.0	3,275.1	104,000.0	340.6	0.41	0.2	0.7
Average/Sum#:	3,494.5	93.8	3,579.2	104,000.0	372.3	0.45	0.2	0.8
Minimum:	2,877.8	0.0	2,877.8	104,000.0	299.3	0.36	0.2	0.6
Maximum:	4,187.1	1,161.2	5,339.1	104,000.0	555.3	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2020 00:00	3,165.0	0.0	3,165.0	104,000.0	329.2	0.39	0.2	0.7
09/11/2020 01:00	2,876.5	0.0	2,876.5	104,000.0	299.2	0.36	0.2	0.6
09/11/2020 02:00	2,873.9	0.0	2,873.9	104,000.0	298.9	0.36	0.2	0.6
09/11/2020 03:00	2,887.8	0.0	2,887.8	104,000.0	300.3	0.36	0.2	0.6
09/11/2020 04:00	3,190.6	0.0	3,190.6	104,000.0	331.8	0.40	0.2	0.7
09/11/2020 05:00	2,878.9	0.0	2,878.9	104,000.0	299.4	0.36	0.2	0.6
09/11/2020 06:00	2,877.4	0.0	2,877.4	104,000.0	299.2	0.36	0.2	0.6
09/11/2020 07:00	2,957.4	0.0	2,957.4	104,000.0	307.6	0.37	0.2	0.6
09/11/2020 08:00	3,169.2	0.0	3,169.2	104,000.0	329.6	0.40	0.2	0.7
09/11/2020 09:00	3,663.9	0.0	3,663.9	104,000.0	381.0	0.46	0.2	0.8
09/11/2020 10:00	3,947.7	0.0	3,947.7	104,000.0	410.6	0.49	0.2	0.8
09/11/2020 11:00	4,009.3	9.4	4,010.0	104,000.0	417.0	0.50	0.3	0.8
09/11/2020 12:00	4,051.2	203.4	4,254.6	104,000.0	442.5	0.53	0.3	0.9
09/11/2020 13:00	4,135.9	503.2	4,639.1	104,000.0	482.5	0.58	0.3	1.0
09/11/2020 14:00	4,127.0	917.5	5,017.0	104,000.0	521.8	0.63	0.3	1.0
09/11/2020 15:00	3,423.8	0.0	3,423.8	104,000.0	356.1	0.43	0.2	0.7
09/11/2020 16:00	3,477.3	0.0	3,477.3	104,000.0	361.6	0.44	0.2	0.7
09/11/2020 17:00	4,043.6	0.0	4,043.6	104,000.0	420.5	0.50	0.3	0.8
09/11/2020 18:00	3,820.5	0.0	3,820.5	104,000.0	397.3	0.48	0.2	0.8
09/11/2020 19:00	3,028.4	0.0	3,028.4	104,000.0	315.0	0.38	0.2	0.6
09/11/2020 20:00	3,674.4	0.0	3,674.4	104,000.0	382.1	0.46	0.2	0.8
09/11/2020 21:00	4,006.2	0.0	4,006.2	104,000.0	416.6	0.50	0.2	0.8
09/11/2020 22:00	3,594.0	0.0	3,594.0	104,000.0	373.8	0.45	0.2	0.7
09/11/2020 23:00	3,479.6	0.0	3,479.6	104,000.0	361.9	0.43	0.2	0.7
Average/Sum#:	3,473.3	68.1	3,539.9	104,000.0	368.1	0.44	0.2	0.7
Minimum:	2,873.9	0.0	2,873.9	104,000.0	298.9	0.36	0.2	0.6
Maximum:	4,135.9	917.5	5,017.0	104,000.0	521.8	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2020 00:00	2,892.9	0.0	2,892.9	104,000.0	300.9	0.36	0.2	0.6
09/12/2020 01:00	2,883.9	0.0	2,883.9	104,000.0	299.9	0.36	0.2	0.6
09/12/2020 02:00	2,887.9	0.0	2,887.9	104,000.0	300.3	0.36	0.2	0.6
09/12/2020 03:00	2,881.2	0.0	2,881.2	104,000.0	299.6	0.36	0.2	0.6
09/12/2020 04:00	2,879.3	0.0	2,879.3	104,000.0	299.4	0.36	0.2	0.6
09/12/2020 05:00	2,887.0	0.0	2,887.0	104,000.0	300.2	0.36	0.2	0.6
09/12/2020 06:00	2,899.8	0.0	2,899.8	104,000.0	301.6	0.36	0.2	0.6
09/12/2020 07:00	2,906.2	0.0	2,906.2	104,000.0	302.2	0.36	0.2	0.6
09/12/2020 08:00	2,977.3	0.0	2,977.3	104,000.0	309.6	0.37	0.2	0.6
09/12/2020 09:00	3,085.4	0.0	3,085.4	104,000.0	320.9	0.39	0.2	0.6
09/12/2020 10:00	3,348.0	0.0	3,348.0	104,000.0	348.2	0.42	0.2	0.7
09/12/2020 11:00	3,520.9	0.0	3,520.9	104,000.0	366.2	0.44	0.2	0.7
09/12/2020 12:00	4,000.7	59.2	4,007.8	104,000.0	416.8	0.51	0.3	0.8
09/12/2020 13:00	4,059.3	1,217.8	5,277.1	104,000.0	548.8	0.66	0.3	1.1
09/12/2020 14:00	4,038.1	1,688.4	5,726.5	104,000.0	595.6	0.71	0.4	1.2
09/12/2020 15:00	4,024.6	359.4	4,384.0	104,000.0	455.9	0.55	0.3	0.9
09/12/2020 16:00	4,025.4	499.9	4,525.3	104,000.0	470.6	0.57	0.3	0.9
09/12/2020 17:00	4,032.4	1,509.6	5,542.0	104,000.0	576.4	0.69	0.3	1.2
09/12/2020 18:00	3,984.6	80.9	3,998.4	104,000.0	415.8	0.51	0.3	0.8
09/12/2020 19:00	3,598.5	0.0	3,598.5	104,000.0	374.2	0.45	0.2	0.7
09/12/2020 20:00	3,408.7	0.0	3,408.7	104,000.0	354.5	0.42	0.2	0.7
09/12/2020 21:00	4,034.4	75.2	4,066.7	104,000.0	422.9	0.51	0.3	0.9
09/12/2020 22:00	3,713.8	12.4	3,714.8	104,000.0	386.3	0.47	0.2	0.8
09/12/2020 23:00	3,491.6	0.0	3,491.6	104,000.0	363.1	0.44	0.2	0.7
Average/Sum#:	3,435.9	229.3	3,658.0	104,000.0	380.4	0.46	0.2	0.8
Minimum:	2,879.3	0.0	2,879.3	104,000.0	299.4	0.36	0.2	0.6
Maximum:	4,059.3	1,688.4	5,726.5	104,000.0	595.6	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2020 00:00	3,042.9	0.0	3,042.9	104,000.0	316.5	0.38	0.2	0.6
09/13/2020 01:00	2,905.8	0.0	2,905.8	104,000.0	302.2	0.36	0.2	0.6
09/13/2020 02:00	2,882.8	0.0	2,882.8	104,000.0	299.8	0.36	0.2	0.6
09/13/2020 03:00	2,893.0	0.0	2,893.0	104,000.0	300.9	0.36	0.2	0.6
09/13/2020 04:00	2,891.2	0.0	2,891.2	104,000.0	300.7	0.36	0.2	0.6
09/13/2020 05:00	2,876.7	0.0	2,876.7	104,000.0	299.2	0.36	0.2	0.6
09/13/2020 06:00	2,876.8	0.0	2,876.8	104,000.0	299.2	0.36	0.2	0.6
09/13/2020 07:00	2,900.9	0.0	2,900.9	104,000.0	301.7	0.36	0.2	0.6
09/13/2020 08:00	3,162.5	0.0	3,162.5	104,000.0	328.9	0.40	0.2	0.7
09/13/2020 09:00	3,489.5	0.0	3,489.5	104,000.0	362.9	0.44	0.2	0.7
09/13/2020 10:00	3,985.4	15.3	3,986.6	104,000.0	414.6	0.50	0.2	0.8
09/13/2020 11:00	4,117.5	411.7	4,516.8	104,000.0	469.7	0.56	0.3	0.9
09/13/2020 12:00	4,090.9	602.2	4,693.1	104,000.0	488.1	0.59	0.3	1.0
09/13/2020 13:00	4,061.0	1,077.8	5,138.8	104,000.0	534.4	0.64	0.3	1.1
09/13/2020 14:00	4,042.7	1,326.8	5,369.5	104,000.0	558.4	0.67	0.3	1.1
09/13/2020 15:00	4,032.0	1,071.1	5,103.1	104,000.0	530.7	0.64	0.3	1.1
09/13/2020 16:00	4,034.0	215.4	4,249.4	104,000.0	441.9	0.53	0.3	0.9
09/13/2020 17:00	4,032.4	301.9	4,334.3	104,000.0	450.8	0.54	0.3	0.9
09/13/2020 18:00	4,011.7	338.0	4,292.2	104,000.0	446.4	0.54	0.3	0.9
09/13/2020 19:00	3,474.7	0.0	3,474.7	104,000.0	361.4	0.44	0.2	0.7
09/13/2020 20:00	4,003.9	782.4	4,614.2	104,000.0	479.9	0.60	0.3	1.0
09/13/2020 21:00	4,084.1	257.5	4,341.6	104,000.0	451.5	0.54	0.3	0.9
09/13/2020 22:00	3,868.1	63.4	3,885.2	104,000.0	404.1	0.49	0.2	0.8
09/13/2020 23:00	3,229.7	0.0	3,229.7	104,000.0	335.9	0.40	0.2	0.7
Average/Sum#:	3,541.3	269.3	3,798.0	104,000.0	395.0	0.48	0.2	0.8
Minimum:	2,876.7	0.0	2,876.7	104,000.0	299.2	0.36	0.2	0.6
Maximum:	4,117.5	1,326.8	5,369.5	104,000.0	558.4	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2020 00:00	2,890.8	0.0	2,890.8	104,000.0	300.6	0.36	0.2	0.6
09/14/2020 01:00	2,876.6	0.0	2,876.6	104,000.0	299.2	0.36	0.2	0.6
09/14/2020 02:00	2,878.2	0.0	2,878.2	104,000.0	299.3	0.36	0.2	0.6
09/14/2020 03:00	2,875.9	0.0	2,875.9	104,000.0	299.1	0.36	0.2	0.6
09/14/2020 04:00	2,879.0	0.0	2,879.0	104,000.0	299.4	0.36	0.2	0.6
09/14/2020 05:00	2,877.5	0.0	2,877.5	104,000.0	299.3	0.36	0.2	0.6
09/14/2020 06:00	2,904.7	0.0	2,904.7	104,000.0	302.1	0.36	0.2	0.6
09/14/2020 07:00	3,044.1	0.0	3,044.1	104,000.0	316.6	0.38	0.2	0.6
09/14/2020 08:00	3,266.2	0.0	3,266.2	104,000.0	339.7	0.41	0.2	0.7
09/14/2020 09:00	3,412.9	0.0	3,412.9	104,000.0	354.9	0.43	0.2	0.7
09/14/2020 10:00	3,631.7	0.0	3,631.7	104,000.0	377.7	0.46	0.2	0.8
09/14/2020 11:00	4,073.3	0.0	4,073.3	104,000.0	423.6	0.51	0.3	0.8
09/14/2020 12:00	4,091.5	479.4	4,556.5	104,000.0	473.9	0.57	0.3	1.0
09/14/2020 13:00	4,066.4	1,411.1	5,477.5	104,000.0	569.7	0.68	0.3	1.1
09/14/2020 14:00	4,059.1	1,877.8	5,936.9	104,000.0	617.4	0.74	0.4	1.2
09/14/2020 15:00	4,044.2	1,341.0	5,385.2	104,000.0	560.1	0.67	0.3	1.1
09/14/2020 16:00	4,046.1	1,679.3	5,725.4	104,000.0	595.4	0.71	0.4	1.2
09/14/2020 17:00	4,052.7	1,888.2	5,940.9	104,000.0	617.9	0.74	0.4	1.2
09/14/2020 18:00	4,071.8	1,473.6	5,545.4	104,000.0	576.7	0.69	0.3	1.2
09/14/2020 19:00	3,690.1	0.6	3,690.1	104,000.0	383.8	0.46	0.2	0.8
09/14/2020 20:00	3,797.6	0.0	3,797.6	104,000.0	395.0	0.47	0.2	0.8
09/14/2020 21:00	4,118.0	148.4	4,202.6	104,000.0	437.1	0.53	0.3	0.9
09/14/2020 22:00	3,729.0	0.0	3,729.0	104,000.0	387.8	0.47	0.2	0.8
09/14/2020 23:00	3,102.3	0.0	3,102.3	104,000.0	322.6	0.39	0.2	0.6
Average/Sum#:	3,520.0	429.1	3,945.8	104,000.0	410.4	0.49	0.3	0.8
Minimum:	2,875.9	0.0	2,875.9	104,000.0	299.1	0.36	0.2	0.6
Maximum:	4,118.0	1,888.2	5,940.9	104,000.0	617.9	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2020 00:00	2,883.8	0.0	2,883.8	104,000.0	299.9	0.36	0.2	0.6
09/15/2020 01:00	2,882.2	0.0	2,882.2	104,000.0	299.7	0.36	0.2	0.6
09/15/2020 02:00	2,883.0	0.0	2,883.0	104,000.0	299.8	0.36	0.2	0.6
09/15/2020 03:00	2,881.6	0.0	2,881.6	104,000.0	299.7	0.36	0.2	0.6
09/15/2020 04:00	2,901.8	0.0	2,901.8	104,000.0	301.8	0.36	0.2	0.6
09/15/2020 05:00	2,974.6	0.0	2,974.6	104,000.0	309.4	0.37	0.2	0.6
09/15/2020 06:00	2,906.8	0.0	2,906.8	104,000.0	302.3	0.36	0.2	0.6
09/15/2020 07:00	3,074.3	0.0	3,074.3	104,000.0	319.7	0.38	0.2	0.6
09/15/2020 08:00	3,393.1	0.0	3,393.1	104,000.0	352.9	0.42	0.2	0.7
09/15/2020 09:00	3,650.0	0.0	3,650.0	104,000.0	379.6	0.46	0.2	0.8
09/15/2020 10:00	4,071.4	2.0	4,071.4	104,000.0	423.4	0.51	0.3	0.8
09/15/2020 11:00	4,113.5	259.8	4,373.3	104,000.0	454.8	0.55	0.3	0.9
09/15/2020 12:00	4,079.6	1,225.1	5,304.7	104,000.0	551.7	0.66	0.3	1.1
09/15/2020 13:00	4,065.7	1,779.7	5,845.4	104,000.0	607.9	0.73	0.4	1.2
09/15/2020 14:00	4,067.5	1,866.9	5,934.4	104,000.0	617.2	0.74	0.4	1.2
09/15/2020 15:00	4,067.4	1,776.6	5,844.0	104,000.0	607.8	0.73	0.4	1.2
09/15/2020 16:00	4,073.2	1,477.6	5,550.8	104,000.0	577.3	0.69	0.3	1.2
09/15/2020 17:00	4,048.3	1,501.5	5,549.8	104,000.0	577.2	0.69	0.3	1.2
09/15/2020 18:00	4,057.9	841.5	4,899.4	104,000.0	509.5	0.61	0.3	1.0
09/15/2020 19:00	4,048.2	260.0	4,196.4	104,000.0	436.4	0.54	0.3	0.9
09/15/2020 20:00	3,588.6	0.0	3,588.6	104,000.0	373.2	0.45	0.2	0.7
09/15/2020 21:00	3,974.4	0.0	3,974.4	104,000.0	413.3	0.50	0.2	0.8
09/15/2020 22:00	3,562.8	0.0	3,562.8	104,000.0	370.5	0.44	0.2	0.7
09/15/2020 23:00	3,373.8	0.0	3,373.8	104,000.0	350.9	0.42	0.2	0.7
Average/Sum#:	3,567.6	457.9	4,020.9	104,000.0	418.2	0.50	0.3	0.8
Minimum:	2,881.6	0.0	2,881.6	104,000.0	299.7	0.36	0.2	0.6
Maximum:	4,113.5	1,866.9	5,934.4	104,000.0	617.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2020 00:00	3,105.6	0.0	3,105.6	104,000.0	323.0	0.39	0.2	0.6
09/16/2020 01:00	2,890.1	0.0	2,890.1	104,000.0	300.6	0.36	0.2	0.6
09/16/2020 02:00	2,875.8	0.0	2,875.8	104,000.0	299.1	0.36	0.2	0.6
09/16/2020 03:00	2,923.3	0.0	2,923.3	104,000.0	304.0	0.37	0.2	0.6
09/16/2020 04:00	3,166.4	0.0	3,166.4	104,000.0	329.3	0.39	0.2	0.7
09/16/2020 05:00	3,210.2	0.0	3,210.2	104,000.0	333.9	0.40	0.2	0.7
09/16/2020 06:00	3,213.5	0.0	3,213.5	104,000.0	334.2	0.40	0.2	0.7
09/16/2020 07:00	3,355.2	0.0	3,355.2	104,000.0	348.9	0.42	0.2	0.7
09/16/2020 08:00	3,696.2	0.0	3,696.2	104,000.0	384.4	0.46	0.2	0.8
09/16/2020 09:00	4,021.1	17.5	4,022.5	104,000.0	418.3	0.50	0.3	0.8
09/16/2020 10:00	4,118.1	333.0	4,451.1	104,000.0	462.9	0.56	0.3	0.9
09/16/2020 11:00	4,092.8	1,045.7	5,138.5	104,000.0	534.4	0.64	0.3	1.1
09/16/2020 12:00	4,059.0	1,641.0	5,700.0	104,000.0	592.8	0.71	0.4	1.2
09/16/2020 13:00	4,051.3	1,452.4	5,503.7	104,000.0	572.4	0.69	0.3	1.1
09/16/2020 14:00	4,045.3	1,820.5	5,865.8	104,000.0	610.0	0.73	0.4	1.2
09/16/2020 15:00	4,028.4	1,851.6	5,880.0	104,000.0	611.5	0.73	0.4	1.2
09/16/2020 16:00	4,028.1	1,883.7	5,911.8	104,000.0	614.8	0.74	0.4	1.2
09/16/2020 17:00	4,031.5	1,830.5	5,862.0	104,000.0	609.6	0.73	0.4	1.2
09/16/2020 18:00	4,034.7	1,393.7	5,428.4	104,000.0	564.6	0.68	0.3	1.1
09/16/2020 19:00	4,046.6	672.6	4,719.2	104,000.0	490.8	0.59	0.3	1.0
09/16/2020 20:00	4,056.4	358.6	4,415.0	104,000.0	459.2	0.55	0.3	0.9
09/16/2020 21:00	4,039.5	374.4	4,387.7	104,000.0	456.3	0.55	0.3	0.9
09/16/2020 22:00	3,564.4	0.0	3,564.4	104,000.0	370.7	0.44	0.2	0.7
09/16/2020 23:00	3,322.5	0.0	3,322.5	104,000.0	345.5	0.42	0.2	0.7
Average/Sum#:	3,665.7	611.5	4,275.4	104,000.0	444.6	0.53	0.3	0.9
Minimum:	2,875.8	0.0	2,875.8	104,000.0	299.1	0.36	0.2	0.6
Maximum:	4,118.1	1,883.7	5,911.8	104,000.0	614.8	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2020 00:00	2,996.1	0.0	2,996.1	104,000.0	311.6	0.37	0.2	0.6
09/17/2020 01:00	2,873.9	0.0	2,873.9	104,000.0	298.9	0.36	0.2	0.6
09/17/2020 02:00	2,872.3	0.0	2,872.3	104,000.0	298.7	0.36	0.2	0.6
09/17/2020 03:00	2,867.8	0.0	2,867.8	104,000.0	298.3	0.36	0.2	0.6
09/17/2020 04:00	3,027.0	0.0	3,027.0	104,000.0	314.8	0.38	0.2	0.6
09/17/2020 05:00	2,995.1	0.0	2,995.1	104,000.0	311.5	0.37	0.2	0.6
09/17/2020 06:00	3,099.3	0.0	3,099.3	104,000.0	322.3	0.39	0.2	0.6
09/17/2020 07:00	3,307.6	0.0	3,307.6	104,000.0	344.0	0.41	0.2	0.7
09/17/2020 08:00	3,672.0	0.0	3,672.0	104,000.0	381.9	0.46	0.2	0.8
09/17/2020 09:00	4,096.4	14.5	4,097.9	104,000.0	426.2	0.51	0.3	0.9
09/17/2020 10:00	4,098.5	239.7	4,338.2	104,000.0	451.2	0.54	0.3	0.9
09/17/2020 11:00	4,071.2	416.7	4,487.9	104,000.0	466.7	0.56	0.3	0.9
09/17/2020 12:00	4,038.0	529.1	4,567.1	104,000.0	475.0	0.57	0.3	1.0
09/17/2020 13:00	4,028.4	803.4	4,831.8	104,000.0	502.5	0.60	0.3	1.0
09/17/2020 14:00	4,013.1	1,092.4	5,105.5	104,000.0	531.0	0.64	0.3	1.1
09/17/2020 15:00	4,000.7	1,861.9	5,862.6	104,000.0	609.7	0.73	0.4	1.2
09/17/2020 16:00	3,989.0	1,887.5	5,876.5	104,000.0	611.2	0.73	0.4	1.2
09/17/2020 17:00	4,016.0	1,239.1	5,255.1	104,000.0	546.5	0.66	0.3	1.1
09/17/2020 18:00	4,050.7	975.6	5,026.3	104,000.0	522.7	0.63	0.3	1.0
09/17/2020 19:00	4,058.8	371.6	4,430.4	104,000.0	460.8	0.55	0.3	0.9
09/17/2020 20:00	4,075.5	535.4	4,610.9	104,000.0	479.5	0.58	0.3	1.0
09/17/2020 21:00	4,080.3	741.3	4,821.6	104,000.0	501.4	0.60	0.3	1.0
09/17/2020 22:00	3,887.5	12.7	3,888.1	104,000.0	404.4	0.49	0.2	0.8
09/17/2020 23:00	3,258.3	0.0	3,258.3	104,000.0	338.9	0.41	0.2	0.7
Average/Sum#:	3,644.7	446.7	4,090.4	104,000.0	425.4	0.51	0.3	0.9
Minimum:	2,867.8	0.0	2,867.8	104,000.0	298.3	0.36	0.2	0.6
Maximum:	4,098.5	1,887.5	5,876.5	104,000.0	611.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2020 00:00	2,906.7	0.0	2,906.7	104,000.0	302.3	0.36	0.2	0.6
09/18/2020 01:00	2,879.3	0.0	2,879.3	104,000.0	299.4	0.36	0.2	0.6
09/18/2020 02:00	2,881.0	0.0	2,881.0	104,000.0	299.6	0.36	0.2	0.6
09/18/2020 03:00	2,876.3	0.0	2,876.3	104,000.0	299.1	0.36	0.2	0.6
09/18/2020 04:00	2,946.5	0.0	2,946.5	104,000.0	306.4	0.37	0.2	0.6
09/18/2020 05:00	3,121.6	0.0	3,121.6	104,000.0	324.6	0.39	0.2	0.6
09/18/2020 06:00	3,232.0	0.0	3,232.0	104,000.0	336.1	0.40	0.2	0.7
09/18/2020 07:00	3,416.9	0.0	3,416.9	104,000.0	355.4	0.43	0.2	0.7
09/18/2020 08:00	4,030.0	199.4	4,209.5	104,000.0	437.8	0.53	0.3	0.9
09/18/2020 09:00	4,012.0	269.8	4,281.8	104,000.0	445.3	0.53	0.3	0.9
09/18/2020 10:00	3,974.7	596.1	4,570.8	104,000.0	475.4	0.57	0.3	1.0
09/18/2020 11:00	3,929.1	777.7	4,706.8	104,000.0	489.5	0.59	0.3	1.0
09/18/2020 12:00	4,052.8	898.6	4,951.4	104,000.0	514.9	0.62	0.3	1.0
09/18/2020 13:00	4,078.8	1,222.9	5,301.7	104,000.0	551.4	0.66	0.3	1.1
09/18/2020 14:00	4,086.2	1,192.0	5,278.2	104,000.0	548.9	0.66	0.3	1.1
09/18/2020 15:00	4,077.9	275.9	4,353.8	104,000.0	452.8	0.54	0.3	0.9
09/18/2020 16:00	4,079.2	453.7	4,532.9	104,000.0	471.4	0.57	0.3	0.9
09/18/2020 17:00	4,077.5	896.3	4,973.8	104,000.0	517.3	0.62	0.3	1.0
09/18/2020 18:00	4,089.9	199.9	4,289.8	104,000.0	446.1	0.54	0.3	0.9
09/18/2020 19:00	3,458.9	1.7	3,458.9	104,000.0	359.7	0.43	0.2	0.7
09/18/2020 20:00	4,041.0	580.5	4,493.8	104,000.0	467.4	0.58	0.3	1.0
09/18/2020 21:00	4,007.3	14.9	4,008.5	104,000.0	416.9	0.50	0.3	0.8
09/18/2020 22:00	3,417.8	0.0	3,417.8	104,000.0	355.5	0.43	0.2	0.7
09/18/2020 23:00	3,059.7	0.0	3,059.7	104,000.0	318.2	0.38	0.2	0.6
Average/Sum#:	3,613.9	315.8	3,922.9	104,000.0	408.0	0.49	0.3	0.8
Minimum:	2,876.3	0.0	2,876.3	104,000.0	299.1	0.36	0.2	0.6
Maximum:	4,089.9	1,222.9	5,301.7	104,000.0	551.4	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2020 00:00	2,877.4	0.0	2,877.4	104,000.0	299.2	0.36	0.2	0.6
09/19/2020 01:00	2,874.5	0.0	2,874.5	104,000.0	298.9	0.36	0.2	0.6
09/19/2020 02:00	2,872.8	0.0	2,872.8	104,000.0	298.8	0.36	0.2	0.6
09/19/2020 03:00	2,869.7	0.0	2,869.7	104,000.0	298.4	0.36	0.2	0.6
09/19/2020 04:00	2,868.7	0.0	2,868.7	104,000.0	298.3	0.36	0.2	0.6
09/19/2020 05:00	2,939.3	0.0	2,939.3	104,000.0	305.7	0.37	0.2	0.6
09/19/2020 06:00	2,913.2	0.0	2,913.2	104,000.0	303.0	0.36	0.2	0.6
09/19/2020 07:00	3,203.7	0.0	3,203.7	104,000.0	333.2	0.40	0.2	0.7
09/19/2020 08:00	3,393.2	0.0	3,393.2	104,000.0	352.9	0.42	0.2	0.7
09/19/2020 09:00	3,720.2	0.0	3,720.2	104,000.0	386.9	0.46	0.2	0.8
09/19/2020 10:00	4,116.1	7.7	4,116.5	104,000.0	428.1	0.51	0.3	0.9
09/19/2020 11:00	4,099.2	349.5	4,448.7	104,000.0	462.7	0.56	0.3	0.9
09/19/2020 12:00	4,082.9	852.1	4,935.0	104,000.0	513.2	0.62	0.3	1.0
09/19/2020 13:00	4,060.8	926.9	4,987.7	104,000.0	518.7	0.62	0.3	1.0
09/19/2020 14:00	4,053.3	735.4	4,788.7	104,000.0	498.0	0.60	0.3	1.0
09/19/2020 15:00	4,046.0	834.9	4,880.9	104,000.0	507.6	0.61	0.3	1.0
09/19/2020 16:00	4,039.9	102.3	4,106.4	104,000.0	427.1	0.52	0.3	0.9
09/19/2020 17:00	3,942.8	0.0	3,942.8	104,000.0	410.1	0.49	0.2	0.8
09/19/2020 18:00	4,078.5	187.7	4,191.1	104,000.0	435.9	0.53	0.3	0.9
09/19/2020 19:00	4,081.3	866.7	4,948.0	104,000.0	514.6	0.62	0.3	1.0
09/19/2020 20:00	4,049.0	7.3	4,049.4	104,000.0	421.1	0.51	0.3	0.8
09/19/2020 21:00	3,763.1	0.0	3,763.1	104,000.0	391.4	0.47	0.2	0.8
09/19/2020 22:00	3,375.8	0.0	3,375.8	104,000.0	351.1	0.42	0.2	0.7
09/19/2020 23:00	3,000.8	0.0	3,000.8	104,000.0	312.1	0.38	0.2	0.6
Average/Sum#:	3,555.1	202.9	3,752.8	104,000.0	390.3	0.47	0.2	0.8
Minimum:	2,868.7	0.0	2,868.7	104,000.0	298.3	0.36	0.2	0.6
Maximum:	4,116.1	926.9	4,987.7	104,000.0	518.7	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2020 00:00	2,875.9	0.0	2,875.9	104,000.0	299.1	0.36	0.2	0.6
09/20/2020 01:00	2,874.5	0.0	2,874.5	104,000.0	298.9	0.36	0.2	0.6
09/20/2020 02:00	2,873.8	0.0	2,873.8	104,000.0	298.9	0.36	0.2	0.6
09/20/2020 03:00	2,874.4	0.0	2,874.4	104,000.0	298.9	0.36	0.2	0.6
09/20/2020 04:00	2,873.7	0.0	2,873.7	104,000.0	298.9	0.36	0.2	0.6
09/20/2020 05:00	2,880.5	0.0	2,880.5	104,000.0	299.6	0.36	0.2	0.6
09/20/2020 06:00	2,880.2	0.0	2,880.2	104,000.0	299.5	0.36	0.2	0.6
09/20/2020 07:00	2,876.2	0.0	2,876.2	104,000.0	299.1	0.36	0.2	0.6
09/20/2020 08:00	2,915.0	0.0	2,915.0	104,000.0	303.2	0.36	0.2	0.6
09/20/2020 09:00	3,167.6	0.0	3,167.6	104,000.0	329.4	0.40	0.2	0.7
09/20/2020 10:00	3,429.4	0.0	3,429.4	104,000.0	356.7	0.43	0.2	0.7
09/20/2020 11:00	3,744.1	0.0	3,744.1	104,000.0	389.4	0.47	0.2	0.8
09/20/2020 12:00	4,095.5	753.7	4,849.2	104,000.0	504.3	0.60	0.3	1.0
09/20/2020 13:00	4,063.6	1,298.4	5,362.0	104,000.0	557.6	0.67	0.3	1.1
09/20/2020 14:00	4,057.2	1,741.3	5,798.5	104,000.0	603.0	0.72	0.4	1.2
09/20/2020 15:00	4,041.1	1,882.7	5,923.8	104,000.0	616.1	0.74	0.4	1.2
09/20/2020 16:00	4,033.1	1,035.3	5,068.4	104,000.0	527.1	0.63	0.3	1.1
09/20/2020 17:00	3,938.9	138.1	4,024.5	104,000.0	418.5	0.51	0.3	0.8
09/20/2020 18:00	4,003.4	0.0	4,003.4	104,000.0	416.4	0.50	0.2	0.8
09/20/2020 19:00	3,832.5	0.0	3,832.5	104,000.0	398.6	0.48	0.2	0.8
09/20/2020 20:00	4,056.4	559.8	4,588.2	104,000.0	477.2	0.58	0.3	1.0
09/20/2020 21:00	3,851.1	0.0	3,851.1	104,000.0	400.5	0.48	0.2	0.8
09/20/2020 22:00	3,349.6	0.0	3,349.6	104,000.0	348.4	0.42	0.2	0.7
09/20/2020 23:00	2,993.9	0.0	2,993.9	104,000.0	311.4	0.37	0.2	0.6
Average/Sum#:	3,440.9	308.7	3,746.3	104,000.0	389.6	0.47	0.2	0.8
Minimum:	2,873.7	0.0	2,873.7	104,000.0	298.9	0.36	0.2	0.6
Maximum:	4,095.5	1,882.7	5,923.8	104,000.0	616.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2020 00:00	2,878.2	0.0	2,878.2	104,000.0	299.3	0.36	0.2	0.6
09/21/2020 01:00	2,867.2	0.0	2,867.2	104,000.0	298.2	0.36	0.2	0.6
09/21/2020 02:00	2,879.0	0.0	2,879.0	104,000.0	299.4	0.36	0.2	0.6
09/21/2020 03:00	2,898.3	0.0	2,898.3	104,000.0	301.4	0.36	0.2	0.6
09/21/2020 04:00	2,897.0	0.0	2,897.0	104,000.0	301.3	0.36	0.2	0.6
09/21/2020 05:00	3,046.9	0.0	3,046.9	104,000.0	316.9	0.38	0.2	0.6
09/21/2020 06:00	3,102.3	0.0	3,102.3	104,000.0	322.6	0.39	0.2	0.6
09/21/2020 07:00	3,061.8	0.0	3,061.8	104,000.0	318.4	0.38	0.2	0.6
09/21/2020 08:00	3,780.9	0.0	3,780.9	104,000.0	393.2	0.47	0.2	0.8
09/21/2020 09:00	4,009.1	4.4	4,009.2	104,000.0	417.0	0.50	0.3	0.8
09/21/2020 10:00	4,100.4	296.8	4,397.2	104,000.0	457.3	0.55	0.3	0.9
09/21/2020 11:00	4,077.7	1,382.6	5,460.3	104,000.0	567.9	0.68	0.3	1.1
09/21/2020 12:00	4,052.8	1,611.0	5,663.8	104,000.0	589.0	0.71	0.4	1.2
09/21/2020 13:00	4,030.1	1,928.7	5,958.8	104,000.0	619.7	0.75	0.4	1.2
09/21/2020 14:00	4,026.8	1,940.3	5,967.1	104,000.0	620.6	0.74	0.4	1.2
09/21/2020 15:00	4,028.9	1,939.8	5,968.7	104,000.0	620.7	0.74	0.4	1.2
09/21/2020 16:00	4,026.1	1,704.8	5,730.9	104,000.0	596.0	0.72	0.4	1.2
09/21/2020 17:00	4,048.0	1,748.2	5,796.2	104,000.0	602.8	0.72	0.4	1.2
09/21/2020 18:00	4,060.8	1,613.6	5,674.4	104,000.0	590.1	0.71	0.4	1.2
09/21/2020 19:00	4,076.3	548.8	4,614.1	104,000.0	479.9	0.58	0.3	1.0
09/21/2020 20:00	3,883.1	0.0	3,883.1	104,000.0	403.8	0.49	0.2	0.8
09/21/2020 21:00	4,099.4	215.9	4,289.4	104,000.0	446.1	0.54	0.3	0.9
09/21/2020 22:00	3,638.2	0.0	3,638.2	104,000.0	378.4	0.45	0.2	0.8
09/21/2020 23:00	3,240.6	0.0	3,240.6	104,000.0	337.0	0.40	0.2	0.7
Average/Sum#:	3,617.1	622.3	4,237.7	104,000.0	440.7	0.53	0.3	0.9
Minimum:	2,867.2	0.0	2,867.2	104,000.0	298.2	0.36	0.2	0.6
Maximum:	4,100.4	1,940.3	5,968.7	104,000.0	620.7	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2020 00:00	3,001.5	0.0	3,001.5	104,000.0	312.2	0.37	0.2	0.6
09/22/2020 01:00	2,882.7	0.0	2,882.7	104,000.0	299.8	0.36	0.2	0.6
09/22/2020 02:00	2,880.5	0.0	2,880.5	104,000.0	299.6	0.36	0.2	0.6
09/22/2020 03:00	2,883.5	0.0	2,883.5	104,000.0	299.9	0.36	0.2	0.6
09/22/2020 04:00	2,997.2	0.0	2,997.2	104,000.0	311.7	0.37	0.2	0.6
09/22/2020 05:00	3,261.9	0.0	3,261.9	104,000.0	339.2	0.41	0.2	0.7
09/22/2020 06:00	3,365.4	0.0	3,365.4	104,000.0	350.0	0.42	0.2	0.7
09/22/2020 07:00	3,588.2	0.0	3,588.2	104,000.0	373.2	0.45	0.2	0.7
09/22/2020 08:00	3,753.6	0.0	3,753.6	104,000.0	390.4	0.47	0.2	0.8
09/22/2020 09:00	4,125.5	120.7	4,222.1	104,000.0	439.1	0.53	0.3	0.9
09/22/2020 10:00	4,134.1	749.3	4,883.4	104,000.0	507.9	0.61	0.3	1.0
09/22/2020 11:00	4,112.9	918.1	5,031.0	104,000.0	523.2	0.63	0.3	1.0
09/22/2020 12:00	4,087.1	1,437.3	5,524.4	104,000.0	574.5	0.69	0.3	1.1
09/22/2020 13:00	4,063.9	1,478.4	5,542.3	104,000.0	576.4	0.69	0.3	1.2
09/22/2020 14:00	4,057.4	1,270.0	5,327.4	104,000.0	554.0	0.67	0.3	1.1
09/22/2020 15:00	4,065.6	1,058.8	5,124.4	104,000.0	532.9	0.64	0.3	1.1
09/22/2020 16:00	4,068.1	1,398.5	5,466.6	104,000.0	568.5	0.68	0.3	1.1
09/22/2020 17:00	4,075.4	1,143.6	5,219.0	104,000.0	542.8	0.65	0.3	1.1
09/22/2020 18:00	4,088.0	766.2	4,792.9	104,000.0	498.5	0.61	0.3	1.0
09/22/2020 19:00	3,904.0	0.0	3,904.0	104,000.0	406.0	0.49	0.2	0.8
09/22/2020 20:00	4,114.3	717.9	4,674.3	104,000.0	486.1	0.60	0.3	1.0
09/22/2020 21:00	4,001.6	0.0	4,001.6	104,000.0	416.2	0.50	0.2	0.8
09/22/2020 22:00	3,427.2	0.0	3,427.2	104,000.0	356.4	0.43	0.2	0.7
09/22/2020 23:00	3,031.1	0.0	3,031.1	104,000.0	315.2	0.38	0.2	0.6
Average/Sum#:	3,665.4	460.8	4,116.1	104,000.0	428.1	0.52	0.2	0.9
Minimum:	2,880.5	0.0	2,880.5	104,000.0	299.6	0.36	0.2	0.6
Maximum:	4,134.1	1,478.4	5,542.3	104,000.0	576.4	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2020 00:00	2,887.2	0.0	2,887.2	104,000.0	300.3	0.36	0.2	0.6
09/23/2020 01:00	2,881.2	0.0	2,881.2	104,000.0	299.6	0.36	0.2	0.6
09/23/2020 02:00	2,882.2	0.0	2,882.2	104,000.0	299.7	0.36	0.2	0.6
09/23/2020 03:00	2,882.1	0.0	2,882.1	104,000.0	299.7	0.36	0.2	0.6
09/23/2020 04:00	2,897.4	0.0	2,897.4	104,000.0	301.3	0.36	0.2	0.6
09/23/2020 05:00	3,139.8	0.0	3,139.8	104,000.0	326.5	0.39	0.2	0.7
09/23/2020 06:00	3,156.8	0.0	3,156.8	104,000.0	328.3	0.39	0.2	0.7
09/23/2020 07:00	3,244.3	0.0	3,244.3	104,000.0	337.4	0.41	0.2	0.7
09/23/2020 08:00	3,637.0	0.0	3,637.0	104,000.0	378.2	0.45	0.2	0.8
09/23/2020 09:00	4,099.4	0.0	4,099.4	104,000.0	426.3	0.51	0.3	0.9
09/23/2020 10:00	4,148.3	4.2	4,148.4	104,000.0	431.4	0.52	0.3	0.9
09/23/2020 11:00	4,112.9	387.3	4,500.2	104,000.0	468.0	0.56	0.3	0.9
09/23/2020 12:00	4,084.4	649.5	4,733.9	104,000.0	492.3	0.59	0.3	1.0
09/23/2020 13:00	4,060.3	782.4	4,842.7	104,000.0	503.6	0.60	0.3	1.0
09/23/2020 14:00	4,057.8	1,438.6	5,496.4	104,000.0	571.6	0.69	0.3	1.1
09/23/2020 15:00	4,046.9	1,029.1	5,076.0	104,000.0	527.9	0.63	0.3	1.1
09/23/2020 16:00	4,046.7	1,476.8	5,523.5	104,000.0	574.4	0.69	0.3	1.1
09/23/2020 17:00	4,051.4	1,885.6	5,937.0	104,000.0	617.4	0.74	0.4	1.2
09/23/2020 18:00	4,068.2	1,767.0	5,835.2	104,000.0	606.9	0.73	0.4	1.2
09/23/2020 19:00	4,076.6	1,016.1	5,092.7	104,000.0	529.6	0.64	0.3	1.1
09/23/2020 20:00	4,087.1	390.4	4,477.5	104,000.0	465.7	0.56	0.3	0.9
09/23/2020 21:00	4,088.5	184.1	4,248.7	104,000.0	441.9	0.53	0.3	0.9
09/23/2020 22:00	3,553.9	0.0	3,553.9	104,000.0	369.6	0.46	0.2	0.8
09/23/2020 23:00	1,245.3	0.0	1,245.3	104,000.0	129.5	0.00	0.0	0.0
Average/Sum#:	3,559.8	458.8	4,017.5	104,000.0	417.8	0.52	0.3	0.9
Minimum:	1,245.3	0.0	1,245.3	104,000.0	129.5	0.36	0.2	0.6
Maximum:	4,148.3	1,885.6	5,937.0	104,000.0	617.4	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/24/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/25/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/26/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/27/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/28/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/28/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/28/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
09/28/2020 04:00	1,504.0	0.0	1,504.0	104,000.0	156.4	0.00	0.0	0.0
09/28/2020 05:00	3,086.6	0.0	3,086.6	104,000.0	321.0	0.36	0.2	0.6
09/28/2020 06:00	2,962.4	0.0	2,962.4	104,000.0	308.1	0.37	0.2	0.6
09/28/2020 07:00	3,163.4	0.0	3,163.4	104,000.0	329.0	0.40	0.2	0.7
09/28/2020 08:00	3,554.2	0.0	3,554.2	104,000.0	369.6	0.44	0.2	0.7
09/28/2020 09:00	3,555.7	0.0	3,555.7	104,000.0	369.8	0.44	0.2	0.7
09/28/2020 10:00	3,482.4	0.0	3,482.4	104,000.0	362.2	0.43	0.2	0.7
09/28/2020 11:00	3,660.3	0.0	3,660.3	104,000.0	380.7	0.46	0.2	0.8
09/28/2020 12:00	3,858.3	19.4	3,859.7	104,000.0	401.4	0.48	0.2	0.8
09/28/2020 13:00	4,012.1	1,855.0	5,867.1	104,000.0	610.2	0.73	0.4	1.2
09/28/2020 14:00	4,006.1	1,817.6	5,823.7	104,000.0	605.7	0.73	0.4	1.2
09/28/2020 15:00	4,002.9	1,760.9	5,763.8	104,000.0	599.4	0.72	0.4	1.2
09/28/2020 16:00	4,006.3	841.0	4,847.3	104,000.0	504.1	0.60	0.3	1.0
09/28/2020 17:00	4,013.2	499.0	4,512.2	104,000.0	469.3	0.56	0.3	0.9
09/28/2020 18:00	4,021.1	211.4	4,232.5	104,000.0	440.2	0.53	0.3	0.9
09/28/2020 19:00	3,854.3	18.7	3,856.2	104,000.0	401.0	0.48	0.2	0.8
09/28/2020 20:00	3,508.2	0.0	3,508.2	104,000.0	364.9	0.44	0.2	0.7
09/28/2020 21:00	2,971.8	0.0	2,971.8	104,000.0	309.1	0.37	0.2	0.6
09/28/2020 22:00	2,880.3	0.0	2,880.3	104,000.0	299.6	0.36	0.2	0.6
09/28/2020 23:00	3,474.6	0.0	3,474.6	104,000.0	361.4	0.43	0.2	0.7
Average/Sum#:	3,478.9	351.2	3,828.3	104,000.0	398.2	0.49	0.2	0.8
Minimum:	1,504.0	0.0	1,504.0	104,000.0	156.4	0.36	0.2	0.6
Maximum:	4,021.1	1,855.0	5,867.1	104,000.0	610.2	0.73	0.4	1.2
%SI	16.67	16.67	16.67	0.00	16.67	20.83	20.83	20.83

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2020 00:00	3,005.2	0.0	3,005.2	104,000.0	312.5	0.38	0.2	0.6
09/29/2020 01:00	2,881.3	0.0	2,881.3	104,000.0	299.7	0.36	0.2	0.6
09/29/2020 02:00	2,872.9	0.0	2,872.9	104,000.0	298.8	0.36	0.2	0.6
09/29/2020 03:00	2,879.1	0.0	2,879.1	104,000.0	299.4	0.36	0.2	0.6
09/29/2020 04:00	2,982.7	0.0	2,982.7	104,000.0	310.2	0.37	0.2	0.6
09/29/2020 05:00	2,871.3	0.0	2,871.3	104,000.0	298.6	0.36	0.2	0.6
09/29/2020 06:00	2,861.4	0.0	2,861.4	104,000.0	297.6	0.36	0.2	0.6
09/29/2020 07:00	3,017.8	0.0	3,017.8	104,000.0	313.9	0.38	0.2	0.6
09/29/2020 08:00	3,326.0	0.0	3,326.0	104,000.0	345.9	0.41	0.2	0.7
09/29/2020 09:00	3,526.7	0.0	3,526.7	104,000.0	366.8	0.44	0.2	0.7
09/29/2020 10:00	3,930.7	0.0	3,930.7	104,000.0	408.8	0.49	0.2	0.8
09/29/2020 11:00	4,094.9	250.9	4,315.7	104,000.0	448.8	0.54	0.3	0.9
09/29/2020 12:00	4,066.6	1,393.0	5,459.6	104,000.0	567.8	0.68	0.3	1.1
09/29/2020 13:00	4,044.0	1,543.4	5,587.4	104,000.0	581.1	0.70	0.3	1.2
09/29/2020 14:00	4,035.2	1,672.4	5,707.6	104,000.0	593.6	0.71	0.4	1.2
09/29/2020 15:00	4,033.1	1,500.6	5,533.7	104,000.0	575.5	0.69	0.3	1.2
09/29/2020 16:00	4,041.4	1,270.9	5,312.3	104,000.0	552.5	0.66	0.3	1.1
09/29/2020 17:00	4,051.3	1,350.6	5,401.9	104,000.0	561.8	0.67	0.3	1.1
09/29/2020 18:00	4,063.2	409.1	4,460.0	104,000.0	463.8	0.56	0.3	0.9
09/29/2020 19:00	3,698.5	0.0	3,698.5	104,000.0	384.6	0.46	0.2	0.8
09/29/2020 20:00	4,109.5	130.9	4,218.1	104,000.0	438.7	0.53	0.3	0.9
09/29/2020 21:00	4,129.5	781.1	4,887.2	104,000.0	508.3	0.61	0.3	1.0
09/29/2020 22:00	3,905.7	0.0	3,905.7	104,000.0	406.2	0.49	0.2	0.8
09/29/2020 23:00	2,910.6	0.0	2,910.6	104,000.0	302.7	0.36	0.2	0.6
Average/Sum#:	3,555.8	429.3	3,981.4	104,000.0	414.1	0.50	0.2	0.8
Minimum:	2,861.4	0.0	2,861.4	104,000.0	297.6	0.36	0.2	0.6
Maximum:	4,129.5	1,672.4	5,707.6	104,000.0	593.6	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:12 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2020 00:00	2,881.7	0.0	2,881.7	104,000.0	299.7	0.36	0.2	0.6
09/30/2020 01:00	2,890.6	0.0	2,890.6	104,000.0	300.6	0.36	0.2	0.6
09/30/2020 02:00	2,980.2	0.0	2,980.2	104,000.0	309.9	0.37	0.2	0.6
09/30/2020 03:00	2,889.4	0.0	2,889.4	104,000.0	300.5	0.36	0.2	0.6
09/30/2020 04:00	2,879.8	0.0	2,879.8	104,000.0	299.5	0.36	0.2	0.6
09/30/2020 05:00	2,881.5	0.0	2,881.5	104,000.0	299.7	0.36	0.2	0.6
09/30/2020 06:00	2,879.5	0.0	2,879.5	104,000.0	299.5	0.36	0.2	0.6
09/30/2020 07:00	2,881.8	0.0	2,881.8	104,000.0	299.7	0.36	0.2	0.6
09/30/2020 08:00	3,201.0	0.0	3,201.0	104,000.0	332.9	0.40	0.2	0.7
09/30/2020 09:00	3,368.6	0.0	3,368.6	104,000.0	350.3	0.42	0.2	0.7
09/30/2020 10:00	4,026.5	106.9	4,099.2	104,000.0	426.3	0.52	0.3	0.9
09/30/2020 11:00	4,084.3	291.9	4,376.2	104,000.0	455.1	0.54	0.3	0.9
09/30/2020 12:00	4,054.2	1,061.1	5,115.3	104,000.0	532.0	0.64	0.3	1.1
09/30/2020 13:00	4,018.6	1,853.5	5,872.1	104,000.0	610.7	0.73	0.4	1.2
09/30/2020 14:00	4,001.0	1,922.9	5,923.9	104,000.0	616.1	0.74	0.4	1.2
09/30/2020 15:00	3,986.6	1,645.4	5,632.0	104,000.0	585.7	0.70	0.4	1.2
09/30/2020 16:00	3,988.0	1,768.0	5,756.0	104,000.0	598.6	0.72	0.4	1.2
09/30/2020 17:00	4,015.0	1,274.0	5,289.0	104,000.0	550.1	0.66	0.3	1.1
09/30/2020 18:00	4,025.0	954.3	4,979.3	104,000.0	517.8	0.62	0.3	1.0
09/30/2020 19:00	4,030.2	373.8	4,404.0	104,000.0	458.0	0.55	0.3	0.9
09/30/2020 20:00	4,052.3	215.8	4,268.1	104,000.0	443.9	0.53	0.3	0.9
09/30/2020 21:00	4,093.3	756.6	4,849.9	104,000.0	504.4	0.60	0.3	1.0
09/30/2020 22:00	4,099.4	104.1	4,177.5	104,000.0	434.5	0.52	0.3	0.9
09/30/2020 23:00	3,680.7	0.0	3,680.7	104,000.0	382.8	0.46	0.2	0.8
Average/Sum#:	3,578.7	513.7	4,089.9	104,000.0	425.3	0.51	0.3	0.9
Minimum:	2,879.5	0.0	2,879.5	104,000.0	299.5	0.36	0.2	0.6
Maximum:	4,099.4	1,922.9	5,923.9	104,000.0	616.1	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/01/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/02/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/03/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/04/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/05/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/06/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/07/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
07/08/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/08/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,345.8	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/09/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/10/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/11/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/12/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/13/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/13/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/13/2020 03:00	1,536.3	0.0	1,536.3	103,400.0	158.9	0.0	0.0	0.0
07/13/2020 04:00	3,814.4	0.0	3,814.4	103,400.0	394.4	0.5	0.2	0.8
07/13/2020 05:00	3,975.7	0.0	3,975.7	103,400.0	411.1	0.5	0.2	0.8
07/13/2020 06:00	3,951.9	0.0	3,951.9	103,400.0	408.6	0.5	0.2	0.8
07/13/2020 07:00	2,995.2	0.0	2,995.2	103,400.0	309.7	0.4	0.2	0.6
07/13/2020 08:00	3,080.9	0.0	3,080.9	103,400.0	318.6	0.4	0.2	0.6
07/13/2020 09:00	3,474.8	0.0	3,474.8	103,400.0	359.3	0.4	0.2	0.7
07/13/2020 10:00	3,922.4	8.2	3,922.8	103,400.0	405.6	0.5	0.2	0.8
07/13/2020 11:00	3,924.5	726.9	4,651.4	103,400.0	481.0	0.6	0.3	1.0
07/13/2020 12:00	3,908.4	828.8	4,737.2	103,400.0	489.8	0.6	0.3	1.0
07/13/2020 13:00	3,896.3	659.3	4,555.6	103,400.0	471.0	0.6	0.3	0.9
07/13/2020 14:00	3,892.2	845.0	4,737.2	103,400.0	489.8	0.6	0.3	1.0
07/13/2020 15:00	3,894.1	837.4	4,731.5	103,400.0	489.2	0.6	0.3	1.0
07/13/2020 16:00	3,900.4	580.5	4,480.9	103,400.0	463.3	0.6	0.3	0.9
07/13/2020 17:00	3,894.2	813.0	4,707.2	103,400.0	486.7	0.6	0.3	1.0
07/13/2020 18:00	3,898.6	1,648.8	5,547.4	103,400.0	573.6	0.7	0.3	1.1
07/13/2020 19:00	3,923.1	897.4	4,802.6	103,400.0	496.6	0.6	0.3	1.0
07/13/2020 20:00	2,745.5	0.0	2,745.5	103,400.0	283.9	0.3	0.2	0.6
07/13/2020 21:00	2,716.8	0.0	2,716.8	103,400.0	280.9	0.3	0.2	0.6
07/13/2020 22:00	2,719.2	0.0	2,719.2	103,400.0	281.2	0.3	0.2	0.6
07/13/2020 23:00	2,723.8	0.0	2,723.8	103,400.0	281.6	0.3	0.2	0.6
Average/Sum#:	3,466.1	373.6	3,838.5	103,400.0	396.9	0.5	0.2	0.8
Minimum:	1,536.3	0.0	1,536.3	103,400.0	158.9	0.3	0.2	0.6
Maximum:	3,975.7	1,648.8	5,547.4	103,400.0	573.6	0.7	0.3	1.1
%SI	12.50	12.50	12.50	0.00	12.50	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2020 00:00	2,772.2	0.0	2,772.2	103,400.0	286.6	0.3	0.2	0.6
07/14/2020 01:00	2,917.4	0.0	2,917.4	103,400.0	301.7	0.4	0.2	0.6
07/14/2020 02:00	2,714.1	0.0	2,714.1	103,400.0	280.6	0.3	0.2	0.6
07/14/2020 03:00	2,717.1	0.0	2,717.1	103,400.0	280.9	0.3	0.2	0.6
07/14/2020 04:00	2,809.6	0.0	2,809.6	103,400.0	290.5	0.3	0.2	0.6
07/14/2020 05:00	2,717.3	0.0	2,717.3	103,400.0	281.0	0.3	0.2	0.6
07/14/2020 06:00	2,716.2	0.0	2,716.2	103,400.0	280.9	0.3	0.2	0.6
07/14/2020 07:00	2,872.8	0.0	2,872.8	103,400.0	297.0	0.4	0.2	0.6
07/14/2020 08:00	3,145.5	0.0	3,145.5	103,400.0	325.2	0.4	0.2	0.6
07/14/2020 09:00	3,472.7	0.0	3,472.7	103,400.0	359.1	0.4	0.2	0.7
07/14/2020 10:00	3,856.1	0.0	3,856.1	103,400.0	398.7	0.5	0.2	0.8
07/14/2020 11:00	3,950.5	425.9	4,355.1	103,400.0	450.3	0.5	0.3	0.9
07/14/2020 12:00	3,931.2	1,183.6	5,114.8	103,400.0	528.9	0.6	0.3	1.1
07/14/2020 13:00	3,914.7	422.3	4,337.0	103,400.0	448.4	0.5	0.3	0.9
07/14/2020 14:00	3,899.6	1,317.3	5,216.9	103,400.0	539.4	0.6	0.3	1.1
07/14/2020 15:00	3,894.0	1,829.2	5,723.2	103,400.0	591.8	0.7	0.4	1.2
07/14/2020 16:00	3,898.8	1,854.4	5,753.2	103,400.0	594.9	0.7	0.4	1.2
07/14/2020 17:00	3,900.8	1,800.6	5,701.4	103,400.0	589.5	0.7	0.4	1.2
07/14/2020 18:00	3,918.9	1,183.0	5,101.9	103,400.0	527.5	0.6	0.3	1.1
07/14/2020 19:00	3,934.1	445.5	4,348.4	103,400.0	449.6	0.5	0.3	0.9
07/14/2020 20:00	3,456.5	0.0	3,456.5	103,400.0	357.4	0.4	0.2	0.7
07/14/2020 21:00	3,289.6	0.0	3,289.6	103,400.0	340.1	0.4	0.2	0.7
07/14/2020 22:00	3,250.7	0.0	3,250.7	103,400.0	336.1	0.4	0.2	0.7
07/14/2020 23:00	2,812.1	0.0	2,812.1	103,400.0	290.8	0.3	0.2	0.6
Average/Sum#:	3,365.1	435.9	3,798.8	103,400.0	392.8	0.5	0.3	0.8
Minimum:	2,714.1	0.0	2,714.1	103,400.0	280.6	0.3	0.2	0.6
Maximum:	3,950.5	1,854.4	5,753.2	103,400.0	594.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2020 00:00	2,763.9	0.0	2,763.9	103,400.0	285.8	0.3	0.2	0.6
07/15/2020 01:00	2,727.3	0.0	2,727.3	103,400.0	282.0	0.3	0.2	0.6
07/15/2020 02:00	2,717.0	0.0	2,717.0	103,400.0	280.9	0.3	0.2	0.6
07/15/2020 03:00	2,714.9	0.0	2,714.9	103,400.0	280.7	0.3	0.2	0.6
07/15/2020 04:00	2,721.5	0.0	2,721.5	103,400.0	281.4	0.3	0.2	0.6
07/15/2020 05:00	2,720.4	0.0	2,720.4	103,400.0	281.3	0.3	0.2	0.6
07/15/2020 06:00	2,720.5	0.0	2,720.5	103,400.0	281.3	0.3	0.2	0.6
07/15/2020 07:00	2,724.8	0.0	2,724.8	103,400.0	281.7	0.3	0.2	0.6
07/15/2020 08:00	3,131.0	0.0	3,131.0	103,400.0	323.7	0.4	0.2	0.6
07/15/2020 09:00	3,467.7	0.0	3,467.7	103,400.0	358.6	0.4	0.2	0.7
07/15/2020 10:00	3,946.4	0.0	3,946.4	103,400.0	408.1	0.5	0.2	0.8
07/15/2020 11:00	3,937.7	731.3	4,632.4	103,400.0	479.0	0.6	0.3	1.0
07/15/2020 12:00	3,911.9	1,429.8	5,341.7	103,400.0	552.3	0.7	0.3	1.1
07/15/2020 13:00	3,896.3	1,484.3	5,380.6	103,400.0	556.4	0.7	0.3	1.1
07/15/2020 14:00	3,885.0	1,811.3	5,696.3	103,400.0	589.0	0.7	0.4	1.2
07/15/2020 15:00	3,883.8	1,889.3	5,773.1	103,400.0	596.9	0.7	0.4	1.2
07/15/2020 16:00	3,873.4	1,912.4	5,785.8	103,400.0	598.3	0.7	0.4	1.2
07/15/2020 17:00	3,883.1	1,882.8	5,765.9	103,400.0	596.2	0.7	0.4	1.2
07/15/2020 18:00	3,912.8	1,541.5	5,454.3	103,400.0	564.0	0.7	0.3	1.1
07/15/2020 19:00	3,921.6	357.9	4,261.6	103,400.0	440.6	0.5	0.3	0.9
07/15/2020 20:00	3,192.6	0.0	3,192.6	103,400.0	330.1	0.4	0.2	0.7
07/15/2020 21:00	2,786.7	0.0	2,786.7	103,400.0	288.1	0.3	0.2	0.6
07/15/2020 22:00	2,718.5	0.0	2,718.5	103,400.0	281.1	0.3	0.2	0.6
07/15/2020 23:00	2,719.1	0.0	2,719.1	103,400.0	281.2	0.3	0.2	0.6
Average/Sum#:	3,286.6	543.4	3,827.7	103,400.0	395.8	0.5	0.3	0.8
Minimum:	2,714.9	0.0	2,714.9	103,400.0	280.7	0.3	0.2	0.6
Maximum:	3,946.4	1,912.4	5,785.8	103,400.0	598.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2020 00:00	2,719.7	0.0	2,719.7	103,400.0	281.2	0.3	0.2	0.6
07/16/2020 01:00	2,720.1	0.0	2,720.1	103,400.0	281.3	0.3	0.2	0.6
07/16/2020 02:00	2,721.7	0.0	2,721.7	103,400.0	281.4	0.3	0.2	0.6
07/16/2020 03:00	2,723.0	0.0	2,723.0	103,400.0	281.6	0.3	0.2	0.6
07/16/2020 04:00	2,725.6	0.0	2,725.6	103,400.0	281.8	0.3	0.2	0.6
07/16/2020 05:00	2,722.4	0.0	2,722.4	103,400.0	281.5	0.3	0.2	0.6
07/16/2020 06:00	2,727.0	0.0	2,727.0	103,400.0	282.0	0.3	0.2	0.6
07/16/2020 07:00	2,736.7	0.0	2,736.7	103,400.0	283.0	0.3	0.2	0.6
07/16/2020 08:00	3,023.9	0.0	3,023.9	103,400.0	312.7	0.4	0.2	0.6
07/16/2020 09:00	3,442.3	0.0	3,442.3	103,400.0	355.9	0.4	0.2	0.7
07/16/2020 10:00	3,884.8	0.0	3,884.8	103,400.0	401.7	0.5	0.2	0.8
07/16/2020 11:00	3,937.4	397.0	4,302.6	103,400.0	444.9	0.5	0.3	0.9
07/16/2020 12:00	3,920.8	1,393.9	5,314.7	103,400.0	549.5	0.7	0.3	1.1
07/16/2020 13:00	3,898.2	1,048.3	4,946.5	103,400.0	511.5	0.6	0.3	1.0
07/16/2020 14:00	3,887.1	1,147.9	5,035.0	103,400.0	520.6	0.6	0.3	1.0
07/16/2020 15:00	3,879.1	1,944.2	5,823.3	103,400.0	602.1	0.7	0.4	1.2
07/16/2020 16:00	3,877.7	1,942.0	5,819.7	103,400.0	601.8	0.7	0.4	1.2
07/16/2020 17:00	3,896.3	1,930.1	5,826.4	103,400.0	602.4	0.7	0.4	1.2
07/16/2020 18:00	3,918.2	1,054.0	4,972.2	103,400.0	514.1	0.6	0.3	1.0
07/16/2020 19:00	3,725.6	18.8	3,727.5	103,400.0	385.4	0.5	0.2	0.8
07/16/2020 20:00	3,112.1	0.0	3,112.1	103,400.0	321.8	0.4	0.2	0.6
07/16/2020 21:00	3,051.4	0.0	3,051.4	103,400.0	315.5	0.4	0.2	0.6
07/16/2020 22:00	2,731.9	0.0	2,731.9	103,400.0	282.5	0.3	0.2	0.6
07/16/2020 23:00	2,793.1	0.0	2,793.1	103,400.0	288.8	0.3	0.2	0.6
Average/Sum#:	3,282.3	453.2	3,733.5	103,400.0	386.0	0.4	0.2	0.8
Minimum:	2,719.7	0.0	2,719.7	103,400.0	281.2	0.3	0.2	0.6
Maximum:	3,937.4	1,944.2	5,826.4	103,400.0	602.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2020 00:00	2,735.1	0.0	2,735.1	103,400.0	282.8	0.3	0.2	0.6
07/17/2020 01:00	2,725.0	0.0	2,725.0	103,400.0	281.8	0.3	0.2	0.6
07/17/2020 02:00	2,725.2	0.0	2,725.2	103,400.0	281.8	0.3	0.2	0.6
07/17/2020 03:00	2,724.8	0.0	2,724.8	103,400.0	281.7	0.3	0.2	0.6
07/17/2020 04:00	2,725.8	0.0	2,725.8	103,400.0	281.8	0.3	0.2	0.6
07/17/2020 05:00	2,726.1	0.0	2,726.1	103,400.0	281.9	0.3	0.2	0.6
07/17/2020 06:00	2,726.2	0.0	2,726.2	103,400.0	281.9	0.3	0.2	0.6
07/17/2020 07:00	2,731.6	0.0	2,731.6	103,400.0	282.4	0.3	0.2	0.6
07/17/2020 08:00	2,998.8	0.0	2,998.8	103,400.0	310.1	0.4	0.2	0.6
07/17/2020 09:00	3,364.3	0.0	3,364.3	103,400.0	347.9	0.4	0.2	0.7
07/17/2020 10:00	3,695.1	0.0	3,695.1	103,400.0	382.1	0.5	0.2	0.8
07/17/2020 11:00	3,929.8	0.0	3,929.8	103,400.0	406.3	0.5	0.2	0.8
07/17/2020 12:00	3,297.5	0.0	3,297.5	103,400.0	341.0	0.4	0.2	0.7
07/17/2020 13:00	3,855.4	0.0	3,855.4	103,400.0	398.6	0.5	0.2	0.8
07/17/2020 14:00	3,926.1	437.6	4,245.5	103,400.0	439.0	0.5	0.3	0.9
07/17/2020 15:00	3,932.3	1,493.3	5,425.6	103,400.0	561.0	0.7	0.3	1.1
07/17/2020 16:00	3,927.6	1,807.2	5,734.8	103,400.0	593.0	0.7	0.4	1.2
07/17/2020 17:00	3,926.6	1,425.9	5,352.5	103,400.0	553.4	0.7	0.3	1.1
07/17/2020 18:00	3,939.9	779.4	4,719.3	103,400.0	488.0	0.6	0.3	1.0
07/17/2020 19:00	3,796.8	131.0	3,826.9	103,400.0	395.7	0.5	0.2	0.8
07/17/2020 20:00	3,260.9	0.0	3,260.9	103,400.0	337.2	0.4	0.2	0.7
07/17/2020 21:00	3,294.2	0.0	3,294.2	103,400.0	340.6	0.4	0.2	0.7
07/17/2020 22:00	3,440.0	0.0	3,440.0	103,400.0	355.7	0.4	0.2	0.7
07/17/2020 23:00	2,980.3	0.0	2,980.3	103,400.0	308.2	0.4	0.2	0.6
Average/Sum#:	3,307.7	253.1	3,551.7	103,400.0	367.2	0.4	0.2	0.8
Minimum:	2,724.8	0.0	2,724.8	103,400.0	281.7	0.3	0.2	0.6
Maximum:	3,939.9	1,807.2	5,734.8	103,400.0	593.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2020 00:00	2,715.2	0.0	2,715.2	103,400.0	280.8	0.3	0.2	0.6
07/18/2020 01:00	2,713.0	0.0	2,713.0	103,400.0	280.5	0.3	0.2	0.6
07/18/2020 02:00	2,713.6	0.0	2,713.6	103,400.0	280.6	0.3	0.2	0.6
07/18/2020 03:00	2,714.5	0.0	2,714.5	103,400.0	280.7	0.3	0.2	0.6
07/18/2020 04:00	2,714.6	0.0	2,714.6	103,400.0	280.7	0.3	0.2	0.6
07/18/2020 05:00	2,714.2	0.0	2,714.2	103,400.0	280.6	0.3	0.2	0.6
07/18/2020 06:00	2,715.9	0.0	2,715.9	103,400.0	280.8	0.3	0.2	0.6
07/18/2020 07:00	2,724.0	0.0	2,724.0	103,400.0	281.7	0.3	0.2	0.6
07/18/2020 08:00	3,034.8	0.0	3,034.8	103,400.0	313.8	0.4	0.2	0.6
07/18/2020 09:00	3,412.3	0.0	3,412.3	103,400.0	352.8	0.4	0.2	0.7
07/18/2020 10:00	3,889.2	0.4	3,889.2	103,400.0	402.1	0.5	0.2	0.8
07/18/2020 11:00	3,937.5	736.1	4,673.6	103,400.0	483.3	0.6	0.3	1.0
07/18/2020 12:00	3,771.1	1.7	3,771.1	103,400.0	389.9	0.5	0.2	0.8
07/18/2020 13:00	3,898.9	734.0	4,632.9	103,400.0	479.0	0.6	0.3	1.0
07/18/2020 14:00	3,898.7	1,906.0	5,804.7	103,400.0	600.2	0.7	0.4	1.2
07/18/2020 15:00	3,880.4	1,975.9	5,856.3	103,400.0	605.5	0.7	0.4	1.2
07/18/2020 16:00	3,880.7	1,806.9	5,687.6	103,400.0	588.1	0.7	0.4	1.2
07/18/2020 17:00	3,880.2	1,771.3	5,651.5	103,400.0	584.4	0.7	0.4	1.2
07/18/2020 18:00	3,884.1	1,788.0	5,672.1	103,400.0	586.5	0.7	0.4	1.2
07/18/2020 19:00	3,920.5	1,140.1	5,060.6	103,400.0	523.3	0.6	0.3	1.0
07/18/2020 20:00	3,929.4	47.3	3,936.5	103,400.0	407.0	0.5	0.2	0.8
07/18/2020 21:00	3,816.3	11.9	3,817.1	103,400.0	394.7	0.5	0.2	0.8
07/18/2020 22:00	3,964.1	593.5	4,539.8	103,400.0	469.4	0.6	0.3	0.9
07/18/2020 23:00	2,795.4	0.0	2,795.4	103,400.0	289.0	0.3	0.2	0.6
Average/Sum#:	3,396.6	521.4	3,915.0	103,400.0	404.8	0.5	0.3	0.8
Minimum:	2,713.0	0.0	2,713.0	103,400.0	280.5	0.3	0.2	0.6
Maximum:	3,964.1	1,975.9	5,856.3	103,400.0	605.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2020 00:00	2,710.3	0.0	2,710.3	103,400.0	280.2	0.3	0.2	0.6
07/19/2020 01:00	2,710.7	0.0	2,710.7	103,400.0	280.3	0.3	0.2	0.6
07/19/2020 02:00	2,712.3	0.0	2,712.3	103,400.0	280.5	0.3	0.2	0.6
07/19/2020 03:00	2,713.4	0.0	2,713.4	103,400.0	280.6	0.3	0.2	0.6
07/19/2020 04:00	2,713.9	0.0	2,713.9	103,400.0	280.6	0.3	0.2	0.6
07/19/2020 05:00	2,715.1	0.0	2,715.1	103,400.0	280.7	0.3	0.2	0.6
07/19/2020 06:00	2,715.7	0.0	2,715.7	103,400.0	280.8	0.3	0.2	0.6
07/19/2020 07:00	2,713.9	0.0	2,713.9	103,400.0	280.6	0.3	0.2	0.6
07/19/2020 08:00	2,729.1	0.0	2,729.1	103,400.0	282.2	0.3	0.2	0.6
07/19/2020 09:00	3,120.9	0.0	3,120.9	103,400.0	322.7	0.4	0.2	0.6
07/19/2020 10:00	3,731.5	2.0	3,731.6	103,400.0	385.8	0.5	0.2	0.8
07/19/2020 11:00	3,927.6	479.4	4,407.0	103,400.0	455.7	0.5	0.3	0.9
07/19/2020 12:00	3,903.2	983.8	4,887.0	103,400.0	505.3	0.6	0.3	1.0
07/19/2020 13:00	3,884.0	1,174.1	5,058.1	103,400.0	523.0	0.6	0.3	1.0
07/19/2020 14:00	3,875.4	1,937.5	5,812.9	103,400.0	601.1	0.7	0.4	1.2
07/19/2020 15:00	3,879.1	1,948.1	5,827.2	103,400.0	602.5	0.7	0.4	1.2
07/19/2020 16:00	3,886.1	1,529.9	5,416.0	103,400.0	560.0	0.7	0.3	1.1
07/19/2020 17:00	3,900.9	1,794.5	5,695.4	103,400.0	588.9	0.7	0.4	1.2
07/19/2020 18:00	3,923.8	1,275.3	5,199.1	103,400.0	537.6	0.6	0.3	1.1
07/19/2020 19:00	3,939.8	158.4	4,098.2	103,400.0	423.8	0.5	0.3	0.8
07/19/2020 20:00	3,840.2	3.5	3,840.4	103,400.0	397.1	0.5	0.2	0.8
07/19/2020 21:00	3,403.4	0.0	3,403.4	103,400.0	351.9	0.4	0.2	0.7
07/19/2020 22:00	2,840.5	0.0	2,840.5	103,400.0	293.7	0.4	0.2	0.6
07/19/2020 23:00	3,219.9	0.0	3,219.9	103,400.0	332.9	0.4	0.2	0.7
Average/Sum#:	3,321.3	470.3	3,791.3	103,400.0	392.0	0.5	0.3	0.8
Minimum:	2,710.3	0.0	2,710.3	103,400.0	280.2	0.3	0.2	0.6
Maximum:	3,939.8	1,948.1	5,827.2	103,400.0	602.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2020 00:00	2,943.5	0.0	2,943.5	103,400.0	304.4	0.4	0.2	0.6
07/20/2020 01:00	2,751.6	0.0	2,751.6	103,400.0	284.5	0.3	0.2	0.6
07/20/2020 02:00	2,720.5	0.0	2,720.5	103,400.0	281.3	0.3	0.2	0.6
07/20/2020 03:00	2,785.7	0.0	2,785.7	103,400.0	288.0	0.3	0.2	0.6
07/20/2020 04:00	2,871.1	0.0	2,871.1	103,400.0	296.9	0.4	0.2	0.6
07/20/2020 05:00	2,720.4	0.0	2,720.4	103,400.0	281.3	0.3	0.2	0.6
07/20/2020 06:00	2,720.3	0.0	2,720.3	103,400.0	281.3	0.3	0.2	0.6
07/20/2020 07:00	2,717.9	0.0	2,717.9	103,400.0	281.0	0.3	0.2	0.6
07/20/2020 08:00	2,726.5	0.0	2,726.5	103,400.0	281.9	0.3	0.2	0.6
07/20/2020 09:00	3,257.2	0.0	3,257.2	103,400.0	336.8	0.4	0.2	0.7
07/20/2020 10:00	3,949.6	0.0	3,949.6	103,400.0	408.4	0.5	0.2	0.8
07/20/2020 11:00	3,959.6	0.0	3,959.6	103,400.0	409.4	0.5	0.2	0.8
07/20/2020 12:00	3,945.6	14.1	3,946.6	103,400.0	408.1	0.5	0.2	0.8
07/20/2020 13:00	3,929.6	887.2	4,816.8	103,400.0	498.1	0.6	0.3	1.0
07/20/2020 14:00	3,912.2	1,479.4	5,391.6	103,400.0	557.5	0.7	0.3	1.1
07/20/2020 15:00	3,902.2	1,645.0	5,547.2	103,400.0	573.6	0.7	0.3	1.1
07/20/2020 16:00	3,902.3	1,642.4	5,544.7	103,400.0	573.3	0.7	0.3	1.1
07/20/2020 17:00	3,913.5	1,487.0	5,400.5	103,400.0	558.4	0.7	0.3	1.1
07/20/2020 18:00	3,924.6	775.3	4,699.9	103,400.0	486.0	0.6	0.3	1.0
07/20/2020 19:00	3,951.3	606.4	4,557.7	103,400.0	471.3	0.6	0.3	0.9
07/20/2020 20:00	3,870.7	195.2	3,944.9	103,400.0	407.9	0.5	0.3	0.8
07/20/2020 21:00	3,127.5	0.0	3,127.5	103,400.0	323.4	0.4	0.2	0.6
07/20/2020 22:00	2,764.3	0.0	2,764.3	103,400.0	285.8	0.3	0.2	0.6
07/20/2020 23:00	3,093.2	0.0	3,093.2	103,400.0	319.8	0.4	0.2	0.6
Average/Sum#:	3,348.4	363.8	3,706.6	103,400.0	383.3	0.5	0.2	0.8
Minimum:	2,717.9	0.0	2,717.9	103,400.0	281.0	0.3	0.2	0.6
Maximum:	3,959.6	1,645.0	5,547.2	103,400.0	573.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2020 00:00	2,806.6	0.0	2,806.6	103,400.0	290.2	0.4	0.2	0.6
07/21/2020 01:00	2,753.0	0.0	2,753.0	103,400.0	284.7	0.3	0.2	0.6
07/21/2020 02:00	2,727.8	0.0	2,727.8	103,400.0	282.1	0.3	0.2	0.6
07/21/2020 03:00	2,823.1	0.0	2,823.1	103,400.0	291.9	0.3	0.2	0.6
07/21/2020 04:00	3,051.2	0.0	3,051.2	103,400.0	315.5	0.4	0.2	0.6
07/21/2020 05:00	1,668.5	0.0	1,668.5	103,400.0	172.5	0.0	0.0	0.0
07/21/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/21/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,638.4	0.0	2,638.4	103,400.0	272.8	0.3	0.2	0.6
Minimum:	1,668.5	0.0	1,668.5	103,400.0	172.5	0.3	0.2	0.6
Maximum:	3,051.2	0.0	3,051.2	103,400.0	315.5	0.4	0.2	0.6
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/22/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/23/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 22:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/24/2020 23:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2020 00:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 01:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 02:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 03:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 04:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 05:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 06:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 07:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 08:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 09:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 10:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 11:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 12:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 13:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 14:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 15:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 16:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 17:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 18:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 19:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 20:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 21:00	0.0	0.0	0.0	103,400.0	0.0	0.0	0.0	0.0
07/25/2020 22:00	1,460.3	0.0	1,460.3	103,400.0	151.0	0.0	0.0	0.0
07/25/2020 23:00	3,765.2	0.0	3,765.2	103,400.0	389.3	0.5	0.2	0.8
Average/Sum#:	2,612.8	0.0	2,612.8	103,400.0	270.2	0.5	0.2	0.8
Minimum:	1,460.3	0.0	1,460.3	103,400.0	151.0	0.5	0.2	0.8
Maximum:	3,765.2	0.0	3,765.2	103,400.0	389.3	0.5	0.2	0.8
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2020 00:00	3,982.6	0.0	3,982.6	103,400.0	411.8	0.5	0.2	0.8
07/26/2020 01:00	3,469.8	0.0	3,469.8	103,400.0	358.8	0.4	0.2	0.7
07/26/2020 02:00	3,170.1	0.0	3,170.1	103,400.0	327.8	0.4	0.2	0.7
07/26/2020 03:00	2,769.8	0.0	2,769.8	103,400.0	286.4	0.3	0.2	0.6
07/26/2020 04:00	2,721.7	0.0	2,721.7	103,400.0	281.4	0.3	0.2	0.6
07/26/2020 05:00	2,731.5	0.0	2,731.5	103,400.0	282.4	0.3	0.2	0.6
07/26/2020 06:00	2,874.5	0.0	2,874.5	103,400.0	297.2	0.4	0.2	0.6
07/26/2020 07:00	2,927.2	0.0	2,927.2	103,400.0	302.7	0.4	0.2	0.6
07/26/2020 08:00	2,948.7	0.0	2,948.7	103,400.0	304.9	0.4	0.2	0.6
07/26/2020 09:00	2,951.9	0.0	2,951.9	103,400.0	305.2	0.4	0.2	0.6
07/26/2020 10:00	2,961.8	0.0	2,961.8	103,400.0	306.3	0.4	0.2	0.6
07/26/2020 11:00	3,030.4	0.0	3,030.4	103,400.0	313.3	0.4	0.2	0.6
07/26/2020 12:00	3,881.2	72.9	3,937.3	103,400.0	407.1	0.5	0.2	0.8
07/26/2020 13:00	3,882.7	528.4	4,411.1	103,400.0	456.1	0.5	0.3	0.9
07/26/2020 14:00	3,883.2	878.8	4,762.0	103,400.0	492.4	0.6	0.3	1.0
07/26/2020 15:00	3,869.4	1,939.5	5,808.9	103,400.0	600.6	0.7	0.4	1.2
07/26/2020 16:00	3,863.0	1,949.9	5,812.9	103,400.0	601.1	0.7	0.4	1.2
07/26/2020 17:00	3,856.6	1,948.9	5,805.5	103,400.0	600.3	0.7	0.4	1.2
07/26/2020 18:00	3,877.1	1,935.4	5,812.5	103,400.0	601.0	0.7	0.4	1.2
07/26/2020 19:00	3,912.5	1,776.3	5,688.8	103,400.0	588.2	0.7	0.4	1.2
07/26/2020 20:00	3,936.4	1,289.4	5,225.8	103,400.0	540.3	0.6	0.3	1.1
07/26/2020 21:00	3,373.7	0.0	3,373.7	103,400.0	348.8	0.4	0.2	0.7
07/26/2020 22:00	3,656.4	0.0	3,656.4	103,400.0	378.1	0.5	0.2	0.8
07/26/2020 23:00	3,748.6	0.0	3,748.6	103,400.0	387.6	0.5	0.2	0.8
Average/Sum#:	3,428.4	513.3	3,941.0	103,400.0	407.5	0.5	0.3	0.8
Minimum:	2,721.7	0.0	2,721.7	103,400.0	281.4	0.3	0.2	0.6
Maximum:	3,982.6	1,949.9	5,812.9	103,400.0	601.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2020 00:00	3,415.1	0.0	3,415.1	103,400.0	353.1	0.4	0.2	0.7
07/27/2020 01:00	3,293.8	0.0	3,293.8	103,400.0	340.6	0.4	0.2	0.7
07/27/2020 02:00	3,115.6	0.0	3,115.6	103,400.0	322.2	0.4	0.2	0.6
07/27/2020 03:00	3,144.3	0.0	3,144.3	103,400.0	325.1	0.4	0.2	0.7
07/27/2020 04:00	2,930.1	0.0	2,930.1	103,400.0	303.0	0.4	0.2	0.6
07/27/2020 05:00	2,871.4	0.0	2,871.4	103,400.0	296.9	0.4	0.2	0.6
07/27/2020 06:00	2,921.4	0.0	2,921.4	103,400.0	302.1	0.4	0.2	0.6
07/27/2020 07:00	2,956.2	0.0	2,956.2	103,400.0	305.7	0.4	0.2	0.6
07/27/2020 08:00	3,005.7	0.0	3,005.7	103,400.0	310.8	0.4	0.2	0.6
07/27/2020 09:00	3,378.5	0.0	3,378.5	103,400.0	349.3	0.4	0.2	0.7
07/27/2020 10:00	3,941.9	244.6	4,154.7	103,400.0	429.6	0.5	0.3	0.9
07/27/2020 11:00	3,920.6	846.7	4,767.3	103,400.0	492.9	0.6	0.3	1.0
07/27/2020 12:00	3,899.4	1,499.7	5,399.1	103,400.0	558.3	0.7	0.3	1.1
07/27/2020 13:00	3,870.0	973.0	4,843.0	103,400.0	500.8	0.6	0.3	1.0
07/27/2020 14:00	3,852.2	1,924.4	5,776.6	103,400.0	597.3	0.7	0.4	1.2
07/27/2020 15:00	3,843.5	1,954.0	5,797.5	103,400.0	599.5	0.7	0.4	1.2
07/27/2020 16:00	3,842.0	1,954.2	5,796.2	103,400.0	599.3	0.7	0.4	1.2
07/27/2020 17:00	3,854.2	1,955.0	5,809.2	103,400.0	600.7	0.7	0.4	1.2
07/27/2020 18:00	3,871.6	1,901.8	5,773.4	103,400.0	597.0	0.7	0.4	1.2
07/27/2020 19:00	3,910.2	1,377.0	5,287.2	103,400.0	546.7	0.7	0.3	1.1
07/27/2020 20:00	3,933.8	1,062.4	4,964.3	103,400.0	513.3	0.6	0.3	1.0
07/27/2020 21:00	3,182.1	0.0	3,182.1	103,400.0	329.0	0.4	0.2	0.7
07/27/2020 22:00	3,275.6	0.0	3,275.6	103,400.0	338.7	0.4	0.2	0.7
07/27/2020 23:00	3,151.2	0.0	3,151.2	103,400.0	325.8	0.4	0.2	0.7
Average/Sum#:	3,474.2	653.9	4,125.4	103,400.0	426.6	0.5	0.3	0.9
Minimum:	2,871.4	0.0	2,871.4	103,400.0	296.9	0.4	0.2	0.6
Maximum:	3,941.9	1,955.0	5,809.2	103,400.0	600.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2020 00:00	2,727.0	0.0	2,727.0	103,400.0	282.0	0.3	0.2	0.6
07/28/2020 01:00	2,709.3	0.0	2,709.3	103,400.0	280.1	0.3	0.2	0.6
07/28/2020 02:00	2,723.1	0.0	2,723.1	103,400.0	281.6	0.3	0.2	0.6
07/28/2020 03:00	2,723.2	0.0	2,723.2	103,400.0	281.6	0.3	0.2	0.6
07/28/2020 04:00	2,719.1	0.0	2,719.1	103,400.0	281.2	0.3	0.2	0.6
07/28/2020 05:00	2,713.3	0.0	2,713.3	103,400.0	280.6	0.3	0.2	0.6
07/28/2020 06:00	2,714.4	0.0	2,714.4	103,400.0	280.7	0.3	0.2	0.6
07/28/2020 07:00	2,859.8	0.0	2,859.8	103,400.0	295.7	0.4	0.2	0.6
07/28/2020 08:00	3,177.3	0.0	3,177.3	103,400.0	328.5	0.4	0.2	0.7
07/28/2020 09:00	3,934.9	23.7	3,937.3	103,400.0	407.1	0.5	0.2	0.8
07/28/2020 10:00	3,938.1	1,006.0	4,944.1	103,400.0	511.2	0.6	0.3	1.0
07/28/2020 11:00	3,915.4	1,307.8	5,223.2	103,400.0	540.1	0.6	0.3	1.1
07/28/2020 12:00	3,886.4	1,389.1	5,275.5	103,400.0	545.5	0.7	0.3	1.1
07/28/2020 13:00	3,862.2	1,934.3	5,796.5	103,400.0	599.4	0.7	0.4	1.2
07/28/2020 14:00	3,848.6	1,729.1	5,577.7	103,400.0	576.7	0.7	0.3	1.2
07/28/2020 15:00	3,839.1	1,601.5	5,440.6	103,400.0	562.6	0.7	0.3	1.1
07/28/2020 16:00	3,834.7	1,477.6	5,312.3	103,400.0	549.3	0.7	0.3	1.1
07/28/2020 17:00	3,845.1	1,432.5	5,277.6	103,400.0	545.7	0.7	0.3	1.1
07/28/2020 18:00	3,867.2	685.4	4,552.6	103,400.0	470.7	0.6	0.3	0.9
07/28/2020 19:00	3,888.3	608.1	4,496.4	103,400.0	464.9	0.6	0.3	0.9
07/28/2020 20:00	3,913.3	828.9	4,742.2	103,400.0	490.3	0.6	0.3	1.0
07/28/2020 21:00	3,329.6	12.0	3,330.2	103,400.0	344.3	0.4	0.2	0.7
07/28/2020 22:00	2,812.7	0.0	2,812.7	103,400.0	290.8	0.3	0.2	0.6
07/28/2020 23:00	3,113.8	0.0	3,113.8	103,400.0	322.0	0.4	0.2	0.6
Average/Sum#:	3,370.7	584.8	3,954.1	103,400.0	408.9	0.5	0.3	0.8
Minimum:	2,709.3	0.0	2,709.3	103,400.0	280.1	0.3	0.2	0.6
Maximum:	3,938.1	1,934.3	5,796.5	103,400.0	599.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2020 00:00	2,729.1	0.0	2,729.1	103,400.0	282.2	0.3	0.2	0.6
07/29/2020 01:00	2,706.4	0.0	2,706.4	103,400.0	279.8	0.3	0.2	0.6
07/29/2020 02:00	2,707.6	0.0	2,707.6	103,400.0	280.0	0.3	0.2	0.6
07/29/2020 03:00	2,709.9	0.0	2,709.9	103,400.0	280.2	0.3	0.2	0.6
07/29/2020 04:00	2,710.3	0.0	2,710.3	103,400.0	280.2	0.3	0.2	0.6
07/29/2020 05:00	2,711.7	0.0	2,711.7	103,400.0	280.4	0.3	0.2	0.6
07/29/2020 06:00	2,712.4	0.0	2,712.4	103,400.0	280.5	0.3	0.2	0.6
07/29/2020 07:00	2,709.1	0.0	2,709.1	103,400.0	280.1	0.3	0.2	0.6
07/29/2020 08:00	2,783.6	0.0	2,783.6	103,400.0	287.8	0.3	0.2	0.6
07/29/2020 09:00	2,984.5	0.0	2,984.5	103,400.0	308.6	0.4	0.2	0.6
07/29/2020 10:00	3,813.6	61.0	3,824.0	103,400.0	395.4	0.5	0.2	0.8
07/29/2020 11:00	3,928.6	560.5	4,489.1	103,400.0	464.2	0.6	0.3	0.9
07/29/2020 12:00	3,911.0	1,549.0	5,460.0	103,400.0	564.6	0.7	0.3	1.1
07/29/2020 13:00	3,903.3	1,867.0	5,770.3	103,400.0	596.6	0.7	0.4	1.2
07/29/2020 14:00	3,893.2	1,887.6	5,780.8	103,400.0	597.7	0.7	0.4	1.2
07/29/2020 15:00	3,890.1	1,894.0	5,784.1	103,400.0	598.1	0.7	0.4	1.2
07/29/2020 16:00	3,888.8	1,899.7	5,788.5	103,400.0	598.5	0.7	0.4	1.2
07/29/2020 17:00	3,899.1	1,877.4	5,776.5	103,400.0	597.3	0.7	0.4	1.2
07/29/2020 18:00	3,911.1	1,811.8	5,722.9	103,400.0	591.7	0.7	0.4	1.2
07/29/2020 19:00	3,929.2	295.9	4,225.1	103,400.0	436.9	0.5	0.3	0.9
07/29/2020 20:00	3,940.2	1,084.3	5,024.5	103,400.0	519.5	0.6	0.3	1.0
07/29/2020 21:00	3,194.0	0.0	3,194.0	103,400.0	330.3	0.4	0.2	0.7
07/29/2020 22:00	3,377.8	0.0	3,377.8	103,400.0	349.3	0.4	0.2	0.7
07/29/2020 23:00	3,084.5	0.0	3,084.5	103,400.0	318.9	0.4	0.2	0.6
Average/Sum#:	3,334.5	616.2	3,948.6	103,400.0	408.3	0.5	0.3	0.8
Minimum:	2,706.4	0.0	2,706.4	103,400.0	279.8	0.3	0.2	0.6
Maximum:	3,940.2	1,899.7	5,788.5	103,400.0	598.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2020 00:00	2,723.5	0.0	2,723.5	103,400.0	281.6	0.3	0.2	0.6
07/30/2020 01:00	2,709.8	0.0	2,709.8	103,400.0	280.2	0.3	0.2	0.6
07/30/2020 02:00	2,712.2	0.0	2,712.2	103,400.0	280.4	0.3	0.2	0.6
07/30/2020 03:00	2,715.2	0.0	2,715.2	103,400.0	280.8	0.3	0.2	0.6
07/30/2020 04:00	2,717.1	0.0	2,717.1	103,400.0	280.9	0.3	0.2	0.6
07/30/2020 05:00	2,722.4	0.0	2,722.4	103,400.0	281.5	0.3	0.2	0.6
07/30/2020 06:00	2,720.8	0.0	2,720.8	103,400.0	281.3	0.3	0.2	0.6
07/30/2020 07:00	2,714.2	0.0	2,714.2	103,400.0	280.6	0.3	0.2	0.6
07/30/2020 08:00	2,710.9	0.0	2,710.9	103,400.0	280.3	0.3	0.2	0.6
07/30/2020 09:00	2,846.2	0.0	2,846.2	103,400.0	294.3	0.4	0.2	0.6
07/30/2020 10:00	3,523.1	0.0	3,523.1	103,400.0	364.3	0.4	0.2	0.7
07/30/2020 11:00	3,929.7	885.6	4,744.5	103,400.0	490.6	0.6	0.3	1.0
07/30/2020 12:00	3,930.3	621.1	4,551.4	103,400.0	470.6	0.6	0.3	0.9
07/30/2020 13:00	3,912.5	1,051.2	4,963.7	103,400.0	513.2	0.6	0.3	1.0
07/30/2020 14:00	3,912.1	1,512.0	5,424.1	103,400.0	560.9	0.7	0.3	1.1
07/30/2020 15:00	3,899.8	1,627.9	5,527.7	103,400.0	571.6	0.7	0.3	1.1
07/30/2020 16:00	3,888.9	1,877.4	5,766.3	103,400.0	596.2	0.7	0.4	1.2
07/30/2020 17:00	3,894.6	1,868.9	5,763.5	103,400.0	595.9	0.7	0.4	1.2
07/30/2020 18:00	3,912.4	1,556.9	5,469.3	103,400.0	565.5	0.7	0.3	1.1
07/30/2020 19:00	3,932.4	1,100.2	5,032.6	103,400.0	520.4	0.6	0.3	1.0
07/30/2020 20:00	3,962.6	936.3	4,898.9	103,400.0	506.5	0.6	0.3	1.0
07/30/2020 21:00	3,840.5	18.6	3,843.3	103,400.0	397.4	0.5	0.2	0.8
07/30/2020 22:00	3,686.0	0.0	3,686.0	103,400.0	381.1	0.5	0.2	0.8
07/30/2020 23:00	3,072.6	0.0	3,072.6	103,400.0	317.7	0.4	0.2	0.6
Average/Sum#:	3,357.9	544.0	3,898.3	103,400.0	403.1	0.5	0.3	0.8
Minimum:	2,709.8	0.0	2,709.8	103,400.0	280.2	0.3	0.2	0.6
Maximum:	3,962.6	1,877.4	5,766.3	103,400.0	596.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2020 00:00	2,735.4	0.0	2,735.4	103,400.0	282.8	0.3	0.2	0.6
07/31/2020 01:00	2,712.2	0.0	2,712.2	103,400.0	280.4	0.3	0.2	0.6
07/31/2020 02:00	2,714.3	0.0	2,714.3	103,400.0	280.7	0.3	0.2	0.6
07/31/2020 03:00	2,715.4	0.0	2,715.4	103,400.0	280.8	0.3	0.2	0.6
07/31/2020 04:00	2,716.9	0.0	2,716.9	103,400.0	280.9	0.3	0.2	0.6
07/31/2020 05:00	2,718.9	0.0	2,718.9	103,400.0	281.1	0.3	0.2	0.6
07/31/2020 06:00	2,720.5	0.0	2,720.5	103,400.0	281.3	0.3	0.2	0.6
07/31/2020 07:00	2,716.3	0.0	2,716.3	103,400.0	280.9	0.3	0.2	0.6
07/31/2020 08:00	2,709.9	0.0	2,709.9	103,400.0	280.2	0.3	0.2	0.6
07/31/2020 09:00	2,857.8	0.0	2,857.8	103,400.0	295.5	0.4	0.2	0.6
07/31/2020 10:00	3,450.0	0.8	3,450.0	103,400.0	356.7	0.4	0.2	0.7
07/31/2020 11:00	3,953.2	1,218.6	5,171.8	103,400.0	534.8	0.6	0.3	1.1
07/31/2020 12:00	3,941.5	783.3	4,724.8	103,400.0	488.5	0.6	0.3	1.0
07/31/2020 13:00	3,928.9	1,168.4	5,097.3	103,400.0	527.1	0.6	0.3	1.1
07/31/2020 14:00	3,921.3	1,866.9	5,788.2	103,400.0	598.5	0.7	0.4	1.2
07/31/2020 15:00	3,913.3	1,133.7	5,047.0	103,400.0	521.9	0.6	0.3	1.0
07/31/2020 16:00	3,924.5	1,043.0	4,967.5	103,400.0	513.6	0.6	0.3	1.0
07/31/2020 17:00	3,918.2	1,497.0	5,415.2	103,400.0	559.9	0.7	0.3	1.1
07/31/2020 18:00	3,924.0	1,322.1	5,246.1	103,400.0	542.4	0.7	0.3	1.1
07/31/2020 19:00	3,939.1	1,246.5	5,185.6	103,400.0	536.2	0.6	0.3	1.1
07/31/2020 20:00	3,954.5	631.7	4,535.7	103,400.0	469.0	0.6	0.3	0.9
07/31/2020 21:00	3,489.2	0.0	3,489.2	103,400.0	360.8	0.4	0.2	0.7
07/31/2020 22:00	3,473.4	0.0	3,473.4	103,400.0	359.1	0.4	0.2	0.7
07/31/2020 23:00	2,817.2	0.0	2,817.2	103,400.0	291.3	0.4	0.2	0.6
Average/Sum#:	3,327.7	496.3	3,821.9	103,400.0	395.2	0.5	0.2	0.8
Minimum:	2,709.9	0.0	2,709.9	103,400.0	280.2	0.3	0.2	0.6
Maximum:	3,954.5	1,866.9	5,788.2	103,400.0	598.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2020 00:00	2,710.5	0.0	2,710.5	103,400.0	280.3	0.3	0.2	0.6
08/01/2020 01:00	2,710.9	0.0	2,710.9	103,400.0	280.3	0.3	0.2	0.6
08/01/2020 02:00	2,712.5	0.0	2,712.5	103,400.0	280.5	0.3	0.2	0.6
08/01/2020 03:00	2,715.1	0.0	2,715.1	103,400.0	280.7	0.3	0.2	0.6
08/01/2020 04:00	2,714.5	0.0	2,714.5	103,400.0	280.7	0.3	0.2	0.6
08/01/2020 05:00	2,716.6	0.0	2,716.6	103,400.0	280.9	0.3	0.2	0.6
08/01/2020 06:00	2,716.9	0.0	2,716.9	103,400.0	280.9	0.3	0.2	0.6
08/01/2020 07:00	2,714.9	0.0	2,714.9	103,400.0	280.7	0.3	0.2	0.6
08/01/2020 08:00	2,725.0	0.0	2,725.0	103,400.0	281.8	0.3	0.2	0.6
08/01/2020 09:00	3,054.1	0.0	3,054.1	103,400.0	315.8	0.4	0.2	0.6
08/01/2020 10:00	3,379.1	0.0	3,379.1	103,400.0	349.4	0.4	0.2	0.7
08/01/2020 11:00	3,471.9	0.0	3,471.9	103,400.0	359.0	0.4	0.2	0.7
08/01/2020 12:00	3,642.9	0.0	3,642.9	103,400.0	376.7	0.5	0.2	0.8
08/01/2020 13:00	3,546.7	0.0	3,546.7	103,400.0	366.7	0.4	0.2	0.7
08/01/2020 14:00	3,432.8	9.2	3,433.3	103,400.0	355.0	0.4	0.2	0.7
08/01/2020 15:00	3,887.9	1,868.5	5,756.4	103,400.0	595.2	0.7	0.4	1.2
08/01/2020 16:00	3,906.7	1,818.9	5,725.6	103,400.0	592.0	0.7	0.4	1.2
08/01/2020 17:00	3,918.9	1,779.9	5,698.8	103,400.0	589.3	0.7	0.4	1.2
08/01/2020 18:00	3,906.9	1,545.8	5,452.7	103,400.0	563.8	0.7	0.3	1.1
08/01/2020 19:00	3,925.0	1,243.3	5,168.3	103,400.0	534.4	0.6	0.3	1.1
08/01/2020 20:00	3,935.9	485.8	4,421.7	103,400.0	457.2	0.5	0.3	0.9
08/01/2020 21:00	3,932.6	186.8	4,104.5	103,400.0	424.4	0.5	0.3	0.9
08/01/2020 22:00	3,414.7	0.0	3,414.7	103,400.0	353.1	0.4	0.2	0.7
08/01/2020 23:00	3,141.3	0.0	3,141.3	103,400.0	324.8	0.4	0.2	0.6
Average/Sum#:	3,288.9	372.4	3,660.4	103,400.0	378.5	0.4	0.2	0.8
Minimum:	2,710.5	0.0	2,710.5	103,400.0	280.3	0.3	0.2	0.6
Maximum:	3,935.9	1,868.5	5,756.4	103,400.0	595.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2020 00:00	2,731.6	0.0	2,731.6	103,400.0	282.4	0.3	0.2	0.6
08/02/2020 01:00	2,698.7	0.0	2,698.7	103,400.0	279.0	0.3	0.2	0.6
08/02/2020 02:00	2,696.6	0.0	2,696.6	103,400.0	278.8	0.3	0.2	0.6
08/02/2020 03:00	2,698.2	0.0	2,698.2	103,400.0	279.0	0.3	0.2	0.6
08/02/2020 04:00	2,712.8	0.0	2,712.8	103,400.0	280.5	0.3	0.2	0.6
08/02/2020 05:00	2,974.2	0.0	2,974.2	103,400.0	307.5	0.4	0.2	0.6
08/02/2020 06:00	3,036.8	0.0	3,036.8	103,400.0	314.0	0.4	0.2	0.6
08/02/2020 07:00	3,070.6	0.0	3,070.6	103,400.0	317.5	0.4	0.2	0.6
08/02/2020 08:00	2,717.2	0.0	2,717.2	103,400.0	281.0	0.3	0.2	0.6
08/02/2020 09:00	2,687.1	0.0	2,687.1	103,400.0	277.8	0.3	0.2	0.6
08/02/2020 10:00	2,686.4	0.0	2,686.4	103,400.0	277.8	0.3	0.2	0.6
08/02/2020 11:00	3,259.2	0.0	3,259.2	103,400.0	337.0	0.4	0.2	0.7
08/02/2020 12:00	3,641.2	19.3	3,642.6	103,400.0	376.6	0.5	0.2	0.8
08/02/2020 13:00	3,870.5	1,242.7	5,113.2	103,400.0	528.7	0.6	0.3	1.1
08/02/2020 14:00	3,861.0	1,232.1	5,093.1	103,400.0	526.6	0.6	0.3	1.1
08/02/2020 15:00	3,863.3	1,878.1	5,741.4	103,400.0	593.7	0.7	0.4	1.2
08/02/2020 16:00	3,857.5	1,400.0	5,257.5	103,400.0	543.6	0.7	0.3	1.1
08/02/2020 17:00	3,863.0	1,739.2	5,602.2	103,400.0	579.3	0.7	0.3	1.2
08/02/2020 18:00	3,881.1	1,285.5	5,166.6	103,400.0	534.2	0.6	0.3	1.1
08/02/2020 19:00	3,899.5	1,179.9	5,079.4	103,400.0	525.2	0.6	0.3	1.1
08/02/2020 20:00	3,915.6	874.5	4,790.1	103,400.0	495.3	0.6	0.3	1.0
08/02/2020 21:00	3,681.0	1.5	3,681.0	103,400.0	380.6	0.5	0.2	0.8
08/02/2020 22:00	3,104.9	0.0	3,104.9	103,400.0	321.0	0.4	0.2	0.6
08/02/2020 23:00	3,515.9	0.0	3,515.9	103,400.0	363.5	0.4	0.2	0.7
Average/Sum#:	3,288.5	452.2	3,739.9	103,400.0	386.7	0.5	0.2	0.8
Minimum:	2,686.4	0.0	2,686.4	103,400.0	277.8	0.3	0.2	0.6
Maximum:	3,915.6	1,878.1	5,741.4	103,400.0	593.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2020 00:00	2,936.5	0.0	2,936.5	103,400.0	303.6	0.4	0.2	0.6
08/03/2020 01:00	2,712.5	0.0	2,712.5	103,400.0	280.5	0.3	0.2	0.6
08/03/2020 02:00	2,700.9	0.0	2,700.9	103,400.0	279.3	0.3	0.2	0.6
08/03/2020 03:00	2,703.0	0.0	2,703.0	103,400.0	279.5	0.3	0.2	0.6
08/03/2020 04:00	2,703.8	0.0	2,703.8	103,400.0	279.6	0.3	0.2	0.6
08/03/2020 05:00	2,708.1	0.0	2,708.1	103,400.0	280.0	0.3	0.2	0.6
08/03/2020 06:00	2,706.9	0.0	2,706.9	103,400.0	279.9	0.3	0.2	0.6
08/03/2020 07:00	2,714.1	0.0	2,714.1	103,300.0	280.4	0.3	0.2	0.6
08/03/2020 08:00	2,829.4	0.0	2,829.4	103,300.0	292.3	0.4	0.2	0.6
08/03/2020 09:00	2,738.6	0.0	2,738.6	103,300.0	282.9	0.3	0.2	0.6
08/03/2020 10:00	3,713.0	0.0	3,713.0	103,300.0	383.6	0.5	0.2	0.8
08/03/2020 11:00	3,919.3	13.0	3,920.2	103,300.0	405.0	0.5	0.2	0.8
08/03/2020 12:00	3,923.8	759.0	4,682.8	103,300.0	483.7	0.6	0.3	1.0
08/03/2020 13:00	3,913.4	894.3	4,807.7	103,300.0	496.6	0.6	0.3	1.0
08/03/2020 14:00	3,897.1	1,808.2	5,705.3	103,300.0	589.4	0.7	0.4	1.2
08/03/2020 15:00	3,884.8	1,659.4	5,544.2	103,300.0	572.7	0.7	0.3	1.1
08/03/2020 16:00	3,875.0	1,637.8	5,512.8	103,300.0	569.5	0.7	0.3	1.1
08/03/2020 17:00	3,869.4	1,682.7	5,552.1	103,300.0	573.5	0.7	0.3	1.1
08/03/2020 18:00	3,893.8	1,903.2	5,797.0	103,300.0	598.8	0.7	0.4	1.2
08/03/2020 19:00	3,922.2	972.4	4,894.6	103,300.0	505.6	0.6	0.3	1.0
08/03/2020 20:00	3,400.8	0.0	3,400.8	103,300.0	351.3	0.4	0.2	0.7
08/03/2020 21:00	3,677.2	0.0	3,677.2	103,300.0	379.9	0.5	0.2	0.8
08/03/2020 22:00	3,132.8	0.0	3,132.8	103,300.0	323.6	0.4	0.2	0.6
08/03/2020 23:00	3,393.2	0.0	3,393.2	103,300.0	350.5	0.4	0.2	0.7
Average/Sum#:	3,327.9	472.1	3,799.5	103,329.2	392.6	0.5	0.2	0.8
Minimum:	2,700.9	0.0	2,700.9	103,300.0	279.3	0.3	0.2	0.6
Maximum:	3,923.8	1,903.2	5,797.0	103,400.0	598.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2020 00:00	2,778.1	0.0	2,778.1	103,300.0	287.0	0.3	0.2	0.6
08/04/2020 01:00	2,703.2	0.0	2,703.2	103,300.0	279.2	0.3	0.2	0.6
08/04/2020 02:00	2,704.1	0.0	2,704.1	103,300.0	279.3	0.3	0.2	0.6
08/04/2020 03:00	2,707.6	0.0	2,707.6	103,300.0	279.7	0.3	0.2	0.6
08/04/2020 04:00	2,707.6	0.0	2,707.6	103,300.0	279.7	0.3	0.2	0.6
08/04/2020 05:00	2,708.9	0.0	2,708.9	103,300.0	279.8	0.3	0.2	0.6
08/04/2020 06:00	2,708.6	0.0	2,708.6	103,300.0	279.8	0.3	0.2	0.6
08/04/2020 07:00	2,710.9	0.0	2,710.9	103,300.0	280.0	0.3	0.2	0.6
08/04/2020 08:00	2,999.4	0.0	2,999.4	103,300.0	309.8	0.4	0.2	0.6
08/04/2020 09:00	3,395.4	0.0	3,395.4	103,300.0	350.7	0.4	0.2	0.7
08/04/2020 10:00	3,490.7	0.0	3,490.7	103,300.0	360.6	0.4	0.2	0.7
08/04/2020 11:00	3,893.8	47.2	3,903.2	103,300.0	403.2	0.5	0.2	0.8
08/04/2020 12:00	3,907.0	918.5	4,825.5	103,300.0	498.5	0.6	0.3	1.0
08/04/2020 13:00	3,890.4	808.3	4,698.7	103,300.0	485.4	0.6	0.3	1.0
08/04/2020 14:00	3,877.7	1,543.6	5,421.3	103,300.0	560.0	0.7	0.3	1.1
08/04/2020 15:00	3,871.6	1,915.2	5,786.8	103,300.0	597.8	0.7	0.4	1.2
08/04/2020 16:00	3,870.5	1,903.7	5,774.2	103,300.0	596.5	0.7	0.4	1.2
08/04/2020 17:00	3,870.1	1,917.1	5,787.2	103,300.0	597.8	0.7	0.4	1.2
08/04/2020 18:00	3,890.4	1,787.2	5,677.6	103,300.0	586.5	0.7	0.4	1.2
08/04/2020 19:00	3,901.9	295.7	4,168.0	103,300.0	430.6	0.5	0.3	0.9
08/04/2020 20:00	3,508.3	0.0	3,508.3	103,300.0	362.4	0.4	0.2	0.7
08/04/2020 21:00	2,724.6	0.0	2,724.6	103,300.0	281.5	0.3	0.2	0.6
08/04/2020 22:00	2,708.5	0.0	2,708.5	103,300.0	279.8	0.3	0.2	0.6
08/04/2020 23:00	2,944.2	0.0	2,944.2	103,300.0	304.1	0.4	0.2	0.6
Average/Sum#:	3,269.7	464.0	3,730.9	103,300.0	385.4	0.4	0.3	0.8
Minimum:	2,703.2	0.0	2,703.2	103,300.0	279.2	0.3	0.2	0.6
Maximum:	3,907.0	1,917.1	5,787.2	103,300.0	597.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2020 00:00	2,707.1	0.0	2,707.1	103,300.0	279.6	0.3	0.2	0.6
08/05/2020 01:00	2,705.3	0.0	2,705.3	103,300.0	279.5	0.3	0.2	0.6
08/05/2020 02:00	2,707.5	0.0	2,707.5	103,300.0	279.7	0.3	0.2	0.6
08/05/2020 03:00	2,706.9	0.0	2,706.9	103,300.0	279.6	0.3	0.2	0.6
08/05/2020 04:00	2,710.6	0.0	2,710.6	103,300.0	280.0	0.3	0.2	0.6
08/05/2020 05:00	2,709.3	0.0	2,709.3	103,300.0	279.9	0.3	0.2	0.6
08/05/2020 06:00	2,709.6	0.0	2,709.6	103,300.0	279.9	0.3	0.2	0.6
08/05/2020 07:00	2,707.3	0.0	2,707.3	103,300.0	279.7	0.3	0.2	0.6
08/05/2020 08:00	2,706.2	0.0	2,706.2	103,300.0	279.6	0.3	0.2	0.6
08/05/2020 09:00	2,766.2	0.0	2,766.2	103,300.0	285.7	0.3	0.2	0.6
08/05/2020 10:00	3,015.8	0.0	3,015.8	103,300.0	311.5	0.4	0.2	0.6
08/05/2020 11:00	3,800.4	26.4	3,804.4	103,300.0	393.0	0.5	0.2	0.8
08/05/2020 12:00	3,943.1	692.6	4,635.7	103,300.0	478.9	0.6	0.3	1.0
08/05/2020 13:00	3,938.8	925.6	4,864.4	103,300.0	502.5	0.6	0.3	1.0
08/05/2020 14:00	3,939.9	1,058.4	4,998.3	103,300.0	516.3	0.6	0.3	1.0
08/05/2020 15:00	3,935.2	1,121.8	5,057.0	103,300.0	522.4	0.6	0.3	1.0
08/05/2020 16:00	3,933.1	1,002.4	4,935.5	103,300.0	509.8	0.6	0.3	1.0
08/05/2020 17:00	3,944.5	544.8	4,489.3	103,300.0	463.7	0.6	0.3	0.9
08/05/2020 18:00	3,946.4	838.0	4,700.6	103,300.0	485.6	0.6	0.3	1.0
08/05/2020 19:00	3,090.4	0.0	3,090.4	103,300.0	319.2	0.4	0.2	0.6
08/05/2020 20:00	3,237.4	0.0	3,237.4	103,300.0	334.4	0.4	0.2	0.7
08/05/2020 21:00	3,048.1	0.0	3,048.1	103,300.0	314.9	0.4	0.2	0.6
08/05/2020 22:00	1,094.6	0.0	1,094.6	103,300.0	113.1	0.0	0.0	0.0
08/05/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,130.6	270.0	3,396.0	103,300.0	350.8	0.4	0.2	0.7
Minimum:	1,094.6	0.0	1,094.6	103,300.0	113.1	0.3	0.2	0.6
Maximum:	3,946.4	1,121.8	5,057.0	103,300.0	522.4	0.6	0.3	1.0
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/06/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 14:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 15:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 16:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 17:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 18:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 19:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 20:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 21:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 22:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/07/2020 23:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/08/2020 07:00	1,392.3	0.0	1,392.3	103,300.0	143.8	0.0	0.0	0.0
08/08/2020 08:00	3,915.7	0.0	3,915.7	103,300.0	404.5	0.5	0.2	0.8
08/08/2020 09:00	3,664.6	0.0	3,664.6	103,300.0	378.6	0.5	0.2	0.8
08/08/2020 10:00	3,901.6	155.5	3,928.0	103,300.0	405.8	0.5	0.3	0.8
08/08/2020 11:00	3,889.0	1,594.8	5,483.8	103,300.0	566.5	0.7	0.3	1.1
08/08/2020 12:00	3,867.4	1,621.0	5,488.4	103,300.0	567.0	0.7	0.3	1.1
08/08/2020 13:00	3,854.5	1,631.5	5,486.0	103,300.0	566.7	0.7	0.3	1.1
08/08/2020 14:00	3,847.8	1,627.5	5,475.3	103,300.0	565.6	0.7	0.3	1.1
08/08/2020 15:00	3,841.0	1,627.7	5,468.7	103,300.0	564.9	0.7	0.3	1.1
08/08/2020 16:00	3,834.3	1,667.9	5,502.2	103,300.0	568.4	0.7	0.3	1.1
08/08/2020 17:00	3,846.0	1,242.2	5,088.2	103,300.0	525.6	0.6	0.3	1.1
08/08/2020 18:00	3,865.5	1,040.9	4,906.4	103,300.0	506.8	0.6	0.3	1.0
08/08/2020 19:00	3,878.0	568.8	4,435.4	103,300.0	458.2	0.6	0.3	0.9
08/08/2020 20:00	3,172.2	0.0	3,172.2	103,300.0	327.7	0.4	0.2	0.7
08/08/2020 21:00	3,845.2	0.0	3,845.2	103,300.0	397.2	0.5	0.2	0.8
08/08/2020 22:00	3,876.7	0.0	3,876.7	103,300.0	400.5	0.5	0.2	0.8
08/08/2020 23:00	3,036.9	0.0	3,036.9	103,300.0	313.7	0.4	0.2	0.6
Average/Sum#:	3,619.3	751.6	4,362.7	103,300.0	450.7	0.6	0.3	0.9
Minimum:	1,392.3	0.0	1,392.3	103,300.0	143.8	0.4	0.2	0.6
Maximum:	3,915.7	1,667.9	5,502.2	103,300.0	568.4	0.7	0.3	1.1
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2020 00:00	2,761.2	0.0	2,761.2	103,300.0	285.2	0.3	0.2	0.6
08/09/2020 01:00	2,696.5	0.0	2,696.5	103,300.0	278.5	0.3	0.2	0.6
08/09/2020 02:00	2,698.2	0.0	2,698.2	103,300.0	278.7	0.3	0.2	0.6
08/09/2020 03:00	2,700.2	0.0	2,700.2	103,300.0	278.9	0.3	0.2	0.6
08/09/2020 04:00	2,699.7	0.0	2,699.7	103,300.0	278.9	0.3	0.2	0.6
08/09/2020 05:00	2,701.1	0.0	2,701.1	103,300.0	279.0	0.3	0.2	0.6
08/09/2020 06:00	2,700.6	0.0	2,700.6	103,300.0	279.0	0.3	0.2	0.6
08/09/2020 07:00	2,724.3	0.0	2,724.3	103,300.0	281.4	0.3	0.2	0.6
08/09/2020 08:00	3,040.8	0.0	3,040.8	103,300.0	314.1	0.4	0.2	0.6
08/09/2020 09:00	3,852.3	25.5	3,854.9	103,300.0	398.2	0.5	0.2	0.8
08/09/2020 10:00	3,884.0	934.8	4,818.8	103,300.0	497.8	0.6	0.3	1.0
08/09/2020 11:00	3,866.0	1,388.2	5,254.2	103,300.0	542.8	0.7	0.3	1.1
08/09/2020 12:00	3,845.6	1,862.8	5,708.4	103,300.0	589.7	0.7	0.4	1.2
08/09/2020 13:00	3,835.4	1,930.8	5,766.2	103,300.0	595.6	0.7	0.4	1.2
08/09/2020 14:00	3,831.5	1,945.1	5,776.6	103,300.0	596.7	0.7	0.4	1.2
08/09/2020 15:00	3,820.4	1,907.0	5,727.4	103,300.0	591.6	0.7	0.4	1.2
08/09/2020 16:00	3,805.1	1,778.2	5,583.3	103,300.0	576.8	0.7	0.3	1.2
08/09/2020 17:00	3,807.7	1,921.9	5,729.6	103,300.0	591.9	0.7	0.4	1.2
08/09/2020 18:00	3,837.2	1,218.7	5,055.9	103,300.0	522.3	0.6	0.3	1.0
08/09/2020 19:00	3,865.4	1,903.0	5,768.4	103,300.0	595.9	0.7	0.4	1.2
08/09/2020 20:00	3,876.1	1,456.6	5,332.7	103,300.0	550.9	0.7	0.3	1.1
08/09/2020 21:00	3,899.7	878.9	4,778.6	103,300.0	493.6	0.6	0.3	1.0
08/09/2020 22:00	3,909.7	690.1	4,544.6	103,300.0	469.5	0.6	0.3	1.0
08/09/2020 23:00	3,377.3	0.0	3,377.3	103,300.0	348.9	0.4	0.2	0.7
Average/Sum#:	3,418.2	826.7	4,241.6	103,300.0	438.2	0.5	0.3	0.9
Minimum:	2,696.5	0.0	2,696.5	103,300.0	278.5	0.3	0.2	0.6
Maximum:	3,909.7	1,945.1	5,776.6	103,300.0	596.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2020 00:00	3,199.3	0.0	3,199.3	103,300.0	330.5	0.4	0.2	0.7
08/10/2020 01:00	3,118.8	0.0	3,118.8	103,300.0	322.2	0.4	0.2	0.6
08/10/2020 02:00	2,878.2	0.0	2,878.2	103,300.0	297.3	0.4	0.2	0.6
08/10/2020 03:00	2,755.7	0.0	2,755.7	103,300.0	284.7	0.3	0.2	0.6
08/10/2020 04:00	2,843.3	0.0	2,843.3	103,300.0	293.7	0.4	0.2	0.6
08/10/2020 05:00	2,696.1	0.0	2,696.1	103,300.0	278.5	0.3	0.2	0.6
08/10/2020 06:00	2,697.8	0.0	2,697.8	103,300.0	278.7	0.3	0.2	0.6
08/10/2020 07:00	2,846.9	0.0	2,846.9	103,300.0	294.1	0.4	0.2	0.6
08/10/2020 08:00	3,297.9	0.0	3,297.9	103,300.0	340.7	0.4	0.2	0.7
08/10/2020 09:00	3,836.4	9.9	3,837.1	103,300.0	396.4	0.5	0.2	0.8
08/10/2020 10:00	3,889.8	886.6	4,776.4	103,300.0	493.4	0.6	0.3	1.0
08/10/2020 11:00	3,866.1	1,566.9	5,433.0	103,300.0	561.2	0.7	0.3	1.1
08/10/2020 12:00	3,846.3	1,930.5	5,776.8	103,300.0	596.7	0.7	0.4	1.2
08/10/2020 13:00	3,826.7	1,950.5	5,777.2	103,300.0	596.8	0.7	0.4	1.2
08/10/2020 14:00	3,814.8	1,940.1	5,754.9	103,300.0	594.5	0.7	0.4	1.2
08/10/2020 15:00	3,796.5	1,930.9	5,727.4	103,300.0	591.6	0.7	0.4	1.2
08/10/2020 16:00	3,801.2	1,908.0	5,709.2	103,300.0	589.8	0.7	0.4	1.2
08/10/2020 17:00	3,830.1	1,806.4	5,636.5	103,300.0	582.3	0.7	0.3	1.2
08/10/2020 18:00	3,861.7	850.3	4,644.0	103,300.0	479.7	0.6	0.3	1.0
08/10/2020 19:00	3,533.5	0.0	3,533.5	103,300.0	365.0	0.4	0.2	0.7
08/10/2020 20:00	3,545.7	0.0	3,545.7	103,300.0	366.3	0.4	0.2	0.7
08/10/2020 21:00	3,738.3	0.0	3,738.3	103,300.0	386.2	0.5	0.2	0.8
08/10/2020 22:00	3,563.6	0.0	3,563.6	103,300.0	368.1	0.4	0.2	0.7
08/10/2020 23:00	3,547.7	0.0	3,547.7	103,300.0	366.5	0.4	0.2	0.7
Average/Sum#:	3,443.0	615.8	4,055.6	103,300.0	419.0	0.5	0.3	0.8
Minimum:	2,696.1	0.0	2,696.1	103,300.0	278.5	0.3	0.2	0.6
Maximum:	3,889.8	1,950.5	5,777.2	103,300.0	596.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2020 00:00	2,723.6	0.0	2,723.6	103,300.0	281.3	0.3	0.2	0.6
08/11/2020 01:00	2,706.8	0.0	2,706.8	103,300.0	279.6	0.3	0.2	0.6
08/11/2020 02:00	2,708.7	0.0	2,708.7	103,300.0	279.8	0.3	0.2	0.6
08/11/2020 03:00	2,709.4	0.0	2,709.4	103,300.0	279.9	0.3	0.2	0.6
08/11/2020 04:00	2,708.7	0.0	2,708.7	103,300.0	279.8	0.3	0.2	0.6
08/11/2020 05:00	2,708.4	0.0	2,708.4	103,300.0	279.8	0.3	0.2	0.6
08/11/2020 06:00	2,711.0	0.0	2,711.0	103,300.0	280.0	0.3	0.2	0.6
08/11/2020 07:00	2,722.6	0.0	2,722.6	103,300.0	281.2	0.3	0.2	0.6
08/11/2020 08:00	2,992.5	0.0	2,992.5	103,300.0	309.1	0.4	0.2	0.6
08/11/2020 09:00	3,132.3	0.0	3,132.3	103,300.0	323.6	0.4	0.2	0.6
08/11/2020 10:00	3,826.7	0.0	3,826.7	103,300.0	395.3	0.5	0.2	0.8
08/11/2020 11:00	3,930.2	253.5	4,145.7	103,300.0	428.3	0.5	0.3	0.9
08/11/2020 12:00	3,910.2	1,054.3	4,964.5	103,300.0	512.8	0.6	0.3	1.0
08/11/2020 13:00	3,889.8	757.5	4,647.3	103,300.0	480.1	0.6	0.3	1.0
08/11/2020 14:00	3,877.3	680.0	4,557.3	103,300.0	470.8	0.6	0.3	0.9
08/11/2020 15:00	3,872.0	771.1	4,643.1	103,300.0	479.6	0.6	0.3	1.0
08/11/2020 16:00	3,863.6	798.6	4,662.2	103,300.0	481.6	0.6	0.3	1.0
08/11/2020 17:00	3,875.0	608.9	4,483.9	103,300.0	463.2	0.6	0.3	0.9
08/11/2020 18:00	3,896.4	527.0	4,423.4	103,300.0	456.9	0.5	0.3	0.9
08/11/2020 19:00	3,686.5	16.9	3,688.5	103,300.0	381.0	0.5	0.2	0.8
08/11/2020 20:00	3,603.0	0.0	3,603.0	103,300.0	372.2	0.4	0.2	0.7
08/11/2020 21:00	3,922.7	0.0	3,922.7	103,300.0	405.2	0.5	0.2	0.8
08/11/2020 22:00	3,270.0	0.0	3,270.0	103,300.0	337.8	0.4	0.2	0.7
08/11/2020 23:00	2,927.9	0.0	2,927.9	103,300.0	302.5	0.4	0.2	0.6
Average/Sum#:	3,340.6	227.8	3,566.3	103,300.0	368.4	0.4	0.2	0.8
Minimum:	2,706.8	0.0	2,706.8	103,300.0	279.6	0.3	0.2	0.6
Maximum:	3,930.2	1,054.3	4,964.5	103,300.0	512.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2020 00:00	2,699.5	0.0	2,699.5	103,300.0	278.9	0.3	0.2	0.6
08/12/2020 01:00	2,702.1	0.0	2,702.1	103,300.0	279.1	0.3	0.2	0.6
08/12/2020 02:00	2,708.5	0.0	2,708.5	103,300.0	279.8	0.3	0.2	0.6
08/12/2020 03:00	2,710.4	0.0	2,710.4	103,300.0	280.0	0.3	0.2	0.6
08/12/2020 04:00	2,710.5	0.0	2,710.5	103,300.0	280.0	0.3	0.2	0.6
08/12/2020 05:00	2,711.7	0.0	2,711.7	103,300.0	280.1	0.3	0.2	0.6
08/12/2020 06:00	2,714.2	0.0	2,714.2	103,300.0	280.4	0.3	0.2	0.6
08/12/2020 07:00	2,773.3	0.0	2,773.3	103,300.0	286.5	0.3	0.2	0.6
08/12/2020 08:00	2,747.0	0.0	2,747.0	103,300.0	283.8	0.3	0.2	0.6
08/12/2020 09:00	3,053.7	0.0	3,053.7	103,300.0	315.4	0.4	0.2	0.6
08/12/2020 10:00	3,607.7	0.0	3,607.7	103,300.0	372.7	0.4	0.2	0.7
08/12/2020 11:00	3,916.1	1,154.6	5,047.6	103,300.0	521.4	0.6	0.3	1.0
08/12/2020 12:00	3,883.1	1,701.1	5,584.2	103,300.0	576.8	0.7	0.3	1.2
08/12/2020 13:00	3,855.5	1,857.9	5,713.4	103,300.0	590.2	0.7	0.4	1.2
08/12/2020 14:00	3,847.8	1,864.3	5,712.1	103,300.0	590.1	0.7	0.4	1.2
08/12/2020 15:00	3,840.6	1,879.3	5,719.9	103,300.0	590.9	0.7	0.4	1.2
08/12/2020 16:00	3,841.6	1,874.3	5,715.9	103,300.0	590.5	0.7	0.4	1.2
08/12/2020 17:00	3,849.7	1,865.7	5,715.4	103,300.0	590.4	0.7	0.4	1.2
08/12/2020 18:00	3,868.5	1,816.6	5,685.1	103,300.0	587.3	0.7	0.4	1.2
08/12/2020 19:00	3,885.9	1,345.7	5,231.6	103,300.0	540.4	0.6	0.3	1.1
08/12/2020 20:00	3,910.4	597.1	4,507.5	103,300.0	465.6	0.6	0.3	0.9
08/12/2020 21:00	3,937.4	629.1	4,566.5	103,300.0	471.7	0.6	0.3	0.9
08/12/2020 22:00	3,943.0	209.5	4,152.5	103,300.0	429.0	0.5	0.3	0.9
08/12/2020 23:00	3,654.6	14.7	3,656.4	103,300.0	377.7	0.5	0.2	0.8
Average/Sum#:	3,390.5	700.4	4,089.4	103,300.0	422.4	0.5	0.3	0.9
Minimum:	2,699.5	0.0	2,699.5	103,300.0	278.9	0.3	0.2	0.6
Maximum:	3,943.0	1,879.3	5,719.9	103,300.0	590.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2020 00:00	3,014.3	0.0	3,014.3	103,300.0	311.4	0.4	0.2	0.6
08/13/2020 01:00	2,725.4	0.0	2,725.4	103,300.0	281.5	0.3	0.2	0.6
08/13/2020 02:00	2,697.4	0.0	2,697.4	103,300.0	278.6	0.3	0.2	0.6
08/13/2020 03:00	2,697.1	0.0	2,697.1	103,300.0	278.6	0.3	0.2	0.6
08/13/2020 04:00	2,696.9	0.0	2,696.9	103,300.0	278.6	0.3	0.2	0.6
08/13/2020 05:00	2,697.7	0.0	2,697.7	103,300.0	278.7	0.3	0.2	0.6
08/13/2020 06:00	2,807.1	0.0	2,807.1	103,300.0	290.0	0.3	0.2	0.6
08/13/2020 07:00	2,880.1	0.0	2,880.1	103,300.0	297.5	0.4	0.2	0.6
08/13/2020 08:00	3,081.7	0.0	3,081.7	103,300.0	318.3	0.4	0.2	0.6
08/13/2020 09:00	3,572.4	0.0	3,572.4	103,300.0	369.0	0.4	0.2	0.7
08/13/2020 10:00	3,897.7	442.8	4,260.8	103,300.0	440.1	0.5	0.3	0.9
08/13/2020 11:00	3,870.8	1,608.4	5,479.2	103,300.0	566.0	0.7	0.3	1.1
08/13/2020 12:00	3,861.3	1,795.6	5,656.9	103,300.0	584.4	0.7	0.4	1.2
08/13/2020 13:00	3,840.4	1,835.7	5,676.1	103,300.0	586.3	0.7	0.4	1.2
08/13/2020 14:00	3,832.7	1,842.6	5,675.3	103,300.0	586.3	0.7	0.4	1.2
08/13/2020 15:00	3,829.1	1,567.6	5,396.7	103,300.0	557.5	0.7	0.3	1.1
08/13/2020 16:00	3,828.5	1,446.9	5,275.4	103,300.0	544.9	0.7	0.3	1.1
08/13/2020 17:00	3,838.8	1,765.7	5,604.5	103,300.0	578.9	0.7	0.3	1.2
08/13/2020 18:00	3,859.2	1,292.0	5,151.2	103,300.0	532.1	0.6	0.3	1.1
08/13/2020 19:00	3,885.9	472.8	4,358.7	103,300.0	450.3	0.5	0.3	0.9
08/13/2020 20:00	3,907.0	89.6	3,996.6	103,300.0	412.8	0.5	0.2	0.8
08/13/2020 21:00	3,909.4	1,480.5	5,389.9	103,300.0	556.8	0.7	0.3	1.1
08/13/2020 22:00	3,921.3	1,531.0	5,452.3	103,300.0	563.2	0.7	0.3	1.1
08/13/2020 23:00	3,610.5	60.2	3,617.7	103,300.0	373.7	0.5	0.2	0.8
Average/Sum#:	3,448.4	718.0	4,160.9	103,300.0	429.8	0.5	0.3	0.9
Minimum:	2,696.9	0.0	2,696.9	103,300.0	278.6	0.3	0.2	0.6
Maximum:	3,921.3	1,842.6	5,676.1	103,300.0	586.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2020 00:00	3,139.1	0.0	3,139.1	103,300.0	324.3	0.4	0.2	0.6
08/14/2020 01:00	3,171.0	0.0	3,171.0	103,300.0	327.6	0.4	0.2	0.7
08/14/2020 02:00	2,759.9	0.0	2,759.9	103,300.0	285.1	0.3	0.2	0.6
08/14/2020 03:00	2,696.4	0.0	2,696.4	103,300.0	278.5	0.3	0.2	0.6
08/14/2020 04:00	2,843.9	0.0	2,843.9	103,300.0	293.8	0.4	0.2	0.6
08/14/2020 05:00	3,254.1	0.0	3,254.1	103,300.0	336.1	0.4	0.2	0.7
08/14/2020 06:00	3,789.4	0.0	3,789.4	103,300.0	391.4	0.5	0.2	0.8
08/14/2020 07:00	3,952.8	446.0	4,354.2	103,300.0	449.8	0.5	0.3	0.9
08/14/2020 08:00	3,930.2	1,723.3	5,653.5	103,300.0	584.0	0.7	0.4	1.2
08/14/2020 09:00	3,911.6	1,814.4	5,726.0	103,300.0	591.5	0.7	0.4	1.2
08/14/2020 10:00	3,882.2	1,866.3	5,748.5	103,300.0	593.8	0.7	0.4	1.2
08/14/2020 11:00	3,863.7	1,408.6	5,272.3	103,300.0	544.6	0.7	0.3	1.1
08/14/2020 12:00	3,840.6	1,105.3	4,945.9	103,300.0	510.9	0.6	0.3	1.0
08/14/2020 13:00	3,829.0	1,161.8	4,990.8	103,300.0	515.5	0.6	0.3	1.0
08/14/2020 14:00	3,821.5	1,140.3	4,961.8	103,300.0	512.6	0.6	0.3	1.0
08/14/2020 15:00	3,824.8	1,869.0	5,693.8	103,300.0	588.2	0.7	0.4	1.2
08/14/2020 16:00	3,812.7	1,921.7	5,734.4	103,300.0	592.4	0.7	0.4	1.2
08/14/2020 17:00	3,809.6	1,844.8	5,654.4	103,300.0	584.1	0.7	0.4	1.2
08/14/2020 18:00	3,818.7	1,729.6	5,548.3	103,300.0	573.1	0.7	0.3	1.1
08/14/2020 19:00	3,832.0	1,871.2	5,703.2	103,300.0	589.1	0.7	0.4	1.2
08/14/2020 20:00	3,856.5	1,482.2	5,338.7	103,300.0	551.5	0.7	0.3	1.1
08/14/2020 21:00	3,872.7	844.2	4,716.9	103,300.0	487.3	0.6	0.3	1.0
08/14/2020 22:00	3,873.5	986.0	4,859.5	103,300.0	502.0	0.6	0.3	1.0
08/14/2020 23:00	3,314.2	41.9	3,318.4	103,300.0	342.8	0.4	0.2	0.7
Average/Sum#:	3,612.5	969.0	4,578.1	103,300.0	472.9	0.6	0.3	1.0
Minimum:	2,696.4	0.0	2,696.4	103,300.0	278.5	0.3	0.2	0.6
Maximum:	3,952.8	1,921.7	5,748.5	103,300.0	593.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2020 00:00	3,106.8	0.0	3,106.8	103,300.0	320.9	0.4	0.2	0.6
08/15/2020 01:00	3,319.4	0.0	3,319.4	103,300.0	342.9	0.4	0.2	0.7
08/15/2020 02:00	2,824.4	0.0	2,824.4	103,300.0	291.8	0.4	0.2	0.6
08/15/2020 03:00	2,705.5	0.0	2,705.5	103,300.0	279.5	0.3	0.2	0.6
08/15/2020 04:00	2,701.8	0.0	2,701.8	103,300.0	279.1	0.3	0.2	0.6
08/15/2020 05:00	2,714.4	0.0	2,714.4	103,300.0	280.4	0.3	0.2	0.6
08/15/2020 06:00	3,271.7	0.0	3,271.7	103,300.0	338.0	0.4	0.2	0.7
08/15/2020 07:00	3,810.2	2.0	3,810.3	103,300.0	393.6	0.5	0.2	0.8
08/15/2020 08:00	3,868.9	1,388.7	5,257.6	103,300.0	543.1	0.7	0.3	1.1
08/15/2020 09:00	3,846.0	1,924.7	5,770.7	103,300.0	596.1	0.7	0.4	1.2
08/15/2020 10:00	3,821.8	1,928.8	5,750.6	103,300.0	594.0	0.7	0.4	1.2
08/15/2020 11:00	3,794.4	1,922.8	5,717.2	103,300.0	590.6	0.7	0.4	1.2
08/15/2020 12:00	3,787.3	1,402.5	5,189.8	103,300.0	536.1	0.6	0.3	1.1
08/15/2020 13:00	3,775.2	1,148.7	4,923.9	103,300.0	508.6	0.6	0.3	1.0
08/15/2020 14:00	3,764.9	1,752.7	5,517.6	103,300.0	570.0	0.7	0.3	1.1
08/15/2020 15:00	3,760.9	1,265.4	5,026.3	103,300.0	519.2	0.6	0.3	1.0
08/15/2020 16:00	3,775.5	1,505.8	5,281.3	103,300.0	545.6	0.7	0.3	1.1
08/15/2020 17:00	3,790.5	1,594.5	5,385.0	103,300.0	556.3	0.7	0.3	1.1
08/15/2020 18:00	3,811.9	1,598.1	5,410.0	103,300.0	558.9	0.7	0.3	1.1
08/15/2020 19:00	3,850.2	1,907.8	5,758.0	103,300.0	594.8	0.7	0.4	1.2
08/15/2020 20:00	3,862.2	1,774.1	5,636.3	103,300.0	582.2	0.7	0.3	1.2
08/15/2020 21:00	3,871.9	1,679.6	5,551.5	103,300.0	573.5	0.7	0.3	1.1
08/15/2020 22:00	3,862.9	1,790.4	5,653.3	103,300.0	584.0	0.7	0.4	1.2
08/15/2020 23:00	3,868.2	633.7	4,501.9	103,300.0	465.0	0.6	0.3	0.9
Average/Sum#:	3,565.3	1,050.8	4,616.1	103,300.0	476.8	0.6	0.3	1.0
Minimum:	2,701.8	0.0	2,701.8	103,300.0	279.1	0.3	0.2	0.6
Maximum:	3,871.9	1,928.8	5,770.7	103,300.0	596.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2020 00:00	3,400.5	13.3	3,401.4	103,300.0	351.4	0.4	0.2	0.7
08/16/2020 01:00	3,397.9	0.0	3,397.9	103,300.0	351.0	0.4	0.2	0.7
08/16/2020 02:00	3,263.2	0.0	3,263.2	103,300.0	337.1	0.4	0.2	0.7
08/16/2020 03:00	3,168.5	0.0	3,168.5	103,300.0	327.3	0.4	0.2	0.7
08/16/2020 04:00	3,194.7	0.0	3,194.7	103,300.0	330.0	0.4	0.2	0.7
08/16/2020 05:00	3,430.2	0.0	3,430.2	103,300.0	354.3	0.4	0.2	0.7
08/16/2020 06:00	3,277.1	0.0	3,277.1	103,300.0	338.5	0.4	0.2	0.7
08/16/2020 07:00	3,569.5	0.0	3,569.5	103,300.0	368.7	0.4	0.2	0.7
08/16/2020 08:00	3,540.5	0.0	3,540.5	103,300.0	365.7	0.4	0.2	0.7
08/16/2020 09:00	3,842.1	582.9	4,337.6	103,300.0	448.1	0.5	0.3	0.9
08/16/2020 10:00	3,826.6	711.9	4,538.5	103,300.0	468.8	0.6	0.3	0.9
08/16/2020 11:00	3,799.7	762.6	4,562.3	103,300.0	471.3	0.6	0.3	0.9
08/16/2020 12:00	3,783.3	435.4	4,218.7	103,300.0	435.8	0.5	0.3	0.9
08/16/2020 13:00	3,762.5	1,042.7	4,805.2	103,300.0	496.4	0.6	0.3	1.0
08/16/2020 14:00	3,752.8	1,878.7	5,631.5	103,300.0	581.7	0.7	0.3	1.2
08/16/2020 15:00	3,756.6	1,739.5	5,496.1	103,300.0	567.7	0.7	0.3	1.1
08/16/2020 16:00	3,744.6	1,606.5	5,351.1	103,300.0	552.8	0.7	0.3	1.1
08/16/2020 17:00	3,773.0	1,303.5	5,076.5	103,300.0	524.4	0.6	0.3	1.0
08/16/2020 18:00	3,797.2	733.5	4,530.7	103,300.0	468.0	0.6	0.3	0.9
08/16/2020 19:00	3,828.4	1,111.6	4,940.0	103,300.0	510.3	0.6	0.3	1.0
08/16/2020 20:00	3,838.7	1,860.0	5,698.7	103,300.0	588.7	0.7	0.4	1.2
08/16/2020 21:00	3,850.8	1,466.9	5,317.7	103,300.0	549.3	0.7	0.3	1.1
08/16/2020 22:00	3,856.9	1,451.6	5,308.5	103,300.0	548.4	0.7	0.3	1.1
08/16/2020 23:00	3,862.8	590.6	4,435.7	103,300.0	458.2	0.6	0.3	0.9
Average/Sum#:	3,638.3	720.5	4,353.8	103,300.0	449.7	0.5	0.3	0.9
Minimum:	3,168.5	0.0	3,168.5	103,300.0	327.3	0.4	0.2	0.7
Maximum:	3,862.8	1,878.7	5,698.7	103,300.0	588.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2020 00:00	3,628.4	0.0	3,628.4	103,300.0	374.8	0.5	0.2	0.7
08/17/2020 01:00	3,209.8	0.0	3,209.8	103,300.0	331.6	0.4	0.2	0.7
08/17/2020 02:00	3,301.4	0.0	3,301.4	103,300.0	341.0	0.4	0.2	0.7
08/17/2020 03:00	3,330.3	0.0	3,330.3	103,300.0	344.0	0.4	0.2	0.7
08/17/2020 04:00	3,397.8	0.0	3,397.8	103,300.0	351.0	0.4	0.2	0.7
08/17/2020 05:00	3,603.0	0.0	3,603.0	103,300.0	372.2	0.4	0.2	0.7
08/17/2020 06:00	3,799.0	9.3	3,799.5	103,300.0	392.5	0.5	0.2	0.8
08/17/2020 07:00	3,880.9	1,023.4	4,904.3	103,300.0	506.6	0.6	0.3	1.0
08/17/2020 08:00	3,875.4	1,820.4	5,695.8	103,300.0	588.4	0.7	0.4	1.2
08/17/2020 09:00	3,864.8	1,929.6	5,794.4	103,300.0	598.6	0.7	0.4	1.2
08/17/2020 10:00	3,846.5	1,937.3	5,783.8	103,300.0	597.5	0.7	0.4	1.2
08/17/2020 11:00	3,827.9	1,932.3	5,760.2	103,300.0	595.0	0.7	0.4	1.2
08/17/2020 12:00	3,823.2	1,596.7	5,419.9	103,300.0	559.9	0.7	0.3	1.1
08/17/2020 13:00	3,819.3	1,063.6	4,882.9	103,300.0	504.4	0.6	0.3	1.0
08/17/2020 14:00	3,808.7	824.6	4,592.1	103,300.0	474.4	0.6	0.3	1.0
08/17/2020 15:00	3,144.8	0.0	3,144.8	103,300.0	324.9	0.4	0.2	0.6
08/17/2020 16:00	3,805.7	606.8	4,303.3	103,300.0	444.5	0.5	0.3	0.9
08/17/2020 17:00	3,821.8	1,313.5	5,135.3	103,300.0	530.5	0.6	0.3	1.1
08/17/2020 18:00	3,843.1	1,298.6	5,141.7	103,300.0	531.1	0.6	0.3	1.1
08/17/2020 19:00	3,851.7	1,383.9	5,235.6	103,300.0	540.8	0.6	0.3	1.1
08/17/2020 20:00	3,861.9	729.0	4,590.9	103,300.0	474.2	0.6	0.3	0.9
08/17/2020 21:00	3,864.2	370.2	4,178.9	103,300.0	431.7	0.5	0.3	0.9
08/17/2020 22:00	3,884.6	46.8	3,896.3	103,300.0	402.5	0.5	0.2	0.8
08/17/2020 23:00	3,517.7	86.5	3,539.3	103,300.0	365.6	0.4	0.2	0.7
Average/Sum#:	3,692.2	748.9	4,427.9	103,300.0	457.4	0.5	0.3	0.9
Minimum:	3,144.8	0.0	3,144.8	103,300.0	324.9	0.4	0.2	0.6
Maximum:	3,884.6	1,937.3	5,794.4	103,300.0	598.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2020 00:00	3,239.1	0.0	3,239.1	103,300.0	334.6	0.4	0.2	0.7
08/18/2020 01:00	3,140.9	0.0	3,140.9	103,300.0	324.5	0.4	0.2	0.6
08/18/2020 02:00	2,959.6	0.0	2,959.6	103,300.0	305.7	0.4	0.2	0.6
08/18/2020 03:00	2,989.6	0.0	2,989.6	103,300.0	308.8	0.4	0.2	0.6
08/18/2020 04:00	3,155.8	0.0	3,155.8	103,300.0	326.0	0.4	0.2	0.7
08/18/2020 05:00	2,727.9	0.0	2,727.9	103,300.0	281.8	0.3	0.2	0.6
08/18/2020 06:00	2,816.5	0.0	2,816.5	103,300.0	290.9	0.3	0.2	0.6
08/18/2020 07:00	3,377.3	0.0	3,377.3	103,300.0	348.9	0.4	0.2	0.7
08/18/2020 08:00	3,877.7	274.3	4,102.6	103,300.0	423.8	0.5	0.3	0.9
08/18/2020 09:00	3,859.6	1,208.6	5,068.2	103,300.0	523.5	0.6	0.3	1.0
08/18/2020 10:00	3,840.3	1,250.8	5,091.1	103,300.0	525.9	0.6	0.3	1.1
08/18/2020 11:00	3,822.8	1,540.7	5,363.5	103,300.0	554.0	0.7	0.3	1.1
08/18/2020 12:00	3,811.1	1,907.7	5,718.8	103,300.0	590.8	0.7	0.4	1.2
08/18/2020 13:00	3,790.8	1,645.0	5,435.8	103,300.0	561.5	0.7	0.3	1.1
08/18/2020 14:00	3,779.4	1,511.3	5,290.7	103,300.0	546.5	0.7	0.3	1.1
08/18/2020 15:00	3,780.7	464.5	4,245.2	103,300.0	438.5	0.5	0.3	0.9
08/18/2020 16:00	3,784.3	783.9	4,568.2	103,300.0	471.9	0.6	0.3	0.9
08/18/2020 17:00	3,781.7	455.4	4,237.1	103,300.0	437.7	0.5	0.3	0.9
08/18/2020 18:00	3,791.6	699.5	4,491.1	103,300.0	463.9	0.6	0.3	0.9
08/18/2020 19:00	3,794.4	648.9	4,391.4	103,300.0	453.6	0.6	0.3	0.9
08/18/2020 20:00	3,089.4	0.0	3,089.4	103,300.0	319.1	0.4	0.2	0.6
08/18/2020 21:00	3,819.5	747.7	4,432.6	103,300.0	457.9	0.6	0.3	0.9
08/18/2020 22:00	3,852.8	459.1	4,311.9	103,300.0	445.4	0.5	0.3	0.9
08/18/2020 23:00	3,856.8	561.8	4,351.2	103,300.0	449.5	0.5	0.3	0.9
Average/Sum#:	3,530.8	590.0	4,108.1	103,300.0	424.4	0.5	0.3	0.9
Minimum:	2,727.9	0.0	2,727.9	103,300.0	281.8	0.3	0.2	0.6
Maximum:	3,877.7	1,907.7	5,718.8	103,300.0	590.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2020 00:00	3,755.4	0.0	3,755.4	103,300.0	387.9	0.5	0.2	0.8
08/19/2020 01:00	3,569.1	0.0	3,569.1	103,300.0	368.7	0.4	0.2	0.7
08/19/2020 02:00	3,424.4	0.0	3,424.4	103,300.0	353.7	0.4	0.2	0.7
08/19/2020 03:00	3,265.6	0.0	3,265.6	103,300.0	337.3	0.4	0.2	0.7
08/19/2020 04:00	3,603.9	0.0	3,603.9	103,300.0	372.3	0.4	0.2	0.7
08/19/2020 05:00	3,685.1	0.0	3,685.1	103,300.0	380.7	0.5	0.2	0.8
08/19/2020 06:00	3,802.8	0.0	3,802.8	103,300.0	392.8	0.5	0.2	0.8
08/19/2020 07:00	3,920.9	315.9	4,221.0	103,300.0	436.0	0.5	0.3	0.9
08/19/2020 08:00	3,900.7	1,269.4	5,170.1	103,300.0	534.1	0.6	0.3	1.1
08/19/2020 09:00	3,860.2	1,018.2	4,878.4	103,300.0	503.9	0.6	0.3	1.0
08/19/2020 10:00	3,848.2	1,797.4	5,645.6	103,300.0	583.2	0.7	0.3	1.2
08/19/2020 11:00	3,850.1	1,858.0	5,708.1	103,300.0	589.6	0.7	0.4	1.2
08/19/2020 12:00	3,854.1	1,896.7	5,750.8	103,300.0	594.1	0.7	0.4	1.2
08/19/2020 13:00	3,839.9	1,516.5	5,356.4	103,300.0	553.3	0.7	0.3	1.1
08/19/2020 14:00	3,840.4	491.6	4,332.0	103,300.0	447.5	0.5	0.3	0.9
08/19/2020 15:00	3,838.2	472.0	4,310.2	103,300.0	445.2	0.5	0.3	0.9
08/19/2020 16:00	3,837.0	910.4	4,747.4	103,300.0	490.4	0.6	0.3	1.0
08/19/2020 17:00	3,834.0	1,738.0	5,572.0	103,300.0	575.6	0.7	0.3	1.2
08/19/2020 18:00	3,847.7	1,373.2	5,220.9	103,300.0	539.3	0.6	0.3	1.1
08/19/2020 19:00	3,869.3	711.3	4,580.6	103,300.0	473.2	0.6	0.3	0.9
08/19/2020 20:00	3,884.2	657.7	4,541.9	103,300.0	469.2	0.6	0.3	0.9
08/19/2020 21:00	3,891.0	599.6	4,490.6	103,300.0	463.9	0.6	0.3	0.9
08/19/2020 22:00	3,678.9	5.2	3,679.3	103,300.0	380.1	0.5	0.2	0.8
08/19/2020 23:00	3,570.7	0.0	3,570.7	103,300.0	368.9	0.4	0.2	0.7
Average/Sum#:	3,761.3	693.0	4,453.4	103,300.0	460.0	0.6	0.3	0.9
Minimum:	3,265.6	0.0	3,265.6	103,300.0	337.3	0.4	0.2	0.7
Maximum:	3,920.9	1,896.7	5,750.8	103,300.0	594.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2020 00:00	3,132.0	0.0	3,132.0	103,300.0	323.5	0.4	0.2	0.6
08/20/2020 01:00	2,966.1	0.0	2,966.1	103,300.0	306.4	0.4	0.2	0.6
08/20/2020 02:00	2,696.0	0.0	2,696.0	103,300.0	278.5	0.3	0.2	0.6
08/20/2020 03:00	2,698.5	0.0	2,698.5	103,300.0	278.8	0.3	0.2	0.6
08/20/2020 04:00	2,700.2	0.0	2,700.2	103,300.0	278.9	0.3	0.2	0.6
08/20/2020 05:00	2,792.5	0.0	2,792.5	103,300.0	288.5	0.3	0.2	0.6
08/20/2020 06:00	2,902.0	0.0	2,902.0	103,300.0	299.8	0.4	0.2	0.6
08/20/2020 07:00	2,821.8	0.0	2,821.8	103,300.0	291.5	0.3	0.2	0.6
08/20/2020 08:00	2,957.5	0.0	2,957.5	103,300.0	305.5	0.4	0.2	0.6
08/20/2020 09:00	3,324.7	0.0	3,324.7	103,300.0	343.4	0.4	0.2	0.7
08/20/2020 10:00	3,670.8	0.0	3,670.8	103,300.0	379.2	0.5	0.2	0.8
08/20/2020 11:00	3,926.2	243.4	4,140.4	103,300.0	427.7	0.5	0.3	0.9
08/20/2020 12:00	3,813.7	68.0	3,829.3	103,300.0	395.6	0.5	0.2	0.8
08/20/2020 13:00	3,852.4	0.0	3,852.4	103,300.0	398.0	0.5	0.2	0.8
08/20/2020 14:00	3,263.6	0.0	3,263.6	103,300.0	337.1	0.4	0.2	0.7
08/20/2020 15:00	3,853.3	532.9	4,279.6	103,300.0	442.1	0.5	0.3	0.9
08/20/2020 16:00	3,502.1	0.0	3,502.1	103,300.0	361.8	0.4	0.2	0.7
08/20/2020 17:00	3,871.1	4.2	3,871.3	103,300.0	399.9	0.5	0.2	0.8
08/20/2020 18:00	3,863.4	516.3	4,338.4	103,300.0	448.2	0.5	0.3	0.9
08/20/2020 19:00	3,425.3	0.0	3,425.3	103,300.0	353.8	0.4	0.2	0.7
08/20/2020 20:00	3,577.4	0.0	3,577.4	103,300.0	369.5	0.4	0.2	0.7
08/20/2020 21:00	3,737.6	0.0	3,737.6	103,300.0	386.1	0.5	0.2	0.8
08/20/2020 22:00	3,317.6	0.0	3,317.6	103,300.0	342.7	0.4	0.2	0.7
08/20/2020 23:00	2,714.4	0.0	2,714.4	103,300.0	280.4	0.3	0.2	0.6
Average/Sum#:	3,307.5	56.9	3,354.6	103,300.0	346.5	0.4	0.2	0.7
Minimum:	2,696.0	0.0	2,696.0	103,300.0	278.5	0.3	0.2	0.6
Maximum:	3,926.2	532.9	4,338.4	103,300.0	448.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2020 00:00	2,701.5	0.0	2,701.5	103,300.0	279.1	0.3	0.2	0.6
08/21/2020 01:00	2,700.8	0.0	2,700.8	103,300.0	279.0	0.3	0.2	0.6
08/21/2020 02:00	2,701.2	0.0	2,701.2	103,300.0	279.0	0.3	0.2	0.6
08/21/2020 03:00	2,848.8	0.0	2,848.8	103,300.0	294.3	0.4	0.2	0.6
08/21/2020 04:00	2,877.0	0.0	2,877.0	103,300.0	297.2	0.4	0.2	0.6
08/21/2020 05:00	2,703.1	0.0	2,703.1	103,300.0	279.2	0.3	0.2	0.6
08/21/2020 06:00	3,001.3	0.0	3,001.3	103,300.0	310.0	0.4	0.2	0.6
08/21/2020 07:00	3,410.3	0.0	3,410.3	103,300.0	352.3	0.4	0.2	0.7
08/21/2020 08:00	3,423.0	0.0	3,423.0	103,300.0	353.6	0.4	0.2	0.7
08/21/2020 09:00	3,730.5	0.0	3,730.5	103,300.0	385.4	0.5	0.2	0.8
08/21/2020 10:00	3,900.0	10.8	3,900.9	103,300.0	403.0	0.5	0.2	0.8
08/21/2020 11:00	3,832.5	18.2	3,838.9	103,300.0	396.6	0.5	0.2	0.8
08/21/2020 12:00	3,567.6	15.4	3,571.0	103,300.0	368.9	0.4	0.2	0.7
08/21/2020 13:00	3,859.8	1,568.3	5,428.1	103,300.0	560.7	0.7	0.3	1.1
08/21/2020 14:00	3,849.8	1,197.7	5,047.5	103,300.0	521.4	0.6	0.3	1.0
08/21/2020 15:00	3,833.1	1,600.5	5,433.6	103,300.0	561.3	0.7	0.3	1.1
08/21/2020 16:00	3,825.6	1,901.5	5,727.1	103,300.0	591.6	0.7	0.4	1.2
08/21/2020 17:00	3,825.5	1,911.0	5,736.5	103,300.0	592.6	0.7	0.4	1.2
08/21/2020 18:00	3,828.0	1,903.0	5,731.0	103,300.0	592.0	0.7	0.4	1.2
08/21/2020 19:00	3,803.1	78.4	3,814.9	103,300.0	394.1	0.5	0.2	0.8
08/21/2020 20:00	3,389.4	0.0	3,389.4	103,300.0	350.1	0.4	0.2	0.7
08/21/2020 21:00	3,847.3	1,104.0	4,918.2	103,300.0	508.1	0.6	0.3	1.0
08/21/2020 22:00	3,866.3	1,085.3	4,897.3	103,300.0	505.9	0.6	0.3	1.0
08/21/2020 23:00	3,285.3	0.0	3,285.3	103,300.0	339.4	0.4	0.2	0.7
Average/Sum#:	3,442.1	516.4	3,950.7	103,300.0	408.1	0.5	0.2	0.8
Minimum:	2,700.8	0.0	2,700.8	103,300.0	279.0	0.3	0.2	0.6
Maximum:	3,900.0	1,911.0	5,736.5	103,300.0	592.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2020 00:00	2,725.2	0.0	2,725.2	103,300.0	281.5	0.3	0.2	0.6
08/22/2020 01:00	2,943.5	0.0	2,943.5	103,300.0	304.1	0.4	0.2	0.6
08/22/2020 02:00	2,880.2	0.0	2,880.2	103,300.0	297.5	0.4	0.2	0.6
08/22/2020 03:00	2,724.5	0.0	2,724.5	103,300.0	281.4	0.3	0.2	0.6
08/22/2020 04:00	2,699.1	0.0	2,699.1	103,300.0	278.8	0.3	0.2	0.6
08/22/2020 05:00	2,696.7	0.0	2,696.7	103,300.0	278.6	0.3	0.2	0.6
08/22/2020 06:00	2,790.5	0.0	2,790.5	103,300.0	288.3	0.3	0.2	0.6
08/22/2020 07:00	3,082.3	0.0	3,082.3	103,300.0	318.4	0.4	0.2	0.6
08/22/2020 08:00	3,091.1	0.0	3,091.1	103,300.0	319.3	0.4	0.2	0.6
08/22/2020 09:00	3,543.3	0.0	3,543.3	103,300.0	366.0	0.4	0.2	0.7
08/22/2020 10:00	3,758.5	12.4	3,759.4	103,300.0	388.3	0.5	0.2	0.8
08/22/2020 11:00	3,849.0	499.0	4,348.0	103,300.0	449.1	0.5	0.3	0.9
08/22/2020 12:00	3,834.1	190.6	3,973.2	103,300.0	410.4	0.5	0.2	0.8
08/22/2020 13:00	3,750.4	88.3	3,805.1	103,300.0	393.1	0.5	0.2	0.8
08/22/2020 14:00	3,772.6	179.5	3,892.9	103,300.0	402.1	0.5	0.2	0.8
08/22/2020 15:00	3,773.8	689.8	4,463.6	103,300.0	461.1	0.6	0.3	0.9
08/22/2020 16:00	3,763.9	1,580.9	5,344.8	103,300.0	552.1	0.7	0.3	1.1
08/22/2020 17:00	3,764.6	1,893.7	5,658.3	103,300.0	584.5	0.7	0.4	1.2
08/22/2020 18:00	3,765.9	1,824.8	5,590.7	103,300.0	577.5	0.7	0.3	1.2
08/22/2020 19:00	3,785.4	954.0	4,739.4	103,300.0	489.6	0.6	0.3	1.0
08/22/2020 20:00	3,828.1	802.5	4,630.6	103,300.0	478.3	0.6	0.3	1.0
08/22/2020 21:00	3,830.8	430.3	4,226.7	103,300.0	436.6	0.5	0.3	0.9
08/22/2020 22:00	3,802.8	0.0	3,802.8	103,300.0	392.8	0.5	0.2	0.8
08/22/2020 23:00	3,391.4	0.0	3,391.4	103,300.0	350.3	0.4	0.2	0.7
Average/Sum#:	3,410.3	381.1	3,783.5	103,300.0	390.8	0.5	0.2	0.8
Minimum:	2,696.7	0.0	2,696.7	103,300.0	278.6	0.3	0.2	0.6
Maximum:	3,849.0	1,893.7	5,658.3	103,300.0	584.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2020 00:00	3,066.2	0.0	3,066.2	103,300.0	316.7	0.4	0.2	0.6
08/23/2020 01:00	2,813.4	0.0	2,813.4	103,300.0	290.6	0.3	0.2	0.6
08/23/2020 02:00	2,694.1	0.0	2,694.1	103,300.0	278.3	0.3	0.2	0.6
08/23/2020 03:00	2,695.5	0.0	2,695.5	103,300.0	278.4	0.3	0.2	0.6
08/23/2020 04:00	2,696.8	0.0	2,696.8	103,300.0	278.6	0.3	0.2	0.6
08/23/2020 05:00	2,698.1	0.0	2,698.1	103,300.0	278.7	0.3	0.2	0.6
08/23/2020 06:00	2,699.1	0.0	2,699.1	103,300.0	278.8	0.3	0.2	0.6
08/23/2020 07:00	2,697.6	0.0	2,697.6	103,300.0	278.7	0.3	0.2	0.6
08/23/2020 08:00	2,779.4	0.0	2,779.4	103,300.0	287.1	0.3	0.2	0.6
08/23/2020 09:00	3,489.2	0.0	3,489.2	103,300.0	360.4	0.4	0.2	0.7
08/23/2020 10:00	3,853.6	89.6	3,934.2	103,300.0	406.4	0.5	0.2	0.8
08/23/2020 11:00	3,836.9	1,243.4	5,080.3	103,300.0	524.8	0.6	0.3	1.0
08/23/2020 12:00	3,827.6	1,630.8	5,458.4	103,300.0	563.9	0.7	0.3	1.1
08/23/2020 13:00	3,814.8	1,594.6	5,409.4	103,300.0	558.8	0.7	0.3	1.1
08/23/2020 14:00	3,820.7	1,260.4	5,081.1	103,300.0	524.9	0.6	0.3	1.1
08/23/2020 15:00	3,827.4	1,168.2	4,995.6	103,300.0	516.0	0.6	0.3	1.0
08/23/2020 16:00	3,834.8	1,344.7	5,179.5	103,300.0	535.0	0.6	0.3	1.1
08/23/2020 17:00	3,849.6	1,221.1	5,070.7	103,300.0	523.8	0.6	0.3	1.0
08/23/2020 18:00	3,845.8	839.0	4,684.8	103,300.0	483.9	0.6	0.3	1.0
08/23/2020 19:00	3,844.2	189.6	3,973.1	103,300.0	410.4	0.5	0.3	0.8
08/23/2020 20:00	3,861.2	0.0	3,861.2	103,300.0	398.9	0.5	0.2	0.8
08/23/2020 21:00	3,864.2	720.2	4,570.0	103,300.0	472.1	0.6	0.3	0.9
08/23/2020 22:00	3,859.5	187.3	4,015.0	103,300.0	414.7	0.5	0.3	0.8
08/23/2020 23:00	3,262.6	0.0	3,262.6	103,300.0	337.0	0.4	0.2	0.7
Average/Sum#:	3,397.2	478.7	3,871.1	103,300.0	399.9	0.5	0.2	0.8
Minimum:	2,694.1	0.0	2,694.1	103,300.0	278.3	0.3	0.2	0.6
Maximum:	3,864.2	1,630.8	5,458.4	103,300.0	563.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2020 00:00	3,046.2	0.0	3,046.2	103,300.0	314.7	0.4	0.2	0.6
08/24/2020 01:00	2,739.7	0.0	2,739.7	103,300.0	283.0	0.3	0.2	0.6
08/24/2020 02:00	2,701.3	0.0	2,701.3	103,300.0	279.0	0.3	0.2	0.6
08/24/2020 03:00	2,703.0	0.0	2,703.0	103,300.0	279.2	0.3	0.2	0.6
08/24/2020 04:00	2,943.2	0.0	2,943.2	103,300.0	304.0	0.4	0.2	0.6
08/24/2020 05:00	3,020.2	0.0	3,020.2	103,300.0	312.0	0.4	0.2	0.6
08/24/2020 06:00	3,282.0	0.0	3,282.0	103,300.0	339.0	0.4	0.2	0.7
08/24/2020 07:00	3,700.0	0.0	3,700.0	103,300.0	382.2	0.5	0.2	0.8
08/24/2020 08:00	3,858.1	405.7	4,215.1	103,300.0	435.4	0.5	0.3	0.9
08/24/2020 09:00	3,866.0	1,033.5	4,899.5	103,300.0	506.1	0.6	0.3	1.0
08/24/2020 10:00	3,859.9	1,179.8	5,039.7	103,300.0	520.6	0.6	0.3	1.0
08/24/2020 11:00	3,842.4	1,828.2	5,670.6	103,300.0	585.8	0.7	0.4	1.2
08/24/2020 12:00	3,823.2	1,452.5	5,275.7	103,300.0	545.0	0.7	0.3	1.1
08/24/2020 13:00	3,808.5	1,030.9	4,839.4	103,300.0	499.9	0.6	0.3	1.0
08/24/2020 14:00	3,789.2	1,259.1	5,048.3	103,300.0	521.5	0.6	0.3	1.0
08/24/2020 15:00	3,795.8	955.3	4,751.1	103,300.0	490.8	0.6	0.3	1.0
08/24/2020 16:00	3,809.6	1,258.2	5,067.8	103,300.0	523.5	0.6	0.3	1.0
08/24/2020 17:00	3,813.1	1,255.9	5,069.0	103,300.0	523.6	0.6	0.3	1.0
08/24/2020 18:00	3,823.2	953.7	4,776.9	103,300.0	493.5	0.6	0.3	1.0
08/24/2020 19:00	3,821.0	229.6	4,020.8	103,300.0	415.3	0.5	0.3	0.8
08/24/2020 20:00	3,635.8	0.0	3,635.8	103,300.0	375.6	0.5	0.2	0.8
08/24/2020 21:00	3,838.5	356.8	4,152.5	103,300.0	429.0	0.5	0.3	0.9
08/24/2020 22:00	3,843.0	501.8	4,259.5	103,300.0	440.0	0.5	0.3	0.9
08/24/2020 23:00	3,415.1	0.0	3,415.1	103,300.0	352.8	0.4	0.2	0.7
Average/Sum#:	3,532.4	570.9	4,094.7	103,300.0	423.0	0.5	0.3	0.9
Minimum:	2,701.3	0.0	2,701.3	103,300.0	279.0	0.3	0.2	0.6
Maximum:	3,866.0	1,828.2	5,670.6	103,300.0	585.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2020 00:00	3,111.7	0.0	3,111.7	103,300.0	321.4	0.4	0.2	0.6
08/25/2020 01:00	2,757.2	0.0	2,757.2	103,300.0	284.8	0.3	0.2	0.6
08/25/2020 02:00	2,700.6	0.0	2,700.6	103,300.0	279.0	0.3	0.2	0.6
08/25/2020 03:00	2,702.1	0.0	2,702.1	103,300.0	279.1	0.3	0.2	0.6
08/25/2020 04:00	2,702.0	0.0	2,702.0	103,300.0	279.1	0.3	0.2	0.6
08/25/2020 05:00	2,704.8	0.0	2,704.8	103,300.0	279.4	0.3	0.2	0.6
08/25/2020 06:00	2,993.1	0.0	2,993.1	103,300.0	309.2	0.4	0.2	0.6
08/25/2020 07:00	3,269.5	0.0	3,269.5	103,300.0	337.7	0.4	0.2	0.7
08/25/2020 08:00	3,753.6	0.0	3,753.6	103,300.0	387.7	0.5	0.2	0.8
08/25/2020 09:00	3,886.1	30.1	3,890.6	103,300.0	401.9	0.5	0.2	0.8
08/25/2020 10:00	3,857.9	747.6	4,605.5	103,300.0	475.7	0.6	0.3	1.0
08/25/2020 11:00	3,835.7	1,350.6	5,186.3	103,300.0	535.7	0.6	0.3	1.1
08/25/2020 12:00	3,827.7	757.5	4,585.2	103,300.0	473.7	0.6	0.3	0.9
08/25/2020 13:00	3,806.4	783.1	4,589.5	103,300.0	474.1	0.6	0.3	0.9
08/25/2020 14:00	3,790.2	817.1	4,607.3	103,300.0	475.9	0.6	0.3	1.0
08/25/2020 15:00	3,789.1	1,240.4	5,029.5	103,300.0	519.5	0.6	0.3	1.0
08/25/2020 16:00	3,782.9	1,382.0	5,164.9	103,300.0	533.5	0.6	0.3	1.1
08/25/2020 17:00	3,782.8	1,843.2	5,626.0	103,300.0	581.2	0.7	0.3	1.2
08/25/2020 18:00	3,793.2	1,169.3	4,962.5	103,300.0	512.6	0.6	0.3	1.0
08/25/2020 19:00	3,808.6	766.0	4,574.6	103,300.0	472.6	0.6	0.3	0.9
08/25/2020 20:00	3,752.7	70.8	3,769.0	103,300.0	389.3	0.5	0.2	0.8
08/25/2020 21:00	3,801.2	0.0	3,801.2	103,300.0	392.7	0.5	0.2	0.8
08/25/2020 22:00	3,672.1	0.0	3,672.1	103,300.0	379.3	0.5	0.2	0.8
08/25/2020 23:00	3,055.4	0.0	3,055.4	103,300.0	315.6	0.4	0.2	0.6
Average/Sum#:	3,455.7	456.6	3,908.9	103,300.0	403.8	0.5	0.2	0.8
Minimum:	2,700.6	0.0	2,700.6	103,300.0	279.0	0.3	0.2	0.6
Maximum:	3,886.1	1,843.2	5,626.0	103,300.0	581.2	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2020 00:00	2,721.7	0.0	2,721.7	103,300.0	281.2	0.3	0.2	0.6
08/26/2020 01:00	2,706.6	0.0	2,706.6	103,300.0	279.6	0.3	0.2	0.6
08/26/2020 02:00	2,702.3	0.0	2,702.3	103,300.0	279.1	0.3	0.2	0.6
08/26/2020 03:00	2,706.4	0.0	2,706.4	103,300.0	279.6	0.3	0.2	0.6
08/26/2020 04:00	2,805.7	0.0	2,805.7	103,300.0	289.8	0.3	0.2	0.6
08/26/2020 05:00	2,925.4	0.0	2,925.4	103,300.0	302.2	0.4	0.2	0.6
08/26/2020 06:00	2,957.0	0.0	2,957.0	103,300.0	305.5	0.4	0.2	0.6
08/26/2020 07:00	3,314.8	0.0	3,314.8	103,300.0	342.4	0.4	0.2	0.7
08/26/2020 08:00	3,677.7	0.0	3,677.7	103,300.0	379.9	0.5	0.2	0.8
08/26/2020 09:00	3,895.8	0.0	3,895.8	103,300.0	402.4	0.5	0.2	0.8
08/26/2020 10:00	3,874.9	402.4	4,277.3	103,300.0	441.8	0.5	0.3	0.9
08/26/2020 11:00	3,842.1	1,270.9	5,113.0	103,300.0	528.2	0.6	0.3	1.1
08/26/2020 12:00	3,804.4	1,755.0	5,559.4	103,300.0	574.3	0.7	0.3	1.1
08/26/2020 13:00	3,793.8	1,896.2	5,690.0	103,300.0	587.8	0.7	0.4	1.2
08/26/2020 14:00	3,779.2	1,900.8	5,680.0	103,300.0	586.7	0.7	0.4	1.2
08/26/2020 15:00	3,777.8	1,901.0	5,678.8	103,300.0	586.6	0.7	0.4	1.2
08/26/2020 16:00	3,792.3	1,899.2	5,691.5	103,300.0	587.9	0.7	0.4	1.2
08/26/2020 17:00	3,819.4	1,826.0	5,645.4	103,300.0	583.2	0.7	0.3	1.2
08/26/2020 18:00	3,829.4	722.8	4,552.2	103,300.0	470.2	0.6	0.3	0.9
08/26/2020 19:00	3,794.2	6.6	3,798.6	103,300.0	392.4	0.5	0.2	0.8
08/26/2020 20:00	3,764.8	0.0	3,764.8	103,300.0	388.9	0.5	0.2	0.8
08/26/2020 21:00	3,792.2	0.0	3,792.2	103,300.0	391.7	0.5	0.2	0.8
08/26/2020 22:00	3,045.3	0.0	3,045.3	103,300.0	314.6	0.4	0.2	0.6
08/26/2020 23:00	2,981.6	0.0	2,981.6	103,300.0	308.0	0.4	0.2	0.6
Average/Sum#:	3,421.0	565.9	3,986.8	103,300.0	411.8	0.5	0.3	0.8
Minimum:	2,702.3	0.0	2,702.3	103,300.0	279.1	0.3	0.2	0.6
Maximum:	3,895.8	1,901.0	5,691.5	103,300.0	587.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2020 00:00	2,710.5	0.0	2,710.5	103,300.0	280.0	0.3	0.2	0.6
08/27/2020 01:00	2,710.8	0.0	2,710.8	103,300.0	280.0	0.3	0.2	0.6
08/27/2020 02:00	2,709.3	0.0	2,709.3	103,300.0	279.9	0.3	0.2	0.6
08/27/2020 03:00	2,711.5	0.0	2,711.5	103,300.0	280.1	0.3	0.2	0.6
08/27/2020 04:00	2,713.1	0.0	2,713.1	103,300.0	280.3	0.3	0.2	0.6
08/27/2020 05:00	2,715.0	0.0	2,715.0	103,300.0	280.5	0.3	0.2	0.6
08/27/2020 06:00	2,724.7	0.0	2,724.7	103,300.0	281.5	0.3	0.2	0.6
08/27/2020 07:00	2,733.2	0.0	2,733.2	103,300.0	282.3	0.3	0.2	0.6
08/27/2020 08:00	2,887.3	0.0	2,887.3	103,300.0	298.3	0.4	0.2	0.6
08/27/2020 09:00	3,198.8	0.0	3,198.8	103,300.0	330.4	0.4	0.2	0.7
08/27/2020 10:00	3,882.5	2.5	3,882.6	103,300.0	401.1	0.5	0.2	0.8
08/27/2020 11:00	3,890.1	385.9	4,264.4	103,300.0	440.5	0.5	0.3	0.9
08/27/2020 12:00	3,866.7	398.0	4,264.7	103,300.0	440.5	0.5	0.3	0.9
08/27/2020 13:00	3,836.3	1,186.4	5,022.7	103,300.0	518.8	0.6	0.3	1.0
08/27/2020 14:00	3,817.0	1,201.9	5,018.9	103,300.0	518.5	0.6	0.3	1.0
08/27/2020 15:00	3,814.6	1,024.2	4,838.8	103,300.0	499.8	0.6	0.3	1.0
08/27/2020 16:00	3,806.3	1,300.6	5,106.9	103,300.0	527.5	0.6	0.3	1.1
08/27/2020 17:00	3,803.0	1,385.1	5,188.1	103,300.0	535.9	0.6	0.3	1.1
08/27/2020 18:00	3,818.5	810.2	4,628.7	103,300.0	478.1	0.6	0.3	1.0
08/27/2020 19:00	3,839.2	373.3	4,212.5	103,300.0	435.2	0.5	0.3	0.9
08/27/2020 20:00	3,629.0	2.4	3,629.1	103,300.0	374.9	0.5	0.2	0.8
08/27/2020 21:00	3,709.7	0.0	3,709.7	103,300.0	383.2	0.5	0.2	0.8
08/27/2020 22:00	3,103.9	0.0	3,103.9	103,300.0	320.6	0.4	0.2	0.6
08/27/2020 23:00	2,947.4	0.0	2,947.4	103,300.0	304.5	0.4	0.2	0.6
Average/Sum#:	3,315.8	336.3	3,651.4	103,300.0	377.2	0.4	0.2	0.8
Minimum:	2,709.3	0.0	2,709.3	103,300.0	279.9	0.3	0.2	0.6
Maximum:	3,890.1	1,385.1	5,188.1	103,300.0	535.9	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2020 00:00	2,706.0	0.0	2,706.0	103,300.0	279.5	0.3	0.2	0.6
08/28/2020 01:00	2,696.7	0.0	2,696.7	103,300.0	278.6	0.3	0.2	0.6
08/28/2020 02:00	2,697.6	0.0	2,697.6	103,300.0	278.7	0.3	0.2	0.6
08/28/2020 03:00	2,702.8	0.0	2,702.8	103,300.0	279.2	0.3	0.2	0.6
08/28/2020 04:00	2,701.8	0.0	2,701.8	103,300.0	279.1	0.3	0.2	0.6
08/28/2020 05:00	2,706.8	0.0	2,706.8	103,300.0	279.6	0.3	0.2	0.6
08/28/2020 06:00	2,714.1	0.0	2,714.1	103,300.0	280.4	0.3	0.2	0.6
08/28/2020 07:00	2,901.1	0.0	2,901.1	103,300.0	299.7	0.4	0.2	0.6
08/28/2020 08:00	3,261.9	0.0	3,261.9	103,300.0	337.0	0.4	0.2	0.7
08/28/2020 09:00	3,719.7	0.0	3,719.7	103,300.0	384.2	0.5	0.2	0.8
08/28/2020 10:00	3,851.4	35.4	3,856.7	103,300.0	398.4	0.5	0.2	0.8
08/28/2020 11:00	3,831.7	1,076.3	4,908.0	103,300.0	507.0	0.6	0.3	1.0
08/28/2020 12:00	3,816.9	1,908.9	5,725.8	103,300.0	591.5	0.7	0.4	1.2
08/28/2020 13:00	3,807.8	1,891.6	5,699.4	103,300.0	588.7	0.7	0.4	1.2
08/28/2020 14:00	3,793.0	1,333.0	5,126.0	103,300.0	529.5	0.6	0.3	1.1
08/28/2020 15:00	3,788.3	1,410.6	5,198.9	103,300.0	537.0	0.6	0.3	1.1
08/28/2020 16:00	3,786.2	1,898.2	5,684.4	103,300.0	587.2	0.7	0.4	1.2
08/28/2020 17:00	3,795.3	1,710.5	5,505.8	103,300.0	568.7	0.7	0.3	1.1
08/28/2020 18:00	3,801.1	738.3	4,539.4	103,300.0	468.9	0.6	0.3	0.9
08/28/2020 19:00	3,828.6	23.1	3,832.1	103,300.0	395.9	0.5	0.2	0.8
08/28/2020 20:00	3,826.9	0.0	3,826.9	103,300.0	395.3	0.5	0.2	0.8
08/28/2020 21:00	3,848.8	0.0	3,848.8	103,300.0	397.6	0.5	0.2	0.8
08/28/2020 22:00	3,707.5	0.0	3,707.5	103,300.0	383.0	0.5	0.2	0.8
08/28/2020 23:00	3,301.1	0.0	3,301.1	103,300.0	341.0	0.4	0.2	0.7
Average/Sum#:	3,399.7	501.1	3,898.7	103,300.0	402.7	0.5	0.2	0.8
Minimum:	2,696.7	0.0	2,696.7	103,300.0	278.6	0.3	0.2	0.6
Maximum:	3,851.4	1,908.9	5,725.8	103,300.0	591.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2020 00:00	2,844.1	0.0	2,844.1	103,300.0	293.8	0.4	0.2	0.6
08/29/2020 01:00	2,709.7	0.0	2,709.7	103,300.0	279.9	0.3	0.2	0.6
08/29/2020 02:00	2,703.2	0.0	2,703.2	103,300.0	279.2	0.3	0.2	0.6
08/29/2020 03:00	2,702.3	0.0	2,702.3	103,300.0	279.1	0.3	0.2	0.6
08/29/2020 04:00	2,702.6	0.0	2,702.6	103,300.0	279.2	0.3	0.2	0.6
08/29/2020 05:00	2,706.3	0.0	2,706.3	103,300.0	279.6	0.3	0.2	0.6
08/29/2020 06:00	2,706.9	0.0	2,706.9	103,300.0	279.6	0.3	0.2	0.6
08/29/2020 07:00	2,712.6	0.0	2,712.6	103,300.0	280.2	0.3	0.2	0.6
08/29/2020 08:00	2,922.0	0.0	2,922.0	103,300.0	301.8	0.4	0.2	0.6
08/29/2020 09:00	3,344.1	0.0	3,344.1	103,300.0	345.4	0.4	0.2	0.7
08/29/2020 10:00	3,528.6	0.0	3,528.6	103,300.0	364.5	0.4	0.2	0.7
08/29/2020 11:00	3,845.7	22.6	3,848.0	103,300.0	397.5	0.5	0.2	0.8
08/29/2020 12:00	3,820.5	828.3	4,648.8	103,300.0	480.2	0.6	0.3	1.0
08/29/2020 13:00	3,806.3	1,778.0	5,584.3	103,300.0	576.9	0.7	0.3	1.2
08/29/2020 14:00	3,792.2	1,498.9	5,291.1	103,300.0	546.6	0.7	0.3	1.1
08/29/2020 15:00	3,788.9	1,851.2	5,640.1	103,300.0	582.6	0.7	0.3	1.2
08/29/2020 16:00	3,792.4	1,173.3	4,965.7	103,300.0	513.0	0.6	0.3	1.0
08/29/2020 17:00	3,819.4	686.1	4,505.5	103,300.0	465.4	0.6	0.3	0.9
08/29/2020 18:00	3,719.9	88.4	3,757.9	103,300.0	388.2	0.5	0.2	0.8
08/29/2020 19:00	3,379.0	0.0	3,379.0	103,300.0	349.1	0.4	0.2	0.7
08/29/2020 20:00	3,583.8	0.0	3,583.8	103,300.0	370.2	0.4	0.2	0.7
08/29/2020 21:00	3,864.6	0.0	3,864.6	103,300.0	399.2	0.5	0.2	0.8
08/29/2020 22:00	3,346.1	0.0	3,346.1	103,300.0	345.7	0.4	0.2	0.7
08/29/2020 23:00	3,127.8	0.0	3,127.8	103,300.0	323.1	0.4	0.2	0.6
Average/Sum#:	3,302.9	330.3	3,630.2	103,300.0	375.0	0.4	0.2	0.8
Minimum:	2,702.3	0.0	2,702.3	103,300.0	279.1	0.3	0.2	0.6
Maximum:	3,864.6	1,851.2	5,640.1	103,300.0	582.6	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2020 00:00	2,711.0	0.0	2,711.0	103,300.0	280.0	0.3	0.2	0.6
08/30/2020 01:00	2,702.7	0.0	2,702.7	103,300.0	279.2	0.3	0.2	0.6
08/30/2020 02:00	2,705.1	0.0	2,705.1	103,300.0	279.4	0.3	0.2	0.6
08/30/2020 03:00	2,706.2	0.0	2,706.2	103,300.0	279.6	0.3	0.2	0.6
08/30/2020 04:00	2,707.6	0.0	2,707.6	103,300.0	279.7	0.3	0.2	0.6
08/30/2020 05:00	2,708.8	0.0	2,708.8	103,300.0	279.8	0.3	0.2	0.6
08/30/2020 06:00	2,712.2	0.0	2,712.2	103,300.0	280.2	0.3	0.2	0.6
08/30/2020 07:00	2,713.4	0.0	2,713.4	103,300.0	280.3	0.3	0.2	0.6
08/30/2020 08:00	2,709.7	0.0	2,709.7	103,300.0	279.9	0.3	0.2	0.6
08/30/2020 09:00	2,858.7	0.0	2,858.7	103,300.0	295.3	0.4	0.2	0.6
08/30/2020 10:00	3,323.7	0.0	3,323.7	103,300.0	343.3	0.4	0.2	0.7
08/30/2020 11:00	3,821.1	19.3	3,823.0	103,300.0	394.9	0.5	0.2	0.8
08/30/2020 12:00	3,823.1	786.2	4,609.3	103,300.0	476.1	0.6	0.3	1.0
08/30/2020 13:00	3,804.6	1,709.5	5,514.1	103,300.0	569.6	0.7	0.3	1.1
08/30/2020 14:00	3,784.0	1,909.1	5,693.1	103,300.0	588.1	0.7	0.4	1.2
08/30/2020 15:00	3,781.3	1,588.2	5,369.5	103,300.0	554.7	0.7	0.3	1.1
08/30/2020 16:00	3,789.3	1,073.2	4,862.5	103,300.0	502.3	0.6	0.3	1.0
08/30/2020 17:00	3,786.1	1,033.4	4,819.5	103,300.0	497.9	0.6	0.3	1.0
08/30/2020 18:00	3,791.6	88.0	3,807.4	103,300.0	393.3	0.5	0.2	0.8
08/30/2020 19:00	3,462.9	0.0	3,462.9	103,300.0	357.7	0.4	0.2	0.7
08/30/2020 20:00	3,184.6	0.0	3,184.6	103,300.0	329.0	0.4	0.2	0.7
08/30/2020 21:00	3,796.5	0.0	3,796.5	103,300.0	392.2	0.5	0.2	0.8
08/30/2020 22:00	2,879.1	0.0	2,879.1	103,300.0	297.4	0.4	0.2	0.6
08/30/2020 23:00	1,157.0	0.0	1,157.0	103,300.0	119.5	0.0	0.0	0.0
Average/Sum#:	3,142.5	342.0	3,480.7	103,300.0	359.6	0.4	0.2	0.8
Minimum:	1,157.0	0.0	1,157.0	103,300.0	119.5	0.3	0.2	0.6
Maximum:	3,823.1	1,909.1	5,693.1	103,300.0	588.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2020 00:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 01:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 02:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 03:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 04:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 05:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 06:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 07:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 08:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 09:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 10:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 11:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 12:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 13:00	0.0	0.0	0.0	103,300.0	0.0	0.0	0.0	0.0
08/31/2020 14:00	1,403.9	0.0	1,403.9	103,300.0	145.0	0.0	0.0	0.0
08/31/2020 15:00	3,561.0	0.0	3,561.0	103,300.0	367.9	0.4	0.2	0.7
08/31/2020 16:00	3,784.1	816.9	4,601.0	103,300.0	475.3	0.6	0.3	1.0
08/31/2020 17:00	3,793.0	1,144.3	4,937.3	103,300.0	510.0	0.6	0.3	1.0
08/31/2020 18:00	3,815.1	878.1	4,693.2	103,300.0	484.8	0.6	0.3	1.0
08/31/2020 19:00	3,840.1	745.0	4,562.8	103,300.0	471.3	0.6	0.3	0.9
08/31/2020 20:00	2,905.2	0.0	2,905.2	103,300.0	300.1	0.4	0.2	0.6
08/31/2020 21:00	3,783.0	0.0	3,783.0	103,300.0	390.8	0.5	0.2	0.8
08/31/2020 22:00	3,287.0	0.0	3,287.0	103,300.0	339.5	0.4	0.2	0.7
08/31/2020 23:00	3,288.0	0.0	3,288.0	103,300.0	339.7	0.4	0.2	0.7
Average/Sum#:	3,346.0	358.4	3,702.2	103,300.0	382.4	0.5	0.2	0.8
Minimum:	1,403.9	0.0	1,403.9	103,300.0	145.0	0.4	0.2	0.6
Maximum:	3,840.1	1,144.3	4,937.3	103,300.0	510.0	0.6	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2020 00:00	3,095.9	0.0	3,095.9	103,300.0	319.8	0.4	0.2	0.6
09/01/2020 01:00	2,783.4	0.0	2,783.4	103,300.0	287.5	0.3	0.2	0.6
09/01/2020 02:00	2,704.6	0.0	2,704.6	103,300.0	279.4	0.3	0.2	0.6
09/01/2020 03:00	2,706.0	0.0	2,706.0	103,300.0	279.5	0.3	0.2	0.6
09/01/2020 04:00	2,733.8	0.0	2,733.8	103,300.0	282.4	0.3	0.2	0.6
09/01/2020 05:00	3,310.4	0.0	3,310.4	103,300.0	342.0	0.4	0.2	0.7
09/01/2020 06:00	3,472.4	0.0	3,472.4	103,300.0	358.7	0.4	0.2	0.7
09/01/2020 07:00	3,818.5	0.0	3,818.5	103,300.0	394.5	0.5	0.2	0.8
09/01/2020 08:00	3,933.7	0.0	3,933.7	103,300.0	406.4	0.5	0.2	0.8
09/01/2020 09:00	3,899.1	0.0	3,899.1	103,300.0	402.8	0.5	0.2	0.8
09/01/2020 10:00	3,845.2	0.8	3,845.2	103,300.0	397.2	0.5	0.2	0.8
09/01/2020 11:00	3,859.1	253.5	4,094.9	103,300.0	423.0	0.5	0.3	0.9
09/01/2020 12:00	3,831.8	1,666.7	5,498.5	103,300.0	568.0	0.7	0.3	1.1
09/01/2020 13:00	3,817.1	1,717.8	5,534.9	103,300.0	571.8	0.7	0.3	1.1
09/01/2020 14:00	3,808.9	1,849.3	5,658.2	103,300.0	584.5	0.7	0.4	1.2
09/01/2020 15:00	3,805.4	1,871.3	5,676.7	103,300.0	586.4	0.7	0.4	1.2
09/01/2020 16:00	3,813.8	1,821.7	5,635.5	103,300.0	582.1	0.7	0.3	1.2
09/01/2020 17:00	3,835.5	1,448.0	5,283.5	103,300.0	545.8	0.7	0.3	1.1
09/01/2020 18:00	3,865.3	1,163.0	5,028.3	103,300.0	519.4	0.6	0.3	1.0
09/01/2020 19:00	3,905.7	932.4	4,838.1	103,300.0	499.8	0.6	0.3	1.0
09/01/2020 20:00	3,931.5	1,177.4	5,108.9	103,300.0	527.7	0.6	0.3	1.1
09/01/2020 21:00	3,910.7	169.8	4,004.1	103,300.0	413.6	0.5	0.3	0.8
09/01/2020 22:00	3,189.1	0.0	3,189.1	103,300.0	329.4	0.4	0.2	0.7
09/01/2020 23:00	3,305.4	0.0	3,305.4	103,300.0	341.4	0.4	0.2	0.7
Average/Sum#:	3,549.3	586.3	4,131.6	103,300.0	426.8	0.5	0.3	0.9
Minimum:	2,704.6	0.0	2,704.6	103,300.0	279.4	0.3	0.2	0.6
Maximum:	3,933.7	1,871.3	5,676.7	103,300.0	586.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2020 00:00	3,387.1	0.0	3,387.1	103,300.0	349.9	0.4	0.2	0.7
09/02/2020 01:00	3,283.4	0.0	3,283.4	103,300.0	339.2	0.4	0.2	0.7
09/02/2020 02:00	3,234.5	0.0	3,234.5	103,300.0	334.1	0.4	0.2	0.7
09/02/2020 03:00	3,329.8	0.0	3,329.8	103,300.0	344.0	0.4	0.2	0.7
09/02/2020 04:00	3,449.0	0.0	3,449.0	103,300.0	356.3	0.4	0.2	0.7
09/02/2020 05:00	3,314.9	0.0	3,314.9	103,300.0	342.4	0.4	0.2	0.7
09/02/2020 06:00	3,281.9	0.0	3,281.9	103,300.0	339.0	0.4	0.2	0.7
09/02/2020 07:00	3,601.0	0.0	3,601.0	103,300.0	372.0	0.4	0.2	0.7
09/02/2020 08:00	3,932.1	0.0	3,932.1	103,300.0	406.2	0.5	0.2	0.8
09/02/2020 09:00	3,620.0	0.0	3,620.0	103,300.0	373.9	0.4	0.2	0.7
09/02/2020 10:00	3,580.3	0.0	3,580.3	103,300.0	369.8	0.4	0.2	0.7
09/02/2020 11:00	3,460.7	0.0	3,460.7	103,300.0	357.5	0.4	0.2	0.7
09/02/2020 12:00	3,551.5	0.0	3,551.5	103,300.0	366.9	0.4	0.2	0.7
09/02/2020 13:00	3,863.2	207.0	4,028.8	103,300.0	416.2	0.5	0.3	0.8
09/02/2020 14:00	3,846.4	1,254.2	5,100.6	103,300.0	526.9	0.6	0.3	1.1
09/02/2020 15:00	3,832.0	1,279.2	5,111.2	103,300.0	528.0	0.6	0.3	1.1
09/02/2020 16:00	3,829.4	1,282.9	5,112.3	103,300.0	528.1	0.6	0.3	1.1
09/02/2020 17:00	3,828.0	1,285.2	5,113.2	103,300.0	528.2	0.6	0.3	1.1
09/02/2020 18:00	3,847.1	915.6	4,762.7	103,300.0	492.0	0.6	0.3	1.0
09/02/2020 19:00	3,873.9	313.7	4,178.2	103,300.0	431.6	0.5	0.3	0.9
09/02/2020 20:00	3,650.6	0.0	3,650.6	103,300.0	377.1	0.5	0.2	0.8
09/02/2020 21:00	3,906.3	464.2	4,314.8	103,300.0	445.7	0.5	0.3	0.9
09/02/2020 22:00	3,831.0	0.0	3,831.0	103,300.0	395.7	0.5	0.2	0.8
09/02/2020 23:00	3,475.0	0.0	3,475.0	103,300.0	359.0	0.4	0.2	0.7
Average/Sum#:	3,617.0	291.8	3,904.4	103,300.0	403.3	0.5	0.2	0.8
Minimum:	3,234.5	0.0	3,234.5	103,300.0	334.1	0.4	0.2	0.7
Maximum:	3,932.1	1,285.2	5,113.2	103,300.0	528.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2020 00:00	3,305.8	0.0	3,305.8	103,300.0	341.5	0.4	0.2	0.7
09/03/2020 01:00	3,247.7	0.0	3,247.7	103,300.0	335.5	0.4	0.2	0.7
09/03/2020 02:00	3,154.3	0.0	3,154.3	103,300.0	325.8	0.4	0.2	0.7
09/03/2020 03:00	3,212.4	0.0	3,212.4	103,300.0	331.8	0.4	0.2	0.7
09/03/2020 04:00	3,367.8	0.0	3,367.8	103,300.0	347.9	0.4	0.2	0.7
09/03/2020 05:00	3,422.8	0.0	3,422.8	103,300.0	353.6	0.4	0.2	0.7
09/03/2020 06:00	3,472.1	0.0	3,472.1	103,300.0	358.7	0.4	0.2	0.7
09/03/2020 07:00	3,477.5	0.0	3,477.5	103,300.0	359.2	0.4	0.2	0.7
09/03/2020 08:00	3,303.3	0.0	3,303.3	103,300.0	341.2	0.4	0.2	0.7
09/03/2020 09:00	3,367.9	0.0	3,367.9	103,300.0	347.9	0.4	0.2	0.7
09/03/2020 10:00	3,730.0	0.0	3,730.0	103,300.0	385.3	0.5	0.2	0.8
09/03/2020 11:00	3,860.1	126.8	3,907.0	103,300.0	403.6	0.5	0.2	0.8
09/03/2020 12:00	3,835.3	1,398.9	5,234.2	103,300.0	540.7	0.6	0.3	1.1
09/03/2020 13:00	3,808.3	1,909.8	5,718.1	103,300.0	590.7	0.7	0.4	1.2
09/03/2020 14:00	3,794.7	1,906.9	5,701.6	103,300.0	589.0	0.7	0.4	1.2
09/03/2020 15:00	3,793.5	1,906.9	5,700.4	103,300.0	588.9	0.7	0.4	1.2
09/03/2020 16:00	3,783.3	1,890.1	5,673.4	103,300.0	586.1	0.7	0.4	1.2
09/03/2020 17:00	3,796.8	1,881.9	5,678.7	103,300.0	586.6	0.7	0.4	1.2
09/03/2020 18:00	3,824.4	1,862.1	5,686.5	103,300.0	587.4	0.7	0.4	1.2
09/03/2020 19:00	3,851.1	1,640.5	5,491.6	103,300.0	567.3	0.7	0.3	1.1
09/03/2020 20:00	3,870.1	1,526.1	5,396.2	103,300.0	557.4	0.7	0.3	1.1
09/03/2020 21:00	3,896.9	1,379.2	5,276.1	103,300.0	545.0	0.7	0.3	1.1
09/03/2020 22:00	3,896.7	157.9	4,042.0	103,300.0	417.5	0.5	0.3	0.8
09/03/2020 23:00	3,438.2	0.0	3,438.2	103,300.0	355.2	0.4	0.2	0.7
Average/Sum#:	3,604.6	732.8	4,333.6	103,300.0	447.7	0.5	0.3	0.9
Minimum:	3,154.3	0.0	3,154.3	103,300.0	325.8	0.4	0.2	0.7
Maximum:	3,896.9	1,909.8	5,718.1	103,300.0	590.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2020 00:00	3,289.6	0.0	3,289.6	103,300.0	339.8	0.4	0.2	0.7
09/04/2020 01:00	3,182.2	0.0	3,182.2	103,300.0	328.7	0.4	0.2	0.7
09/04/2020 02:00	3,225.6	0.0	3,225.6	103,300.0	333.2	0.4	0.2	0.7
09/04/2020 03:00	3,302.9	0.0	3,302.9	103,300.0	341.2	0.4	0.2	0.7
09/04/2020 04:00	3,446.7	0.0	3,446.7	103,300.0	356.0	0.4	0.2	0.7
09/04/2020 05:00	3,272.8	0.0	3,272.8	103,300.0	338.1	0.4	0.2	0.7
09/04/2020 06:00	3,184.1	0.0	3,184.1	103,300.0	328.9	0.4	0.2	0.7
09/04/2020 07:00	3,259.9	0.0	3,259.9	103,300.0	336.7	0.4	0.2	0.7
09/04/2020 08:00	3,550.9	0.0	3,550.9	103,300.0	366.8	0.4	0.2	0.7
09/04/2020 09:00	3,638.6	0.0	3,638.6	103,300.0	375.9	0.5	0.2	0.8
09/04/2020 10:00	3,863.6	0.0	3,863.6	103,300.0	399.1	0.5	0.2	0.8
09/04/2020 11:00	3,845.2	481.4	4,312.2	103,300.0	445.5	0.5	0.3	0.9
09/04/2020 12:00	3,819.5	1,173.6	4,993.1	103,300.0	515.8	0.6	0.3	1.0
09/04/2020 13:00	3,804.5	1,869.6	5,674.1	103,300.0	586.1	0.7	0.4	1.2
09/04/2020 14:00	3,792.4	1,895.2	5,687.6	103,300.0	587.5	0.7	0.4	1.2
09/04/2020 15:00	3,786.5	1,894.7	5,681.2	103,300.0	586.9	0.7	0.4	1.2
09/04/2020 16:00	3,775.2	1,892.0	5,667.2	103,300.0	585.4	0.7	0.4	1.2
09/04/2020 17:00	3,773.7	1,896.2	5,669.9	103,300.0	585.7	0.7	0.4	1.2
09/04/2020 18:00	3,779.7	1,901.7	5,681.4	103,300.0	586.9	0.7	0.4	1.2
09/04/2020 19:00	3,795.8	1,901.3	5,697.1	103,300.0	588.5	0.7	0.4	1.2
09/04/2020 20:00	3,819.7	1,887.7	5,707.4	103,300.0	589.6	0.7	0.4	1.2
09/04/2020 21:00	3,861.8	1,751.2	5,613.0	103,300.0	579.8	0.7	0.3	1.2
09/04/2020 22:00	3,881.5	914.4	4,795.9	103,300.0	495.4	0.6	0.3	1.0
09/04/2020 23:00	3,238.8	2.2	3,238.8	103,300.0	334.6	0.4	0.2	0.7
Average/Sum#:	3,591.3	810.9	4,401.5	103,300.0	454.7	0.5	0.3	0.9
Minimum:	3,182.2	0.0	3,182.2	103,300.0	328.7	0.4	0.2	0.7
Maximum:	3,881.5	1,901.7	5,707.4	103,300.0	589.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2020 00:00	3,116.4	0.0	3,116.4	103,300.0	321.9	0.4	0.2	0.6
09/05/2020 01:00	3,184.7	0.0	3,184.7	103,300.0	329.0	0.4	0.2	0.7
09/05/2020 02:00	3,182.7	0.0	3,182.7	103,300.0	328.8	0.4	0.2	0.7
09/05/2020 03:00	2,939.5	0.0	2,939.5	104,000.0	305.7	0.4	0.2	0.6
09/05/2020 04:00	2,911.1	0.0	2,911.1	104,000.0	302.8	0.4	0.2	0.6
09/05/2020 05:00	2,712.5	0.0	2,712.5	104,000.0	282.1	0.3	0.2	0.6
09/05/2020 06:00	2,713.2	0.0	2,713.2	104,000.0	282.2	0.3	0.2	0.6
09/05/2020 07:00	2,741.0	0.0	2,741.0	104,000.0	285.1	0.3	0.2	0.6
09/05/2020 08:00	3,021.9	0.0	3,021.9	104,000.0	314.3	0.4	0.2	0.6
09/05/2020 09:00	3,626.6	2.7	3,626.7	104,000.0	377.2	0.5	0.2	0.8
09/05/2020 10:00	3,819.1	470.7	4,289.8	104,000.0	446.1	0.5	0.3	0.9
09/05/2020 11:00	3,786.6	1,306.7	5,093.3	104,000.0	529.7	0.6	0.3	1.1
09/05/2020 12:00	3,759.0	1,724.6	5,483.6	104,000.0	570.3	0.7	0.3	1.1
09/05/2020 13:00	3,744.2	1,876.0	5,620.2	104,000.0	584.5	0.7	0.4	1.2
09/05/2020 14:00	3,739.1	1,875.7	5,614.8	104,000.0	583.9	0.7	0.4	1.2
09/05/2020 15:00	3,742.4	1,878.3	5,620.7	104,000.0	584.6	0.7	0.4	1.2
09/05/2020 16:00	3,731.1	1,877.6	5,608.7	104,000.0	583.3	0.7	0.3	1.2
09/05/2020 17:00	3,742.9	1,820.1	5,563.0	104,000.0	578.6	0.7	0.3	1.2
09/05/2020 18:00	3,756.6	1,189.1	4,945.7	104,000.0	514.4	0.6	0.3	1.0
09/05/2020 19:00	3,783.0	1,421.8	5,204.8	104,000.0	541.3	0.7	0.3	1.1
09/05/2020 20:00	3,801.1	1,812.5	5,613.6	104,000.0	583.8	0.7	0.4	1.2
09/05/2020 21:00	3,812.4	1,370.2	5,182.6	104,000.0	539.0	0.6	0.3	1.1
09/05/2020 22:00	3,822.8	289.2	4,091.8	104,000.0	425.5	0.5	0.3	0.9
09/05/2020 23:00	3,557.6	0.0	3,557.6	104,000.0	370.0	0.4	0.2	0.7
Average/Sum#:	3,447.8	788.1	4,235.0	103,912.5	440.2	0.5	0.3	0.9
Minimum:	2,712.5	0.0	2,712.5	103,300.0	282.1	0.3	0.2	0.6
Maximum:	3,822.8	1,878.3	5,620.7	104,000.0	584.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2020 00:00	3,288.6	0.0	3,288.6	104,000.0	342.0	0.4	0.2	0.7
09/06/2020 01:00	3,063.5	0.0	3,063.5	104,000.0	318.6	0.4	0.2	0.6
09/06/2020 02:00	2,709.7	0.0	2,709.7	104,000.0	281.8	0.3	0.2	0.6
09/06/2020 03:00	2,710.9	0.0	2,710.9	104,000.0	281.9	0.3	0.2	0.6
09/06/2020 04:00	2,711.2	0.0	2,711.2	104,000.0	282.0	0.3	0.2	0.6
09/06/2020 05:00	2,727.6	0.0	2,727.6	104,000.0	283.7	0.3	0.2	0.6
09/06/2020 06:00	2,868.0	0.0	2,868.0	104,000.0	298.3	0.4	0.2	0.6
09/06/2020 07:00	2,944.9	0.0	2,944.9	104,000.0	306.3	0.4	0.2	0.6
09/06/2020 08:00	3,247.3	0.0	3,247.3	104,000.0	337.7	0.4	0.2	0.7
09/06/2020 09:00	3,788.6	0.0	3,788.6	104,000.0	394.0	0.5	0.2	0.8
09/06/2020 10:00	3,730.7	0.0	3,730.7	104,000.0	388.0	0.5	0.2	0.8
09/06/2020 11:00	3,423.7	0.0	3,423.7	104,000.0	356.1	0.4	0.2	0.7
09/06/2020 12:00	3,779.7	635.5	4,383.4	104,000.0	455.9	0.6	0.3	0.9
09/06/2020 13:00	3,764.5	1,232.7	4,997.2	104,000.0	519.7	0.6	0.3	1.0
09/06/2020 14:00	3,739.3	1,672.4	5,411.7	104,000.0	562.8	0.7	0.3	1.1
09/06/2020 15:00	3,720.9	1,863.8	5,584.7	104,000.0	580.8	0.7	0.3	1.2
09/06/2020 16:00	3,716.9	1,861.9	5,578.8	104,000.0	580.2	0.7	0.3	1.2
09/06/2020 17:00	3,704.7	1,863.7	5,568.4	104,000.0	579.1	0.7	0.3	1.2
09/06/2020 18:00	3,742.6	1,772.6	5,515.2	104,000.0	573.6	0.7	0.3	1.1
09/06/2020 19:00	3,775.1	1,541.7	5,316.8	104,000.0	552.9	0.7	0.3	1.1
09/06/2020 20:00	3,776.7	1,598.9	5,375.6	104,000.0	559.1	0.7	0.3	1.1
09/06/2020 21:00	3,765.6	1,781.1	5,546.7	104,000.0	576.9	0.7	0.3	1.2
09/06/2020 22:00	3,773.4	993.8	4,767.2	104,000.0	495.8	0.6	0.3	1.0
09/06/2020 23:00	3,749.6	129.3	3,785.8	104,000.0	393.7	0.5	0.2	0.8
Average/Sum#:	3,426.0	706.1	4,126.9	104,000.0	429.2	0.5	0.2	0.9
Minimum:	2,709.7	0.0	2,709.7	104,000.0	281.8	0.3	0.2	0.6
Maximum:	3,788.6	1,863.8	5,584.7	104,000.0	580.8	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2020 00:00	3,381.6	0.0	3,381.6	104,000.0	351.7	0.4	0.2	0.7
09/07/2020 01:00	3,093.3	0.0	3,093.3	104,000.0	321.7	0.4	0.2	0.6
09/07/2020 02:00	2,812.0	0.0	2,812.0	104,000.0	292.4	0.4	0.2	0.6
09/07/2020 03:00	2,784.4	0.0	2,784.4	104,000.0	289.6	0.3	0.2	0.6
09/07/2020 04:00	2,703.9	0.0	2,703.9	104,000.0	281.2	0.3	0.2	0.6
09/07/2020 05:00	2,702.7	0.0	2,702.7	104,000.0	281.1	0.3	0.2	0.6
09/07/2020 06:00	2,712.1	0.0	2,712.1	104,000.0	282.1	0.3	0.2	0.6
09/07/2020 07:00	2,954.3	0.0	2,954.3	104,000.0	307.2	0.4	0.2	0.6
09/07/2020 08:00	3,527.0	0.0	3,527.0	104,000.0	366.8	0.4	0.2	0.7
09/07/2020 09:00	3,808.1	674.3	4,428.5	104,000.0	460.6	0.6	0.3	0.9
09/07/2020 10:00	3,777.8	1,796.8	5,574.6	104,000.0	579.8	0.7	0.3	1.2
09/07/2020 11:00	3,764.9	1,658.3	5,423.2	104,000.0	564.0	0.7	0.3	1.1
09/07/2020 12:00	3,745.2	907.2	4,652.4	104,000.0	483.8	0.6	0.3	1.0
09/07/2020 13:00	3,735.2	1,768.7	5,503.9	104,000.0	572.4	0.7	0.3	1.1
09/07/2020 14:00	3,728.0	975.4	4,703.4	104,000.0	489.2	0.6	0.3	1.0
09/07/2020 15:00	3,717.7	722.5	4,440.2	104,000.0	461.8	0.6	0.3	0.9
09/07/2020 16:00	3,698.9	1,301.1	5,000.0	104,000.0	520.0	0.6	0.3	1.0
09/07/2020 17:00	3,707.8	726.6	4,434.4	104,000.0	461.2	0.6	0.3	0.9
09/07/2020 18:00	3,714.9	255.2	3,965.0	104,000.0	412.4	0.5	0.2	0.8
09/07/2020 19:00	3,748.1	0.0	3,748.1	104,000.0	389.8	0.5	0.2	0.8
09/07/2020 20:00	3,755.1	247.8	3,983.1	104,000.0	414.2	0.5	0.2	0.8
09/07/2020 21:00	3,764.3	1,004.1	4,768.4	104,000.0	495.9	0.6	0.3	1.0
09/07/2020 22:00	3,781.5	50.8	3,787.6	104,000.0	393.9	0.5	0.2	0.8
09/07/2020 23:00	3,523.8	0.0	3,523.8	104,000.0	366.5	0.4	0.2	0.7
Average/Sum#:	3,443.4	503.7	3,942.0	104,000.0	410.0	0.5	0.2	0.8
Minimum:	2,702.7	0.0	2,702.7	104,000.0	281.1	0.3	0.2	0.6
Maximum:	3,808.1	1,796.8	5,574.6	104,000.0	579.8	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2020 00:00	3,151.9	0.0	3,151.9	104,000.0	327.8	0.4	0.2	0.7
09/08/2020 01:00	3,574.2	0.0	3,574.2	104,000.0	371.7	0.4	0.2	0.7
09/08/2020 02:00	3,668.6	0.0	3,668.6	104,000.0	381.5	0.5	0.2	0.8
09/08/2020 03:00	3,320.0	0.0	3,320.0	104,000.0	345.3	0.4	0.2	0.7
09/08/2020 04:00	3,388.3	0.0	3,388.3	104,000.0	352.4	0.4	0.2	0.7
09/08/2020 05:00	3,568.3	0.0	3,568.3	104,000.0	371.1	0.4	0.2	0.7
09/08/2020 06:00	3,897.2	0.0	3,897.2	104,000.0	405.3	0.5	0.2	0.8
09/08/2020 07:00	3,923.8	500.0	4,363.8	104,000.0	453.8	0.6	0.3	0.9
09/08/2020 08:00	3,912.0	841.8	4,753.8	104,000.0	494.4	0.6	0.3	1.0
09/08/2020 09:00	3,895.2	1,294.3	5,189.5	104,000.0	539.7	0.6	0.3	1.1
09/08/2020 10:00	3,879.5	636.2	4,515.7	104,000.0	469.6	0.6	0.3	0.9
09/08/2020 11:00	3,682.6	0.0	3,682.6	104,000.0	383.0	0.5	0.2	0.8
09/08/2020 12:00	3,720.9	0.0	3,720.9	104,000.0	387.0	0.5	0.2	0.8
09/08/2020 13:00	3,799.2	0.0	3,799.2	104,000.0	395.1	0.5	0.2	0.8
09/08/2020 14:00	3,234.9	0.0	3,234.9	104,000.0	336.4	0.4	0.2	0.7
09/08/2020 15:00	2,699.6	0.0	2,699.6	104,000.0	280.8	0.3	0.2	0.6
09/08/2020 16:00	2,687.9	0.0	2,687.9	104,000.0	279.5	0.3	0.2	0.6
09/08/2020 17:00	2,693.4	0.0	2,693.4	104,000.0	280.1	0.3	0.2	0.6
09/08/2020 18:00	2,836.8	0.0	2,836.8	104,000.0	295.0	0.4	0.2	0.6
09/08/2020 19:00	3,010.7	0.0	3,010.7	104,000.0	313.1	0.4	0.2	0.6
09/08/2020 20:00	2,778.5	0.0	2,778.5	104,000.0	289.0	0.3	0.2	0.6
09/08/2020 21:00	3,785.6	0.0	3,785.6	104,000.0	393.7	0.5	0.2	0.8
09/08/2020 22:00	3,526.2	0.0	3,526.2	104,000.0	366.7	0.4	0.2	0.7
09/08/2020 23:00	2,800.6	0.0	2,800.6	104,000.0	291.3	0.4	0.2	0.6
Average/Sum#:	3,393.2	136.3	3,527.0	104,000.0	366.8	0.4	0.2	0.7
Minimum:	2,687.9	0.0	2,687.9	104,000.0	279.5	0.3	0.2	0.6
Maximum:	3,923.8	1,294.3	5,189.5	104,000.0	539.7	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2020 00:00	2,699.6	0.0	2,699.6	104,000.0	280.8	0.3	0.2	0.6
09/09/2020 01:00	2,702.4	0.0	2,702.4	104,000.0	281.0	0.3	0.2	0.6
09/09/2020 02:00	2,707.5	0.0	2,707.5	104,000.0	281.6	0.3	0.2	0.6
09/09/2020 03:00	2,707.4	0.0	2,707.4	104,000.0	281.6	0.3	0.2	0.6
09/09/2020 04:00	2,708.6	0.0	2,708.6	104,000.0	281.7	0.3	0.2	0.6
09/09/2020 05:00	2,729.3	0.0	2,729.3	104,000.0	283.8	0.3	0.2	0.6
09/09/2020 06:00	3,371.2	1.4	3,371.2	104,000.0	350.6	0.4	0.2	0.7
09/09/2020 07:00	3,982.4	1,822.9	5,805.3	104,000.0	603.8	0.7	0.4	1.2
09/09/2020 08:00	3,971.9	1,982.3	5,954.2	104,000.0	619.2	0.7	0.4	1.2
09/09/2020 09:00	3,942.9	1,946.9	5,889.8	104,000.0	612.5	0.7	0.4	1.2
09/09/2020 10:00	3,918.6	1,930.3	5,848.9	104,000.0	608.3	0.7	0.4	1.2
09/09/2020 11:00	3,901.0	1,939.5	5,840.5	104,000.0	607.4	0.7	0.4	1.2
09/09/2020 12:00	3,884.5	1,938.3	5,822.8	104,000.0	605.6	0.7	0.4	1.2
09/09/2020 13:00	3,872.8	1,934.9	5,807.7	104,000.0	604.0	0.7	0.4	1.2
09/09/2020 14:00	3,873.7	1,934.7	5,808.4	104,000.0	604.1	0.7	0.4	1.2
09/09/2020 15:00	3,879.9	1,933.2	5,813.1	104,000.0	604.6	0.7	0.4	1.2
09/09/2020 16:00	3,876.9	1,878.4	5,755.3	104,000.0	598.6	0.7	0.4	1.2
09/09/2020 17:00	3,442.7	68.9	3,451.0	104,000.0	358.9	0.4	0.2	0.7
09/09/2020 18:00	3,425.0	0.0	3,425.0	104,000.0	356.2	0.4	0.2	0.7
09/09/2020 19:00	3,689.7	0.0	3,689.7	104,000.0	383.7	0.5	0.2	0.8
09/09/2020 20:00	3,209.2	0.0	3,209.2	104,000.0	333.8	0.4	0.2	0.7
09/09/2020 21:00	2,974.0	0.0	2,974.0	104,000.0	309.3	0.4	0.2	0.6
09/09/2020 22:00	3,121.1	0.0	3,121.1	104,000.0	324.6	0.4	0.2	0.6
09/09/2020 23:00	3,178.3	0.0	3,178.3	104,000.0	330.5	0.4	0.2	0.7
Average/Sum#:	3,407.1	804.7	4,209.2	104,000.0	437.8	0.5	0.3	0.9
Minimum:	2,699.6	0.0	2,699.6	104,000.0	280.8	0.3	0.2	0.6
Maximum:	3,982.4	1,982.3	5,954.2	104,000.0	619.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2020 00:00	2,779.0	0.0	2,779.0	104,000.0	289.0	0.3	0.2	0.6
09/10/2020 01:00	2,791.6	0.0	2,791.6	104,000.0	290.3	0.3	0.2	0.6
09/10/2020 02:00	2,730.5	0.0	2,730.5	104,000.0	284.0	0.3	0.2	0.6
09/10/2020 03:00	2,730.8	0.0	2,730.8	104,000.0	284.0	0.3	0.2	0.6
09/10/2020 04:00	2,839.2	0.0	2,839.2	104,000.0	295.3	0.4	0.2	0.6
09/10/2020 05:00	2,730.2	0.0	2,730.2	104,000.0	283.9	0.3	0.2	0.6
09/10/2020 06:00	2,746.0	0.0	2,746.0	104,000.0	285.6	0.3	0.2	0.6
09/10/2020 07:00	2,860.5	0.0	2,860.5	104,000.0	297.5	0.4	0.2	0.6
09/10/2020 08:00	2,725.1	0.0	2,725.1	104,000.0	283.4	0.3	0.2	0.6
09/10/2020 09:00	3,031.1	0.0	3,031.1	104,000.0	315.2	0.4	0.2	0.6
09/10/2020 10:00	3,190.1	0.0	3,190.1	104,000.0	331.8	0.4	0.2	0.7
09/10/2020 11:00	3,866.5	0.0	3,866.5	104,000.0	402.1	0.5	0.2	0.8
09/10/2020 12:00	3,835.2	0.0	3,835.2	104,000.0	398.9	0.5	0.2	0.8
09/10/2020 13:00	3,924.1	192.9	4,074.6	104,000.0	423.8	0.5	0.3	0.9
09/10/2020 14:00	3,899.6	135.9	3,940.4	104,000.0	409.8	0.5	0.3	0.8
09/10/2020 15:00	3,888.7	90.5	3,956.6	104,000.0	411.5	0.5	0.2	0.8
09/10/2020 16:00	3,876.7	5.0	3,877.1	104,000.0	403.2	0.5	0.2	0.8
09/10/2020 17:00	3,913.4	101.7	4,015.1	104,000.0	417.6	0.5	0.3	0.8
09/10/2020 18:00	3,781.0	28.9	3,788.2	104,000.0	394.0	0.5	0.2	0.8
09/10/2020 19:00	3,954.3	1,148.2	5,102.5	104,000.0	530.7	0.6	0.3	1.1
09/10/2020 20:00	3,964.4	261.4	4,225.8	104,000.0	439.5	0.5	0.3	0.9
09/10/2020 21:00	3,923.7	106.0	4,011.7	104,000.0	417.2	0.5	0.3	0.8
09/10/2020 22:00	3,517.7	0.0	3,517.7	104,000.0	365.8	0.4	0.2	0.7
09/10/2020 23:00	3,085.5	0.0	3,085.5	104,000.0	320.9	0.4	0.2	0.6
Average/Sum#:	3,357.7	86.3	3,435.5	104,000.0	357.3	0.4	0.2	0.7
Minimum:	2,725.1	0.0	2,725.1	104,000.0	283.4	0.3	0.2	0.6
Maximum:	3,964.4	1,148.2	5,102.5	104,000.0	530.7	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2020 00:00	3,107.4	0.0	3,107.4	104,000.0	323.2	0.4	0.2	0.6
09/11/2020 01:00	2,907.1	0.0	2,907.1	104,000.0	302.3	0.4	0.2	0.6
09/11/2020 02:00	2,722.7	0.0	2,722.7	104,000.0	283.2	0.3	0.2	0.6
09/11/2020 03:00	2,739.2	0.0	2,739.2	104,000.0	284.9	0.3	0.2	0.6
09/11/2020 04:00	3,124.1	0.0	3,124.1	104,000.0	324.9	0.4	0.2	0.6
09/11/2020 05:00	2,746.2	0.0	2,746.2	104,000.0	285.6	0.3	0.2	0.6
09/11/2020 06:00	2,725.6	0.0	2,725.6	104,000.0	283.5	0.3	0.2	0.6
09/11/2020 07:00	2,857.5	0.0	2,857.5	104,000.0	297.2	0.4	0.2	0.6
09/11/2020 08:00	3,152.9	0.0	3,152.9	104,000.0	327.9	0.4	0.2	0.7
09/11/2020 09:00	3,723.3	0.0	3,723.3	104,000.0	387.2	0.5	0.2	0.8
09/11/2020 10:00	3,872.4	0.0	3,872.4	104,000.0	402.7	0.5	0.2	0.8
09/11/2020 11:00	3,929.1	7.7	3,929.6	104,000.0	408.7	0.5	0.2	0.8
09/11/2020 12:00	3,920.8	190.4	4,111.2	104,000.0	427.6	0.5	0.3	0.9
09/11/2020 13:00	3,904.4	497.8	4,402.2	104,000.0	457.8	0.5	0.3	0.9
09/11/2020 14:00	3,904.7	919.0	4,823.7	104,000.0	501.7	0.6	0.3	1.0
09/11/2020 15:00	3,661.2	19.8	3,662.8	104,000.0	380.9	0.5	0.2	0.8
09/11/2020 16:00	3,641.4	0.0	3,641.4	104,000.0	378.7	0.5	0.2	0.8
09/11/2020 17:00	3,892.0	0.0	3,892.0	104,000.0	404.8	0.5	0.2	0.8
09/11/2020 18:00	3,708.2	0.0	3,708.2	104,000.0	385.7	0.5	0.2	0.8
09/11/2020 19:00	3,003.8	0.0	3,003.8	104,000.0	312.4	0.4	0.2	0.6
09/11/2020 20:00	3,569.1	0.0	3,569.1	104,000.0	371.2	0.4	0.2	0.7
09/11/2020 21:00	3,944.3	0.0	3,944.3	104,000.0	410.2	0.5	0.2	0.8
09/11/2020 22:00	3,597.9	0.0	3,597.9	104,000.0	374.2	0.4	0.2	0.7
09/11/2020 23:00	3,631.0	0.0	3,631.0	104,000.0	377.6	0.5	0.2	0.8
Average/Sum#:	3,416.1	68.1	3,483.2	104,000.0	362.3	0.4	0.2	0.7
Minimum:	2,722.7	0.0	2,722.7	104,000.0	283.2	0.3	0.2	0.6
Maximum:	3,944.3	919.0	4,823.7	104,000.0	501.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2020 00:00	3,164.0	0.0	3,164.0	104,000.0	329.1	0.4	0.2	0.7
09/12/2020 01:00	2,735.0	0.0	2,735.0	104,000.0	284.4	0.3	0.2	0.6
09/12/2020 02:00	2,733.8	0.0	2,733.8	104,000.0	284.3	0.3	0.2	0.6
09/12/2020 03:00	2,733.3	0.0	2,733.3	104,000.0	284.3	0.3	0.2	0.6
09/12/2020 04:00	2,734.1	0.0	2,734.1	104,000.0	284.3	0.3	0.2	0.6
09/12/2020 05:00	2,751.3	0.0	2,751.3	104,000.0	286.1	0.3	0.2	0.6
09/12/2020 06:00	2,856.8	0.0	2,856.8	104,000.0	297.1	0.4	0.2	0.6
09/12/2020 07:00	2,793.8	0.0	2,793.8	104,000.0	290.6	0.3	0.2	0.6
09/12/2020 08:00	2,942.1	0.0	2,942.1	104,000.0	306.0	0.4	0.2	0.6
09/12/2020 09:00	3,161.7	0.0	3,161.7	104,000.0	328.8	0.4	0.2	0.7
09/12/2020 10:00	3,497.6	0.0	3,497.6	104,000.0	363.8	0.4	0.2	0.7
09/12/2020 11:00	3,755.4	0.0	3,755.4	104,000.0	390.6	0.5	0.2	0.8
09/12/2020 12:00	3,861.4	48.7	3,867.2	104,000.0	402.2	0.5	0.2	0.8
09/12/2020 13:00	3,853.2	1,205.8	5,059.0	104,000.0	526.1	0.6	0.3	1.1
09/12/2020 14:00	3,831.3	1,675.2	5,506.5	104,000.0	572.7	0.7	0.3	1.1
09/12/2020 15:00	3,819.8	360.2	4,180.0	104,000.0	434.7	0.5	0.3	0.9
09/12/2020 16:00	3,809.0	492.3	4,301.3	104,000.0	447.3	0.5	0.3	0.9
09/12/2020 17:00	3,831.9	1,498.0	5,329.9	104,000.0	554.3	0.7	0.3	1.1
09/12/2020 18:00	3,818.3	85.1	3,833.6	104,000.0	398.7	0.5	0.2	0.8
09/12/2020 19:00	3,533.8	0.0	3,533.8	104,000.0	367.5	0.4	0.2	0.7
09/12/2020 20:00	3,480.7	0.0	3,480.7	104,000.0	362.0	0.4	0.2	0.7
09/12/2020 21:00	3,860.9	67.5	3,891.3	104,000.0	404.7	0.5	0.2	0.8
09/12/2020 22:00	3,541.9	12.8	3,542.9	104,000.0	368.5	0.4	0.2	0.7
09/12/2020 23:00	3,420.1	0.0	3,420.1	104,000.0	355.7	0.4	0.2	0.7
Average/Sum#:	3,355.1	226.9	3,575.2	104,000.0	371.8	0.4	0.2	0.8
Minimum:	2,733.3	0.0	2,733.3	104,000.0	284.3	0.3	0.2	0.6
Maximum:	3,861.4	1,675.2	5,506.5	104,000.0	572.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2020 00:00	3,137.0	0.0	3,137.0	104,000.0	326.2	0.4	0.2	0.7
09/13/2020 01:00	2,899.9	0.0	2,899.9	104,000.0	301.6	0.4	0.2	0.6
09/13/2020 02:00	2,753.2	0.0	2,753.2	104,000.0	286.3	0.3	0.2	0.6
09/13/2020 03:00	2,756.2	0.0	2,756.2	104,000.0	286.6	0.3	0.2	0.6
09/13/2020 04:00	2,754.4	0.0	2,754.4	104,000.0	286.5	0.3	0.2	0.6
09/13/2020 05:00	2,736.4	0.0	2,736.4	104,000.0	284.6	0.3	0.2	0.6
09/13/2020 06:00	2,730.7	0.0	2,730.7	104,000.0	284.0	0.3	0.2	0.6
09/13/2020 07:00	2,745.5	0.0	2,745.5	104,000.0	285.5	0.3	0.2	0.6
09/13/2020 08:00	3,063.7	0.0	3,063.7	104,000.0	318.6	0.4	0.2	0.6
09/13/2020 09:00	3,472.4	0.0	3,472.4	104,000.0	361.1	0.4	0.2	0.7
09/13/2020 10:00	3,792.5	2.1	3,792.6	104,000.0	394.4	0.5	0.2	0.8
09/13/2020 11:00	3,890.9	391.1	4,270.3	104,000.0	444.1	0.5	0.3	0.9
09/13/2020 12:00	3,863.2	595.0	4,458.2	104,000.0	463.7	0.6	0.3	0.9
09/13/2020 13:00	3,840.9	1,067.3	4,908.2	104,000.0	510.5	0.6	0.3	1.0
09/13/2020 14:00	3,825.0	1,314.5	5,139.5	104,000.0	534.5	0.6	0.3	1.1
09/13/2020 15:00	3,817.5	1,064.2	4,881.7	104,000.0	507.7	0.6	0.3	1.0
09/13/2020 16:00	3,822.5	215.4	4,037.9	104,000.0	419.9	0.5	0.3	0.8
09/13/2020 17:00	3,824.5	299.1	4,123.6	104,000.0	428.9	0.5	0.3	0.9
09/13/2020 18:00	3,810.0	335.5	4,088.5	104,000.0	425.2	0.5	0.3	0.9
09/13/2020 19:00	3,343.8	0.0	3,343.8	104,000.0	347.8	0.4	0.2	0.7
09/13/2020 20:00	3,835.7	772.6	4,453.8	104,000.0	463.2	0.6	0.3	1.0
09/13/2020 21:00	3,902.7	259.5	4,162.2	104,000.0	432.9	0.5	0.3	0.9
09/13/2020 22:00	3,700.9	63.6	3,718.1	104,000.0	386.7	0.5	0.2	0.8
09/13/2020 23:00	3,185.0	0.0	3,185.0	104,000.0	331.2	0.4	0.2	0.7
Average/Sum#:	3,396.0	265.8	3,650.5	104,000.0	379.7	0.4	0.2	0.8
Minimum:	2,730.7	0.0	2,730.7	104,000.0	284.0	0.3	0.2	0.6
Maximum:	3,902.7	1,314.5	5,139.5	104,000.0	534.5	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2020 00:00	2,903.6	0.0	2,903.6	104,000.0	302.0	0.4	0.2	0.6
09/14/2020 01:00	2,726.1	0.0	2,726.1	104,000.0	283.5	0.3	0.2	0.6
09/14/2020 02:00	2,727.3	0.0	2,727.3	104,000.0	283.6	0.3	0.2	0.6
09/14/2020 03:00	2,728.7	0.0	2,728.7	104,000.0	283.8	0.3	0.2	0.6
09/14/2020 04:00	2,743.0	0.0	2,743.0	104,000.0	285.3	0.3	0.2	0.6
09/14/2020 05:00	2,736.5	0.0	2,736.5	104,000.0	284.6	0.3	0.2	0.6
09/14/2020 06:00	2,776.5	0.0	2,776.5	104,000.0	288.8	0.3	0.2	0.6
09/14/2020 07:00	2,990.3	0.0	2,990.3	104,000.0	311.0	0.4	0.2	0.6
09/14/2020 08:00	3,325.4	0.0	3,325.4	104,000.0	345.8	0.4	0.2	0.7
09/14/2020 09:00	3,580.9	0.0	3,580.9	104,000.0	372.4	0.4	0.2	0.7
09/14/2020 10:00	3,784.3	0.0	3,784.3	104,000.0	393.6	0.5	0.2	0.8
09/14/2020 11:00	3,883.8	18.9	3,885.1	104,000.0	404.1	0.5	0.2	0.8
09/14/2020 12:00	3,869.5	522.6	4,392.1	104,000.0	456.8	0.5	0.3	0.9
09/14/2020 13:00	3,854.0	1,396.7	5,250.7	104,000.0	546.1	0.7	0.3	1.1
09/14/2020 14:00	3,846.5	1,860.4	5,706.9	104,000.0	593.5	0.7	0.4	1.2
09/14/2020 15:00	3,831.9	1,329.5	5,161.4	104,000.0	536.8	0.6	0.3	1.1
09/14/2020 16:00	3,836.3	1,663.9	5,500.2	104,000.0	572.0	0.7	0.3	1.1
09/14/2020 17:00	3,847.2	1,872.1	5,719.3	104,000.0	594.8	0.7	0.4	1.2
09/14/2020 18:00	3,867.2	1,465.8	5,333.0	104,000.0	554.6	0.7	0.3	1.1
09/14/2020 19:00	3,517.9	0.4	3,517.9	104,000.0	365.9	0.4	0.2	0.7
09/14/2020 20:00	3,642.3	0.0	3,642.3	104,000.0	378.8	0.5	0.2	0.8
09/14/2020 21:00	3,922.2	153.3	4,014.2	104,000.0	417.5	0.5	0.3	0.8
09/14/2020 22:00	3,644.7	0.0	3,644.7	104,000.0	379.0	0.5	0.2	0.8
09/14/2020 23:00	3,203.6	0.0	3,203.6	104,000.0	333.2	0.4	0.2	0.7
Average/Sum#:	3,407.9	428.5	3,833.1	104,000.0	398.6	0.5	0.2	0.8
Minimum:	2,726.1	0.0	2,726.1	104,000.0	283.5	0.3	0.2	0.6
Maximum:	3,922.2	1,872.1	5,719.3	104,000.0	594.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2020 00:00	3,028.3	0.0	3,028.3	104,000.0	314.9	0.4	0.2	0.6
09/15/2020 01:00	2,863.8	0.0	2,863.8	104,000.0	297.8	0.4	0.2	0.6
09/15/2020 02:00	2,731.6	0.0	2,731.6	104,000.0	284.1	0.3	0.2	0.6
09/15/2020 03:00	2,731.4	0.0	2,731.4	104,000.0	284.1	0.3	0.2	0.6
09/15/2020 04:00	2,784.5	0.0	2,784.5	104,000.0	289.6	0.3	0.2	0.6
09/15/2020 05:00	2,951.5	0.0	2,951.5	104,000.0	307.0	0.4	0.2	0.6
09/15/2020 06:00	2,989.9	0.0	2,989.9	104,000.0	310.9	0.4	0.2	0.6
09/15/2020 07:00	3,203.0	0.0	3,203.0	104,000.0	333.1	0.4	0.2	0.7
09/15/2020 08:00	3,573.3	0.0	3,573.3	104,000.0	371.6	0.4	0.2	0.7
09/15/2020 09:00	3,819.7	0.0	3,819.7	104,000.0	397.2	0.5	0.2	0.8
09/15/2020 10:00	3,885.3	0.8	3,885.3	104,000.0	404.1	0.5	0.2	0.8
09/15/2020 11:00	3,880.2	243.2	4,123.4	104,000.0	428.8	0.5	0.3	0.9
09/15/2020 12:00	3,853.0	1,211.8	5,064.8	104,000.0	526.7	0.6	0.3	1.1
09/15/2020 13:00	3,845.9	1,762.5	5,608.4	104,000.0	583.3	0.7	0.3	1.2
09/15/2020 14:00	3,845.9	1,850.1	5,696.0	104,000.0	592.4	0.7	0.4	1.2
09/15/2020 15:00	3,841.9	1,762.1	5,604.0	104,000.0	582.8	0.7	0.3	1.2
09/15/2020 16:00	3,853.3	1,464.6	5,317.9	104,000.0	553.1	0.7	0.3	1.1
09/15/2020 17:00	3,841.6	1,489.2	5,330.8	104,000.0	554.4	0.7	0.3	1.1
09/15/2020 18:00	3,855.9	837.3	4,693.2	104,000.0	488.1	0.6	0.3	1.0
09/15/2020 19:00	3,844.9	259.5	3,992.8	104,000.0	415.3	0.5	0.3	0.9
09/15/2020 20:00	3,446.5	0.0	3,446.5	104,000.0	358.4	0.4	0.2	0.7
09/15/2020 21:00	3,837.3	0.0	3,837.3	104,000.0	399.1	0.5	0.2	0.8
09/15/2020 22:00	3,443.9	0.0	3,443.9	104,000.0	358.2	0.4	0.2	0.7
09/15/2020 23:00	3,393.3	0.0	3,393.3	104,000.0	352.9	0.4	0.2	0.7
Average/Sum#:	3,472.7	453.4	3,921.4	104,000.0	407.8	0.5	0.2	0.8
Minimum:	2,731.4	0.0	2,731.4	104,000.0	284.1	0.3	0.2	0.6
Maximum:	3,885.3	1,850.1	5,696.0	104,000.0	592.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2020 00:00	3,289.4	0.0	3,289.4	104,000.0	342.1	0.4	0.2	0.7
09/16/2020 01:00	3,231.2	0.0	3,231.2	104,000.0	336.0	0.4	0.2	0.7
09/16/2020 02:00	3,102.1	0.0	3,102.1	104,000.0	322.6	0.4	0.2	0.6
09/16/2020 03:00	3,088.5	0.0	3,088.5	104,000.0	321.2	0.4	0.2	0.6
09/16/2020 04:00	3,103.1	0.0	3,103.1	104,000.0	322.7	0.4	0.2	0.6
09/16/2020 05:00	3,286.2	0.0	3,286.2	104,000.0	341.8	0.4	0.2	0.7
09/16/2020 06:00	3,422.4	0.0	3,422.4	104,000.0	355.9	0.4	0.2	0.7
09/16/2020 07:00	3,669.9	0.0	3,669.9	104,000.0	381.7	0.5	0.2	0.8
09/16/2020 08:00	3,854.9	0.0	3,854.9	104,000.0	400.9	0.5	0.2	0.8
09/16/2020 09:00	3,869.8	13.1	3,870.8	104,000.0	402.6	0.5	0.2	0.8
09/16/2020 10:00	3,891.0	324.1	4,215.1	104,000.0	438.4	0.5	0.3	0.9
09/16/2020 11:00	3,867.6	1,035.5	4,903.1	104,000.0	509.9	0.6	0.3	1.0
09/16/2020 12:00	3,839.2	1,626.4	5,465.6	104,000.0	568.4	0.7	0.3	1.1
09/16/2020 13:00	3,842.0	1,439.9	5,281.9	104,000.0	549.3	0.7	0.3	1.1
09/16/2020 14:00	3,836.3	1,804.8	5,641.1	104,000.0	586.7	0.7	0.4	1.2
09/16/2020 15:00	3,818.1	1,835.1	5,653.2	104,000.0	587.9	0.7	0.4	1.2
09/16/2020 16:00	3,816.1	1,865.8	5,681.9	104,000.0	590.9	0.7	0.4	1.2
09/16/2020 17:00	3,821.6	1,813.4	5,635.0	104,000.0	586.0	0.7	0.4	1.2
09/16/2020 18:00	3,834.3	1,382.8	5,217.1	104,000.0	542.6	0.6	0.3	1.1
09/16/2020 19:00	3,851.5	669.9	4,521.4	104,000.0	470.2	0.6	0.3	0.9
09/16/2020 20:00	3,868.0	356.1	4,224.1	104,000.0	439.3	0.5	0.3	0.9
09/16/2020 21:00	3,871.4	372.4	4,225.2	104,000.0	439.4	0.5	0.3	0.9
09/16/2020 22:00	3,514.1	0.0	3,514.1	104,000.0	365.5	0.4	0.2	0.7
09/16/2020 23:00	3,463.2	0.0	3,463.2	104,000.0	360.2	0.4	0.2	0.7
Average/Sum#:	3,627.2	605.8	4,231.7	104,000.0	440.1	0.5	0.3	0.9
Minimum:	3,088.5	0.0	3,088.5	104,000.0	321.2	0.4	0.2	0.6
Maximum:	3,891.0	1,865.8	5,681.9	104,000.0	590.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2020 00:00	3,345.3	0.0	3,345.3	104,000.0	347.9	0.4	0.2	0.7
09/17/2020 01:00	3,219.2	0.0	3,219.2	104,000.0	334.8	0.4	0.2	0.7
09/17/2020 02:00	3,170.8	0.0	3,170.8	104,000.0	329.8	0.4	0.2	0.7
09/17/2020 03:00	3,164.1	0.0	3,164.1	104,000.0	329.1	0.4	0.2	0.7
09/17/2020 04:00	3,337.9	0.0	3,337.9	104,000.0	347.1	0.4	0.2	0.7
09/17/2020 05:00	3,446.1	0.0	3,446.1	104,000.0	358.4	0.4	0.2	0.7
09/17/2020 06:00	3,638.4	0.0	3,638.4	104,000.0	378.4	0.5	0.2	0.8
09/17/2020 07:00	3,869.1	0.0	3,869.1	104,000.0	402.4	0.5	0.2	0.8
09/17/2020 08:00	3,857.2	0.0	3,857.2	104,000.0	401.1	0.5	0.2	0.8
09/17/2020 09:00	3,890.0	10.5	3,891.1	104,000.0	404.7	0.5	0.2	0.8
09/17/2020 10:00	3,876.6	238.1	4,114.7	104,000.0	427.9	0.5	0.3	0.9
09/17/2020 11:00	3,853.6	412.9	4,266.5	104,000.0	443.7	0.5	0.3	0.9
09/17/2020 12:00	3,826.0	523.4	4,349.4	104,000.0	452.3	0.5	0.3	0.9
09/17/2020 13:00	3,820.5	795.9	4,616.4	104,000.0	480.1	0.6	0.3	1.0
09/17/2020 14:00	3,806.2	1,080.7	4,886.9	104,000.0	508.2	0.6	0.3	1.0
09/17/2020 15:00	3,799.8	1,840.5	5,640.3	104,000.0	586.6	0.7	0.4	1.2
09/17/2020 16:00	3,795.2	1,868.8	5,664.0	104,000.0	589.1	0.7	0.4	1.2
09/17/2020 17:00	3,817.4	1,230.3	5,047.7	104,000.0	525.0	0.6	0.3	1.1
09/17/2020 18:00	3,854.7	968.4	4,823.1	104,000.0	501.6	0.6	0.3	1.0
09/17/2020 19:00	3,867.8	370.5	4,238.3	104,000.0	440.8	0.5	0.3	0.9
09/17/2020 20:00	3,889.8	529.7	4,419.5	104,000.0	459.6	0.6	0.3	0.9
09/17/2020 21:00	3,901.6	734.3	4,635.9	104,000.0	482.1	0.6	0.3	1.0
09/17/2020 22:00	3,866.8	16.0	3,867.9	104,000.0	402.3	0.5	0.2	0.8
09/17/2020 23:00	3,356.1	0.0	3,356.1	104,000.0	349.0	0.4	0.2	0.7
Average/Sum#:	3,677.9	442.5	4,119.4	104,000.0	428.4	0.5	0.3	0.9
Minimum:	3,164.1	0.0	3,164.1	104,000.0	329.1	0.4	0.2	0.7
Maximum:	3,901.6	1,868.8	5,664.0	104,000.0	589.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2020 00:00	3,154.5	0.0	3,154.5	104,000.0	328.1	0.4	0.2	0.7
09/18/2020 01:00	2,893.7	0.0	2,893.7	104,000.0	300.9	0.4	0.2	0.6
09/18/2020 02:00	2,856.4	0.0	2,856.4	104,000.0	297.1	0.4	0.2	0.6
09/18/2020 03:00	2,858.2	0.0	2,858.2	104,000.0	297.3	0.4	0.2	0.6
09/18/2020 04:00	2,974.9	0.0	2,974.9	104,000.0	309.4	0.4	0.2	0.6
09/18/2020 05:00	3,263.0	0.0	3,263.0	104,000.0	339.4	0.4	0.2	0.7
09/18/2020 06:00	3,487.0	0.0	3,487.0	104,000.0	362.6	0.4	0.2	0.7
09/18/2020 07:00	3,729.3	0.0	3,729.3	104,000.0	387.8	0.5	0.2	0.8
09/18/2020 08:00	3,846.7	232.9	4,074.9	104,000.0	423.8	0.5	0.3	0.8
09/18/2020 09:00	3,821.9	265.2	4,087.1	104,000.0	425.1	0.5	0.3	0.9
09/18/2020 10:00	3,795.8	588.4	4,384.2	104,000.0	456.0	0.5	0.3	0.9
09/18/2020 11:00	3,745.2	770.2	4,515.4	104,000.0	469.6	0.6	0.3	0.9
09/18/2020 12:00	3,854.6	890.1	4,744.7	104,000.0	493.4	0.6	0.3	1.0
09/18/2020 13:00	3,871.8	1,211.8	5,083.6	104,000.0	528.7	0.6	0.3	1.1
09/18/2020 14:00	3,872.1	1,184.4	5,056.5	104,000.0	525.9	0.6	0.3	1.1
09/18/2020 15:00	3,869.1	286.5	4,155.6	104,000.0	432.2	0.5	0.3	0.9
09/18/2020 16:00	3,871.6	448.9	4,320.5	104,000.0	449.3	0.5	0.3	0.9
09/18/2020 17:00	3,871.8	890.1	4,761.9	104,000.0	495.2	0.6	0.3	1.0
09/18/2020 18:00	3,885.7	202.0	4,087.7	104,000.0	425.1	0.5	0.3	0.9
09/18/2020 19:00	3,296.7	1.7	3,296.7	104,000.0	342.9	0.4	0.2	0.7
09/18/2020 20:00	3,855.2	630.8	4,391.4	104,000.0	456.7	0.6	0.3	0.9
09/18/2020 21:00	3,875.0	16.5	3,876.3	104,000.0	403.1	0.5	0.2	0.8
09/18/2020 22:00	3,423.6	0.0	3,423.6	104,000.0	356.1	0.4	0.2	0.7
09/18/2020 23:00	3,259.9	0.0	3,259.9	104,000.0	339.0	0.4	0.2	0.7
Average/Sum#:	3,551.4	317.5	3,864.0	104,000.0	401.9	0.5	0.3	0.8
Minimum:	2,856.4	0.0	2,856.4	104,000.0	297.1	0.4	0.2	0.6
Maximum:	3,885.7	1,211.8	5,083.6	104,000.0	528.7	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2020 00:00	2,943.5	0.0	2,943.5	104,000.0	306.1	0.4	0.2	0.6
09/19/2020 01:00	2,830.6	0.0	2,830.6	104,000.0	294.4	0.4	0.2	0.6
09/19/2020 02:00	2,723.2	0.0	2,723.2	104,000.0	283.2	0.3	0.2	0.6
09/19/2020 03:00	2,722.4	0.0	2,722.4	104,000.0	283.1	0.3	0.2	0.6
09/19/2020 04:00	2,721.4	0.0	2,721.4	104,000.0	283.0	0.3	0.2	0.6
09/19/2020 05:00	2,889.4	0.0	2,889.4	104,000.0	300.5	0.4	0.2	0.6
09/19/2020 06:00	3,010.1	0.0	3,010.1	104,000.0	313.1	0.4	0.2	0.6
09/19/2020 07:00	3,368.8	0.0	3,368.8	104,000.0	350.4	0.4	0.2	0.7
09/19/2020 08:00	3,653.6	0.0	3,653.6	104,000.0	380.0	0.5	0.2	0.8
09/19/2020 09:00	3,853.6	0.0	3,853.6	104,000.0	400.8	0.5	0.2	0.8
09/19/2020 10:00	3,913.1	7.3	3,913.5	104,000.0	407.0	0.5	0.2	0.8
09/19/2020 11:00	3,881.8	338.3	4,220.1	104,000.0	438.9	0.5	0.3	0.9
09/19/2020 12:00	3,860.6	844.0	4,704.6	104,000.0	489.3	0.6	0.3	1.0
09/19/2020 13:00	3,846.9	918.8	4,765.7	104,000.0	495.6	0.6	0.3	1.0
09/19/2020 14:00	3,842.2	729.3	4,571.5	104,000.0	475.4	0.6	0.3	1.0
09/19/2020 15:00	3,838.8	829.6	4,668.4	104,000.0	485.5	0.6	0.3	1.0
09/19/2020 16:00	3,833.4	49.7	3,869.7	104,000.0	402.4	0.5	0.2	0.8
09/19/2020 17:00	3,813.7	0.0	3,813.7	104,000.0	396.6	0.5	0.2	0.8
09/19/2020 18:00	3,860.8	181.6	3,969.8	104,000.0	412.9	0.5	0.3	0.8
09/19/2020 19:00	3,877.5	861.0	4,738.5	104,000.0	492.8	0.6	0.3	1.0
09/19/2020 20:00	3,860.0	6.6	3,860.3	104,000.0	401.5	0.5	0.2	0.8
09/19/2020 21:00	3,690.7	0.0	3,690.7	104,000.0	383.8	0.5	0.2	0.8
09/19/2020 22:00	3,435.9	0.0	3,435.9	104,000.0	357.3	0.4	0.2	0.7
09/19/2020 23:00	3,220.0	0.0	3,220.0	104,000.0	334.9	0.4	0.2	0.7
Average/Sum#:	3,478.8	198.6	3,673.3	104,000.0	382.0	0.5	0.2	0.8
Minimum:	2,721.4	0.0	2,721.4	104,000.0	283.0	0.3	0.2	0.6
Maximum:	3,913.1	918.8	4,765.7	104,000.0	495.6	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2020 00:00	2,873.8	0.0	2,873.8	104,000.0	298.9	0.4	0.2	0.6
09/20/2020 01:00	2,720.8	0.0	2,720.8	104,000.0	283.0	0.3	0.2	0.6
09/20/2020 02:00	2,721.9	0.0	2,721.9	104,000.0	283.1	0.3	0.2	0.6
09/20/2020 03:00	2,722.2	0.0	2,722.2	104,000.0	283.1	0.3	0.2	0.6
09/20/2020 04:00	2,726.1	0.0	2,726.1	104,000.0	283.5	0.3	0.2	0.6
09/20/2020 05:00	2,739.9	0.0	2,739.9	104,000.0	284.9	0.3	0.2	0.6
09/20/2020 06:00	2,738.0	0.0	2,738.0	104,000.0	284.8	0.3	0.2	0.6
09/20/2020 07:00	2,724.2	0.0	2,724.2	104,000.0	283.3	0.3	0.2	0.6
09/20/2020 08:00	2,762.6	0.0	2,762.6	104,000.0	287.3	0.3	0.2	0.6
09/20/2020 09:00	3,090.7	0.0	3,090.7	104,000.0	321.4	0.4	0.2	0.6
09/20/2020 10:00	3,463.0	0.0	3,463.0	104,000.0	360.2	0.4	0.2	0.7
09/20/2020 11:00	3,718.0	0.0	3,718.0	104,000.0	386.7	0.5	0.2	0.8
09/20/2020 12:00	3,872.5	740.7	4,613.2	104,000.0	479.8	0.6	0.3	1.0
09/20/2020 13:00	3,852.2	1,286.2	5,138.4	104,000.0	534.4	0.6	0.3	1.1
09/20/2020 14:00	3,847.8	1,726.0	5,573.8	104,000.0	579.7	0.7	0.3	1.2
09/20/2020 15:00	3,833.4	1,860.5	5,693.9	104,000.0	592.2	0.7	0.4	1.2
09/20/2020 16:00	3,834.5	1,030.1	4,864.6	104,000.0	505.9	0.6	0.3	1.0
09/20/2020 17:00	3,752.8	139.3	3,839.2	104,000.0	399.3	0.5	0.2	0.8
09/20/2020 18:00	3,828.1	0.0	3,828.1	104,000.0	398.1	0.5	0.2	0.8
09/20/2020 19:00	3,739.1	0.0	3,739.1	104,000.0	388.9	0.5	0.2	0.8
09/20/2020 20:00	3,861.8	587.3	4,449.1	104,000.0	462.7	0.6	0.3	0.9
09/20/2020 21:00	3,814.5	1.4	3,814.5	104,000.0	396.7	0.5	0.2	0.8
09/20/2020 22:00	3,457.8	0.0	3,457.8	104,000.0	359.6	0.4	0.2	0.7
09/20/2020 23:00	3,268.7	0.0	3,268.7	104,000.0	339.9	0.4	0.2	0.7
Average/Sum#:	3,331.9	307.1	3,636.7	104,000.0	378.2	0.4	0.2	0.8
Minimum:	2,720.8	0.0	2,720.8	104,000.0	283.0	0.3	0.2	0.6
Maximum:	3,872.5	1,860.5	5,693.9	104,000.0	592.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2020 00:00	2,914.1	0.0	2,914.1	104,000.0	303.1	0.4	0.2	0.6
09/21/2020 01:00	2,716.0	0.0	2,716.0	104,000.0	282.5	0.3	0.2	0.6
09/21/2020 02:00	2,728.9	0.0	2,728.9	104,000.0	283.8	0.3	0.2	0.6
09/21/2020 03:00	2,855.9	0.0	2,855.9	104,000.0	297.0	0.4	0.2	0.6
09/21/2020 04:00	2,964.8	0.0	2,964.8	104,000.0	308.3	0.4	0.2	0.6
09/21/2020 05:00	3,230.1	0.0	3,230.1	104,000.0	335.9	0.4	0.2	0.7
09/21/2020 06:00	3,420.8	0.0	3,420.8	104,000.0	355.8	0.4	0.2	0.7
09/21/2020 07:00	3,518.0	0.0	3,518.0	104,000.0	365.9	0.4	0.2	0.7
09/21/2020 08:00	3,763.3	0.0	3,763.3	104,000.0	391.4	0.5	0.2	0.8
09/21/2020 09:00	3,858.3	7.9	3,859.1	104,000.0	401.3	0.5	0.2	0.8
09/21/2020 10:00	3,887.1	228.4	4,115.5	104,000.0	428.0	0.5	0.3	0.9
09/21/2020 11:00	3,868.5	1,370.3	5,238.8	104,000.0	544.8	0.7	0.3	1.1
09/21/2020 12:00	3,841.2	1,597.0	5,438.2	104,000.0	565.6	0.7	0.3	1.1
09/21/2020 13:00	3,827.3	1,903.1	5,730.4	104,000.0	596.0	0.7	0.4	1.2
09/21/2020 14:00	3,824.8	1,902.5	5,727.3	104,000.0	595.6	0.7	0.4	1.2
09/21/2020 15:00	3,827.9	1,903.9	5,731.8	104,000.0	596.1	0.7	0.4	1.2
09/21/2020 16:00	3,827.1	1,687.5	5,514.6	104,000.0	573.5	0.7	0.3	1.1
09/21/2020 17:00	3,852.0	1,733.0	5,585.0	104,000.0	580.8	0.7	0.3	1.2
09/21/2020 18:00	3,869.7	1,599.8	5,469.5	104,000.0	568.8	0.7	0.3	1.1
09/21/2020 19:00	3,886.6	547.2	4,422.9	104,000.0	460.0	0.6	0.3	0.9
09/21/2020 20:00	3,748.7	0.0	3,748.7	104,000.0	389.9	0.5	0.2	0.8
09/21/2020 21:00	3,922.2	203.7	4,101.5	104,000.0	426.6	0.5	0.3	0.9
09/21/2020 22:00	3,663.8	0.0	3,663.8	104,000.0	381.0	0.5	0.2	0.8
09/21/2020 23:00	3,273.4	0.0	3,273.4	104,000.0	340.4	0.4	0.2	0.7
Average/Sum#:	3,545.4	611.8	4,155.5	104,000.0	432.2	0.5	0.3	0.9
Minimum:	2,716.0	0.0	2,716.0	104,000.0	282.5	0.3	0.2	0.6
Maximum:	3,922.2	1,903.9	5,731.8	104,000.0	596.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2020 00:00	2,977.3	0.0	2,977.3	104,000.0	309.6	0.4	0.2	0.6
09/22/2020 01:00	2,975.1	0.0	2,975.1	104,000.0	309.4	0.4	0.2	0.6
09/22/2020 02:00	2,876.0	0.0	2,876.0	104,000.0	299.1	0.4	0.2	0.6
09/22/2020 03:00	2,874.5	0.0	2,874.5	104,000.0	298.9	0.4	0.2	0.6
09/22/2020 04:00	3,030.4	0.0	3,030.4	104,000.0	315.2	0.4	0.2	0.6
09/22/2020 05:00	3,366.6	0.0	3,366.6	104,000.0	350.1	0.4	0.2	0.7
09/22/2020 06:00	3,296.0	0.0	3,296.0	104,000.0	342.8	0.4	0.2	0.7
09/22/2020 07:00	3,564.5	0.0	3,564.5	104,000.0	370.7	0.4	0.2	0.7
09/22/2020 08:00	3,834.7	0.0	3,834.7	104,000.0	398.8	0.5	0.2	0.8
09/22/2020 09:00	3,928.9	116.3	4,030.1	104,000.0	419.1	0.5	0.3	0.8
09/22/2020 10:00	3,921.5	740.8	4,662.3	104,000.0	484.9	0.6	0.3	1.0
09/22/2020 11:00	3,901.9	908.6	4,810.5	104,000.0	500.3	0.6	0.3	1.0
09/22/2020 12:00	3,881.1	1,424.3	5,305.4	104,000.0	551.8	0.7	0.3	1.1
09/22/2020 13:00	3,865.7	1,465.5	5,331.2	104,000.0	554.4	0.7	0.3	1.1
09/22/2020 14:00	3,862.4	1,259.4	5,121.8	104,000.0	532.7	0.6	0.3	1.1
09/22/2020 15:00	3,869.2	1,049.7	4,918.9	104,000.0	511.6	0.6	0.3	1.0
09/22/2020 16:00	3,876.1	1,386.0	5,262.1	104,000.0	547.3	0.7	0.3	1.1
09/22/2020 17:00	3,881.9	1,134.2	5,016.1	104,000.0	521.7	0.6	0.3	1.0
09/22/2020 18:00	3,908.9	767.7	4,653.6	104,000.0	484.0	0.6	0.3	1.0
09/22/2020 19:00	3,745.4	0.0	3,745.4	104,000.0	389.5	0.5	0.2	0.8
09/22/2020 20:00	3,946.1	767.0	4,636.4	104,000.0	482.2	0.6	0.3	1.0
09/22/2020 21:00	3,852.9	48.8	3,860.2	104,000.0	401.5	0.5	0.2	0.8
09/22/2020 22:00	3,349.6	0.0	3,349.6	104,000.0	348.4	0.4	0.2	0.7
09/22/2020 23:00	3,122.0	0.0	3,122.0	104,000.0	324.7	0.4	0.2	0.6
Average/Sum#:	3,571.2	461.2	4,025.9	104,000.0	418.7	0.5	0.2	0.8
Minimum:	2,874.5	0.0	2,874.5	104,000.0	298.9	0.4	0.2	0.6
Maximum:	3,946.1	1,465.5	5,331.2	104,000.0	554.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2020 00:00	2,765.9	0.0	2,765.9	104,000.0	287.7	0.3	0.2	0.6
09/23/2020 01:00	2,730.4	0.0	2,730.4	104,000.0	284.0	0.3	0.2	0.6
09/23/2020 02:00	2,730.1	0.0	2,730.1	104,000.0	283.9	0.3	0.2	0.6
09/23/2020 03:00	2,727.9	0.0	2,727.9	104,000.0	283.7	0.3	0.2	0.6
09/23/2020 04:00	2,746.0	0.0	2,746.0	104,000.0	285.6	0.3	0.2	0.6
09/23/2020 05:00	3,064.2	0.0	3,064.2	104,000.0	318.7	0.4	0.2	0.6
09/23/2020 06:00	3,214.6	0.0	3,214.6	104,000.0	334.3	0.4	0.2	0.7
09/23/2020 07:00	3,407.8	0.0	3,407.8	104,000.0	354.4	0.4	0.2	0.7
09/23/2020 08:00	3,797.5	0.0	3,797.5	104,000.0	394.9	0.5	0.2	0.8
09/23/2020 09:00	3,954.6	0.0	3,954.6	104,000.0	411.3	0.5	0.2	0.8
09/23/2020 10:00	3,921.4	24.6	3,923.4	104,000.0	408.0	0.5	0.2	0.8
09/23/2020 11:00	3,896.4	389.7	4,286.1	104,000.0	445.8	0.5	0.3	0.9
09/23/2020 12:00	3,879.8	643.6	4,523.4	104,000.0	470.4	0.6	0.3	0.9
09/23/2020 13:00	3,867.0	774.7	4,641.7	104,000.0	482.7	0.6	0.3	1.0
09/23/2020 14:00	3,861.0	1,424.4	5,285.4	104,000.0	549.7	0.7	0.3	1.1
09/23/2020 15:00	3,853.5	1,020.6	4,874.1	104,000.0	506.9	0.6	0.3	1.0
09/23/2020 16:00	3,852.5	1,463.1	5,315.6	104,000.0	552.8	0.7	0.3	1.1
09/23/2020 17:00	3,856.9	1,868.1	5,725.0	104,000.0	595.4	0.7	0.4	1.2
09/23/2020 18:00	3,874.1	1,752.1	5,626.2	104,000.0	585.1	0.7	0.4	1.2
09/23/2020 19:00	3,888.8	1,009.6	4,898.4	104,000.0	509.4	0.6	0.3	1.0
09/23/2020 20:00	3,905.6	390.4	4,296.0	104,000.0	446.8	0.5	0.3	0.9
09/23/2020 21:00	3,907.6	180.8	4,064.9	104,000.0	422.7	0.5	0.3	0.8
09/23/2020 22:00	3,765.1	0.0	3,765.1	104,000.0	391.6	0.5	0.2	0.8
09/23/2020 23:00	3,946.0	0.0	3,946.0	104,000.0	410.4	0.5	0.2	0.8
Average/Sum#:	3,558.9	455.9	4,012.9	104,000.0	417.3	0.5	0.3	0.8
Minimum:	2,727.9	0.0	2,727.9	104,000.0	283.7	0.3	0.2	0.6
Maximum:	3,954.6	1,868.1	5,725.0	104,000.0	595.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2020 00:00	3,939.3	0.0	3,939.3	104,000.0	409.7	0.5	0.2	0.8
09/24/2020 01:00	3,748.1	0.0	3,748.1	104,000.0	389.8	0.5	0.2	0.8
09/24/2020 02:00	3,494.3	0.0	3,494.3	104,000.0	363.4	0.4	0.2	0.7
09/24/2020 03:00	3,489.7	0.0	3,489.7	104,000.0	362.9	0.4	0.2	0.7
09/24/2020 04:00	3,711.9	0.0	3,711.9	104,000.0	386.0	0.5	0.2	0.8
09/24/2020 05:00	3,098.9	0.0	3,098.9	104,000.0	322.3	0.4	0.2	0.6
09/24/2020 06:00	3,074.0	0.0	3,074.0	104,000.0	319.7	0.4	0.2	0.6
09/24/2020 07:00	3,198.5	0.0	3,198.5	104,000.0	332.6	0.4	0.2	0.7
09/24/2020 08:00	3,872.5	0.0	3,872.5	104,000.0	402.7	0.5	0.2	0.8
09/24/2020 09:00	3,888.4	0.0	3,888.4	104,000.0	404.4	0.5	0.2	0.8
09/24/2020 10:00	3,878.8	0.0	3,878.8	104,000.0	403.4	0.5	0.2	0.8
09/24/2020 11:00	3,861.2	0.0	3,861.2	104,000.0	401.6	0.5	0.2	0.8
09/24/2020 12:00	3,840.6	426.6	4,258.7	104,000.0	442.9	0.5	0.3	0.9
09/24/2020 13:00	3,836.5	491.4	4,327.9	104,000.0	450.1	0.5	0.3	0.9
09/24/2020 14:00	3,815.3	488.1	4,303.4	104,000.0	447.6	0.5	0.3	0.9
09/24/2020 15:00	3,795.1	1,388.1	5,183.2	104,000.0	539.1	0.6	0.3	1.1
09/24/2020 16:00	3,787.6	1,883.9	5,671.5	104,000.0	589.8	0.7	0.4	1.2
09/24/2020 17:00	3,813.5	1,891.3	5,704.8	104,000.0	593.3	0.7	0.4	1.2
09/24/2020 18:00	3,866.8	1,861.6	5,728.4	104,000.0	595.8	0.7	0.4	1.2
09/24/2020 19:00	3,898.0	816.1	4,714.1	104,000.0	490.3	0.6	0.3	1.0
09/24/2020 20:00	3,907.1	350.3	4,211.9	104,000.0	438.0	0.5	0.3	0.9
09/24/2020 21:00	3,610.5	0.0	3,610.5	104,000.0	375.5	0.5	0.2	0.8
09/24/2020 22:00	3,732.1	0.0	3,732.1	104,000.0	388.1	0.5	0.2	0.8
09/24/2020 23:00	3,834.3	42.0	3,848.2	104,000.0	400.2	0.5	0.2	0.8
Average/Sum#:	3,708.0	401.6	4,106.3	104,000.0	427.1	0.5	0.3	0.9
Minimum:	3,074.0	0.0	3,074.0	104,000.0	319.7	0.4	0.2	0.6
Maximum:	3,939.3	1,891.3	5,728.4	104,000.0	595.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2020 00:00	3,546.5	0.0	3,546.5	104,000.0	368.8	0.4	0.2	0.7
09/25/2020 01:00	3,299.8	0.0	3,299.8	104,000.0	343.2	0.4	0.2	0.7
09/25/2020 02:00	3,075.0	0.0	3,075.0	104,000.0	319.8	0.4	0.2	0.6
09/25/2020 03:00	3,070.0	0.0	3,070.0	104,000.0	319.3	0.4	0.2	0.6
09/25/2020 04:00	3,275.4	0.0	3,275.4	104,000.0	340.6	0.4	0.2	0.7
09/25/2020 05:00	2,791.3	0.0	2,791.3	104,000.0	290.3	0.4	0.2	0.6
09/25/2020 06:00	2,872.6	0.0	2,872.6	104,000.0	298.8	0.4	0.2	0.6
09/25/2020 07:00	3,009.7	0.0	3,009.7	104,000.0	313.0	0.4	0.2	0.6
09/25/2020 08:00	3,595.7	0.0	3,595.7	104,000.0	374.0	0.4	0.2	0.7
09/25/2020 09:00	3,952.2	0.0	3,952.2	104,000.0	411.0	0.5	0.2	0.8
09/25/2020 10:00	3,908.3	0.0	3,908.3	104,000.0	406.5	0.5	0.2	0.8
09/25/2020 11:00	3,784.8	0.0	3,784.8	104,000.0	393.6	0.5	0.2	0.8
09/25/2020 12:00	3,816.2	0.0	3,816.2	104,000.0	396.9	0.5	0.2	0.8
09/25/2020 13:00	3,879.6	0.0	3,879.6	104,000.0	403.5	0.5	0.2	0.8
09/25/2020 14:00	3,866.2	0.0	3,866.2	104,000.0	402.1	0.5	0.2	0.8
09/25/2020 15:00	3,860.8	0.0	3,860.8	104,000.0	401.5	0.5	0.2	0.8
09/25/2020 16:00	3,804.7	0.0	3,804.7	104,000.0	395.7	0.5	0.2	0.8
09/25/2020 17:00	3,611.4	0.0	3,611.4	104,000.0	375.6	0.4	0.2	0.8
09/25/2020 18:00	3,533.1	0.0	3,533.1	104,000.0	367.4	0.4	0.2	0.7
09/25/2020 19:00	3,473.6	0.0	3,473.6	104,000.0	361.3	0.4	0.2	0.7
09/25/2020 20:00	3,894.0	162.3	4,015.7	104,000.0	417.6	0.5	0.3	0.8
09/25/2020 21:00	3,918.7	0.0	3,918.7	104,000.0	407.5	0.5	0.2	0.8
09/25/2020 22:00	3,926.6	0.0	3,926.6	104,000.0	408.4	0.5	0.2	0.8
09/25/2020 23:00	3,758.5	0.0	3,758.5	104,000.0	390.9	0.5	0.2	0.8
Average/Sum#:	3,563.5	6.8	3,568.6	104,000.0	371.1	0.5	0.2	0.7
Minimum:	2,791.3	0.0	2,791.3	104,000.0	290.3	0.4	0.2	0.6
Maximum:	3,952.2	162.3	4,015.7	104,000.0	417.6	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2020 00:00	3,302.9	0.0	3,302.9	104,000.0	343.5	0.4	0.2	0.7
09/26/2020 01:00	3,039.8	0.0	3,039.8	104,000.0	316.1	0.4	0.2	0.6
09/26/2020 02:00	2,819.8	0.0	2,819.8	104,000.0	293.3	0.4	0.2	0.6
09/26/2020 03:00	2,808.3	0.0	2,808.3	104,000.0	292.1	0.4	0.2	0.6
09/26/2020 04:00	2,901.0	0.0	2,901.0	104,000.0	301.7	0.4	0.2	0.6
09/26/2020 05:00	2,833.5	0.0	2,833.5	104,000.0	294.7	0.4	0.2	0.6
09/26/2020 06:00	2,843.9	0.0	2,843.9	104,000.0	295.8	0.4	0.2	0.6
09/26/2020 07:00	3,008.1	0.0	3,008.1	104,000.0	312.8	0.4	0.2	0.6
09/26/2020 08:00	3,314.0	0.0	3,314.0	104,000.0	344.7	0.4	0.2	0.7
09/26/2020 09:00	3,547.0	0.0	3,547.0	104,000.0	368.9	0.4	0.2	0.7
09/26/2020 10:00	3,422.1	0.0	3,422.1	104,000.0	355.9	0.4	0.2	0.7
09/26/2020 11:00	3,786.5	0.0	3,786.5	104,000.0	393.8	0.5	0.2	0.8
09/26/2020 12:00	3,424.0	0.0	3,424.0	104,000.0	356.1	0.4	0.2	0.7
09/26/2020 13:00	3,551.3	0.0	3,551.3	104,000.0	369.3	0.4	0.2	0.7
09/26/2020 14:00	3,209.3	0.0	3,209.3	104,000.0	333.8	0.4	0.2	0.7
09/26/2020 15:00	3,223.3	0.0	3,223.3	104,000.0	335.2	0.4	0.2	0.7
09/26/2020 16:00	3,276.0	0.0	3,276.0	104,000.0	340.7	0.4	0.2	0.7
09/26/2020 17:00	3,230.6	0.0	3,230.6	104,000.0	336.0	0.4	0.2	0.7
09/26/2020 18:00	3,124.7	0.0	3,124.7	104,000.0	325.0	0.4	0.2	0.6
09/26/2020 19:00	3,084.6	0.0	3,084.6	104,000.0	320.8	0.4	0.2	0.6
09/26/2020 20:00	2,969.0	0.0	2,969.0	104,000.0	308.8	0.4	0.2	0.6
09/26/2020 21:00	3,423.9	0.0	3,423.9	104,000.0	356.1	0.4	0.2	0.7
09/26/2020 22:00	3,358.6	0.0	3,358.6	104,000.0	349.3	0.4	0.2	0.7
09/26/2020 23:00	3,075.3	0.0	3,075.3	104,000.0	319.8	0.4	0.2	0.6
Average/Sum#:	3,190.7	0.0	3,190.7	104,000.0	331.8	0.4	0.2	0.7
Minimum:	2,808.3	0.0	2,808.3	104,000.0	292.1	0.4	0.2	0.6
Maximum:	3,786.5	0.0	3,786.5	104,000.0	393.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2020 00:00	2,898.9	0.0	2,898.9	104,000.0	301.5	0.4	0.2	0.6
09/27/2020 01:00	2,879.5	0.0	2,879.5	104,000.0	299.5	0.4	0.2	0.6
09/27/2020 02:00	2,873.2	0.0	2,873.2	104,000.0	298.8	0.4	0.2	0.6
09/27/2020 03:00	2,875.0	0.0	2,875.0	104,000.0	299.0	0.4	0.2	0.6
09/27/2020 04:00	2,877.9	0.0	2,877.9	104,000.0	299.3	0.4	0.2	0.6
09/27/2020 05:00	2,883.2	0.0	2,883.2	104,000.0	299.9	0.4	0.2	0.6
09/27/2020 06:00	2,872.4	0.0	2,872.4	104,000.0	298.7	0.4	0.2	0.6
09/27/2020 07:00	2,888.4	0.0	2,888.4	104,000.0	300.4	0.4	0.2	0.6
09/27/2020 08:00	3,562.2	0.0	3,562.2	104,000.0	370.5	0.4	0.2	0.7
09/27/2020 09:00	3,390.6	0.0	3,390.6	104,000.0	352.6	0.4	0.2	0.7
09/27/2020 10:00	3,140.0	0.0	3,140.0	104,000.0	326.6	0.4	0.2	0.7
09/27/2020 11:00	3,808.7	81.4	3,847.0	104,000.0	400.1	0.5	0.2	0.8
09/27/2020 12:00	3,707.3	67.1	3,720.7	104,000.0	387.0	0.5	0.2	0.8
09/27/2020 13:00	3,507.8	0.0	3,507.8	104,000.0	364.8	0.4	0.2	0.7
09/27/2020 14:00	3,494.1	0.0	3,494.1	104,000.0	363.4	0.4	0.2	0.7
09/27/2020 15:00	3,577.2	0.0	3,577.2	104,000.0	372.0	0.4	0.2	0.7
09/27/2020 16:00	3,800.4	227.4	3,959.6	104,000.0	411.8	0.5	0.3	0.8
09/27/2020 17:00	3,682.0	0.0	3,682.0	104,000.0	382.9	0.5	0.2	0.8
09/27/2020 18:00	3,674.8	0.0	3,674.8	104,000.0	382.2	0.5	0.2	0.8
09/27/2020 19:00	3,544.3	0.0	3,544.3	104,000.0	368.6	0.4	0.2	0.7
09/27/2020 20:00	3,564.4	0.0	3,564.4	104,000.0	370.7	0.4	0.2	0.7
09/27/2020 21:00	3,694.2	0.0	3,694.2	104,000.0	384.2	0.5	0.2	0.8
09/27/2020 22:00	3,336.4	0.0	3,336.4	104,000.0	347.0	0.4	0.2	0.7
09/27/2020 23:00	3,345.8	0.0	3,345.8	104,000.0	348.0	0.4	0.2	0.7
Average/Sum#:	3,328.3	15.7	3,337.1	104,000.0	347.1	0.4	0.2	0.7
Minimum:	2,872.4	0.0	2,872.4	104,000.0	298.7	0.4	0.2	0.6
Maximum:	3,808.7	227.4	3,959.6	104,000.0	411.8	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2020 00:00	2,917.6	0.0	2,917.6	104,000.0	303.4	0.4	0.2	0.6
09/28/2020 01:00	2,903.6	0.0	2,903.6	104,000.0	302.0	0.4	0.2	0.6
09/28/2020 02:00	2,903.4	0.0	2,903.4	104,000.0	302.0	0.4	0.2	0.6
09/28/2020 03:00	2,934.0	0.0	2,934.0	104,000.0	305.1	0.4	0.2	0.6
09/28/2020 04:00	2,970.7	0.0	2,970.7	104,000.0	309.0	0.4	0.2	0.6
09/28/2020 05:00	2,921.5	0.0	2,921.5	104,000.0	303.8	0.4	0.2	0.6
09/28/2020 06:00	2,900.6	0.0	2,900.6	104,000.0	301.7	0.4	0.2	0.6
09/28/2020 07:00	3,187.4	0.0	3,187.4	104,000.0	331.5	0.4	0.2	0.7
09/28/2020 08:00	3,654.8	0.0	3,654.8	104,000.0	380.1	0.5	0.2	0.8
09/28/2020 09:00	3,628.9	0.0	3,628.9	104,000.0	377.4	0.5	0.2	0.8
09/28/2020 10:00	3,387.8	0.0	3,387.8	104,000.0	352.3	0.4	0.2	0.7
09/28/2020 11:00	3,422.4	0.0	3,422.4	104,000.0	355.9	0.4	0.2	0.7
09/28/2020 12:00	3,730.9	35.6	3,735.5	104,000.0	388.5	0.5	0.2	0.8
09/28/2020 13:00	3,791.2	1,816.6	5,607.8	104,000.0	583.2	0.7	0.3	1.2
09/28/2020 14:00	3,788.2	1,797.9	5,586.1	104,000.0	581.0	0.7	0.3	1.2
09/28/2020 15:00	3,784.5	1,745.7	5,530.2	104,000.0	575.1	0.7	0.3	1.2
09/28/2020 16:00	3,782.4	835.7	4,618.1	104,000.0	480.3	0.6	0.3	1.0
09/28/2020 17:00	3,789.4	497.0	4,286.4	104,000.0	445.8	0.5	0.3	0.9
09/28/2020 18:00	3,800.6	211.0	4,011.6	104,000.0	417.2	0.5	0.3	0.8
09/28/2020 19:00	3,679.1	18.5	3,681.0	104,000.0	382.8	0.5	0.2	0.8
09/28/2020 20:00	3,447.8	0.0	3,447.8	104,000.0	358.6	0.4	0.2	0.7
09/28/2020 21:00	3,069.8	0.0	3,069.8	104,000.0	319.3	0.4	0.2	0.6
09/28/2020 22:00	2,732.7	0.0	2,732.7	104,000.0	284.2	0.3	0.2	0.6
09/28/2020 23:00	3,361.7	0.0	3,361.7	104,000.0	349.6	0.4	0.2	0.7
Average/Sum#:	3,353.8	289.9	3,641.7	104,000.0	378.7	0.5	0.2	0.8
Minimum:	2,732.7	0.0	2,732.7	104,000.0	284.2	0.3	0.2	0.6
Maximum:	3,800.6	1,816.6	5,607.8	104,000.0	583.2	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2020 00:00	3,103.7	0.0	3,103.7	104,000.0	322.8	0.4	0.2	0.6
09/29/2020 01:00	3,128.1	0.0	3,128.1	104,000.0	325.3	0.4	0.2	0.7
09/29/2020 02:00	2,891.1	0.0	2,891.1	104,000.0	300.7	0.4	0.2	0.6
09/29/2020 03:00	2,840.0	0.0	2,840.0	104,000.0	295.4	0.4	0.2	0.6
09/29/2020 04:00	3,011.2	0.0	3,011.2	104,000.0	313.2	0.4	0.2	0.6
09/29/2020 05:00	2,790.5	0.0	2,790.5	104,000.0	290.2	0.3	0.2	0.6
09/29/2020 06:00	2,751.9	0.0	2,751.9	104,000.0	286.2	0.3	0.2	0.6
09/29/2020 07:00	2,960.0	0.0	2,960.0	104,000.0	307.8	0.4	0.2	0.6
09/29/2020 08:00	3,362.7	0.0	3,362.7	104,000.0	349.7	0.4	0.2	0.7
09/29/2020 09:00	3,652.0	0.0	3,652.0	104,000.0	379.8	0.5	0.2	0.8
09/29/2020 10:00	3,866.8	0.0	3,866.8	104,000.0	402.1	0.5	0.2	0.8
09/29/2020 11:00	3,863.5	276.0	4,131.2	104,000.0	429.6	0.5	0.3	0.9
09/29/2020 12:00	3,840.2	1,379.5	5,219.7	104,000.0	542.8	0.7	0.3	1.1
09/29/2020 13:00	3,820.6	1,529.7	5,350.3	104,000.0	556.4	0.7	0.3	1.1
09/29/2020 14:00	3,811.6	1,657.8	5,469.4	104,000.0	568.8	0.7	0.3	1.1
09/29/2020 15:00	3,807.7	1,488.6	5,296.3	104,000.0	550.8	0.7	0.3	1.1
09/29/2020 16:00	3,821.1	1,259.9	5,081.0	104,000.0	528.4	0.6	0.3	1.1
09/29/2020 17:00	3,824.6	1,339.9	5,164.5	104,000.0	537.1	0.6	0.3	1.1
09/29/2020 18:00	3,831.3	409.8	4,228.8	104,000.0	439.8	0.5	0.3	0.9
09/29/2020 19:00	3,587.2	0.0	3,587.2	104,000.0	373.1	0.4	0.2	0.7
09/29/2020 20:00	3,887.3	77.7	3,957.2	104,000.0	411.5	0.5	0.2	0.8
09/29/2020 21:00	3,903.2	774.6	4,662.3	104,000.0	484.9	0.6	0.3	1.0
09/29/2020 22:00	3,854.5	0.0	3,854.5	104,000.0	400.9	0.5	0.2	0.8
09/29/2020 23:00	2,774.6	0.0	2,774.6	104,000.0	288.6	0.3	0.2	0.6
Average/Sum#:	3,457.7	424.7	3,880.6	104,000.0	403.6	0.5	0.2	0.8
Minimum:	2,751.9	0.0	2,751.9	104,000.0	286.2	0.3	0.2	0.6
Maximum:	3,903.2	1,657.8	5,469.4	104,000.0	568.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:13 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2020 00:00	2,721.9	0.0	2,721.9	104,000.0	283.1	0.3	0.2	0.6
09/30/2020 01:00	2,727.8	0.0	2,727.8	104,000.0	283.7	0.3	0.2	0.6
09/30/2020 02:00	2,901.4	0.0	2,901.4	104,000.0	301.7	0.4	0.2	0.6
09/30/2020 03:00	2,938.6	0.0	2,938.6	104,000.0	305.6	0.4	0.2	0.6
09/30/2020 04:00	2,947.1	0.0	2,947.1	104,000.0	306.5	0.4	0.2	0.6
09/30/2020 05:00	2,724.8	0.0	2,724.8	104,000.0	283.4	0.3	0.2	0.6
09/30/2020 06:00	2,726.9	0.0	2,726.9	104,000.0	283.6	0.3	0.2	0.6
09/30/2020 07:00	2,726.2	0.0	2,726.2	104,000.0	283.5	0.3	0.2	0.6
09/30/2020 08:00	3,092.8	0.0	3,092.8	104,000.0	321.7	0.4	0.2	0.6
09/30/2020 09:00	3,365.1	0.0	3,365.1	104,000.0	350.0	0.4	0.2	0.7
09/30/2020 10:00	3,845.0	101.2	3,918.9	104,000.0	407.6	0.5	0.2	0.8
09/30/2020 11:00	3,850.4	284.0	4,134.4	104,000.0	430.0	0.5	0.3	0.9
09/30/2020 12:00	3,831.4	1,051.6	4,883.0	104,000.0	507.8	0.6	0.3	1.0
09/30/2020 13:00	3,796.8	1,830.5	5,627.3	104,000.0	585.2	0.7	0.4	1.2
09/30/2020 14:00	3,777.2	1,887.7	5,664.9	104,000.0	589.1	0.7	0.4	1.2
09/30/2020 15:00	3,769.0	1,631.1	5,400.1	104,000.0	561.6	0.7	0.3	1.1
09/30/2020 16:00	3,772.1	1,740.5	5,512.6	104,000.0	573.3	0.7	0.3	1.1
09/30/2020 17:00	3,790.5	1,264.6	5,055.1	104,000.0	525.7	0.6	0.3	1.1
09/30/2020 18:00	3,802.4	948.4	4,750.8	104,000.0	494.1	0.6	0.3	1.0
09/30/2020 19:00	3,822.5	372.6	4,195.1	104,000.0	436.3	0.5	0.3	0.9
09/30/2020 20:00	3,845.4	225.7	4,071.1	104,000.0	423.4	0.5	0.3	0.8
09/30/2020 21:00	3,876.4	752.8	4,629.2	104,000.0	481.4	0.6	0.3	1.0
09/30/2020 22:00	3,802.5	7.0	3,807.8	104,000.0	396.0	0.5	0.2	0.8
09/30/2020 23:00	3,549.1	0.0	3,549.1	104,000.0	369.1	0.4	0.2	0.7
Average/Sum#:	3,416.8	504.1	3,919.7	104,000.0	407.6	0.5	0.3	0.8
Minimum:	2,721.9	0.0	2,721.9	104,000.0	283.1	0.3	0.2	0.6
Maximum:	3,876.4	1,887.7	5,664.9	104,000.0	589.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 04:25	200.0	179.0	182.6		|R-A|/Span * 100	1.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 04:19	10.0	9.2	9.6	>1x Alert	|R-A|/Span * 100	4.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/13/20 05:25	200.0	181.6	183.2		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/13/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 05:25	200.0	179.0	178.0		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 05:19	10.0	9.2	9.0		|R-A|/Span * 100	2.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/13/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/13/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 10:09	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/13/20 10:20	200.0	181.5	181.9		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 10:09	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/13/20 10:14	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 10:09	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 10:20	200.0	179.0	175.8		|R-A|/Span * 100	1.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/13/20 10:09	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/13/20 10:14	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/13/20 10:09	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/13/20 10:14	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 04:25	200.0	179.0	179.4		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 04:24	200.0	179.0	177.2		|R-A|/Span * 100	0.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/14/20 05:25	200.0	181.5	181.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/14/20 05:20	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 05:25	200.0	179.0	177.2		|R-A|/Span * 100	0.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/14/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/14/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/14/20 05:25	200.0	181.6	183.2		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/14/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 05:25	200.0	179.0	177.3		|R-A|/Span * 100	0.9

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/14/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/14/20 05:20	10.0	9.2	9.0		|R-A|/Span * 100	2.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/14/20 05:15	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/14/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 04:24	200.0	179.0	176.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 04:24	200.0	179.0	178.8		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/15/20 05:24	200.0	181.5	181.7		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/15/20 05:19	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 05:24	200.0	179.0	176.9		|R-A|/Span * 100	1.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/15/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/15/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 05:25	200.0	181.6	183.1		|R-A|/Span * 100	0.8

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/15/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 05:25	200.0	179.0	176.6		|R-A|/Span * 100	1.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 05:20	10.0	9.2	8.9	>1x Alert	|R-A|/Span * 100	3.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/15/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/15/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:24	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 08:34	200.0	181.6	183.3		|R-A|/Span * 100	0.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:24	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 08:29	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:24	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 08:34	200.0	179.0	179.2		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:24	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/15/20 08:29	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/15/20 08:24	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/15/20 08:29	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:42	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/15/20 08:52	200.0	181.6	183.1		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:42	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/15/20 08:47	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:42	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/15/20 08:52	200.0	179.0	179.7		|R-A|/Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/15/20 08:42	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/15/20 08:47	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/15/20 08:42	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/15/20 08:47	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 04:25	200.0	179.0	178.5		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 04:25	200.0	179.0	176.5		|R-A|/Span * 100	1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/16/20 05:24	200.0	181.5	181.7		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/16/20 05:20	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 05:24	200.0	179.0	176.9		|R-A|/Span * 100	1.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/16/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/16/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 05:25	200.0	181.6	183.6		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/16/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 05:25	200.0	179.0	179.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/16/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/16/20 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/16/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/16/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 04:25	200.0	179.0	178.4		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 04:25	200.0	179.0	176.0		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/17/20 05:24	200.0	181.5	181.5		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/17/20 05:19	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:24	200.0	179.0	176.7		|R-A|/Span * 100	1.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/17/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/17/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:25	200.0	181.6	182.6		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:25	200.0	179.0	179.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/17/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/17/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/17/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 04:24	200.0	179.0	176.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 04:25	200.0	179.0	177.9		|R-A|/Span * 100	0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:24	200.0	181.6	183.1		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:24	200.0	179.0	178.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/18/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/18/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/18/20 05:25	200.0	181.5	181.5		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/18/20 05:19	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:25	200.0	179.0	176.6		|R-A|/Span * 100	1.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/18/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/18/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/18/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/18/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 04:25	200.0	179.0	178.1		|R-A|/Span * 100	0.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 04:24	200.0	179.0	176.2		|R-A|/Span * 100	1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/19/20 05:25	200.0	181.5	181.5		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/19/20 05:19	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:25	200.0	179.0	176.4		|R-A|/Span * 100	1.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/19/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/19/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:25	200.0	181.6	182.6		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:25	200.0	179.0	178.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/19/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/19/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/19/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 04:25	200.0	179.0	177.7		|R-A|/Span * 100	0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 04:25	200.0	179.0	175.9		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/20/20 05:24	200.0	181.6	183.2		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/20/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 05:24	200.0	179.0	178.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/20/20 05:14	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/20/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/20/20 05:25	200.0	181.5	181.7		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/20/20 05:20	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 05:25	200.0	179.0	176.7		|R-A|/Span * 100	1.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/20/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/20/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/20/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/20/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/21/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/21/20 04:25	200.0	179.0	177.8		|R-A|/Span * 100	0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/21/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/21/20 04:20	10.0	9.3	9.1		|R-A|/Span * 100	2.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/21/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/21/20 04:24	200.0	179.0	176.2		|R-A|/Span * 100	1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/21/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/21/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**		**Pass**
	Zero	07/26/20 01:24	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/26/20 01:34	200.0	181.5	181.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**		**Pass**
	Zero	07/26/20 01:24	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/26/20 01:29	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**		**Offline**
	Zero	07/26/20 01:24	200.0	0.0	0.0	Off	|R-A|/Span * 100	0.0
	High	07/26/20 01:34	200.0	179.0	174.4	Off	|R-A|/Span * 100	2.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**		**Offline**
	Zero	07/26/20 01:24	10.0	0.0	0.0	Off	|R-A|/Span * 100	0.0
	High	07/26/20 01:29	10.0	9.0	8.9	Off	|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**		**Offline**
	High	07/26/20 01:24	21.0	18.1	18.0	Off	|R-A|	0.1
	Zero	07/26/20 01:29	21.0	0.0	0.0	Off	|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 01:27	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 01:38	200.0	181.6	183.2		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 01:27	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/26/20 01:32	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 01:27	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 01:38	200.0	179.0	179.7		|R-A|/Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 01:27	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 01:32	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/26/20 01:27	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/26/20 01:32	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 03:23	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/26/20 03:33	200.0	181.5	181.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 03:23	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/26/20 03:28	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 03:23	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 03:33	200.0	179.0	174.9		|R-A|/Span * 100	2.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 03:23	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 03:28	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/26/20 03:23	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/26/20 03:28	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 04:25	200.0	179.0	179.6		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 04:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 04:25	200.0	179.0	178.3		|R-A|/Span * 100	0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/26/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/26/20 04:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/27/20 01:42	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 01:52	200.0	181.6	183.6		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/20 01:42	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/27/20 01:47	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/20 01:42	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 01:52	200.0	179.0	179.8		|R-A|/Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/20 01:42	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 01:47	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/27/20 01:42	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/27/20 01:47	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/20 03:37	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/27/20 03:48	200.0	181.5	181.9		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/20 03:37	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/27/20 03:42	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/20 03:37	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 03:48	200.0	179.0	176.1		|R-A|/Span * 100	1.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/20 03:37	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 03:42	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	07/27/20 03:37	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/27/20 03:42	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 04:24	200.0	179.0	176.4		|R-A|/Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/27/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/27/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 04:25	200.0	179.0	178.5		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/27/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/27/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 01:56	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/28/20 02:06	200.0	181.6	183.3		|R-A|/Span * 100	0.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 01:56	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/28/20 02:01	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 01:56	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 02:06	200.0	179.0	179.3		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 01:56	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 02:01	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/28/20 01:56	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/28/20 02:01	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 03:52	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/28/20 04:01	200.0	181.5	181.7		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 03:52	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/28/20 03:57	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 03:52	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 04:01	200.0	179.0	176.2		|R-A|/Span * 100	1.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 03:52	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 03:57	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/28/20 03:52	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/28/20 03:57	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 04:24	200.0	179.0	178.3		|R-A|/Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 04:25	200.0	179.0	176.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/28/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/28/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 02:09	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 02:20	200.0	181.6	183.8		|R-A|/Span * 100	1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 02:09	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/29/20 02:15	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 02:09	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 02:20	200.0	179.0	179.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 02:09	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 02:15	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/29/20 02:09	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/29/20 02:15	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:05	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/29/20 04:15	200.0	181.5	181.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:05	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/29/20 04:10	10.0	9.2	9.4		|R-A|/Span * 100	2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:05	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:15	200.0	179.0	176.2		|R-A|/Span * 100	1.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:05	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:10	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/29/20 04:05	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/29/20 04:10	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:24	200.0	179.0	178.4		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:25	200.0	179.0	176.3		|R-A|/Span * 100	1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/29/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/29/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 02:24	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 02:33	200.0	181.6	182.9		|R-A|/Span * 100	0.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 02:24	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 02:29	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 02:24	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 02:33	200.0	179.0	179.2		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 02:24	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 02:29	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/30/20 02:24	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/30/20 02:29	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Warning**
	Zero	07/30/20 04:14	200.0	0.0	13.2	>2x	|R-A|/Span * 100	6.6
	High	07/30/20 04:25	200.0	180.5	176.4		|R-A|/Span * 100	2.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Fail**
	Zero	07/30/20 04:14	10.0	0.0	13.3	>4x	|R-A|/Span * 100	133.0
	High	07/30/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 04:25	200.0	179.0	176.0		|R-A|/Span * 100	1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 04:19	200.0	0.0	0.7		|R-A|/Span * 100	0.4
	High	07/30/20 04:29	200.0	180.4	181.1		|R-A|/Span * 100	0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/20 04:19	10.0	0.0	0.7	>1x Alert	|R-A|/Span * 100	7.0
	High	07/30/20 04:25	10.0	9.2	9.5		|R-A|/Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 04:19	200.0	0.0	1.7		|R-A|/Span * 100	0.9
	High	07/30/20 04:29	200.0	180.5	176.9		|R-A|/Span * 100	1.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/20 04:19	10.0	0.0	1.8		|R-A|	1.8
	High	07/30/20 04:25	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Fail
	High	07/30/20 04:19	21.0	18.1	14.5	>2x	|R-A|	3.6
	Zero	07/30/20 04:25	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 05:36	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/30/20 05:47	200.0	180.5	180.9		|R-A|/Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/20 05:36	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/30/20 05:41	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 05:52	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/30/20 06:02	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	07/30/20 05:52	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/30/20 05:57	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	07/30/20 05:52	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 06:02	200.0	180.5	180.6		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 05:52	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 05:57	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/30/20 05:52	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/30/20 05:57	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:07	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/30/20 06:17	200.0	180.5	181.4		|R-A|/Span * 100	0.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:07	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/30/20 06:12	10.0	9.0	9.3	>1x Alert	|R-A|/Span * 100	3.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:23	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	07/30/20 06:33	200.0	180.4	180.7		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:23	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/30/20 06:27	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:23	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 06:33	200.0	180.5	180.7		|R-A|/Span * 100	0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/30/20 06:23	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/30/20 06:27	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/30/20 06:23	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/30/20 06:27	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 02:38	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 02:48	200.0	181.6	182.6		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 02:38	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	07/31/20 02:42	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 02:38	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 02:48	200.0	179.0	178.9		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 02:38	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 02:42	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/31/20 02:38	21.0	18.0	17.9		|R-A|	0.1
	Zero	07/31/20 02:42	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 04:25	200.0	180.5	180.1		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 04:25	200.0	179.0	176.3		|R-A|/Span * 100	1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	07/31/20 05:25	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	07/31/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 05:25	200.0	180.5	180.2		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	07/31/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	07/31/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	07/31/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	07/31/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 02:51	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 03:01	200.0	181.6	182.8		|R-A|/Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 02:51	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/01/20 02:56	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 02:51	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 03:01	200.0	179.0	178.7		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 02:51	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 02:56	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/01/20 02:51	21.0	18.0	17.9		|R-A|	0.1
	Zero	08/01/20 02:56	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 04:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 04:25	200.0	179.0	175.8		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 04:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/01/20 05:24	200.0	180.4	180.7		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/01/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 05:24	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/01/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/01/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/01/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/01/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 03:06	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/02/20 03:16	200.0	181.6	183.1		|R-A|/Span * 100	0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 03:06	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/02/20 03:11	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 03:06	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 03:16	200.0	179.0	179.0		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 03:06	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 03:11	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/02/20 03:06	21.0	18.0	17.9		|R-A|	0.1
	Zero	08/02/20 03:11	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 04:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 04:24	200.0	179.0	176.4		|R-A|/Span * 100	1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 04:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/02/20 05:25	200.0	180.4	180.7		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/02/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 05:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/02/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/02/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/02/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/02/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 03:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 03:30	200.0	181.6	183.3		|R-A|/Span * 100	0.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 03:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 03:24	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 03:19	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 03:30	200.0	179.0	178.7		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 03:19	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 03:24	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/03/20 03:19	21.0	18.0	17.9		|R-A|	0.1
	Zero	08/03/20 03:24	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 04:24	200.0	180.5	179.9		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 04:25	200.0	179.0	176.0		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 04:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/03/20 05:25	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/03/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 05:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/03/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/03/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/03/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/03/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 03:34	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 03:43	200.0	179.5	181.9		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 03:34	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 03:38	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 03:34	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 03:43	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 03:34	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 03:38	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/04/20 03:34	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/04/20 03:38	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 04:24	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 04:25	200.0	180.0	176.5		|R-A|/Span * 100	1.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 04:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/04/20 05:25	200.0	180.4	181.0		|R-A|/Span * 100	0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/04/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 05:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/04/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/04/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/04/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/04/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 03:47	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 03:58	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 03:47	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 03:52	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 03:47	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 03:58	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 03:47	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 03:52	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/05/20 03:47	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/05/20 03:52	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 04:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 04:25	200.0	180.0	176.9		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 04:19	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/05/20 05:24	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/05/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 05:24	200.0	180.5	180.2		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/05/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/05/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/05/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/05/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/08/20 11:01	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/08/20 11:12	200.0	179.5	181.8		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/08/20 11:01	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/08/20 11:07	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/08/20 11:01	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/20 11:12	200.0	180.0	179.5		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/08/20 11:01	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/08/20 11:07	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/08/20 11:01	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/08/20 11:07	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 00:20	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/09/20 00:30	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 00:20	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/09/20 00:25	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 00:20	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 00:30	200.0	180.5	179.0		|R-A|/Span * 100	0.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 00:20	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 00:25	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/09/20 00:20	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/09/20 00:25	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 04:25	200.0	180.5	181.3		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 04:25	200.0	180.0	176.9		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 04:19	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 05:24	200.0	179.5	181.8		|R-A|/Span * 100	1.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 05:24	200.0	180.0	179.6		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/09/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/09/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/09/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/09/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 00:35	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/10/20 00:45	200.0	180.4	181.4		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 00:35	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/10/20 00:40	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 00:35	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 00:45	200.0	180.5	180.2		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 00:35	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 00:40	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/10/20 00:35	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/10/20 00:40	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 04:24	200.0	180.5	181.3		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 04:25	200.0	180.0	176.7		|R-A|/Span * 100	1.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 04:19	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 05:25	200.0	179.5	181.9		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/10/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 05:25	200.0	180.0	179.6		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/10/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/10/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/10/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/10/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 00:49	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/11/20 00:59	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 00:49	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/11/20 00:54	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 00:49	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 00:59	200.0	180.5	180.1		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 00:49	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 00:54	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/11/20 00:49	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/11/20 00:54	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 04:25	200.0	180.5	180.9		|R-A|/Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 04:25	200.0	180.0	176.3		|R-A|/Span * 100	1.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 04:19	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 05:24	200.0	179.5	181.9		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 05:24	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/11/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/11/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/11/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/11/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 01:03	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/12/20 01:13	200.0	180.4	181.1		|R-A|/Span * 100	0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 01:03	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/12/20 01:07	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 01:03	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 01:13	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 01:03	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 01:07	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/12/20 01:03	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/12/20 01:07	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 04:25	200.0	180.5	180.6		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 04:25	200.0	180.0	176.3		|R-A|/Span * 100	1.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 04:19	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 05:25	200.0	179.5	181.7		|R-A|/Span * 100	1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/12/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 05:25	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/12/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/12/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/12/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/12/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/13/20 01:17	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/13/20 01:27	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/13/20 01:17	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/13/20 01:22	10.0	9.2	9.3		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/20 01:17	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 01:27	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/20 01:17	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 01:22	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/13/20 01:17	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/13/20 01:22	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 04:24	200.0	180.5	180.7		|R-A|/Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 04:25	200.0	180.0	176.8		|R-A|/Span * 100	1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 05:25	200.0	179.5	181.8		|R-A|/Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/13/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 05:25	200.0	180.0	179.5		|R-A|/Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/13/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/13/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/13/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/13/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 01:31	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/14/20 01:41	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 01:31	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/14/20 01:35	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 01:31	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 01:41	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 01:31	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 01:35	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/14/20 01:31	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/14/20 01:35	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 04:24	200.0	180.0	177.0		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 04:25	200.0	180.5	180.3		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 05:25	200.0	179.5	182.4		|R-A|/Span * 100	1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/14/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 05:25	200.0	180.0	179.4		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/14/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/14/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/20 12:50	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/14/20 13:01	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/20 12:50	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/14/20 12:56	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/14/20 12:50	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 13:01	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/14/20 12:50	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/14/20 12:56	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/14/20 12:50	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/14/20 12:56	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 04:25	200.0	180.5	180.1		|R-A|/Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 04:25	200.0	180.0	177.1		|R-A|/Span * 100	1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/15/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/15/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/15/20 05:25	200.0	180.4	181.3		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/15/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 05:25	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/15/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/15/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/15/20 05:24	200.0	179.5	181.9		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/15/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 05:24	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/15/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/15/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/15/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 04:25	200.0	180.5	180.1		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 04:25	200.0	180.0	176.6		|R-A|/Span * 100	1.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/16/20 05:24	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/16/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 05:24	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/16/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/16/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 05:25	200.0	179.5	181.7		|R-A|/Span * 100	1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/16/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 05:25	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/16/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/16/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/16/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/16/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 04:25	200.0	180.5	179.5		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 04:24	200.0	180.0	176.7		|R-A|/Span * 100	1.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/17/20 05:25	200.0	180.4	181.1		|R-A|/Span * 100	0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/17/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 05:25	200.0	180.5	180.2		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/17/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/17/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/17/20 05:24	200.0	179.5	182.1		|R-A|/Span * 100	1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/17/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 05:24	200.0	180.0	179.2		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/17/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/17/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/17/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 04:24	200.0	180.0	176.7		|R-A|/Span * 100	1.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 04:25	200.0	180.5	178.6		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/18/20 05:25	200.0	180.4	181.0		|R-A|/Span * 100	0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/18/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 05:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/18/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/18/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 05:24	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/18/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 05:24	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/18/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/18/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/18/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/18/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 04:25	200.0	180.5	179.3		|R-A|/Span * 100	0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 04:25	200.0	180.0	177.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/19/20 05:24	200.0	179.5	182.1		|R-A|/Span * 100	1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/19/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 05:24	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/19/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/19/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/19/20 05:24	200.0	180.4	181.1		|R-A|/Span * 100	0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/19/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 05:24	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/19/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/19/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/19/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 04:25	200.0	180.5	180.8		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 04:25	200.0	180.0	177.6		|R-A|/Span * 100	1.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/20/20 05:25	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/20/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 05:25	200.0	180.5	179.5		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/20/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/20/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/20/20 05:24	200.0	179.5	182.6		|R-A|/Span * 100	1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/20/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 05:24	200.0	180.0	179.5		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/20/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/20/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/20/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/20/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 04:24	200.0	180.0	177.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 04:25	200.0	180.5	180.3		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/21/20 05:24	200.0	180.4	181.4		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/21/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 05:24	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/21/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/21/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/21/20 05:24	200.0	179.5	182.8		|R-A|/Span * 100	1.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/21/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 05:24	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/21/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/21/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/21/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/21/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 04:24	200.0	180.5	180.2		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 04:25	200.0	180.0	177.0		|R-A|/Span * 100	1.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/22/20 05:25	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/22/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 05:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/22/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/22/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 05:25	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/22/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 05:25	200.0	180.0	179.2		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/22/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/22/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/22/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/22/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 04:25	200.0	180.5	180.4		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 04:25	200.0	180.0	176.9		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/23/20 05:25	200.0	180.4	181.4		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/23/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/23/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/23/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:25	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:25	200.0	180.0	179.5		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/23/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/23/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/23/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 04:25	200.0	180.5	179.7		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 04:25	200.0	180.0	176.9		|R-A|/Span * 100	1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/24/20 05:25	200.0	180.4	181.4		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/24/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 05:25	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/24/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/24/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 05:25	200.0	179.5	181.8		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/24/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 05:25	200.0	180.0	179.0		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/24/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/24/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/24/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/24/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 04:24	200.0	180.5	180.1		|R-A|/Span * 100	0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 04:25	200.0	180.0	177.1		|R-A|/Span * 100	1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/25/20 05:25	200.0	180.4	181.5		|R-A|/Span * 100	0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:15	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/25/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 05:25	200.0	180.5	179.9		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/25/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/25/20 05:19	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 05:25	200.0	179.5	182.4		|R-A|/Span * 100	1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/25/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 05:25	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/25/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/25/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/25/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/25/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 04:25	200.0	180.5	180.7		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 04:25	200.0	180.0	177.3		|R-A|/Span * 100	1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/26/20 05:24	200.0	180.4	181.5		|R-A|/Span * 100	0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:15	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	08/26/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:24	200.0	180.5	179.7		|R-A|/Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/26/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/26/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:25	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:19	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:25	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/26/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/26/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/26/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/26/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/27/20 04:25	200.0	180.5	180.5		|R-A|/Span * 100	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 04:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	08/27/20 04:25	200.0	180.0	184.3		|R-A|/Span * 100	2.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 04:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	08/27/20 04:19	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/27/20 05:25	200.0	180.4	181.1		|R-A|/Span * 100	0.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/27/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:25	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/27/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/27/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:25	200.0	179.5	182.5		|R-A|/Span * 100	1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:25	200.0	180.0	178.9		|R-A|/Span * 100	0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/27/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/27/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/27/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/27/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 04:25	200.0	180.5	180.3		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 04:25	200.0	180.0	184.7		|R-A|/Span * 100	2.4

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 04:19	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/28/20 05:25	200.0	180.4	181.4		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/28/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:25	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/28/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/28/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:25	200.0	179.5	181.4		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:25	200.0	180.0	179.0		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/28/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/28/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/28/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/28/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 04:25	200.0	180.5	180.4		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 04:25	200.0	180.0	184.6		|R-A|/Span * 100	2.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 04:19	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/29/20 05:25	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/29/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:25	200.0	180.5	179.5		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/29/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/29/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:25	200.0	179.5	182.2		|R-A|/Span * 100	1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:25	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/29/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/29/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/29/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/29/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 04:24	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 04:25	200.0	180.0	185.4	>1x Alert	|R-A|/Span * 100	2.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 04:20	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/30/20 05:24	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/30/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:24	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/30/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/30/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:25	200.0	179.5	181.8		|R-A|/Span * 100	1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:25	200.0	180.0	178.9		|R-A|/Span * 100	0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/30/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/30/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/30/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/30/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 04:25	200.0	180.5	181.0		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	08/31/20 05:24	200.0	180.4	181.3		|R-A|/Span * 100	0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 05:14	10.0	0.0	0.2		|R-A|/Span * 100	2.0
	High	08/31/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 05:24	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	08/31/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	08/31/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 17:03	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 17:13	200.0	179.5	183.1		|R-A|/Span * 100	1.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	08/31/20 17:03	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 17:08	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	08/31/20 17:03	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 17:13	200.0	180.0	179.2		|R-A|/Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	08/31/20 17:03	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	08/31/20 17:08	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	08/31/20 17:03	21.0	18.3	18.2		|R-A|	0.1
	Zero	08/31/20 17:08	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/01/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 04:24	200.0	180.5	179.9		|R-A|/Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/01/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/01/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 04:25	200.0	180.0	185.1	>1x Alert	|R-A|/Span * 100	2.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/01/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 04:20	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/01/20 05:15	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/01/20 05:25	200.0	180.4	181.0		|R-A|/Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/01/20 05:15	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	09/01/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/01/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:25	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/01/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/01/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/01/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/01/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:25	200.0	179.5	182.1		|R-A|/Span * 100	1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/01/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/01/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:25	200.0	180.0	179.2		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/01/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/01/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/01/20 05:14	21.0	18.3	18.2		|R-A|	0.1
	Zero	09/01/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/02/20 04:24	200.0	180.5	179.2		|R-A|/Span * 100	0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 04:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/02/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 04:24	200.0	180.0	185.1	>1x Alert	|R-A|/Span * 100	2.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 04:19	10.0	9.0	9.5	>1x Alert	|R-A|/Span * 100	5.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:14	200.0	0.0	0.3		|R-A|/Span * 100	0.2
	High	09/02/20 05:25	200.0	180.4	180.7		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:14	10.0	0.0	0.3		|R-A|/Span * 100	3.0
	High	09/02/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:25	200.0	180.5	179.9		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/02/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/02/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:25	200.0	179.5	181.7		|R-A|/Span * 100	1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:25	200.0	180.0	178.8		|R-A|/Span * 100	0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/02/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/02/20 05:20	10.0	9.0	9.2		|R-A|/Span * 100	2.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/02/20 05:15	21.0	18.3	18.2		|R-A|	0.1
	Zero	09/02/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 04:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/03/20 04:25	200.0	180.5	179.6		|R-A|/Span * 100	0.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 04:25	200.0	180.0	178.6		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 04:20	10.0	9.0	8.9		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:25	200.0	180.4	180.7		|R-A|/Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/03/20 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:25	200.0	180.5	179.4		|R-A|/Span * 100	0.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/03/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/03/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:25	200.0	179.5	179.2		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/03/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/03/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/03/20 05:15	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/03/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/04/20 04:24	200.0	180.5	179.9		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 04:25	200.0	180.0	178.6		|R-A|/Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:24	200.0	180.4	181.0		|R-A|/Span * 100	0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/04/20 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:24	200.0	180.5	179.4		|R-A|/Span * 100	0.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/04/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/04/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:25	200.0	179.5	179.2		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:25	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/04/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/04/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/04/20 05:15	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/04/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 04:25	200.0	180.5	179.9		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 04:25	200.0	180.0	178.7		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:24	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/05/20 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:24	200.0	180.5	179.5		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/05/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/05/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:25	200.0	179.5	179.2		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:25	200.0	180.0	180.0		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/05/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/05/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/05/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/05/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 04:25	200.0	180.5	179.2		|R-A|/Span * 100	0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 04:24	200.0	180.0	178.4		|R-A|/Span * 100	0.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:24	200.0	180.4	180.8		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/06/20 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:24	200.0	180.5	179.5		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/06/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/06/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:24	200.0	179.5	179.4		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:24	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/06/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/06/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/06/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/06/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 04:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 04:25	200.0	180.0	178.9		|R-A|/Span * 100	0.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 04:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:25	200.0	180.4	181.1		|R-A|/Span * 100	0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/07/20 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:25	200.0	180.5	179.4		|R-A|/Span * 100	0.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/07/20 05:15	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/07/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:25	200.0	179.5	180.1		|R-A|/Span * 100	0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:25	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/07/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/07/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/07/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/07/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 04:25	200.0	180.5	180.6		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 04:25	200.0	180.0	178.6		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 04:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:25	200.0	180.4	182.1		|R-A|/Span * 100	0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/08/20 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:25	200.0	180.5	179.6		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/08/20 05:14	21.0	18.1	18.0		|R-A|	0.1
	Zero	09/08/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:25	200.0	179.5	179.9		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:25	200.0	180.0	180.2		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/08/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/08/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/08/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/08/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 04:24	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 04:25	200.0	180.0	180.3		|R-A|/Span * 100	0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:25	200.0	181.3	181.8		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:15	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	09/09/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:25	200.0	180.0	178.3		|R-A|/Span * 100	0.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/09/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/09/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:25	200.0	179.5	180.6		|R-A|/Span * 100	0.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:25	200.0	180.0	180.7		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/09/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/09/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/09/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/09/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 04:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 04:25	200.0	180.0	180.2		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:25	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:25	200.0	180.0	179.0		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/10/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/10/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:25	200.0	179.5	179.7		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:25	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/10/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/10/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/10/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/10/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 04:24	200.0	180.5	179.3		|R-A|/Span * 100	0.6

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 04:25	200.0	180.0	179.6		|R-A|/Span * 100	0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 04:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:24	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:24	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/11/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/11/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:24	200.0	179.5	179.0		|R-A|/Span * 100	0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	10.0	0.0	-0.1		|R-A|/Span * 100	1.0
	High	09/11/20 05:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:24	200.0	180.0	180.0		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/11/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/11/20 05:19	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/11/20 05:14	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/11/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/12/20 04:24	200.0	180.5	180.3		|R-A|/Span * 100	0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 04:25	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:25	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:25	200.0	180.0	179.1		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/12/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/12/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:25	200.0	179.5	179.9		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/12/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/12/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:25	200.0	180.0	180.2		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/12/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/12/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/12/20 05:15	21.0	18.3	18.3		|R-A|	0.0
	Zero	09/12/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/13/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 04:24	200.0	180.0	178.7		|R-A|/Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/13/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/13/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 04:24	200.0	180.5	180.0		|R-A|/Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/13/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/13/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:25	200.0	181.3	181.4		|R-A|/Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/13/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/13/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:25	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/13/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/13/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/13/20 05:20	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/13/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:25	200.0	181.3	181.5		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/13/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/13/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:25	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/13/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/13/20 05:20	10.0	9.0	9.0		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/13/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/13/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 04:25	200.0	180.5	181.6		|R-A|/Span * 100	0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 04:25	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 04:19	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:24	200.0	181.3	181.4		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/14/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:24	200.0	180.0	179.4		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/14/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/14/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/14/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/14/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:25	200.0	181.3	180.7		|R-A|/Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/14/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/14/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:25	200.0	180.0	180.3		|R-A|/Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/14/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/14/20 05:20	10.0	9.0	9.1		|R-A|/Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/14/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/14/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/15/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 04:25	200.0	180.5	181.1		|R-A|/Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/15/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/15/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 04:25	200.0	180.0	181.5		|R-A|/Span * 100	0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Warning
	Zero	09/15/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 04:20	10.0	9.3	8.5	>2x	|R-A|/Span * 100	8.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:25	200.0	181.3	181.3		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:25	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/15/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/15/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:24	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:19	10.0	8.9	9.1		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:24	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/15/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/15/20 05:19	10.0	9.3	8.6		|R-A|	0.7
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/15/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/15/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 04:24	200.0	180.0	180.8		|R-A|/Span * 100	0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Warning**
	Zero	09/16/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 04:19	10.0	9.3	8.5	>2x	|R-A|/Span * 100	8.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 04:15	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/16/20 04:25	200.0	180.5	180.7		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:25	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:20	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:25	200.0	180.0	179.2		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/16/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/16/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:25	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:25	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/16/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/16/20 05:20	10.0	9.3	8.5		|R-A|	0.8
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/16/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/16/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 04:25	200.0	180.5	181.1		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 04:25	200.0	180.0	178.9		|R-A|/Span * 100	0.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:25	200.0	181.3	181.5		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:19	10.0	9.3	9.1		|R-A|/Span * 100	2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/17/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/17/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:24	200.0	181.3	181.4		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:24	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/17/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/17/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/17/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/17/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 04:25	200.0	180.5	181.3		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 04:20	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 04:25	200.0	180.0	178.8		|R-A|/Span * 100	0.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:25	200.0	181.3	181.5		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:19	10.0	9.3	9.1		|R-A|/Span * 100	2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/18/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/18/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:24	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:24	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/18/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/18/20 05:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/18/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/18/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 04:25	200.0	180.5	181.2		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 04:20	10.0	9.3	9.1		|R-A|/Span * 100	2.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 04:25	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:25	200.0	181.3	181.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:19	10.0	9.2	9.3		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:19	10.0	9.3	9.0	>1x Alert	|R-A|/Span * 100	3.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/19/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/19/20 05:19	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:25	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:25	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/19/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/19/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/19/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/19/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 04:24	200.0	180.5	182.4		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 04:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 04:24	200.0	180.0	180.3		|R-A|/Span * 100	0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 04:19	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:25	200.0	181.3	181.7		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:20	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/20/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/20/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:20	10.0	9.3	9.0	>1x Alert	|R-A|/Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/20/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/20/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/20/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:24	200.0	181.3	181.4		|R-A|/Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/20/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/20/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:24	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/20/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/20/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	High	09/20/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/20/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/21/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 04:25	200.0	180.5	182.2		|R-A|/Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/21/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 04:20	10.0	9.3	9.1		|R-A|/Span * 100	2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/21/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 04:24	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online		Pass
	Zero	09/21/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online		Pass
	Zero	09/21/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:25	200.0	181.3	181.7		|R-A|/Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:19	10.0	9.3	9.0	>1x Alert	|R-A|/Span * 100	3.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/21/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/21/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:25	200.0	181.3	181.8		|R-A|/Span * 100	0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:25	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/21/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/21/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/21/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/21/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 04:24	200.0	180.5	179.3		|R-A|/Span * 100	0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 04:24	200.0	180.0	179.0		|R-A|/Span * 100	0.5

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 04:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:24	200.0	181.3	180.8		|R-A|/Span * 100	0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:24	200.0	180.0	179.7		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/22/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/22/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:25	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:15	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/22/20 05:20	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:25	200.0	180.0	179.6		|R-A|/Span * 100	0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/22/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/22/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/22/20 05:15	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/22/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 04:25	200.0	180.5	179.9		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 04:14	200.0	0.0	0.1		|R-A|/Span * 100	0.1
	High	09/23/20 04:24	200.0	180.0	179.6		|R-A|/Span * 100	0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:24	200.0	181.3	180.8		|R-A|/Span * 100	0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:19	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:24	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/23/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/23/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:25	200.0	181.3	180.4		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/23/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/23/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/23/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/23/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 04:25	200.0	180.0	178.6		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 04:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 05:25	200.0	181.3	180.3		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 05:20	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 05:25	200.0	180.0	179.4		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/24/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/24/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/24/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/24/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 04:24	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 04:19	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 05:24	200.0	181.3	180.4		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 05:24	200.0	180.0	179.8		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/25/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/25/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/25/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/25/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 04:25	200.0	180.0	179.9		|R-A|/Span * 100	0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 05:25	200.0	181.3	180.3		|R-A|/Span * 100	0.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 05:25	200.0	180.0	179.7		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/26/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/26/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/26/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/26/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 04:25	200.0	180.0	180.0		|R-A|/Span * 100	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 05:25	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 05:19	10.0	8.9	8.9		|R-A|/Span * 100	0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 05:25	200.0	180.0	180.1		|R-A|/Span * 100	0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/27/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/27/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/27/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/27/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 04:25	200.0	180.0	180.3		|R-A|/Span * 100	0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 04:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 05:24	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 05:19	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 05:24	200.0	180.0	180.4		|R-A|/Span * 100	0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/28/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/28/20 05:19	21.0	0.0	0.0		|R-A|	0.0

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 08:18	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 08:28	200.0	181.3	181.1		|R-A|/Span * 100	0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 08:18	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 08:23	10.0	9.2	9.1		|R-A|/Span * 100	1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 08:18	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 08:28	200.0	180.0	178.3		|R-A|/Span * 100	0.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/28/20 08:18	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/28/20 08:23	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/28/20 08:18	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/28/20 08:23	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 04:24	200.0	180.0	181.4		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 04:25	200.0	180.5	179.8		|R-A|/Span * 100	0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 04:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:24	200.0	181.3	181.4		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:20	10.0	8.9	9.0		|R-A|/Span * 100	1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:24	200.0	180.0	179.9		|R-A|/Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:20	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/29/20 05:14	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/29/20 05:20	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:25	200.0	181.3	181.0		|R-A|/Span * 100	0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:25	200.0	180.0	179.0		|R-A|/Span * 100	0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/29/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/29/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/29/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/29/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 04:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 04:25	200.0	180.5	178.9		|R-A|/Span * 100	0.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 04:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 04:20	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 04:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 04:25	200.0	180.0	181.4		|R-A|/Span * 100	0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 04:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 04:19	10.0	9.3	9.4		|R-A|/Span * 100	1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:25	200.0	181.3	180.7		|R-A|/Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:47 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:14	10.0	0.0	0.1		|R-A|/Span * 100	1.0
	High	09/30/20 05:19	10.0	9.2	9.2		|R-A|/Span * 100	0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:14	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:25	200.0	180.0	179.3		|R-A|/Span * 100	0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:14	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:19	10.0	9.3	9.2		|R-A|/Span * 100	1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/30/20 05:14	21.0	18.0	18.0		|R-A|	0.0
	Zero	09/30/20 05:19	21.0	0.0	0.0		|R-A|	0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:25	200.0	181.3	181.5		|R-A|/Span * 100	0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:19	10.0	8.9	9.1		|R-A|/Span * 100	2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:15	200.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:25	200.0	180.0	179.5		|R-A|/Span * 100	0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**
	Zero	09/30/20 05:15	10.0	0.0	0.0		|R-A|/Span * 100	0.0
	High	09/30/20 05:19	10.0	9.3	9.3		|R-A|/Span * 100	0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**
	High	09/30/20 05:15	21.0	18.1	18.1		|R-A|	0.0
	Zero	09/30/20 05:19	21.0	0.0	0.0		|R-A|	0.0

Monthly Summary Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:54 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr 1 Hour(s) Sum	Unit CT1 OperatingTime, Hr 1 Hour(s) Running Sum	Unit CT1 DBOn, Hr 1 Hour(s) Sum	Unit CT1 DBOn, Hr 1 Hour(s) Running Sum	Unit CT2 OperatingTime, Hr 1 Hour(s) Sum	Unit CT2 OperatingTime, Hr 1 Hour(s) Running Sum	Unit CT2 DBOn, Hr 1 Hour(s) Sum	Unit CT2 DBOn, Hr 1 Hour(s) Running Sum
Jul 20	332.60	332.60	126.91	126.91	338.70	338.70	126.49	126.49
Aug 20	672.37	1,004.97	299.47	426.38	670.66	1,009.36	293.64	420.13
Sep 20	618.32	1,623.29	242.65	669.03	720.00	1,729.36	255.64	675.77
Sum/Avg	1,623.29		669.03		1,729.36		675.77	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:49 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2020	0.2276	2.3663	0.8761	5.1800	0.1638	0.9456	0.0817	0.4726	0.2723	1.5762
Aug 2020	0.4257	2.4817	1.7833	5.9949	0.3379	1.1020	0.1690	0.5507	0.5626	1.8361
Sep 2020	0.4176	2.5642	1.7227	7.1656	0.3285	1.3362	0.1645	0.6681	0.5474	2.2261
Sum/Avg	2.5642		7.1656		1.3362		0.6681		2.2261	
Limit Value										

CO Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:16 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:

Operating time for EDS: 1,735.00 Hour(s)
Operating time for CMS: 1,735.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.06
4. Total Availability as a percentage of operating time	99.94

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:16 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:

Operating time for EDS: 1,735.00 Hour(s)
Operating time for CMS: 1,735.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.06
4. Total Availability as a percentage of operating time	99.94

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:15 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:

Operating time for EDS: 1,629.00 Hour(s)
Operating time for CMS: 1,629.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	2
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:15 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:

Operating time for EDS: 1,629.00 Hour(s)
Operating time for CMS: 1,629.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	2
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.12
4. Total Availability as a percentage of operating time	99.88

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:18 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,629.00 Hour(s)
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,629.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:18 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,629.00 Hour(s)
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,629.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx SCR Invalid Data

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:19 **Location:** Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,629.00 Hour(s)
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/29/2020 10:00	07/29/2020 10:59	1		
2	07/29/2020 21:00	07/29/2020 21:59	1		
3	09/21/2020 09:00	09/21/2020 09:59	1		

Total Operating Time:	1,629.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.82 %
Percent Monitor Downtime:	0.18 %

O2 Invalid Data

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:19 **Location:** Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,629.00 Hour(s)
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/30/2020 04:00	07/30/2020 04:59	1	3 - Quality assurance calibration	
2	07/30/2020 05:00	07/30/2020 05:59	1	3 - Quality assurance calibration	

Total Operating Time:	**1,629.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.88 %**
Percent Monitor Downtime:	**0.12 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	100.00

CO Invalid Data

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:20 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,735.00 Hour(s)
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2020 13:00	07/14/2020 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	**1,735.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.94 %**
Percent Monitor Downtime:	**0.06 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00

NOx Invalid Data

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:20 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 1,735.00 Hour(s)
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2020 13:00	07/14/2020 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	**1,735.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.94 %**
Percent Monitor Downtime:	**0.06 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00

NOx SCR Invalid Data

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:21 **Location:** Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,735.00 Hour(s)
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,735.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:22 **Location:** Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,735.00 Hour(s)
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2020 13:00	07/14/2020 13:59	1	3 - Quality assurance calibration	

Total Operating Time:	**1,735.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.94 %**
Percent Monitor Downtime:	**0.06 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A15	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	102	Highest Error:	2.5
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0727	L	200.0	47.6	48.3		23.8 %
07/14/2020	0732	M	200.0	105.0	107.9		52.5 %
07/14/2020	0737	H	200.0	179.0	177.6		89.5 %
07/14/2020	0744	L	200.0	47.6	48.7		23.8 %
07/14/2020	0749	M	200.0	105.0	107.6		52.5 %
07/14/2020	0754	H	200.0	179.0	177.4		89.5 %
07/14/2020	0801	L	200.0	47.6	48.6		23.8 %
07/14/2020	0806	M	200.0	105.0	107.3		52.5 %
07/14/2020	0811	H	200.0	179.0	177.2		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.533	No	**2.0**
M	105.000	107.600	No	**2.5**
H	179.000	177.400	No	**0.9**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT001	Component ID:	A16	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	103	Highest Error:	3.6
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0927	L	21.0	5.5	5.3		26.2 %
07/14/2020	0932	M	21.0	11.1	10.9		52.9 %
07/14/2020	0937	H	21.0	18.1	18.0		86.2 %
07/14/2020	0944	L	21.0	5.5	5.3		26.2 %
07/14/2020	0949	M	21.0	11.1	10.9		52.9 %
07/14/2020	0954	H	21.0	18.1	18.0		86.2 %
07/14/2020	1001	L	21.0	5.5	5.3		26.2 %
07/14/2020	1006	M	21.0	11.1	10.9		52.9 %
07/14/2020	1011	H	21.0	18.1	18.0		86.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	**3.6**
M	11.100	10.900	No	**1.8**
H	18.100	18.000	No	**0.6**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	102	Highest Error:	1.4
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	0825	L	200.0	48.2	48.6		24.1 %
07/14/2020	0830	M	200.0	106.0	107.4		53.0 %
07/14/2020	0835	H	200.0	179.0	177.3		89.5 %
07/14/2020	0842	L	200.0	48.2	48.9		24.1 %
07/14/2020	0847	M	200.0	106.0	107.4		53.0 %
07/14/2020	0852	H	200.0	179.0	177.4		89.5 %
07/14/2020	0859	L	200.0	48.2	48.9		24.1 %
07/14/2020	0904	M	200.0	106.0	107.6		53.0 %
07/14/2020	0909	H	200.0	179.0	177.3		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	48.800	No	**1.2**
M	106.000	107.467	No	**1.4**
H	179.000	177.333	No	**0.9**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	07/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	103	Highest Error:	1.8
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/14/2020	1027	L	21.0	5.6	5.5		26.7 %
07/14/2020	1031	M	21.0	11.2	11.1		53.3 %
07/14/2020	1036	H	21.0	18.0	17.9		85.7 %
07/14/2020	1044	L	21.0	5.6	5.5		26.7 %
07/14/2020	1049	M	21.0	11.2	11.1		53.3 %
07/14/2020	1054	H	21.0	18.0	17.9		85.7 %
07/14/2020	1101	L	21.0	5.6	5.5		26.7 %
07/14/2020	1106	M	21.0	11.2	11.1		53.3 %
07/14/2020	1111	H	21.0	18.0	17.9		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.500	No	**1.8**
M	11.200	11.100	No	**0.9**
H	18.000	17.900	No	**0.6**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	07:27	L	200	50.300	49.900	25.2 %
07/14/2020	07:32	M	200	112.800	114.300	56.4 %
07/14/2020	07:44	L	200	50.300	49.900	25.2 %
07/14/2020	07:49	M	200	112.800	114.200	56.4 %
07/14/2020	08:01	L	200	50.300	49.900	25.2 %
07/14/2020	08:06	M	200	112.800	114.200	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.900	Std	**0.8**
M	112.800	114.233	Std	**1.3**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	11:42	L	10	2.400	2.400	24.0 %
07/14/2020	11:46	M	10	5.700	5.700	57.0 %
07/14/2020	11:54	L	10	2.400	2.300	24.0 %
07/14/2020	11:59	M	10	5.700	5.700	57.0 %
07/14/2020	12:06	L	10	2.400	2.300	24.0 %
07/14/2020	12:11	M	10	5.700	5.800	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.333	Std	**2.8**
M	5.700	5.733	Std	**0.6**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	08:25	L	200	49.400	50.300	24.7 %
07/14/2020	08:30	M	200	112.700	117.600	56.4 %
07/14/2020	08:42	L	200	49.400	50.400	24.7 %
07/14/2020	08:47	M	200	112.700	117.400	56.4 %
07/14/2020	08:59	L	200	49.400	50.400	24.7 %
07/14/2020	09:04	M	200	112.700	117.500	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.367	Std	**2.0**
M	112.700	117.500	Std	**4.3**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 07/14/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/14/2020	12:55	L	10	2.400	2.300	24.0 %
07/14/2020	13:00	M	10	5.700	5.700	57.0 %
07/14/2020	13:08	L	10	2.400	2.200	24.0 %
07/14/2020	13:13	M	10	5.700	5.700	57.0 %
07/14/2020	13:20	L	10	2.400	2.300	24.0 %
07/14/2020	13:25	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.267	Std	**5.6**
M	5.700	5.700	Std	**0.0**

Roseville Energy Park
Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.
Teledyne Monitor Labs, Inc.
35 Inverness Drive East
Englewood, CO 80112-5189
Telephone: (800) 846-6062
http://www.teledyne-ml.com/
http://www.regperfect.com/
©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.
RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

7/15,17/20 Taylor Sullivan
Q2 EDRs

7/9/20 Taylor Sullivan
Looking at GHG totals for 2019. Recalculated CO2_Year_Mton tag for Q4 2019

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:26 **Location:** Roseville, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:25 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:26 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:27 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:27 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:58 **Location:** Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:59 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:59 **Location:** Roseville, CA

Tag Name: CT1_NOx_SUSD_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:00 **Location:** Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:01 **Location:** Roseville, CA

Tag Name: CT1_SO2_Norm_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:01 **Location:** Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:56 **Location:** Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:56 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:57 **Location:** Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 00:58 **Location:** Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,629.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 579.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,629.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:07 **Location:** Roseville, CA

Tag Name: CT2_NOx_SUSD_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:07 **Location:** Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:08 **Location:** Roseville, CA

Tag Name: CT2_SO2_Norm_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:08 **Location:** Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:03 **Location:** Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:04 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:04 **Location:** Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:05 **Location:** Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:06 **Location:** Roseville, CA

Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:06 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,735.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 473.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,735.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants; and
d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/03/2020 01:14 **Location:** Roseville, CA

Date	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Running Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Running Sum
Jul 20	0.8761	0.8761	0.2723	0.2723
Aug 20	1.7833	2.6594	0.5626	0.8349
Sep 20	1.7227	4.3821	0.5474	1.3823
Sum/Avg	4.3821		1.3823	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:24 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton 1 Day(s) Sum	Unit CT1 CO, Ton 1 Day(s) Rolling Sum	Unit CT1 NOx, Ton 1 Day(s) Sum	Unit CT1 NOx, Ton 1 Day(s) Rolling Sum	Unit CT1 OperatingTime, Hrs 1 Day(s) Sum	Unit CT1 OperatingTime, Hrs 1 Day(s) Rolling Sum	Unit CT2 CO, Ton 1 Day(s) Sum	Unit CT2 CO, Ton 1 Day(s) Rolling Sum	Unit CT2 NOx, Ton 1 Day(s) Sum	Unit CT2 NOx, Ton 1 Day(s) Rolling Sum	Unit CT2 OperatingTime, Hrs 1 Day(s) Sum	Unit CT2 OperatingTime, Hrs 1 Day(s) Rolling Sum
Jul 2020	0.1134	1.0800	0.4424	2.6090	332.60	1,916.41	0.1142	1.2761	0.4336	2.5711	338.70	1,833.66
Aug 2020	0.2103	1.1535	0.9080	3.0470	672.37	2,238.06	0.2158	1.3186	0.8756	2.9482	670.66	2,155.49
Sep 2020	0.1826	1.2045	0.8159	3.6601	618.32	2,719.30	0.2345	1.3497	0.9070	3.5058	720.00	2,665.52
Sum/Avg	1.2045		3.6601		2,719.30		1.3497		3.5058		2,665.52	
Limit Value												

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% o2 averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O2 averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O2 averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

Ammonia slip ppmv @ 15% O2 = ((a-(bxc/1,000,000)) x 1,000,000/b) x d,

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O2 across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/01/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/02/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/03/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/04/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/05/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 06:00	0	22.6	27.7	17.5	0.0	672,629.0	0.27	0.27
07/13/2020 07:00	3	5.5	14.8	14.2	15.3	677,762.9	0.82	1.00
07/13/2020 08:00	2	1.9	13.3	14.2	26.1	684,099.0	0.00	1.00
07/13/2020 09:00	2	1.9	12.4	14.3	27.1	760,860.5	0.00	1.00
07/13/2020 10:00	1	1.8	9.9	14.5	24.4	899,754.6	0.00	1.00
07/13/2020 11:00	2	2.1	12.2	13.5	29.5	942,312.0	0.00	1.00
07/13/2020 12:00	2	2.2	12.5	13.3	29.8	930,668.0	0.00	1.00
07/13/2020 13:00	2	2.1	11.7	13.6	28.2	934,210.1	0.00	1.00
07/13/2020 14:00	2	2.2	12.6	13.3	30.2	930,848.2	0.00	1.00
07/13/2020 15:00	2	2.2	12.7	13.3	30.6	928,686.0	0.00	1.00
07/13/2020 16:00	2	2.1	11.7	13.7	28.4	930,257.6	0.00	1.00
07/13/2020 17:00	2	2.2	12.8	13.3	30.7	927,244.5	0.00	1.00
07/13/2020 18:00	3	2.5	16.3	12.1	41.9	932,920.4	0.00	1.00
07/13/2020 19:00	2	2.2	13.2	13.2	31.4	931,920.0	0.00	1.00
07/13/2020 20:00	2	1.9	12.7	14.4	31.0	780,361.2	0.00	1.00
07/13/2020 21:00	2	1.8	13.5	14.5	26.0	635,712.5	0.00	1.00
07/13/2020 22:00	2	1.8	13.3	14.5	25.8	636,996.3	0.00	1.00
07/13/2020 23:00	2	1.9	13.2	14.5	25.8	638,066.2	0.00	1.00
Average/Sum#:	2	3.4	13.7	14.0	26.8	820,850.5	1.09 #	17.27 #
Minimum:	1	1.8	9.9	12.1	0.0	635,712.5	0.00	0.00
Maximum:	3	22.6	27.7	17.5	41.9	942,312.0	0.82	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/14/2020 00:00	2	1.9	13.1	14.5	25.4	637,852.2	0.00	1.00
07/14/2020 01:00	3	1.9	14.0	14.4	29.2	648,053.8	0.00	1.00
07/14/2020 02:00	2	1.9	13.1	14.5	25.4	634,642.6	0.00	1.00
07/14/2020 03:00	2	1.9	13.4	14.5	26.4	635,070.6	0.00	1.00
07/14/2020 04:00	2	1.8	14.0	14.4	27.6	635,202.2	0.00	1.00
07/14/2020 05:00	2	1.9	13.7	14.5	27.7	635,926.4	0.00	1.00
07/14/2020 06:00	2	1.9	13.4	14.5	26.5	636,996.3	0.00	1.00
07/14/2020 07:00	3	1.9	13.9	14.4	30.9	653,110.1	0.00	1.00
07/14/2020 08:00	2	1.9	13.6	14.3	29.7	680,769.9	0.00	1.00
07/14/2020 09:00	2	1.9	12.8	14.4	29.9	748,969.8	0.00	1.00
07/14/2020 10:00	1	1.8	10.2	14.5	23.2	876,217.6	0.00	1.00
07/14/2020 11:00	1	2.0	10.9	14.0	27.3	951,849.2	0.00	1.00
07/14/2020 12:00	1	2.3	14.4	12.8	37.3	939,492.8	0.00	1.00
07/14/2020 13:00	2	2.0	10.9	13.9	25.6	929,839.2	0.00	1.00
07/14/2020 14:00	3	2.4	15.3	12.6	36.9	934,673.4	0.00	1.00
07/14/2020 15:00	4	2.6	16.8	11.9	45.2	942,316.1	0.00	1.00
07/14/2020 16:00	4	2.6	16.8	11.8	46.3	936,024.1	0.00	1.00
07/14/2020 17:00	4	2.6	16.5	11.9	45.0	938,512.2	0.00	1.00
07/14/2020 18:00	2	2.3	14.5	12.8	34.6	936,111.5	0.00	1.00
07/14/2020 19:00	2	2.1	11.2	13.8	26.4	925,036.5	0.00	1.00
07/14/2020 20:00	1	1.9	9.1	14.5	22.3	899,754.6	0.00	1.00
07/14/2020 21:00	2	1.9	11.8	14.4	30.3	826,921.6	0.00	1.00
07/14/2020 22:00	2	1.9	12.4	14.4	29.9	798,058.4	0.00	1.00
07/14/2020 23:00	2	1.9	13.4	14.3	27.7	673,507.8	0.00	1.00
Average/Sum#:	2	2.1	13.3	13.8	30.7	793,954.5	0.00 #	24.00 #
Minimum:	1	1.8	9.1	11.8	22.3	634,642.6	0.00	1.00
Maximum:	4	2.6	16.8	14.5	46.3	951,849.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/15/2020 00:00	2	1.9	12.9	14.4	24.4	638,151.8	0.00	1.00
07/15/2020 01:00	2	1.9	13.0	14.4	24.9	628,671.1	0.00	1.00
07/15/2020 02:00	2	1.9	13.0	14.4	25.2	627,617.7	0.00	1.00
07/15/2020 03:00	2	1.9	13.1	14.4	25.6	627,617.7	0.00	1.00
07/15/2020 04:00	2	1.8	13.6	14.4	25.6	627,828.4	0.00	1.00
07/15/2020 05:00	2	1.9	13.4	14.4	26.7	628,249.8	0.00	1.00
07/15/2020 06:00	2	1.9	13.2	14.4	25.9	628,671.1	0.00	1.00
07/15/2020 07:00	2	1.9	12.9	14.4	25.0	631,831.3	0.00	1.00
07/15/2020 08:00	2	1.9	12.6	14.3	26.5	696,539.0	0.00	1.00
07/15/2020 09:00	2	1.9	12.0	14.3	26.2	751,316.0	0.00	1.00
07/15/2020 10:00	1	1.8	10.3	14.5	24.1	875,789.7	0.00	1.00
07/15/2020 11:00	2	2.1	12.1	13.5	28.8	938,795.9	0.00	1.00
07/15/2020 12:00	3	2.4	15.5	12.5	37.1	945,718.0	0.00	1.00
07/15/2020 13:00	3	2.5	15.7	12.4	38.2	941,841.8	0.00	1.00
07/15/2020 14:00	3	2.6	16.4	11.9	43.4	937,751.4	0.00	1.00
07/15/2020 15:00	4	2.6	16.7	11.8	45.7	939,936.8	0.00	1.00
07/15/2020 16:00	4	2.6	16.5	11.7	45.5	931,208.6	0.00	1.00
07/15/2020 17:00	4	2.6	16.3	11.8	44.9	938,431.9	0.00	1.00
07/15/2020 18:00	3	2.5	15.5	12.3	40.5	940,285.0	0.00	1.00
07/15/2020 19:00	2	2.0	10.7	13.9	25.6	918,296.9	0.00	1.00
07/15/2020 20:00	2	1.9	11.3	14.4	28.7	844,829.5	0.00	1.00
07/15/2020 21:00	2	1.9	13.0	14.3	26.2	666,038.2	0.00	1.00
07/15/2020 22:00	2	1.9	12.3	14.4	22.3	631,199.3	0.00	1.00
07/15/2020 23:00	2	1.9	12.7	14.4	24.3	629,724.5	0.00	1.00
Average/Sum#:	2	2.1	13.5	13.7	30.5	773,597.6	0.00 #	24.00 #
Minimum:	1	1.8	10.3	11.7	22.3	627,617.7	0.00	1.00
Maximum:	4	2.6	16.7	14.5	45.7	945,718.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/16/2020 00:00	2	1.9	13.0	14.4	25.3	629,513.9	0.00	1.00
07/16/2020 01:00	2	1.9	13.1	14.4	25.5	629,092.5	0.00	1.00
07/16/2020 02:00	2	1.9	13.2	14.4	25.8	628,881.8	0.00	1.00
07/16/2020 03:00	2	1.9	13.3	14.4	26.3	628,881.8	0.00	1.00
07/16/2020 04:00	2	1.8	13.7	14.4	27.0	628,671.1	0.00	1.00
07/16/2020 05:00	2	1.9	13.4	14.4	27.1	628,671.1	0.00	1.00
07/16/2020 06:00	2	1.9	13.1	14.4	25.6	630,145.9	0.00	1.00
07/16/2020 07:00	2	1.9	12.9	14.4	25.3	633,727.5	0.00	1.00
07/16/2020 08:00	2	1.9	13.1	14.2	27.9	666,725.7	0.00	1.00
07/16/2020 09:00	2	1.9	11.8	14.3	26.0	751,108.5	0.00	1.00
07/16/2020 10:00	2	1.9	11.1	14.4	26.9	843,986.8	0.00	1.00
07/16/2020 11:00	1	2.0	10.7	14.0	25.1	942,918.2	0.00	1.00
07/16/2020 12:00	3	2.4	15.1	12.5	36.6	941,479.3	0.00	1.00
07/16/2020 13:00	2	2.3	13.5	13.0	31.6	933,808.8	0.00	1.00
07/16/2020 14:00	2	2.3	14.1	12.9	33.1	937,713.3	0.00	1.00
07/16/2020 15:00	4	2.7	16.6	11.7	45.3	935,822.9	0.00	1.00
07/16/2020 16:00	4	2.7	16.5	11.7	45.7	935,376.4	0.00	1.00
07/16/2020 17:00	4	2.7	16.5	11.7	46.7	941,628.1	0.00	1.00
07/16/2020 18:00	2	2.3	13.6	12.9	32.2	922,820.9	0.00	1.00
07/16/2020 19:00	1	1.9	9.3	14.4	22.7	905,926.9	0.00	1.00
07/16/2020 20:00	2	1.9	12.1	14.3	28.2	744,261.4	0.00	1.00
07/16/2020 21:00	2	1.9	12.7	14.3	27.6	707,743.4	0.00	1.00
07/16/2020 22:00	2	1.9	12.9	14.4	25.0	632,252.7	0.00	1.00
07/16/2020 23:00	2	1.9	13.1	14.4	25.8	641,733.3	0.00	1.00
Average/Sum#:	2	2.1	13.3	13.8	29.8	767,620.5	0.00 #	24.00 #
Minimum:	1	1.8	9.3	11.7	22.7	628,671.1	0.00	1.00
Maximum:	4	2.7	16.6	14.4	46.7	942,918.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/17/2020 00:00	2	1.9	12.9	14.4	24.9	629,513.9	0.00	1.00
07/17/2020 01:00	2	1.9	13.2	14.4	25.8	629,513.9	0.00	1.00
07/17/2020 02:00	2	1.9	13.3	14.4	26.1	629,092.5	0.00	1.00
07/17/2020 03:00	2	1.9	13.3	14.4	26.4	629,092.5	0.00	1.00
07/17/2020 04:00	2	1.8	13.8	14.4	26.8	628,460.5	0.00	1.00
07/17/2020 05:00	2	1.9	13.5	14.4	27.1	628,460.5	0.00	1.00
07/17/2020 06:00	2	1.9	13.2	14.4	26.4	629,935.2	0.00	1.00
07/17/2020 07:00	2	1.9	12.9	14.4	24.9	627,617.7	0.00	1.00
07/17/2020 08:00	3	1.9	13.4	14.3	28.4	669,358.0	0.00	1.00
07/17/2020 09:00	2	1.9	12.3	14.3	27.8	734,302.0	0.00	1.00
07/17/2020 10:00	2	1.8	12.4	14.5	31.4	815,449.4	0.00	1.00
07/17/2020 11:00	1	1.8	9.3	14.5	21.2	924,789.4	0.00	1.00
07/17/2020 12:00	2	1.9	11.6	14.3	25.5	751,316.0	0.00	1.00
07/17/2020 13:00	1	1.8	9.7	14.5	22.2	880,069.1	0.00	1.00
07/17/2020 14:00	2	2.1	12.4	13.4	31.7	920,435.8	0.00	1.00
07/17/2020 15:00	3	2.4	15.9	12.4	40.6	946,513.9	0.00	1.00
07/17/2020 16:00	4	2.6	16.6	11.9	45.7	942,772.6	0.00	1.00
07/17/2020 17:00	3	2.4	15.4	12.4	39.4	934,269.6	0.00	1.00
07/17/2020 18:00	2	2.2	12.3	13.4	29.9	938,329.6	0.00	1.00
07/17/2020 19:00	2	2.0	11.8	14.3	30.7	835,971.3	0.00	1.00
07/17/2020 20:00	3	1.9	13.6	14.4	30.2	692,928.7	0.00	1.00
07/17/2020 21:00	3	1.9	13.7	14.4	29.2	678,391.8	0.00	1.00
07/17/2020 22:00	3	1.9	13.5	14.4	28.9	688,925.8	0.00	1.00
07/17/2020 23:00	2	1.8	13.2	14.5	25.9	639,564.0	0.00	1.00
Average/Sum#:	2	2.0	13.1	14.0	29.0	751,044.7	0.00 #	24.00 #
Minimum:	1	1.8	9.3	11.9	21.2	627,617.7	0.00	1.00
Maximum:	4	2.6	16.6	14.5	45.7	946,513.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/18/2020 00:00	2	1.8	13.2	14.5	26.2	636,996.3	0.00	1.00
07/18/2020 01:00	2	1.8	12.8	14.5	24.5	637,210.3	0.00	1.00
07/18/2020 02:00	2	1.9	12.9	14.5	24.9	637,210.3	0.00	1.00
07/18/2020 03:00	2	1.9	12.9	14.5	25.2	636,996.3	0.00	1.00
07/18/2020 04:00	2	1.8	13.6	14.5	26.1	636,782.3	0.00	1.00
07/18/2020 05:00	2	1.9	13.4	14.5	26.9	636,782.3	0.00	1.00
07/18/2020 06:00	2	1.9	13.0	14.5	26.0	637,210.3	0.00	1.00
07/18/2020 07:00	2	1.9	13.0	14.5	25.8	641,489.7	0.00	1.00
07/18/2020 08:00	3	1.9	13.6	14.3	29.6	674,337.8	0.00	1.00
07/18/2020 09:00	2	1.9	12.4	14.4	28.2	752,551.4	0.00	1.00
07/18/2020 10:00	1	1.8	9.4	14.5	20.4	899,540.6	0.00	1.00
07/18/2020 11:00	2	2.1	12.1	13.4	28.5	929,382.7	0.00	1.00
07/18/2020 12:00	1	1.9	9.7	14.5	22.7	878,571.3	0.00	1.00
07/18/2020 13:00	2	2.1	12.1	13.5	28.8	936,575.2	0.00	1.00
07/18/2020 14:00	4	2.6	16.8	11.8	45.0	945,504.8	0.00	1.00
07/18/2020 15:00	4	2.7	16.6	11.6	46.3	931,503.1	0.00	1.00
07/18/2020 16:00	4	2.6	16.2	11.9	44.2	934,860.4	0.00	1.00
07/18/2020 17:00	4	2.6	16.2	12.0	44.0	939,517.4	0.00	1.00
07/18/2020 18:00	4	2.6	16.2	11.9	44.0	931,360.7	0.00	1.00
07/18/2020 19:00	2	2.3	14.4	12.8	34.2	925,967.6	0.00	1.00
07/18/2020 20:00	1	1.9	9.7	14.4	23.3	905,084.2	0.00	1.00
07/18/2020 21:00	2	1.8	9.7	14.6	24.2	898,168.5	0.00	1.00
07/18/2020 22:00	2	2.1	11.7	13.6	28.2	921,078.6	0.00	1.00
07/18/2020 23:00	3	1.9	13.2	14.4	27.1	638,994.5	0.00	1.00
Average/Sum#:	2	2.1	13.1	13.7	30.2	797,653.2	0.00 #	24.00 #
Minimum:	1	1.8	9.4	11.6	20.4	636,782.3	0.00	1.00
Maximum:	4	2.7	16.8	14.6	46.3	945,504.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/19/2020 00:00	2	1.8	13.2	14.5	25.8	636,782.3	0.00	1.00
07/19/2020 01:00	2	1.8	13.3	14.5	26.3	636,996.3	0.00	1.00
07/19/2020 02:00	2	1.8	13.3	14.5	26.2	636,354.4	0.00	1.00
07/19/2020 03:00	2	1.9	13.1	14.5	25.8	636,568.4	0.00	1.00
07/19/2020 04:00	2	1.8	13.5	14.5	25.7	635,926.4	0.00	1.00
07/19/2020 05:00	2	1.9	13.2	14.5	26.5	636,354.4	0.00	1.00
07/19/2020 06:00	2	1.9	12.9	14.5	25.5	637,638.2	0.00	1.00
07/19/2020 07:00	2	1.9	12.9	14.5	25.6	639,136.0	0.00	1.00
07/19/2020 08:00	3	1.9	13.2	14.5	26.7	642,773.6	0.00	1.00
07/19/2020 09:00	2	1.9	13.1	14.4	29.0	712,943.4	0.00	1.00
07/19/2020 10:00	2	1.8	10.8	14.6	25.1	860,998.4	0.00	1.00
07/19/2020 11:00	1	2.0	11.1	13.8	25.4	931,208.6	0.00	1.00
07/19/2020 12:00	2	2.2	13.0	13.1	30.8	932,086.4	0.00	1.00
07/19/2020 13:00	2	2.3	13.7	12.8	32.8	926,812.9	0.00	1.00
07/19/2020 14:00	4	2.7	16.3	11.7	45.1	933,143.6	0.00	1.00
07/19/2020 15:00	4	2.7	16.3	11.6	45.9	923,551.6	0.00	1.00
07/19/2020 16:00	3	2.5	15.1	12.3	39.2	930,412.4	0.00	1.00
07/19/2020 17:00	4	2.6	16.2	11.9	44.6	934,556.1	0.00	1.00
07/19/2020 18:00	3	2.4	14.8	12.6	36.6	927,413.8	0.00	1.00
07/19/2020 19:00	2	2.0	10.2	14.2	25.2	916,901.2	0.00	1.00
07/19/2020 20:00	2	1.9	9.7	14.5	24.1	887,986.1	0.00	1.00
07/19/2020 21:00	3	1.9	12.8	14.4	31.5	758,450.4	0.00	1.00
07/19/2020 22:00	2	1.8	13.2	14.5	26.9	658,179.6	0.00	1.00
07/19/2020 23:00	2	1.9	12.9	14.4	29.1	730,429.9	0.00	1.00
Average/Sum#:	2	2.1	13.2	13.8	30.2	779,316.9	0.00 #	24.00 #
Minimum:	1	1.8	9.7	11.6	24.1	635,926.4	0.00	1.00
Maximum:	4	2.7	16.3	14.6	45.9	934,556.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/20/2020 00:00	3	1.9	13.4	14.4	27.1	640,469.3	0.00	1.00
07/20/2020 01:00	2	1.9	13.1	14.5	25.9	636,996.3	0.00	1.00
07/20/2020 02:00	3	1.9	13.4	14.5	26.6	637,852.2	0.00	1.00
07/20/2020 03:00	3	1.9	13.4	14.4	27.0	639,837.2	0.00	1.00
07/20/2020 04:00	2	1.8	13.7	14.4	27.1	642,997.4	0.00	1.00
07/20/2020 05:00	3	1.9	13.7	14.4	28.6	627,617.7	0.00	1.00
07/20/2020 06:00	3	1.9	13.5	14.4	27.0	628,039.1	0.00	1.00
07/20/2020 07:00	2	1.9	13.2	14.5	26.3	639,136.0	0.00	1.00
07/20/2020 08:00	2	1.9	12.9	14.5	25.5	640,633.8	0.00	1.00
07/20/2020 09:00	2	1.9	12.5	14.4	28.6	741,596.0	0.00	1.00
07/20/2020 10:00	1	1.8	9.4	14.5	22.0	915,160.6	0.00	1.00
07/20/2020 11:00	1	1.9	9.4	14.5	23.6	930,780.6	0.00	1.00
07/20/2020 12:00	1	1.8	9.4	14.5	23.6	929,496.8	0.00	1.00
07/20/2020 13:00	2	2.2	12.7	13.2	30.8	934,943.4	0.00	1.00
07/20/2020 14:00	3	2.5	15.2	12.4	38.2	941,519.5	0.00	1.00
07/20/2020 15:00	3	2.5	15.6	12.1	40.1	932,297.9	0.00	1.00
07/20/2020 16:00	3	2.5	15.6	12.1	40.6	931,831.0	0.00	1.00
07/20/2020 17:00	3	2.5	15.1	12.4	38.5	941,036.2	0.00	1.00
07/20/2020 18:00	2	2.2	12.4	13.3	28.7	918,054.9	0.00	1.00
07/20/2020 19:00	2	2.1	11.7	13.6	28.3	929,707.8	0.00	1.00
07/20/2020 20:00	2	2.0	10.7	14.1	26.6	848,237.6	0.00	1.00
07/20/2020 21:00	3	1.9	13.7	14.3	29.5	661,681.0	0.00	1.00
07/20/2020 22:00	2	1.9	13.0	14.5	25.0	639,136.0	0.00	1.00
07/20/2020 23:00	3	1.9	13.2	14.3	28.9	689,691.9	0.00	1.00
Average/Sum#:	2	2.0	12.9	13.9	28.9	775,781.3	0.00 #	24.00 #
Minimum:	1	1.8	9.4	12.1	22.0	627,617.7	0.00	1.00
Maximum:	3	2.5	15.6	14.5	40.6	941,519.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/21/2020 00:00	2	1.9	13.2	14.4	26.2	637,941.1	0.00	1.00
07/21/2020 01:00	2	1.9	12.9	14.4	25.0	629,513.9	0.00	1.00
07/21/2020 02:00	3	1.9	13.2	14.4	26.1	627,828.4	0.00	1.00
07/21/2020 03:00	2	1.9	13.0	14.4	25.4	634,991.6	0.00	1.00
07/21/2020 04:00	2	2.3	16.0	14.4	24.9	663,433.4	0.10	1.00
07/21/2020 05:00	0	11.4	31.0	16.9	0.0	358,789.2	0.05	0.05
07/21/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	3.6	16.6	14.8	21.3	592,082.9	0.15 #	5.05 #
Minimum:	2	1.9	12.9	14.4	0.0	358,789.2	0.00	0.00
Maximum:	3	11.4	31.0	16.9	26.2	663,433.4	0.10	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/22/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/23/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2020 01:00	0	22.8	26.6	17.5	0.0	668,601.3	0.28	0.28
07/26/2020 02:00	4	4.3	14.6	14.3	22.2	726,417.4	0.65	1.00
07/26/2020 03:00	3	1.8	13.7	14.5	26.7	640,205.9	0.00	1.00
07/26/2020 04:00	2	1.8	13.5	14.5	25.8	635,712.5	0.00	1.00
07/26/2020 05:00	2	1.9	13.1	14.5	25.8	639,136.0	0.00	1.00
07/26/2020 06:00	3	1.9	12.9	14.4	26.0	647,211.0	0.00	1.00
07/26/2020 07:00	2	1.9	12.5	14.4	24.4	634,570.2	0.00	1.00
07/26/2020 08:00	2	1.9	12.5	14.4	24.2	629,303.2	0.00	1.00
07/26/2020 09:00	2	1.9	12.1	14.4	23.0	629,303.2	0.00	1.00
07/26/2020 10:00	2	1.9	11.9	14.4	22.6	630,567.3	0.00	1.00
07/26/2020 11:00	2	1.9	11.8	14.4	22.8	648,685.8	0.00	1.00
07/26/2020 12:00	2	1.9	10.4	14.2	25.5	907,499.1	0.00	1.00
07/26/2020 13:00	2	2.0	11.7	13.7	26.4	917,704.5	0.00	1.00
07/26/2020 14:00	2	2.2	13.4	13.3	32.6	934,091.6	0.00	1.00
07/26/2020 15:00	4	2.7	17.4	11.7	48.5	932,548.2	0.00	1.00
07/26/2020 16:00	4	2.7	17.2	11.7	49.4	932,994.8	0.00	1.00
07/26/2020 17:00	4	2.7	17.0	11.7	48.9	931,506.3	0.00	1.00
07/26/2020 18:00	4	2.7	17.1	11.7	48.6	933,143.6	0.00	1.00
07/26/2020 19:00	4	2.6	16.8	11.9	46.6	932,882.3	0.00	1.00
07/26/2020 20:00	3	2.4	15.3	12.6	39.3	930,713.6	0.00	1.00
07/26/2020 21:00	2	2.0	12.0	14.3	27.6	758,578.1	0.00	1.00
07/26/2020 22:00	2	1.9	12.5	14.4	31.5	807,539.0	0.00	1.00
07/26/2020 23:00	3	1.9	12.7	14.5	33.0	816,519.3	0.00	1.00
Average/Sum#:	3	3.1	14.3	13.8	30.5	776,758.0	0.93 #	22.28 #
Minimum:	2	1.8	10.4	11.7	0.0	629,303.2	0.00	0.00
Maximum:	4	22.8	26.6	17.5	49.4	934,091.6	0.65	1.00
%SI	8.33	4.17	4.17	4.17	4.17	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/27/2020 00:00	3	1.9	13.8	14.4	31.0	701,356.0	0.00	1.00
07/27/2020 01:00	3	1.9	14.3	14.5	30.0	652,616.3	0.00	1.00
07/27/2020 02:00	3	1.9	13.6	14.4	30.2	702,830.7	0.00	1.00
07/27/2020 03:00	3	1.9	13.7	14.4	31.2	691,032.6	0.00	1.00
07/27/2020 04:00	2	1.8	14.0	14.5	27.2	641,703.7	0.00	1.00
07/27/2020 05:00	3	1.9	14.4	14.4	30.0	646,157.6	0.00	1.00
07/27/2020 06:00	3	1.9	13.8	14.5	28.3	645,341.2	0.00	1.00
07/27/2020 07:00	3	1.9	13.2	14.5	26.8	638,708.1	0.00	1.00
07/27/2020 08:00	3	1.9	13.5	14.5	28.1	642,131.7	0.00	1.00
07/27/2020 09:00	2	1.9	12.7	14.4	27.4	713,364.8	0.00	1.00
07/27/2020 10:00	2	1.9	10.6	14.1	26.0	902,410.4	0.00	1.00
07/27/2020 11:00	2	2.2	12.9	13.3	32.3	934,271.8	0.00	1.00
07/27/2020 12:00	3	2.4	16.0	12.4	40.6	941,519.5	0.00	1.00
07/27/2020 13:00	2	2.3	13.4	13.1	32.7	924,361.5	0.00	1.00
07/27/2020 14:00	4	2.7	16.7	11.7	46.5	927,487.3	0.00	1.00
07/27/2020 15:00	4	2.7	16.8	11.7	47.8	929,571.2	0.00	1.00
07/27/2020 16:00	4	2.7	16.8	11.7	48.2	927,933.9	0.00	1.00
07/27/2020 17:00	4	2.7	16.9	11.7	48.9	931,506.3	0.00	1.00
07/27/2020 18:00	4	2.6	16.8	11.8	48.2	935,271.7	0.00	1.00
07/27/2020 19:00	3	2.4	16.0	12.5	39.8	928,600.2	0.00	1.00
07/27/2020 20:00	2	2.3	14.7	12.9	35.3	910,153.7	0.00	1.00
07/27/2020 21:00	3	2.0	14.2	14.4	32.2	681,973.3	0.00	1.00
07/27/2020 22:00	3	1.9	13.6	14.4	30.5	705,358.9	0.00	1.00
07/27/2020 23:00	3	1.9	13.5	14.4	31.3	713,786.1	0.00	1.00
Average/Sum#:	3	2.2	14.4	13.5	34.6	790,393.7	0.00 #	24.00 #
Minimum:	2	1.8	10.6	11.7	26.0	638,708.1	0.00	1.00
Maximum:	4	2.7	16.9	14.5	48.9	941,519.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/28/2020 00:00	3	1.8	13.5	14.5	26.9	636,140.4	0.00	1.00
07/28/2020 01:00	3	1.8	13.3	14.5	26.4	634,856.6	0.00	1.00
07/28/2020 02:00	2	1.9	13.2	14.5	26.1	635,284.5	0.00	1.00
07/28/2020 03:00	2	1.9	13.0	14.5	25.9	635,070.6	0.00	1.00
07/28/2020 04:00	2	1.8	13.6	14.5	26.7	635,284.5	0.00	1.00
07/28/2020 05:00	2	1.9	13.4	14.5	26.1	635,070.6	0.00	1.00
07/28/2020 06:00	3	1.9	13.1	14.5	26.3	636,568.4	0.00	1.00
07/28/2020 07:00	3	1.9	13.7	14.4	29.0	648,053.8	0.00	1.00
07/28/2020 08:00	3	1.9	13.3	14.4	29.2	696,931.7	0.00	1.00
07/28/2020 09:00	1	1.8	9.8	14.5	22.8	916,230.5	0.00	1.00
07/28/2020 10:00	2	2.2	13.7	13.0	34.4	931,728.6	0.00	1.00
07/28/2020 11:00	3	2.4	15.6	12.6	38.0	934,838.4	0.00	1.00
07/28/2020 12:00	3	2.4	15.8	12.5	38.2	932,023.7	0.00	1.00
07/28/2020 13:00	4	2.7	16.8	11.7	46.6	932,250.5	0.00	1.00
07/28/2020 14:00	3	2.6	16.1	12.0	42.6	927,515.8	0.00	1.00
07/28/2020 15:00	3	2.5	15.8	12.2	40.8	925,069.8	0.00	1.00
07/28/2020 16:00	3	2.5	15.5	12.3	39.3	914,807.3	0.00	1.00
07/28/2020 17:00	3	2.4	15.5	12.4	39.1	918,964.3	0.00	1.00
07/28/2020 18:00	2	2.2	12.5	13.5	29.4	915,293.6	0.00	1.00
07/28/2020 19:00	2	2.1	12.2	13.6	28.7	915,826.0	0.00	1.00
07/28/2020 20:00	2	2.2	12.9	13.3	31.9	923,820.9	0.00	1.00
07/28/2020 21:00	2	1.9	12.4	14.3	28.5	738,866.7	0.00	1.00
07/28/2020 22:00	2	1.9	13.2	14.5	26.8	655,184.0	0.00	1.00
07/28/2020 23:00	3	1.9	13.3	14.4	29.6	705,148.2	0.00	1.00
Average/Sum#:	3	2.1	13.8	13.6	31.6	790,867.9	0.00 #	24.00 #
Minimum:	1	1.8	9.8	11.7	22.8	634,856.6	0.00	1.00
Maximum:	4	2.7	16.8	14.5	46.6	934,838.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/29/2020 00:00	2	1.8	13.3	14.5	26.4	636,354.4	0.00	1.00
07/29/2020 01:00	3	1.9	13.2	14.5	26.2	635,070.6	0.00	1.00
07/29/2020 02:00	2	1.9	13.1	14.5	25.6	634,000.7	0.00	1.00
07/29/2020 03:00	2	1.9	13.0	14.5	25.6	634,642.6	0.00	1.00
07/29/2020 04:00	2	1.9	13.5	14.5	26.2	634,214.7	0.00	1.00
07/29/2020 05:00	2	1.9	13.2	14.5	25.9	634,642.6	0.00	1.00
07/29/2020 06:00	3	1.9	13.1	14.5	26.1	636,568.4	0.00	1.00
07/29/2020 07:00	3	1.9	13.1	14.5	26.3	638,280.1	0.00	1.00
07/29/2020 08:00	3	1.9	13.3	14.5	27.8	652,830.3	0.00	1.00
07/29/2020 09:00	3	1.9	13.7	14.4	29.6	673,756.8	0.00	1.00
07/29/2020 10:00	2	1.8	0.0	14.4	23.4	876,853.0	0.00	1.00
07/29/2020 11:00	2	2.1	11.9	13.7	28.8	932,540.0	0.00	1.00
07/29/2020 12:00	3	2.4	16.0	12.3	41.9	941,240.4	0.00	1.00
07/29/2020 13:00	4	2.6	17.2	11.9	48.4	949,619.7	0.00	1.00
07/29/2020 14:00	4	2.6	17.2	11.8	48.5	939,786.3	0.00	1.00
07/29/2020 15:00	4	2.6	17.2	11.8	49.3	937,980.5	0.00	1.00
07/29/2020 16:00	4	2.6	17.2	11.8	50.0	939,184.3	0.00	1.00
07/29/2020 17:00	4	2.6	17.3	11.8	49.9	936,927.1	0.00	1.00
07/29/2020 18:00	4	2.6	17.0	11.9	48.4	938,055.7	0.00	1.00
07/29/2020 19:00	2	2.0	11.0	14.0	26.7	911,361.9	0.00	1.00
07/29/2020 20:00	3	2.2	14.7	12.9	36.2	928,812.1	0.00	1.00
07/29/2020 21:00	3	1.9	0.0	14.4	30.5	734,011.5	0.00	1.00
07/29/2020 22:00	2	1.9	12.9	14.5	30.8	765,165.9	0.00	1.00
07/29/2020 23:00	3	1.9	13.9	14.4	29.3	655,848.9	0.00	1.00
Average/Sum#:	3	2.1	14.4	13.6	33.7	783,239.5	0.00 #	24.00 #
Minimum:	2	1.8	11.0	11.8	23.4	634,000.7	0.00	1.00
Maximum:	4	2.6	17.3	14.5	50.0	949,619.7	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/30/2020 00:00	2	1.8	13.2	14.5	25.6	635,284.5	0.00	1.00
07/30/2020 01:00	2	1.9	13.2	14.5	26.0	635,712.5	0.00	1.00
07/30/2020 02:00	2	1.9	13.0	14.5	25.6	636,140.4	0.00	1.00
07/30/2020 03:00	2	1.9	13.0	14.5	25.8	636,354.4	0.00	1.00
07/30/2020 04:00	0	1.8	13.5	0.0	28.0	194,799.0	0.00	1.00
07/30/2020 05:00	0	1.6	13.5	0.0	28.7	195,061.1	0.00	1.00
07/30/2020 06:00	2	1.8	14.1	14.5	28.3	638,494.1	0.00	1.00
07/30/2020 07:00	2	1.9	13.3	14.5	25.2	639,350.0	0.00	1.00
07/30/2020 08:00	2	1.9	13.1	14.5	25.8	637,424.3	0.00	1.00
07/30/2020 09:00	3	1.9	13.3	14.5	27.9	665,240.7	0.00	1.00
07/30/2020 10:00	2	1.8	12.4	14.6	30.8	821,002.5	0.00	1.00
07/30/2020 11:00	2	2.2	13.1	13.2	30.6	923,561.1	0.00	1.00
07/30/2020 12:00	2	2.1	12.2	13.6	29.1	933,459.7	0.00	1.00
07/30/2020 13:00	2	2.3	14.1	13.0	34.5	937,969.0	0.00	1.00
07/30/2020 14:00	3	2.5	16.5	12.4	42.5	948,608.3	0.00	1.00
07/30/2020 15:00	3	2.5	16.8	12.2	44.2	942,226.9	0.00	1.00
07/30/2020 16:00	4	2.6	17.3	11.8	48.1	938,281.4	0.00	1.00
07/30/2020 17:00	4	2.6	17.2	11.8	48.1	937,378.5	0.00	1.00
07/30/2020 18:00	3	2.5	16.4	12.3	43.1	941,718.1	0.00	1.00
07/30/2020 19:00	2	2.3	14.7	12.9	36.0	933,262.7	0.00	1.00
07/30/2020 20:00	2	2.2	13.7	13.1	34.3	933,315.4	0.00	1.00
07/30/2020 21:00	2	1.9	9.9	14.5	24.2	884,776.5	0.00	1.00
07/30/2020 22:00	2	1.9	11.5	14.5	29.8	835,990.8	0.00	1.00
07/30/2020 23:00	3	1.9	14.2	14.4	30.0	660,905.3	0.00	1.00
Average/Sum#:	2	2.1	13.9	13.7	32.2	804,384.4	0.00 #	24.00 #
Minimum:	2	1.6	9.9	11.8	24.2	635,284.5	0.00	1.00
Maximum:	4	2.6	17.3	14.6	48.1	948,608.3	0.00	1.00
%SI	8.33	0.00	0.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/31/2020 00:00	2	1.8	13.2	14.5	24.8	635,498.5	0.00	1.00
07/31/2020 01:00	2	1.9	13.0	14.5	24.8	636,568.4	0.00	1.00
07/31/2020 02:00	2	1.9	13.2	14.5	25.7	636,354.4	0.00	1.00
07/31/2020 03:00	2	1.9	13.2	14.5	26.0	635,498.5	0.00	1.00
07/31/2020 04:00	2	1.8	14.0	14.5	26.7	635,926.4	0.00	1.00
07/31/2020 05:00	3	1.9	13.7	14.5	27.5	635,926.4	0.00	1.00
07/31/2020 06:00	3	1.9	13.5	14.5	26.8	638,280.1	0.00	1.00
07/31/2020 07:00	2	1.9	13.2	14.5	25.9	639,350.0	0.00	1.00
07/31/2020 08:00	3	1.9	13.2	14.5	26.5	637,210.3	0.00	1.00
07/31/2020 09:00	3	1.9	14.0	14.5	30.2	665,026.7	0.00	1.00
07/31/2020 10:00	2	1.8	12.4	14.5	29.0	786,135.2	0.00	1.00
07/31/2020 11:00	2	2.3	14.9	12.8	35.3	942,028.7	0.00	1.00
07/31/2020 12:00	2	2.2	12.7	13.4	31.8	940,338.1	0.00	1.00
07/31/2020 13:00	3	2.3	14.7	12.9	37.4	949,011.1	0.00	1.00
07/31/2020 14:00	4	2.6	17.6	11.8	48.9	942,344.6	0.00	1.00
07/31/2020 15:00	3	2.3	14.9	12.9	36.6	937,542.2	0.00	1.00
07/31/2020 16:00	3	2.3	14.6	13.0	36.7	935,195.5	0.00	1.00
07/31/2020 17:00	3	2.4	16.6	12.4	43.4	944,419.5	0.00	1.00
07/31/2020 18:00	3	2.4	16.2	12.6	39.5	936,653.3	0.00	1.00
07/31/2020 19:00	3	2.4	15.6	12.7	37.1	936,552.7	0.00	1.00
07/31/2020 20:00	2	2.2	12.1	13.5	29.3	906,410.9	0.00	1.00
07/31/2020 21:00	3	2.0	12.5	14.3	30.1	757,540.7	0.00	1.00
07/31/2020 22:00	3	1.9	13.1	14.4	30.9	746,230.9	0.00	1.00
07/31/2020 23:00	2	1.8	13.4	14.5	26.6	646,625.1	0.00	1.00
Average/Sum#:	3	2.1	14.0	13.8	31.6	779,277.8	0.00 #	24.00 #
Minimum:	2	1.8	12.1	11.8	24.8	635,498.5	0.00	1.00
Maximum:	4	2.6	17.6	14.5	48.9	949,011.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/01/2020 00:00	2	1.9	13.2	14.5	25.3	635,498.5	0.00	1.00
08/01/2020 01:00	2	1.9	13.2	14.5	26.0	635,498.5	0.00	1.00
08/01/2020 02:00	3	1.9	13.2	14.5	26.1	634,856.6	0.00	1.00
08/01/2020 03:00	2	1.9	13.2	14.5	26.2	635,070.6	0.00	1.00
08/01/2020 04:00	2	1.8	13.9	14.5	27.1	634,642.6	0.00	1.00
08/01/2020 05:00	3	1.9	13.6	14.5	27.8	635,712.5	0.00	1.00
08/01/2020 06:00	3	1.9	13.4	14.5	26.8	636,996.3	0.00	1.00
08/01/2020 07:00	2	1.8	13.1	14.5	26.0	638,708.1	0.00	1.00
08/01/2020 08:00	3	1.9	13.2	14.5	27.0	639,136.0	0.00	1.00
08/01/2020 09:00	3	1.9	13.7	14.4	30.6	690,821.9	0.00	1.00
08/01/2020 10:00	3	1.9	13.0	14.5	31.0	758,746.7	0.00	1.00
08/01/2020 11:00	2	1.8	12.9	14.5	30.5	764,310.0	0.00	1.00
08/01/2020 12:00	2	1.8	12.3	14.6	29.9	806,873.5	0.00	1.00
08/01/2020 13:00	1	1.8	9.9	14.6	20.9	856,868.4	0.00	1.00
08/01/2020 14:00	2	1.8	10.5	14.5	23.4	816,305.3	0.00	1.00
08/01/2020 15:00	4	2.6	17.0	11.8	45.6	938,732.9	0.00	1.00
08/01/2020 16:00	4	2.6	17.4	11.9	48.4	942,316.1	0.00	1.00
08/01/2020 17:00	4	2.6	17.5	12.0	48.7	947,826.3	0.00	1.00
08/01/2020 18:00	3	2.5	16.7	12.3	43.1	939,170.4	0.00	1.00
08/01/2020 19:00	3	2.4	15.8	12.7	37.5	934,381.6	0.00	1.00
08/01/2020 20:00	2	2.1	12.0	13.8	27.9	925,036.5	0.00	1.00
08/01/2020 21:00	2	2.0	10.4	14.2	25.5	911,178.2	0.00	1.00
08/01/2020 22:00	3	1.9	12.5	14.4	30.5	775,094.2	0.00	1.00
08/01/2020 23:00	3	1.9	13.7	14.4	29.8	691,032.6	0.00	1.00
Average/Sum#:	3	2.0	13.6	14.0	30.9	767,700.6	0.00 #	24.00 #
Minimum:	1	1.8	9.9	11.8	20.9	634,642.6	0.00	1.00
Maximum:	4	2.6	17.5	14.6	48.7	947,826.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/02/2020 00:00	2	1.8	13.4	14.5	25.9	633,572.8	0.00	1.00
08/02/2020 01:00	3	1.8	13.4	14.5	26.3	632,074.9	0.00	1.00
08/02/2020 02:00	2	1.8	13.3	14.5	25.9	632,074.9	0.00	1.00
08/02/2020 03:00	2	1.8	13.3	14.5	26.1	632,074.9	0.00	1.00
08/02/2020 04:00	2	1.8	13.8	14.5	26.4	634,000.7	0.00	1.00
08/02/2020 05:00	3	1.9	14.5	14.3	32.1	656,908.7	0.00	1.00
08/02/2020 06:00	3	1.9	14.2	14.4	29.8	659,009.1	0.00	1.00
08/02/2020 07:00	3	1.9	13.9	14.4	29.0	646,368.3	0.00	1.00
08/02/2020 08:00	3	1.8	13.2	14.5	26.2	633,144.8	0.00	1.00
08/02/2020 09:00	3	1.8	13.4	14.5	27.3	633,572.8	0.00	1.00
08/02/2020 10:00	3	1.8	13.6	14.6	28.2	644,064.2	0.00	1.00
08/02/2020 11:00	2	1.8	13.0	14.6	31.1	771,442.4	0.00	1.00
08/02/2020 12:00	1	1.8	10.4	14.5	23.2	839,628.3	0.00	1.00
08/02/2020 13:00	2	2.3	14.7	12.7	33.7	928,369.5	0.00	1.00
08/02/2020 14:00	2	2.4	14.7	12.7	35.0	924,194.5	0.00	1.00
08/02/2020 15:00	4	2.6	17.1	11.8	46.9	933,766.8	0.00	1.00
08/02/2020 16:00	3	2.4	15.6	12.5	38.5	927,948.0	0.00	1.00
08/02/2020 17:00	4	2.6	16.5	12.0	44.0	930,131.5	0.00	1.00
08/02/2020 18:00	3	2.4	15.3	12.6	37.2	922,629.1	0.00	1.00
08/02/2020 19:00	3	2.3	15.1	12.8	35.8	928,334.5	0.00	1.00
08/02/2020 20:00	2	2.2	13.3	13.2	31.7	922,494.1	0.00	1.00
08/02/2020 21:00	2	1.9	11.1	14.4	28.3	840,615.9	0.00	1.00
08/02/2020 22:00	3	1.8	14.0	14.4	32.2	686,819.0	0.00	1.00
08/02/2020 23:00	3	1.8	13.1	14.5	31.9	776,934.4	0.00	1.00
Average/Sum#:	3	2.0	13.9	13.8	31.4	765,423.9	0.00 #	24.00 #
Minimum:	1	1.8	10.4	11.8	23.2	632,074.9	0.00	1.00
Maximum:	4	2.6	17.1	14.6	46.9	933,766.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/03/2020 00:00	2	1.8	13.5	14.5	26.6	638,708.1	0.00	1.00
08/03/2020 01:00	2	1.8	13.5	14.5	26.5	633,572.8	0.00	1.00
08/03/2020 02:00	2	1.8	13.3	14.5	26.1	633,572.8	0.00	1.00
08/03/2020 03:00	2	1.8	13.2	14.5	25.8	633,358.8	0.00	1.00
08/03/2020 04:00	2	1.8	13.6	14.5	25.8	632,716.9	0.00	1.00
08/03/2020 05:00	3	1.9	13.3	14.5	26.8	634,428.6	0.00	1.00
08/03/2020 06:00	3	1.9	13.2	14.5	26.3	636,140.4	0.00	1.00
08/03/2020 07:00	3	1.8	13.4	14.5	27.9	639,136.0	0.00	1.00
08/03/2020 08:00	3	1.9	14.1	14.5	29.9	655,184.0	0.00	1.00
08/03/2020 09:00	3	1.8	14.0	14.6	28.9	648,628.9	0.00	1.00
08/03/2020 10:00	1	1.8	10.2	14.5	22.1	857,602.0	0.00	1.00
08/03/2020 11:00	1	1.9	9.5	14.5	22.9	923,077.6	0.00	1.00
08/03/2020 12:00	2	2.1	12.5	13.4	30.6	931,756.4	0.00	1.00
08/03/2020 13:00	2	2.2	13.3	13.3	32.8	943,461.3	0.00	1.00
08/03/2020 14:00	4	2.6	17.2	11.9	45.3	938,207.9	0.00	1.00
08/03/2020 15:00	3	2.5	16.5	12.1	43.1	931,675.4	0.00	1.00
08/03/2020 16:00	3	2.5	16.4	12.2	42.9	936,560.4	0.00	1.00
08/03/2020 17:00	3	2.5	16.4	12.1	43.0	931,675.4	0.00	1.00
08/03/2020 18:00	4	2.6	16.8	11.7	46.9	929,422.4	0.00	1.00
08/03/2020 19:00	2	2.3	13.6	13.1	32.1	922,254.7	0.00	1.00
08/03/2020 20:00	2	1.9	12.0	14.4	28.5	769,195.1	0.00	1.00
08/03/2020 21:00	2	1.9	12.0	14.5	30.5	819,942.8	0.00	1.00
08/03/2020 22:00	3	1.9	13.8	14.4	28.7	655,006.2	0.00	1.00
08/03/2020 23:00	2	1.9	13.2	14.4	28.1	698,195.8	0.00	1.00
Average/Sum#:	2	2.0	13.7	13.8	31.2	773,895.0	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.7	22.1	632,716.9	0.00	1.00
Maximum:	4	2.6	17.2	14.6	46.9	943,461.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/04/2020 00:00	2	1.9	12.9	14.5	24.9	634,214.7	0.00	1.00
08/04/2020 01:00	2	1.9	12.9	14.5	24.9	634,000.7	0.00	1.00
08/04/2020 02:00	2	1.9	12.8	14.5	24.7	633,358.8	0.00	1.00
08/04/2020 03:00	2	1.9	12.7	14.5	24.4	632,930.8	0.00	1.00
08/04/2020 04:00	2	1.8	13.4	14.5	25.3	633,358.8	0.00	1.00
08/04/2020 05:00	2	1.9	13.3	14.5	26.3	634,214.7	0.00	1.00
08/04/2020 06:00	2	1.9	13.0	14.5	25.2	635,070.6	0.00	1.00
08/04/2020 07:00	2	1.9	12.8	14.5	24.7	637,424.3	0.00	1.00
08/04/2020 08:00	3	1.9	13.6	14.3	29.7	666,245.7	0.00	1.00
08/04/2020 09:00	2	1.9	12.5	14.4	28.5	747,705.7	0.00	1.00
08/04/2020 10:00	2	1.9	12.4	14.4	29.2	750,865.9	0.00	1.00
08/04/2020 11:00	1	1.8	9.5	14.5	21.4	912,165.0	0.00	1.00
08/04/2020 12:00	2	2.2	12.7	13.2	30.4	935,476.9	0.00	1.00
08/04/2020 13:00	2	2.2	12.3	13.3	29.8	923,640.7	0.00	1.00
08/04/2020 14:00	3	2.5	15.8	12.3	39.1	936,304.1	0.00	1.00
08/04/2020 15:00	4	2.7	16.7	11.7	46.2	930,166.6	0.00	1.00
08/04/2020 16:00	4	2.6	16.7	11.7	47.0	927,636.2	0.00	1.00
08/04/2020 17:00	4	2.6	16.5	11.7	46.0	929,124.7	0.00	1.00
08/04/2020 18:00	4	2.6	16.2	11.9	44.1	932,121.5	0.00	1.00
08/04/2020 19:00	1	2.0	10.1	14.1	23.6	893,750.8	0.00	1.00
08/04/2020 20:00	3	1.9	12.0	14.4	30.6	797,426.4	0.00	1.00
08/04/2020 21:00	2	1.9	12.6	14.5	24.2	636,782.3	0.00	1.00
08/04/2020 22:00	2	1.9	12.8	14.5	24.9	635,070.6	0.00	1.00
08/04/2020 23:00	3	1.9	13.6	14.3	29.4	659,398.6	0.00	1.00
Average/Sum#:	2	2.1	13.3	13.8	30.2	762,019.0	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.7	21.4	632,930.8	0.00	1.00
Maximum:	4	2.7	16.7	14.5	47.0	936,304.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/05/2020 00:00	2	1.9	12.6	14.5	23.9	633,358.8	0.00	1.00
08/05/2020 01:00	2	1.9	12.6	14.5	24.5	633,144.8	0.00	1.00
08/05/2020 02:00	2	1.9	12.6	14.5	24.6	633,144.8	0.00	1.00
08/05/2020 03:00	2	1.9	12.8	14.5	25.0	632,930.8	0.00	1.00
08/05/2020 04:00	2	1.8	13.4	14.5	25.5	632,930.8	0.00	1.00
08/05/2020 05:00	3	1.9	13.2	14.5	26.4	632,930.8	0.00	1.00
08/05/2020 06:00	2	1.9	13.1	14.5	25.7	634,428.6	0.00	1.00
08/05/2020 07:00	2	1.9	13.0	14.5	25.6	634,428.6	0.00	1.00
08/05/2020 08:00	2	1.9	12.7	14.5	25.2	634,214.7	0.00	1.00
08/05/2020 09:00	2	1.9	12.8	14.5	25.7	640,419.9	0.00	1.00
08/05/2020 10:00	3	1.9	13.3	14.3	28.1	661,058.5	0.00	1.00
08/05/2020 11:00	1	1.8	10.0	14.4	22.7	871,586.0	0.00	1.00
08/05/2020 12:00	2	2.1	12.0	13.5	29.0	937,315.5	0.00	1.00
08/05/2020 13:00	2	2.2	12.9	13.2	32.3	942,235.1	0.00	1.00
08/05/2020 14:00	2	2.3	13.8	13.0	33.9	942,476.0	0.00	1.00
08/05/2020 15:00	2	2.3	14.3	12.9	35.1	940,109.8	0.00	1.00
08/05/2020 16:00	2	2.3	13.7	13.0	33.9	929,301.8	0.00	1.00
08/05/2020 17:00	2	2.1	11.5	13.7	28.3	931,208.6	0.00	1.00
08/05/2020 18:00	2	2.2	12.9	13.3	32.1	921,118.1	0.00	1.00
08/05/2020 19:00	3	2.0	13.1	14.3	29.7	695,916.6	0.00	1.00
08/05/2020 20:00	3	1.9	13.1	14.3	29.2	702,141.2	0.00	1.00
08/05/2020 21:00	3	1.9	13.7	14.3	29.5	668,735.6	0.00	1.00
08/05/2020 22:00	2	1.9	12.5	14.3	27.3	737,206.8	0.05	1.00
08/05/2020 23:00	0	10.7	36.9	15.9	0.0	478,203.0	0.10	0.10
Average/Sum#:	2	2.4	13.9	14.1	26.8	737,522.7	0.15 #	23.10 #
Minimum:	1	1.8	10.0	12.9	0.0	478,203.0	0.00	0.10
Maximum:	3	10.7	36.9	15.9	35.1	942,476.0	0.10	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 22:00	0	23.4	27.4	17.5	0.0	675,045.7	0.27	0.27
08/08/2020 23:00	3	4.1	14.7	14.4	20.6	702,409.4	0.65	1.00
Average/Sum#:	3	13.8	21.1	16.0	10.3	688,727.6	0.92 #	1.27 #
Minimum:	3	4.1	14.7	14.4	0.0	675,045.7	0.00	0.00
Maximum:	3	23.4	27.4	17.5	20.6	702,409.4	0.65	1.00
%SI	95.83	91.67	91.67	91.67	91.67	91.67	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/09/2020 00:00	2	1.9	13.5	14.5	25.3	633,786.7	0.00	1.00
08/09/2020 01:00	2	1.9	13.3	14.5	25.1	632,930.8	0.00	1.00
08/09/2020 02:00	2	1.9	13.2	14.5	25.1	633,144.8	0.00	1.00
08/09/2020 03:00	2	1.8	13.3	14.5	25.9	633,144.8	0.00	1.00
08/09/2020 04:00	2	1.8	13.6	14.5	25.8	633,144.8	0.00	1.00
08/09/2020 05:00	2	1.9	13.1	14.5	24.7	633,786.7	0.00	1.00
08/09/2020 06:00	2	1.9	12.9	14.5	25.0	633,572.8	0.00	1.00
08/09/2020 07:00	3	1.9	13.1	14.5	26.4	639,564.0	0.00	1.00
08/09/2020 08:00	2	1.9	13.0	14.4	27.1	686,608.3	0.00	1.00
08/09/2020 09:00	1	1.8	10.1	14.5	23.5	869,370.5	0.00	1.00
08/09/2020 10:00	2	2.2	13.3	13.1	31.8	919,270.0	0.00	1.00
08/09/2020 11:00	3	2.4	15.5	12.5	37.3	928,437.1	0.00	1.00
08/09/2020 12:00	4	2.6	16.7	11.8	44.8	928,198.9	0.00	1.00
08/09/2020 13:00	4	2.7	16.8	11.7	46.5	927,933.9	0.00	1.00
08/09/2020 14:00	4	2.7	17.0	11.7	47.3	929,720.1	0.00	1.00
08/09/2020 15:00	4	2.6	16.9	11.7	47.1	921,086.7	0.00	1.00
08/09/2020 16:00	4	2.6	16.5	11.9	44.8	917,514.3	0.00	1.00
08/09/2020 17:00	4	2.7	16.9	11.7	47.3	920,937.9	0.00	1.00
08/09/2020 18:00	3	2.4	14.3	12.7	37.4	913,172.3	0.00	1.00
08/09/2020 19:00	4	2.6	17.2	11.8	48.1	934,970.7	0.00	1.00
08/09/2020 20:00	3	2.5	16.0	12.3	40.6	915,762.7	0.00	1.00
08/09/2020 21:00	2	2.2	13.3	13.2	32.7	918,225.7	0.00	1.00
08/09/2020 22:00	2	2.2	12.5	13.5	30.3	905,485.6	0.00	1.00
08/09/2020 23:00	3	1.9	13.1	14.4	31.5	738,014.4	0.00	1.00
Average/Sum#:	3	2.2	14.4	13.3	34.2	806,157.7	0.00 #	24.00 #
Minimum:	1	1.8	10.1	11.7	23.5	632,930.8	0.00	1.00
Maximum:	4	2.7	17.2	14.5	48.1	934,970.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/10/2020 00:00	3	1.9	14.1	14.4	31.6	667,857.7	0.00	1.00
08/10/2020 01:00	3	1.8	14.0	14.5	28.3	635,712.5	0.00	1.00
08/10/2020 02:00	3	1.8	13.8	14.5	28.1	632,502.9	0.00	1.00
08/10/2020 03:00	3	1.8	13.7	14.5	27.7	634,214.7	0.00	1.00
08/10/2020 04:00	2	1.8	14.4	14.5	29.3	641,917.7	0.00	1.00
08/10/2020 05:00	3	1.9	13.7	14.5	26.7	631,861.0	0.00	1.00
08/10/2020 06:00	3	1.8	13.6	14.5	27.6	633,144.8	0.00	1.00
08/10/2020 07:00	3	1.9	14.2	14.5	30.4	652,616.3	0.00	1.00
08/10/2020 08:00	2	1.9	13.2	14.5	30.0	734,567.8	0.00	1.00
08/10/2020 09:00	1	1.8	10.2	14.5	23.0	869,584.5	0.00	1.00
08/10/2020 10:00	2	2.2	13.2	13.2	32.4	924,983.9	0.00	1.00
08/10/2020 11:00	3	2.5	16.1	12.3	40.6	936,463.3	0.00	1.00
08/10/2020 12:00	4	2.7	16.7	11.7	46.3	928,975.8	0.00	1.00
08/10/2020 13:00	4	2.7	16.6	11.6	46.6	920,312.1	0.00	1.00
08/10/2020 14:00	4	2.7	16.7	11.6	46.9	917,661.6	0.00	1.00
08/10/2020 15:00	4	2.7	16.6	11.6	46.4	910,593.6	0.00	1.00
08/10/2020 16:00	4	2.7	16.6	11.7	46.4	917,216.6	0.00	1.00
08/10/2020 17:00	4	2.6	16.3	11.8	45.0	916,761.9	0.00	1.00
08/10/2020 18:00	2	2.2	12.9	13.2	30.5	891,370.8	0.00	1.00
08/10/2020 19:00	2	1.9	11.9	14.5	30.5	820,370.8	0.00	1.00
08/10/2020 20:00	2	1.8	12.6	14.5	32.4	803,253.0	0.00	1.00
08/10/2020 21:00	2	1.8	11.8	14.5	29.3	831,283.4	0.00	1.00
08/10/2020 22:00	3	1.9	13.1	14.5	33.7	793,196.3	0.00	1.00
08/10/2020 23:00	3	1.9	12.9	14.4	30.4	752,551.4	0.00	1.00
Average/Sum#:	3	2.1	14.1	13.6	34.2	791,623.9	0.00 #	24.00 #
Minimum:	1	1.8	10.2	11.6	23.0	631,861.0	0.00	1.00
Maximum:	4	2.7	16.7	14.5	46.9	936,463.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/11/2020 00:00	2	1.8	12.9	14.5	25.0	634,000.7	0.00	1.00
08/11/2020 01:00	2	1.9	12.9	14.5	25.0	634,642.6	0.00	1.00
08/11/2020 02:00	2	1.9	12.9	14.5	24.8	634,642.6	0.00	1.00
08/11/2020 03:00	2	1.9	12.8	14.4	24.7	624,668.2	0.00	1.00
08/11/2020 04:00	2	1.8	13.6	14.5	25.8	634,428.6	0.00	1.00
08/11/2020 05:00	2	1.9	13.2	14.4	25.3	624,668.2	0.00	1.00
08/11/2020 06:00	3	1.9	13.1	14.5	26.0	635,712.5	0.00	1.00
08/11/2020 07:00	2	1.9	13.0	14.5	25.8	638,922.1	0.00	1.00
08/11/2020 08:00	3	1.9	13.7	14.3	29.8	665,830.7	0.00	1.00
08/11/2020 09:00	3	1.9	13.0	14.3	28.6	697,161.5	0.00	1.00
08/11/2020 10:00	2	1.8	11.1	14.4	26.9	841,880.0	0.00	1.00
08/11/2020 11:00	2	1.9	10.4	14.1	25.9	916,104.6	0.00	1.00
08/11/2020 12:00	2	2.2	14.0	13.0	34.2	934,155.4	0.00	1.00
08/11/2020 13:00	2	2.2	12.5	13.4	30.6	923,174.6	0.00	1.00
08/11/2020 14:00	2	2.1	12.2	13.5	30.3	918,439.6	0.00	1.00
08/11/2020 15:00	2	2.2	12.7	13.4	31.5	920,435.8	0.00	1.00
08/11/2020 16:00	2	2.2	12.8	13.3	31.4	911,207.8	0.00	1.00
08/11/2020 17:00	2	2.1	12.0	13.6	29.7	915,075.6	0.00	1.00
08/11/2020 18:00	2	2.1	11.7	13.7	29.4	913,900.6	0.00	1.00
08/11/2020 19:00	2	1.9	10.8	14.5	28.2	850,968.9	0.00	1.00
08/11/2020 20:00	2	1.8	11.7	14.5	30.8	831,069.4	0.00	1.00
08/11/2020 21:00	1	1.8	9.6	14.5	23.5	905,531.9	0.00	1.00
08/11/2020 22:00	3	1.9	13.0	14.4	31.4	735,907.6	0.00	1.00
08/11/2020 23:00	3	1.9	13.7	14.4	28.0	644,472.2	0.00	1.00
Average/Sum#:	2	2.0	12.5	14.1	28.0	774,458.4	0.00 #	24.00 #
Minimum:	1	1.8	9.6	13.0	23.5	624,668.2	0.00	1.00
Maximum:	3	2.2	14.0	14.5	34.2	934,155.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/12/2020 00:00	2	1.9	13.0	14.5	25.2	632,074.9	0.00	1.00
08/12/2020 01:00	3	1.9	13.0	14.5	26.2	632,502.9	0.00	1.00
08/12/2020 02:00	2	1.9	13.0	14.5	25.6	633,786.7	0.00	1.00
08/12/2020 03:00	2	1.9	13.0	14.5	25.7	634,214.7	0.00	1.00
08/12/2020 04:00	2	1.8	13.6	14.5	26.2	633,358.8	0.00	1.00
08/12/2020 05:00	2	1.9	13.3	14.5	26.1	633,358.8	0.00	1.00
08/12/2020 06:00	3	1.9	13.2	14.5	26.2	636,140.4	0.00	1.00
08/12/2020 07:00	2	1.9	12.8	14.4	25.3	631,620.7	0.00	1.00
08/12/2020 08:00	2	1.9	12.8	14.5	25.6	637,638.2	0.00	1.00
08/12/2020 09:00	3	1.9	13.1	14.4	28.6	686,187.0	0.00	1.00
08/12/2020 10:00	2	1.8	11.9	14.4	28.5	799,533.2	0.00	1.00
08/12/2020 11:00	2	2.3	14.6	12.9	34.5	938,740.4	0.00	1.00
08/12/2020 12:00	3	2.6	16.5	12.1	43.0	939,923.1	0.00	1.00
08/12/2020 13:00	4	2.6	16.8	11.8	46.2	929,553.2	0.00	1.00
08/12/2020 14:00	4	2.6	16.9	11.8	47.3	929,252.3	0.00	1.00
08/12/2020 15:00	4	2.6	16.9	11.8	47.8	928,800.8	0.00	1.00
08/12/2020 16:00	4	2.6	17.0	11.8	48.5	927,446.4	0.00	1.00
08/12/2020 17:00	4	2.6	17.0	11.8	48.5	927,897.9	0.00	1.00
08/12/2020 18:00	4	2.6	16.9	11.9	47.7	932,425.8	0.00	1.00
08/12/2020 19:00	3	2.4	15.9	12.5	40.2	920,122.8	0.00	1.00
08/12/2020 20:00	2	2.1	12.5	13.6	30.0	916,013.6	0.00	1.00
08/12/2020 21:00	2	2.1	12.3	13.6	31.2	928,582.3	0.00	1.00
08/12/2020 22:00	2	2.0	10.6	14.2	27.4	921,397.8	0.00	1.00
08/12/2020 23:00	2	1.9	11.5	14.5	30.5	843,265.9	0.00	1.00
Average/Sum#:	3	2.2	14.1	13.5	33.8	798,909.9	0.00 #	24.00 #
Minimum:	2	1.8	10.6	11.8	25.2	631,620.7	0.00	1.00
Maximum:	4	2.6	17.0	14.5	48.5	939,923.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/13/2020 00:00	3	1.9	14.3	14.4	31.6	661,748.0	0.00	1.00
08/13/2020 01:00	3	1.8	13.7	14.5	28.0	632,288.9	0.00	1.00
08/13/2020 02:00	3	1.8	13.7	14.5	27.3	633,572.8	0.00	1.00
08/13/2020 03:00	3	1.8	13.9	14.5	28.3	632,930.8	0.00	1.00
08/13/2020 04:00	3	1.8	14.5	14.5	29.4	632,074.9	0.00	1.00
08/13/2020 05:00	3	1.8	14.0	14.5	28.2	632,288.9	0.00	1.00
08/13/2020 06:00	3	1.9	14.2	14.5	30.8	653,686.2	0.00	1.00
08/13/2020 07:00	3	1.8	14.2	14.5	30.0	648,978.8	0.00	1.00
08/13/2020 08:00	3	1.9	14.1	14.5	30.9	675,511.4	0.00	1.00
08/13/2020 09:00	2	1.8	11.9	14.6	27.4	799,048.3	0.00	1.00
08/13/2020 10:00	2	2.0	11.4	13.9	26.9	903,037.6	0.00	1.00
08/13/2020 11:00	3	2.5	16.3	12.2	40.7	933,097.4	0.00	1.00
08/13/2020 12:00	4	2.6	16.8	11.9	45.7	929,078.4	0.00	1.00
08/13/2020 13:00	4	2.6	16.8	11.9	46.1	933,034.5	0.00	1.00
08/13/2020 14:00	4	2.6	16.9	11.8	46.8	922,480.4	0.00	1.00
08/13/2020 15:00	3	2.5	16.3	12.2	42.6	917,514.3	0.00	1.00
08/13/2020 16:00	3	2.4	15.9	12.4	40.2	918,158.8	0.00	1.00
08/13/2020 17:00	4	2.6	16.7	12.0	46.0	929,516.0	0.00	1.00
08/13/2020 18:00	3	2.4	15.3	12.6	37.9	918,999.3	0.00	1.00
08/13/2020 19:00	2	2.1	11.8	13.8	27.6	914,235.4	0.00	1.00
08/13/2020 20:00	2	2.0	10.5	14.3	26.6	920,626.7	0.00	1.00
08/13/2020 21:00	3	2.4	16.5	12.4	42.9	936,364.1	0.00	1.00
08/13/2020 22:00	3	2.5	16.8	12.3	43.6	936,304.1	0.00	1.00
08/13/2020 23:00	3	2.0	13.4	14.4	33.9	790,684.6	0.00	1.00
Average/Sum#:	3	2.1	14.6	13.5	35.0	808,552.5	0.00 #	24.00 #
Minimum:	2	1.8	10.5	11.8	26.6	632,074.9	0.00	1.00
Maximum:	4	2.6	16.9	14.6	46.8	936,364.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/14/2020 00:00	3	1.8	14.1	14.5	28.8	649,406.7	0.00	1.00
08/14/2020 01:00	3	1.9	14.0	14.5	29.1	635,712.5	0.00	1.00
08/14/2020 02:00	3	1.8	13.5	14.5	26.8	634,000.7	0.00	1.00
08/14/2020 03:00	3	1.8	13.4	14.5	26.9	633,358.8	0.00	1.00
08/14/2020 04:00	3	1.8	14.5	14.4	30.0	649,107.2	0.00	1.00
08/14/2020 05:00	2	1.9	13.2	14.4	28.8	722,424.0	0.00	1.00
08/14/2020 06:00	2	1.8	10.7	14.6	26.4	884,256.9	0.00	1.00
08/14/2020 07:00	2	2.0	11.4	13.9	28.1	930,034.8	0.00	1.00
08/14/2020 08:00	4	2.5	16.8	12.0	45.1	938,902.0	0.00	1.00
08/14/2020 09:00	4	2.6	17.2	11.9	47.4	939,729.4	0.00	1.00
08/14/2020 10:00	4	2.6	17.2	11.8	47.7	932,111.5	0.00	1.00
08/14/2020 11:00	3	2.4	15.5	12.4	39.9	919,125.4	0.00	1.00
08/14/2020 12:00	2	2.3	14.2	13.0	34.8	931,208.6	0.00	1.00
08/14/2020 13:00	2	2.3	14.5	12.8	35.0	914,809.3	0.00	1.00
08/14/2020 14:00	2	2.3	14.3	12.9	34.6	921,793.8	0.00	1.00
08/14/2020 15:00	4	2.6	17.1	11.8	47.0	926,844.5	0.00	1.00
08/14/2020 16:00	4	2.7	17.1	11.7	47.9	922,128.7	0.00	1.00
08/14/2020 17:00	4	2.6	16.7	11.8	46.3	919,470.7	0.00	1.00
08/14/2020 18:00	4	2.6	16.2	12.0	43.1	921,514.9	0.00	1.00
08/14/2020 19:00	4	2.6	16.5	11.8	45.8	924,135.7	0.00	1.00
08/14/2020 20:00	3	2.5	15.4	12.3	38.8	913,692.7	0.00	1.00
08/14/2020 21:00	2	2.2	12.7	13.3	30.0	918,054.9	0.00	1.00
08/14/2020 22:00	2	2.3	13.6	13.0	32.2	910,060.5	0.00	1.00
08/14/2020 23:00	2	2.0	12.1	14.2	25.2	718,436.8	0.00	1.00
Average/Sum#:	3	2.2	14.7	13.1	36.1	846,263.4	0.00 #	24.00 #
Minimum:	2	1.8	10.7	11.7	25.2	633,358.8	0.00	1.00
Maximum:	4	2.7	17.2	14.6	47.9	939,729.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/15/2020 00:00	3	1.9	13.1	14.3	26.5	652,344.0	0.00	1.00
08/15/2020 01:00	2	1.9	12.7	14.3	25.6	675,790.2	0.00	1.00
08/15/2020 02:00	2	1.9	12.3	14.4	22.4	634,148.8	0.00	1.00
08/15/2020 03:00	2	1.9	11.9	14.4	21.7	626,775.0	0.00	1.00
08/15/2020 04:00	2	1.8	12.5	14.4	22.3	626,564.3	0.00	1.00
08/15/2020 05:00	2	1.9	12.4	14.4	23.4	626,775.0	0.00	1.00
08/15/2020 06:00	2	1.9	12.0	14.3	26.0	733,679.5	0.00	1.00
08/15/2020 07:00	1	1.8	10.2	14.5	23.3	857,388.0	0.00	1.00
08/15/2020 08:00	3	2.4	15.3	12.5	37.9	925,665.7	0.00	1.00
08/15/2020 09:00	4	2.7	16.9	11.7	46.7	924,212.6	0.00	1.00
08/15/2020 10:00	4	2.7	16.7	11.7	47.1	922,128.7	0.00	1.00
08/15/2020 11:00	4	2.7	16.5	11.7	46.0	919,151.7	0.00	1.00
08/15/2020 12:00	3	2.4	14.9	12.4	37.1	907,042.3	0.00	1.00
08/15/2020 13:00	2	2.3	13.9	12.8	32.8	906,356.1	0.00	1.00
08/15/2020 14:00	4	2.6	16.2	11.9	42.7	910,210.7	0.00	1.00
08/15/2020 15:00	3	2.4	14.7	12.6	34.4	902,005.2	0.00	1.00
08/15/2020 16:00	3	2.5	15.8	12.3	39.5	911,941.1	0.00	1.00
08/15/2020 17:00	3	2.5	16.1	12.2	42.0	917,829.1	0.00	1.00
08/15/2020 18:00	3	2.5	16.2	12.2	42.9	920,662.4	0.00	1.00
08/15/2020 19:00	4	2.6	17.4	11.7	49.8	921,086.7	0.00	1.00
08/15/2020 20:00	4	2.6	17.2	11.9	48.3	923,752.8	0.00	1.00
08/15/2020 21:00	4	2.6	17.0	12.1	45.8	932,297.9	0.00	1.00
08/15/2020 22:00	4	2.6	17.1	11.9	46.3	929,382.7	0.00	1.00
08/15/2020 23:00	2	2.1	11.8	13.6	27.4	891,626.6	0.00	1.00
Average/Sum#:	3	2.3	14.6	12.9	35.7	837,450.7	0.00 #	24.00 #
Minimum:	1	1.8	10.2	11.7	21.7	626,564.3	0.00	1.00
Maximum:	4	2.7	17.4	14.5	49.8	932,297.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/16/2020 00:00	2	1.8	11.5	14.5	27.6	792,554.4	0.00	1.00
08/16/2020 01:00	2	1.9	11.4	14.5	26.1	772,654.9	0.00	1.00
08/16/2020 02:00	2	1.9	12.4	14.4	26.9	711,679.3	0.00	1.00
08/16/2020 03:00	2	1.9	13.2	14.4	27.1	663,433.4	0.00	1.00
08/16/2020 04:00	3	1.8	14.4	14.5	28.8	652,188.4	0.00	1.00
08/16/2020 05:00	3	1.9	13.2	14.4	29.7	721,159.9	0.00	1.00
08/16/2020 06:00	2	1.8	12.9	14.5	31.1	764,737.9	0.00	1.00
08/16/2020 07:00	2	1.9	12.0	14.4	28.1	796,162.3	0.00	1.00
08/16/2020 08:00	2	1.9	11.7	14.3	26.0	756,295.7	0.00	1.00
08/16/2020 09:00	2	2.0	11.5	13.7	27.3	897,924.0	0.00	1.00
08/16/2020 10:00	2	2.1	12.2	13.5	29.3	912,887.9	0.00	1.00
08/16/2020 11:00	2	2.2	12.5	13.4	29.7	906,924.1	0.00	1.00
08/16/2020 12:00	2	2.0	11.0	13.9	25.5	903,233.2	0.00	1.00
08/16/2020 13:00	2	2.3	13.6	13.0	32.8	907,980.4	0.00	1.00
08/16/2020 14:00	4	2.7	17.1	11.7	46.4	909,923.0	0.00	1.00
08/16/2020 15:00	4	2.6	16.5	11.9	43.7	906,102.5	0.00	1.00
08/16/2020 16:00	3	2.5	15.1	12.1	37.4	901,952.7	0.00	1.00
08/16/2020 17:00	3	2.4	13.9	12.5	33.1	898,114.2	0.00	1.00
08/16/2020 18:00	2	2.2	11.8	13.4	26.0	899,072.8	0.00	1.00
08/16/2020 19:00	2	2.3	13.7	12.9	32.2	914,946.7	0.00	1.00
08/16/2020 20:00	4	2.6	16.6	11.7	44.0	916,174.7	0.00	1.00
08/16/2020 21:00	3	2.5	15.4	12.3	37.6	913,851.9	0.00	1.00
08/16/2020 22:00	3	2.5	15.6	12.4	37.6	925,086.4	0.00	1.00
08/16/2020 23:00	2	2.1	11.4	13.8	25.3	864,859.0	0.00	1.00
Average/Sum#:	3	2.2	13.4	13.4	31.6	842,079.2	0.00 #	24.00 #
Minimum:	2	1.8	11.0	11.7	25.3	652,188.4	0.00	1.00
Maximum:	4	2.7	17.1	14.5	46.4	925,086.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/17/2020 00:00	2	1.9	12.0	14.4	28.3	757,818.4	0.00	1.00
08/17/2020 01:00	2	1.9	12.2	14.4	25.2	704,937.5	0.00	1.00
08/17/2020 02:00	2	1.9	11.9	14.3	24.6	691,559.3	0.00	1.00
08/17/2020 03:00	2	1.9	12.3	14.3	24.9	674,960.2	0.00	1.00
08/17/2020 04:00	2	1.9	13.4	14.3	26.7	662,925.9	0.00	1.00
08/17/2020 05:00	2	1.9	12.1	14.4	28.1	773,408.8	0.00	1.00
08/17/2020 06:00	1	1.8	9.4	14.5	21.0	884,776.5	0.00	1.00
08/17/2020 07:00	2	2.3	13.4	13.0	31.1	924,794.8	0.00	1.00
08/17/2020 08:00	3	2.6	16.4	11.8	42.9	924,286.2	0.00	1.00
08/17/2020 09:00	4	2.7	16.4	11.7	44.8	929,868.9	0.00	1.00
08/17/2020 10:00	4	2.7	16.1	11.6	44.2	919,870.3	0.00	1.00
08/17/2020 11:00	4	2.7	16.0	11.6	43.5	917,072.6	0.00	1.00
08/17/2020 12:00	3	2.5	15.2	12.1	38.6	913,001.5	0.00	1.00
08/17/2020 13:00	2	2.3	13.1	12.9	30.1	906,901.3	0.00	1.00
08/17/2020 14:00	2	2.2	12.0	13.2	26.7	883,189.8	0.00	1.00
08/17/2020 15:00	2	1.9	11.4	14.3	23.6	704,216.1	0.00	1.00
08/17/2020 16:00	2	2.1	10.9	13.6	24.4	879,620.7	0.00	1.00
08/17/2020 17:00	2	2.4	14.3	12.6	33.1	916,194.4	0.00	1.00
08/17/2020 18:00	2	2.4	14.5	12.6	33.7	916,194.4	0.00	1.00
08/17/2020 19:00	3	2.4	14.9	12.5	34.9	922,894.2	0.00	1.00
08/17/2020 20:00	2	2.2	11.9	13.3	28.4	898,955.0	0.00	1.00
08/17/2020 21:00	2	2.0	10.4	13.9	24.4	893,647.2	0.00	1.00
08/17/2020 22:00	1	1.9	9.1	14.4	22.8	899,606.5	0.00	1.00
08/17/2020 23:00	2	1.9	10.9	14.2	25.9	794,266.1	0.00	1.00
Average/Sum#:	2	2.2	12.9	13.3	30.5	845,623.6	0.00 #	24.00 #
Minimum:	1	1.8	9.1	11.6	21.0	662,925.9	0.00	1.00
Maximum:	4	2.7	16.4	14.5	44.8	929,868.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/18/2020 00:00	2	1.9	11.4	14.3	24.9	738,866.7	0.00	1.00
08/18/2020 01:00	2	1.9	12.2	14.4	26.5	709,783.2	0.00	1.00
08/18/2020 02:00	2	1.9	12.2	14.4	25.0	673,756.8	0.00	1.00
08/18/2020 03:00	3	1.9	12.9	14.3	27.2	662,925.9	0.00	1.00
08/18/2020 04:00	2	1.9	12.9	14.3	25.6	679,110.0	0.00	1.00
08/18/2020 05:00	2	1.9	12.6	14.5	24.2	636,782.3	0.00	1.00
08/18/2020 06:00	2	1.9	12.8	14.4	25.6	643,208.1	0.00	1.00
08/18/2020 07:00	2	1.9	11.3	14.4	24.2	754,236.8	0.00	1.00
08/18/2020 08:00	1	2.0	9.9	14.1	23.1	901,000.7	0.00	1.00
08/18/2020 09:00	2	2.3	14.1	12.7	32.7	914,842.3	0.00	1.00
08/18/2020 10:00	2	2.4	14.5	12.7	34.1	919,518.4	0.00	1.00
08/18/2020 11:00	3	2.5	15.4	12.2	37.6	912,477.4	0.00	1.00
08/18/2020 12:00	4	2.7	16.4	11.7	43.9	919,449.4	0.00	1.00
08/18/2020 13:00	3	2.5	15.5	12.1	39.2	914,557.6	0.00	1.00
08/18/2020 14:00	3	2.5	15.2	12.3	37.5	911,622.6	0.00	1.00
08/18/2020 15:00	2	2.1	10.9	13.8	24.8	893,019.0	0.00	1.00
08/18/2020 16:00	2	2.2	12.1	13.3	27.9	893,909.8	0.00	1.00
08/18/2020 17:00	2	2.1	10.9	13.8	24.6	890,318.7	0.00	1.00
08/18/2020 18:00	2	2.1	11.6	13.5	27.0	901,599.4	0.00	1.00
08/18/2020 19:00	2	2.2	11.6	13.5	26.4	874,396.0	0.00	1.00
08/18/2020 20:00	2	1.9	12.0	14.3	25.1	696,124.1	0.00	1.00
08/18/2020 21:00	2	2.1	12.4	13.4	27.8	871,684.3	0.00	1.00
08/18/2020 22:00	2	2.1	10.9	13.8	24.7	897,455.2	0.00	1.00
08/18/2020 23:00	2	2.0	11.0	13.7	25.6	879,094.4	0.00	1.00
Average/Sum#:	2	2.1	12.6	13.6	28.6	820,405.8	0.00 #	24.00 #
Minimum:	1	1.9	9.9	11.7	23.1	636,782.3	0.00	1.00
Maximum:	4	2.7	16.4	14.5	43.9	919,518.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/19/2020 00:00	1	1.9	9.3	14.5	21.7	863,807.2	0.00	1.00
08/19/2020 01:00	2	1.9	12.0	14.4	29.4	795,530.2	0.00	1.00
08/19/2020 02:00	2	1.9	11.8	14.3	24.6	729,322.2	0.00	1.00
08/19/2020 03:00	3	1.9	13.2	14.4	27.8	679,445.2	0.00	1.00
08/19/2020 04:00	2	1.8	13.0	14.5	28.3	755,751.1	0.00	1.00
08/19/2020 05:00	2	1.9	12.6	14.4	28.5	740,963.9	0.00	1.00
08/19/2020 06:00	2	1.8	11.6	14.5	28.3	829,999.6	0.00	1.00
08/19/2020 07:00	2	2.0	10.5	14.1	25.0	923,555.9	0.00	1.00
08/19/2020 08:00	2	2.3	15.1	12.7	35.7	928,536.5	0.00	1.00
08/19/2020 09:00	2	2.3	13.7	13.0	32.9	913,700.8	0.00	1.00
08/19/2020 10:00	4	2.6	16.9	11.9	45.5	925,578.7	0.00	1.00
08/19/2020 11:00	4	2.6	17.2	11.8	48.3	925,640.6	0.00	1.00
08/19/2020 12:00	4	2.6	17.3	11.8	49.7	932,412.5	0.00	1.00
08/19/2020 13:00	3	2.5	16.4	12.3	42.3	921,495.2	0.00	1.00
08/19/2020 14:00	2	2.1	12.0	13.8	28.5	907,677.6	0.00	1.00
08/19/2020 15:00	2	2.0	11.5	13.9	27.8	913,014.8	0.00	1.00
08/19/2020 16:00	2	2.2	13.4	13.2	33.5	913,068.2	0.00	1.00
08/19/2020 17:00	4	2.6	17.0	12.0	44.4	923,207.4	0.00	1.00
08/19/2020 18:00	3	2.4	16.0	12.5	38.8	916,536.2	0.00	1.00
08/19/2020 19:00	2	2.2	12.5	13.5	29.6	916,404.0	0.00	1.00
08/19/2020 20:00	2	2.1	12.3	13.5	29.8	910,852.3	0.00	1.00
08/19/2020 21:00	2	2.1	12.1	13.6	29.3	912,636.9	0.00	1.00
08/19/2020 22:00	2	1.9	11.2	14.4	27.8	837,666.4	0.00	1.00
08/19/2020 23:00	2	1.9	12.1	14.4	30.4	809,224.5	0.00	1.00
Average/Sum#:	2	2.1	13.4	13.5	32.8	867,751.2	0.00 #	24.00 #
Minimum:	1	1.8	9.3	11.8	21.7	679,445.2	0.00	1.00
Maximum:	4	2.6	17.3	14.5	49.7	932,412.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/20/2020 00:00	2	1.9	13.5	14.4	28.2	689,768.5	0.00	1.00
08/20/2020 01:00	3	1.8	14.3	14.5	29.1	644,913.3	0.00	1.00
08/20/2020 02:00	2	1.9	13.8	14.5	26.5	634,428.6	0.00	1.00
08/20/2020 03:00	3	1.8	13.9	14.5	27.7	633,144.8	0.00	1.00
08/20/2020 04:00	2	1.8	14.3	14.5	27.4	632,716.9	0.00	1.00
08/20/2020 05:00	3	1.8	14.2	14.5	29.6	640,633.8	0.00	1.00
08/20/2020 06:00	3	1.9	14.0	14.5	28.5	641,061.8	0.00	1.00
08/20/2020 07:00	3	1.8	13.9	14.5	28.3	636,354.4	0.00	1.00
08/20/2020 08:00	3	1.9	14.4	14.5	31.2	668,022.3	0.00	1.00
08/20/2020 09:00	3	1.9	13.3	14.5	31.0	737,563.4	0.00	1.00
08/20/2020 10:00	2	1.8	12.8	14.6	33.4	832,088.3	0.00	1.00
08/20/2020 11:00	1	2.0	10.8	14.1	25.2	915,299.1	0.00	1.00
08/20/2020 12:00	2	1.9	10.6	14.4	25.7	868,004.4	0.00	1.00
08/20/2020 13:00	1	1.8	9.5	14.5	23.2	895,261.2	0.00	1.00
08/20/2020 14:00	2	1.9	12.7	14.3	28.7	721,437.7	0.00	1.00
08/20/2020 15:00	2	2.0	11.6	13.9	26.5	883,278.7	0.00	1.00
08/20/2020 16:00	2	1.9	12.2	14.4	29.8	787,524.4	0.00	1.00
08/20/2020 17:00	2	1.8	10.4	14.5	24.5	862,095.4	0.00	1.00
08/20/2020 18:00	2	2.0	11.7	13.8	27.9	886,654.1	0.00	1.00
08/20/2020 19:00	2	1.9	12.4	14.4	29.1	756,132.9	0.00	1.00
08/20/2020 20:00	2	1.9	12.2	14.4	28.6	769,405.8	0.00	1.00
08/20/2020 21:00	2	1.9	12.4	14.4	29.5	782,678.7	0.00	1.00
08/20/2020 22:00	2	1.9	13.0	14.3	25.5	649,024.2	0.00	1.00
08/20/2020 23:00	2	1.9	12.6	14.4	23.4	625,089.6	0.00	1.00
Average/Sum#:	2	1.9	12.7	14.4	27.9	741,357.6	0.00 #	24.00 #
Minimum:	1	1.8	9.5	13.8	23.2	625,089.6	0.00	1.00
Maximum:	3	2.0	14.4	14.6	33.4	915,299.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/21/2020 00:00	2	1.8	13.0	14.5	25.0	632,716.9	0.00	1.00
08/21/2020 01:00	2	1.9	12.8	14.5	24.5	632,288.9	0.00	1.00
08/21/2020 02:00	2	1.9	12.7	14.5	24.5	632,074.9	0.00	1.00
08/21/2020 03:00	3	1.9	13.6	14.4	28.7	644,472.2	0.00	1.00
08/21/2020 04:00	2	1.8	13.6	14.4	26.6	633,095.4	0.00	1.00
08/21/2020 05:00	2	1.9	12.8	14.5	24.7	632,074.9	0.00	1.00
08/21/2020 06:00	3	1.9	13.4	14.3	28.6	672,470.4	0.00	1.00
08/21/2020 07:00	2	1.9	12.4	14.4	29.1	757,186.3	0.00	1.00
08/21/2020 08:00	2	1.9	12.5	14.4	29.0	738,225.1	0.00	1.00
08/21/2020 09:00	2	1.8	12.5	14.5	31.8	800,899.3	0.00	1.00
08/21/2020 10:00	2	1.8	10.9	14.4	26.8	857,049.0	0.00	1.00
08/21/2020 11:00	2	1.9	9.5	14.4	24.0	897,710.4	0.00	1.00
08/21/2020 12:00	2	1.9	10.7	14.4	27.9	860,419.9	0.00	1.00
08/21/2020 13:00	3	2.4	16.1	12.3	42.9	934,074.8	0.00	1.00
08/21/2020 14:00	3	2.3	15.0	12.8	36.7	922,924.4	0.00	1.00
08/21/2020 15:00	3	2.5	16.4	12.2	42.1	922,079.1	0.00	1.00
08/21/2020 16:00	4	2.7	17.1	11.7	47.3	917,067.8	0.00	1.00
08/21/2020 17:00	4	2.7	16.9	11.7	46.9	917,960.9	0.00	1.00
08/21/2020 18:00	4	2.7	16.9	11.7	47.0	916,621.2	0.00	1.00
08/21/2020 19:00	1	1.9	9.8	14.3	21.9	845,930.8	0.00	1.00
08/21/2020 20:00	2	1.9	11.6	14.3	26.1	742,601.5	0.00	1.00
08/21/2020 21:00	2	2.2	13.9	12.9	32.8	898,342.4	0.00	1.00
08/21/2020 22:00	2	2.3	14.3	12.8	32.7	882,010.7	0.00	1.00
08/21/2020 23:00	3	2.0	12.5	14.4	28.4	723,898.8	0.00	1.00
Average/Sum#:	2	2.1	13.4	13.7	31.5	792,258.2	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.7	21.9	632,074.9	0.00	1.00
Maximum:	4	2.7	17.1	14.5	47.3	934,074.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/22/2020 00:00	2	1.8	13.1	14.5	25.8	633,786.7	0.00	1.00
08/22/2020 01:00	3	1.9	13.3	14.4	28.1	671,860.7	0.00	1.00
08/22/2020 02:00	3	1.9	13.6	14.4	28.7	655,006.2	0.00	1.00
08/22/2020 03:00	2	1.8	13.1	14.5	25.8	635,284.5	0.00	1.00
08/22/2020 04:00	2	1.8	13.7	14.5	26.8	630,577.1	0.00	1.00
08/22/2020 05:00	3	1.9	13.6	14.5	28.0	631,005.1	0.00	1.00
08/22/2020 06:00	3	1.9	14.0	14.5	29.4	647,908.9	0.00	1.00
08/22/2020 07:00	3	1.9	13.4	14.4	28.6	686,608.3	0.00	1.00
08/22/2020 08:00	3	1.9	13.3	14.4	28.7	671,228.6	0.00	1.00
08/22/2020 09:00	2	1.8	12.4	14.5	30.6	780,571.9	0.00	1.00
08/22/2020 10:00	1	1.8	9.9	14.6	23.5	892,299.5	0.00	1.00
08/22/2020 11:00	2	2.0	11.2	13.8	26.6	913,849.7	0.00	1.00
08/22/2020 12:00	2	2.0	10.0	14.2	24.4	889,308.3	0.00	1.00
08/22/2020 13:00	2	1.9	9.8	14.3	24.1	865,019.7	0.00	1.00
08/22/2020 14:00	2	1.9	9.9	14.2	24.3	875,818.4	0.00	1.00
08/22/2020 15:00	2	2.1	12.1	13.5	28.9	898,453.4	0.00	1.00
08/22/2020 16:00	3	2.5	16.1	12.2	39.8	909,644.1	0.00	1.00
08/22/2020 17:00	4	2.7	16.8	11.6	45.9	900,580.6	0.00	1.00
08/22/2020 18:00	4	2.6	16.4	11.7	44.2	896,526.4	0.00	1.00
08/22/2020 19:00	2	2.3	13.4	13.0	31.0	887,352.3	0.00	1.00
08/22/2020 20:00	2	2.2	12.9	13.3	30.9	901,477.7	0.00	1.00
08/22/2020 21:00	2	2.1	11.4	13.8	26.5	883,760.9	0.00	1.00
08/22/2020 22:00	2	1.9	9.5	14.5	23.3	885,418.5	0.00	1.00
08/22/2020 23:00	3	1.9	12.7	14.5	31.7	778,432.2	0.00	1.00
Average/Sum#:	2	2.0	12.7	13.9	29.4	792,574.2	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.6	23.3	630,577.1	0.00	1.00
Maximum:	4	2.7	16.8	14.6	45.9	913,849.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/23/2020 00:00	3	1.9	13.9	14.4	29.1	662,380.0	0.00	1.00
08/23/2020 01:00	3	1.9	13.9	14.5	27.7	637,210.3	0.00	1.00
08/23/2020 02:00	3	1.8	13.8	14.5	27.9	631,433.0	0.00	1.00
08/23/2020 03:00	3	1.8	13.6	14.5	26.9	631,861.0	0.00	1.00
08/23/2020 04:00	2	1.8	13.9	14.5	27.0	632,074.9	0.00	1.00
08/23/2020 05:00	3	1.9	13.7	14.5	27.4	632,074.9	0.00	1.00
08/23/2020 06:00	3	1.9	13.5	14.5	26.9	632,288.9	0.00	1.00
08/23/2020 07:00	3	1.8	13.7	14.5	28.2	634,000.7	0.00	1.00
08/23/2020 08:00	3	1.8	13.5	14.5	28.1	651,332.5	0.00	1.00
08/23/2020 09:00	2	1.8	12.4	14.6	30.6	810,351.4	0.00	1.00
08/23/2020 10:00	1	1.9	9.7	14.3	22.6	897,180.5	0.00	1.00
08/23/2020 11:00	3	2.3	14.8	12.8	36.7	929,179.8	0.00	1.00
08/23/2020 12:00	3	2.5	16.4	12.2	42.4	928,060.5	0.00	1.00
08/23/2020 13:00	3	2.5	16.3	12.2	42.9	919,875.4	0.00	1.00
08/23/2020 14:00	3	2.4	15.6	12.7	39.2	918,182.3	0.00	1.00
08/23/2020 15:00	3	2.3	15.5	12.8	38.4	912,611.5	0.00	1.00
08/23/2020 16:00	3	2.4	16.7	12.6	42.0	922,134.1	0.00	1.00
08/23/2020 17:00	3	2.4	16.1	12.8	39.9	923,600.7	0.00	1.00
08/23/2020 18:00	2	2.2	13.7	13.3	33.0	912,108.7	0.00	1.00
08/23/2020 19:00	2	1.9	10.4	14.2	25.2	882,154.6	0.00	1.00
08/23/2020 20:00	2	1.9	9.6	14.5	24.3	898,684.8	0.00	1.00
08/23/2020 21:00	2	2.1	12.5	13.5	30.3	894,752.3	0.00	1.00
08/23/2020 22:00	2	2.0	10.9	14.1	27.5	888,514.8	0.00	1.00
08/23/2020 23:00	3	1.9	13.0	14.4	31.3	737,803.7	0.00	1.00
Average/Sum#:	3	2.0	13.6	13.8	31.5	796,660.5	0.00 #	24.00 #
Minimum:	1	1.8	9.6	12.2	22.6	631,433.0	0.00	1.00
Maximum:	3	2.5	16.7	14.6	42.9	929,179.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/24/2020 00:00	3	1.9	14.3	14.4	30.7	655,848.9	0.00	1.00
08/24/2020 01:00	2	1.8	13.4	14.5	26.0	634,856.6	0.00	1.00
08/24/2020 02:00	2	1.9	13.1	14.5	25.4	634,000.7	0.00	1.00
08/24/2020 03:00	2	1.8	13.1	14.5	25.6	633,786.7	0.00	1.00
08/24/2020 04:00	2	1.8	13.9	14.4	28.3	659,851.9	0.00	1.00
08/24/2020 05:00	3	1.9	13.7	14.4	28.2	647,000.4	0.00	1.00
08/24/2020 06:00	2	1.9	13.0	14.4	27.2	688,293.8	0.00	1.00
08/24/2020 07:00	2	1.9	12.4	14.5	30.1	783,781.5	0.00	1.00
08/24/2020 08:00	2	1.9	11.0	14.0	25.3	888,935.0	0.00	1.00
08/24/2020 09:00	2	2.3	14.1	13.0	33.8	920,981.2	0.00	1.00
08/24/2020 10:00	3	2.3	14.9	12.8	36.5	922,924.4	0.00	1.00
08/24/2020 11:00	4	2.6	17.2	11.8	46.6	920,373.6	0.00	1.00
08/24/2020 12:00	3	2.5	16.0	12.4	40.3	918,481.0	0.00	1.00
08/24/2020 13:00	2	2.3	14.0	13.0	34.0	909,540.5	0.00	1.00
08/24/2020 14:00	3	2.4	15.1	12.7	35.6	912,337.2	0.00	1.00
08/24/2020 15:00	2	2.3	13.6	13.1	32.9	904,346.8	0.00	1.00
08/24/2020 16:00	3	2.4	15.5	12.7	37.6	914,174.3	0.00	1.00
08/24/2020 17:00	3	2.4	15.6	12.7	37.8	913,172.3	0.00	1.00
08/24/2020 18:00	2	2.3	14.1	13.1	33.6	904,697.9	0.00	1.00
08/24/2020 19:00	2	2.0	10.7	14.1	25.7	878,445.5	0.00	1.00
08/24/2020 20:00	2	1.9	11.4	14.5	29.1	837,488.6	0.00	1.00
08/24/2020 21:00	2	1.9	11.2	14.0	26.7	889,927.4	0.00	1.00
08/24/2020 22:00	2	2.1	11.7	13.7	27.3	874,910.0	0.00	1.00
08/24/2020 23:00	3	1.9	12.5	14.4	31.1	772,144.7	0.00	1.00
Average/Sum#:	2	2.1	13.6	13.7	31.5	817,512.5	0.00 #	24.00 #
Minimum:	2	1.8	10.7	11.8	25.3	633,786.7	0.00	1.00
Maximum:	4	2.6	17.2	14.5	46.6	922,924.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/25/2020 00:00	3	1.9	13.7	14.4	29.0	671,860.7	0.00	1.00
08/25/2020 01:00	3	1.8	13.8	14.5	27.4	634,000.7	0.00	1.00
08/25/2020 02:00	3	1.8	13.6	14.5	26.7	633,572.8	0.00	1.00
08/25/2020 03:00	2	1.8	13.4	14.5	26.1	633,358.8	0.00	1.00
08/25/2020 04:00	2	1.8	13.9	14.5	26.4	633,786.7	0.00	1.00
08/25/2020 05:00	2	1.9	13.5	14.5	26.6	633,786.7	0.00	1.00
08/25/2020 06:00	3	1.9	13.8	14.4	29.5	673,335.4	0.00	1.00
08/25/2020 07:00	2	1.9	12.9	14.4	27.9	709,361.8	0.00	1.00
08/25/2020 08:00	2	1.8	12.4	14.5	31.6	816,091.3	0.00	1.00
08/25/2020 09:00	1	1.9	9.8	14.5	23.4	910,239.3	0.00	1.00
08/25/2020 10:00	2	2.1	12.7	13.4	30.8	912,767.0	0.00	1.00
08/25/2020 11:00	3	2.4	15.7	12.5	37.9	914,742.9	0.00	1.00
08/25/2020 12:00	2	2.2	12.7	13.4	30.4	910,028.2	0.00	1.00
08/25/2020 13:00	2	2.2	12.6	13.4	30.5	910,941.1	0.00	1.00
08/25/2020 14:00	2	2.2	12.7	13.3	30.6	903,099.3	0.00	1.00
08/25/2020 15:00	3	2.4	15.0	12.7	36.8	909,999.2	0.00	1.00
08/25/2020 16:00	3	2.4	15.6	12.5	38.4	910,667.2	0.00	1.00
08/25/2020 17:00	4	2.6	16.8	11.8	45.9	913,601.7	0.00	1.00
08/25/2020 18:00	3	2.3	14.6	12.8	35.1	907,370.5	0.00	1.00
08/25/2020 19:00	2	2.2	12.8	13.3	29.8	891,747.5	0.00	1.00
08/25/2020 20:00	2	1.9	9.7	14.4	24.3	861,473.3	0.00	1.00
08/25/2020 21:00	2	1.8	9.5	14.5	23.2	880,283.1	0.00	1.00
08/25/2020 22:00	2	1.9	11.3	14.4	28.9	820,601.2	0.00	1.00
08/25/2020 23:00	3	1.9	13.5	14.4	27.7	650,581.9	0.00	1.00
Average/Sum#:	2	2.0	13.2	13.8	30.2	801,970.8	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.8	23.2	633,358.8	0.00	1.00
Maximum:	4	2.6	16.8	14.5	45.9	914,742.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/26/2020 00:00	2	1.9	13.4	14.5	26.1	633,786.7	0.00	1.00
08/26/2020 01:00	3	1.8	13.6	14.5	27.0	634,000.7	0.00	1.00
08/26/2020 02:00	3	1.8	13.6	14.5	27.2	632,716.9	0.00	1.00
08/26/2020 03:00	3	1.8	13.6	14.5	26.9	632,930.8	0.00	1.00
08/26/2020 04:00	2	1.8	14.4	14.5	28.4	639,350.0	0.00	1.00
08/26/2020 05:00	3	1.9	13.9	14.5	27.7	638,922.1	0.00	1.00
08/26/2020 06:00	3	1.9	13.8	14.5	27.6	641,703.7	0.00	1.00
08/26/2020 07:00	3	1.9	13.4	14.4	29.7	698,406.4	0.00	1.00
08/26/2020 08:00	2	1.8	12.7	14.5	30.4	773,296.8	0.00	1.00
08/26/2020 09:00	2	1.8	12.1	14.4	30.5	822,708.0	0.00	1.00
08/26/2020 10:00	2	2.0	11.5	13.9	28.9	914,188.6	0.00	1.00
08/26/2020 11:00	3	2.3	15.7	12.7	37.5	923,860.5	0.00	1.00
08/26/2020 12:00	4	2.6	17.1	12.0	45.2	922,745.8	0.00	1.00
08/26/2020 13:00	4	2.7	17.2	11.7	47.5	911,560.3	0.00	1.00
08/26/2020 14:00	4	2.7	17.0	11.7	47.4	911,262.6	0.00	1.00
08/26/2020 15:00	4	2.7	17.0	11.7	47.2	910,816.1	0.00	1.00
08/26/2020 16:00	4	2.7	17.2	11.7	48.2	912,304.6	0.00	1.00
08/26/2020 17:00	4	2.6	17.3	11.8	47.9	914,053.2	0.00	1.00
08/26/2020 18:00	2	2.2	12.9	13.4	30.3	898,525.0	0.00	1.00
08/26/2020 19:00	2	1.9	10.1	14.3	25.3	869,169.5	0.00	1.00
08/26/2020 20:00	2	1.9	10.7	14.5	27.6	848,829.1	0.00	1.00
08/26/2020 21:00	2	1.8	10.8	14.6	27.6	876,214.2	0.00	1.00
08/26/2020 22:00	3	1.9	14.3	14.4	32.3	679,234.5	0.00	1.00
08/26/2020 23:00	3	1.9	14.1	14.4	28.4	640,679.9	0.00	1.00
Average/Sum#:	3	2.1	14.1	13.7	33.5	786,719.4	0.00 #	24.00 #
Minimum:	2	1.8	10.1	11.7	25.3	632,716.9	0.00	1.00
Maximum:	4	2.7	17.3	14.6	48.2	923,860.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/27/2020 00:00	2	1.9	13.3	14.5	25.6	633,358.8	0.00	1.00
08/27/2020 01:00	2	1.9	13.2	14.5	25.9	633,358.8	0.00	1.00
08/27/2020 02:00	3	1.9	13.3	14.5	26.4	632,930.8	0.00	1.00
08/27/2020 03:00	3	1.9	13.5	14.5	26.9	632,716.9	0.00	1.00
08/27/2020 04:00	3	1.8	14.2	14.5	27.8	632,930.8	0.00	1.00
08/27/2020 05:00	3	1.9	14.0	14.5	28.6	633,358.8	0.00	1.00
08/27/2020 06:00	3	1.9	13.7	14.5	27.4	634,214.7	0.00	1.00
08/27/2020 07:00	3	1.9	13.5	14.5	27.4	637,424.3	0.00	1.00
08/27/2020 08:00	3	1.9	14.1	14.4	30.4	651,424.6	0.00	1.00
08/27/2020 09:00	3	1.9	13.2	14.4	28.8	700,934.6	0.00	1.00
08/27/2020 10:00	2	1.8	10.6	14.5	25.6	870,440.4	0.00	1.00
08/27/2020 11:00	2	2.0	12.3	13.9	31.2	912,623.5	0.00	1.00
08/27/2020 12:00	2	2.0	11.6	14.0	29.3	919,697.5	0.00	1.00
08/27/2020 13:00	3	2.3	15.2	12.8	36.5	920,388.4	0.00	1.00
08/27/2020 14:00	3	2.4	15.4	12.7	37.3	907,828.2	0.00	1.00
08/27/2020 15:00	3	2.3	14.5	13.0	35.8	909,193.8	0.00	1.00
08/27/2020 16:00	3	2.4	16.1	12.6	38.8	910,089.7	0.00	1.00
08/27/2020 17:00	3	2.4	16.2	12.5	39.6	913,275.6	0.00	1.00
08/27/2020 18:00	2	2.2	13.5	13.3	32.2	903,820.1	0.00	1.00
08/27/2020 19:00	2	2.0	11.7	13.9	28.3	897,559.9	0.00	1.00
08/27/2020 20:00	2	1.9	11.9	14.5	31.4	843,479.8	0.00	1.00
08/27/2020 21:00	2	1.8	12.0	14.5	31.1	842,196.0	0.00	1.00
08/27/2020 22:00	3	1.9	14.2	14.4	32.1	685,554.9	0.00	1.00
08/27/2020 23:00	3	1.8	14.0	14.5	27.5	633,572.8	0.00	1.00
Average/Sum#:	3	2.0	13.6	14.0	30.5	770,515.6	0.00 #	24.00 #
Minimum:	2	1.8	10.6	12.5	25.6	632,716.9	0.00	1.00
Maximum:	3	2.4	16.2	14.5	39.6	920,388.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/28/2020 00:00	3	1.8	13.8	14.5	27.7	631,647.0	0.00	1.00
08/28/2020 01:00	3	1.8	13.8	14.5	27.8	631,219.1	0.00	1.00
08/28/2020 02:00	3	1.8	13.6	14.5	27.2	631,219.1	0.00	1.00
08/28/2020 03:00	2	1.9	13.2	14.5	26.0	632,288.9	0.00	1.00
08/28/2020 04:00	2	1.8	13.7	14.5	26.3	632,502.9	0.00	1.00
08/28/2020 05:00	2	1.9	13.3	14.5	26.3	631,861.0	0.00	1.00
08/28/2020 06:00	2	1.9	13.2	14.5	25.7	634,000.7	0.00	1.00
08/28/2020 07:00	3	1.9	14.0	14.4	29.7	651,424.6	0.00	1.00
08/28/2020 08:00	2	1.9	12.7	14.4	27.2	710,836.6	0.00	1.00
08/28/2020 09:00	2	1.9	12.2	14.4	29.4	789,420.5	0.00	1.00
08/28/2020 10:00	1	1.8	9.9	14.5	23.5	893,549.4	0.00	1.00
08/28/2020 11:00	2	2.2	14.2	13.0	34.8	922,021.3	0.00	1.00
08/28/2020 12:00	4	2.7	17.5	11.7	48.1	916,323.5	0.00	1.00
08/28/2020 13:00	4	2.7	17.6	11.7	49.5	915,281.6	0.00	1.00
08/28/2020 14:00	3	2.4	15.8	12.6	39.2	910,254.7	0.00	1.00
08/28/2020 15:00	3	2.4	16.2	12.5	40.6	913,112.6	0.00	1.00
08/28/2020 16:00	4	2.7	17.5	11.7	48.7	909,327.6	0.00	1.00
08/28/2020 17:00	4	2.6	16.9	12.0	45.3	910,898.0	0.00	1.00
08/28/2020 18:00	2	2.2	13.0	13.4	29.7	895,786.1	0.00	1.00
08/28/2020 19:00	1	1.9	9.5	14.5	23.0	887,558.2	0.00	1.00
08/28/2020 20:00	2	1.8	9.4	14.6	23.7	895,994.8	0.00	1.00
08/28/2020 21:00	1	1.8	9.4	14.5	22.9	893,977.4	0.00	1.00
08/28/2020 22:00	2	1.9	10.4	14.4	26.6	828,817.8	0.00	1.00
08/28/2020 23:00	2	1.8	12.8	14.4	28.9	717,367.7	0.00	1.00
Average/Sum#:	2	2.1	13.5	13.8	31.6	791,112.1	0.00 #	24.00 #
Minimum:	1	1.8	9.4	11.7	22.9	631,219.1	0.00	1.00
Maximum:	4	2.7	17.6	14.6	49.5	922,021.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/29/2020 00:00	3	1.9	13.5	14.5	27.3	642,559.6	0.00	1.00
08/29/2020 01:00	2	1.8	13.4	14.5	26.1	632,716.9	0.00	1.00
08/29/2020 02:00	2	1.9	13.2	14.5	25.8	633,572.8	0.00	1.00
08/29/2020 03:00	2	1.9	13.3	14.5	26.0	632,930.8	0.00	1.00
08/29/2020 04:00	2	1.8	13.6	14.5	25.8	632,502.9	0.00	1.00
08/29/2020 05:00	3	1.9	13.3	14.5	26.5	632,288.9	0.00	1.00
08/29/2020 06:00	2	1.9	13.1	14.5	25.7	633,358.8	0.00	1.00
08/29/2020 07:00	2	1.9	13.0	14.5	25.2	635,712.5	0.00	1.00
08/29/2020 08:00	3	1.9	14.0	14.4	30.2	659,641.2	0.00	1.00
08/29/2020 09:00	2	1.9	12.6	14.5	28.8	748,048.1	0.00	1.00
08/29/2020 10:00	2	1.9	12.2	14.4	28.2	758,661.1	0.00	1.00
08/29/2020 11:00	1	1.8	9.9	14.5	24.0	896,331.1	0.00	1.00
08/29/2020 12:00	2	2.2	12.8	13.3	31.7	910,306.8	0.00	1.00
08/29/2020 13:00	4	2.6	17.0	11.9	44.5	915,384.1	0.00	1.00
08/29/2020 14:00	3	2.5	16.1	12.3	40.6	909,552.6	0.00	1.00
08/29/2020 15:00	4	2.6	17.2	11.8	47.2	913,300.7	0.00	1.00
08/29/2020 16:00	3	2.3	15.0	12.8	36.0	906,525.1	0.00	1.00
08/29/2020 17:00	2	2.2	12.6	13.5	30.1	901,414.3	0.00	1.00
08/29/2020 18:00	2	2.0	10.7	14.4	25.9	857,470.3	0.00	1.00
08/29/2020 19:00	3	1.8	12.4	14.4	30.4	753,183.4	0.00	1.00
08/29/2020 20:00	2	1.8	12.4	14.4	29.3	779,939.9	0.00	1.00
08/29/2020 21:00	2	1.8	10.3	14.5	24.6	863,379.3	0.00	1.00
08/29/2020 22:00	3	1.9	12.9	14.4	30.0	723,898.8	0.00	1.00
08/29/2020 23:00	3	1.9	14.0	14.4	29.1	643,418.8	0.00	1.00
Average/Sum#:	2	2.0	13.3	14.0	30.0	759,004.1	0.00 #	24.00 #
Minimum:	1	1.8	9.9	11.8	24.0	632,288.9	0.00	1.00
Maximum:	4	2.6	17.2	14.5	47.2	915,384.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/30/2020 00:00	2	1.9	13.4	14.5	26.2	633,786.7	0.00	1.00
08/30/2020 01:00	3	1.8	13.4	14.5	26.3	633,358.8	0.00	1.00
08/30/2020 02:00	3	1.9	13.3	14.5	26.3	633,358.8	0.00	1.00
08/30/2020 03:00	2	1.8	13.2	14.5	26.0	632,930.8	0.00	1.00
08/30/2020 04:00	2	1.8	13.7	14.5	26.1	632,716.9	0.00	1.00
08/30/2020 05:00	3	1.9	13.3	14.5	26.7	632,716.9	0.00	1.00
08/30/2020 06:00	3	1.9	13.4	14.5	26.7	635,498.5	0.00	1.00
08/30/2020 07:00	3	1.9	13.4	14.5	26.8	635,498.5	0.00	1.00
08/30/2020 08:00	3	1.9	13.1	14.5	26.1	635,284.5	0.00	1.00
08/30/2020 09:00	3	1.9	13.7	14.4	29.4	653,320.8	0.00	1.00
08/30/2020 10:00	2	1.8	12.5	14.5	28.0	750,401.8	0.00	1.00
08/30/2020 11:00	2	1.8	11.4	14.5	27.8	851,610.8	0.00	1.00
08/30/2020 12:00	2	2.1	12.7	13.4	30.1	914,227.7	0.00	1.00
08/30/2020 13:00	3	2.6	16.9	12.0	43.0	915,052.5	0.00	1.00
08/30/2020 14:00	4	2.7	17.3	11.7	47.4	913,941.9	0.00	1.00
08/30/2020 15:00	3	2.5	16.4	12.1	41.7	901,641.5	0.00	1.00
08/30/2020 16:00	3	2.3	14.5	12.9	34.7	900,396.5	0.00	1.00
08/30/2020 17:00	2	2.3	14.2	13.0	33.2	904,166.8	0.00	1.00
08/30/2020 18:00	1	1.9	9.8	14.4	23.1	875,588.9	0.00	1.00
08/30/2020 19:00	2	1.9	12.1	14.4	30.0	792,791.4	0.00	1.00
08/30/2020 20:00	2	1.9	12.6	14.3	26.6	695,709.1	0.00	1.00
08/30/2020 21:00	1	1.8	9.9	14.5	22.8	865,091.1	0.00	1.00
08/30/2020 22:00	3	1.8	12.6	14.3	28.5	708,365.9	0.00	1.00
08/30/2020 23:00	4	2.4	16.9	12.3	47.2	892,514.4	0.00	1.00
Average/Sum#:	3	2.0	13.5	13.9	30.4	759,998.8	0.00 #	24.00 #
Minimum:	1	1.8	9.8	11.7	22.8	632,716.9	0.00	1.00
Maximum:	4	2.7	17.3	14.5	47.4	915,052.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/31/2020 00:00	4	2.5	18.0	12.1	46.1	919,381.7	0.00	1.00
08/31/2020 01:00	2	2.3	15.3	12.9	35.7	921,280.3	0.00	1.00
08/31/2020 02:00	2	2.1	12.6	13.6	30.2	918,452.3	0.00	1.00
08/31/2020 03:00	2	2.1	12.3	13.6	31.3	916,013.6	0.00	1.00
08/31/2020 04:00	2	2.1	14.5	13.1	38.8	931,033.0	0.00	1.00
08/31/2020 05:00	2	2.2	12.7	13.5	32.5	919,735.0	0.00	1.00
08/31/2020 06:00	3	2.2	14.5	13.1	38.5	944,727.3	0.00	1.00
08/31/2020 07:00	3	2.4	16.0	12.7	41.4	937,554.7	0.00	1.00
08/31/2020 08:00	3	2.5	17.3	12.4	43.9	937,491.8	0.00	1.00
08/31/2020 09:00	3	2.3	15.3	12.9	36.8	922,307.3	0.00	1.00
08/31/2020 10:00	3	2.3	15.3	12.9	37.2	922,307.3	0.00	1.00
08/31/2020 11:00	3	2.4	17.0	12.4	40.6	915,097.7	0.00	1.00
08/31/2020 12:00	4	2.6	17.9	12.0	46.1	922,745.8	0.00	1.00
08/31/2020 13:00	4	2.6	17.6	12.0	44.4	909,359.3	0.00	1.00
08/31/2020 14:00	3	2.4	15.9	12.6	36.1	892,600.7	0.00	1.00
08/31/2020 15:00	1	2.1	11.6	14.0	24.5	888,935.0	0.00	1.00
08/31/2020 16:00	2	2.2	13.5	13.3	32.8	905,081.4	0.00	1.00
08/31/2020 17:00	3	2.3	15.3	12.8	36.3	902,805.7	0.00	1.00
08/31/2020 18:00	2	2.2	13.7	13.2	32.4	902,930.9	0.00	1.00
08/31/2020 19:00	2	2.2	13.2	13.4	31.6	900,533.5	0.00	1.00
08/31/2020 20:00	2	1.9	12.7	14.4	25.7	664,065.5	0.00	1.00
08/31/2020 21:00	1	1.8	10.1	14.5	23.4	873,650.0	0.00	1.00
08/31/2020 22:00	2	1.9	12.5	14.3	28.5	732,227.1	0.00	1.00
08/31/2020 23:00	2	1.9	12.3	14.3	26.4	708,988.4	0.00	1.00
Average/Sum#:	3	2.2	14.5	13.2	35.1	887,887.7	0.00 #	24.00 #
Minimum:	1	1.8	10.1	12.0	23.4	664,065.5	0.00	1.00
Maximum:	4	2.6	18.0	14.5	46.1	944,727.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/01/2020 00:00	3	1.9	13.5	14.4	27.3	637,730.4	0.00	1.00
09/01/2020 01:00	2	1.8	13.2	14.5	25.2	634,000.7	0.00	1.00
09/01/2020 02:00	2	1.9	13.1	14.5	25.5	633,144.8	0.00	1.00
09/01/2020 03:00	2	1.9	13.1	14.5	25.5	634,642.6	0.00	1.00
09/01/2020 04:00	2	1.8	13.7	14.5	26.3	638,708.1	0.00	1.00
09/01/2020 05:00	3	1.9	13.0	14.4	30.2	744,334.8	0.00	1.00
09/01/2020 06:00	2	1.9	12.9	14.4	30.7	763,717.4	0.00	1.00
09/01/2020 07:00	3	1.9	12.8	14.4	33.4	817,230.3	0.00	1.00
09/01/2020 08:00	1	1.8	10.0	14.5	24.6	917,728.3	0.00	1.00
09/01/2020 09:00	2	1.8	9.9	14.5	25.9	911,095.2	0.00	1.00
09/01/2020 10:00	2	1.9	9.5	14.5	23.5	890,553.8	0.00	1.00
09/01/2020 11:00	2	1.9	10.7	14.1	28.2	906,035.3	0.00	1.00
09/01/2020 12:00	3	2.5	16.8	12.1	43.1	922,027.2	0.00	1.00
09/01/2020 13:00	4	2.6	17.0	12.0	44.4	915,821.8	0.00	1.00
09/01/2020 14:00	4	2.6	17.2	11.8	46.5	914,504.6	0.00	1.00
09/01/2020 15:00	4	2.6	17.1	11.8	47.0	917,815.3	0.00	1.00
09/01/2020 16:00	4	2.6	17.0	11.8	46.3	911,043.4	0.00	1.00
09/01/2020 17:00	3	2.5	16.0	12.4	40.5	915,581.0	0.00	1.00
09/01/2020 18:00	3	2.3	15.0	12.8	36.4	914,809.3	0.00	1.00
09/01/2020 19:00	2	2.3	13.9	13.1	34.3	915,934.2	0.00	1.00
09/01/2020 20:00	3	2.3	15.4	12.8	37.7	927,827.3	0.00	1.00
09/01/2020 21:00	2	2.0	10.6	14.2	26.5	884,402.9	0.00	1.00
09/01/2020 22:00	3	1.9	12.9	14.3	29.9	716,872.9	0.00	1.00
09/01/2020 23:00	2	1.9	12.7	14.4	29.0	733,800.8	0.00	1.00
Average/Sum#:	3	2.1	13.6	13.6	32.8	821,640.1	0.00 #	24.00 #
Minimum:	1	1.8	9.5	11.8	23.5	633,144.8	0.00	1.00
Maximum:	4	2.6	17.2	14.5	47.0	927,827.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/02/2020 00:00	2	1.9	12.8	14.4	29.0	731,061.9	0.00	1.00
09/02/2020 01:00	3	1.9	13.5	14.3	29.2	675,997.7	0.00	1.00
09/02/2020 02:00	3	1.9	13.7	14.4	28.2	652,056.7	0.00	1.00
09/02/2020 03:00	3	1.9	13.6	14.4	27.6	648,685.8	0.00	1.00
09/02/2020 04:00	2	1.8	13.9	14.4	27.5	644,682.9	0.00	1.00
09/02/2020 05:00	3	1.9	13.2	14.3	28.1	665,208.3	0.00	1.00
09/02/2020 06:00	2	1.9	12.7	14.3	28.4	725,379.9	0.00	1.00
09/02/2020 07:00	2	1.9	12.6	14.4	30.9	783,942.8	0.00	1.00
09/02/2020 08:00	3	1.9	12.7	14.4	33.7	827,132.3	0.00	1.00
09/02/2020 09:00	3	1.9	12.6	14.4	32.0	794,266.1	0.00	1.00
09/02/2020 10:00	3	1.8	13.1	14.5	34.7	810,528.1	0.00	1.00
09/02/2020 11:00	2	1.9	12.7	14.5	30.0	758,104.8	0.00	1.00
09/02/2020 12:00	2	1.8	12.4	14.4	28.4	744,966.9	0.00	1.00
09/02/2020 13:00	0	1.6	11.1	13.9	31.0	849,043.1	0.00	1.00
09/02/2020 14:00	2	2.3	15.9	12.7	35.7	918,683.4	0.00	1.00
09/02/2020 15:00	3	2.4	15.8	12.6	37.7	909,759.8	0.00	1.00
09/02/2020 16:00	3	2.4	15.8	12.6	37.9	909,429.8	0.00	1.00
09/02/2020 17:00	3	2.4	15.8	12.6	37.9	909,099.8	0.00	1.00
09/02/2020 18:00	2	2.3	13.7	13.1	32.7	903,117.8	0.00	1.00
09/02/2020 19:00	2	2.0	11.3	14.0	27.2	900,644.6	0.00	1.00
09/02/2020 20:00	2	1.9	11.9	14.4	31.9	831,978.0	0.00	1.00
09/02/2020 21:00	2	2.0	11.6	13.9	28.2	900,103.1	0.00	1.00
09/02/2020 22:00	2	1.9	9.9	14.5	25.1	875,789.7	0.00	1.00
09/02/2020 23:00	3	1.9	12.8	14.4	32.2	763,085.4	0.00	1.00
Average/Sum#:	2	2.0	13.1	14.0	31.1	797,197.9	0.00 #	24.00 #
Minimum:	2	1.6	9.9	12.6	25.1	644,682.9	0.00	1.00
Maximum:	3	2.4	15.9	14.5	37.9	918,683.4	0.00	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/03/2020 00:00	3	1.9	13.3	14.4	28.9	692,296.7	0.00	1.00
09/03/2020 01:00	3	1.9	13.7	14.4	27.9	639,205.2	0.00	1.00
09/03/2020 02:00	2	1.9	13.1	14.5	25.8	634,856.6	0.00	1.00
09/03/2020 03:00	3	1.9	13.2	14.5	26.7	640,205.9	0.00	1.00
09/03/2020 04:00	3	1.8	14.4	14.4	30.2	649,528.5	0.00	1.00
09/03/2020 05:00	3	1.9	13.6	14.4	28.1	637,730.4	0.00	1.00
09/03/2020 06:00	3	1.9	13.2	14.4	26.7	628,249.8	0.00	1.00
09/03/2020 07:00	3	1.9	13.1	14.5	27.0	644,699.3	0.00	1.00
09/03/2020 08:00	2	1.9	12.6	14.4	29.7	753,604.8	0.00	1.00
09/03/2020 09:00	2	1.9	12.6	14.4	29.5	743,702.8	0.00	1.00
09/03/2020 10:00	2	1.9	12.1	14.4	30.2	803,957.5	0.00	1.00
09/03/2020 11:00	2	1.9	10.0	14.3	24.6	886,183.6	0.00	1.00
09/03/2020 12:00	3	2.4	15.9	12.5	39.0	921,590.0	0.00	1.00
09/03/2020 13:00	4	2.7	17.4	11.7	47.1	916,770.1	0.00	1.00
09/03/2020 14:00	4	2.7	17.3	11.7	47.7	915,430.4	0.00	1.00
09/03/2020 15:00	4	2.7	17.2	11.7	48.0	914,983.9	0.00	1.00
09/03/2020 16:00	4	2.7	16.8	11.7	47.3	910,220.7	0.00	1.00
09/03/2020 17:00	4	2.7	16.8	11.7	46.9	910,518.4	0.00	1.00
09/03/2020 18:00	4	2.6	16.8	11.7	46.8	908,881.0	0.00	1.00
09/03/2020 19:00	4	2.5	16.3	12.1	43.9	917,981.2	0.00	1.00
09/03/2020 20:00	3	2.5	16.2	12.3	42.0	922,291.4	0.00	1.00
09/03/2020 21:00	3	2.4	16.0	12.5	40.2	921,916.1	0.00	1.00
09/03/2020 22:00	2	2.0	10.7	14.2	26.6	897,484.0	0.00	1.00
09/03/2020 23:00	3	1.9	12.9	14.5	35.3	819,087.0	0.00	1.00
Average/Sum#:	3	2.2	14.4	13.4	35.3	801,307.3	0.00 #	24.00 #
Minimum:	2	1.8	10.0	11.7	24.6	628,249.8	0.00	1.00
Maximum:	4	2.7	17.4	14.5	48.0	922,291.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/04/2020 00:00	3	1.9	12.9	14.4	30.6	754,658.2	0.00	1.00
09/04/2020 01:00	3	1.9	13.4	14.4	29.6	699,881.2	0.00	1.00
09/04/2020 02:00	3	1.9	14.0	14.3	30.5	668,943.1	0.00	1.00
09/04/2020 03:00	3	1.9	14.3	14.3	30.8	659,813.6	0.00	1.00
09/04/2020 04:00	3	1.9	14.6	14.3	30.6	668,320.6	0.00	1.00
09/04/2020 05:00	3	1.9	13.8	14.3	31.2	684,089.7	0.00	1.00
09/04/2020 06:00	3	1.9	13.8	14.3	30.5	679,732.5	0.00	1.00
09/04/2020 07:00	3	1.9	14.1	14.3	31.0	668,320.6	0.00	1.00
09/04/2020 08:00	2	1.9	12.8	14.4	28.5	727,901.7	0.00	1.00
09/04/2020 09:00	2	1.9	12.6	14.4	28.4	721,159.9	0.00	1.00
09/04/2020 10:00	2	1.9	11.8	14.4	28.4	796,583.6	0.00	1.00
09/04/2020 11:00	2	2.0	11.5	13.8	27.3	902,855.7	0.00	1.00
09/04/2020 12:00	2	2.3	14.6	12.8	34.8	911,766.1	0.00	1.00
09/04/2020 13:00	4	2.7	17.1	11.8	46.1	918,567.7	0.00	1.00
09/04/2020 14:00	4	2.7	17.0	11.7	47.3	911,262.6	0.00	1.00
09/04/2020 15:00	4	2.7	17.0	11.7	47.4	909,923.0	0.00	1.00
09/04/2020 16:00	4	2.7	16.8	11.7	46.9	907,987.9	0.00	1.00
09/04/2020 17:00	4	2.7	16.7	11.7	46.4	907,839.1	0.00	1.00
09/04/2020 18:00	4	2.7	16.3	11.6	46.1	898,960.8	0.00	1.00
09/04/2020 19:00	4	2.7	16.4	11.7	46.9	910,220.7	0.00	1.00
09/04/2020 20:00	4	2.7	16.6	11.7	47.5	910,518.4	0.00	1.00
09/04/2020 21:00	4	2.6	16.6	11.9	46.4	912,949.6	0.00	1.00
09/04/2020 22:00	2	2.3	13.6	13.1	33.6	903,117.8	0.00	1.00
09/04/2020 23:00	3	2.0	13.3	14.4	29.9	706,201.6	0.00	1.00
Average/Sum#:	3	2.2	14.7	13.2	36.5	805,899.0	0.00 #	24.00 #
Minimum:	2	1.9	11.5	11.6	27.3	659,813.6	0.00	1.00
Maximum:	4	2.7	17.1	14.4	47.5	918,567.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/05/2020 00:00	3	1.9	14.0	14.5	28.9	654,114.1	0.00	1.00
09/05/2020 01:00	3	1.8	13.9	14.5	28.4	639,136.0	0.00	1.00
09/05/2020 02:00	3	1.8	13.4	14.5	26.8	633,786.7	0.00	1.00
09/05/2020 03:00	2	1.9	13.0	14.5	25.9	639,136.0	0.00	1.00
09/05/2020 04:00	2	1.8	13.3	14.5	25.5	638,066.2	0.00	1.00
09/05/2020 05:00	3	1.9	12.9	14.5	26.3	636,996.3	0.00	1.00
09/05/2020 06:00	2	1.9	12.8	14.5	25.4	637,852.2	0.00	1.00
09/05/2020 07:00	3	1.9	13.0	14.5	26.9	647,053.0	0.00	1.00
09/05/2020 08:00	3	1.8	13.6	14.4	29.5	684,290.8	0.00	1.00
09/05/2020 09:00	2	1.8	11.7	14.6	28.2	839,478.9	0.00	1.00
09/05/2020 10:00	2	2.0	11.3	13.8	26.2	907,484.8	0.00	1.00
09/05/2020 11:00	3	2.4	15.0	12.6	35.3	914,544.5	0.00	1.00
09/05/2020 12:00	3	2.6	16.0	11.9	41.7	905,646.0	0.00	1.00
09/05/2020 13:00	4	2.7	16.2	11.7	44.8	908,434.5	0.00	1.00
09/05/2020 14:00	4	2.7	16.3	11.7	45.8	906,797.1	0.00	1.00
09/05/2020 15:00	4	2.7	16.4	11.7	46.4	901,438.5	0.00	1.00
09/05/2020 16:00	4	2.7	16.3	11.7	45.9	898,908.0	0.00	1.00
09/05/2020 17:00	4	2.6	16.2	11.7	45.4	891,912.1	0.00	1.00
09/05/2020 18:00	3	2.4	14.3	12.8	34.6	908,384.8	0.00	1.00
09/05/2020 19:00	3	2.5	15.6	12.4	38.9	909,136.7	0.00	1.00
09/05/2020 20:00	4	2.6	16.5	11.8	46.6	916,160.0	0.00	1.00
09/05/2020 21:00	3	2.4	15.4	12.5	38.6	918,329.5	0.00	1.00
09/05/2020 22:00	2	2.0	10.8	14.0	25.4	887,744.2	0.00	1.00
09/05/2020 23:00	2	1.9	11.6	14.5	30.5	827,645.9	0.00	1.00
Average/Sum#:	3	2.2	14.1	13.3	34.1	802,186.5	0.00 #	24.00 #
Minimum:	2	1.8	10.8	11.7	25.4	633,786.7	0.00	1.00
Maximum:	4	2.7	16.5	14.6	46.6	918,329.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/06/2020 00:00	2	1.9	12.5	14.4	28.0	726,427.0	0.00	1.00
09/06/2020 01:00	3	1.9	13.3	14.5	27.2	652,616.3	0.00	1.00
09/06/2020 02:00	2	1.9	12.8	14.5	25.1	639,778.0	0.00	1.00
09/06/2020 03:00	2	1.9	12.7	14.5	24.8	640,633.8	0.00	1.00
09/06/2020 04:00	2	1.8	13.1	14.5	24.8	639,991.9	0.00	1.00
09/06/2020 05:00	2	1.9	12.7	14.5	25.3	644,485.4	0.00	1.00
09/06/2020 06:00	3	1.9	13.2	14.4	27.1	650,160.6	0.00	1.00
09/06/2020 07:00	2	1.9	12.9	14.4	25.8	642,154.7	0.00	1.00
09/06/2020 08:00	2	1.9	12.7	14.4	26.7	691,664.7	0.00	1.00
09/06/2020 09:00	2	1.9	11.6	14.4	27.3	805,221.5	0.00	1.00
09/06/2020 10:00	1	1.9	10.0	14.5	23.0	871,082.3	0.00	1.00
09/06/2020 11:00	2	1.8	11.9	14.4	27.5	777,201.0	0.00	1.00
09/06/2020 12:00	2	2.1	12.3	13.6	28.8	902,694.5	0.00	1.00
09/06/2020 13:00	3	2.4	15.2	12.7	37.3	903,820.1	0.00	1.00
09/06/2020 14:00	4	2.6	16.7	12.0	43.6	899,511.8	0.00	1.00
09/06/2020 15:00	4	2.7	17.1	11.7	47.6	898,014.9	0.00	1.00
09/06/2020 16:00	4	2.7	17.0	11.7	47.6	895,633.3	0.00	1.00
09/06/2020 17:00	4	2.7	16.7	11.7	46.1	894,889.1	0.00	1.00
09/06/2020 18:00	4	2.6	16.5	11.8	45.7	897,349.2	0.00	1.00
09/06/2020 19:00	3	2.5	15.8	12.2	40.6	905,866.4	0.00	1.00
09/06/2020 20:00	3	2.5	15.9	12.1	41.3	907,554.9	0.00	1.00
09/06/2020 21:00	4	2.6	16.3	11.8	44.2	905,325.0	0.00	1.00
09/06/2020 22:00	2	2.3	13.7	13.0	31.8	897,753.0	0.00	1.00
09/06/2020 23:00	2	2.0	10.2	14.3	23.8	855,475.3	0.00	1.00
Average/Sum#:	3	2.2	13.9	13.4	33.0	797,721.0	0.00 #	24.00 #
Minimum:	1	1.8	10.0	11.7	23.0	639,778.0	0.00	1.00
Maximum:	4	2.7	17.1	14.5	47.6	907,554.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/07/2020 00:00	2	1.9	12.1	14.4	28.3	759,503.8	0.00	1.00
09/07/2020 01:00	3	1.9	13.1	14.3	27.4	656,078.8	0.00	1.00
09/07/2020 02:00	3	1.8	13.3	14.5	27.0	641,061.8	0.00	1.00
09/07/2020 03:00	3	1.8	13.3	14.5	27.0	640,419.9	0.00	1.00
09/07/2020 04:00	2	1.8	13.6	14.5	26.2	639,991.9	0.00	1.00
09/07/2020 05:00	2	1.9	13.1	14.5	26.0	638,494.1	0.00	1.00
09/07/2020 06:00	2	1.9	13.0	14.5	26.0	639,136.0	0.00	1.00
09/07/2020 07:00	3	1.9	13.5	14.4	29.0	671,439.3	0.00	1.00
09/07/2020 08:00	2	1.8	11.9	14.5	27.9	800,471.3	0.00	1.00
09/07/2020 09:00	2	2.1	12.5	13.5	29.6	904,745.4	0.00	1.00
09/07/2020 10:00	4	2.6	17.1	11.8	45.3	908,334.7	0.00	1.00
09/07/2020 11:00	4	2.6	16.4	12.0	43.7	904,435.6	0.00	1.00
09/07/2020 12:00	2	2.3	13.3	13.1	32.4	889,248.0	0.00	1.00
09/07/2020 13:00	4	2.6	16.6	11.9	44.8	906,711.1	0.00	1.00
09/07/2020 14:00	2	2.3	13.6	13.0	31.8	881,978.6	0.00	1.00
09/07/2020 15:00	2	2.2	12.5	13.4	28.9	880,631.2	0.00	1.00
09/07/2020 16:00	3	2.4	15.1	12.5	35.7	884,256.9	0.00	1.00
09/07/2020 17:00	2	2.2	12.5	13.4	27.2	879,900.8	0.00	1.00
09/07/2020 18:00	1	2.0	10.4	14.1	23.1	873,209.4	0.00	1.00
09/07/2020 19:00	2	1.9	9.4	14.4	23.1	868,425.7	0.00	1.00
09/07/2020 20:00	2	2.0	10.2	14.1	24.7	880,257.9	0.00	1.00
09/07/2020 21:00	2	2.2	14.0	13.0	33.5	898,619.7	0.00	1.00
09/07/2020 22:00	1	1.9	9.9	14.4	23.4	869,268.5	0.00	1.00
09/07/2020 23:00	2	1.9	12.1	14.4	30.1	800,375.9	0.00	1.00
Average/Sum#:	2	2.1	13.0	13.7	30.1	804,874.8	0.00 #	24.00 #
Minimum:	1	1.8	9.4	11.8	23.1	638,494.1	0.00	1.00
Maximum:	4	2.6	17.1	14.5	45.3	908,334.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/08/2020 00:00	2	1.9	13.3	14.3	26.8	670,603.0	0.00	1.00
09/08/2020 01:00	2	1.9	11.9	14.3	26.6	742,186.5	0.00	1.00
09/08/2020 02:00	2	1.9	12.3	14.4	28.8	751,287.3	0.00	1.00
09/08/2020 03:00	3	1.9	13.3	14.4	27.7	660,694.6	0.00	1.00
09/08/2020 04:00	3	1.8	14.0	14.4	28.4	656,270.3	0.00	1.00
09/08/2020 05:00	3	1.8	13.3	14.5	33.4	777,576.3	0.00	1.00
09/08/2020 06:00	2	1.9	10.6	14.5	25.3	882,208.9	0.00	1.00
09/08/2020 07:00	2	2.0	12.3	13.8	32.9	910,956.5	0.00	1.00
09/08/2020 08:00	3	2.2	13.7	13.3	36.1	933,370.8	0.00	1.00
09/08/2020 09:00	3	2.4	16.9	12.6	43.0	928,733.7	0.00	1.00
09/08/2020 10:00	2	2.1	13.4	13.6	33.4	921,641.4	0.00	1.00
09/08/2020 11:00	2	1.9	11.9	14.5	31.9	852,038.7	0.00	1.00
09/08/2020 12:00	2	1.8	12.7	14.5	33.5	836,632.7	0.00	1.00
09/08/2020 13:00	2	1.9	12.8	14.5	33.4	829,999.6	0.00	1.00
09/08/2020 14:00	2	1.9	13.5	14.4	27.1	664,486.8	0.00	1.00
09/08/2020 15:00	2	1.9	13.0	14.5	24.7	639,991.9	0.00	1.00
09/08/2020 16:00	3	1.8	14.3	14.6	30.5	646,672.6	0.00	1.00
09/08/2020 17:00	3	1.8	14.8	14.6	31.8	647,542.1	0.00	1.00
09/08/2020 18:00	3	1.8	15.1	14.5	33.0	651,974.4	0.00	1.00
09/08/2020 19:00	3	1.9	15.0	14.5	33.1	665,668.6	0.00	1.00
09/08/2020 20:00	3	1.8	14.3	14.5	30.4	649,192.7	0.00	1.00
09/08/2020 21:00	1	1.8	10.3	14.6	23.5	898,168.5	0.00	1.00
09/08/2020 22:00	3	1.9	13.9	14.5	38.7	810,100.1	0.00	1.00
09/08/2020 23:00	3	1.8	15.2	14.6	32.9	661,888.5	0.00	1.00
Average/Sum#:	2	1.9	13.4	14.3	31.1	762,078.6	0.00 #	24.00 #
Minimum:	1	1.8	10.3	12.6	23.5	639,991.9	0.00	1.00
Maximum:	3	2.4	16.9	14.6	43.0	933,370.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/09/2020 00:00	3	1.8	14.8	14.6	30.7	646,890.0	0.00	1.00
09/09/2020 01:00	3	1.8	14.5	14.5	30.5	635,284.5	0.00	1.00
09/09/2020 02:00	3	1.8	14.3	14.5	30.0	635,498.5	0.00	1.00
09/09/2020 03:00	3	1.8	14.2	14.5	29.6	636,568.4	0.00	1.00
09/09/2020 04:00	3	1.8	14.6	14.5	30.0	636,568.4	0.00	1.00
09/09/2020 05:00	3	1.9	14.2	14.5	30.9	641,061.8	0.00	1.00
09/09/2020 06:00	2	1.8	13.0	14.4	30.6	768,773.8	0.00	1.00
09/09/2020 07:00	4	2.5	17.5	12.0	51.3	971,214.2	0.00	1.00
09/09/2020 08:00	5	2.7	18.2	11.6	56.7	954,326.8	0.00	1.00
09/09/2020 09:00	5	2.6	18.8	11.8	58.3	939,936.8	0.00	1.00
09/09/2020 10:00	5	2.6	18.0	11.7	53.4	943,116.6	0.00	1.00
09/09/2020 11:00	5	2.7	18.2	11.7	54.1	947,284.4	0.00	1.00
09/09/2020 12:00	5	2.7	18.0	11.7	53.0	943,265.5	0.00	1.00
09/09/2020 13:00	5	2.7	17.7	11.7	52.6	940,586.2	0.00	1.00
09/09/2020 14:00	5	2.7	17.7	11.7	52.3	939,841.9	0.00	1.00
09/09/2020 15:00	5	2.7	17.7	11.7	52.5	941,330.4	0.00	1.00
09/09/2020 16:00	5	2.6	17.9	11.8	52.8	913,902.7	0.00	1.00
09/09/2020 17:00	2	2.0	12.2	14.2	26.9	738,058.4	0.00	1.00
09/09/2020 18:00	2	1.9	12.4	14.3	27.3	710,855.7	0.00	1.00
09/09/2020 19:00	2	1.9	12.5	14.4	29.5	764,349.5	0.00	1.00
09/09/2020 20:00	3	1.9	13.5	14.4	26.6	635,834.3	0.00	1.00
09/09/2020 21:00	2	1.9	13.4	14.4	26.1	633,306.1	0.00	1.00
09/09/2020 22:00	3	1.9	13.6	14.4	27.8	655,848.9	0.00	1.00
09/09/2020 23:00	2	1.9	12.9	14.4	24.9	644,050.8	0.00	1.00
Average/Sum#:	4	2.2	15.4	13.3	39.1	784,073.1	0.00 #	24.00 #
Minimum:	2	1.8	12.2	11.6	24.9	633,306.1	0.00	1.00
Maximum:	5	2.7	18.8	14.6	58.3	971,214.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/10/2020 00:00	2	1.9	13.1	14.4	25.5	632,463.4	0.00	1.00
09/10/2020 01:00	2	1.9	13.1	14.4	25.7	635,412.9	0.00	1.00
09/10/2020 02:00	3	1.9	13.4	14.4	26.5	632,252.7	0.00	1.00
09/10/2020 03:00	3	1.9	13.5	14.4	27.1	632,042.0	0.00	1.00
09/10/2020 04:00	3	1.8	14.5	14.4	29.9	650,581.9	0.00	1.00
09/10/2020 05:00	3	1.9	14.3	14.5	29.9	640,419.9	0.00	1.00
09/10/2020 06:00	3	1.9	14.2	14.5	29.7	643,415.5	0.00	1.00
09/10/2020 07:00	3	1.9	14.1	14.4	30.1	646,157.6	0.00	1.00
09/10/2020 08:00	3	1.8	13.6	14.5	27.5	642,773.6	0.00	1.00
09/10/2020 09:00	3	1.9	13.8	14.4	30.4	691,243.3	0.00	1.00
09/10/2020 10:00	3	1.9	13.5	14.4	29.7	702,409.4	0.00	1.00
09/10/2020 11:00	2	1.9	12.4	14.4	31.5	833,452.7	0.00	1.00
09/10/2020 12:00	3	1.9	12.8	14.5	34.4	844,549.7	0.00	1.00
09/10/2020 13:00	2	1.9	12.3	14.2	31.7	889,717.1	0.00	1.00
09/10/2020 14:00	2	1.9	10.8	14.3	25.6	868,754.5	0.00	1.00
09/10/2020 15:00	2	1.9	10.2	14.3	25.7	902,782.7	0.00	1.00
09/10/2020 16:00	1	1.9	9.3	14.5	22.6	900,396.5	0.00	1.00
09/10/2020 17:00	2	1.9	10.4	14.2	26.7	908,725.5	0.00	1.00
09/10/2020 18:00	2	1.8	10.8	14.5	27.9	876,645.6	0.00	1.00
09/10/2020 19:00	3	2.3	15.0	12.8	36.9	938,816.5	0.00	1.00
09/10/2020 20:00	2	2.0	11.1	14.0	28.0	917,911.3	0.00	1.00
09/10/2020 21:00	2	1.9	10.5	14.2	27.2	910,769.4	0.00	1.00
09/10/2020 22:00	2	1.9	12.3	14.5	33.3	847,759.3	0.00	1.00
09/10/2020 23:00	2	1.9	13.1	14.3	28.1	706,706.0	0.00	1.00
Average/Sum#:	2	1.9	12.6	14.3	28.8	770,673.3	0.00 #	24.00 #
Minimum:	1	1.8	9.3	12.8	22.6	632,042.0	0.00	1.00
Maximum:	3	2.3	15.0	14.5	36.9	938,816.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/11/2020 00:00	3	1.9	13.5	14.3	28.9	683,052.3	0.00	1.00
09/11/2020 01:00	2	1.9	13.4	14.5	25.8	640,205.9	0.00	1.00
09/11/2020 02:00	2	1.9	13.5	14.5	26.7	639,564.0	0.00	1.00
09/11/2020 03:00	2	1.9	13.4	14.5	26.5	642,559.6	0.00	1.00
09/11/2020 04:00	3	1.8	14.4	14.3	31.0	688,447.0	0.00	1.00
09/11/2020 05:00	3	1.9	14.3	14.4	29.4	630,777.9	0.00	1.00
09/11/2020 06:00	3	1.9	14.1	14.4	28.6	630,356.6	0.00	1.00
09/11/2020 07:00	3	1.9	13.6	14.4	27.6	648,053.8	0.00	1.00
09/11/2020 08:00	3	1.9	13.7	14.3	29.8	683,882.2	0.00	1.00
09/11/2020 09:00	2	1.8	13.0	14.5	33.0	815,235.5	0.00	1.00
09/11/2020 10:00	1	1.8	10.6	14.5	24.4	878,571.3	0.00	1.00
09/11/2020 11:00	2	1.8	10.8	14.6	28.8	906,428.5	0.00	1.00
09/11/2020 12:00	2	1.9	11.3	14.2	28.9	904,433.3	0.00	1.00
09/11/2020 13:00	2	2.0	12.1	13.8	29.8	930,630.0	0.00	1.00
09/11/2020 14:00	2	2.2	14.0	13.1	33.7	916,109.8	0.00	1.00
09/11/2020 15:00	3	2.0	12.8	14.4	30.4	750,233.9	0.00	1.00
09/11/2020 16:00	2	1.8	13.0	14.5	30.8	773,724.8	0.00	1.00
09/11/2020 17:00	1	1.8	10.1	14.5	24.1	899,754.6	0.00	1.00
09/11/2020 18:00	2	1.9	12.2	14.5	32.1	850,113.0	0.00	1.00
09/11/2020 19:00	2	1.9	13.4	14.4	26.5	663,644.1	0.00	1.00
09/11/2020 20:00	2	1.9	12.7	14.4	31.5	805,010.9	0.00	1.00
09/11/2020 21:00	2	1.9	10.5	14.5	25.1	891,409.7	0.00	1.00
09/11/2020 22:00	3	1.9	12.8	14.4	31.8	787,524.4	0.00	1.00
09/11/2020 23:00	3	1.9	12.9	14.4	30.4	762,453.4	0.00	1.00
Average/Sum#:	2	1.9	12.8	14.3	29.0	767,590.7	0.00 #	24.00 #
Minimum:	1	1.8	10.1	13.1	24.1	630,356.6	0.00	1.00
Maximum:	3	2.2	14.4	14.6	33.7	930,630.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/12/2020 00:00	3	1.9	13.7	14.4	26.9	633,938.1	0.00	1.00
09/12/2020 01:00	3	1.9	13.8	14.4	27.3	631,831.3	0.00	1.00
09/12/2020 02:00	3	1.9	13.9	14.4	27.8	632,674.1	0.00	1.00
09/12/2020 03:00	3	1.9	14.0	14.4	28.3	631,199.3	0.00	1.00
09/12/2020 04:00	3	1.8	14.6	14.4	29.8	630,777.9	0.00	1.00
09/12/2020 05:00	3	1.9	14.2	14.4	29.4	632,463.4	0.00	1.00
09/12/2020 06:00	3	1.9	13.8	14.4	28.1	635,412.9	0.00	1.00
09/12/2020 07:00	3	1.9	13.9	14.4	28.1	636,677.0	0.00	1.00
09/12/2020 08:00	2	1.9	13.2	14.4	26.3	652,267.4	0.00	1.00
09/12/2020 09:00	3	1.9	14.0	14.3	30.4	665,830.7	0.00	1.00
09/12/2020 10:00	2	1.8	12.9	14.4	28.6	733,590.1	0.00	1.00
09/12/2020 11:00	2	1.9	12.3	14.4	27.9	771,512.6	0.00	1.00
09/12/2020 12:00	2	1.8	10.6	14.4	25.7	878,117.1	0.00	1.00
09/12/2020 13:00	3	2.3	15.5	12.8	37.6	927,827.3	0.00	1.00
09/12/2020 14:00	3	2.5	17.4	12.0	44.3	916,437.3	0.00	1.00
09/12/2020 15:00	2	2.0	11.7	14.0	27.1	904,812.4	0.00	1.00
09/12/2020 16:00	2	2.1	12.2	13.8	30.0	907,677.6	0.00	1.00
09/12/2020 17:00	3	2.4	16.8	12.3	41.2	917,832.8	0.00	1.00
09/12/2020 18:00	1	1.9	10.2	14.4	23.6	876,010.2	0.00	1.00
09/12/2020 19:00	2	1.9	12.5	14.4	30.7	788,367.1	0.00	1.00
09/12/2020 20:00	2	1.9	12.5	14.3	27.7	735,546.9	0.00	1.00
09/12/2020 21:00	2	1.9	10.5	14.4	26.0	890,968.6	0.00	1.00
09/12/2020 22:00	2	1.9	12.2	14.4	30.9	813,859.4	0.00	1.00
09/12/2020 23:00	2	1.9	12.4	14.3	28.7	753,390.9	0.00	1.00
Average/Sum#:	2	2.0	13.3	14.1	29.7	758,292.6	0.00 #	24.00 #
Minimum:	1	1.8	10.2	12.0	23.6	630,777.9	0.00	1.00
Maximum:	3	2.5	17.4	14.4	44.3	927,827.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/13/2020 00:00	3	1.9	13.6	14.3	28.0	656,701.2	0.00	1.00
09/13/2020 01:00	2	1.9	13.1	14.4	25.0	636,677.0	0.00	1.00
09/13/2020 02:00	3	1.9	13.5	14.4	26.9	631,620.7	0.00	1.00
09/13/2020 03:00	3	1.9	13.6	14.4	27.0	633,938.1	0.00	1.00
09/13/2020 04:00	2	1.8	14.0	14.4	27.1	633,516.8	0.00	1.00
09/13/2020 05:00	3	1.9	13.8	14.4	28.2	630,356.6	0.00	1.00
09/13/2020 06:00	3	1.9	13.6	14.5	27.1	640,205.9	0.00	1.00
09/13/2020 07:00	2	1.9	13.3	14.5	26.5	645,555.2	0.00	1.00
09/13/2020 08:00	3	1.9	13.7	14.4	29.7	692,928.7	0.00	1.00
09/13/2020 09:00	2	1.9	12.9	14.4	30.1	764,560.2	0.00	1.00
09/13/2020 10:00	1	1.8	10.3	14.5	24.2	887,130.2	0.00	1.00
09/13/2020 11:00	2	2.0	11.8	13.9	29.5	918,883.8	0.00	1.00
09/13/2020 12:00	2	2.1	12.6	13.6	30.2	915,638.4	0.00	1.00
09/13/2020 13:00	2	2.3	14.9	13.0	35.8	926,354.9	0.00	1.00
09/13/2020 14:00	3	2.4	16.6	12.6	39.0	921,309.1	0.00	1.00
09/13/2020 15:00	2	2.3	15.2	12.9	35.7	908,441.9	0.00	1.00
09/13/2020 16:00	2	2.0	11.1	14.1	26.4	889,924.5	0.00	1.00
09/13/2020 17:00	2	2.0	11.4	14.0	27.1	894,690.6	0.00	1.00
09/13/2020 18:00	2	2.0	11.7	14.0	27.6	885,958.0	0.00	1.00
09/13/2020 19:00	3	1.9	12.9	14.5	31.7	773,296.8	0.00	1.00
09/13/2020 20:00	2	2.1	13.7	13.4	32.1	876,249.0	0.00	1.00
09/13/2020 21:00	2	2.0	11.3	14.1	26.6	909,257.5	0.00	1.00
09/13/2020 22:00	2	1.9	12.2	14.4	32.4	851,360.6	0.00	1.00
09/13/2020 23:00	3	1.9	13.6	14.4	29.5	707,676.4	0.00	1.00
Average/Sum#:	2	2.0	13.1	14.1	29.3	784,676.3	0.00 #	24.00 #
Minimum:	1	1.8	10.3	12.6	24.2	630,356.6	0.00	1.00
Maximum:	3	2.4	16.6	14.5	39.0	926,354.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/14/2020 00:00	2	1.8	13.4	14.5	25.3	643,201.5	0.00	1.00
09/14/2020 01:00	2	1.9	13.4	14.5	25.8	640,205.9	0.00	1.00
09/14/2020 02:00	2	1.9	13.6	14.5	26.6	640,419.9	0.00	1.00
09/14/2020 03:00	2	1.9	13.7	14.5	26.7	639,991.9	0.00	1.00
09/14/2020 04:00	2	1.8	13.9	14.4	26.5	630,777.9	0.00	1.00
09/14/2020 05:00	3	1.9	13.9	14.4	28.0	630,567.3	0.00	1.00
09/14/2020 06:00	3	1.9	14.0	14.4	28.2	636,466.3	0.00	1.00
09/14/2020 07:00	3	1.9	14.4	14.3	30.4	656,908.7	0.00	1.00
09/14/2020 08:00	3	1.9	13.5	14.3	29.6	704,838.6	0.00	1.00
09/14/2020 09:00	2	1.9	13.0	14.4	29.4	747,705.7	0.00	1.00
09/14/2020 10:00	2	1.8	12.9	14.5	31.9	808,174.4	0.00	1.00
09/14/2020 11:00	1	1.8	9.8	14.5	22.2	906,387.8	0.00	1.00
09/14/2020 12:00	2	2.0	12.1	13.8	29.9	914,042.6	0.00	1.00
09/14/2020 13:00	3	2.4	16.6	12.5	39.8	928,763.2	0.00	1.00
09/14/2020 14:00	4	2.6	18.0	11.8	48.0	929,101.8	0.00	1.00
09/14/2020 15:00	3	2.4	15.8	12.5	39.0	913,112.6	0.00	1.00
09/14/2020 16:00	3	2.5	17.2	12.1	44.1	926,540.1	0.00	1.00
09/14/2020 17:00	4	2.6	17.8	11.8	48.4	929,854.2	0.00	1.00
09/14/2020 18:00	3	2.5	16.3	12.3	42.5	918,310.5	0.00	1.00
09/14/2020 19:00	2	1.9	12.6	14.5	32.2	821,226.7	0.00	1.00
09/14/2020 20:00	2	1.8	12.6	14.6	33.2	858,607.4	0.00	1.00
09/14/2020 21:00	1	1.9	10.7	14.3	25.2	906,932.4	0.00	1.00
09/14/2020 22:00	3	1.9	13.2	14.5	35.3	829,785.6	0.00	1.00
09/14/2020 23:00	3	1.9	14.3	14.4	29.6	679,655.9	0.00	1.00
Average/Sum#:	3	2.0	14.0	13.8	32.4	785,065.8	0.00 #	24.00 #
Minimum:	1	1.8	9.8	11.8	22.2	630,567.3	0.00	1.00
Maximum:	4	2.6	18.0	14.6	48.4	929,854.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/15/2020 00:00	2	1.9	13.6	14.5	25.7	641,703.7	0.00	1.00
09/15/2020 01:00	2	1.9	13.4	14.5	25.6	641,275.8	0.00	1.00
09/15/2020 02:00	2	1.9	13.5	14.5	26.2	641,489.7	0.00	1.00
09/15/2020 03:00	2	1.9	13.7	14.5	26.8	641,275.8	0.00	1.00
09/15/2020 04:00	2	1.8	14.3	14.5	27.9	645,769.2	0.00	1.00
09/15/2020 05:00	3	1.9	14.3	14.4	29.9	651,846.0	0.00	1.00
09/15/2020 06:00	3	1.9	14.0	14.5	28.4	646,839.0	0.00	1.00
09/15/2020 07:00	3	1.9	14.4	14.3	30.9	663,340.9	0.00	1.00
09/15/2020 08:00	2	1.9	12.9	14.4	28.9	743,492.1	0.00	1.00
09/15/2020 09:00	3	1.9	13.2	14.5	33.8	812,239.8	0.00	1.00
09/15/2020 10:00	1	1.8	9.9	14.5	22.7	905,959.8	0.00	1.00
09/15/2020 11:00	2	1.9	10.9	14.1	28.1	915,903.2	0.00	1.00
09/15/2020 12:00	3	2.3	15.2	12.8	36.3	932,730.2	0.00	1.00
09/15/2020 13:00	4	2.6	17.5	12.0	45.6	935,363.0	0.00	1.00
09/15/2020 14:00	4	2.6	17.8	11.8	48.6	928,800.8	0.00	1.00
09/15/2020 15:00	4	2.6	17.7	11.9	48.2	924,817.9	0.00	1.00
09/15/2020 16:00	3	2.5	17.2	12.4	43.8	930,080.8	0.00	1.00
09/15/2020 17:00	3	2.5	17.2	12.3	43.7	919,106.7	0.00	1.00
09/15/2020 18:00	2	2.2	14.1	13.3	34.3	918,054.9	0.00	1.00
09/15/2020 19:00	2	2.0	11.8	14.1	29.3	878,848.2	0.00	1.00
09/15/2020 20:00	3	1.9	13.2	14.4	33.0	786,260.3	0.00	1.00
09/15/2020 21:00	2	1.8	10.9	14.5	26.8	884,348.6	0.00	1.00
09/15/2020 22:00	3	1.9	13.0	14.4	32.1	780,571.9	0.00	1.00
09/15/2020 23:00	2	1.9	12.9	14.4	28.6	739,278.5	0.00	1.00
Average/Sum#:	3	2.1	14.0	13.8	32.7	796,224.9	0.00 #	24.00 #
Minimum:	1	1.8	9.9	11.8	22.7	641,275.8	0.00	1.00
Maximum:	4	2.6	17.8	14.5	48.6	935,363.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/16/2020 00:00	3	1.9	14.1	14.3	29.7	670,188.0	0.00	1.00
09/16/2020 01:00	2	1.9	13.6	14.5	26.2	643,201.5	0.00	1.00
09/16/2020 02:00	2	1.9	13.5	14.5	26.3	639,991.9	0.00	1.00
09/16/2020 03:00	3	1.9	13.4	14.5	26.9	650,476.6	0.00	1.00
09/16/2020 04:00	3	1.9	14.1	14.3	29.3	683,259.8	0.00	1.00
09/16/2020 05:00	3	1.9	13.4	14.3	29.3	692,804.2	0.00	1.00
09/16/2020 06:00	3	1.9	13.6	14.3	29.8	693,426.7	0.00	1.00
09/16/2020 07:00	2	1.9	12.8	14.3	28.9	723,927.5	0.00	1.00
09/16/2020 08:00	2	1.8	12.5	14.5	31.8	822,510.5	0.00	1.00
09/16/2020 09:00	1	1.9	9.8	14.5	22.7	895,047.2	0.00	1.00
09/16/2020 10:00	2	2.0	11.3	14.0	29.5	918,705.1	0.00	1.00
09/16/2020 11:00	3	2.2	14.5	13.0	35.8	926,354.9	0.00	1.00
09/16/2020 12:00	3	2.5	17.1	12.1	43.2	922,494.1	0.00	1.00
09/16/2020 13:00	3	2.4	16.6	12.4	41.6	922,186.5	0.00	1.00
09/16/2020 14:00	4	2.6	17.8	11.9	48.3	928,165.4	0.00	1.00
09/16/2020 15:00	4	2.6	17.7	11.8	48.1	920,223.1	0.00	1.00
09/16/2020 16:00	4	2.6	17.8	11.8	49.2	925,189.1	0.00	1.00
09/16/2020 17:00	4	2.6	17.7	11.9	48.3	927,556.8	0.00	1.00
09/16/2020 18:00	3	2.4	16.4	12.5	41.1	920,448.8	0.00	1.00
09/16/2020 19:00	2	2.2	13.0	13.5	31.5	908,261.5	0.00	1.00
09/16/2020 20:00	2	2.0	11.7	14.0	28.6	911,361.9	0.00	1.00
09/16/2020 21:00	2	2.0	11.7	13.9	27.8	892,669.1	0.00	1.00
09/16/2020 22:00	2	1.9	12.3	14.4	29.2	780,993.3	0.00	1.00
09/16/2020 23:00	2	1.9	12.6	14.3	27.0	716,872.9	0.00	1.00
Average/Sum#:	3	2.1	14.1	13.6	33.8	818,179.9	0.00 #	24.00 #
Minimum:	1	1.8	9.8	11.8	22.7	639,991.9	0.00	1.00
Maximum:	4	2.6	17.8	14.5	49.2	928,165.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/17/2020 00:00	3	1.9	13.7	14.4	27.7	656,481.0	0.00	1.00
09/17/2020 01:00	2	1.9	12.9	14.5	24.1	639,564.0	0.00	1.00
09/17/2020 02:00	2	1.9	12.9	14.5	24.5	639,136.0	0.00	1.00
09/17/2020 03:00	2	1.9	12.9	14.5	25.0	638,280.1	0.00	1.00
09/17/2020 04:00	3	1.9	14.1	14.3	28.8	653,173.9	0.00	1.00
09/17/2020 05:00	3	1.9	14.0	14.3	29.6	646,326.8	0.00	1.00
09/17/2020 06:00	3	1.9	14.2	14.3	30.7	668,735.6	0.00	1.00
09/17/2020 07:00	3	1.9	13.2	14.3	30.0	713,760.6	0.00	1.00
09/17/2020 08:00	2	1.8	12.6	14.5	31.3	817,161.2	0.00	1.00
09/17/2020 09:00	1	1.9	9.9	14.5	23.3	911,951.1	0.00	1.00
09/17/2020 10:00	2	1.9	10.9	14.1	27.5	908,653.4	0.00	1.00
09/17/2020 11:00	2	2.0	11.7	13.9	28.0	913,014.8	0.00	1.00
09/17/2020 12:00	2	2.1	12.1	13.7	29.0	903,439.7	0.00	1.00
09/17/2020 13:00	2	2.2	13.1	13.4	31.5	917,514.3	0.00	1.00
09/17/2020 14:00	3	2.3	14.5	12.9	35.3	908,955.4	0.00	1.00
09/17/2020 15:00	4	2.6	17.5	11.8	46.9	917,514.3	0.00	1.00
09/17/2020 16:00	4	2.6	17.3	11.7	47.4	909,774.1	0.00	1.00
09/17/2020 17:00	3	2.4	15.3	12.7	36.9	912,671.3	0.00	1.00
09/17/2020 18:00	2	2.3	14.2	13.1	34.9	917,689.9	0.00	1.00
09/17/2020 19:00	2	2.0	11.7	13.9	28.1	901,472.5	0.00	1.00
09/17/2020 20:00	2	2.1	12.4	13.7	30.3	911,998.6	0.00	1.00
09/17/2020 21:00	2	2.2	13.2	13.4	32.1	915,505.8	0.00	1.00
09/17/2020 22:00	2	2.0	10.9	14.4	27.0	851,992.6	0.00	1.00
09/17/2020 23:00	3	1.9	13.4	14.3	29.2	703,178.7	0.00	1.00
Average/Sum#:	2	2.1	13.3	13.8	30.8	811,581.1	0.00 #	24.00 #
Minimum:	1	1.8	9.9	11.7	23.3	638,280.1	0.00	1.00
Maximum:	4	2.6	17.5	14.5	47.4	917,689.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/18/2020 00:00	2	1.9	13.1	14.4	25.0	636,887.7	0.00	1.00
09/18/2020 01:00	2	1.9	13.0	14.4	25.0	630,777.9	0.00	1.00
09/18/2020 02:00	2	1.9	13.0	14.4	25.0	631,199.3	0.00	1.00
09/18/2020 03:00	2	1.9	13.0	14.4	25.2	630,145.9	0.00	1.00
09/18/2020 04:00	2	1.8	13.7	14.4	27.3	645,525.6	0.00	1.00
09/18/2020 05:00	2	1.9	13.0	14.3	27.3	673,507.8	0.00	1.00
09/18/2020 06:00	2	1.9	13.0	14.3	27.9	697,369.0	0.00	1.00
09/18/2020 07:00	2	1.9	12.4	14.3	27.9	737,414.3	0.00	1.00
09/18/2020 08:00	2	1.9	11.1	14.2	27.4	894,826.9	0.00	1.00
09/18/2020 09:00	2	2.0	11.6	14.1	29.5	896,771.6	0.00	1.00
09/18/2020 10:00	2	2.1	13.1	13.7	32.4	904,200.5	0.00	1.00
09/18/2020 11:00	2	2.2	14.0	13.4	34.4	893,777.6	0.00	1.00
09/18/2020 12:00	2	2.2	13.7	13.2	33.0	915,735.9	0.00	1.00
09/18/2020 13:00	3	2.3	15.5	12.7	37.5	920,854.4	0.00	1.00
09/18/2020 14:00	3	2.3	15.6	12.8	37.6	927,996.4	0.00	1.00
09/18/2020 15:00	2	2.0	11.3	14.1	27.7	911,875.5	0.00	1.00
09/18/2020 16:00	2	2.0	12.0	13.9	29.5	922,209.5	0.00	1.00
09/18/2020 17:00	2	2.2	13.8	13.2	33.2	920,004.2	0.00	1.00
09/18/2020 18:00	2	2.0	10.8	14.1	26.7	898,382.7	0.00	1.00
09/18/2020 19:00	2	1.9	12.4	14.4	29.4	757,818.4	0.00	1.00
09/18/2020 20:00	2	2.0	12.4	13.6	29.1	876,806.8	0.00	1.00
09/18/2020 21:00	1	1.9	9.8	14.4	23.1	878,327.7	0.00	1.00
09/18/2020 22:00	2	1.9	12.5	14.3	28.4	737,621.8	0.00	1.00
09/18/2020 23:00	3	1.9	13.6	14.3	28.0	660,228.5	0.00	1.00
Average/Sum#:	2	2.0	12.8	14.0	29.1	800,011.1	0.00 #	24.00 #
Minimum:	1	1.8	9.8	12.7	23.1	630,145.9	0.00	1.00
Maximum:	3	2.3	15.6	14.4	37.6	927,996.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/19/2020 00:00	2	1.9	12.9	14.5	24.2	640,205.9	0.00	1.00
09/19/2020 01:00	2	1.9	12.9	14.5	24.6	639,564.0	0.00	1.00
09/19/2020 02:00	2	1.9	13.0	14.4	25.2	629,513.9	0.00	1.00
09/19/2020 03:00	3	1.9	13.3	14.4	26.2	628,671.1	0.00	1.00
09/19/2020 04:00	2	1.8	13.9	14.4	27.1	628,460.5	0.00	1.00
09/19/2020 05:00	3	1.9	13.6	14.4	28.2	644,050.8	0.00	1.00
09/19/2020 06:00	3	1.9	13.6	14.4	27.6	638,362.4	0.00	1.00
09/19/2020 07:00	3	1.9	13.4	14.3	28.8	691,351.8	0.00	1.00
09/19/2020 08:00	2	1.9	12.5	14.3	27.8	732,227.1	0.00	1.00
09/19/2020 09:00	2	1.8	12.7	14.5	32.7	827,859.8	0.00	1.00
09/19/2020 10:00	1	1.9	10.0	14.5	24.0	916,016.5	0.00	1.00
09/19/2020 11:00	2	2.0	11.3	14.0	28.3	918,308.2	0.00	1.00
09/19/2020 12:00	2	2.2	13.3	13.3	32.0	924,721.8	0.00	1.00
09/19/2020 13:00	2	2.2	13.8	13.2	33.3	922,494.1	0.00	1.00
09/19/2020 14:00	2	2.2	13.1	13.4	31.3	909,297.8	0.00	1.00
09/19/2020 15:00	2	2.2	13.4	13.3	31.8	914,631.3	0.00	1.00
09/19/2020 16:00	2	1.9	10.3	14.3	25.5	886,183.6	0.00	1.00
09/19/2020 17:00	2	1.9	9.8	14.5	23.8	877,501.5	0.00	1.00
09/19/2020 18:00	2	1.9	10.7	14.2	27.6	890,943.4	0.00	1.00
09/19/2020 19:00	2	2.2	13.7	13.2	32.8	915,202.3	0.00	1.00
09/19/2020 20:00	2	1.9	10.2	14.5	25.8	901,038.5	0.00	1.00
09/19/2020 21:00	3	1.9	12.8	14.4	34.2	824,604.2	0.00	1.00
09/19/2020 22:00	2	1.9	13.0	14.4	29.3	739,699.8	0.00	1.00
09/19/2020 23:00	3	1.9	14.2	14.4	29.1	657,534.4	0.00	1.00
Average/Sum#:	2	2.0	12.6	14.2	28.4	787,435.2	0.00 #	24.00 #
Minimum:	1	1.8	9.8	13.2	23.8	628,460.5	0.00	1.00
Maximum:	3	2.2	14.2	14.5	34.2	924,721.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/20/2020 00:00	2	1.9	13.2	14.5	24.7	639,991.9	0.00	1.00
09/20/2020 01:00	2	1.9	13.1	14.5	24.9	639,564.0	0.00	1.00
09/20/2020 02:00	2	1.9	13.2	14.5	25.4	639,564.0	0.00	1.00
09/20/2020 03:00	2	1.9	13.3	14.5	25.9	639,564.0	0.00	1.00
09/20/2020 04:00	2	1.8	13.7	14.5	26.1	639,564.0	0.00	1.00
09/20/2020 05:00	3	1.9	13.7	14.4	27.5	631,199.3	0.00	1.00
09/20/2020 06:00	3	1.9	13.8	14.4	27.7	630,988.6	0.00	1.00
09/20/2020 07:00	2	1.9	13.4	14.5	26.5	639,991.9	0.00	1.00
09/20/2020 08:00	3	1.9	13.4	14.5	27.2	648,764.8	0.00	1.00
09/20/2020 09:00	3	1.9	13.6	14.4	29.2	693,982.1	0.00	1.00
09/20/2020 10:00	2	1.9	12.9	14.5	29.7	763,240.1	0.00	1.00
09/20/2020 11:00	2	1.8	12.4	14.6	31.3	846,434.7	0.00	1.00
09/20/2020 12:00	2	2.1	12.9	13.4	29.7	920,801.0	0.00	1.00
09/20/2020 13:00	3	2.4	15.6	12.7	37.1	931,208.6	0.00	1.00
09/20/2020 14:00	4	2.6	17.1	12.0	45.1	927,823.5	0.00	1.00
09/20/2020 15:00	4	2.6	17.6	11.8	47.7	927,145.5	0.00	1.00
09/20/2020 16:00	2	2.3	14.5	13.0	34.7	913,700.8	0.00	1.00
09/20/2020 17:00	2	2.0	11.5	14.3	28.7	868,339.6	0.00	1.00
09/20/2020 18:00	2	1.8	10.1	14.5	24.7	890,981.7	0.00	1.00
09/20/2020 19:00	2	1.9	11.5	14.5	29.2	852,894.6	0.00	1.00
09/20/2020 20:00	2	2.0	12.4	13.7	29.4	907,624.1	0.00	1.00
09/20/2020 21:00	2	1.9	10.9	14.5	26.9	856,960.1	0.00	1.00
09/20/2020 22:00	2	1.9	12.9	14.3	28.3	722,890.1	0.00	1.00
09/20/2020 23:00	2	1.9	13.1	14.4	25.2	656,059.6	0.00	1.00
Average/Sum#:	2	2.0	13.3	14.0	29.7	767,886.6	0.00 #	24.00 #
Minimum:	2	1.8	10.1	11.8	24.7	630,988.6	0.00	1.00
Maximum:	4	2.6	17.6	14.6	47.7	931,208.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/21/2020 00:00	3	1.9	13.7	14.5	27.0	640,419.9	0.00	1.00
09/21/2020 01:00	2	1.9	13.7	14.5	26.8	638,066.2	0.00	1.00
09/21/2020 02:00	3	1.9	13.7	14.5	27.2	640,633.8	0.00	1.00
09/21/2020 03:00	3	1.8	13.8	14.5	27.5	644,913.3	0.00	1.00
09/21/2020 04:00	2	1.8	14.1	14.5	27.6	644,699.3	0.00	1.00
09/21/2020 05:00	3	1.9	15.0	14.3	33.7	657,531.2	0.00	1.00
09/21/2020 06:00	3	1.9	14.5	14.3	31.2	669,358.0	0.00	1.00
09/21/2020 07:00	3	1.9	14.6	14.4	31.5	670,807.3	0.00	1.00
09/21/2020 08:00	2	1.8	12.4	14.6	31.5	854,694.7	0.00	1.00
09/21/2020 09:00	0	1.3	0.0	14.5	30.6	892,265.6	0.00	1.00
09/21/2020 10:00	2	2.0	11.2	14.1	27.8	920,937.9	0.00	1.00
09/21/2020 11:00	3	2.4	16.4	12.5	40.2	925,828.7	0.00	1.00
09/21/2020 12:00	3	2.5	17.2	12.2	44.3	927,116.0	0.00	1.00
09/21/2020 13:00	4	2.7	17.6	11.7	49.5	922,426.4	0.00	1.00
09/21/2020 14:00	4	2.7	17.4	11.7	49.5	923,766.1	0.00	1.00
09/21/2020 15:00	4	2.7	17.4	11.7	50.2	923,914.9	0.00	1.00
09/21/2020 16:00	4	2.6	17.0	12.0	46.0	917,052.7	0.00	1.00
09/21/2020 17:00	4	2.6	17.3	12.0	47.6	927,515.8	0.00	1.00
09/21/2020 18:00	4	2.5	16.9	12.1	45.4	918,292.4	0.00	1.00
09/21/2020 19:00	2	2.1	12.3	13.7	30.2	912,759.4	0.00	1.00
09/21/2020 20:00	2	1.9	11.5	14.5	30.8	864,021.2	0.00	1.00
09/21/2020 21:00	2	1.9	10.8	14.2	26.7	911,791.4	0.00	1.00
09/21/2020 22:00	2	1.9	12.2	14.4	30.8	797,215.7	0.00	1.00
09/21/2020 23:00	3	1.9	13.3	14.4	30.4	709,993.9	0.00	1.00
Average/Sum#:	3	2.1	14.5	13.6	35.2	810,667.6	0.00 #	24.00 #
Minimum:	2	1.3	10.8	11.7	26.7	638,066.2	0.00	1.00
Maximum:	4	2.7	17.6	14.6	50.2	927,515.8	0.00	1.00
%SI	4.17	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/22/2020 00:00	3	1.9	13.9	14.4	29.4	657,745.1	0.00	1.00
09/22/2020 01:00	2	1.9	13.1	14.5	25.9	641,489.7	0.00	1.00
09/22/2020 02:00	2	1.9	13.0	14.5	26.1	641,061.8	0.00	1.00
09/22/2020 03:00	2	1.9	12.9	14.5	25.7	641,703.7	0.00	1.00
09/22/2020 04:00	3	1.8	14.2	14.4	30.1	656,691.7	0.00	1.00
09/22/2020 05:00	3	1.9	13.3	14.3	30.1	703,801.1	0.00	1.00
09/22/2020 06:00	2	1.9	12.8	14.4	29.3	737,382.4	0.00	1.00
09/22/2020 07:00	3	1.9	12.7	14.4	32.1	786,260.3	0.00	1.00
09/22/2020 08:00	3	1.8	12.7	14.5	34.2	835,348.9	0.00	1.00
09/22/2020 09:00	2	1.9	10.1	14.3	24.5	911,082.2	0.00	1.00
09/22/2020 10:00	2	2.1	12.8	13.4	32.2	927,374.2	0.00	1.00
09/22/2020 11:00	2	2.2	13.4	13.2	33.8	930,497.2	0.00	1.00
09/22/2020 12:00	3	2.4	16.2	12.5	40.7	936,588.5	0.00	1.00
09/22/2020 13:00	3	2.5	16.4	12.4	41.3	928,630.8	0.00	1.00
09/22/2020 14:00	3	2.4	15.4	12.7	38.7	925,196.5	0.00	1.00
09/22/2020 15:00	3	2.3	14.4	13.0	36.1	923,754.8	0.00	1.00
09/22/2020 16:00	3	2.4	16.3	12.5	41.5	926,806.9	0.00	1.00
09/22/2020 17:00	3	2.3	14.9	12.9	37.5	929,154.4	0.00	1.00
09/22/2020 18:00	2	2.2	13.2	13.4	32.8	910,210.7	0.00	1.00
09/22/2020 19:00	2	1.9	11.4	14.5	30.2	868,728.6	0.00	1.00
09/22/2020 20:00	2	2.1	13.4	13.5	32.6	899,563.8	0.00	1.00
09/22/2020 21:00	2	1.9	10.3	14.5	26.2	890,553.8	0.00	1.00
09/22/2020 22:00	3	1.9	12.9	14.4	31.7	750,865.9	0.00	1.00
09/22/2020 23:00	3	1.9	14.4	14.4	31.6	664,065.5	0.00	1.00
Average/Sum#:	3	2.1	13.5	13.8	32.3	817,689.9	0.00 #	24.00 #
Minimum:	2	1.8	10.1	12.4	24.5	641,061.8	0.00	1.00
Maximum:	3	2.5	16.4	14.5	41.5	936,588.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/23/2020 00:00	3	1.9	13.6	14.5	27.5	642,559.6	0.00	1.00
09/23/2020 01:00	3	1.8	13.6	14.5	28.1	641,061.8	0.00	1.00
09/23/2020 02:00	3	1.8	13.8	14.5	28.5	641,275.8	0.00	1.00
09/23/2020 03:00	3	1.8	13.7	14.5	28.0	641,275.8	0.00	1.00
09/23/2020 04:00	3	1.8	14.2	14.5	28.9	644,699.3	0.00	1.00
09/23/2020 05:00	3	1.9	14.7	14.3	34.4	677,450.1	0.00	1.00
09/23/2020 06:00	3	1.9	14.5	14.3	32.9	681,184.9	0.00	1.00
09/23/2020 07:00	3	1.9	13.8	14.4	31.9	710,836.6	0.00	1.00
09/23/2020 08:00	3	1.8	13.2	14.5	34.5	809,244.2	0.00	1.00
09/23/2020 09:00	2	1.8	10.7	14.5	26.6	912,165.0	0.00	1.00
09/23/2020 10:00	2	1.9	10.2	14.5	27.3	923,077.6	0.00	1.00
09/23/2020 11:00	2	2.0	11.5	13.9	30.6	915,558.0	0.00	1.00
09/23/2020 12:00	2	2.1	12.6	13.6	31.3	923,517.3	0.00	1.00
09/23/2020 13:00	2	2.2	13.1	13.4	33.2	919,522.8	0.00	1.00
09/23/2020 14:00	3	2.4	16.3	12.5	42.1	931,860.7	0.00	1.00
09/23/2020 15:00	3	2.3	14.2	13.0	35.8	915,087.5	0.00	1.00
09/23/2020 16:00	3	2.4	16.3	12.4	42.2	925,408.7	0.00	1.00
09/23/2020 17:00	4	2.6	17.2	11.8	48.4	929,101.8	0.00	1.00
09/23/2020 18:00	4	2.6	16.6	11.9	46.1	923,448.5	0.00	1.00
09/23/2020 19:00	3	2.3	13.9	13.0	34.6	918,034.4	0.00	1.00
09/23/2020 20:00	2	2.1	11.3	13.9	27.8	911,058.5	0.00	1.00
09/23/2020 21:00	2	2.0	10.4	14.2	26.5	903,206.9	0.00	1.00
09/23/2020 22:00	3	2.3	13.9	14.4	28.9	778,675.8	0.10	1.00
09/23/2020 23:00	0	11.6	32.2	16.6	0.0	412,419.7	0.05	0.05
Average/Sum#:	3	2.5	14.4	13.9	31.5	801,322.1	0.15 #	23.05 #
Minimum:	2	1.8	10.2	11.8	0.0	412,419.7	0.00	0.05
Maximum:	4	11.6	32.2	16.6	48.4	931,860.7	0.10	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2020 04:00	0	24.9	29.0	17.6	0.0	649,024.2	0.27	0.27
09/28/2020 05:00	4	4.7	15.9	14.3	21.9	666,038.2	0.60	1.00
09/28/2020 06:00	3	1.9	15.2	14.4	32.6	649,107.2	0.00	1.00
09/28/2020 07:00	3	1.9	14.3	14.4	32.2	693,139.4	0.00	1.00
09/28/2020 08:00	3	1.8	13.9	14.5	37.5	790,842.6	0.00	1.00
09/28/2020 09:00	3	1.8	13.8	14.6	36.4	803,830.4	0.00	1.00
09/28/2020 10:00	3	1.8	13.5	14.6	35.1	787,310.3	0.00	1.00
09/28/2020 11:00	2	1.8	11.8	14.6	28.8	827,523.6	0.00	1.00
09/28/2020 12:00	2	1.8	11.9	14.5	30.6	858,885.9	0.00	1.00
09/28/2020 13:00	4	2.5	18.5	11.9	51.8	928,469.7	0.00	1.00
09/28/2020 14:00	4	2.6	18.6	11.9	51.8	921,622.6	0.00	1.00
09/28/2020 15:00	4	2.6	18.4	12.0	50.8	922,284.2	0.00	1.00
09/28/2020 16:00	3	2.2	14.2	13.3	35.6	908,324.8	0.00	1.00
09/28/2020 17:00	2	2.1	12.5	13.8	31.7	905,170.2	0.00	1.00
09/28/2020 18:00	2	1.9	11.3	14.2	29.4	899,732.3	0.00	1.00
09/28/2020 19:00	2	1.9	11.6	14.5	31.0	858,030.0	0.00	1.00
09/28/2020 20:00	3	1.8	13.5	14.5	35.7	780,785.9	0.00	1.00
09/28/2020 21:00	3	1.8	14.3	14.6	31.3	671,887.4	0.00	1.00
09/28/2020 22:00	3	1.8	13.8	14.5	28.1	641,061.8	0.00	1.00
09/28/2020 23:00	3	1.8	13.1	14.5	32.4	773,296.8	0.00	1.00
Average/Sum#:	3	3.3	15.0	14.2	33.2	796,818.4	0.87 #	19.27 #
Minimum:	2	1.8	11.3	11.9	0.0	641,061.8	0.00	0.00
Maximum:	4	24.9	29.0	17.6	51.8	928,469.7	0.60	1.00
%SI	20.83	16.67	16.67	16.67	16.67	16.67	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/29/2020 00:00	3	1.9	14.5	14.5	32.2	668,664.2	0.00	1.00
09/29/2020 01:00	3	1.8	14.3	14.5	30.0	641,275.8	0.00	1.00
09/29/2020 02:00	3	1.9	13.9	14.5	29.0	639,350.0	0.00	1.00
09/29/2020 03:00	3	1.9	13.9	14.5	29.3	640,633.8	0.00	1.00
09/29/2020 04:00	3	1.8	15.0	14.4	33.1	653,531.5	0.00	1.00
09/29/2020 05:00	3	1.9	14.2	14.5	30.7	638,922.1	0.00	1.00
09/29/2020 06:00	3	1.9	13.9	14.5	29.9	636,782.3	0.00	1.00
09/29/2020 07:00	4	1.9	14.9	14.4	35.3	661,326.6	0.00	1.00
09/29/2020 08:00	3	1.9	13.4	14.5	32.8	740,131.1	0.00	1.00
09/29/2020 09:00	3	1.8	13.5	14.6	35.3	797,309.3	0.00	1.00
09/29/2020 10:00	2	1.8	10.8	14.5	26.7	874,719.8	0.00	1.00
09/29/2020 11:00	2	1.9	11.0	14.2	29.1	917,309.9	0.00	1.00
09/29/2020 12:00	3	2.4	16.5	12.6	41.8	936,818.3	0.00	1.00
09/29/2020 13:00	3	2.5	17.0	12.3	44.0	925,316.9	0.00	1.00
09/29/2020 14:00	4	2.5	17.3	12.1	46.1	923,739.0	0.00	1.00
09/29/2020 15:00	3	2.5	16.7	12.3	43.2	916,399.7	0.00	1.00
09/29/2020 16:00	3	2.4	15.9	12.7	39.5	922,691.4	0.00	1.00
09/29/2020 17:00	3	2.4	16.0	12.5	41.1	915,884.1	0.00	1.00
09/29/2020 18:00	2	2.1	12.0	13.9	29.4	907,341.5	0.00	1.00
09/29/2020 19:00	3	1.9	12.4	14.4	32.7	810,277.9	0.00	1.00
09/29/2020 20:00	2	1.9	10.5	14.3	27.4	910,252.2	0.00	1.00
09/29/2020 21:00	2	2.1	13.3	13.4	34.7	928,104.6	0.00	1.00
09/29/2020 22:00	2	1.9	10.8	14.5	28.6	869,156.5	0.00	1.00
09/29/2020 23:00	3	1.8	13.2	14.5	27.5	647,694.9	0.00	1.00
Average/Sum#:	3	2.0	14.0	13.9	33.7	796,818.1	0.00 #	24.00 #
Minimum:	2	1.8	10.5	12.1	26.7	636,782.3	0.00	1.00
Maximum:	4	2.5	17.3	14.6	46.1	936,818.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:07 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 NOx, _SCR, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 NH3Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/30/2020 00:00	2	1.8	13.1	14.5	26.2	641,275.8	0.00	1.00
09/30/2020 01:00	3	1.9	13.0	14.5	26.5	643,201.5	0.00	1.00
09/30/2020 02:00	3	1.9	13.9	14.4	30.1	652,899.4	0.00	1.00
09/30/2020 03:00	3	1.9	13.2	14.5	26.9	642,987.5	0.00	1.00
09/30/2020 04:00	3	1.8	13.6	14.5	27.6	640,847.8	0.00	1.00
09/30/2020 05:00	3	1.9	13.7	14.4	29.4	631,410.0	0.00	1.00
09/30/2020 06:00	3	1.9	13.7	14.5	29.0	640,847.8	0.00	1.00
09/30/2020 07:00	3	1.9	13.4	14.5	28.3	641,275.8	0.00	1.00
09/30/2020 08:00	3	1.9	13.5	14.4	31.4	701,356.0	0.00	1.00
09/30/2020 09:00	3	1.8	12.9	14.5	30.9	749,545.9	0.00	1.00
09/30/2020 10:00	2	1.9	11.1	14.3	28.1	884,523.7	0.00	1.00
09/30/2020 11:00	2	2.0	11.5	14.1	31.2	916,507.4	0.00	1.00
09/30/2020 12:00	3	2.2	15.1	13.0	37.6	922,194.6	0.00	1.00
09/30/2020 13:00	4	2.6	18.4	11.8	50.1	919,019.2	0.00	1.00
09/30/2020 14:00	4	2.6	18.3	11.7	51.8	917,067.8	0.00	1.00
09/30/2020 15:00	4	2.5	17.5	12.1	46.9	911,445.3	0.00	1.00
09/30/2020 16:00	4	2.6	17.7	11.9	48.8	910,819.4	0.00	1.00
09/30/2020 17:00	3	2.4	16.0	12.7	41.3	918,683.4	0.00	1.00
09/30/2020 18:00	3	2.2	14.5	13.1	36.7	909,087.1	0.00	1.00
09/30/2020 19:00	2	2.0	12.0	13.9	30.4	895,994.8	0.00	1.00
09/30/2020 20:00	2	2.0	11.2	14.2	29.7	907,294.8	0.00	1.00
09/30/2020 21:00	2	2.1	13.6	13.4	35.3	920,983.5	0.00	1.00
09/30/2020 22:00	2	2.0	10.9	14.3	29.4	901,537.7	0.00	1.00
09/30/2020 23:00	3	1.9	13.0	14.5	36.3	819,087.0	0.00	1.00
Average/Sum#:	3	2.1	14.0	13.7	34.2	801,662.2	0.00 #	24.00 #
Minimum:	2	1.8	10.9	11.7	26.2	631,410.0	0.00	1.00
Maximum:	4	2.6	18.4	14.5	51.8	922,194.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/01/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/02/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/03/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/04/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/05/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2020 03:00	0	23.5	29.3	17.4	0.0	621,718.7	0.27	0.27
07/13/2020 04:00	1	6.7	18.1	14.5	26.2	843,907.8	0.65	1.00
07/13/2020 05:00	1	1.9	17.7	14.4	36.6	866,108.3	0.00	1.00
07/13/2020 06:00	1	1.8	17.0	14.4	33.4	860,841.2	0.00	1.00
07/13/2020 07:00	1	2.0	15.9	14.2	21.5	633,001.1	0.00	1.00
07/13/2020 08:00	1	1.9	15.0	14.2	22.1	651,192.0	0.00	1.00
07/13/2020 09:00	1	1.9	13.7	14.4	24.2	756,975.7	0.00	1.00
07/13/2020 10:00	1	1.9	15.4	14.5	33.2	867,872.7	0.00	1.00
07/13/2020 11:00	2	2.1	17.4	13.5	36.3	890,125.8	0.00	1.00
07/13/2020 12:00	2	2.2	17.6	13.3	37.1	882,558.0	0.00	1.00
07/13/2020 13:00	2	2.1	16.9	13.5	36.2	871,620.1	0.00	1.00
07/13/2020 14:00	2	2.2	17.6	13.3	37.0	882,558.0	0.00	1.00
07/13/2020 15:00	2	2.2	17.6	13.3	37.8	881,476.9	0.00	1.00
07/13/2020 16:00	2	2.1	16.8	13.6	36.4	869,115.5	0.00	1.00
07/13/2020 17:00	2	2.2	17.4	13.3	37.9	876,972.2	0.00	1.00
07/13/2020 18:00	3	2.5	19.8	12.2	45.5	902,875.7	0.00	1.00
07/13/2020 19:00	2	2.3	18.1	13.1	38.7	871,866.9	0.00	1.00
07/13/2020 20:00	1	1.9	14.1	14.4	21.1	598,122.4	0.00	1.00
07/13/2020 21:00	1	1.9	14.8	14.5	22.6	601,048.9	0.00	1.00
07/13/2020 22:00	1	1.8	14.6	14.5	22.6	601,690.8	0.00	1.00
07/13/2020 23:00	1	1.9	14.5	14.5	22.6	602,546.7	0.00	1.00
Average/Sum#:	2	3.3	17.1	14.0	30.0	782,580.7	0.92 #	20.27 #
Minimum:	1	1.8	13.7	12.2	0.0	598,122.4	0.00	0.00
Maximum:	3	23.5	29.3	17.4	45.5	902,875.7	0.65	1.00
%SI	16.67	12.50	12.50	12.50	12.50	12.50	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/14/2020 00:00	2	1.9	15.0	14.4	23.9	603,810.8	0.00	1.00
07/14/2020 01:00	2	1.9	15.9	14.3	26.4	625,992.9	0.00	1.00
07/14/2020 02:00	2	1.9	15.6	14.5	24.7	600,407.0	0.00	1.00
07/14/2020 03:00	2	1.9	16.0	14.5	25.7	601,048.9	0.00	1.00
07/14/2020 04:00	2	1.9	16.2	14.4	25.3	612,027.4	0.00	1.00
07/14/2020 05:00	2	1.9	16.7	14.4	27.0	592,012.7	0.00	1.00
07/14/2020 06:00	2	1.9	16.4	14.5	25.8	601,048.9	0.00	1.00
07/14/2020 07:00	2	1.9	15.9	14.3	25.4	616,241.0	0.00	1.00
07/14/2020 08:00	1	1.8	14.8	14.3	23.1	674,752.7	0.00	1.00
07/14/2020 09:00	1	1.8	14.0	14.5	26.0	768,375.5	0.00	1.00
07/14/2020 10:00	2	1.7	14.5	14.5	33.4	853,108.6	0.00	1.00
07/14/2020 11:00	1	2.0	16.1	13.7	37.4	856,460.8	0.00	1.00
07/14/2020 12:00	2	2.3	19.0	12.8	39.3	894,183.4	0.00	1.00
07/14/2020 13:00	0	0.0	15.7	0.0	29.8	293,803.8	0.00	1.00
07/14/2020 14:00	2	2.3	19.0	12.6	41.1	889,960.9	0.00	1.00
07/14/2020 15:00	3	2.6	20.3	11.9	48.4	900,472.6	0.00	1.00
07/14/2020 16:00	3	2.6	20.3	11.9	49.3	905,189.5	0.00	1.00
07/14/2020 17:00	3	2.6	20.2	12.0	48.9	907,051.3	0.00	1.00
07/14/2020 18:00	2	2.3	18.9	12.8	40.9	891,816.5	0.00	1.00
07/14/2020 19:00	2	2.1	16.1	13.8	34.6	867,173.5	0.00	1.00
07/14/2020 20:00	1	1.9	13.1	14.3	22.9	741,564.1	0.00	1.00
07/14/2020 21:00	1	1.9	13.0	14.3	21.5	705,668.5	0.00	1.00
07/14/2020 22:00	1	1.9	13.2	14.3	22.0	697,369.0	0.00	1.00
07/14/2020 23:00	1	1.9	14.2	14.4	22.0	612,659.4	0.00	1.00
Average/Sum#:	2	2.0	16.3	13.8	31.0	739,930.3	0.00 #	24.00 #
Minimum:	1	1.7	13.0	11.9	21.5	592,012.7	0.00	1.00
Maximum:	3	2.6	20.3	14.5	49.3	907,051.3	0.00	1.00
%SI	4.17	4.17	0.00	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/15/2020 00:00	2	1.9	15.1	14.4	23.9	602,125.4	0.00	1.00
07/15/2020 01:00	2	1.9	15.7	14.4	25.3	594,119.5	0.00	1.00
07/15/2020 02:00	2	1.9	16.2	14.4	25.8	591,802.0	0.00	1.00
07/15/2020 03:00	2	1.9	16.2	14.4	25.7	591,380.7	0.00	1.00
07/15/2020 04:00	2	1.8	16.8	14.4	26.2	592,855.4	0.00	1.00
07/15/2020 05:00	2	1.9	16.8	14.4	26.7	592,644.7	0.00	1.00
07/15/2020 06:00	2	1.9	16.5	14.4	26.0	592,644.7	0.00	1.00
07/15/2020 07:00	2	1.9	16.0	14.4	24.6	593,487.5	0.00	1.00
07/15/2020 08:00	1	1.9	14.0	14.2	21.5	661,615.9	0.00	1.00
07/15/2020 09:00	1	1.9	13.0	14.3	23.5	744,053.9	0.00	1.00
07/15/2020 10:00	1	1.9	14.7	14.4	32.3	859,787.8	0.00	1.00
07/15/2020 11:00	2	2.1	16.8	13.5	36.0	886,424.7	0.00	1.00
07/15/2020 12:00	2	2.4	19.4	12.5	42.5	900,396.5	0.00	1.00
07/15/2020 13:00	3	2.5	19.6	12.4	43.9	896,409.1	0.00	1.00
07/15/2020 14:00	3	2.6	19.7	11.9	48.1	896,212.2	0.00	1.00
07/15/2020 15:00	3	2.6	19.8	11.8	50.1	898,252.1	0.00	1.00
07/15/2020 16:00	3	2.6	19.7	11.8	49.6	900,358.9	0.00	1.00
07/15/2020 17:00	3	2.6	19.7	11.8	49.6	897,198.7	0.00	1.00
07/15/2020 18:00	3	2.5	20.0	12.3	45.9	898,087.6	0.00	1.00
07/15/2020 19:00	2	2.1	15.8	13.9	34.5	861,954.8	0.00	1.00
07/15/2020 20:00	1	1.9	13.2	14.3	19.8	684,919.7	0.00	1.00
07/15/2020 21:00	1	1.9	14.0	14.4	21.5	606,971.0	0.00	1.00
07/15/2020 22:00	1	1.9	14.5	14.4	22.2	592,223.4	0.00	1.00
07/15/2020 23:00	2	1.9	15.3	14.4	23.8	592,434.1	0.00	1.00
Average/Sum#:	2	2.1	16.6	13.6	32.0	730,348.3	0.00 #	24.00 #
Minimum:	1	1.8	13.0	11.8	19.8	591,380.7	0.00	1.00
Maximum:	3	2.6	20.0	14.4	50.1	900,396.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/16/2020 00:00	2	1.9	15.9	14.4	25.1	592,434.1	0.00	1.00
07/16/2020 01:00	2	1.9	16.2	14.4	25.8	592,644.7	0.00	1.00
07/16/2020 02:00	2	1.9	16.4	14.4	26.0	592,855.4	0.00	1.00
07/16/2020 03:00	2	1.9	16.6	14.4	26.3	593,276.8	0.00	1.00
07/16/2020 04:00	2	1.9	17.2	14.4	26.9	593,698.1	0.00	1.00
07/16/2020 05:00	2	1.9	17.0	14.4	27.1	593,066.1	0.00	1.00
07/16/2020 06:00	2	1.9	16.6	14.4	25.8	594,119.5	0.00	1.00
07/16/2020 07:00	2	1.9	15.8	14.4	24.2	596,226.3	0.00	1.00
07/16/2020 08:00	1	1.9	15.0	14.2	22.9	639,132.8	0.00	1.00
07/16/2020 09:00	1	1.9	13.0	14.3	22.3	738,451.7	0.00	1.00
07/16/2020 10:00	1	1.9	13.9	14.5	29.5	859,527.8	0.00	1.00
07/16/2020 11:00	2	2.0	15.6	13.9	33.9	870,367.0	0.00	1.00
07/16/2020 12:00	2	2.4	19.4	12.5	41.4	895,831.8	0.00	1.00
07/16/2020 13:00	2	2.3	18.0	13.0	38.7	886,659.0	0.00	1.00
07/16/2020 14:00	2	2.3	18.4	12.9	39.5	891,152.9	0.00	1.00
07/16/2020 15:00	3	2.6	19.7	11.7	49.2	896,228.7	0.00	1.00
07/16/2020 16:00	3	2.6	19.7	11.7	49.7	895,782.2	0.00	1.00
07/16/2020 17:00	3	2.6	19.8	11.7	50.4	896,675.3	0.00	1.00
07/16/2020 18:00	2	2.3	18.2	12.9	39.6	880,026.3	0.00	1.00
07/16/2020 19:00	1	1.9	13.8	14.4	27.8	811,963.3	0.00	1.00
07/16/2020 20:00	1	1.9	14.6	14.2	23.0	657,732.5	0.00	1.00
07/16/2020 21:00	1	2.0	14.5	14.2	22.9	644,855.8	0.00	1.00
07/16/2020 22:00	2	1.9	15.4	14.4	24.3	595,172.9	0.00	1.00
07/16/2020 23:00	2	1.9	15.4	14.4	24.2	608,445.8	0.00	1.00
Average/Sum#:	2	2.1	16.5	13.8	31.1	725,680.3	0.00 #	24.00 #
Minimum:	1	1.9	13.0	11.7	22.3	592,434.1	0.00	1.00
Maximum:	3	2.6	19.8	14.5	50.4	896,675.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/17/2020 00:00	2	1.9	16.0	14.4	25.4	595,804.9	0.00	1.00
07/17/2020 01:00	2	1.9	16.3	14.4	26.0	593,698.1	0.00	1.00
07/17/2020 02:00	2	1.9	16.5	14.4	26.3	593,698.1	0.00	1.00
07/17/2020 03:00	2	1.9	16.6	14.4	26.5	593,487.5	0.00	1.00
07/17/2020 04:00	2	1.8	17.1	14.4	26.8	593,698.1	0.00	1.00
07/17/2020 05:00	2	1.9	16.9	14.4	27.0	593,908.8	0.00	1.00
07/17/2020 06:00	2	1.9	16.7	14.4	26.3	593,908.8	0.00	1.00
07/17/2020 07:00	2	1.9	16.1	14.4	24.9	594,962.2	0.00	1.00
07/17/2020 08:00	1	1.9	15.2	14.2	23.7	633,818.7	0.00	1.00
07/17/2020 09:00	1	1.9	13.3	14.4	22.6	732,958.1	0.00	1.00
07/17/2020 10:00	1	1.9	14.5	14.6	30.2	830,566.8	0.00	1.00
07/17/2020 11:00	1	1.8	14.8	14.5	31.2	869,370.5	0.00	1.00
07/17/2020 12:00	1	1.9	13.0	14.3	20.3	707,535.9	0.00	1.00
07/17/2020 13:00	1	1.9	13.8	14.5	30.5	852,894.6	0.00	1.00
07/17/2020 14:00	2	2.0	16.0	13.9	35.3	858,824.7	0.00	1.00
07/17/2020 15:00	3	2.4	20.1	12.4	45.1	903,820.1	0.00	1.00
07/17/2020 16:00	3	2.6	20.3	12.0	49.9	912,436.7	0.00	1.00
07/17/2020 17:00	3	2.4	19.8	12.5	44.8	902,189.8	0.00	1.00
07/17/2020 18:00	2	2.2	17.2	13.4	37.7	891,038.8	0.00	1.00
07/17/2020 19:00	2	1.9	14.9	14.3	32.2	821,032.2	0.00	1.00
07/17/2020 20:00	1	1.9	14.1	14.4	23.4	710,415.2	0.00	1.00
07/17/2020 21:00	1	1.9	14.0	14.4	24.9	717,578.4	0.00	1.00
07/17/2020 22:00	1	1.9	14.0	14.5	26.8	761,100.4	0.00	1.00
07/17/2020 23:00	2	1.9	15.5	14.3	25.5	639,479.7	0.00	1.00
Average/Sum#:	2	2.0	15.9	14.1	29.7	729,092.8	0.00 #	24.00 #
Minimum:	1	1.8	13.0	12.0	20.3	593,487.5	0.00	1.00
Maximum:	3	2.6	20.3	14.6	49.9	912,436.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/18/2020 00:00	1	1.9	14.8	14.5	22.6	600,834.9	0.00	1.00
07/18/2020 01:00	1	1.9	15.1	14.5	23.9	600,193.0	0.00	1.00
07/18/2020 02:00	2	1.9	15.4	14.5	24.2	600,407.0	0.00	1.00
07/18/2020 03:00	2	1.9	15.6	14.5	24.7	600,621.0	0.00	1.00
07/18/2020 04:00	1	1.8	16.3	14.5	25.3	600,621.0	0.00	1.00
07/18/2020 05:00	1	1.9	16.2	14.5	25.6	600,407.0	0.00	1.00
07/18/2020 06:00	2	1.9	15.8	14.5	24.7	600,834.9	0.00	1.00
07/18/2020 07:00	1	1.9	15.2	14.5	23.5	602,760.7	0.00	1.00
07/18/2020 08:00	1	1.9	15.0	14.3	24.0	651,099.0	0.00	1.00
07/18/2020 09:00	1	1.9	13.7	14.5	24.8	754,895.2	0.00	1.00
07/18/2020 10:00	1	1.8	14.5	14.5	30.9	860,383.7	0.00	1.00
07/18/2020 11:00	2	2.1	17.0	13.4	35.0	882,457.1	0.00	1.00
07/18/2020 12:00	1	1.9	13.5	14.4	27.9	821,443.9	0.00	1.00
07/18/2020 13:00	2	2.1	16.5	13.5	35.6	886,424.7	0.00	1.00
07/18/2020 14:00	3	2.6	20.1	11.8	48.4	903,218.1	0.00	1.00
07/18/2020 15:00	3	2.7	19.9	11.7	50.3	901,289.6	0.00	1.00
07/18/2020 16:00	3	2.6	19.9	11.9	48.5	894,842.8	0.00	1.00
07/18/2020 17:00	3	2.6	20.0	12.0	48.5	899,204.1	0.00	1.00
07/18/2020 18:00	3	2.6	19.9	12.0	48.6	902,435.3	0.00	1.00
07/18/2020 19:00	2	2.3	18.8	12.8	40.7	884,715.8	0.00	1.00
07/18/2020 20:00	1	1.9	15.0	14.4	33.0	857,470.3	0.00	1.00
07/18/2020 21:00	1	1.8	14.9	14.5	31.8	844,549.7	0.00	1.00
07/18/2020 22:00	2	2.1	16.7	13.6	35.8	880,558.6	0.00	1.00
07/18/2020 23:00	1	1.9	14.3	14.4	21.0	608,867.1	0.00	1.00
Average/Sum#:	2	2.1	16.4	13.7	32.5	760,022.3	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.7	21.0	600,193.0	0.00	1.00
Maximum:	3	2.7	20.1	14.5	50.3	903,218.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/19/2020 00:00	1	1.9	14.4	14.5	21.9	599,551.1	0.00	1.00
07/19/2020 01:00	1	1.9	14.5	14.5	22.5	599,765.1	0.00	1.00
07/19/2020 02:00	1	1.9	15.0	14.5	23.5	600,193.0	0.00	1.00
07/19/2020 03:00	2	1.9	15.4	14.5	24.2	600,407.0	0.00	1.00
07/19/2020 04:00	1	1.8	16.1	14.5	25.0	600,407.0	0.00	1.00
07/19/2020 05:00	1	1.9	16.1	14.5	25.4	600,621.0	0.00	1.00
07/19/2020 06:00	1	1.9	15.7	14.5	24.3	600,834.9	0.00	1.00
07/19/2020 07:00	1	1.9	15.1	14.5	23.0	600,407.0	0.00	1.00
07/19/2020 08:00	1	1.9	14.7	14.5	23.0	603,830.6	0.00	1.00
07/19/2020 09:00	1	1.8	14.5	14.4	23.7	679,866.5	0.00	1.00
07/19/2020 10:00	1	1.9	14.4	14.6	29.3	838,609.4	0.00	1.00
07/19/2020 11:00	2	2.0	15.9	13.8	34.6	878,939.0	0.00	1.00
07/19/2020 12:00	2	2.2	17.7	13.1	37.4	887,141.2	0.00	1.00
07/19/2020 13:00	2	2.3	18.3	12.8	39.6	884,208.6	0.00	1.00
07/19/2020 14:00	3	2.6	19.9	11.8	49.6	904,572.5	0.00	1.00
07/19/2020 15:00	3	2.6	19.9	11.7	50.5	896,824.1	0.00	1.00
07/19/2020 16:00	3	2.5	19.6	12.3	45.0	891,718.2	0.00	1.00
07/19/2020 17:00	3	2.6	20.2	11.9	49.4	896,060.0	0.00	1.00
07/19/2020 18:00	2	2.4	19.3	12.7	42.9	897,808.0	0.00	1.00
07/19/2020 19:00	2	2.0	15.3	14.1	34.6	853,473.6	0.00	1.00
07/19/2020 20:00	1	1.9	14.1	14.4	29.6	836,613.0	0.00	1.00
07/19/2020 21:00	1	1.9	13.7	14.4	24.4	741,385.3	0.00	1.00
07/19/2020 22:00	1	1.9	14.4	14.5	22.5	628,437.4	0.00	1.00
07/19/2020 23:00	1	1.9	13.9	14.4	23.8	701,356.0	0.00	1.00
Average/Sum#:	2	2.1	16.2	13.8	31.2	742,626.2	0.00 #	24.00 #
Minimum:	1	1.8	13.7	11.7	21.9	599,551.1	0.00	1.00
Maximum:	3	2.6	20.2	14.6	50.5	904,572.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/20/2020 00:00	2	1.9	15.6	14.3	26.3	631,595.1	0.00	1.00
07/20/2020 01:00	2	1.9	15.9	14.5	25.6	608,751.9	0.00	1.00
07/20/2020 02:00	2	1.9	16.2	14.5	26.3	601,904.8	0.00	1.00
07/20/2020 03:00	2	1.9	15.9	14.4	25.3	606,760.3	0.00	1.00
07/20/2020 04:00	2	1.8	16.1	14.3	26.0	616,033.5	0.00	1.00
07/20/2020 05:00	2	1.9	17.3	14.4	28.6	592,644.7	0.00	1.00
07/20/2020 06:00	2	1.9	17.0	14.4	27.4	592,644.7	0.00	1.00
07/20/2020 07:00	2	1.9	16.5	14.5	25.9	601,262.9	0.00	1.00
07/20/2020 08:00	1	1.9	15.7	14.5	24.4	603,188.6	0.00	1.00
07/20/2020 09:00	1	1.9	13.7	14.4	22.3	709,572.5	0.00	1.00
07/20/2020 10:00	1	1.9	14.8	14.5	32.1	873,863.9	0.00	1.00
07/20/2020 11:00	1	1.9	15.0	14.4	32.1	862,526.7	0.00	1.00
07/20/2020 12:00	1	1.9	14.8	14.5	32.2	873,222.0	0.00	1.00
07/20/2020 13:00	2	2.2	17.3	13.3	37.2	897,513.5	0.00	1.00
07/20/2020 14:00	2	2.4	19.4	12.4	43.6	898,181.3	0.00	1.00
07/20/2020 15:00	3	2.5	19.8	12.2	45.6	902,875.7	0.00	1.00
07/20/2020 16:00	3	2.5	19.8	12.2	45.8	902,403.4	0.00	1.00
07/20/2020 17:00	3	2.5	19.5	12.4	44.2	899,631.3	0.00	1.00
07/20/2020 18:00	2	2.2	16.9	13.3	36.7	875,710.9	0.00	1.00
07/20/2020 19:00	2	2.1	16.4	13.6	36.2	884,122.9	0.00	1.00
07/20/2020 20:00	1	2.0	14.8	14.2	31.6	833,713.7	0.00	1.00
07/20/2020 21:00	1	1.9	14.1	14.3	22.0	671,017.9	0.00	1.00
07/20/2020 22:00	1	1.9	14.8	14.5	23.3	611,533.6	0.00	1.00
07/20/2020 23:00	1	1.9	14.5	14.3	23.8	663,548.4	0.00	1.00
Average/Sum#:	2	2.0	16.3	13.9	31.0	742,259.3	0.00 #	24.00 #
Minimum:	1	1.8	13.7	12.2	22.0	592,644.7	0.00	1.00
Maximum:	3	2.5	19.8	14.5	45.8	902,875.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/21/2020 00:00	2	1.9	15.5	14.4	25.3	611,395.3	0.00	1.00
07/21/2020 01:00	2	1.9	15.0	14.4	23.6	599,807.9	0.00	1.00
07/21/2020 02:00	2	1.9	15.9	14.4	25.5	594,330.2	0.00	1.00
07/21/2020 03:00	2	1.9	15.3	14.3	24.6	605,659.1	0.00	1.00
07/21/2020 04:00	1	1.9	14.7	14.4	23.9	664,697.5	0.02	1.00
07/21/2020 05:00	0	9.7	32.0	15.7	0.0	454,280.2	0.15	0.15
07/21/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	3.2	18.1	14.6	20.5	588,361.7	0.17 #	5.15 #
Minimum:	1	1.9	14.7	14.3	0.0	454,280.2	0.00	0.00
Maximum:	2	9.7	32.0	15.7	25.5	664,697.5	0.15	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/22/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/23/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2020 22:00	0	23.5	28.2	17.5	0.0	608,185.5	0.28	0.28
07/25/2020 23:00	1	5.5	17.2	14.5	26.3	832,995.2	0.57	1.00
Average/Sum#:	1	14.5	22.7	16.0	13.2	720,590.4	0.85 #	1.28 #
Minimum:	1	5.5	17.2	14.5	0.0	608,185.5	0.00	0.00
Maximum:	1	23.5	28.2	17.5	26.3	832,995.2	0.57	1.00
%SI	95.83	91.67	91.67	91.67	91.67	91.67	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/26/2020 00:00	1	1.9	17.0	14.4	35.4	867,583.0	0.00	1.00
07/26/2020 01:00	1	1.9	15.5	14.4	26.0	755,922.3	0.00	1.00
07/26/2020 02:00	1	1.9	15.5	14.3	25.5	680,147.4	0.00	1.00
07/26/2020 03:00	1	1.9	16.1	14.4	24.4	603,389.5	0.00	1.00
07/26/2020 04:00	1	1.8	15.9	14.5	24.0	602,118.8	0.00	1.00
07/26/2020 05:00	1	1.8	16.2	14.5	24.7	604,258.5	0.00	1.00
07/26/2020 06:00	1	1.9	15.6	14.3	24.4	616,655.9	0.00	1.00
07/26/2020 07:00	1	1.9	15.6	14.2	24.4	618,693.7	0.00	1.00
07/26/2020 08:00	1	1.9	15.4	14.2	24.1	623,190.3	0.00	1.00
07/26/2020 09:00	1	1.9	15.2	14.2	23.8	623,803.5	0.00	1.00
07/26/2020 10:00	1	1.9	15.0	14.2	23.2	626,051.8	0.00	1.00
07/26/2020 11:00	1	1.9	14.4	14.2	22.2	640,359.2	0.00	1.00
07/26/2020 12:00	1	1.9	14.6	14.3	31.0	844,685.9	0.00	1.00
07/26/2020 13:00	2	2.1	16.0	13.7	33.9	867,492.3	0.00	1.00
07/26/2020 14:00	2	2.2	17.3	13.3	37.5	887,242.9	0.00	1.00
07/26/2020 15:00	3	2.6	20.5	11.8	50.8	903,820.1	0.00	1.00
07/26/2020 16:00	3	2.6	20.4	11.8	51.3	904,572.5	0.00	1.00
07/26/2020 17:00	3	2.6	20.2	11.7	51.0	893,549.4	0.00	1.00
07/26/2020 18:00	3	2.6	20.4	11.8	51.1	904,422.0	0.00	1.00
07/26/2020 19:00	3	2.6	20.4	12.0	49.6	905,051.0	0.00	1.00
07/26/2020 20:00	2	2.4	19.7	12.6	43.6	891,445.8	0.00	1.00
07/26/2020 21:00	1	1.9	13.5	14.3	22.4	723,720.0	0.00	1.00
07/26/2020 22:00	1	1.9	13.8	14.4	27.0	796,583.6	0.00	1.00
07/26/2020 23:00	1	1.9	14.8	14.5	31.2	829,357.6	0.00	1.00
Average/Sum#:	2	2.1	16.6	13.7	32.6	758,921.5	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.7	22.2	602,118.8	0.00	1.00
Maximum:	3	2.6	20.5	14.5	51.3	905,051.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/27/2020 00:00	1	1.8	14.8	14.5	26.0	755,537.1	0.00	1.00
07/27/2020 01:00	1	1.9	14.3	14.4	24.2	717,578.4	0.00	1.00
07/27/2020 02:00	1	1.9	15.0	14.3	23.8	668,528.1	0.00	1.00
07/27/2020 03:00	1	1.9	14.9	14.4	23.7	684,922.9	0.00	1.00
07/27/2020 04:00	1	1.9	16.5	14.3	25.4	628,690.3	0.00	1.00
07/27/2020 05:00	1	1.9	16.4	14.4	25.1	625,510.9	0.00	1.00
07/27/2020 06:00	1	1.9	16.3	14.3	25.3	626,822.9	0.00	1.00
07/27/2020 07:00	1	1.9	16.1	14.3	25.4	634,292.5	0.00	1.00
07/27/2020 08:00	1	1.9	15.5	14.3	23.9	644,874.4	0.00	1.00
07/27/2020 09:00	1	1.9	13.5	14.4	22.8	735,907.6	0.00	1.00
07/27/2020 10:00	2	1.9	15.6	14.1	34.2	865,154.0	0.00	1.00
07/27/2020 11:00	2	2.2	17.5	13.3	36.9	888,143.8	0.00	1.00
07/27/2020 12:00	2	2.5	20.0	12.4	44.1	899,470.2	0.00	1.00
07/27/2020 13:00	2	2.3	17.8	13.1	38.1	879,240.7	0.00	1.00
07/27/2020 14:00	3	2.7	19.8	11.8	49.0	898,854.0	0.00	1.00
07/27/2020 15:00	3	2.7	19.7	11.7	50.3	892,358.6	0.00	1.00
07/27/2020 16:00	3	2.6	19.8	11.7	50.3	892,060.9	0.00	1.00
07/27/2020 17:00	3	2.7	20.0	11.7	51.0	894,144.8	0.00	1.00
07/27/2020 18:00	3	2.6	20.1	11.8	50.7	898,402.6	0.00	1.00
07/27/2020 19:00	2	2.4	19.7	12.5	44.2	891,267.0	0.00	1.00
07/27/2020 20:00	2	2.3	19.0	12.9	41.5	878,656.9	0.00	1.00
07/27/2020 21:00	1	1.9	14.4	14.4	22.5	693,139.4	0.00	1.00
07/27/2020 22:00	1	1.9	14.5	14.4	25.3	713,575.4	0.00	1.00
07/27/2020 23:00	1	1.9	14.5	14.4	23.7	686,397.6	0.00	1.00
Average/Sum#:	2	2.1	16.9	13.5	33.6	774,730.5	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.7	22.5	625,510.9	0.00	1.00
Maximum:	3	2.7	20.1	14.5	51.0	899,470.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/28/2020 00:00	1	1.9	14.9	14.5	22.8	603,402.6	0.00	1.00
07/28/2020 01:00	1	1.9	15.0	14.5	23.3	599,337.1	0.00	1.00
07/28/2020 02:00	1	1.9	14.9	14.5	22.9	602,546.7	0.00	1.00
07/28/2020 03:00	1	1.9	15.0	14.5	23.4	602,546.7	0.00	1.00
07/28/2020 04:00	1	1.8	16.1	14.5	24.6	601,690.8	0.00	1.00
07/28/2020 05:00	2	1.9	16.3	14.5	25.3	600,407.0	0.00	1.00
07/28/2020 06:00	2	1.9	16.0	14.5	25.0	600,621.0	0.00	1.00
07/28/2020 07:00	2	1.9	15.7	14.4	25.1	622,982.8	0.00	1.00
07/28/2020 08:00	1	1.9	14.3	14.4	22.9	692,086.0	0.00	1.00
07/28/2020 09:00	1	1.9	14.9	14.5	32.4	871,082.3	0.00	1.00
07/28/2020 10:00	2	2.2	18.3	13.1	38.5	897,499.7	0.00	1.00
07/28/2020 11:00	2	2.4	19.4	12.7	42.6	901,983.1	0.00	1.00
07/28/2020 12:00	2	2.4	19.5	12.5	43.2	889,310.7	0.00	1.00
07/28/2020 13:00	3	2.7	20.0	11.8	49.8	902,014.3	0.00	1.00
07/28/2020 14:00	3	2.6	19.6	12.0	47.2	887,356.2	0.00	1.00
07/28/2020 15:00	3	2.5	19.7	12.2	45.2	885,561.1	0.00	1.00
07/28/2020 16:00	3	2.5	19.3	12.4	43.5	884,970.4	0.00	1.00
07/28/2020 17:00	3	2.4	19.5	12.4	43.7	879,170.5	0.00	1.00
07/28/2020 18:00	2	2.2	16.8	13.5	36.5	871,064.9	0.00	1.00
07/28/2020 19:00	2	2.1	16.4	13.6	35.6	872,117.0	0.00	1.00
07/28/2020 20:00	2	2.2	17.4	13.3	37.9	883,458.9	0.00	1.00
07/28/2020 21:00	1	1.9	13.8	14.3	23.3	714,383.1	0.00	1.00
07/28/2020 22:00	1	1.9	14.7	14.5	22.7	622,232.2	0.00	1.00
07/28/2020 23:00	1	1.9	14.3	14.4	23.4	678,391.8	0.00	1.00
Average/Sum#:	2	2.1	16.7	13.6	32.5	756,925.7	0.00 #	24.00 #
Minimum:	1	1.8	13.8	11.8	22.7	599,337.1	0.00	1.00
Maximum:	3	2.7	20.0	14.5	49.8	902,014.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/29/2020 00:00	1	1.9	14.7	14.5	23.0	603,830.6	0.00	1.00
07/29/2020 01:00	1	1.9	14.7	14.5	22.9	598,695.2	0.00	1.00
07/29/2020 02:00	1	1.9	15.1	14.5	24.2	599,123.2	0.00	1.00
07/29/2020 03:00	2	1.9	15.5	14.5	24.5	599,551.1	0.00	1.00
07/29/2020 04:00	1	1.8	16.2	14.5	25.0	599,551.1	0.00	1.00
07/29/2020 05:00	2	1.9	16.2	14.5	25.4	599,979.1	0.00	1.00
07/29/2020 06:00	1	1.9	15.9	14.5	24.5	600,193.0	0.00	1.00
07/29/2020 07:00	1	1.9	15.2	14.5	23.1	599,337.1	0.00	1.00
07/29/2020 08:00	1	1.9	15.1	14.4	24.0	606,339.0	0.00	1.00
07/29/2020 09:00	1	1.9	15.2	14.3	24.0	640,309.6	0.00	1.00
07/29/2020 10:00	1	1.9	14.7	14.4	30.5	833,031.4	0.00	1.00
07/29/2020 11:00	2	2.1	16.7	13.7	35.5	882,898.3	0.00	1.00
07/29/2020 12:00	3	2.4	20.2	12.4	45.3	909,620.0	0.00	1.00
07/29/2020 13:00	3	2.6	20.5	11.9	51.7	907,776.2	0.00	1.00
07/29/2020 14:00	3	2.6	20.4	11.9	52.1	909,449.9	0.00	1.00
07/29/2020 15:00	4	2.6	20.4	11.9	52.8	910,058.6	0.00	1.00
07/29/2020 16:00	4	2.6	20.5	11.9	53.0	910,667.2	0.00	1.00
07/29/2020 17:00	3	2.6	20.7	11.9	53.0	908,841.3	0.00	1.00
07/29/2020 18:00	3	2.6	20.5	12.0	52.0	910,436.4	0.00	1.00
07/29/2020 19:00	2	2.0	15.8	14.0	35.8	867,103.6	0.00	1.00
07/29/2020 20:00	2	2.3	18.6	12.9	40.9	889,270.0	0.00	1.00
07/29/2020 21:00	1	1.9	14.4	14.3	24.2	685,334.7	0.00	1.00
07/29/2020 22:00	1	1.9	14.0	14.5	26.1	747,406.2	0.00	1.00
07/29/2020 23:00	1	1.9	14.8	14.3	24.1	661,681.0	0.00	1.00
Average/Sum#:	2	2.1	16.9	13.6	34.1	749,186.8	0.00 #	24.00 #
Minimum:	1	1.8	14.0	11.9	22.9	598,695.2	0.00	1.00
Maximum:	4	2.6	20.7	14.5	53.0	910,667.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/30/2020 00:00	1	1.8	14.7	14.5	22.6	602,546.7	0.00	1.00
07/30/2020 01:00	1	1.9	14.9	14.5	23.4	599,551.1	0.00	1.00
07/30/2020 02:00	1	1.9	15.4	14.5	24.8	599,979.1	0.00	1.00
07/30/2020 03:00	2	1.9	15.8	14.5	25.3	600,834.9	0.00	1.00
07/30/2020 04:00	1	1.8	16.6	14.5	26.0	601,048.9	0.00	1.00
07/30/2020 05:00	2	1.9	16.8	14.5	26.7	602,332.8	0.00	1.00
07/30/2020 06:00	2	1.9	16.4	14.5	26.0	601,904.8	0.00	1.00
07/30/2020 07:00	2	1.9	15.7	14.5	24.4	600,407.0	0.00	1.00
07/30/2020 08:00	1	1.9	14.9	14.5	22.9	599,765.1	0.00	1.00
07/30/2020 09:00	1	1.8	14.9	14.4	23.8	620,033.2	0.00	1.00
07/30/2020 10:00	1	1.9	14.4	14.5	27.4	779,502.0	0.00	1.00
07/30/2020 11:00	2	2.1	17.8	13.3	37.4	883,999.5	0.00	1.00
07/30/2020 12:00	2	2.1	16.8	13.6	37.3	882,809.7	0.00	1.00
07/30/2020 13:00	2	2.3	18.6	13.0	40.3	889,605.8	0.00	1.00
07/30/2020 14:00	3	2.4	20.4	12.4	47.2	903,659.0	0.00	1.00
07/30/2020 15:00	3	2.5	20.5	12.2	48.4	899,727.6	0.00	1.00
07/30/2020 16:00	3	2.6	20.2	11.9	51.4	907,167.6	0.00	1.00
07/30/2020 17:00	3	2.6	20.3	11.9	51.7	906,711.1	0.00	1.00
07/30/2020 18:00	3	2.5	20.4	12.3	47.7	900,476.2	0.00	1.00
07/30/2020 19:00	2	2.3	19.0	12.9	42.3	890,810.6	0.00	1.00
07/30/2020 20:00	2	2.2	18.5	13.1	40.7	889,248.0	0.00	1.00
07/30/2020 21:00	1	1.9	14.4	14.4	30.6	837,245.0	0.00	1.00
07/30/2020 22:00	1	1.8	14.7	14.5	30.6	815,449.4	0.00	1.00
07/30/2020 23:00	1	1.9	15.0	14.3	23.3	659,191.1	0.00	1.00
Average/Sum#:	2	2.1	17.0	13.7	33.4	753,083.6	0.00 #	24.00 #
Minimum:	1	1.8	14.4	11.9	22.6	599,551.1	0.00	1.00
Maximum:	3	2.6	20.5	14.5	51.7	907,167.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/31/2020 00:00	1	1.9	14.9	14.5	23.2	605,114.4	0.00	1.00
07/31/2020 01:00	2	1.9	15.2	14.5	24.0	599,979.1	0.00	1.00
07/31/2020 02:00	2	1.9	15.7	14.5	25.6	600,621.0	0.00	1.00
07/31/2020 03:00	2	1.9	16.0	14.5	25.6	600,834.9	0.00	1.00
07/31/2020 04:00	2	1.8	16.9	14.5	26.6	601,048.9	0.00	1.00
07/31/2020 05:00	2	1.9	17.0	14.5	27.2	601,476.9	0.00	1.00
07/31/2020 06:00	2	1.9	16.7	14.5	26.5	601,904.8	0.00	1.00
07/31/2020 07:00	2	1.9	16.1	14.5	25.1	601,048.9	0.00	1.00
07/31/2020 08:00	1	1.9	15.2	14.5	23.3	599,551.1	0.00	1.00
07/31/2020 09:00	2	1.9	15.7	14.4	26.2	622,561.4	0.00	1.00
07/31/2020 10:00	1	1.9	13.9	14.5	24.8	763,240.1	0.00	1.00
07/31/2020 11:00	2	2.3	19.3	12.8	42.0	904,158.2	0.00	1.00
07/31/2020 12:00	2	2.2	17.6	13.4	39.3	891,951.7	0.00	1.00
07/31/2020 13:00	2	2.3	19.1	12.9	42.3	902,279.5	0.00	1.00
07/31/2020 14:00	3	2.6	20.7	11.9	52.7	910,667.2	0.00	1.00
07/31/2020 15:00	2	2.3	19.1	12.9	43.1	893,378.2	0.00	1.00
07/31/2020 16:00	2	2.3	19.0	13.0	42.4	890,299.2	0.00	1.00
07/31/2020 17:00	3	2.4	20.4	12.4	47.5	902,047.9	0.00	1.00
07/31/2020 18:00	2	2.4	19.9	12.6	45.1	894,910.6	0.00	1.00
07/31/2020 19:00	2	2.4	19.5	12.7	43.3	895,469.9	0.00	1.00
07/31/2020 20:00	2	2.2	17.0	13.5	37.3	867,919.0	0.00	1.00
07/31/2020 21:00	1	1.9	13.7	14.3	25.5	748,618.7	0.00	1.00
07/31/2020 22:00	1	1.9	14.3	14.5	27.7	768,375.5	0.00	1.00
07/31/2020 23:00	1	1.9	15.0	14.5	23.6	623,302.1	0.00	1.00
Average/Sum#:	2	2.1	17.0	13.8	32.9	745,448.3	0.00 #	24.00 #
Minimum:	1	1.8	13.7	11.9	23.2	599,551.1	0.00	1.00
Maximum:	3	2.6	20.7	14.5	52.7	910,667.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/01/2020 00:00	2	1.9	15.3	14.5	24.1	599,765.1	0.00	1.00
08/01/2020 01:00	2	1.9	15.7	14.5	25.3	599,765.1	0.00	1.00
08/01/2020 02:00	2	1.9	16.1	14.5	26.3	600,193.0	0.00	1.00
08/01/2020 03:00	2	1.9	16.4	14.5	26.5	600,621.0	0.00	1.00
08/01/2020 04:00	2	1.8	17.2	14.5	27.3	600,621.0	0.00	1.00
08/01/2020 05:00	2	1.9	17.2	14.5	27.6	601,048.9	0.00	1.00
08/01/2020 06:00	2	1.9	16.6	14.5	26.4	601,048.9	0.00	1.00
08/01/2020 07:00	2	1.9	16.0	14.5	25.3	600,621.0	0.00	1.00
08/01/2020 08:00	1	1.9	15.2	14.5	23.8	602,974.7	0.00	1.00
08/01/2020 09:00	1	1.9	15.2	14.4	25.1	665,329.6	0.00	1.00
08/01/2020 10:00	1	1.9	14.3	14.5	26.4	747,620.1	0.00	1.00
08/01/2020 11:00	1	1.8	14.2	14.6	27.4	780,354.5	0.00	1.00
08/01/2020 12:00	1	1.8	15.2	14.6	32.2	818,828.8	0.00	1.00
08/01/2020 13:00	1	1.8	15.3	14.6	31.0	797,091.9	0.00	1.00
08/01/2020 14:00	1	1.9	13.8	14.5	25.5	759,602.6	0.00	1.00
08/01/2020 15:00	3	2.4	19.8	11.9	49.9	905,646.0	0.00	1.00
08/01/2020 16:00	3	2.5	20.7	12.0	52.7	910,898.0	0.00	1.00
08/01/2020 17:00	3	2.5	21.1	12.0	52.9	906,743.6	0.00	1.00
08/01/2020 18:00	3	2.5	20.7	12.3	47.8	897,769.1	0.00	1.00
08/01/2020 19:00	2	2.4	19.8	12.7	44.1	892,463.9	0.00	1.00
08/01/2020 20:00	2	2.1	16.7	13.7	36.8	869,584.5	0.00	1.00
08/01/2020 21:00	2	2.0	15.6	14.1	34.8	854,681.9	0.00	1.00
08/01/2020 22:00	1	1.9	13.6	14.3	23.8	732,642.0	0.00	1.00
08/01/2020 23:00	1	1.9	14.4	14.4	23.9	684,290.8	0.00	1.00
Average/Sum#:	2	2.0	16.5	14.0	32.0	734,591.9	0.00 #	24.00 #
Minimum:	1	1.8	13.6	11.9	23.8	599,765.1	0.00	1.00
Maximum:	3	2.5	21.1	14.6	52.9	910,898.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/02/2020 00:00	2	1.9	15.1	14.5	24.0	604,258.5	0.00	1.00
08/02/2020 01:00	2	1.9	15.3	14.5	24.3	596,983.4	0.00	1.00
08/02/2020 02:00	2	1.9	15.7	14.5	25.2	596,555.5	0.00	1.00
08/02/2020 03:00	2	1.9	16.1	14.5	26.3	596,983.4	0.00	1.00
08/02/2020 04:00	1	1.8	16.5	14.5	25.7	600,193.0	0.00	1.00
08/02/2020 05:00	2	1.9	16.4	14.2	26.6	628,504.5	0.00	1.00
08/02/2020 06:00	1	1.9	15.7	14.2	25.2	641,789.9	0.00	1.00
08/02/2020 07:00	1	1.9	15.1	14.3	24.6	658,776.1	0.00	1.00
08/02/2020 08:00	2	1.9	15.1	14.5	23.8	601,262.9	0.00	1.00
08/02/2020 09:00	2	1.8	15.1	14.5	24.0	594,415.8	0.00	1.00
08/02/2020 10:00	2	1.8	15.4	14.6	24.6	603,850.9	0.00	1.00
08/02/2020 11:00	1	1.8	14.3	14.5	25.7	721,087.5	0.00	1.00
08/02/2020 12:00	1	1.9	14.5	14.5	29.3	805,820.7	0.00	1.00
08/02/2020 13:00	2	2.2	18.8	12.7	40.8	882,944.7	0.00	1.00
08/02/2020 14:00	2	2.3	18.8	12.8	41.8	890,294.9	0.00	1.00
08/02/2020 15:00	3	2.6	20.3	11.8	51.8	893,436.5	0.00	1.00
08/02/2020 16:00	3	2.3	19.5	12.5	44.6	886,213.2	0.00	1.00
08/02/2020 17:00	3	2.5	20.1	12.0	49.1	891,356.8	0.00	1.00
08/02/2020 18:00	2	2.4	19.2	12.7	43.4	892,129.9	0.00	1.00
08/02/2020 19:00	2	2.3	19.0	12.8	42.2	887,928.0	0.00	1.00
08/02/2020 20:00	2	2.2	17.8	13.2	39.0	880,877.8	0.00	1.00
08/02/2020 21:00	1	1.9	13.9	14.4	28.3	801,850.6	0.00	1.00
08/02/2020 22:00	1	1.9	14.9	14.3	24.6	666,038.2	0.00	1.00
08/02/2020 23:00	1	1.9	14.3	14.5	28.5	777,790.3	0.00	1.00
Average/Sum#:	2	2.0	16.5	13.8	31.8	733,389.3	0.00 #	24.00 #
Minimum:	1	1.8	13.9	11.8	23.8	594,415.8	0.00	1.00
Maximum:	3	2.6	20.3	14.6	51.8	893,436.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/03/2020 00:00	2	1.9	15.6	14.4	25.5	639,626.5	0.00	1.00
08/03/2020 01:00	1	1.8	14.9	14.5	23.2	600,193.0	0.00	1.00
08/03/2020 02:00	2	1.9	15.0	14.5	23.9	597,625.4	0.00	1.00
08/03/2020 03:00	2	1.9	15.4	14.5	24.8	598,053.3	0.00	1.00
08/03/2020 04:00	1	1.8	16.0	14.5	25.2	598,267.3	0.00	1.00
08/03/2020 05:00	2	1.9	16.0	14.5	25.1	599,123.2	0.00	1.00
08/03/2020 06:00	2	1.9	15.6	14.5	24.4	598,909.2	0.00	1.00
08/03/2020 07:00	1	1.9	15.1	14.5	23.6	599,979.1	0.00	1.00
08/03/2020 08:00	2	1.8	16.0	14.4	26.9	615,819.6	0.00	1.00
08/03/2020 09:00	2	1.8	15.7	14.6	25.7	614,936.8	0.00	1.00
08/03/2020 10:00	1	1.9	13.8	14.5	27.1	820,798.7	0.00	1.00
08/03/2020 11:00	1	1.8	14.8	14.5	32.1	866,588.9	0.00	1.00
08/03/2020 12:00	2	2.1	17.3	13.4	37.4	883,187.4	0.00	1.00
08/03/2020 13:00	2	2.2	17.9	13.3	39.2	894,810.7	0.00	1.00
08/03/2020 14:00	3	2.6	20.4	12.0	49.8	906,897.5	0.00	1.00
08/03/2020 15:00	3	2.5	20.3	12.2	48.6	901,459.0	0.00	1.00
08/03/2020 16:00	3	2.5	20.4	12.2	47.8	896,422.1	0.00	1.00
08/03/2020 17:00	3	2.5	20.2	12.1	47.8	892,460.1	0.00	1.00
08/03/2020 18:00	3	2.6	20.2	11.8	51.7	901,111.3	0.00	1.00
08/03/2020 19:00	2	2.3	18.2	13.0	39.6	876,431.6	0.00	1.00
08/03/2020 20:00	1	1.9	13.5	14.4	24.3	740,121.2	0.00	1.00
08/03/2020 21:00	1	1.8	14.4	14.6	30.9	825,784.6	0.00	1.00
08/03/2020 22:00	1	1.9	14.1	14.4	22.5	681,762.7	0.00	1.00
08/03/2020 23:00	1	1.9	13.7	14.4	25.8	738,435.8	0.00	1.00
Average/Sum#:	2	2.0	16.4	13.8	32.2	745,366.9	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.8	22.5	597,625.4	0.00	1.00
Maximum:	3	2.6	20.4	14.6	51.7	906,897.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/04/2020 00:00	1	1.9	14.4	14.5	22.5	614,101.2	0.00	1.00
08/04/2020 01:00	1	1.9	14.6	14.5	23.0	597,411.4	0.00	1.00
08/04/2020 02:00	2	1.9	15.0	14.5	23.8	597,625.4	0.00	1.00
08/04/2020 03:00	1	1.9	15.3	14.5	24.7	598,481.3	0.00	1.00
08/04/2020 04:00	1	1.8	16.2	14.5	25.3	598,481.3	0.00	1.00
08/04/2020 05:00	2	1.9	16.3	14.4	25.6	589,484.5	0.00	1.00
08/04/2020 06:00	2	1.9	16.0	14.5	25.1	598,695.2	0.00	1.00
08/04/2020 07:00	2	1.9	15.5	14.5	24.3	599,123.2	0.00	1.00
08/04/2020 08:00	1	1.9	15.4	14.3	24.7	642,799.5	0.00	1.00
08/04/2020 09:00	1	1.9	13.7	14.4	24.7	738,857.1	0.00	1.00
08/04/2020 10:00	1	1.9	14.0	14.5	26.9	771,585.1	0.00	1.00
08/04/2020 11:00	1	1.8	14.8	14.4	31.8	849,464.5	0.00	1.00
08/04/2020 12:00	2	2.2	17.4	13.2	36.9	886,568.9	0.00	1.00
08/04/2020 13:00	2	2.2	16.9	13.3	36.8	874,629.7	0.00	1.00
08/04/2020 14:00	3	2.5	19.5	12.3	44.5	891,718.2	0.00	1.00
08/04/2020 15:00	3	2.6	19.9	11.8	50.9	899,606.5	0.00	1.00
08/04/2020 16:00	3	2.6	19.9	11.8	51.1	897,650.2	0.00	1.00
08/04/2020 17:00	3	2.6	19.8	11.8	50.7	899,606.5	0.00	1.00
08/04/2020 18:00	3	2.6	19.6	11.9	49.3	892,408.2	0.00	1.00
08/04/2020 19:00	2	2.0	15.2	14.0	33.7	854,600.2	0.00	1.00
08/04/2020 20:00	1	1.9	13.4	14.4	24.7	763,506.8	0.00	1.00
08/04/2020 21:00	1	1.9	14.4	14.4	21.9	593,066.1	0.00	1.00
08/04/2020 22:00	1	1.9	14.5	14.5	23.0	598,695.2	0.00	1.00
08/04/2020 23:00	2	1.9	15.4	14.3	25.5	630,972.7	0.00	1.00
Average/Sum#:	2	2.1	16.1	13.8	31.3	728,297.5	0.00 #	24.00 #
Minimum:	1	1.8	13.4	11.8	21.9	589,484.5	0.00	1.00
Maximum:	3	2.6	19.9	14.5	51.1	899,606.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/05/2020 00:00	2	1.9	15.3	14.5	24.4	598,267.3	0.00	1.00
08/05/2020 01:00	2	1.9	15.4	14.5	24.5	598,053.3	0.00	1.00
08/05/2020 02:00	2	1.9	15.5	14.5	24.9	598,481.3	0.00	1.00
08/05/2020 03:00	2	1.9	15.7	14.4	26.0	589,063.2	0.00	1.00
08/05/2020 04:00	2	1.8	16.5	14.4	25.8	589,905.9	0.00	1.00
08/05/2020 05:00	2	1.9	16.5	14.4	26.0	589,695.2	0.00	1.00
08/05/2020 06:00	2	1.9	16.4	14.4	27.4	589,695.2	0.00	1.00
08/05/2020 07:00	1	1.9	16.6	14.4	24.9	589,273.8	0.00	1.00
08/05/2020 08:00	1	1.9	16.0	14.5	24.2	598,267.3	0.00	1.00
08/05/2020 09:00	1	1.9	15.0	14.4	23.2	601,914.7	0.00	1.00
08/05/2020 10:00	1	1.9	14.5	14.3	22.2	646,326.8	0.00	1.00
08/05/2020 11:00	1	1.9	14.4	14.4	29.5	827,975.1	0.00	1.00
08/05/2020 12:00	2	2.1	16.8	13.5	35.9	886,239.6	0.00	1.00
08/05/2020 13:00	2	2.2	17.8	13.2	38.3	893,682.8	0.00	1.00
08/05/2020 14:00	2	2.3	18.5	13.0	40.0	894,979.5	0.00	1.00
08/05/2020 15:00	2	2.3	18.8	12.9	40.8	894,234.1	0.00	1.00
08/05/2020 16:00	2	2.3	18.2	13.1	39.8	895,041.7	0.00	1.00
08/05/2020 17:00	2	2.1	16.3	13.7	36.2	881,947.3	0.00	1.00
08/05/2020 18:00	2	2.2	17.6	13.3	38.2	874,990.1	0.00	1.00
08/05/2020 19:00	1	2.0	14.6	14.2	23.2	652,418.3	0.00	1.00
08/05/2020 20:00	1	1.9	13.7	14.3	23.2	693,841.7	0.00	1.00
08/05/2020 21:00	1	2.4	15.9	14.3	21.9	653,381.4	0.08	1.00
08/05/2020 22:00	0	16.3	32.5	16.8	0.0	377,760.7	0.07	0.07
08/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	2.6	16.9	14.1	27.8	696,323.3	0.15 #	22.07 #
Minimum:	1	1.8	13.7	12.9	0.0	377,760.7	0.00	0.00
Maximum:	2	16.3	32.5	16.8	40.8	895,041.7	0.08	1.00
%SI	8.33	4.17	4.17	4.17	4.17	4.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2020 07:00	0	23.4	28.3	17.7	0.0	615,385.1	0.27	0.27
08/08/2020 08:00	1	5.7	16.5	14.4	25.5	852,203.3	0.57	1.00
08/08/2020 09:00	1	1.9	15.4	14.4	27.5	797,637.0	0.00	1.00
08/08/2020 10:00	1	1.9	16.2	14.4	36.0	854,942.2	0.00	1.00
08/08/2020 11:00	2	2.4	21.0	12.2	48.6	891,699.9	0.00	1.00
08/08/2020 12:00	3	2.5	20.9	12.2	46.4	892,486.9	0.00	1.00
08/08/2020 13:00	3	2.5	20.9	12.2	47.0	892,014.7	0.00	1.00
08/08/2020 14:00	3	2.5	20.8	12.2	47.0	890,283.3	0.00	1.00
08/08/2020 15:00	3	2.5	20.8	12.2	47.2	889,181.4	0.00	1.00
08/08/2020 16:00	3	2.5	20.7	12.1	47.7	884,523.7	0.00	1.00
08/08/2020 17:00	2	2.4	19.5	12.7	41.4	877,767.6	0.00	1.00
08/08/2020 18:00	2	2.3	18.6	13.0	39.3	878,511.7	0.00	1.00
08/08/2020 19:00	2	2.1	16.7	13.6	34.4	859,548.3	0.00	1.00
08/08/2020 20:00	1	1.9	13.4	14.3	19.3	679,940.0	0.00	1.00
08/08/2020 21:00	1	1.9	14.4	14.4	31.8	836,823.6	0.00	1.00
08/08/2020 22:00	1	1.9	14.9	14.4	32.5	843,776.1	0.00	1.00
08/08/2020 23:00	1	1.9	14.5	14.3	22.6	650,891.6	0.00	1.00
Average/Sum#:	2	3.7	18.4	13.6	35.0	828,683.3	0.84 #	16.27 #
Minimum:	1	1.9	13.4	12.1	0.0	615,385.1	0.00	0.00
Maximum:	3	23.4	28.3	17.7	48.6	892,486.9	0.57	1.00
%SI	33.33	29.17	29.17	29.17	29.17	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/09/2020 00:00	2	1.9	15.3	14.5	24.4	610,249.7	0.00	1.00
08/09/2020 01:00	1	1.8	14.6	14.5	22.4	595,913.6	0.00	1.00
08/09/2020 02:00	1	1.9	14.6	14.5	22.9	596,341.5	0.00	1.00
08/09/2020 03:00	1	1.9	14.7	14.5	23.1	596,769.5	0.00	1.00
08/09/2020 04:00	1	1.8	15.3	14.5	23.7	596,769.5	0.00	1.00
08/09/2020 05:00	1	1.9	15.4	14.5	24.5	596,983.4	0.00	1.00
08/09/2020 06:00	1	1.9	14.9	14.5	23.2	596,983.4	0.00	1.00
08/09/2020 07:00	2	1.9	14.8	14.5	23.7	602,118.8	0.00	1.00
08/09/2020 08:00	1	1.9	14.4	14.3	22.6	651,721.5	0.00	1.00
08/09/2020 09:00	1	1.9	13.8	14.5	29.7	852,038.7	0.00	1.00
08/09/2020 10:00	2	2.2	17.4	13.2	36.5	885,324.0	0.00	1.00
08/09/2020 11:00	2	2.4	18.9	12.5	41.4	884,909.0	0.00	1.00
08/09/2020 12:00	3	2.6	19.5	11.9	48.3	897,277.3	0.00	1.00
08/09/2020 13:00	3	2.6	19.5	11.7	49.4	886,553.4	0.00	1.00
08/09/2020 14:00	3	2.7	19.6	11.7	50.0	888,190.8	0.00	1.00
08/09/2020 15:00	3	2.6	19.6	11.7	49.8	880,599.4	0.00	1.00
08/09/2020 16:00	3	2.6	19.3	12.0	47.3	887,510.1	0.00	1.00
08/09/2020 17:00	3	2.6	19.5	11.7	49.4	881,046.0	0.00	1.00
08/09/2020 18:00	3	2.4	17.9	12.7	42.4	872,256.5	0.00	1.00
08/09/2020 19:00	3	2.6	20.0	11.8	50.3	896,747.2	0.00	1.00
08/09/2020 20:00	3	2.5	19.4	12.4	44.9	887,548.1	0.00	1.00
08/09/2020 21:00	2	2.2	17.6	13.2	38.9	877,854.4	0.00	1.00
08/09/2020 22:00	2	2.2	17.1	13.5	37.2	868,844.3	0.00	1.00
08/09/2020 23:00	1	1.9	13.9	14.4	25.8	735,064.9	0.00	1.00
Average/Sum#:	2	2.2	17.0	13.3	35.5	771,900.6	0.00 #	24.00 #
Minimum:	1	1.8	13.8	11.7	22.4	595,913.6	0.00	1.00
Maximum:	3	2.7	20.0	14.5	50.3	897,277.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/10/2020 00:00	1	1.9	14.0	14.4	23.7	696,299.6	0.00	1.00
08/10/2020 01:00	1	1.9	14.4	14.4	24.3	678,813.1	0.00	1.00
08/10/2020 02:00	2	1.9	15.9	14.4	26.6	626,353.6	0.00	1.00
08/10/2020 03:00	2	1.9	15.6	14.5	25.3	609,179.9	0.00	1.00
08/10/2020 04:00	1	1.8	16.3	14.4	26.4	618,769.1	0.00	1.00
08/10/2020 05:00	1	1.9	15.4	14.5	24.0	595,913.6	0.00	1.00
08/10/2020 06:00	2	1.8	15.2	14.5	23.8	596,341.5	0.00	1.00
08/10/2020 07:00	2	1.9	16.0	14.4	27.1	619,611.9	0.00	1.00
08/10/2020 08:00	1	1.9	14.2	14.5	24.9	729,004.5	0.00	1.00
08/10/2020 09:00	1	1.9	14.5	14.5	30.9	848,187.2	0.00	1.00
08/10/2020 10:00	2	2.2	17.5	13.2	37.0	877,498.7	0.00	1.00
08/10/2020 11:00	3	2.5	19.7	12.3	44.4	893,629.0	0.00	1.00
08/10/2020 12:00	3	2.7	19.7	11.8	49.6	897,951.1	0.00	1.00
08/10/2020 13:00	3	2.7	19.4	11.7	49.3	888,339.6	0.00	1.00
08/10/2020 14:00	3	2.7	19.4	11.7	49.4	884,916.1	0.00	1.00
08/10/2020 15:00	3	2.6	19.3	11.7	49.1	880,599.4	0.00	1.00
08/10/2020 16:00	3	2.6	19.3	11.8	49.0	887,567.6	0.00	1.00
08/10/2020 17:00	3	2.6	19.3	11.9	48.5	886,017.6	0.00	1.00
08/10/2020 18:00	2	2.3	17.2	13.2	36.9	853,133.6	0.00	1.00
08/10/2020 19:00	1	1.9	13.5	14.5	27.1	780,999.8	0.00	1.00
08/10/2020 20:00	1	1.8	14.2	14.5	28.6	783,781.5	0.00	1.00
08/10/2020 21:00	2	1.8	15.1	14.5	33.3	826,362.0	0.00	1.00
08/10/2020 22:00	1	1.9	14.3	14.5	27.7	787,633.0	0.00	1.00
08/10/2020 23:00	1	1.9	14.1	14.5	27.9	784,209.4	0.00	1.00
Average/Sum#:	2	2.1	16.4	13.6	34.0	772,129.7	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.7	23.7	595,913.6	0.00	1.00
Maximum:	3	2.7	19.7	14.5	49.6	897,951.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/11/2020 00:00	1	1.9	14.9	14.5	22.6	601,904.8	0.00	1.00
08/11/2020 01:00	2	1.9	15.2	14.5	24.0	598,267.3	0.00	1.00
08/11/2020 02:00	2	1.9	15.4	14.5	24.5	598,695.2	0.00	1.00
08/11/2020 03:00	2	1.9	15.6	14.5	24.8	598,909.2	0.00	1.00
08/11/2020 04:00	2	1.8	16.3	14.4	25.4	589,484.5	0.00	1.00
08/11/2020 05:00	2	1.9	16.2	14.4	25.8	589,484.5	0.00	1.00
08/11/2020 06:00	2	1.9	16.0	14.4	25.4	589,905.9	0.00	1.00
08/11/2020 07:00	2	1.9	15.6	14.5	24.5	601,690.8	0.00	1.00
08/11/2020 08:00	1	1.9	15.1	14.3	24.3	641,347.1	0.00	1.00
08/11/2020 09:00	1	1.9	14.1	14.3	22.8	671,432.9	0.00	1.00
08/11/2020 10:00	1	1.9	13.8	14.5	28.9	845,833.5	0.00	1.00
08/11/2020 11:00	2	1.9	15.4	14.1	34.0	862,536.0	0.00	1.00
08/11/2020 12:00	2	2.2	18.3	13.0	38.7	888,912.4	0.00	1.00
08/11/2020 13:00	2	2.1	17.0	13.4	37.8	876,614.2	0.00	1.00
08/11/2020 14:00	2	2.1	16.7	13.5	36.5	871,250.0	0.00	1.00
08/11/2020 15:00	2	2.2	16.9	13.4	37.2	875,701.2	0.00	1.00
08/11/2020 16:00	2	2.2	17.0	13.3	37.3	867,782.6	0.00	1.00
08/11/2020 17:00	2	2.1	16.3	13.6	36.2	868,927.9	0.00	1.00
08/11/2020 18:00	2	2.1	16.2	13.7	36.3	869,013.9	0.00	1.00
08/11/2020 19:00	1	1.9	14.4	14.4	30.4	802,693.4	0.00	1.00
08/11/2020 20:00	1	1.8	14.2	14.5	28.6	796,405.9	0.00	1.00
08/11/2020 21:00	2	1.9	14.9	14.5	34.0	867,016.8	0.00	1.00
08/11/2020 22:00	1	1.9	13.7	14.4	22.6	711,679.3	0.00	1.00
08/11/2020 23:00	2	1.9	14.8	14.4	24.3	637,309.0	0.00	1.00
Average/Sum#:	2	2.0	15.6	14.1	29.5	738,449.9	0.00 #	24.00 #
Minimum:	1	1.8	13.7	13.0	22.6	589,484.5	0.00	1.00
Maximum:	2	2.2	18.3	14.5	38.7	888,912.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/12/2020 00:00	2	1.9	15.3	14.5	24.6	596,769.5	0.00	1.00
08/12/2020 01:00	2	1.9	15.5	14.5	25.0	597,197.4	0.00	1.00
08/12/2020 02:00	2	1.9	15.7	14.5	25.2	598,695.2	0.00	1.00
08/12/2020 03:00	2	1.9	15.8	14.5	25.4	599,123.2	0.00	1.00
08/12/2020 04:00	2	1.8	16.4	14.4	25.9	589,905.9	0.00	1.00
08/12/2020 05:00	2	1.9	16.4	14.4	26.5	590,116.6	0.00	1.00
08/12/2020 06:00	2	1.9	16.2	14.4	25.9	590,748.6	0.00	1.00
08/12/2020 07:00	1	1.9	14.8	14.4	23.2	603,600.1	0.00	1.00
08/12/2020 08:00	1	1.9	14.5	14.4	22.6	597,911.8	0.00	1.00
08/12/2020 09:00	1	1.9	14.3	14.3	23.1	654,418.9	0.00	1.00
08/12/2020 10:00	1	1.9	13.4	14.4	25.6	785,206.9	0.00	1.00
08/12/2020 11:00	2	2.2	18.5	12.9	39.6	892,522.3	0.00	1.00
08/12/2020 12:00	3	2.6	19.9	12.1	46.6	897,595.4	0.00	1.00
08/12/2020 13:00	3	2.6	19.7	11.9	49.3	898,038.1	0.00	1.00
08/12/2020 14:00	3	2.6	19.8	11.9	50.3	897,885.9	0.00	1.00
08/12/2020 15:00	3	2.6	19.7	11.8	50.5	889,222.9	0.00	1.00
08/12/2020 16:00	3	2.6	19.8	11.9	50.8	898,494.6	0.00	1.00
08/12/2020 17:00	3	2.6	19.8	11.9	51.0	898,342.4	0.00	1.00
08/12/2020 18:00	3	2.6	20.0	11.9	50.8	893,625.5	0.00	1.00
08/12/2020 19:00	3	2.4	19.4	12.6	44.6	891,610.8	0.00	1.00
08/12/2020 20:00	2	2.1	16.7	13.6	37.6	873,430.1	0.00	1.00
08/12/2020 21:00	2	2.1	16.9	13.6	38.2	884,873.3	0.00	1.00
08/12/2020 22:00	2	2.0	15.4	14.1	35.7	863,945.7	0.00	1.00
08/12/2020 23:00	1	1.8	14.6	14.5	30.1	808,174.4	0.00	1.00
Average/Sum#:	2	2.2	17.0	13.5	35.3	762,144.0	0.00 #	24.00 #
Minimum:	1	1.8	13.4	11.8	22.6	589,905.9	0.00	1.00
Maximum:	3	2.6	20.0	14.5	51.0	898,494.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/13/2020 00:00	1	1.9	15.1	14.3	23.9	646,119.3	0.00	1.00
08/13/2020 01:00	2	1.8	15.2	14.5	23.9	602,332.8	0.00	1.00
08/13/2020 02:00	2	1.9	15.0	14.5	23.8	596,127.6	0.00	1.00
08/13/2020 03:00	2	1.8	15.3	14.5	24.4	596,127.6	0.00	1.00
08/13/2020 04:00	1	1.8	15.8	14.5	24.5	596,127.6	0.00	1.00
08/13/2020 05:00	1	1.8	15.5	14.5	24.5	596,341.5	0.00	1.00
08/13/2020 06:00	2	1.9	16.1	14.4	26.8	610,974.0	0.00	1.00
08/13/2020 07:00	2	1.9	16.1	14.4	26.7	626,775.0	0.00	1.00
08/13/2020 08:00	1	1.9	14.8	14.4	24.4	670,596.6	0.00	1.00
08/13/2020 09:00	1	1.8	15.2	14.6	31.1	802,091.4	0.00	1.00
08/13/2020 10:00	2	2.0	15.8	13.9	35.2	860,976.7	0.00	1.00
08/13/2020 11:00	3	2.5	19.9	12.2	44.6	890,912.9	0.00	1.00
08/13/2020 12:00	3	2.6	20.5	12.0	49.8	899,204.1	0.00	1.00
08/13/2020 13:00	3	2.6	20.2	11.9	50.1	892,103.9	0.00	1.00
08/13/2020 14:00	3	2.6	20.2	11.9	50.5	892,103.9	0.00	1.00
08/13/2020 15:00	3	2.5	19.8	12.3	47.1	887,737.3	0.00	1.00
08/13/2020 16:00	3	2.4	19.5	12.5	44.6	888,332.6	0.00	1.00
08/13/2020 17:00	3	2.6	20.1	12.0	49.8	890,741.3	0.00	1.00
08/13/2020 18:00	2	2.4	19.2	12.7	43.4	888,622.8	0.00	1.00
08/13/2020 19:00	2	2.1	16.2	13.8	35.8	868,523.7	0.00	1.00
08/13/2020 20:00	2	2.0	15.3	14.2	34.9	843,728.9	0.00	1.00
08/13/2020 21:00	3	2.4	20.0	12.5	46.0	907,732.7	0.00	1.00
08/13/2020 22:00	3	2.5	20.5	12.4	48.0	907,364.5	0.00	1.00
08/13/2020 23:00	1	1.9	15.2	14.4	31.3	787,313.7	0.00	1.00
Average/Sum#:	2	2.2	17.4	13.5	36.0	777,042.2	0.00 #	24.00 #
Minimum:	1	1.8	14.8	11.9	23.8	596,127.6	0.00	1.00
Maximum:	3	2.6	20.5	14.6	50.5	907,732.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/14/2020 00:00	1	1.9	14.3	14.4	23.0	683,237.4	0.00	1.00
08/14/2020 01:00	1	1.9	13.7	14.4	23.0	690,189.9	0.00	1.00
08/14/2020 02:00	2	1.9	14.9	14.5	23.9	610,035.8	0.00	1.00
08/14/2020 03:00	1	1.8	14.8	14.5	23.0	595,913.6	0.00	1.00
08/14/2020 04:00	1	1.8	15.9	14.4	25.7	618,979.8	0.00	1.00
08/14/2020 05:00	1	1.9	14.2	14.4	24.7	708,097.7	0.00	1.00
08/14/2020 06:00	2	1.8	15.5	14.5	34.1	837,488.6	0.00	1.00
08/14/2020 07:00	2	2.0	16.6	13.8	36.1	867,559.3	0.00	1.00
08/14/2020 08:00	3	2.5	20.9	12.1	48.4	908,799.8	0.00	1.00
08/14/2020 09:00	3	2.6	21.0	11.9	51.4	900,016.1	0.00	1.00
08/14/2020 10:00	3	2.6	20.7	11.8	51.5	893,587.0	0.00	1.00
08/14/2020 11:00	3	2.4	19.6	12.5	45.2	887,843.5	0.00	1.00
08/14/2020 12:00	2	2.3	18.4	12.9	40.8	874,548.6	0.00	1.00
08/14/2020 13:00	2	2.3	18.6	12.8	40.8	871,528.7	0.00	1.00
08/14/2020 14:00	2	2.3	18.5	12.9	40.5	877,458.7	0.00	1.00
08/14/2020 15:00	3	2.6	20.3	11.9	50.2	894,994.9	0.00	1.00
08/14/2020 16:00	3	2.7	20.0	11.8	50.6	891,480.2	0.00	1.00
08/14/2020 17:00	3	2.6	19.9	11.8	49.6	878,989.9	0.00	1.00
08/14/2020 18:00	3	2.6	19.9	12.0	47.0	881,817.0	0.00	1.00
08/14/2020 19:00	3	2.6	19.8	11.8	49.4	886,514.2	0.00	1.00
08/14/2020 20:00	3	2.5	19.4	12.3	44.5	878,183.2	0.00	1.00
08/14/2020 21:00	2	2.2	17.3	13.3	37.5	878,053.3	0.00	1.00
08/14/2020 22:00	2	2.3	18.0	13.0	38.5	870,191.2	0.00	1.00
08/14/2020 23:00	1	2.0	13.4	14.2	21.8	700,654.7	0.00	1.00
Average/Sum#:	2	2.3	17.7	13.1	38.4	816,090.1	0.00 #	24.00 #
Minimum:	1	1.8	13.4	11.8	21.8	595,913.6	0.00	1.00
Maximum:	3	2.7	21.0	14.5	51.5	908,799.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/15/2020 00:00	1	1.9	13.4	14.2	21.2	655,893.0	0.00	1.00
08/15/2020 01:00	1	1.9	13.0	14.3	22.3	711,478.2	0.00	1.00
08/15/2020 02:00	1	1.9	13.9	14.4	21.4	614,766.2	0.00	1.00
08/15/2020 03:00	1	1.9	13.8	14.4	20.3	588,852.5	0.00	1.00
08/15/2020 04:00	1	1.8	14.2	14.4	20.7	588,009.8	0.00	1.00
08/15/2020 05:00	1	1.9	14.5	14.4	21.9	590,748.6	0.00	1.00
08/15/2020 06:00	1	1.9	13.2	14.3	21.5	701,311.3	0.00	1.00
08/15/2020 07:00	1	1.9	14.1	14.5	30.4	842,196.0	0.00	1.00
08/15/2020 08:00	2	2.4	19.2	12.5	42.4	885,398.1	0.00	1.00
08/15/2020 09:00	3	2.6	20.1	11.7	50.8	887,297.7	0.00	1.00
08/15/2020 10:00	3	2.7	19.8	11.7	50.4	884,171.8	0.00	1.00
08/15/2020 11:00	3	2.7	19.5	11.7	49.3	879,110.9	0.00	1.00
08/15/2020 12:00	3	2.4	18.7	12.5	42.4	873,986.2	0.00	1.00
08/15/2020 13:00	2	2.3	17.8	12.9	38.3	870,611.6	0.00	1.00
08/15/2020 14:00	3	2.6	19.2	12.0	45.9	877,047.1	0.00	1.00
08/15/2020 15:00	2	2.4	18.1	12.7	39.6	867,079.4	0.00	1.00
08/15/2020 16:00	3	2.5	19.2	12.4	43.7	879,009.3	0.00	1.00
08/15/2020 17:00	3	2.5	19.7	12.2	46.0	875,644.6	0.00	1.00
08/15/2020 18:00	3	2.5	19.8	12.3	47.3	889,966.6	0.00	1.00
08/15/2020 19:00	4	2.6	20.7	11.8	53.5	895,091.9	0.00	1.00
08/15/2020 20:00	3	2.6	20.6	12.0	51.7	895,819.0	0.00	1.00
08/15/2020 21:00	3	2.5	20.5	12.1	49.6	892,460.1	0.00	1.00
08/15/2020 22:00	3	2.6	20.3	11.9	49.7	888,604.3	0.00	1.00
08/15/2020 23:00	2	2.2	16.7	13.5	37.8	860,516.7	0.00	1.00
Average/Sum#:	2	2.3	17.5	13.0	38.3	808,128.0	0.00 #	24.00 #
Minimum:	1	1.8	13.0	11.7	20.3	588,009.8	0.00	1.00
Maximum:	4	2.7	20.7	14.5	53.5	895,819.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/16/2020 00:00	1	1.9	13.6	14.4	24.5	740,331.9	0.00	1.00
08/16/2020 01:00	1	1.8	13.6	14.5	26.0	751,043.7	0.00	1.00
08/16/2020 02:00	1	1.9	13.6	14.5	24.3	721,301.5	0.00	1.00
08/16/2020 03:00	1	1.9	13.5	14.4	22.7	689,557.8	0.00	1.00
08/16/2020 04:00	1	1.9	14.1	14.4	23.7	695,246.2	0.00	1.00
08/16/2020 05:00	1	1.8	14.4	14.5	27.8	758,104.8	0.00	1.00
08/16/2020 06:00	1	1.9	14.0	14.5	25.7	724,297.1	0.00	1.00
08/16/2020 07:00	1	1.9	13.2	14.4	25.0	776,779.6	0.00	1.00
08/16/2020 08:00	1	1.9	13.0	14.4	24.8	770,459.2	0.00	1.00
08/16/2020 09:00	2	2.0	16.1	13.7	35.7	852,276.5	0.00	1.00
08/16/2020 10:00	2	2.1	16.5	13.4	35.7	855,981.5	0.00	1.00
08/16/2020 11:00	2	2.2	16.5	13.4	36.1	860,546.3	0.00	1.00
08/16/2020 12:00	2	2.1	15.2	13.8	33.5	840,556.5	0.00	1.00
08/16/2020 13:00	2	2.3	17.2	13.0	37.3	860,483.9	0.00	1.00
08/16/2020 14:00	3	2.6	19.4	11.8	48.2	875,378.2	0.00	1.00
08/16/2020 15:00	3	2.6	19.3	12.0	46.9	873,508.1	0.00	1.00
08/16/2020 16:00	3	2.5	18.2	12.1	41.5	860,247.5	0.00	1.00
08/16/2020 17:00	2	2.4	17.3	12.5	39.2	854,912.1	0.00	1.00
08/16/2020 18:00	2	2.2	15.9	13.3	33.8	843,277.1	0.00	1.00
08/16/2020 19:00	2	2.3	17.7	12.9	38.2	873,521.6	0.00	1.00
08/16/2020 20:00	3	2.6	19.7	11.8	47.8	885,912.2	0.00	1.00
08/16/2020 21:00	3	2.5	19.2	12.4	43.2	884,970.4	0.00	1.00
08/16/2020 22:00	3	2.5	19.2	12.4	43.0	883,520.4	0.00	1.00
08/16/2020 23:00	2	2.1	16.2	13.5	35.0	847,932.8	0.00	1.00
Average/Sum#:	2	2.2	16.1	13.4	34.2	815,839.5	0.00 #	24.00 #
Minimum:	1	1.8	13.0	11.8	22.7	689,557.8	0.00	1.00
Maximum:	3	2.6	19.7	14.5	48.2	885,912.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/17/2020 00:00	1	1.9	14.0	14.5	27.3	801,969.2	0.00	1.00
08/17/2020 01:00	1	1.9	12.9	14.4	21.1	698,617.1	0.00	1.00
08/17/2020 02:00	1	1.9	12.6	14.4	21.7	718,421.1	0.00	1.00
08/17/2020 03:00	1	1.9	12.7	14.4	22.3	724,741.5	0.00	1.00
08/17/2020 04:00	1	1.8	13.3	14.4	23.6	739,489.2	0.00	1.00
08/17/2020 05:00	1	1.9	13.8	14.4	27.4	784,153.5	0.00	1.00
08/17/2020 06:00	1	1.9	14.1	14.5	30.0	839,842.3	0.00	1.00
08/17/2020 07:00	2	2.1	17.6	13.0	37.8	878,165.1	0.00	1.00
08/17/2020 08:00	3	2.5	19.6	11.9	48.0	895,299.2	0.00	1.00
08/17/2020 09:00	3	2.5	19.6	11.7	50.1	891,019.0	0.00	1.00
08/17/2020 10:00	3	2.5	19.4	11.7	49.6	889,381.6	0.00	1.00
08/17/2020 11:00	3	2.5	19.2	11.7	48.7	885,660.3	0.00	1.00
08/17/2020 12:00	3	2.4	19.1	12.2	45.1	881,311.2	0.00	1.00
08/17/2020 13:00	2	2.2	17.4	12.9	38.2	863,422.1	0.00	1.00
08/17/2020 14:00	2	2.1	16.3	13.2	34.2	843,707.7	0.00	1.00
08/17/2020 15:00	1	1.9	12.7	14.3	20.4	674,130.3	0.00	1.00
08/17/2020 16:00	2	2.1	15.1	13.6	32.9	833,848.1	0.00	1.00
08/17/2020 17:00	2	2.4	18.0	12.6	38.9	875,276.7	0.00	1.00
08/17/2020 18:00	2	2.4	18.3	12.6	39.7	876,266.6	0.00	1.00
08/17/2020 19:00	2	2.4	18.5	12.5	40.6	881,648.5	0.00	1.00
08/17/2020 20:00	2	2.2	16.1	13.3	35.8	854,448.7	0.00	1.00
08/17/2020 21:00	2	2.0	14.9	13.9	32.4	844,543.6	0.00	1.00
08/17/2020 22:00	1	1.9	14.1	14.3	30.9	835,141.4	0.00	1.00
08/17/2020 23:00	1	2.0	13.4	14.2	24.7	747,256.1	0.00	1.00
Average/Sum#:	2	2.1	15.9	13.4	34.2	823,240.0	0.00 #	24.00 #
Minimum:	1	1.8	12.6	11.7	20.4	674,130.3	0.00	1.00
Maximum:	3	2.5	19.6	14.5	50.1	895,299.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/18/2020 00:00	1	1.9	13.7	14.3	23.5	694,256.7	0.00	1.00
08/18/2020 01:00	1	1.9	13.3	14.4	22.4	683,658.8	0.00	1.00
08/18/2020 02:00	1	1.9	13.7	14.4	22.6	644,050.8	0.00	1.00
08/18/2020 03:00	1	1.9	14.1	14.3	22.3	640,724.6	0.00	1.00
08/18/2020 04:00	1	1.9	13.5	14.3	21.2	676,412.7	0.00	1.00
08/18/2020 05:00	1	1.9	14.1	14.5	21.7	602,974.7	0.00	1.00
08/18/2020 06:00	1	1.9	14.6	14.4	23.2	612,870.1	0.00	1.00
08/18/2020 07:00	1	1.9	12.7	14.4	21.6	735,064.9	0.00	1.00
08/18/2020 08:00	2	1.9	14.9	14.0	33.0	841,104.4	0.00	1.00
08/18/2020 09:00	2	2.3	18.4	12.7	38.0	874,260.6	0.00	1.00
08/18/2020 10:00	2	2.4	18.5	12.7	39.9	878,268.6	0.00	1.00
08/18/2020 11:00	3	2.5	19.1	12.3	42.4	882,164.1	0.00	1.00
08/18/2020 12:00	3	2.6	19.4	11.8	47.6	889,072.4	0.00	1.00
08/18/2020 13:00	3	2.5	19.0	12.1	43.6	873,786.1	0.00	1.00
08/18/2020 14:00	3	2.5	18.9	12.3	41.7	870,221.4	0.00	1.00
08/18/2020 15:00	2	2.1	15.1	13.8	32.6	845,764.2	0.00	1.00
08/18/2020 16:00	2	2.2	16.2	13.3	34.3	850,304.4	0.00	1.00
08/18/2020 17:00	2	2.1	15.1	13.8	32.0	844,221.2	0.00	1.00
08/18/2020 18:00	2	2.1	15.8	13.4	33.7	847,034.6	0.00	1.00
08/18/2020 19:00	2	2.1	15.9	13.5	33.3	839,420.1	0.00	1.00
08/18/2020 20:00	1	2.0	13.5	14.3	22.0	662,095.9	0.00	1.00
08/18/2020 21:00	2	2.1	16.5	13.4	36.2	836,079.2	0.00	1.00
08/18/2020 22:00	2	2.1	15.7	13.7	34.2	847,141.1	0.00	1.00
08/18/2020 23:00	2	2.1	16.1	13.6	34.5	843,227.8	0.00	1.00
Average/Sum#:	2	2.1	15.7	13.6	31.6	783,924.1	0.00 #	24.00 #
Minimum:	1	1.9	12.7	11.8	21.2	602,974.7	0.00	1.00
Maximum:	3	2.6	19.4	14.5	47.6	889,072.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/19/2020 00:00	1	1.9	13.7	14.5	28.9	829,999.6	0.00	1.00
08/19/2020 01:00	1	1.9	13.4	14.4	25.4	776,779.6	0.00	1.00
08/19/2020 02:00	1	1.9	13.0	14.4	23.2	745,177.5	0.00	1.00
08/19/2020 03:00	1	1.9	13.5	14.4	23.6	710,625.9	0.00	1.00
08/19/2020 04:00	1	1.8	14.8	14.6	30.0	809,264.6	0.00	1.00
08/19/2020 05:00	1	1.9	15.0	14.6	31.5	827,523.6	0.00	1.00
08/19/2020 06:00	1	1.9	14.5	14.5	30.3	840,484.2	0.00	1.00
08/19/2020 07:00	2	2.0	15.8	14.0	36.0	865,317.4	0.00	1.00
08/19/2020 08:00	2	2.3	19.3	12.7	41.6	891,962.9	0.00	1.00
08/19/2020 09:00	2	2.2	17.9	13.0	39.9	873,484.7	0.00	1.00
08/19/2020 10:00	3	2.6	20.1	12.0	48.9	897,357.6	0.00	1.00
08/19/2020 11:00	3	2.6	20.6	11.9	52.1	897,125.1	0.00	1.00
08/19/2020 12:00	4	2.6	20.7	11.8	53.1	894,038.5	0.00	1.00
08/19/2020 13:00	3	2.5	20.0	12.3	47.0	881,049.4	0.00	1.00
08/19/2020 14:00	2	2.1	16.4	13.7	36.7	851,135.3	0.00	1.00
08/19/2020 15:00	2	2.0	15.8	13.8	35.9	858,687.0	0.00	1.00
08/19/2020 16:00	2	2.2	17.6	13.2	38.9	872,163.3	0.00	1.00
08/19/2020 17:00	3	2.6	20.1	12.0	48.3	885,663.7	0.00	1.00
08/19/2020 18:00	3	2.4	19.8	12.5	44.6	879,203.1	0.00	1.00
08/19/2020 19:00	2	2.2	17.4	13.4	37.9	864,015.5	0.00	1.00
08/19/2020 20:00	2	2.1	17.3	13.5	37.8	868,289.1	0.00	1.00
08/19/2020 21:00	2	2.1	16.9	13.6	36.8	870,241.1	0.00	1.00
08/19/2020 22:00	1	1.9	13.9	14.4	28.2	800,797.2	0.00	1.00
08/19/2020 23:00	1	1.9	14.0	14.4	27.4	777,201.0	0.00	1.00
Average/Sum#:	2	2.1	16.7	13.5	36.8	844,482.8	0.00 #	24.00 #
Minimum:	1	1.8	13.0	11.8	23.2	710,625.9	0.00	1.00
Maximum:	4	2.6	20.7	14.6	53.1	897,357.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/20/2020 00:00	1	1.9	14.6	14.4	24.0	681,552.0	0.00	1.00
08/20/2020 01:00	1	1.9	15.6	14.4	25.4	645,525.6	0.00	1.00
08/20/2020 02:00	2	1.9	15.4	14.5	24.3	595,913.6	0.00	1.00
08/20/2020 03:00	2	1.8	15.4	14.5	24.2	596,555.5	0.00	1.00
08/20/2020 04:00	1	1.8	15.7	14.5	24.2	596,769.5	0.00	1.00
08/20/2020 05:00	2	1.9	16.5	14.4	27.6	607,813.7	0.00	1.00
08/20/2020 06:00	2	1.9	16.6	14.3	27.7	622,050.7	0.00	1.00
08/20/2020 07:00	2	1.9	16.5	14.4	27.2	614,134.2	0.00	1.00
08/20/2020 08:00	2	1.9	16.1	14.4	26.4	643,629.5	0.00	1.00
08/20/2020 09:00	1	1.9	14.5	14.5	26.9	734,781.8	0.00	1.00
08/20/2020 10:00	1	1.8	15.8	14.6	33.6	824,263.1	0.00	1.00
08/20/2020 11:00	2	2.0	16.3	14.1	35.5	861,327.7	0.00	1.00
08/20/2020 12:00	1	1.9	14.9	14.4	32.1	833,452.7	0.00	1.00
08/20/2020 13:00	1	1.8	14.9	14.5	32.3	851,610.8	0.00	1.00
08/20/2020 14:00	1	1.9	13.6	14.3	21.7	699,443.9	0.00	1.00
08/20/2020 15:00	2	2.0	16.4	13.7	35.8	840,864.6	0.00	1.00
08/20/2020 16:00	1	1.9	13.6	14.4	25.8	762,242.7	0.00	1.00
08/20/2020 17:00	1	1.9	14.9	14.5	33.4	855,676.3	0.00	1.00
08/20/2020 18:00	2	2.0	16.5	13.7	34.6	852,466.7	0.00	1.00
08/20/2020 19:00	1	1.9	13.3	14.4	24.0	745,388.2	0.00	1.00
08/20/2020 20:00	1	1.9	13.6	14.4	26.7	778,465.1	0.00	1.00
08/20/2020 21:00	1	1.9	14.0	14.4	28.8	813,438.1	0.00	1.00
08/20/2020 22:00	1	1.9	13.6	14.3	23.2	711,063.2	0.00	1.00
08/20/2020 23:00	1	1.9	14.7	14.4	22.6	590,748.6	0.00	1.00
Average/Sum#:	1	1.9	15.1	14.4	27.8	723,299.1	0.00 #	24.00 #
Minimum:	1	1.8	13.3	13.7	21.7	590,748.6	0.00	1.00
Maximum:	2	2.0	16.6	14.6	35.8	861,327.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/21/2020 00:00	1	1.9	14.4	14.5	22.3	597,197.4	0.00	1.00
08/21/2020 01:00	1	1.9	14.6	14.5	22.8	596,983.4	0.00	1.00
08/21/2020 02:00	1	1.9	14.8	14.5	23.1	596,983.4	0.00	1.00
08/21/2020 03:00	2	1.9	15.5	14.3	25.6	610,638.8	0.00	1.00
08/21/2020 04:00	1	1.9	16.0	14.3	25.5	616,655.9	0.00	1.00
08/21/2020 05:00	2	1.9	15.5	14.4	24.3	588,220.4	0.00	1.00
08/21/2020 06:00	1	1.9	15.2	14.3	24.1	643,214.5	0.00	1.00
08/21/2020 07:00	1	1.9	13.7	14.4	25.0	742,228.0	0.00	1.00
08/21/2020 08:00	1	1.9	13.9	14.4	26.1	744,966.9	0.00	1.00
08/21/2020 09:00	1	1.8	14.6	14.5	31.3	824,650.2	0.00	1.00
08/21/2020 10:00	1	1.9	14.9	14.4	32.1	849,043.1	0.00	1.00
08/21/2020 11:00	1	1.9	14.4	14.4	31.1	835,559.6	0.00	1.00
08/21/2020 12:00	1	1.9	13.8	14.4	27.5	777,201.0	0.00	1.00
08/21/2020 13:00	3	2.4	19.6	12.3	45.6	892,832.9	0.00	1.00
08/21/2020 14:00	2	2.3	19.1	12.8	42.2	881,503.5	0.00	1.00
08/21/2020 15:00	3	2.5	20.2	12.2	46.2	883,514.8	0.00	1.00
08/21/2020 16:00	3	2.6	20.2	11.8	50.6	890,276.3	0.00	1.00
08/21/2020 17:00	3	2.6	20.0	11.8	50.5	891,781.2	0.00	1.00
08/21/2020 18:00	3	2.6	20.1	11.8	50.3	890,878.3	0.00	1.00
08/21/2020 19:00	1	1.9	14.6	14.3	31.0	817,712.3	0.00	1.00
08/21/2020 20:00	1	1.9	12.9	14.3	21.7	726,417.4	0.00	1.00
08/21/2020 21:00	2	2.2	18.0	12.9	40.1	869,755.7	0.00	1.00
08/21/2020 22:00	2	2.3	18.5	12.9	40.0	865,989.7	0.00	1.00
08/21/2020 23:00	1	1.9	13.7	14.4	24.2	715,050.2	0.00	1.00
Average/Sum#:	2	2.1	16.2	13.7	32.6	764,552.3	0.00 #	24.00 #
Minimum:	1	1.8	12.9	11.8	21.7	588,220.4	0.00	1.00
Maximum:	3	2.6	20.2	14.5	50.6	892,832.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/22/2020 00:00	1	1.9	14.6	14.5	22.8	602,332.8	0.00	1.00
08/22/2020 01:00	1	1.9	15.0	14.3	24.1	630,972.7	0.00	1.00
08/22/2020 02:00	2	1.9	15.2	14.3	25.2	617,278.4	0.00	1.00
08/22/2020 03:00	1	1.9	14.8	14.5	23.2	602,118.8	0.00	1.00
08/22/2020 04:00	1	1.8	15.4	14.5	24.1	596,555.5	0.00	1.00
08/22/2020 05:00	2	1.9	15.5	14.5	24.8	596,127.6	0.00	1.00
08/22/2020 06:00	2	1.9	16.1	14.4	26.4	607,392.4	0.00	1.00
08/22/2020 07:00	1	1.9	14.8	14.3	23.4	660,643.5	0.00	1.00
08/22/2020 08:00	1	1.9	14.3	14.3	23.4	662,510.9	0.00	1.00
08/22/2020 09:00	1	1.9	14.3	14.5	29.6	783,139.6	0.00	1.00
08/22/2020 10:00	1	1.8	15.2	14.5	32.3	830,855.5	0.00	1.00
08/22/2020 11:00	2	2.0	16.0	13.7	34.2	854,178.5	0.00	1.00
08/22/2020 12:00	2	2.0	15.0	14.2	32.7	838,823.5	0.00	1.00
08/22/2020 13:00	1	1.9	14.3	14.3	29.7	815,637.5	0.00	1.00
08/22/2020 14:00	2	1.9	14.6	14.2	32.2	821,859.0	0.00	1.00
08/22/2020 15:00	2	2.2	16.1	13.5	33.9	853,299.4	0.00	1.00
08/22/2020 16:00	3	2.5	19.2	12.2	43.2	869,033.6	0.00	1.00
08/22/2020 17:00	3	2.6	19.8	11.7	48.3	870,031.0	0.00	1.00
08/22/2020 18:00	3	2.6	19.6	11.8	47.4	869,057.8	0.00	1.00
08/22/2020 19:00	2	2.3	17.6	13.1	37.3	859,577.2	0.00	1.00
08/22/2020 20:00	2	2.2	17.3	13.3	37.8	861,836.4	0.00	1.00
08/22/2020 21:00	2	2.1	15.8	13.8	34.2	842,099.6	0.00	1.00
08/22/2020 22:00	1	1.9	14.5	14.5	31.4	840,484.2	0.00	1.00
08/22/2020 23:00	1	1.9	14.0	14.5	26.0	749,545.9	0.00	1.00
Average/Sum#:	2	2.0	15.8	13.9	31.2	755,641.3	0.00 #	24.00 #
Minimum:	1	1.8	14.0	11.7	22.8	596,127.6	0.00	1.00
Maximum:	3	2.6	19.8	14.5	48.3	870,031.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/23/2020 00:00	1	1.9	14.4	14.4	23.2	667,225.7	0.00	1.00
08/23/2020 01:00	2	1.9	15.2	14.5	24.7	621,804.3	0.00	1.00
08/23/2020 02:00	2	1.9	15.2	14.5	24.1	595,485.6	0.00	1.00
08/23/2020 03:00	2	1.8	15.2	14.5	24.1	595,699.6	0.00	1.00
08/23/2020 04:00	1	1.8	15.5	14.5	23.8	596,127.6	0.00	1.00
08/23/2020 05:00	1	1.9	15.3	14.5	24.1	596,341.5	0.00	1.00
08/23/2020 06:00	2	1.8	15.1	14.5	23.7	596,555.5	0.00	1.00
08/23/2020 07:00	2	1.9	15.2	14.5	24.2	596,341.5	0.00	1.00
08/23/2020 08:00	2	1.8	15.1	14.5	24.8	614,315.2	0.00	1.00
08/23/2020 09:00	1	1.9	14.1	14.6	26.8	783,397.7	0.00	1.00
08/23/2020 10:00	2	1.9	15.1	14.2	32.7	830,647.9	0.00	1.00
08/23/2020 11:00	2	2.3	19.1	12.8	41.2	887,251.7	0.00	1.00
08/23/2020 12:00	3	2.5	20.3	12.2	47.2	887,607.4	0.00	1.00
08/23/2020 13:00	3	2.5	20.2	12.2	47.5	879,579.7	0.00	1.00
08/23/2020 14:00	3	2.4	19.8	12.7	44.5	876,598.6	0.00	1.00
08/23/2020 15:00	2	2.3	19.9	12.8	44.1	872,374.1	0.00	1.00
08/23/2020 16:00	3	2.4	20.7	12.6	47.0	882,701.3	0.00	1.00
08/23/2020 17:00	3	2.4	20.3	12.8	46.0	885,561.1	0.00	1.00
08/23/2020 18:00	2	2.2	18.3	13.3	39.8	871,926.9	0.00	1.00
08/23/2020 19:00	2	1.9	15.5	14.2	34.3	838,823.5	0.00	1.00
08/23/2020 20:00	1	1.9	15.0	14.5	33.3	853,536.5	0.00	1.00
08/23/2020 21:00	2	2.1	17.3	13.4	36.9	862,007.0	0.00	1.00
08/23/2020 22:00	2	2.0	15.5	14.1	35.3	835,147.5	0.00	1.00
08/23/2020 23:00	1	1.9	13.9	14.4	23.8	709,993.9	0.00	1.00
Average/Sum#:	2	2.1	16.7	13.8	33.2	759,877.1	0.00 #	24.00 #
Minimum:	1	1.8	13.9	12.2	23.2	595,485.6	0.00	1.00
Maximum:	3	2.5	20.7	14.6	47.5	887,607.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/24/2020 00:00	1	1.9	14.4	14.4	23.6	663,012.1	0.00	1.00
08/24/2020 01:00	1	1.9	14.7	14.5	23.1	605,542.3	0.00	1.00
08/24/2020 02:00	1	1.9	14.5	14.5	22.7	596,983.4	0.00	1.00
08/24/2020 03:00	1	1.9	14.6	14.5	22.8	597,411.4	0.00	1.00
08/24/2020 04:00	1	1.8	15.5	14.3	24.7	630,765.2	0.00	1.00
08/24/2020 05:00	1	1.9	15.0	14.3	24.0	647,364.3	0.00	1.00
08/24/2020 06:00	1	1.9	13.6	14.4	23.5	714,207.5	0.00	1.00
08/24/2020 07:00	1	1.8	14.8	14.6	31.1	830,784.1	0.00	1.00
08/24/2020 08:00	2	2.0	16.0	13.9	34.6	851,782.0	0.00	1.00
08/24/2020 09:00	2	2.3	18.5	13.0	39.4	877,298.3	0.00	1.00
08/24/2020 10:00	2	2.3	19.3	12.8	42.0	880,151.0	0.00	1.00
08/24/2020 11:00	3	2.6	20.7	11.9	50.4	891,343.1	0.00	1.00
08/24/2020 12:00	3	2.4	20.1	12.4	45.1	878,042.7	0.00	1.00
08/24/2020 13:00	2	2.3	18.3	13.0	39.6	866,550.9	0.00	1.00
08/24/2020 14:00	2	2.4	19.0	12.7	40.8	870,920.5	0.00	1.00
08/24/2020 15:00	2	2.3	18.0	13.1	39.0	861,684.0	0.00	1.00
08/24/2020 16:00	2	2.4	19.6	12.7	42.8	874,260.6	0.00	1.00
08/24/2020 17:00	2	2.4	19.7	12.7	43.0	874,427.6	0.00	1.00
08/24/2020 18:00	2	2.3	18.6	13.1	40.1	866,424.3	0.00	1.00
08/24/2020 19:00	2	2.0	15.5	14.1	34.5	836,355.8	0.00	1.00
08/24/2020 20:00	1	1.9	13.7	14.4	27.4	791,316.6	0.00	1.00
08/24/2020 21:00	2	2.0	15.8	13.9	34.9	839,261.5	0.00	1.00
08/24/2020 22:00	2	2.1	16.2	13.7	35.1	836,870.5	0.00	1.00
08/24/2020 23:00	1	1.9	13.6	14.4	25.0	743,281.4	0.00	1.00
Average/Sum#:	2	2.1	16.7	13.6	33.7	788,585.0	0.00 #	24.00 #
Minimum:	1	1.8	13.6	11.9	22.7	596,983.4	0.00	1.00
Maximum:	3	2.6	20.7	14.6	50.4	891,343.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/25/2020 00:00	1	1.9	14.2	14.4	23.6	677,127.7	0.00	1.00
08/25/2020 01:00	2	1.9	15.9	14.5	25.9	609,393.9	0.00	1.00
08/25/2020 02:00	2	1.9	15.2	14.5	23.7	596,983.4	0.00	1.00
08/25/2020 03:00	1	1.9	14.9	14.5	23.4	597,197.4	0.00	1.00
08/25/2020 04:00	1	1.8	15.4	14.5	23.8	597,197.4	0.00	1.00
08/25/2020 05:00	1	1.9	15.2	14.5	23.9	597,839.3	0.00	1.00
08/25/2020 06:00	1	1.9	15.4	14.3	24.9	641,554.6	0.00	1.00
08/25/2020 07:00	1	1.9	13.8	14.4	24.1	711,468.6	0.00	1.00
08/25/2020 08:00	1	1.8	15.2	14.6	33.4	842,739.4	0.00	1.00
08/25/2020 09:00	1	1.9	15.3	14.5	33.0	859,955.7	0.00	1.00
08/25/2020 10:00	2	2.1	17.2	13.4	37.1	868,580.2	0.00	1.00
08/25/2020 11:00	2	2.4	19.6	12.6	42.8	883,856.2	0.00	1.00
08/25/2020 12:00	2	2.2	17.4	13.4	37.8	864,928.4	0.00	1.00
08/25/2020 13:00	2	2.2	17.1	13.4	37.0	865,658.8	0.00	1.00
08/25/2020 14:00	2	2.2	17.1	13.3	37.0	857,511.9	0.00	1.00
08/25/2020 15:00	2	2.3	19.0	12.7	41.2	867,580.4	0.00	1.00
08/25/2020 16:00	3	2.4	19.4	12.5	43.1	869,747.5	0.00	1.00
08/25/2020 17:00	3	2.6	20.2	11.8	49.5	874,625.8	0.00	1.00
08/25/2020 18:00	2	2.4	18.8	12.8	41.0	866,625.9	0.00	1.00
08/25/2020 19:00	2	2.2	17.2	13.3	36.9	851,565.7	0.00	1.00
08/25/2020 20:00	1	1.9	14.3	14.3	30.7	807,752.9	0.00	1.00
08/25/2020 21:00	1	1.9	14.3	14.5	31.1	840,270.2	0.00	1.00
08/25/2020 22:00	1	1.9	13.9	14.4	28.0	799,111.8	0.00	1.00
08/25/2020 23:00	1	1.9	14.5	14.3	23.0	654,833.8	0.00	1.00
Average/Sum#:	2	2.1	16.3	13.8	32.3	771,004.5	0.00 #	24.00 #
Minimum:	1	1.8	13.8	11.8	23.0	596,983.4	0.00	1.00
Maximum:	3	2.6	20.2	14.6	49.5	883,856.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/26/2020 00:00	2	1.9	15.0	14.5	23.9	601,690.8	0.00	1.00
08/26/2020 01:00	2	1.9	15.2	14.5	24.3	598,267.3	0.00	1.00
08/26/2020 02:00	2	1.9	15.1	14.5	24.1	597,197.4	0.00	1.00
08/26/2020 03:00	2	1.8	15.2	14.5	24.3	598,267.3	0.00	1.00
08/26/2020 04:00	2	1.8	16.7	14.4	27.4	610,552.6	0.00	1.00
08/26/2020 05:00	2	1.9	16.8	14.3	27.8	627,030.4	0.00	1.00
08/26/2020 06:00	2	1.9	17.2	14.3	27.1	633,877.5	0.00	1.00
08/26/2020 07:00	1	1.9	14.8	14.4	25.1	721,370.6	0.00	1.00
08/26/2020 08:00	1	1.8	15.6	14.5	31.3	812,881.8	0.00	1.00
08/26/2020 09:00	1	1.9	16.1	14.5	34.0	861,025.6	0.00	1.00
08/26/2020 10:00	2	2.0	17.1	13.9	36.7	864,302.4	0.00	1.00
08/26/2020 11:00	2	2.4	20.5	12.7	41.7	882,109.7	0.00	1.00
08/26/2020 12:00	3	2.6	21.3	12.0	48.5	883,663.4	0.00	1.00
08/26/2020 13:00	3	2.6	21.2	11.8	50.5	884,557.9	0.00	1.00
08/26/2020 14:00	3	2.6	21.0	11.8	50.1	882,902.5	0.00	1.00
08/26/2020 15:00	3	2.6	20.9	11.8	50.0	882,752.0	0.00	1.00
08/26/2020 16:00	3	2.6	21.1	11.8	51.0	884,708.3	0.00	1.00
08/26/2020 17:00	3	2.6	21.4	11.9	51.3	887,387.0	0.00	1.00
08/26/2020 18:00	2	2.2	18.2	13.4	38.0	858,537.8	0.00	1.00
08/26/2020 19:00	1	1.9	15.4	14.3	31.9	814,185.0	0.00	1.00
08/26/2020 20:00	1	1.9	14.8	14.5	30.3	832,139.3	0.00	1.00
08/26/2020 21:00	1	1.8	16.1	14.5	34.0	838,130.5	0.00	1.00
08/26/2020 22:00	1	1.9	16.4	14.3	25.0	652,759.0	0.00	1.00
08/26/2020 23:00	1	1.9	16.4	14.3	25.9	639,064.7	0.00	1.00
Average/Sum#:	2	2.1	17.5	13.6	34.8	764,556.7	0.00 #	24.00 #
Minimum:	1	1.8	14.8	11.8	23.9	597,197.4	0.00	1.00
Maximum:	3	2.6	21.4	14.5	51.3	887,387.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/27/2020 00:00	2	1.8	16.5	14.5	25.4	599,123.2	0.00	1.00
08/27/2020 01:00	2	1.9	16.9	14.5	26.5	599,123.2	0.00	1.00
08/27/2020 02:00	2	1.9	17.2	14.5	27.0	598,909.2	0.00	1.00
08/27/2020 03:00	2	1.9	17.6	14.4	27.9	590,116.6	0.00	1.00
08/27/2020 04:00	2	1.8	18.5	14.4	28.7	590,537.9	0.00	1.00
08/27/2020 05:00	2	1.9	18.4	14.4	28.9	590,959.3	0.00	1.00
08/27/2020 06:00	2	1.9	17.7	14.4	27.4	593,066.1	0.00	1.00
08/27/2020 07:00	2	1.9	17.2	14.4	26.8	594,751.5	0.00	1.00
08/27/2020 08:00	2	1.9	17.1	14.3	27.1	618,938.3	0.00	1.00
08/27/2020 09:00	1	1.9	14.8	14.4	23.0	696,088.9	0.00	1.00
08/27/2020 10:00	1	1.9	15.9	14.5	33.1	858,243.9	0.00	1.00
08/27/2020 11:00	2	2.0	17.2	13.9	35.6	861,759.2	0.00	1.00
08/27/2020 12:00	2	2.0	17.1	13.9	36.9	861,759.2	0.00	1.00
08/27/2020 13:00	2	2.3	20.0	12.8	40.7	877,107.9	0.00	1.00
08/27/2020 14:00	2	2.3	20.1	12.8	42.3	876,600.7	0.00	1.00
08/27/2020 15:00	2	2.3	19.4	13.0	41.2	866,377.6	0.00	1.00
08/27/2020 16:00	2	2.4	20.5	12.7	43.5	880,940.7	0.00	1.00
08/27/2020 17:00	3	2.4	20.6	12.5	44.5	873,660.2	0.00	1.00
08/27/2020 18:00	2	2.2	18.6	13.3	39.0	861,476.0	0.00	1.00
08/27/2020 19:00	2	2.0	16.7	13.9	35.4	851,390.7	0.00	1.00
08/27/2020 20:00	1	1.9	14.8	14.4	28.3	789,841.8	0.00	1.00
08/27/2020 21:00	1	1.8	15.9	14.5	33.5	819,942.8	0.00	1.00
08/27/2020 22:00	1	1.9	15.8	14.4	24.2	675,442.2	0.00	1.00
08/27/2020 23:00	1	1.9	16.5	14.3	25.8	631,802.6	0.00	1.00
Average/Sum#:	2	2.0	17.5	14.0	32.2	735,748.3	0.00 #	24.00 #
Minimum:	1	1.8	14.8	12.5	23.0	590,116.6	0.00	1.00
Maximum:	3	2.4	20.6	14.5	44.5	880,940.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/28/2020 00:00	1	1.8	16.2	14.5	24.4	598,053.3	0.00	1.00
08/28/2020 01:00	1	1.9	16.2	14.5	24.5	596,127.6	0.00	1.00
08/28/2020 02:00	1	1.9	16.0	14.5	24.3	596,341.5	0.00	1.00
08/28/2020 03:00	1	1.9	15.9	14.5	24.1	597,411.4	0.00	1.00
08/28/2020 04:00	1	1.8	16.5	14.5	24.6	597,197.4	0.00	1.00
08/28/2020 05:00	1	1.9	16.6	14.5	25.5	598,267.3	0.00	1.00
08/28/2020 06:00	1	1.9	16.5	14.5	25.0	599,979.1	0.00	1.00
08/28/2020 07:00	2	1.9	16.9	14.3	26.7	621,843.2	0.00	1.00
08/28/2020 08:00	1	1.9	14.5	14.4	23.1	709,993.9	0.00	1.00
08/28/2020 09:00	1	1.9	14.7	14.5	29.0	822,082.6	0.00	1.00
08/28/2020 10:00	1	1.9	15.8	14.5	32.6	852,466.7	0.00	1.00
08/28/2020 11:00	2	2.2	19.4	13.0	39.0	878,858.4	0.00	1.00
08/28/2020 12:00	3	2.7	21.7	11.8	51.5	890,125.8	0.00	1.00
08/28/2020 13:00	3	2.6	21.6	11.8	51.9	885,912.2	0.00	1.00
08/28/2020 14:00	2	2.4	20.5	12.6	44.0	873,626.8	0.00	1.00
08/28/2020 15:00	3	2.4	20.8	12.5	44.7	875,453.4	0.00	1.00
08/28/2020 16:00	3	2.6	21.5	11.8	51.4	883,654.9	0.00	1.00
08/28/2020 17:00	3	2.5	21.2	12.0	49.0	875,046.8	0.00	1.00
08/28/2020 18:00	2	2.2	18.0	13.4	37.3	856,164.1	0.00	1.00
08/28/2020 19:00	1	1.9	15.6	14.4	33.3	834,084.8	0.00	1.00
08/28/2020 20:00	1	1.9	15.7	14.5	32.8	845,833.5	0.00	1.00
08/28/2020 21:00	1	1.9	15.5	14.5	32.0	850,754.9	0.00	1.00
08/28/2020 22:00	1	1.8	15.3	14.4	29.0	806,907.0	0.00	1.00
08/28/2020 23:00	1	1.9	14.6	14.4	25.1	718,421.1	0.00	1.00
Average/Sum#:	2	2.1	17.4	13.8	33.5	761,025.3	0.00 #	24.00 #
Minimum:	1	1.8	14.5	11.8	23.1	596,127.6	0.00	1.00
Maximum:	3	2.7	21.7	14.5	51.9	890,125.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/29/2020 00:00	1	1.9	16.4	14.4	25.7	618,979.8	0.00	1.00
08/29/2020 01:00	1	1.9	15.9	14.5	23.6	598,909.2	0.00	1.00
08/29/2020 02:00	1	1.9	15.8	14.5	23.7	597,411.4	0.00	1.00
08/29/2020 03:00	1	1.9	15.9	14.5	24.1	597,197.4	0.00	1.00
08/29/2020 04:00	1	1.8	16.7	14.5	25.0	597,411.4	0.00	1.00
08/29/2020 05:00	1	1.9	16.8	14.5	25.7	598,267.3	0.00	1.00
08/29/2020 06:00	1	1.9	16.7	14.5	25.2	598,267.3	0.00	1.00
08/29/2020 07:00	2	1.9	16.5	14.5	25.3	599,551.1	0.00	1.00
08/29/2020 08:00	2	1.9	17.0	14.3	26.9	626,200.4	0.00	1.00
08/29/2020 09:00	1	1.9	14.7	14.5	25.0	739,061.2	0.00	1.00
08/29/2020 10:00	1	1.9	14.7	14.4	26.7	767,931.1	0.00	1.00
08/29/2020 11:00	1	1.9	15.7	14.5	32.6	850,540.9	0.00	1.00
08/29/2020 12:00	2	2.1	18.2	13.3	37.0	865,260.0	0.00	1.00
08/29/2020 13:00	3	2.6	21.3	12.0	47.7	887,664.0	0.00	1.00
08/29/2020 14:00	3	2.5	20.7	12.4	44.9	880,620.4	0.00	1.00
08/29/2020 15:00	3	2.6	21.3	11.8	50.3	876,732.6	0.00	1.00
08/29/2020 16:00	2	2.3	19.8	12.8	41.1	867,302.1	0.00	1.00
08/29/2020 17:00	2	2.2	17.9	13.5	37.5	861,256.9	0.00	1.00
08/29/2020 18:00	1	1.9	15.4	14.3	31.4	805,470.5	0.00	1.00
08/29/2020 19:00	1	1.9	14.0	14.4	23.6	735,486.2	0.00	1.00
08/29/2020 20:00	1	1.9	14.6	14.4	28.0	779,939.9	0.00	1.00
08/29/2020 21:00	1	1.8	16.0	14.5	34.1	854,178.5	0.00	1.00
08/29/2020 22:00	1	1.9	14.9	14.4	24.9	728,323.1	0.00	1.00
08/29/2020 23:00	1	1.9	15.3	14.4	24.6	680,709.3	0.00	1.00
Average/Sum#:	1	2.0	16.8	14.0	30.6	733,861.3	0.00 #	24.00 #
Minimum:	1	1.8	14.0	11.8	23.6	597,197.4	0.00	1.00
Maximum:	3	2.6	21.3	14.5	50.3	887,664.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/30/2020 00:00	1	1.8	16.1	14.5	24.4	599,123.2	0.00	1.00
08/30/2020 01:00	1	1.9	15.9	14.5	24.1	597,411.4	0.00	1.00
08/30/2020 02:00	1	1.9	16.1	14.5	24.5	597,839.3	0.00	1.00
08/30/2020 03:00	2	1.9	16.4	14.5	25.1	598,267.3	0.00	1.00
08/30/2020 04:00	1	1.8	17.1	14.5	25.6	598,481.3	0.00	1.00
08/30/2020 05:00	1	1.9	17.0	14.5	26.2	598,695.2	0.00	1.00
08/30/2020 06:00	2	1.9	17.3	14.5	26.9	599,551.1	0.00	1.00
08/30/2020 07:00	2	1.9	17.3	14.5	26.4	599,765.1	0.00	1.00
08/30/2020 08:00	1	1.9	16.4	14.5	24.6	598,909.2	0.00	1.00
08/30/2020 09:00	1	1.9	16.4	14.4	25.4	622,140.0	0.00	1.00
08/30/2020 10:00	1	1.9	14.5	14.5	23.7	734,567.8	0.00	1.00
08/30/2020 11:00	1	1.9	15.4	14.5	31.5	844,977.6	0.00	1.00
08/30/2020 12:00	2	2.1	18.0	13.4	36.1	869,310.6	0.00	1.00
08/30/2020 13:00	3	2.6	21.1	12.1	46.5	886,391.1	0.00	1.00
08/30/2020 14:00	3	2.6	21.1	11.8	49.7	885,009.3	0.00	1.00
08/30/2020 15:00	3	2.5	20.8	12.2	45.5	873,126.1	0.00	1.00
08/30/2020 16:00	2	2.3	19.4	12.9	39.9	859,827.3	0.00	1.00
08/30/2020 17:00	2	2.3	19.1	13.0	38.5	863,084.1	0.00	1.00
08/30/2020 18:00	1	2.0	15.5	14.3	32.2	816,052.4	0.00	1.00
08/30/2020 19:00	1	1.9	14.3	14.4	24.6	753,604.8	0.00	1.00
08/30/2020 20:00	1	1.9	14.1	14.3	22.0	682,637.3	0.00	1.00
08/30/2020 21:00	1	1.8	15.5	14.5	32.5	839,200.4	0.00	1.00
08/30/2020 22:00	1	2.6	17.4	14.4	20.2	626,564.3	0.10	1.00
08/30/2020 23:00	0	18.3	37.2	16.7	0.0	389,633.8	0.05	0.05
Average/Sum#:	2	2.7	17.9	14.1	29.0	705,590.4	0.15 #	23.05 #
Minimum:	1	1.8	14.1	11.8	0.0	389,633.8	0.00	0.05
Maximum:	3	18.3	37.2	16.7	49.7	886,391.1	0.10	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/31/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2020 14:00	0	25.4	31.5	17.5	0.0	584,019.2	0.27	0.27
08/31/2020 15:00	0	5.1	15.9	14.4	21.0	775,094.2	0.53	1.00
08/31/2020 16:00	2	2.2	19.4	13.3	39.6	856,430.8	0.00	1.00
08/31/2020 17:00	2	2.3	20.8	12.9	43.1	873,008.0	0.00	1.00
08/31/2020 18:00	2	2.2	19.4	13.2	39.2	862,203.8	0.00	1.00
08/31/2020 19:00	2	2.2	19.0	13.4	38.7	860,546.3	0.00	1.00
08/31/2020 20:00	1	1.8	15.6	14.4	23.9	632,252.7	0.00	1.00
08/31/2020 21:00	1	1.7	15.5	14.5	31.8	836,204.8	0.00	1.00
08/31/2020 22:00	1	1.9	14.4	14.3	22.5	704,423.6	0.00	1.00
08/31/2020 23:00	1	1.9	14.2	14.3	23.6	704,838.6	0.00	1.00
Average/Sum#:	1	4.7	18.6	14.2	28.3	768,902.2	0.80 #	9.27 #
Minimum:	0	1.7	14.2	12.9	0.0	584,019.2	0.00	0.00
Maximum:	2	25.4	31.5	17.5	43.1	873,008.0	0.53	1.00
%SI	62.50	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/01/2020 00:00	1	1.9	15.5	14.3	24.4	663,548.4	0.00	1.00
09/01/2020 01:00	2	1.9	16.7	14.4	26.0	605,706.9	0.00	1.00
09/01/2020 02:00	1	1.9	16.0	14.5	24.1	597,839.3	0.00	1.00
09/01/2020 03:00	2	1.9	16.5	14.5	25.3	598,053.3	0.00	1.00
09/01/2020 04:00	1	1.8	17.3	14.5	26.0	604,258.5	0.00	1.00
09/01/2020 05:00	1	1.9	15.2	14.4	24.7	720,527.9	0.00	1.00
09/01/2020 06:00	1	1.9	15.2	14.4	27.6	755,711.6	0.00	1.00
09/01/2020 07:00	1	1.9	15.6	14.5	31.8	844,121.7	0.00	1.00
09/01/2020 08:00	1	1.9	16.7	14.5	35.5	869,584.5	0.00	1.00
09/01/2020 09:00	1	1.9	16.3	14.5	33.8	861,881.5	0.00	1.00
09/01/2020 10:00	1	1.9	15.4	14.5	31.9	849,899.0	0.00	1.00
09/01/2020 11:00	2	1.9	16.6	14.0	34.7	839,516.7	0.00	1.00
09/01/2020 12:00	3	2.5	21.4	12.1	46.2	883,901.2	0.00	1.00
09/01/2020 13:00	3	2.6	21.6	12.0	48.4	879,816.7	0.00	1.00
09/01/2020 14:00	3	2.6	21.6	11.8	50.3	879,591.8	0.00	1.00
09/01/2020 15:00	3	2.6	21.6	11.8	50.6	882,451.1	0.00	1.00
09/01/2020 16:00	3	2.6	21.5	11.9	50.0	885,713.3	0.00	1.00
09/01/2020 17:00	3	2.5	21.1	12.4	45.8	879,331.6	0.00	1.00
09/01/2020 18:00	2	2.3	20.3	12.8	42.6	878,122.3	0.00	1.00
09/01/2020 19:00	2	2.3	19.5	13.1	41.1	877,485.0	0.00	1.00
09/01/2020 20:00	2	2.3	20.8	12.8	44.0	892,154.6	0.00	1.00
09/01/2020 21:00	2	2.0	16.7	14.2	36.2	845,364.1	0.00	1.00
09/01/2020 22:00	1	1.9	15.2	14.3	23.3	683,467.3	0.00	1.00
09/01/2020 23:00	1	1.9	14.6	14.4	25.1	719,263.8	0.00	1.00
Average/Sum#:	2	2.1	17.9	13.6	35.4	791,554.7	0.00 #	24.00 #
Minimum:	1	1.8	14.6	11.8	23.3	597,839.3	0.00	1.00
Maximum:	3	2.6	21.6	14.5	50.6	892,154.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/02/2020 00:00	1	1.9	14.9	14.4	26.6	737,171.7	0.00	1.00
09/02/2020 01:00	1	1.9	14.8	14.3	25.1	703,801.1	0.00	1.00
09/02/2020 02:00	1	1.9	14.8	14.3	24.9	693,219.2	0.00	1.00
09/02/2020 03:00	1	1.9	14.8	14.3	25.6	713,760.6	0.00	1.00
09/02/2020 04:00	1	1.8	15.3	14.4	27.3	750,655.2	0.00	1.00
09/02/2020 05:00	1	1.9	15.6	14.3	26.7	710,440.8	0.00	1.00
09/02/2020 06:00	1	1.9	15.1	14.3	25.2	703,386.2	0.00	1.00
09/02/2020 07:00	1	1.9	15.2	14.4	29.3	783,732.1	0.00	1.00
09/02/2020 08:00	1	1.9	16.1	14.5	34.6	869,156.5	0.00	1.00
09/02/2020 09:00	1	1.9	15.4	14.4	28.4	787,735.0	0.00	1.00
09/02/2020 10:00	1	1.8	15.4	14.6	29.8	803,830.4	0.00	1.00
09/02/2020 11:00	1	1.8	14.8	14.6	28.0	777,094.0	0.00	1.00
09/02/2020 12:00	1	1.8	14.6	14.6	28.8	797,526.7	0.00	1.00
09/02/2020 13:00	2	1.9	15.9	14.3	35.5	863,567.3	0.00	1.00
09/02/2020 14:00	2	2.3	19.8	12.8	41.4	890,802.1	0.00	1.00
09/02/2020 15:00	2	2.4	20.0	12.8	43.1	892,661.8	0.00	1.00
09/02/2020 16:00	2	2.4	20.0	12.8	43.3	892,830.9	0.00	1.00
09/02/2020 17:00	2	2.4	19.9	12.7	42.9	882,109.7	0.00	1.00
09/02/2020 18:00	2	2.2	18.4	13.2	39.3	875,008.8	0.00	1.00
09/02/2020 19:00	2	2.0	16.2	14.1	36.0	869,181.7	0.00	1.00
09/02/2020 20:00	1	1.8	14.2	14.5	28.2	806,890.5	0.00	1.00
09/02/2020 21:00	2	2.0	16.8	13.9	37.1	871,932.1	0.00	1.00
09/02/2020 22:00	1	1.8	14.7	14.6	32.4	860,128.9	0.00	1.00
09/02/2020 23:00	1	1.8	14.3	14.5	26.7	768,161.5	0.00	1.00
Average/Sum#:	1	2.0	16.1	14.1	31.9	804,366.0	0.00 #	24.00 #
Minimum:	1	1.8	14.2	12.7	24.9	693,219.2	0.00	1.00
Maximum:	2	2.4	20.0	14.6	43.3	892,830.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/03/2020 00:00	1	1.9	14.3	14.5	25.4	730,716.3	0.00	1.00
09/03/2020 01:00	1	1.9	14.3	14.5	24.9	717,877.9	0.00	1.00
09/03/2020 02:00	1	1.9	14.6	14.4	24.7	686,397.6	0.00	1.00
09/03/2020 03:00	1	1.9	14.4	14.4	24.7	699,038.5	0.00	1.00
09/03/2020 04:00	1	1.8	14.7	14.5	26.5	744,410.5	0.00	1.00
09/03/2020 05:00	1	1.9	14.7	14.5	27.5	756,607.0	0.00	1.00
09/03/2020 06:00	1	1.9	14.5	14.5	27.5	767,519.6	0.00	1.00
09/03/2020 07:00	1	1.8	14.4	14.5	27.7	768,589.4	0.00	1.00
09/03/2020 08:00	1	1.9	14.3	14.5	25.4	730,074.4	0.00	1.00
09/03/2020 09:00	1	1.8	14.2	14.5	26.4	744,410.5	0.00	1.00
09/03/2020 10:00	1	1.9	14.4	14.6	30.3	837,522.6	0.00	1.00
09/03/2020 11:00	1	1.8	15.5	14.4	34.0	850,307.2	0.00	1.00
09/03/2020 12:00	2	2.4	19.9	12.6	42.2	892,105.7	0.00	1.00
09/03/2020 13:00	3	2.6	20.7	11.8	50.0	888,922.0	0.00	1.00
09/03/2020 14:00	3	2.6	20.6	11.8	50.4	886,363.7	0.00	1.00
09/03/2020 15:00	3	2.6	20.6	11.8	50.6	886,213.2	0.00	1.00
09/03/2020 16:00	3	2.6	20.5	11.8	50.0	881,999.6	0.00	1.00
09/03/2020 17:00	3	2.6	20.6	11.9	50.1	892,560.4	0.00	1.00
09/03/2020 18:00	3	2.6	20.7	11.9	50.6	893,777.6	0.00	1.00
09/03/2020 19:00	3	2.5	20.8	12.2	48.2	892,959.1	0.00	1.00
09/03/2020 20:00	3	2.5	20.7	12.4	46.9	898,020.2	0.00	1.00
09/03/2020 21:00	3	2.4	20.5	12.6	45.9	899,200.3	0.00	1.00
09/03/2020 22:00	2	2.0	16.1	14.3	36.0	866,264.7	0.00	1.00
09/03/2020 23:00	1	1.9	14.4	14.5	26.6	760,030.5	0.00	1.00
Average/Sum#:	2	2.2	17.1	13.5	36.4	815,495.4	0.00 #	24.00 #
Minimum:	1	1.8	14.2	11.8	24.7	686,397.6	0.00	1.00
Maximum:	3	2.6	20.8	14.6	50.6	899,200.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/04/2020 00:00	1	1.9	14.2	14.5	25.0	727,078.8	0.00	1.00
09/04/2020 01:00	1	1.9	14.6	14.5	24.9	703,327.8	0.00	1.00
09/04/2020 02:00	1	1.9	14.4	14.5	25.1	712,956.6	0.00	1.00
09/04/2020 03:00	1	1.9	14.4	14.5	25.7	730,074.4	0.00	1.00
09/04/2020 04:00	1	1.8	15.0	14.5	28.2	761,742.3	0.00	1.00
09/04/2020 05:00	1	1.9	15.0	14.4	26.1	712,311.4	0.00	1.00
09/04/2020 06:00	1	1.9	14.7	14.4	24.9	692,928.7	0.00	1.00
09/04/2020 07:00	1	1.9	14.4	14.5	25.3	720,445.6	0.00	1.00
09/04/2020 08:00	1	1.8	14.9	14.6	29.9	797,309.3	0.00	1.00
09/04/2020 09:00	1	1.8	15.0	14.6	30.3	817,089.9	0.00	1.00
09/04/2020 10:00	1	1.8	15.3	14.6	33.4	867,519.5	0.00	1.00
09/04/2020 11:00	2	2.0	16.6	13.9	35.7	871,540.8	0.00	1.00
09/04/2020 12:00	2	2.3	19.1	12.9	40.0	882,936.4	0.00	1.00
09/04/2020 13:00	3	2.6	20.9	11.9	49.3	891,799.6	0.00	1.00
09/04/2020 14:00	3	2.6	20.9	11.9	50.3	893,929.8	0.00	1.00
09/04/2020 15:00	3	2.6	20.9	11.9	50.3	893,016.9	0.00	1.00
09/04/2020 16:00	3	2.6	20.7	11.8	49.8	880,946.2	0.00	1.00
09/04/2020 17:00	3	2.6	20.6	11.8	49.5	881,397.7	0.00	1.00
09/04/2020 18:00	3	2.6	20.4	11.8	49.1	883,203.5	0.00	1.00
09/04/2020 19:00	3	2.6	20.7	11.8	49.8	885,611.3	0.00	1.00
09/04/2020 20:00	3	2.6	21.1	11.9	50.9	897,125.1	0.00	1.00
09/04/2020 21:00	3	2.6	21.4	12.1	50.7	902,263.9	0.00	1.00
09/04/2020 22:00	2	2.2	19.0	13.2	41.1	881,055.6	0.00	1.00
09/04/2020 23:00	1	1.9	14.8	14.5	24.9	715,952.2	0.00	1.00
Average/Sum#:	2	2.2	17.5	13.4	37.1	816,815.1	0.00 #	24.00 #
Minimum:	1	1.8	14.2	11.8	24.9	692,928.7	0.00	1.00
Maximum:	3	2.6	21.4	14.6	50.9	902,263.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/05/2020 00:00	1	1.9	14.7	14.5	24.2	688,777.7	0.00	1.00
09/05/2020 01:00	1	1.8	14.5	14.5	25.1	703,969.7	0.00	1.00
09/05/2020 02:00	1	1.8	14.7	14.5	25.3	703,541.8	0.00	1.00
09/05/2020 03:00	2	1.9	16.3	14.4	27.3	644,050.8	0.00	1.00
09/05/2020 04:00	1	1.8	16.4	14.4	26.3	637,941.1	0.00	1.00
09/05/2020 05:00	1	1.8	15.3	14.6	24.0	613,197.8	0.00	1.00
09/05/2020 06:00	1	1.8	15.2	14.6	23.9	613,415.2	0.00	1.00
09/05/2020 07:00	1	1.8	15.2	14.6	24.4	619,718.9	0.00	1.00
09/05/2020 08:00	1	1.8	15.5	14.5	24.9	672,515.8	0.00	1.00
09/05/2020 09:00	1	1.8	15.2	14.7	31.1	833,140.1	0.00	1.00
09/05/2020 10:00	1	1.9	16.3	13.9	34.2	872,714.6	0.00	1.00
09/05/2020 11:00	2	2.4	19.4	12.7	40.5	884,614.8	0.00	1.00
09/05/2020 12:00	3	2.6	20.4	12.1	45.6	887,480.4	0.00	1.00
09/05/2020 13:00	3	2.6	20.2	11.8	47.7	879,591.8	0.00	1.00
09/05/2020 14:00	3	2.6	20.3	11.8	48.5	878,688.9	0.00	1.00
09/05/2020 15:00	3	2.6	20.6	11.9	49.4	889,517.2	0.00	1.00
09/05/2020 16:00	3	2.6	20.4	11.9	49.1	887,539.2	0.00	1.00
09/05/2020 17:00	3	2.6	20.4	12.0	48.5	890,279.7	0.00	1.00
09/05/2020 18:00	2	2.3	18.9	12.9	39.9	880,539.9	0.00	1.00
09/05/2020 19:00	2	2.4	19.8	12.5	43.3	882,463.6	0.00	1.00
09/05/2020 20:00	3	2.6	20.9	12.0	49.6	898,280.8	0.00	1.00
09/05/2020 21:00	2	2.4	19.9	12.6	43.6	889,300.9	0.00	1.00
09/05/2020 22:00	2	2.0	15.6	14.1	34.0	856,897.2	0.00	1.00
09/05/2020 23:00	1	1.8	14.4	14.6	28.9	804,265.1	0.00	1.00
Average/Sum#:	2	2.2	17.5	13.4	35.8	792,185.1	0.00 #	24.00 #
Minimum:	1	1.8	14.4	11.8	23.9	613,197.8	0.00	1.00
Maximum:	3	2.6	20.9	14.7	49.6	898,280.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/06/2020 00:00	1	1.8	14.0	14.6	24.7	743,401.8	0.00	1.00
09/06/2020 01:00	1	1.9	14.5	14.5	23.6	681,716.6	0.00	1.00
09/06/2020 02:00	1	1.8	14.8	14.6	23.4	612,545.7	0.00	1.00
09/06/2020 03:00	1	1.8	14.6	14.6	22.9	612,763.1	0.00	1.00
09/06/2020 04:00	1	1.8	14.9	14.6	22.5	612,980.4	0.00	1.00
09/06/2020 05:00	1	1.9	14.7	14.6	23.0	616,675.7	0.00	1.00
09/06/2020 06:00	1	1.8	15.6	14.5	25.2	638,280.1	0.00	1.00
09/06/2020 07:00	1	1.9	15.5	14.4	25.0	645,314.9	0.00	1.00
09/06/2020 08:00	1	1.9	13.5	14.5	22.4	722,585.3	0.00	1.00
09/06/2020 09:00	1	1.8	14.6	14.6	30.8	856,433.7	0.00	1.00
09/06/2020 10:00	1	1.8	14.4	14.6	29.1	843,391.5	0.00	1.00
09/06/2020 11:00	1	1.9	13.6	14.5	24.7	761,956.3	0.00	1.00
09/06/2020 12:00	2	2.0	16.9	13.7	35.5	867,111.9	0.00	1.00
09/06/2020 13:00	2	2.3	19.6	12.8	41.7	878,629.4	0.00	1.00
09/06/2020 14:00	3	2.5	20.7	12.2	46.3	885,875.9	0.00	1.00
09/06/2020 15:00	3	2.6	20.6	11.9	49.0	883,735.2	0.00	1.00
09/06/2020 16:00	3	2.6	20.6	11.9	49.1	882,822.3	0.00	1.00
09/06/2020 17:00	3	2.6	20.2	11.8	48.0	871,465.6	0.00	1.00
09/06/2020 18:00	3	2.6	20.3	12.0	48.3	882,586.3	0.00	1.00
09/06/2020 19:00	3	2.5	20.3	12.3	44.9	880,412.5	0.00	1.00
09/06/2020 20:00	3	2.5	20.3	12.2	44.9	880,051.9	0.00	1.00
09/06/2020 21:00	3	2.6	20.2	11.9	46.8	877,801.0	0.00	1.00
09/06/2020 22:00	2	2.3	18.0	13.1	37.7	870,462.3	0.00	1.00
09/06/2020 23:00	1	1.9	14.9	14.4	31.2	829,449.8	0.00	1.00
Average/Sum#:	2	2.1	17.0	13.5	34.2	784,935.4	0.00 #	24.00 #
Minimum:	1	1.8	13.5	11.8	22.4	612,545.7	0.00	1.00
Maximum:	3	2.6	20.7	14.6	49.1	885,875.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/07/2020 00:00	1	1.9	13.4	14.5	23.4	752,541.5	0.00	1.00
09/07/2020 01:00	1	1.9	14.2	14.4	22.9	677,759.7	0.00	1.00
09/07/2020 02:00	2	1.8	15.8	14.6	26.6	635,586.8	0.00	1.00
09/07/2020 03:00	2	1.8	15.9	14.6	26.1	629,500.5	0.00	1.00
09/07/2020 04:00	1	1.8	15.5	14.6	23.5	611,241.5	0.00	1.00
09/07/2020 05:00	1	1.8	15.3	14.6	24.0	611,024.1	0.00	1.00
09/07/2020 06:00	1	1.8	15.2	14.6	24.3	613,197.8	0.00	1.00
09/07/2020 07:00	1	1.8	15.5	14.5	25.1	657,323.7	0.00	1.00
09/07/2020 08:00	1	1.9	14.0	14.6	27.2	797,309.3	0.00	1.00
09/07/2020 09:00	2	2.0	17.3	13.6	36.7	864,050.5	0.00	1.00
09/07/2020 10:00	3	2.6	21.1	12.0	48.2	892,126.1	0.00	1.00
09/07/2020 11:00	3	2.5	20.9	12.2	47.5	887,764.8	0.00	1.00
09/07/2020 12:00	2	2.2	18.0	13.2	38.5	860,425.3	0.00	1.00
09/07/2020 13:00	3	2.6	20.5	12.0	47.4	880,739.9	0.00	1.00
09/07/2020 14:00	2	2.2	18.2	13.2	38.5	870,029.1	0.00	1.00
09/07/2020 15:00	2	2.2	17.1	13.5	36.0	854,594.8	0.00	1.00
09/07/2020 16:00	2	2.4	18.9	12.7	39.5	868,415.5	0.00	1.00
09/07/2020 17:00	2	2.2	16.8	13.5	34.2	853,484.5	0.00	1.00
09/07/2020 18:00	2	2.0	14.7	14.1	31.2	830,515.6	0.00	1.00
09/07/2020 19:00	1	1.9	14.3	14.5	30.8	834,065.0	0.00	1.00
09/07/2020 20:00	1	1.9	15.1	14.1	32.0	834,140.6	0.00	1.00
09/07/2020 21:00	2	2.2	18.2	13.1	37.6	870,637.9	0.00	1.00
09/07/2020 22:00	1	1.9	15.2	14.5	32.7	842,837.9	0.00	1.00
09/07/2020 23:00	1	1.8	14.0	14.5	25.9	784,209.4	0.00	1.00
Average/Sum#:	2	2.0	16.5	13.8	32.5	783,896.7	0.00 #	24.00 #
Minimum:	1	1.8	13.4	12.0	22.9	611,024.1	0.00	1.00
Maximum:	3	2.6	21.1	14.6	48.2	892,126.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/08/2020 00:00	1	1.9	13.6	14.4	21.3	690,611.3	0.00	1.00
09/08/2020 01:00	1	1.8	13.6	14.5	27.5	795,336.0	0.00	1.00
09/08/2020 02:00	1	1.8	14.7	14.6	30.8	829,262.5	0.00	1.00
09/08/2020 03:00	1	1.8	14.1	14.5	24.8	738,847.2	0.00	1.00
09/08/2020 04:00	1	1.8	14.9	14.5	27.6	754,039.3	0.00	1.00
09/08/2020 05:00	1	1.8	15.9	14.7	32.0	819,666.8	0.00	1.00
09/08/2020 06:00	1	1.8	16.2	14.6	36.4	880,996.4	0.00	1.00
09/08/2020 07:00	2	2.0	18.2	13.9	39.8	887,778.3	0.00	1.00
09/08/2020 08:00	2	2.2	19.3	13.4	42.8	902,724.6	0.00	1.00
09/08/2020 09:00	2	2.3	21.5	12.8	47.4	912,442.4	0.00	1.00
09/08/2020 10:00	2	2.1	18.6	13.7	41.1	893,169.0	0.00	1.00
09/08/2020 11:00	1	1.9	15.1	14.6	32.1	832,523.1	0.00	1.00
09/08/2020 12:00	1	1.8	15.1	14.6	32.2	841,217.8	0.00	1.00
09/08/2020 13:00	1	1.8	15.4	14.6	33.9	858,824.7	0.00	1.00
09/08/2020 14:00	1	1.9	14.7	14.5	24.5	719,803.7	0.00	1.00
09/08/2020 15:00	1	1.8	14.7	14.6	22.3	610,372.0	0.00	1.00
09/08/2020 16:00	2	1.8	16.3	14.7	27.1	617,345.3	0.00	1.00
09/08/2020 17:00	2	1.8	16.8	14.7	28.4	618,670.6	0.00	1.00
09/08/2020 18:00	2	1.8	16.7	14.6	27.8	641,238.4	0.00	1.00
09/08/2020 19:00	1	1.8	16.0	14.6	26.4	680,582.2	0.00	1.00
09/08/2020 20:00	2	1.8	16.6	14.7	28.2	638,328.5	0.00	1.00
09/08/2020 21:00	1	1.8	15.6	14.6	32.4	855,781.6	0.00	1.00
09/08/2020 22:00	1	1.8	16.1	14.7	33.3	809,948.3	0.00	1.00
09/08/2020 23:00	1	1.8	17.3	14.7	28.5	643,408.6	0.00	1.00
Average/Sum#:	1	1.9	16.1	14.4	31.2	769,704.9	0.00 #	24.00 #
Minimum:	1	1.8	13.6	12.8	21.3	610,372.0	0.00	1.00
Maximum:	2	2.3	21.5	14.7	47.4	912,442.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/09/2020 00:00	2	1.8	17.0	14.7	27.9	620,216.7	0.00	1.00
09/09/2020 01:00	2	1.8	16.8	14.7	27.8	620,658.5	0.00	1.00
09/09/2020 02:00	2	1.8	16.5	14.6	26.8	612,111.0	0.00	1.00
09/09/2020 03:00	2	1.8	16.6	14.6	27.4	612,111.0	0.00	1.00
09/09/2020 04:00	1	1.8	17.2	14.6	27.5	612,328.3	0.00	1.00
09/09/2020 05:00	2	1.8	17.1	14.6	28.3	616,893.1	0.00	1.00
09/09/2020 06:00	1	1.9	15.3	14.5	27.3	750,187.8	0.00	1.00
09/09/2020 07:00	3	2.4	22.2	12.1	53.7	939,611.9	0.00	1.00
09/09/2020 08:00	4	2.6	23.0	11.8	58.6	931,810.5	0.00	1.00
09/09/2020 09:00	3	2.6	22.8	11.9	57.2	931,969.4	0.00	1.00
09/09/2020 10:00	3	2.6	22.5	11.9	56.3	925,578.7	0.00	1.00
09/09/2020 11:00	4	2.6	22.4	11.9	56.5	924,209.3	0.00	1.00
09/09/2020 12:00	4	2.6	22.0	11.9	55.8	921,470.5	0.00	1.00
09/09/2020 13:00	3	2.6	21.8	11.9	55.3	919,035.9	0.00	1.00
09/09/2020 14:00	4	2.6	21.7	11.9	55.1	919,188.1	0.00	1.00
09/09/2020 15:00	4	2.6	21.7	11.9	55.2	919,948.9	0.00	1.00
09/09/2020 16:00	3	2.6	21.6	11.9	54.3	910,819.4	0.00	1.00
09/09/2020 17:00	1	1.9	14.5	14.4	26.4	756,132.9	0.00	1.00
09/09/2020 18:00	1	1.9	13.8	14.5	25.9	762,170.3	0.00	1.00
09/09/2020 19:00	1	1.8	14.9	14.5	30.7	821,012.7	0.00	1.00
09/09/2020 20:00	1	1.9	14.7	14.4	23.9	703,252.1	0.00	1.00
09/09/2020 21:00	2	1.9	16.5	14.4	27.3	651,635.3	0.00	1.00
09/09/2020 22:00	1	1.9	15.3	14.4	24.2	683,869.5	0.00	1.00
09/09/2020 23:00	1	1.9	15.1	14.4	25.0	696,299.6	0.00	1.00
Average/Sum#:	2	2.2	18.5	13.4	38.9	781,771.7	0.00 #	24.00 #
Minimum:	1	1.8	13.8	11.8	23.9	612,111.0	0.00	1.00
Maximum:	4	2.6	23.0	14.7	58.6	939,611.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/10/2020 00:00	2	1.9	17.0	14.5	27.8	618,380.7	0.00	1.00
09/10/2020 01:00	1	1.9	15.5	14.5	23.8	621,162.3	0.00	1.00
09/10/2020 02:00	2	1.8	17.4	14.5	28.6	607,682.1	0.00	1.00
09/10/2020 03:00	2	1.8	17.4	14.5	27.9	607,682.1	0.00	1.00
09/10/2020 04:00	1	1.9	17.2	14.5	26.8	631,861.0	0.00	1.00
09/10/2020 05:00	1	1.9	18.0	14.6	29.2	617,110.4	0.00	1.00
09/10/2020 06:00	2	1.8	17.7	14.6	28.9	620,805.7	0.00	1.00
09/10/2020 07:00	2	1.9	17.2	14.5	28.4	636,568.4	0.00	1.00
09/10/2020 08:00	2	1.8	17.1	14.6	27.3	616,023.6	0.00	1.00
09/10/2020 09:00	1	1.9	16.2	14.4	26.1	664,065.5	0.00	1.00
09/10/2020 10:00	1	1.8	14.9	14.5	23.8	709,961.0	0.00	1.00
09/10/2020 11:00	1	1.8	15.3	14.6	32.8	874,040.5	0.00	1.00
09/10/2020 12:00	1	1.8	15.4	14.6	30.7	867,084.7	0.00	1.00
09/10/2020 13:00	1	1.9	16.7	14.2	36.0	866,212.0	0.00	1.00
09/10/2020 14:00	1	1.9	16.2	14.4	34.2	863,369.4	0.00	1.00
09/10/2020 15:00	1	1.9	15.9	14.4	33.3	866,951.0	0.00	1.00
09/10/2020 16:00	1	1.8	15.0	14.6	31.8	876,431.6	0.00	1.00
09/10/2020 17:00	1	1.9	16.1	14.3	34.2	866,472.2	0.00	1.00
09/10/2020 18:00	1	1.9	15.1	14.5	30.7	843,051.9	0.00	1.00
09/10/2020 19:00	2	2.2	20.0	13.0	41.8	919,941.2	0.00	1.00
09/10/2020 20:00	2	2.0	16.8	14.1	37.2	885,091.2	0.00	1.00
09/10/2020 21:00	1	1.9	16.1	14.3	34.1	865,642.2	0.00	1.00
09/10/2020 22:00	1	1.8	14.7	14.5	27.1	782,711.6	0.00	1.00
09/10/2020 23:00	1	1.9	15.7	14.4	24.3	676,074.3	0.00	1.00
Average/Sum#:	1	1.9	16.4	14.4	30.3	750,182.4	0.00 #	24.00 #
Minimum:	1	1.8	14.7	13.0	23.8	607,682.1	0.00	1.00
Maximum:	2	2.2	20.0	14.6	41.8	919,941.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/11/2020 00:00	1	1.9	15.6	14.4	25.0	680,919.9	0.00	1.00
09/11/2020 01:00	1	1.8	16.6	14.4	26.5	636,887.7	0.00	1.00
09/11/2020 02:00	1	1.8	16.5	14.6	25.8	615,588.9	0.00	1.00
09/11/2020 03:00	1	1.8	16.6	14.6	25.7	619,284.1	0.00	1.00
09/11/2020 04:00	1	1.7	16.2	14.4	25.5	684,501.5	0.00	1.00
09/11/2020 05:00	2	1.9	18.2	14.5	29.7	611,105.6	0.00	1.00
09/11/2020 06:00	2	1.8	18.0	14.6	28.5	616,241.0	0.00	1.00
09/11/2020 07:00	1	1.9	16.7	14.5	26.2	635,926.4	0.00	1.00
09/11/2020 08:00	1	1.9	15.3	14.4	24.0	690,821.9	0.00	1.00
09/11/2020 09:00	1	1.8	15.6	14.6	31.9	841,652.6	0.00	1.00
09/11/2020 10:00	1	1.8	15.6	14.6	31.5	875,344.8	0.00	1.00
09/11/2020 11:00	1	1.8	16.1	14.6	33.9	888,386.9	0.00	1.00
09/11/2020 12:00	1	1.9	16.5	14.2	35.6	873,978.9	0.00	1.00
09/11/2020 13:00	2	2.0	17.2	13.9	36.2	895,603.5	0.00	1.00
09/11/2020 14:00	2	2.2	18.9	13.2	38.7	892,260.0	0.00	1.00
09/11/2020 15:00	1	1.9	15.5	14.6	32.5	827,958.3	0.00	1.00
09/11/2020 16:00	1	1.8	15.9	14.7	31.2	836,453.2	0.00	1.00
09/11/2020 17:00	1	1.8	15.9	14.6	34.2	879,909.5	0.00	1.00
09/11/2020 18:00	1	1.9	14.8	14.6	28.7	838,392.0	0.00	1.00
09/11/2020 19:00	1	1.9	15.5	14.4	23.2	658,166.4	0.00	1.00
09/11/2020 20:00	1	1.9	14.4	14.5	27.2	794,266.1	0.00	1.00
09/11/2020 21:00	1	1.8	16.2	14.6	34.7	891,647.4	0.00	1.00
09/11/2020 22:00	1	1.9	14.7	14.5	26.9	800,685.3	0.00	1.00
09/11/2020 23:00	1	1.8	14.9	14.5	28.3	807,960.4	0.00	1.00
Average/Sum#:	1	1.9	16.1	14.4	29.7	766,414.3	0.00 #	24.00 #
Minimum:	1	1.7	14.4	13.2	23.2	611,105.6	0.00	1.00
Maximum:	2	2.2	18.9	14.7	38.7	895,603.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/12/2020 00:00	1	1.9	14.9	14.4	23.7	693,350.1	0.00	1.00
09/12/2020 01:00	2	1.8	17.4	14.5	27.7	608,538.0	0.00	1.00
09/12/2020 02:00	2	1.8	17.7	14.5	27.9	608,324.0	0.00	1.00
09/12/2020 03:00	2	1.8	17.9	14.5	28.4	608,324.0	0.00	1.00
09/12/2020 04:00	2	1.8	18.6	14.5	29.3	608,324.0	0.00	1.00
09/12/2020 05:00	1	1.8	18.0	14.5	28.1	612,175.5	0.00	1.00
09/12/2020 06:00	1	1.9	16.2	14.4	25.6	625,932.3	0.00	1.00
09/12/2020 07:00	1	1.9	16.5	14.5	26.0	621,804.3	0.00	1.00
09/12/2020 08:00	1	1.9	16.5	14.4	26.4	644,682.9	0.00	1.00
09/12/2020 09:00	1	1.9	14.9	14.4	22.7	692,718.1	0.00	1.00
09/12/2020 10:00	1	1.9	14.1	14.5	25.4	778,432.2	0.00	1.00
09/12/2020 11:00	1	1.8	14.9	14.6	29.9	849,043.1	0.00	1.00
09/12/2020 12:00	1	1.8	15.9	14.5	33.5	860,597.6	0.00	1.00
09/12/2020 13:00	2	2.3	19.9	12.9	40.8	900,567.7	0.00	1.00
09/12/2020 14:00	3	2.5	21.4	12.2	47.0	901,459.0	0.00	1.00
09/12/2020 15:00	2	2.0	16.6	14.0	35.1	862,737.4	0.00	1.00
09/12/2020 16:00	2	2.0	16.6	13.9	35.8	875,062.2	0.00	1.00
09/12/2020 17:00	2	2.4	20.8	12.4	44.0	893,025.8	0.00	1.00
09/12/2020 18:00	1	1.9	15.4	14.4	32.3	839,983.8	0.00	1.00
09/12/2020 19:00	1	1.8	14.2	14.5	25.7	786,349.2	0.00	1.00
09/12/2020 20:00	1	1.9	14.0	14.5	25.5	774,580.7	0.00	1.00
09/12/2020 21:00	1	1.9	15.7	14.5	33.8	865,947.0	0.00	1.00
09/12/2020 22:00	1	1.9	14.5	14.5	26.1	788,488.9	0.00	1.00
09/12/2020 23:00	1	1.9	14.1	14.5	24.9	761,100.4	0.00	1.00
Average/Sum#:	1	1.9	16.5	14.2	30.2	752,564.5	0.00 #	24.00 #
Minimum:	1	1.8	14.0	12.2	22.7	608,324.0	0.00	1.00
Maximum:	3	2.5	21.4	14.6	47.0	901,459.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/13/2020 00:00	1	1.9	14.8	14.4	23.4	687,240.4	0.00	1.00
09/13/2020 01:00	1	1.9	16.0	14.4	25.3	635,412.9	0.00	1.00
09/13/2020 02:00	1	1.9	15.8	14.5	24.3	612,603.4	0.00	1.00
09/13/2020 03:00	1	1.8	16.3	14.5	25.2	613,245.4	0.00	1.00
09/13/2020 04:00	1	1.8	16.5	14.5	25.5	613,031.4	0.00	1.00
09/13/2020 05:00	1	1.9	17.2	14.5	27.2	608,965.9	0.00	1.00
09/13/2020 06:00	1	1.8	17.0	14.6	26.6	617,327.8	0.00	1.00
09/13/2020 07:00	1	1.8	16.3	14.6	25.0	620,588.4	0.00	1.00
09/13/2020 08:00	1	1.8	15.9	14.4	24.6	671,228.6	0.00	1.00
09/13/2020 09:00	1	1.9	14.9	14.6	27.4	784,919.3	0.00	1.00
09/13/2020 10:00	1	1.8	15.5	14.6	31.3	857,303.1	0.00	1.00
09/13/2020 11:00	1	2.0	17.2	14.0	35.9	881,393.3	0.00	1.00
09/13/2020 12:00	2	2.0	17.4	13.7	37.0	881,947.3	0.00	1.00
09/13/2020 13:00	3	1.1	19.2	13.0	49.4	884,925.5	0.00	1.00
09/13/2020 14:00	2	2.4	20.6	12.7	39.0	892,630.9	0.00	1.00
09/13/2020 15:00	2	2.3	19.8	13.0	40.1	880,071.8	0.00	1.00
09/13/2020 16:00	2	2.0	16.2	14.2	34.9	858,240.7	0.00	1.00
09/13/2020 17:00	1	2.0	15.9	14.1	34.1	863,744.3	0.00	1.00
09/13/2020 18:00	1	2.0	16.1	14.1	33.2	856,293.0	0.00	1.00
09/13/2020 19:00	1	1.9	14.3	14.6	25.4	756,009.2	0.00	1.00
09/13/2020 20:00	2	2.1	18.2	13.5	38.1	857,185.6	0.00	1.00
09/13/2020 21:00	2	2.0	16.6	14.2	36.5	884,811.7	0.00	1.00
09/13/2020 22:00	1	1.9	15.3	14.5	30.6	827,431.9	0.00	1.00
09/13/2020 23:00	1	1.9	15.1	14.5	24.3	708,677.1	0.00	1.00
Average/Sum#:	1	1.9	16.6	14.2	31.0	764,801.2	0.00 #	24.00 #
Minimum:	1	1.1	14.3	12.7	23.4	608,965.9	0.00	1.00
Maximum:	3	2.4	20.6	14.6	49.4	892,630.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/14/2020 00:00	1	1.9	16.5	14.5	26.4	646,197.1	0.00	1.00
09/14/2020 01:00	1	1.8	16.4	14.6	25.7	616,241.0	0.00	1.00
09/14/2020 02:00	1	1.8	16.8	14.6	26.6	616,458.3	0.00	1.00
09/14/2020 03:00	1	1.8	16.9	14.6	26.7	616,893.1	0.00	1.00
09/14/2020 04:00	1	1.9	17.0	14.6	25.9	620,153.6	0.00	1.00
09/14/2020 05:00	1	1.8	17.4	14.6	28.0	618,632.0	0.00	1.00
09/14/2020 06:00	1	1.8	16.9	14.6	26.2	627,761.5	0.00	1.00
09/14/2020 07:00	1	1.9	17.1	14.4	27.3	655,216.9	0.00	1.00
09/14/2020 08:00	1	1.9	14.7	14.5	24.4	739,917.1	0.00	1.00
09/14/2020 09:00	1	1.8	15.2	14.6	29.3	809,482.0	0.00	1.00
09/14/2020 10:00	1	1.8	16.8	14.7	35.3	869,363.6	0.00	1.00
09/14/2020 11:00	1	1.8	15.9	14.6	32.7	878,387.9	0.00	1.00
09/14/2020 12:00	1	2.0	17.5	13.8	36.3	881,060.6	0.00	1.00
09/14/2020 13:00	2	2.4	20.9	12.7	42.9	912,003.2	0.00	1.00
09/14/2020 14:00	3	2.6	21.7	12.0	50.3	913,206.0	0.00	1.00
09/14/2020 15:00	2	2.4	20.5	12.7	43.3	896,472.0	0.00	1.00
09/14/2020 16:00	3	2.5	21.5	12.2	47.3	900,357.2	0.00	1.00
09/14/2020 17:00	3	2.6	21.7	11.9	51.0	905,037.4	0.00	1.00
09/14/2020 18:00	3	2.4	20.8	12.5	46.4	904,146.1	0.00	1.00
09/14/2020 19:00	1	1.9	15.2	14.6	28.7	795,353.0	0.00	1.00
09/14/2020 20:00	1	1.8	16.3	14.7	33.5	836,674.1	0.00	1.00
09/14/2020 21:00	1	1.9	16.6	14.4	35.6	879,591.8	0.00	1.00
09/14/2020 22:00	1	1.8	15.4	14.6	30.3	823,828.3	0.00	1.00
09/14/2020 23:00	1	1.9	15.4	14.5	24.7	712,956.6	0.00	1.00
Average/Sum#:	1	2.0	17.5	14.0	33.5	778,141.3	0.00 #	24.00 #
Minimum:	1	1.8	14.7	11.9	24.4	616,241.0	0.00	1.00
Maximum:	3	2.6	21.7	14.7	51.0	913,206.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/15/2020 00:00	1	1.9	16.8	14.4	26.9	663,433.4	0.00	1.00
09/15/2020 01:00	1	1.9	16.9	14.5	26.3	637,210.3	0.00	1.00
09/15/2020 02:00	1	1.8	16.8	14.6	26.4	617,545.2	0.00	1.00
09/15/2020 03:00	1	1.8	17.1	14.6	26.9	617,545.2	0.00	1.00
09/15/2020 04:00	1	1.7	16.9	14.6	26.2	629,500.5	0.00	1.00
09/15/2020 05:00	1	1.8	17.6	14.4	27.8	646,789.7	0.00	1.00
09/15/2020 06:00	1	1.9	17.4	14.4	27.6	655,006.2	0.00	1.00
09/15/2020 07:00	1	1.9	15.5	14.4	24.2	701,777.3	0.00	1.00
09/15/2020 08:00	1	1.8	15.0	14.6	28.6	807,743.0	0.00	1.00
09/15/2020 09:00	1	1.8	16.8	14.7	35.5	877,315.1	0.00	1.00
09/15/2020 10:00	1	1.8	16.3	14.6	33.5	878,387.9	0.00	1.00
09/15/2020 11:00	1	1.9	16.6	14.2	35.1	876,431.6	0.00	1.00
09/15/2020 12:00	2	2.3	20.0	12.9	40.1	901,594.8	0.00	1.00
09/15/2020 13:00	3	2.6	21.9	12.1	48.8	907,710.5	0.00	1.00
09/15/2020 14:00	3	2.6	21.7	12.0	50.8	911,513.5	0.00	1.00
09/15/2020 15:00	3	2.5	21.7	12.1	50.1	906,932.4	0.00	1.00
09/15/2020 16:00	2	2.4	21.4	12.6	46.9	912,564.6	0.00	1.00
09/15/2020 17:00	2	2.4	21.4	12.5	46.9	903,820.1	0.00	1.00
09/15/2020 18:00	2	2.2	18.9	13.4	39.7	891,221.4	0.00	1.00
09/15/2020 19:00	2	1.9	16.7	14.2	36.3	848,838.7	0.00	1.00
09/15/2020 20:00	1	1.9	14.5	14.5	25.2	766,877.7	0.00	1.00
09/15/2020 21:00	1	1.8	15.8	14.6	34.1	867,519.5	0.00	1.00
09/15/2020 22:00	1	1.8	14.9	14.6	26.1	778,615.6	0.00	1.00
09/15/2020 23:00	1	1.8	14.9	14.6	27.1	767,095.0	0.00	1.00
Average/Sum#:	1	2.0	17.6	13.9	34.0	790,541.2	0.00 #	24.00 #
Minimum:	1	1.7	14.5	12.0	24.2	617,545.2	0.00	1.00
Maximum:	3	2.6	21.9	14.7	50.8	912,564.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/16/2020 00:00	1	1.8	14.9	14.5	25.4	732,000.1	0.00	1.00
09/16/2020 01:00	1	1.9	15.0	14.5	25.2	718,947.8	0.00	1.00
09/16/2020 02:00	1	1.9	15.3	14.5	24.6	690,275.5	0.00	1.00
09/16/2020 03:00	1	1.9	15.4	14.4	25.0	676,706.3	0.00	1.00
09/16/2020 04:00	1	1.8	15.8	14.4	24.6	679,866.5	0.00	1.00
09/16/2020 05:00	1	1.9	14.6	14.5	24.6	731,358.2	0.00	1.00
09/16/2020 06:00	1	1.9	14.8	14.5	26.7	761,528.3	0.00	1.00
09/16/2020 07:00	1	1.8	15.3	14.6	30.7	829,697.3	0.00	1.00
09/16/2020 08:00	1	1.8	16.4	14.6	35.2	871,432.1	0.00	1.00
09/16/2020 09:00	1	1.9	15.2	14.6	31.4	875,127.4	0.00	1.00
09/16/2020 10:00	2	1.9	16.6	14.1	36.3	882,876.0	0.00	1.00
09/16/2020 11:00	2	2.2	19.1	13.2	41.2	906,843.5	0.00	1.00
09/16/2020 12:00	3	2.2	21.6	12.2	51.4	894,690.6	0.00	1.00
09/16/2020 13:00	2	2.4	20.8	12.6	45.7	906,295.0	0.00	1.00
09/16/2020 14:00	3	2.6	21.6	12.0	51.5	902,743.0	0.00	1.00
09/16/2020 15:00	3	2.6	21.2	12.0	51.0	904,589.4	0.00	1.00
09/16/2020 16:00	3	2.6	21.2	12.0	51.9	909,205.5	0.00	1.00
09/16/2020 17:00	3	2.6	21.2	12.0	51.5	901,665.9	0.00	1.00
09/16/2020 18:00	3	2.4	20.4	12.6	46.0	895,240.6	0.00	1.00
09/16/2020 19:00	2	2.1	17.7	13.6	38.8	882,059.4	0.00	1.00
09/16/2020 20:00	2	2.0	16.3	14.0	36.1	871,866.9	0.00	1.00
09/16/2020 21:00	2	2.0	16.3	14.0	35.9	872,065.3	0.00	1.00
09/16/2020 22:00	1	1.9	13.8	14.5	26.0	782,069.7	0.00	1.00
09/16/2020 23:00	1	1.8	13.8	14.5	25.8	770,729.2	0.00	1.00
Average/Sum#:	2	2.1	17.3	13.7	35.9	827,078.3	0.00 #	24.00 #
Minimum:	1	1.8	13.8	12.0	24.6	676,706.3	0.00	1.00
Maximum:	3	2.6	21.6	14.6	51.9	909,205.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/17/2020 00:00	1	1.9	14.1	14.5	25.4	744,410.5	0.00	1.00
09/17/2020 01:00	1	1.9	14.2	14.5	24.4	716,380.1	0.00	1.00
09/17/2020 02:00	1	1.9	14.3	14.5	24.0	705,681.5	0.00	1.00
09/17/2020 03:00	1	1.9	14.4	14.5	24.1	704,183.7	0.00	1.00
09/17/2020 04:00	1	1.8	14.7	14.5	25.8	742,698.8	0.00	1.00
09/17/2020 05:00	1	1.8	14.4	14.5	27.2	766,877.7	0.00	1.00
09/17/2020 06:00	1	1.8	15.1	14.6	30.8	822,524.1	0.00	1.00
09/17/2020 07:00	1	1.8	16.7	14.6	37.2	874,692.7	0.00	1.00
09/17/2020 08:00	1	1.8	16.3	14.6	35.3	871,866.9	0.00	1.00
09/17/2020 09:00	1	1.8	15.6	14.6	33.5	879,692.1	0.00	1.00
09/17/2020 10:00	2	1.9	16.2	14.2	35.1	874,592.1	0.00	1.00
09/17/2020 11:00	2	2.0	16.4	14.0	35.6	880,599.4	0.00	1.00
09/17/2020 12:00	2	2.0	16.5	13.8	36.1	872,381.2	0.00	1.00
09/17/2020 13:00	2	2.2	17.5	13.5	37.8	888,460.3	0.00	1.00
09/17/2020 14:00	2	2.3	18.6	13.1	40.5	892,232.7	0.00	1.00
09/17/2020 15:00	3	2.6	21.2	12.0	50.0	902,589.2	0.00	1.00
09/17/2020 16:00	3	2.6	21.1	11.9	50.7	896,364.3	0.00	1.00
09/17/2020 17:00	2	2.3	19.5	12.8	43.2	887,589.9	0.00	1.00
09/17/2020 18:00	2	2.2	18.7	13.2	41.4	892,082.2	0.00	1.00
09/17/2020 19:00	2	2.0	16.3	14.0	37.0	874,843.9	0.00	1.00
09/17/2020 20:00	2	2.1	16.8	13.8	37.8	886,461.2	0.00	1.00
09/17/2020 21:00	2	2.1	17.8	13.5	39.8	892,161.5	0.00	1.00
09/17/2020 22:00	1	1.8	15.8	14.5	34.8	860,811.6	0.00	1.00
09/17/2020 23:00	1	1.9	14.1	14.4	24.0	735,275.6	0.00	1.00
Average/Sum#:	2	2.0	16.5	13.9	34.6	836,060.6	0.00 #	24.00 #
Minimum:	1	1.8	14.1	11.9	24.0	704,183.7	0.00	1.00
Maximum:	3	2.6	21.2	14.6	50.7	902,589.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/18/2020 00:00	1	1.9	14.1	14.4	23.3	691,243.3	0.00	1.00
09/18/2020 01:00	2	1.9	15.7	14.4	26.1	633,938.1	0.00	1.00
09/18/2020 02:00	2	1.9	15.6	14.4	25.4	625,932.3	0.00	1.00
09/18/2020 03:00	2	1.9	15.7	14.5	25.9	636,140.4	0.00	1.00
09/18/2020 04:00	1	1.8	16.6	14.4	26.7	651,846.0	0.00	1.00
09/18/2020 05:00	1	1.9	14.7	14.5	25.3	726,222.9	0.00	1.00
09/18/2020 06:00	1	1.8	14.3	14.5	27.1	775,864.5	0.00	1.00
09/18/2020 07:00	1	1.8	15.1	14.6	31.8	842,956.8	0.00	1.00
09/18/2020 08:00	2	1.9	16.9	14.2	37.0	866,212.0	0.00	1.00
09/18/2020 09:00	2	1.9	17.0	14.2	37.1	868,869.1	0.00	1.00
09/18/2020 10:00	2	2.0	17.8	13.8	38.5	879,517.6	0.00	1.00
09/18/2020 11:00	2	2.1	18.5	13.5	39.8	869,029.3	0.00	1.00
09/18/2020 12:00	2	2.2	18.4	13.3	39.9	889,044.7	0.00	1.00
09/18/2020 13:00	2	2.3	19.8	12.9	43.0	905,018.3	0.00	1.00
09/18/2020 14:00	2	2.3	19.9	12.9	43.5	900,225.4	0.00	1.00
09/18/2020 15:00	2	2.0	16.3	14.1	37.4	870,390.0	0.00	1.00
09/18/2020 16:00	2	2.0	16.6	14.0	37.1	891,713.6	0.00	1.00
09/18/2020 17:00	2	2.2	18.2	13.3	39.3	892,288.1	0.00	1.00
09/18/2020 18:00	2	2.0	15.9	14.2	36.3	868,869.1	0.00	1.00
09/18/2020 19:00	1	1.9	13.9	14.5	23.5	733,711.9	0.00	1.00
09/18/2020 20:00	2	2.0	17.0	13.7	37.3	868,633.5	0.00	1.00
09/18/2020 21:00	1	1.9	15.0	14.6	33.4	876,214.2	0.00	1.00
09/18/2020 22:00	1	1.9	14.0	14.5	24.7	761,956.3	0.00	1.00
09/18/2020 23:00	1	1.9	14.1	14.5	24.4	725,367.0	0.00	1.00
Average/Sum#:	2	2.0	16.3	14.1	32.7	802,133.5	0.00 #	24.00 #
Minimum:	1	1.8	13.9	12.9	23.3	625,932.3	0.00	1.00
Maximum:	2	2.3	19.9	14.6	43.5	905,018.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/19/2020 00:00	1	1.9	15.5	14.5	25.9	654,970.0	0.00	1.00
09/19/2020 01:00	2	1.9	16.0	14.5	26.3	629,935.2	0.00	1.00
09/19/2020 02:00	2	1.8	16.4	14.6	26.7	615,588.9	0.00	1.00
09/19/2020 03:00	2	1.8	16.6	14.6	26.8	615,371.5	0.00	1.00
09/19/2020 04:00	1	1.8	17.2	14.6	27.1	615,154.1	0.00	1.00
09/19/2020 05:00	2	1.9	16.6	14.4	27.3	633,095.4	0.00	1.00
09/19/2020 06:00	1	1.9	16.6	14.4	27.1	659,641.2	0.00	1.00
09/19/2020 07:00	1	1.9	14.1	14.5	24.2	749,759.9	0.00	1.00
09/19/2020 08:00	1	1.8	14.7	14.6	29.7	826,002.0	0.00	1.00
09/19/2020 09:00	1	1.8	16.1	14.6	35.0	871,214.8	0.00	1.00
09/19/2020 10:00	1	1.8	15.9	14.6	34.4	884,691.6	0.00	1.00
09/19/2020 11:00	2	2.0	16.3	14.1	35.5	883,882.9	0.00	1.00
09/19/2020 12:00	2	2.2	17.8	13.4	37.7	893,412.5	0.00	1.00
09/19/2020 13:00	2	2.2	18.1	13.3	39.1	893,008.8	0.00	1.00
09/19/2020 14:00	2	2.1	17.4	13.5	38.2	879,762.6	0.00	1.00
09/19/2020 15:00	2	2.2	17.7	13.4	37.7	886,474.1	0.00	1.00
09/19/2020 16:00	2	1.9	15.3	14.4	34.1	847,779.0	0.00	1.00
09/19/2020 17:00	1	1.8	14.6	14.6	31.6	862,085.3	0.00	1.00
09/19/2020 18:00	1	1.9	15.8	14.3	34.7	856,720.2	0.00	1.00
09/19/2020 19:00	2	2.2	18.1	13.4	38.3	899,803.1	0.00	1.00
09/19/2020 20:00	1	1.9	15.4	14.6	34.4	872,736.3	0.00	1.00
09/19/2020 21:00	1	1.9	14.5	14.6	29.1	834,262.0	0.00	1.00
09/19/2020 22:00	1	1.8	14.4	14.6	26.9	776,659.3	0.00	1.00
09/19/2020 23:00	1	1.9	14.5	14.5	24.7	716,594.1	0.00	1.00
Average/Sum#:	1	1.9	16.1	14.3	31.4	785,775.2	0.00 #	24.00 #
Minimum:	1	1.8	14.1	13.3	24.2	615,154.1	0.00	1.00
Maximum:	2	2.2	18.1	14.6	39.1	899,803.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/20/2020 00:00	1	1.8	16.3	14.5	26.3	639,564.0	0.00	1.00
09/20/2020 01:00	1	1.8	15.8	14.6	24.8	615,154.1	0.00	1.00
09/20/2020 02:00	1	1.8	16.1	14.6	25.6	615,371.5	0.00	1.00
09/20/2020 03:00	2	1.8	16.3	14.6	26.2	615,371.5	0.00	1.00
09/20/2020 04:00	1	1.8	16.8	14.6	26.2	616,241.0	0.00	1.00
09/20/2020 05:00	1	1.8	16.2	14.6	25.4	619,284.1	0.00	1.00
09/20/2020 06:00	1	1.8	16.1	14.6	25.6	619,066.8	0.00	1.00
09/20/2020 07:00	1	1.8	16.4	14.6	26.2	615,806.2	0.00	1.00
09/20/2020 08:00	1	1.8	15.7	14.6	25.0	624,501.0	0.00	1.00
09/20/2020 09:00	1	1.8	15.5	14.5	24.7	687,707.8	0.00	1.00
09/20/2020 10:00	1	1.8	15.0	14.6	29.0	782,963.0	0.00	1.00
09/20/2020 11:00	1	1.8	16.5	14.7	34.4	854,123.2	0.00	1.00
09/20/2020 12:00	2	2.1	18.0	13.5	38.0	887,905.2	0.00	1.00
09/20/2020 13:00	2	2.3	20.2	12.8	42.3	903,482.0	0.00	1.00
09/20/2020 14:00	3	2.5	21.6	12.2	49.2	912,477.4	0.00	1.00
09/20/2020 15:00	3	2.6	21.3	12.0	51.5	911,205.8	0.00	1.00
09/20/2020 16:00	2	2.3	19.2	13.1	41.2	888,194.6	0.00	1.00
09/20/2020 17:00	1	1.9	15.3	14.3	32.6	828,501.8	0.00	1.00
09/20/2020 18:00	1	1.8	15.4	14.6	33.9	865,345.8	0.00	1.00
09/20/2020 19:00	1	1.9	14.8	14.6	30.4	845,347.8	0.00	1.00
09/20/2020 20:00	2	2.0	17.3	13.7	37.4	880,045.4	0.00	1.00
09/20/2020 21:00	1	1.8	15.0	14.6	32.3	862,302.6	0.00	1.00
09/20/2020 22:00	1	1.9	14.3	14.5	25.6	769,445.3	0.00	1.00
09/20/2020 23:00	1	1.9	14.4	14.4	24.8	716,103.6	0.00	1.00
Average/Sum#:	1	1.9	16.6	14.1	31.6	757,313.0	0.00 #	24.00 #
Minimum:	1	1.8	14.3	12.0	24.7	615,154.1	0.00	1.00
Maximum:	3	2.6	21.6	14.7	51.5	912,477.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/21/2020 00:00	2	1.8	16.8	14.5	27.6	648,550.8	0.00	1.00
09/21/2020 01:00	1	1.8	15.8	14.6	24.8	614,067.3	0.00	1.00
09/21/2020 02:00	2	1.8	16.0	14.6	25.8	616,893.1	0.00	1.00
09/21/2020 03:00	2	1.8	16.8	14.5	27.8	635,498.5	0.00	1.00
09/21/2020 04:00	1	1.8	17.3	14.4	27.7	649,528.5	0.00	1.00
09/21/2020 05:00	1	1.8	15.1	14.5	25.3	718,733.8	0.00	1.00
09/21/2020 06:00	1	1.8	15.1	14.6	28.2	773,398.7	0.00	1.00
09/21/2020 07:00	1	1.8	15.3	14.6	30.2	795,353.0	0.00	1.00
09/21/2020 08:00	1	1.8	16.8	14.7	36.4	864,504.4	0.00	1.00
09/21/2020 09:00	1	1.8	15.5	14.6	32.8	872,301.6	0.00	1.00
09/21/2020 10:00	2	1.9	16.7	14.2	37.0	874,796.5	0.00	1.00
09/21/2020 11:00	2	2.4	20.7	12.7	43.6	909,832.2	0.00	1.00
09/21/2020 12:00	3	2.5	21.2	12.3	47.8	900,635.4	0.00	1.00
09/21/2020 13:00	3	2.6	21.3	11.9	52.2	906,863.3	0.00	1.00
09/21/2020 14:00	3	2.6	21.1	11.9	52.0	906,254.6	0.00	1.00
09/21/2020 15:00	3	2.6	21.1	11.9	52.5	907,015.4	0.00	1.00
09/21/2020 16:00	3	2.5	21.1	12.2	49.6	902,718.3	0.00	1.00
09/21/2020 17:00	3	2.5	21.7	12.1	50.8	903,820.1	0.00	1.00
09/21/2020 18:00	3	2.5	21.4	12.3	49.5	905,730.9	0.00	1.00
09/21/2020 19:00	2	2.1	17.4	13.8	38.9	887,232.7	0.00	1.00
09/21/2020 20:00	1	1.9	14.7	14.6	30.8	847,521.5	0.00	1.00
09/21/2020 21:00	2	1.9	16.4	14.3	36.5	885,146.1	0.00	1.00
09/21/2020 22:00	1	1.8	14.6	14.5	29.1	815,235.5	0.00	1.00
09/21/2020 23:00	1	1.9	14.7	14.5	25.5	728,362.6	0.00	1.00
Average/Sum#:	2	2.1	17.7	13.7	36.8	811,249.8	0.00 #	24.00 #
Minimum:	1	1.8	14.6	11.9	24.8	614,067.3	0.00	1.00
Maximum:	3	2.6	21.7	14.7	52.5	909,832.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/22/2020 00:00	1	1.9	16.3	14.4	27.1	652,267.4	0.00	1.00
09/22/2020 01:00	2	1.9	16.7	14.4	27.7	651,846.0	0.00	1.00
09/22/2020 02:00	2	1.9	16.4	14.5	27.2	639,991.9	0.00	1.00
09/22/2020 03:00	2	1.9	16.3	14.5	27.2	639,564.0	0.00	1.00
09/22/2020 04:00	1	1.8	16.5	14.4	26.6	664,065.5	0.00	1.00
09/22/2020 05:00	1	1.8	14.5	14.5	25.7	749,117.9	0.00	1.00
09/22/2020 06:00	1	1.9	14.6	14.5	25.3	733,497.9	0.00	1.00
09/22/2020 07:00	1	1.8	14.7	14.6	29.5	805,786.7	0.00	1.00
09/22/2020 08:00	1	1.8	16.3	14.7	36.4	880,849.1	0.00	1.00
09/22/2020 09:00	1	1.9	16.3	14.3	35.5	869,584.5	0.00	1.00
09/22/2020 10:00	2	2.1	17.9	13.5	38.5	897,343.1	0.00	1.00
09/22/2020 11:00	2	2.2	18.3	13.3	40.2	901,477.7	0.00	1.00
09/22/2020 12:00	2	2.4	20.3	12.6	45.0	910,419.7	0.00	1.00
09/22/2020 13:00	3	2.4	20.4	12.5	46.1	903,820.1	0.00	1.00
09/22/2020 14:00	2	2.3	19.8	12.8	44.0	900,607.9	0.00	1.00
09/22/2020 15:00	2	2.3	19.2	13.1	42.3	898,201.9	0.00	1.00
09/22/2020 16:00	2	2.4	20.5	12.7	46.2	914,007.3	0.00	1.00
09/22/2020 17:00	2	2.3	19.6	13.0	43.3	904,340.1	0.00	1.00
09/22/2020 18:00	2	2.2	18.2	13.5	40.2	895,677.6	0.00	1.00
09/22/2020 19:00	1	1.8	14.7	14.6	31.1	846,652.1	0.00	1.00
09/22/2020 20:00	2	2.1	18.3	13.5	40.4	892,346.5	0.00	1.00
09/22/2020 21:00	1	1.9	15.3	14.5	34.1	859,099.8	0.00	1.00
09/22/2020 22:00	1	1.8	15.1	14.5	26.8	745,480.4	0.00	1.00
09/22/2020 23:00	1	1.9	15.4	14.5	26.0	694,768.9	0.00	1.00
Average/Sum#:	2	2.0	17.2	13.9	34.7	810,450.6	0.00 #	24.00 #
Minimum:	1	1.8	14.5	12.5	25.3	639,564.0	0.00	1.00
Maximum:	3	2.4	20.5	14.7	46.2	914,007.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/23/2020 00:00	2	1.8	16.6	14.6	27.6	625,370.5	0.00	1.00
09/23/2020 01:00	2	1.8	17.1	14.6	28.3	617,327.8	0.00	1.00
09/23/2020 02:00	2	1.8	17.4	14.6	28.8	617,110.4	0.00	1.00
09/23/2020 03:00	2	1.8	17.6	14.6	29.2	616,675.7	0.00	1.00
09/23/2020 04:00	1	1.8	18.2	14.6	29.7	620,805.7	0.00	1.00
09/23/2020 05:00	1	1.9	17.2	14.4	27.9	671,439.3	0.00	1.00
09/23/2020 06:00	1	1.9	15.5	14.5	26.4	715,310.3	0.00	1.00
09/23/2020 07:00	1	1.8	15.2	14.6	28.3	770,355.6	0.00	1.00
09/23/2020 08:00	1	1.8	16.6	14.7	36.1	872,235.0	0.00	1.00
09/23/2020 09:00	1	1.9	16.4	14.6	36.1	894,038.5	0.00	1.00
09/23/2020 10:00	1	1.8	16.3	14.6	35.9	886,865.3	0.00	1.00
09/23/2020 11:00	2	2.0	17.2	14.0	37.2	884,767.2	0.00	1.00
09/23/2020 12:00	2	2.1	17.4	13.7	38.3	894,690.6	0.00	1.00
09/23/2020 13:00	2	2.1	17.8	13.5	39.7	893,271.8	0.00	1.00
09/23/2020 14:00	2	2.4	20.5	12.6	46.1	906,954.9	0.00	1.00
09/23/2020 15:00	2	2.2	19.0	13.1	42.2	889,950.3	0.00	1.00
09/23/2020 16:00	3	2.4	20.6	12.5	46.4	901,211.7	0.00	1.00
09/23/2020 17:00	3	2.6	21.5	12.0	51.8	916,129.5	0.00	1.00
09/23/2020 18:00	3	2.5	21.2	12.1	50.0	910,511.6	0.00	1.00
09/23/2020 19:00	2	2.3	18.7	13.1	41.3	894,339.5	0.00	1.00
09/23/2020 20:00	2	2.0	16.4	14.0	36.8	886,751.9	0.00	1.00
09/23/2020 21:00	2	1.9	15.8	14.3	35.4	877,054.1	0.00	1.00
09/23/2020 22:00	1	1.8	14.7	14.5	32.0	837,916.5	0.00	1.00
09/23/2020 23:00	1	1.8	15.7	14.6	34.5	892,082.2	0.00	1.00
Average/Sum#:	2	2.0	17.5	13.9	36.1	812,215.2	0.00 #	24.00 #
Minimum:	1	1.8	14.7	12.0	26.4	616,675.7	0.00	1.00
Maximum:	3	2.6	21.5	14.7	51.8	916,129.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/24/2020 00:00	1	1.8	15.8	14.6	34.8	890,560.6	0.00	1.00
09/24/2020 01:00	1	1.9	14.7	14.5	29.7	834,065.0	0.00	1.00
09/24/2020 02:00	1	1.9	14.0	14.5	25.9	777,576.3	0.00	1.00
09/24/2020 03:00	1	1.9	13.9	14.5	26.2	776,506.4	0.00	1.00
09/24/2020 04:00	1	1.7	15.0	14.5	31.0	825,934.1	0.00	1.00
09/24/2020 05:00	1	1.8	15.7	14.4	25.3	679,023.8	0.00	1.00
09/24/2020 06:00	1	1.8	15.6	14.4	25.1	673,546.1	0.00	1.00
09/24/2020 07:00	1	1.8	14.7	14.4	24.6	700,723.9	0.00	1.00
09/24/2020 08:00	1	1.7	15.1	14.6	33.6	875,344.8	0.00	1.00
09/24/2020 09:00	1	1.7	15.6	14.6	33.9	879,040.0	0.00	1.00
09/24/2020 10:00	1	1.7	15.6	14.6	34.3	876,866.3	0.00	1.00
09/24/2020 11:00	1	1.7	15.5	14.6	33.9	872,953.7	0.00	1.00
09/24/2020 12:00	2	1.9	16.6	14.0	36.4	879,011.7	0.00	1.00
09/24/2020 13:00	2	1.9	16.7	13.9	37.2	880,539.9	0.00	1.00
09/24/2020 14:00	2	1.9	16.5	13.9	36.6	875,649.1	0.00	1.00
09/24/2020 15:00	3	2.2	19.5	12.7	46.1	900,313.0	0.00	1.00
09/24/2020 16:00	3	2.5	21.5	11.9	51.3	897,429.4	0.00	1.00
09/24/2020 17:00	3	2.5	21.7	11.9	51.5	902,755.0	0.00	1.00
09/24/2020 18:00	3	2.6	22.3	11.9	53.2	906,558.9	0.00	1.00
09/24/2020 19:00	2	2.2	19.2	13.4	39.6	895,238.4	0.00	1.00
09/24/2020 20:00	2	2.0	17.1	14.0	36.8	869,286.8	0.00	1.00
09/24/2020 21:00	1	1.8	15.2	14.6	30.0	816,220.4	0.00	1.00
09/24/2020 22:00	1	1.8	15.7	14.7	34.2	857,215.5	0.00	1.00
09/24/2020 23:00	1	1.8	17.0	14.6	37.7	869,910.5	0.00	1.00
Average/Sum#:	2	1.9	16.7	14.0	35.4	842,177.9	0.00 #	24.00 #
Minimum:	1	1.7	13.9	11.9	24.6	673,546.1	0.00	1.00
Maximum:	3	2.6	22.3	14.7	53.2	906,558.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/25/2020 00:00	1	1.8	15.4	14.6	30.2	801,656.7	0.00	1.00
09/25/2020 01:00	1	1.8	14.9	14.5	25.9	734,353.8	0.00	1.00
09/25/2020 02:00	1	1.9	16.0	14.4	26.0	673,756.8	0.00	1.00
09/25/2020 03:00	1	1.9	16.1	14.4	26.3	672,703.4	0.00	1.00
09/25/2020 04:00	1	1.8	15.6	14.5	26.3	728,790.5	0.00	1.00
09/25/2020 05:00	2	1.9	16.4	14.5	26.7	621,162.3	0.00	1.00
09/25/2020 06:00	2	1.8	17.1	14.5	28.5	639,350.0	0.00	1.00
09/25/2020 07:00	1	1.8	17.1	14.4	28.0	659,430.5	0.00	1.00
09/25/2020 08:00	1	1.9	15.2	14.6	29.9	812,959.9	0.00	1.00
09/25/2020 09:00	1	1.8	16.4	14.6	35.7	893,386.4	0.00	1.00
09/25/2020 10:00	1	1.8	16.0	14.6	34.0	883,604.8	0.00	1.00
09/25/2020 11:00	1	1.8	14.9	14.6	30.6	855,564.2	0.00	1.00
09/25/2020 12:00	1	1.8	15.1	14.6	32.0	862,737.4	0.00	1.00
09/25/2020 13:00	1	1.8	15.6	14.6	34.3	877,083.7	0.00	1.00
09/25/2020 14:00	1	1.8	15.7	14.6	34.0	874,040.5	0.00	1.00
09/25/2020 15:00	1	1.8	15.7	14.6	34.3	872,736.3	0.00	1.00
09/25/2020 16:00	1	1.8	15.2	14.6	31.9	860,128.9	0.00	1.00
09/25/2020 17:00	1	1.9	14.3	14.6	28.3	816,437.8	0.00	1.00
09/25/2020 18:00	1	1.8	14.0	14.6	27.0	798,613.5	0.00	1.00
09/25/2020 19:00	1	1.9	13.9	14.5	26.2	773,082.9	0.00	1.00
09/25/2020 20:00	2	1.9	16.2	14.3	36.3	866,472.2	0.00	1.00
09/25/2020 21:00	2	1.9	16.1	14.4	36.1	858,523.7	0.00	1.00
09/25/2020 22:00	2	1.9	16.1	14.4	35.8	860,419.9	0.00	1.00
09/25/2020 23:00	1	1.8	14.9	14.6	30.4	849,695.2	0.00	1.00
Average/Sum#:	1	1.8	15.6	14.5	30.6	797,778.8	0.00 #	24.00 #
Minimum:	1	1.8	13.9	14.3	25.9	621,162.3	0.00	1.00
Maximum:	2	1.9	17.1	14.6	36.3	893,386.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/26/2020 00:00	1	1.9	14.3	14.4	23.8	723,688.1	0.00	1.00
09/26/2020 01:00	1	1.9	16.1	14.3	26.2	655,871.3	0.00	1.00
09/26/2020 02:00	1	1.9	15.5	14.5	24.2	627,581.5	0.00	1.00
09/26/2020 03:00	1	1.9	15.3	14.5	24.4	625,013.8	0.00	1.00
09/26/2020 04:00	1	1.8	16.8	14.4	27.7	635,623.6	0.00	1.00
09/26/2020 05:00	1	1.9	15.9	14.5	25.4	630,577.1	0.00	1.00
09/26/2020 06:00	1	1.9	15.8	14.5	25.2	632,930.8	0.00	1.00
09/26/2020 07:00	2	1.8	16.2	14.4	26.9	659,009.1	0.00	1.00
09/26/2020 08:00	1	1.9	13.9	14.4	23.5	726,216.3	0.00	1.00
09/26/2020 09:00	1	1.8	14.0	14.6	26.5	801,874.1	0.00	1.00
09/26/2020 10:00	1	1.9	13.8	14.5	24.5	761,528.3	0.00	1.00
09/26/2020 11:00	1	1.8	14.9	14.6	31.6	855,998.9	0.00	1.00
09/26/2020 12:00	1	1.9	13.8	14.5	24.4	761,956.3	0.00	1.00
09/26/2020 13:00	1	1.8	13.8	14.6	27.0	802,743.5	0.00	1.00
09/26/2020 14:00	1	1.9	14.6	14.5	25.2	714,240.4	0.00	1.00
09/26/2020 15:00	1	1.9	13.9	14.5	23.7	717,236.0	0.00	1.00
09/26/2020 16:00	1	1.8	13.6	14.5	23.3	729,004.5	0.00	1.00
09/26/2020 17:00	1	1.9	13.5	14.5	23.1	718,947.8	0.00	1.00
09/26/2020 18:00	1	1.9	14.3	14.5	24.7	695,410.8	0.00	1.00
09/26/2020 19:00	1	1.9	14.7	14.4	23.4	675,863.6	0.00	1.00
09/26/2020 20:00	2	1.9	16.0	14.4	26.5	650,581.9	0.00	1.00
09/26/2020 21:00	1	1.8	13.8	14.5	24.9	761,956.3	0.00	1.00
09/26/2020 22:00	1	1.9	13.9	14.5	24.8	747,406.2	0.00	1.00
09/26/2020 23:00	1	1.9	15.2	14.4	25.2	673,756.8	0.00	1.00
Average/Sum#:	1	1.9	14.7	14.5	25.3	707,709.0	0.00 #	24.00 #
Minimum:	1	1.8	13.5	14.3	23.1	625,013.8	0.00	1.00
Maximum:	2	1.9	16.8	14.6	31.6	855,998.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/27/2020 00:00	2	1.9	16.1	14.4	26.8	635,202.2	0.00	1.00
09/27/2020 01:00	2	1.9	16.2	14.4	26.8	630,988.6	0.00	1.00
09/27/2020 02:00	2	1.9	16.4	14.4	27.1	629,513.9	0.00	1.00
09/27/2020 03:00	2	1.9	16.5	14.4	27.3	629,935.2	0.00	1.00
09/27/2020 04:00	1	1.8	17.0	14.4	27.5	630,567.3	0.00	1.00
09/27/2020 05:00	2	1.9	16.9	14.4	27.9	631,831.3	0.00	1.00
09/27/2020 06:00	2	1.9	16.6	14.4	27.5	629,303.2	0.00	1.00
09/27/2020 07:00	2	1.9	16.4	14.4	26.8	632,884.7	0.00	1.00
09/27/2020 08:00	1	1.8	14.4	14.5	26.9	792,768.3	0.00	1.00
09/27/2020 09:00	1	1.8	14.3	14.5	25.1	754,467.2	0.00	1.00
09/27/2020 10:00	1	1.9	14.4	14.4	23.6	688,083.1	0.00	1.00
09/27/2020 11:00	1	1.9	15.4	14.4	33.7	842,933.4	0.00	1.00
09/27/2020 12:00	1	1.9	14.9	14.5	30.2	828,073.8	0.00	1.00
09/27/2020 13:00	1	1.8	13.9	14.6	26.4	792,961.9	0.00	1.00
09/27/2020 14:00	1	1.8	13.9	14.6	26.7	789,918.8	0.00	1.00
09/27/2020 15:00	1	1.8	14.1	14.6	28.9	808,612.5	0.00	1.00
09/27/2020 16:00	2	1.9	16.2	14.2	34.9	841,685.0	0.00	1.00
09/27/2020 17:00	1	1.9	14.5	14.6	29.8	832,305.7	0.00	1.00
09/27/2020 18:00	1	1.8	14.4	14.6	29.1	830,784.1	0.00	1.00
09/27/2020 19:00	1	1.8	13.9	14.6	26.3	801,221.9	0.00	1.00
09/27/2020 20:00	1	1.8	14.2	14.6	27.6	805,786.7	0.00	1.00
09/27/2020 21:00	1	1.8	14.7	14.6	30.1	835,131.5	0.00	1.00
09/27/2020 22:00	1	1.9	13.9	14.5	24.0	742,484.8	0.00	1.00
09/27/2020 23:00	1	1.9	14.1	14.5	25.4	744,624.5	0.00	1.00
Average/Sum#:	1	1.9	15.1	14.5	27.8	740,919.6	0.00 #	24.00 #
Minimum:	1	1.8	13.9	14.2	23.6	629,303.2	0.00	1.00
Maximum:	2	1.9	17.0	14.6	34.9	842,933.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/28/2020 00:00	2	1.9	16.1	14.4	27.0	639,205.2	0.00	1.00
09/28/2020 01:00	2	1.9	16.3	14.4	27.2	636,255.6	0.00	1.00
09/28/2020 02:00	2	1.9	16.7	14.4	27.8	636,255.6	0.00	1.00
09/28/2020 03:00	2	1.9	16.6	14.4	27.8	642,786.7	0.00	1.00
09/28/2020 04:00	1	2.0	17.4	14.4	28.2	651,003.3	0.00	1.00
09/28/2020 05:00	2	1.9	17.0	14.5	28.0	650,048.6	0.00	1.00
09/28/2020 06:00	2	1.9	17.7	14.5	30.2	645,555.2	0.00	1.00
09/28/2020 07:00	1	1.8	15.8	14.5	26.7	709,319.0	0.00	1.00
09/28/2020 08:00	1	1.8	16.2	14.7	34.1	839,545.5	0.00	1.00
09/28/2020 09:00	1	1.8	17.3	14.8	36.8	847,247.2	0.00	1.00
09/28/2020 10:00	1	1.8	16.2	14.8	31.3	790,898.7	0.00	1.00
09/28/2020 11:00	1	1.8	15.8	14.7	29.6	786,093.8	0.00	1.00
09/28/2020 12:00	1	1.8	15.4	14.6	33.8	844,478.4	0.00	1.00
09/28/2020 13:00	3	2.5	21.7	12.1	49.8	907,554.9	0.00	1.00
09/28/2020 14:00	3	2.5	21.8	12.1	52.2	904,131.3	0.00	1.00
09/28/2020 15:00	3	2.5	21.7	12.1	51.6	894,950.0	0.00	1.00
09/28/2020 16:00	2	2.2	18.6	13.4	40.4	876,979.4	0.00	1.00
09/28/2020 17:00	2	2.0	17.0	13.8	38.8	859,844.2	0.00	1.00
09/28/2020 18:00	1	1.9	15.9	14.2	33.7	852,722.2	0.00	1.00
09/28/2020 19:00	1	1.8	14.8	14.6	30.1	832,088.3	0.00	1.00
09/28/2020 20:00	1	1.8	15.1	14.7	29.9	792,057.4	0.00	1.00
09/28/2020 21:00	1	1.8	16.1	14.6	26.6	694,059.1	0.00	1.00
09/28/2020 22:00	1	1.8	16.7	14.7	26.7	627,726.5	0.00	1.00
09/28/2020 23:00	1	1.8	15.3	14.7	28.5	772,178.7	0.00	1.00
Average/Sum#:	2	2.0	17.1	14.2	33.2	763,874.4	0.00 #	24.00 #
Minimum:	1	1.8	14.8	12.1	26.6	627,726.5	0.00	1.00
Maximum:	3	2.5	21.8	14.8	52.2	907,554.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/29/2020 00:00	1	1.8	15.5	14.6	25.1	701,667.0	0.00	1.00
09/29/2020 01:00	1	1.8	15.3	14.6	25.7	707,101.2	0.00	1.00
09/29/2020 02:00	2	1.8	17.0	14.6	29.0	653,628.4	0.00	1.00
09/29/2020 03:00	2	1.8	17.3	14.6	29.0	642,107.9	0.00	1.00
09/29/2020 04:00	1	1.8	17.6	14.5	28.0	670,162.1	0.00	1.00
09/29/2020 05:00	2	1.8	17.4	14.6	28.5	630,804.7	0.00	1.00
09/29/2020 06:00	1	1.8	16.4	14.6	26.2	622,109.9	0.00	1.00
09/29/2020 07:00	2	1.8	17.5	14.5	29.9	658,607.5	0.00	1.00
09/29/2020 08:00	1	1.8	15.3	14.7	28.2	772,399.5	0.00	1.00
09/29/2020 09:00	1	1.7	16.4	14.7	34.0	838,882.9	0.00	1.00
09/29/2020 10:00	1	1.9	16.0	14.6	34.4	874,040.5	0.00	1.00
09/29/2020 11:00	2	1.9	16.6	14.2	35.9	878,066.7	0.00	1.00
09/29/2020 12:00	2	2.3	20.5	12.7	43.1	906,492.1	0.00	1.00
09/29/2020 13:00	3	2.4	20.9	12.4	46.2	896,409.1	0.00	1.00
09/29/2020 14:00	3	2.5	21.2	12.3	47.7	905,730.9	0.00	1.00
09/29/2020 15:00	3	2.4	20.6	12.5	45.8	897,951.1	0.00	1.00
09/29/2020 16:00	2	2.3	20.0	12.8	43.1	893,338.1	0.00	1.00
09/29/2020 17:00	2	2.4	20.0	12.7	44.0	896,973.0	0.00	1.00
09/29/2020 18:00	2	2.0	16.5	14.0	35.8	872,859.2	0.00	1.00
09/29/2020 19:00	1	1.9	13.9	14.6	27.0	811,003.6	0.00	1.00
09/29/2020 20:00	2	1.9	15.6	14.4	35.4	866,951.0	0.00	1.00
09/29/2020 21:00	2	2.1	17.9	13.5	38.5	897,343.1	0.00	1.00
09/29/2020 22:00	1	1.8	15.4	14.6	34.2	871,432.1	0.00	1.00
09/29/2020 23:00	1	1.8	15.2	14.6	22.1	627,326.8	0.00	1.00
Average/Sum#:	2	2.0	17.3	14.0	34.0	791,391.2	0.00 #	24.00 #
Minimum:	1	1.7	13.9	12.3	22.1	622,109.9	0.00	1.00
Maximum:	3	2.5	21.2	14.7	47.7	906,492.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:09 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/30/2020 00:00	1	1.8	15.4	14.6	23.9	615,371.5	0.00	1.00
09/30/2020 01:00	1	1.8	15.7	14.6	25.1	616,675.7	0.00	1.00
09/30/2020 02:00	2	1.9	16.7	14.5	27.9	645,555.2	0.00	1.00
09/30/2020 03:00	2	1.9	16.7	14.4	27.5	643,840.1	0.00	1.00
09/30/2020 04:00	1	1.8	17.3	14.4	27.5	645,736.3	0.00	1.00
09/30/2020 05:00	1	1.8	17.3	14.6	27.9	616,023.6	0.00	1.00
09/30/2020 06:00	2	1.8	17.2	14.6	27.7	616,458.3	0.00	1.00
09/30/2020 07:00	1	1.8	16.8	14.6	26.7	616,241.0	0.00	1.00
09/30/2020 08:00	1	1.8	15.8	14.5	25.2	688,349.7	0.00	1.00
09/30/2020 09:00	1	1.8	14.9	14.6	26.9	760,791.3	0.00	1.00
09/30/2020 10:00	1	1.9	16.0	14.4	34.2	858,734.4	0.00	1.00
09/30/2020 11:00	2	1.9	16.7	14.2	36.9	878,884.3	0.00	1.00
09/30/2020 12:00	2	2.2	19.7	13.1	40.0	891,530.4	0.00	1.00
09/30/2020 13:00	3	2.6	21.6	12.0	50.0	900,435.0	0.00	1.00
09/30/2020 14:00	3	2.6	21.4	11.9	51.6	896,364.3	0.00	1.00
09/30/2020 15:00	3	2.5	21.1	12.3	47.7	894,266.0	0.00	1.00
09/30/2020 16:00	3	2.5	21.0	12.1	49.4	892,148.9	0.00	1.00
09/30/2020 17:00	2	2.4	19.9	12.8	43.6	888,773.3	0.00	1.00
09/30/2020 18:00	2	2.2	18.8	13.2	39.8	878,743.6	0.00	1.00
09/30/2020 19:00	2	2.0	16.4	14.0	36.4	865,912.8	0.00	1.00
09/30/2020 20:00	2	1.9	15.9	14.2	35.7	865,394.5	0.00	1.00
09/30/2020 21:00	2	2.1	18.1	13.5	38.5	890,866.1	0.00	1.00
09/30/2020 22:00	2	1.9	15.2	14.4	33.7	834,295.5	0.00	1.00
09/30/2020 23:00	1	1.8	15.4	14.7	30.6	815,249.3	0.00	1.00
Average/Sum#:	2	2.0	17.5	13.8	34.8	779,860.0	0.00 #	24.00 #
Minimum:	1	1.8	14.9	11.9	23.9	615,371.5	0.00	1.00
Maximum:	3	2.6	21.6	14.7	51.6	900,435.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	**Max Lbs/ Hr (worst case turbine**	**Pounds per Startup or Shutdown (both turbines combined)**
NOx	**37.1**	**122.8**
CO	**89.5**	**204.8**

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/13/2020 05:00	294
07/21/2020 06:00	07/26/2020 00:00	115
08/06/2020 00:00	08/08/2020 21:00	70
09/24/2020 00:00	09/28/2020 03:00	100

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	579.00 Hour(s)
Offline Percentage:	26.22 %
Total Online:	1,629.00 Hour(s)
Online Percentage:	73.78 %

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/13/2020 06:44	07/13/2020 07:48	Cold Startup	65
2	07/21/2020 04:54	07/21/2020 05:02	Shutdown	9
3	07/26/2020 01:43	07/26/2020 02:38	Cold Startup	56
4	08/05/2020 22:57	08/05/2020 23:05	Shutdown	9
5	08/08/2020 22:44	08/08/2020 23:38	Cold Startup	55
6	09/23/2020 22:54	09/23/2020 23:02	Shutdown	9
7	09/28/2020 04:44	09/28/2020 05:35	Cold Startup	52

Startup / Shutdown Events

CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:23 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	228	0.23
Warm Startup	0		0.00
Shutdown	3	27	0.03
Total Process Events:	7	255	0.26

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,623.28 Hour(s)
Total Startup Time:	228 Minute(s)
Total Shutdown Time:	27 Minute(s)
Total Startup/Shutdown Time:	255 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.26 %

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
07/01/2020 00:00	07/13/2020 02:00	291
07/21/2020 06:00	07/25/2020 21:00	112
08/05/2020 23:00	08/08/2020 06:00	56
08/31/2020 00:00	08/31/2020 13:00	14

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	473.00 Hour(s)
Offline Percentage:	21.42 %
Total Online:	1,735.00 Hour(s)
Online Percentage:	78.58 %

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/13/2020 03:44	07/13/2020 04:38	Cold Startup	55
2	07/21/2020 04:59	07/21/2020 05:08	Shutdown	10
3	07/25/2020 22:43	07/25/2020 23:33	Cold Startup	51
4	08/05/2020 21:55	08/05/2020 22:03	Shutdown	9
5	08/08/2020 07:44	08/08/2020 08:33	Cold Startup	50
6	08/30/2020 22:54	08/30/2020 23:02	Shutdown	9
7	08/31/2020 14:44	08/31/2020 15:31	Cold Startup	48

Startup / Shutdown Events

CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 22:25 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	4	204	0.20
Warm Startup	0		0.00
Shutdown	3	28	0.03
Total Process Events:	7	232	0.22

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,729.35 Hour(s)
Total Startup Time:	204 Minute(s)
Total Shutdown Time:	28 Minute(s)
Total Startup/Shutdown Time:	232 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.22 %

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.00	0.00	0.00
07/02/2020	0.00	0.00	0.00	0.00	0.00
07/03/2020	0.00	0.00	0.00	0.00	0.00
07/04/2020	0.00	0.00	0.00	0.00	0.00
07/05/2020	0.00	0.00	0.00	0.00	0.00
07/06/2020	0.00	0.00	0.00	0.00	0.00
07/07/2020	0.00	0.00	0.00	0.00	0.00
07/08/2020	0.00	0.00	0.00	0.00	0.00
07/09/2020	0.00	0.00	0.00	0.00	0.00
07/10/2020	0.00	0.00	0.00	0.00	0.00
07/11/2020	0.00	0.00	0.00	0.00	0.00
07/12/2020	0.00	0.00	0.00	0.00	0.00
07/13/2020	71.49	120.71	9.39	18.82	31.33
07/14/2020	24.97	118.82	11.66	23.31	38.81
07/15/2020	21.18	122.64	11.73	23.50	39.08
07/16/2020	22.90	119.88	11.44	22.88	38.10
07/17/2020	24.35	112.72	10.79	21.56	35.91
07/18/2020	24.25	125.15	11.97	23.93	39.86
07/19/2020	24.50	121.49	11.60	23.21	38.57
07/20/2020	24.25	118.81	11.32	22.60	37.68
07/21/2020	31.92	20.68	1.82	3.62	6.02
07/22/2020	0.00	0.00	0.00	0.00	0.00
07/23/2020	0.00	0.00	0.00	0.00	0.00
07/24/2020	0.00	0.00	0.00	0.00	0.00
07/25/2020	23.50	13.62	0.26	0.52	0.86
07/26/2020	49.67	129.61	11.49	23.00	38.28
07/27/2020	23.35	130.52	12.40	24.84	41.37
07/28/2020	22.42	126.78	12.07	24.15	40.15
07/29/2020	22.69	126.26	12.05	24.14	40.11
07/30/2020	21.45	121.89	11.91	23.86	39.62
07/31/2020	22.11	122.78	11.68	23.34	38.78
Monthly Avg/Sum*:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
Daily Min:	21.18	13.62	0.26	0.52	0.86
Daily Max:	71.49	130.52	12.40	24.84	41.37
Jul 2020 - Jul 2020	455.00	1,752.36	163.58	327.28	544.53
QTD:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
YTD 2020:	1,510.06 *	4,027.76 *	372.07 *	744.45 *	1,239.38 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2020	25.18	117.17	11.17	22.35	37.13
08/02/2020	22.36	117.79	11.37	22.74	37.91
08/03/2020	22.84	120.40	11.55	23.13	38.44
08/04/2020	23.43	119.41	11.37	22.78	37.86
08/05/2020	47.39	107.35	10.05	20.08	33.39
08/06/2020	0.00	0.00	0.00	0.00	0.00
08/07/2020	0.00	0.00	0.00	0.00	0.00
08/08/2020	61.48	69.74	4.76	9.53	15.87
08/09/2020	20.51	135.52	12.91	25.83	43.03
08/10/2020	23.58	128.58	12.23	24.50	40.79
08/11/2020	29.79	113.63	10.91	21.85	36.22
08/12/2020	22.48	130.64	12.43	24.94	41.51
08/13/2020	22.89	132.42	12.62	25.25	42.17
08/14/2020	23.70	144.67	13.90	27.73	46.27
08/15/2020	18.53	146.66	14.02	28.03	46.74
08/16/2020	26.49	137.72	13.18	26.35	43.90
08/17/2020	30.86	138.62	13.35	26.82	44.65
08/18/2020	30.29	130.87	12.51	25.01	41.67
08/19/2020	30.56	140.89	13.46	26.87	44.88
08/20/2020	39.34	105.45	10.05	20.14	33.60
08/21/2020	28.60	124.96	11.96	23.91	39.90
08/22/2020	35.35	120.76	11.53	22.98	38.41
08/23/2020	29.84	123.32	11.74	23.55	39.29
08/24/2020	31.42	130.26	12.41	24.82	41.31
08/25/2020	28.55	124.20	11.88	23.74	39.56
08/26/2020	26.91	126.00	12.04	24.07	40.09
08/27/2020	29.02	116.33	11.13	22.21	36.99
08/28/2020	26.75	124.05	11.82	23.63	39.43
08/29/2020	27.11	115.63	10.99	21.99	36.62
08/30/2020	32.86	114.55	10.86	21.66	36.00
08/31/2020	33.19	108.91	9.49	19.01	31.65
Monthly Avg/Sum*:	851.30 *	3,566.50 *	337.69 *	675.50 *	1,125.28 *
Daily Min:	18.53	69.74	4.76	9.53	15.87
Daily Max:	61.48	146.66	14.02	28.03	46.74
Jul 2020 - Aug 2020	1,306.30	5,318.86	501.27	1,002.78	1,669.81
QTD:	1,306.30 *	5,318.86 *	501.27 *	1,002.78 *	1,669.81 *
YTD 2020:	2,361.36 *	7,594.26 *	709.76 *	1,419.95 *	2,364.66 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2020	28.01	131.26	12.54	25.07	41.78
09/02/2020	28.93	121.27	11.65	23.25	38.80
09/03/2020	19.91	135.75	12.87	25.79	43.01
09/04/2020	20.04	138.63	13.20	26.31	43.89
09/05/2020	21.31	134.48	12.86	25.71	42.86
09/06/2020	23.30	132.06	12.59	25.14	41.90
09/07/2020	30.08	126.35	12.07	24.14	40.16
09/08/2020	27.86	110.84	10.64	21.25	35.40
09/09/2020	19.49	133.30	12.76	25.54	42.51
09/10/2020	36.57	110.01	10.52	20.99	35.03
09/11/2020	37.20	109.93	10.50	21.03	35.06
09/12/2020	38.49	113.22	10.83	21.67	36.10
09/13/2020	38.53	115.70	11.16	22.27	37.18
09/14/2020	27.93	121.94	11.65	23.27	38.85
09/15/2020	26.76	124.51	11.90	23.78	39.67
09/16/2020	25.52	132.95	12.74	25.48	42.49
09/17/2020	29.77	128.93	12.30	24.59	40.97
09/18/2020	30.70	121.91	11.66	23.34	38.87
09/19/2020	30.63	117.17	11.12	22.25	37.10
09/20/2020	27.21	115.89	11.05	22.14	36.89
09/21/2020	25.51	130.86	12.58	25.13	41.90
09/22/2020	26.71	127.89	12.20	24.39	40.66
09/23/2020	33.97	125.68	11.96	23.87	39.84
09/24/2020	15.83	62.42	6.14	12.31	20.53
09/25/2020	17.37	55.78	5.34	10.67	17.82
09/26/2020	15.02	50.38	4.79	9.53	15.93
09/27/2020	15.99	52.41	5.00	9.99	16.66
09/28/2020	51.02	115.72	10.15	20.30	33.86
09/29/2020	32.79	122.88	11.78	23.56	39.29
09/30/2020	32.11	125.24	11.99	24.00	40.01
Monthly Avg/Sum*:	834.56 *	3,445.36 *	328.54 *	656.76 *	1,095.02 *
Daily Min:	15.02	50.38	4.79	9.53	15.93
Daily Max:	51.02	138.63	13.20	26.31	43.89
Jul 2020 - Sep 2020	2,140.86	8,764.22	829.81	1,659.54	2,764.83
QTD:	2,140.86 *	8,764.22 *	829.81 *	1,659.54 *	2,764.83 *
YTD 2020:	3,195.92 *	11,039.62 *	1,038.30 *	2,076.71 *	3,459.68 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
07/01/2020	0.0	0.0	0.0	0.0
07/02/2020	0.0	0.0	0.0	0.0
07/03/2020	0.0	0.0	0.0	0.0
07/04/2020	0.0	0.0	0.0	0.0
07/05/2020	0.0	0.0	0.0	0.0
07/06/2020	0.0	0.0	0.0	0.0
07/07/2020	0.0	0.0	0.0	0.0
07/08/2020	0.0	0.0	0.0	0.0
07/09/2020	0.0	0.0	0.0	0.0
07/10/2020	0.0	0.0	0.0	0.0
07/11/2020	0.0	0.0	0.0	0.0
07/12/2020	0.0	0.0	0.0	0.0
07/13/2020	28.8	12.7	22.8	13.7
07/14/2020	0.0	0.0	0.0	0.0
07/15/2020	0.0	0.0	0.0	0.0
07/16/2020	0.0	0.0	0.0	0.0
07/17/2020	0.0	0.0	0.0	0.0
07/18/2020	0.0	0.0	0.0	0.0
07/19/2020	0.0	0.0	0.0	0.0
07/20/2020	0.0	0.0	0.0	0.0
07/21/2020	6.9	0.8	9.1	0.9
07/22/2020	0.0	0.0	0.0	0.0
07/23/2020	0.0	0.0	0.0	0.0
07/24/2020	0.0	0.0	0.0	0.0
07/25/2020	0.0	0.0	23.5	12.3
07/26/2020	26.2	11.3	0.0	0.0
07/27/2020	0.0	0.0	0.0	0.0
07/28/2020	0.0	0.0	0.0	0.0
07/29/2020	0.0	0.0	0.0	0.0
07/30/2020	0.0	0.0	0.0	0.0
07/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	61.9 *	24.8 *	55.4 *	26.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	28.8	12.7	23.5	13.7
Jul 2020 - Jul 2020	61.9	24.8	55.4	26.9
QTD:	61.9 *	24.8 *	55.4 *	26.9 *
YTD 2020:	416.3 *	104.6 *	203.1 *	89.4 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
08/01/2020	0.0	0.0	0.0	0.0
08/02/2020	0.0	0.0	0.0	0.0
08/03/2020	0.0	0.0	0.0	0.0
08/04/2020	0.0	0.0	0.0	0.0
08/05/2020	7.9	0.9	8.0	1.1
08/06/2020	0.0	0.0	0.0	0.0
08/07/2020	0.0	0.0	0.0	0.0
08/08/2020	24.9	10.7	26.1	12.6
08/09/2020	0.0	0.0	0.0	0.0
08/10/2020	0.0	0.0	0.0	0.0
08/11/2020	0.0	0.0	0.0	0.0
08/12/2020	0.0	0.0	0.0	0.0
08/13/2020	0.0	0.0	0.0	0.0
08/14/2020	0.0	0.0	0.0	0.0
08/15/2020	0.0	0.0	0.0	0.0
08/16/2020	0.0	0.0	0.0	0.0
08/17/2020	0.0	0.0	0.0	0.0
08/18/2020	0.0	0.0	0.0	0.0
08/19/2020	0.0	0.0	0.0	0.0
08/20/2020	0.0	0.0	0.0	0.0
08/21/2020	0.0	0.0	0.0	0.0
08/22/2020	0.0	0.0	0.0	0.0
08/23/2020	0.0	0.0	0.0	0.0
08/24/2020	0.0	0.0	0.0	0.0
08/25/2020	0.0	0.0	0.0	0.0
08/26/2020	0.0	0.0	0.0	0.0
08/27/2020	0.0	0.0	0.0	0.0
08/28/2020	0.0	0.0	0.0	0.0
08/29/2020	0.0	0.0	0.0	0.0
08/30/2020	0.0	0.0	5.7	1.2
08/31/2020	0.0	0.0	11.7	12.0
Monthly Avg/Sum*:	32.8 *	11.6 *	51.5 *	26.9 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	24.9	10.7	26.1	12.6
Jul 2020 - Aug 2020	94.7	36.4	106.9	53.8
QTD:	94.7 *	36.4 *	106.9 *	53.8 *
YTD 2020:	449.1 *	116.2 *	254.6 *	116.3 *

Monthly Summary By Day Report

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/02/2020 23:56 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
09/01/2020	0.0	0.0	0.0	0.0
09/02/2020	0.0	0.0	0.0	0.0
09/03/2020	0.0	0.0	0.0	0.0
09/04/2020	0.0	0.0	0.0	0.0
09/05/2020	0.0	0.0	0.0	0.0
09/06/2020	0.0	0.0	0.0	0.0
09/07/2020	0.0	0.0	0.0	0.0
09/08/2020	0.0	0.0	0.0	0.0
09/09/2020	0.0	0.0	0.0	0.0
09/10/2020	0.0	0.0	0.0	0.0
09/11/2020	0.0	0.0	0.0	0.0
09/12/2020	0.0	0.0	0.0	0.0
09/13/2020	0.0	0.0	0.0	0.0
09/14/2020	0.0	0.0	0.0	0.0
09/15/2020	0.0	0.0	0.0	0.0
09/16/2020	0.0	0.0	0.0	0.0
09/17/2020	0.0	0.0	0.0	0.0
09/18/2020	0.0	0.0	0.0	0.0
09/19/2020	0.0	0.0	0.0	0.0
09/20/2020	0.0	0.0	0.0	0.0
09/21/2020	0.0	0.0	0.0	0.0
09/22/2020	0.0	0.0	0.0	0.0
09/23/2020	5.5	0.8	0.0	0.0
09/24/2020	0.0	0.0	0.0	0.0
09/25/2020	0.0	0.0	0.0	0.0
09/26/2020	0.0	0.0	0.0	0.0
09/27/2020	0.0	0.0	0.0	0.0
09/28/2020	25.3	10.8	0.0	0.0
09/29/2020	0.0	0.0	0.0	0.0
09/30/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	30.8 *	11.6 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	25.3	10.8	0.0	0.0
Jul 2020 - Sep 2020	125.5	48.0	106.9	53.8
QTD:	125.5 *	48.0 *	106.9 *	53.8 *
YTD 2020:	479.9 *	127.8 *	254.6 *	116.3 *

CT1 SUSD EVENT 1

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 6:39	0			0			0			0			0			0		
07/13/20 6:40	0			0			0			0			0			0		
07/13/20 6:41	0			0			0			0			0			0		
07/13/20 6:42	0			0			0			0			0			0		
07/13/20 6:43	0			0			0			0			0			0		
07/13/20 6:44	0			0.1			0			0			0			1		
07/13/20 6:45	22026.6			0.1			0			0			0			1		
07/13/20 6:46	38122.9			40.5			20.23			4.92			4.05			1		
07/13/20 6:47	52370.9			551.2			16.46			85.13			4.18			1		
07/13/20 6:48	73088.2			369.5			21.35			74.84			7.12			1		
07/13/20 6:49	118758.6			203.2			24.63			62.62			12.49			1		
07/13/20 6:50	139167.9			87.4			40.64			31.09			23.79			1		
07/13/20 6:51	150104.1			276			47.92			105.23			30.06			1		
07/13/20 6:52	169358.1			1808			36.96			770.17			25.91			1		
07/13/20 6:53	191153.6			986.5			45.65			469.93			35.79			1		
07/13/20 6:54	216491.9			142.1			53.77			76.01			47.32			1		
07/13/20 6:55	237825.3			8.3			58.76			4.83			56.55			1		
07/13/20 6:56	263548.7			1.9			58.05			1.22			61.53			1		
07/13/20 6:57	287269.6			1.6			47.97			1.15			55.18			1		
07/13/20 6:58	308217.9			1.7			24.67			1.27			30.34			1		
07/13/20 6:59	317228.8			1.7			15.7			1.33			19.86			1		
07/13/20 7:00	317536.8			1.7			14.88			1.31			18.82			1		
07/13/20 7:01	317690.9			1.7			12.74			1.31			16.12			1		
07/13/20 7:02	316920.7			1.6			11.03			1.25			13.92			1		
07/13/20 7:03	316073.6			1.5			9.32			1.18			11.73			1		
07/13/20 7:04	319385.3			1.5			8.21			1.12			10.44			1		
07/13/20 7:05	327163.8			1.3			7.29			1.03			9.49			1		
07/13/20 7:06	330321.5			1.2			6.25			0.97			8.21			1		
07/13/20 7:07	339178.3			1.1			5.81			0.92			7.83			1		
07/13/20 7:08	340795.7			1.1			5.28			0.94			7.16			1		
07/13/20 7:09	341257.8			1.1			5.28			0.87			7.16			1		
07/13/20 7:10	341565.8			1			5.2			0.8			7.05			1		
07/13/20 7:11	341565.8			1			5.2			0.8			7.05			1		
07/13/20 7:12	341026.7			1			5.2			0.8			7.04			1		
07/13/20 7:13	339871.5			1			5.2			0.79			7.02			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 7:14	339871.5			0.9			5.2			0.72			7.01			1		
07/13/20 7:15	339332.4			0.9			5.28			0.72			7.13			1		
07/13/20 7:16	339255.3			0.9			5.28			0.72			7.12			1		
07/13/20 7:17	338947.3			0.9			5.37			0.72			7.24			1		
07/13/20 7:18	339178.3			0.9			5.46			0.72			7.36			1		
07/13/20 7:19	338716.3			0.9			5.46			0.72			7.35			1		
07/13/20 7:20	338331.2			0.8			5.46			0.65			7.34			1		
07/13/20 7:21	336482.8			0.8			5.64			0.64			7.54			1		
07/13/20 7:22	320540.5			0.8			5.9			0.62			7.54			1		
07/13/20 7:23	308449			0.9			6.43			0.66			7.92			1		
07/13/20 7:24	305599.4			0.9			6.52			0.65			7.95			1		
07/13/20 7:25	304752.2			0.9			6.69			0.65			8.15			1		
07/13/20 7:26	305137.3			0.8			6.79			0.6			8.28			1		
07/13/20 7:27	316227.6			0.8			6.79			0.62			8.57			1		
07/13/20 7:28	317690.9			0.8			7.22			0.61			9.15			1		
07/13/20 7:29	317921.9			0.8			6.87			0.61			8.71			1		
07/13/20 7:30	317998.9			0.8			6.87			0.61			8.71			1		
07/13/20 7:31	317998.9			0.8			6.96			0.61			8.83			1		
07/13/20 7:32	318538.1			0.8			7.13			0.61			9.07			1		
07/13/20 7:33	318076			0.8			7.22			0.61			9.17			1		
07/13/20 7:34	318538.1			0.8			5.81			0.61			7.39			1		
07/13/20 7:35	317921.9			0.8			3.26			0.61			4.13			1		
07/13/20 7:36	317844.9			0.8			2.64			0.61			3.35			1		
07/13/20 7:37	317921.9			0.8			2.64			0.61			3.35			1		
07/13/20 7:38	317459.8			0.8			2.82			0.61			3.57			1		
07/13/20 7:39	317767.9			0.8			2.99			0.61			3.8			1		
07/13/20 7:40	317382.8			0.8			3.17			0.61			4.01			1		
07/13/20 7:41	317459.8			0.8			3.17			0.61			4.02			1		
07/13/20 7:42	317459.8			0.8			2.73			0.61			3.46			1		
07/13/20 7:43	316997.8			0.8			2.38			0.61			3.01			1		
07/13/20 7:44	316535.7			0.8			2.29			0.61			2.89			1		
07/13/20 7:45	305522.4			0.8			2.2			0.59			2.69			1		
07/13/20 7:46	303828			0.8			2.03			0.59			2.46			1		
07/13/20 7:47	303828			0.8			1.97			0.59			2.39			1		
07/13/20 7:48	303597			0.7			1.88			0.53			2.28			1		
07/13/20 7:49	303519.9			0.7			1.79			0.53			2.17			0		
07/13/20 7:50	303057.8			0.7			1.79			0.53			2.17			0		
07/13/20 7:51	303211.9			0.7			1.7			0.53			2.06			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 7:52	303442.9			0.7			1.61			0.53			1.95			0		
07/13/20 7:53	308680			0.7			1.61			0.54			1.99			0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 4:49	382307.3			0.7			1.75			0.65			2.55			0		
07/21/20 4:50	367520.2			0.7			1.72			0.62			2.41			0		
07/21/20 4:51	345647.7			0.7			1.82			0.58			2.39			0		
07/21/20 4:52	322234.8			0.8			1.94			0.59			2.38			0		
07/21/20 4:53	300054.2			0.8			1.94			0.55			2.21			0		
07/21/20 4:54	285344.2			0.9			1.85			0.58			2.01			1		
07/21/20 4:55	264703.9			0.8			1.82			0.5			1.83			1		
07/21/20 4:56	241368.1			0.7			3.87			0.41			3.56			1		
07/21/20 4:57	220958.8			0.7			7.71			0.34			6.49			1		
07/21/20 4:58	194696.4			0.5			12.52			0.23			9.29			1		
07/21/20 4:59	172053.7			2.3			14.64			0.9			9.59			1		
07/21/20 5:00	150797.3			125.6			16.52			43.83			9.49			1		
07/21/20 5:01	131851.3			925.4			16.52			282.35			8.3			1		
07/21/20 5:02	21487.5			1816.5			17.87			90.27			1.46			1		
07/21/20 5:03	0			0			20.06			0			0			0		
07/21/20 5:04	0			0			0.1			0			0			0		
07/21/20 5:05	0			0			0.1			0			0			0		
07/21/20 5:06	0			0			0.1			0			0			0		
07/21/20 5:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 1:38	0			0	X		59	X		0	X		0	X		0		
07/26/20 1:39	0			0	X		53.1	X		0	X		0	X		0		
07/26/20 1:40	0			0	X		35.4	X		0	X		0	X		0		
07/26/20 1:41	0			0			0.5			0			0			0		
07/26/20 1:42	0			0			0.4			0			0			0		
07/26/20 1:43	0			0.4			0.3			0			0			1		
07/26/20 1:44	3927.8			0.4			0.2			0			0			1		
07/26/20 1:45	27648.7			41.3			26.55			2.64			2.8			1		
07/26/20 1:46	43514			553.1			16.96			55.72			2.81			1		
07/26/20 1:47	58070			457.5			19.18			61.45			4.24			1		
07/26/20 1:48	91726			263.6			24.14			55.94			8.43			1		
07/26/20 1:49	134161.8			130.7			21.24			40.59			10.85			1		
07/26/20 1:50	140092			49.5			46.82			16.05			24.99			1		
07/26/20 1:51	156650.5			1012.2			42.69			367.05			25.48			1		
07/26/20 1:52	178060.9			1655.2			45.68			682.11			30.98			1		
07/26/20 1:53	201242.7			488.4			57.56			227.51			44.13			1		
07/26/20 1:54	225656.8			55.2			65.54			28.8			56.33			1		
07/26/20 1:55	247221.3			3.3			63.99			1.88			60.26			1		
07/26/20 1:56	273560.7			1.8			54.02			1.16			56.29			1		
07/26/20 1:57	296126.4			1.8			37.24			1.2			42.01			1		
07/26/20 1:58	316381.6			1.8			19.61			1.33			23.63			1		
07/26/20 1:59	335327.5			1.9			14.45			1.46			18.46			1		
07/26/20 2:00	346032.8			1.9			12.67			1.53			16.7			1		
07/26/20 2:01	347881.2			1.8			9.77			1.42			12.95			1		
07/26/20 2:02	348112.2			1.6			8.89			1.28			11.79			1		
07/26/20 2:03	356121.8			1.4			7.66			1.16			10.39			1		
07/26/20 2:04	360588.8			1.3			6.7			1.12			9.21			1		
07/26/20 2:05	361513			1.3			6.35			1.05			8.74			1		
07/26/20 2:06	363669.4			1.1			6.17			0.9			8.54			1		
07/26/20 2:07	362591.2			1.1			6.08			0.91			8.4			1		
07/26/20 2:08	360973.9			1			5.99			0.83			8.24			1		
07/26/20 2:09	359510.6			1			5.81			0.83			7.95			1		
07/26/20 2:10	358971.4			1			5.72			0.83			7.82			1		
07/26/20 2:11	358894.4			0.9			5.72			0.75			7.82			1		
07/26/20 2:12	358817.4			0.9			5.72			0.75			7.82			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 2:13	359356.5			0.9			5.72			0.76			7.83			1		
07/26/20 2:14	357970.3			0.9			5.72			0.75			7.8			1		
07/26/20 2:15	358201.3			0.8			5.72			0.68			7.8			1		
07/26/20 2:16	357277.1			0.8			5.72			0.68			7.78			1		
07/26/20 2:17	357508.2			0.8			5.63			0.68			7.66			1		
07/26/20 2:18	357277.1			0.8			5.63			0.68			7.66			1		
07/26/20 2:19	357277.1			0.8			5.72			0.68			7.78			1		
07/26/20 2:20	356815			0.8			5.81			0.67			7.9			1		
07/26/20 2:21	357046.1			0.8			5.99			0.68			8.15			1		
07/26/20 2:22	361513			0.8			6.08			0.68			8.37			1		
07/26/20 2:23	363130.3			0.8			6.08			0.7			8.42			1		
07/26/20 2:24	363977.5			0.7			4.08			0.61			5.66			1		
07/26/20 2:25	363592.4			0.7			2.72			0.61			3.77			1		
07/26/20 2:26	349575.5			0.7			2.63			0.59			3.51			1		
07/26/20 2:27	339255.3			0.8			2.68			0.63			3.47			1		
07/26/20 2:28	339871.5			0.8			2.73			0.62			3.53			1		
07/26/20 2:29	340718.7			0.8			2.77			0.63			3.6			1		
07/26/20 2:30	341488.8			0.8			2.68			0.64			3.49			1		
07/26/20 2:31	341565.8			0.8			2.59			0.64			3.37			1		
07/26/20 2:32	341565.8			0.8			2.5			0.64			3.26			1		
07/26/20 2:33	341334.8			0.8			2.41			0.64			3.14			1		
07/26/20 2:34	341334.8			0.8			2.23			0.64			2.91			1		
07/26/20 2:35	341334.8			0.8			2.15			0.64			2.79			1		
07/26/20 2:36	337715			0.8			2.06			0.63			2.65			1		
07/26/20 2:37	332555			0.8			1.97			0.62			2.49			1		
07/26/20 2:38	328627.2			0.8			1.85			0.6			2.31			1		
07/26/20 2:39	328396.1			0.8			1.85			0.6			2.31			0		
07/26/20 2:40	327703			0.8			1.79			0.61			2.23			0		
07/26/20 2:41	327548.9			0.8			1.79			0.61			2.23			0		
07/26/20 2:42	327703			0.8			1.7			0.61			2.12			0		
07/26/20 2:43	323621.1			0.8			1.7			0.6			2.09			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 22:52	339409.4			0.8			1.7			0.63			2.19			0		
08/05/20 22:53	324391.3			0.8			1.7			0.6			2.1			0		
08/05/20 22:54	301517.5			0.8			1.7			0.56			1.95			0		
08/05/20 22:55	287885.7			0.8			1.76			0.53			1.93			0		
08/05/20 22:56	286268.4			0.8			1.72			0.54			1.88			0		
08/05/20 22:57	286345.4			0.7			1.72			0.48			1.88			1		
08/05/20 22:58	274330.9			0.7			1.63			0.46			1.71			1		
08/05/20 22:59	252227.3			0.6			2.49			0.38			2.39			1		
08/05/20 23:00	230893.9			0.7			6.09			0.35			5.35			1		
08/05/20 23:01	207866.1			0.6			9.4			0.29			7.43			1		
08/05/20 23:02	181988.8			0.5			13.88			0.23			9.61			1		
08/05/20 23:03	159654.1			7.5			15.86			2.77			9.63			1		
08/05/20 23:04	141709.4			443.1			16.72			145.2			9.02			1		
08/05/20 23:05	92188.1			1519.5			17.38			323.81			6.1			1		
08/05/20 23:06	0			0			18.75			0			0			0		
08/05/20 23:07	0			0			23.6			0			0			0		
08/05/20 23:08	0			0			0.1			0			0			0		
08/05/20 23:09	0			0			0.1			0			0			0		
08/05/20 23:10	0			0			0.1			0			0			0		

CT1 SUSD EVENT 5

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 22:39	0			0			0			0			0			0		
08/08/20 22:40	0			0			0			0			0			0		
08/08/20 22:41	0			0			0			0			0			0		
08/08/20 22:42	0			0			0			0			0			0		
08/08/20 22:43	0			0			0			0			0			0		
08/08/20 22:44	2541.5			0.2			0			0			0			1		
08/08/20 22:45	24568.1			0.4			0			0			0			1		
08/08/20 22:46	39740.2			45.5			21.91			4.19			3.32			1		
08/08/20 22:47	53064			533.2			15.53			65.4			3.13			1		
08/08/20 22:48	73242.2			340.2			20.51			57.65			5.72			1		
08/08/20 22:49	118373.5			177.5			23.86			48.6			10.75			1		
08/08/20 22:50	139013.8			69.7			38.14			22.42			20.18			1		
08/08/20 22:51	149411			259.8			47.2			89.72			26.83			1		
08/08/20 22:52	168665			1781.8			44.42			694.8			28.51			1		
08/08/20 22:53	190922.6			925.1			57.29			408.34			41.62			1		
08/08/20 22:54	216337.9			123.1			64.5			61.58			53.11			1		
08/08/20 22:55	236901.1			6.7			61.6			3.68			55.53			1		
08/08/20 22:56	263471.7			1.8			55.73			1.09			55.89			1		
08/08/20 22:57	286499.4			1.6			41.97			1.07			45.76			1		
08/08/20 22:58	306677.6			1.7			25.01			1.19			29.19			1		
08/08/20 22:59	327240.9			1.8			14.14			1.38			17.61			1		
08/08/20 23:00	342721.1			1.8			13.1			1.44			17.09			1		
08/08/20 23:01	347419.1			1.7			9.77			1.34			12.92			1		
08/08/20 23:02	348266.2			1.6			8.76			1.3			11.61			1		
08/08/20 23:03	355274.7			1.4			7.51			1.18			10.15			1		
08/08/20 23:04	358355.3			1.3			6.53			1.04			8.9			1		
08/08/20 23:05	358586.4			1.2			6.26			0.96			8.54			1		
08/08/20 23:06	358355.3			1.1			6.17			0.9			8.42			1		
08/08/20 23:07	357970.3			1.1			5.63			0.9			7.67			1		
08/08/20 23:08	357662.2			1			5.45			0.83			7.41			1		
08/08/20 23:09	356738			1			5.45			0.82			7.39			1		
08/08/20 23:10	356275.9			1			5.36			0.82			7.26			1		
08/08/20 23:11	355967.8			0.9			5.26			0.75			7.13			1		
08/08/20 23:12	355505.7			0.9			5.26			0.75			7.12			1		
08/08/20 23:13	355197.7			0.9			5.26			0.75			7.12			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 23:14	354658.6			0.9			5.26			0.74			7.11			1		
08/08/20 23:15	353965.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:16	353965.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:17	354042.4			0.8			5.26			0.67			7.09			1		
08/08/20 23:18	353426.3			0.8			5.36			0.67			7.2			1		
08/08/20 23:19	353888.4			0.8			5.45			0.67			7.34			1		
08/08/20 23:20	353041.2			0.8			5.54			0.67			7.44			1		
08/08/20 23:21	346725.9			0.8			5.72			0.67			7.54			1		
08/08/20 23:22	326547.7			0.8			6.08			0.62			7.56			1		
08/08/20 23:23	314918.3			0.8			6.26			0.59			7.5			1		
08/08/20 23:24	317305.8			0.9			4.47			0.66			5.4			1		
08/08/20 23:25	324391.3			0.9			2.86			0.67			3.53			1		
08/08/20 23:26	318692.1			0.9			2.68			0.66			3.25			1		
08/08/20 23:27	308217.9			0.9			2.68			0.64			3.15			1		
08/08/20 23:28	307447.8			0.9			2.68			0.64			3.14			1		
08/08/20 23:29	307216.7			0.9			2.77			0.64			3.24			1		
08/08/20 23:30	304752.2			0.9			2.77			0.63			3.21			1		
08/08/20 23:31	303519.9			0.9			2.77			0.63			3.2			1		
08/08/20 23:32	303828			0.8			2.59			0.57			3			1		
08/08/20 23:33	303288.9			0.8			2.41			0.56			2.79			1		
08/08/20 23:34	303828			0.8			2.23			0.57			2.58			1		
08/08/20 23:35	304521.2			0.8			2.09			0.58			2.42			1		
08/08/20 23:36	304598.2			0.8			1.88			0.57			2.18			1		
08/08/20 23:37	304675.2			0.8			1.79			0.57			2.07			1		
08/08/20 23:38	304598.2			0.8			1.7			0.57			1.97			1		
08/08/20 23:39	304752.2			0.8			1.7			0.57			1.97			0		
08/08/20 23:40	304675.2			0.8			1.61			0.57			1.87			0		
08/08/20 23:41	304136.1			0.8			1.61			0.57			1.86			0		
08/08/20 23:42	304059.1			0.8			1.61			0.57			1.86			0		
08/08/20 23:43	304829.2			0.8			1.63			0.58			1.9			0		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/23/20 22:49	320848.5			0.7			1.61			0.53			1.98			0		
09/23/20 22:50	310297.3			0.7			1.67			0.51			1.99			0		
09/23/20 22:51	306061.5			0.8			1.76			0.56			2.07			0		
09/23/20 22:52	295433.3			0.8			1.79			0.55			2.02			0		
09/23/20 22:53	289426			0.7			1.79			0.48			1.98			0		
09/23/20 22:54	288116.8			0.7			1.82			0.49			2			1		
09/23/20 22:55	276641.4			0.6			1.63			0.41			1.73			1		
09/23/20 22:56	254306.7			0.6			2.21			0.38			2.16			1		
09/23/20 22:57	232742.3			0.6			5.24			0.3			4.68			1		
09/23/20 22:58	210099.6			0.5			8.46			0.24			6.81			1		
09/23/20 22:59	185146.4			0.4			12.96			0.18			9.19			1		
09/23/20 23:00	161656.5			4.1			15.05			1.54			9.32			1		
09/23/20 23:01	142402.5			317.1			16.05			105.12			8.76			1		
09/23/20 23:02	69545.4			1383.6			16.3			223.91			4.34			1		
09/23/20 23:03	0			0			17.7			0			0			0		
09/23/20 23:04	0			0			11.8			0			0			0		
09/23/20 23:05	0			0			0.1			0			0			0		
09/23/20 23:06	0			0			0.1			0			0			0		
09/23/20 23:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 7

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/28/20 4:39	0			0			0			0			0			0		
09/28/20 4:40	0			0			0			0			0			0		
09/28/20 4:41	0			0			0			0			0			0		
09/28/20 4:42	0			0			0			0			0			0		
09/28/20 4:43	0			0			0			0			0			0		
09/28/20 4:44	0			0.1			0			0			0			1		
09/28/20 4:45	0			0.1			0			0			0			1		
09/28/20 4:46	10166.1			10.3			20.65			0.24			0.81			1		
09/28/20 4:47	36659.6			571.6			14.75			48.75			2.07			1		
09/28/20 4:48	55451.5			421.3			19.47			54.41			4.14			1		
09/28/20 4:49	97579.2			230.9			24.14			52.46			9.03			1		
09/28/20 4:50	136318.3			102.3			34.04			32.48			17.78			1		
09/28/20 4:51	141940.4			41.5			50.33			13.71			27.37			1		
09/28/20 4:52	160424.3			1356			41.99			506.28			25.8			1		
09/28/20 4:53	182758.9			1407.2			51.03			598.82			35.74			1		
09/28/20 4:54	206710.9			349			66.34			167.95			52.54			1		
09/28/20 4:55	230277.8			31			68.79			16.62			60.7			1		
09/28/20 4:56	252381.3			2.2			61.84			1.28			59.8			1		
09/28/20 4:57	279028.9			1.6			55.5			1.04			59.33			1		
09/28/20 4:58	301748.6			1.5			38.4			1.08			44.39			1		
09/28/20 4:59	314918.3			1.7			19.15			1.25			23.11			1		
09/28/20 5:00	315919.5			1.8			14.54			1.32			17.6			1		
09/28/20 5:01	315457.4			1.7			13.08			1.26			15.81			1		
09/28/20 5:02	315688.5			1.6			11.63			1.21			14.06			1		
09/28/20 5:03	316997.8			1.6			9.89			1.15			12.01			1		
09/28/20 5:04	326008.6			1.5			8.94			1.12			11.16			1		
09/28/20 5:05	326701.8			1.4			7.75			1.07			9.7			1		
09/28/20 5:06	326855.8			1.3			7.13			1.01			8.93			1		
09/28/20 5:07	326855.8			1.2			7.04			0.94			8.82			1		
09/28/20 5:08	326239.7			1.1			6.87			0.87			8.59			1		
09/28/20 5:09	325084.4			1.1			6.69			0.87			8.34			1		
09/28/20 5:10	324391.3			1.1			6.52			0.8			8.1			1		
09/28/20 5:11	324237.3			1.1			6.44			0.81			8			1		
09/28/20 5:12	333017.1			1			6.26			0.76			7.98			1		
09/28/20 5:13	336328.8			1			5.9			0.77			7.6			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/28/20 5:14	337175.9			0.9			6.08			0.71			7.86			1		
09/28/20 5:15	337561			0.9			6.08			0.7			7.86			1		
09/28/20 5:16	336790.8			0.9			6.17			0.7			7.96			1		
09/28/20 5:17	336790.8			0.9			6.26			0.7			8.08			1		
09/28/20 5:18	338408.2			0.9			6.35			0.72			8.24			1		
09/28/20 5:19	338562.2			0.8			6.26			0.64			8.12			1		
09/28/20 5:20	338639.2			1.2	X		6.35	X		0.95	X		8.24	X		1		
09/28/20 5:21	338562.2			3	X		6.53	X		2.33	X		8.47	X		1		
09/28/20 5:22	337869.1			0.9	X		6.82	X		0.73	X		8.83	X		1		
09/28/20 5:23	321926.8			0.8	X		6.99	X		0.61	X		8.62	X		1		
09/28/20 5:24	309142.1			0.8	X		7.51	X		0.58	X		8.89	X		1		
09/28/20 5:25	308217.9			0.8	X		7.33	X		0.58	X		8.65	X		1		
09/28/20 5:26	307832.8			0.8			4.56			0.58			5.38			1		
09/28/20 5:27	307755.8			0.8			3.4			0.58			4.01			1		
09/28/20 5:28	308217.9			0.8			3.31			0.58			3.91			1		
09/28/20 5:29	308294.9			0.8			3.22			0.58			3.8			1		
09/28/20 5:30	303905			0.8			3.04			0.57			3.54			1		
09/28/20 5:31	288655.9			0.8			2.95			0.54			3.26			1		
09/28/20 5:32	286576.4			0.8			2.27			0.54			2.49			1		
09/28/20 5:33	286653.4			0.7			2.12			0.49			2.33			1		
09/28/20 5:34	288501.8			0.6			2.12			0.43			2.34			1		
09/28/20 5:35	291120.4			0.6			2.12			0.44			2.37			1		
09/28/20 5:36	290966.3			0.6			2.09			0.43			2.33			0		
09/28/20 5:37	290812.3			0.6			2			0.43			2.22			0		
09/28/20 5:38	290658.3			0.7			1.91			0.49			2.12			0		
09/28/20 5:39	290735.3			0.7			1.82			0.49			2.02			0		
09/28/20 5:40	290658.3			0.7			1.72			0.49			1.92			0		

CT2 SUSD EVENT 1

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 3:39	0			0			0			0			0			0		
07/13/20 3:40	0			0			0			0			0			0		
07/13/20 3:41	0			0			0			0			0			0		
07/13/20 3:42	0			0			0			0			0			0		
07/13/20 3:43	0			0			0			0			0			0		
07/13/20 3:44	15403.2			0			0			0			0			1		
07/13/20 3:45	32731.8			41.3			17.7			3.12			2.2			1		
07/13/20 3:46	42897.9			480.4			17.28			47.75			2.83			1		
07/13/20 3:47	53449.1			457.7			16.86			56.65			3.43			1		
07/13/20 3:48	72164			306.3			21.99			51.14			6.04			1		
07/13/20 3:49	115061.9			181.4			23.85			48.33			10.45			1		
07/13/20 3:50	133699.7			74.9			40.49			23.16			20.61			1		
07/13/20 3:51	142787.6			333			42.69			110.02			23.21			1		
07/13/20 3:52	160270.2			1562.8			33.04			579.67			20.17			1		
07/13/20 3:53	181526.6			822.2			41.75			345.46			28.87			1		
07/13/20 3:54	203861.3			131.7			51.36			62.13			39.88			1		
07/13/20 3:55	225502.8			7			56.17			3.63			48.25			1		
07/13/20 3:56	246143			1.7			60.9			0.96			57.09			1		
07/13/20 3:57	270249			1.5			52.04			0.97			53.56			1		
07/13/20 3:58	280954.3			1.6			31.88			1.03			34.12			1		
07/13/20 3:59	281339.3			1.7			19.18			1.13			20.55			1		
07/13/20 4:00	279028.9			1.7			17.79			1.12			18.9			1		
07/13/20 4:01	281878.5			1.7			16.47			1.09			17.68			1		
07/13/20 4:02	294817.2			1.5			15.5			1.02			17.4			1		
07/13/20 4:03	301286.5			1.4			14.88			0.98			17.08			1		
07/13/20 4:04	312453.8			1.4			13.71			1			16.32			1		
07/13/20 4:05	319000.2			1.4			11.01			1.04			13.37			1		
07/13/20 4:06	335866.7			1.3			10.21			1.03			13.07			1		
07/13/20 4:07	351038.8			1.2			9.21			0.94			12.31			1		
07/13/20 4:08	367982.3			1.1			9.17			0.93			12.85			1		
07/13/20 4:09	389238.7			1			9.22	X		0.91			13.67	X		1		
07/13/20 4:10	395014.9			0.9			9.77			0.84			14.7			1		
07/13/20 4:11	393397.6			0.8			10.42			0.76			15.61			1		
07/13/20 4:12	393320.6			0.8			10.33			0.76			15.47			1		
07/13/20 4:13	393243.6			0.8			10.23			0.76			15.33			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 4:14	392242.3			0.8			10.42			0.75			15.57			1		
07/13/20 4:15	393243.6			0.8			10.51			0.76			15.74			1		
07/13/20 4:16	393397.6			0.8			10.51			0.76			15.75			1		
07/13/20 4:17	392165.3			0.8			10.79			0.75			16.11			1		
07/13/20 4:18	392088.3			0.8			11.15			0.75			16.66			1		
07/13/20 4:19	393166.5			0.7			11.34			0.67			16.98			1		
07/13/20 4:20	392781.5			0.7			11.43			0.67			17.1			1		
07/13/20 4:21	393166.5			0.7			11.62			0.67			17.39			1		
07/13/20 4:22	393243.6			0.7			11.8			0.67			17.68			1		
07/13/20 4:23	392319.4			0.7			10.42			0.67			15.57			1		
07/13/20 4:24	393089.5			0.7			6.91			0.67			10.35			1		
07/13/20 4:25	393320.6			0.7			6.18			0.67			9.25			1		
07/13/20 4:26	392935.5			0.7			5.9			0.67			8.83			1		
07/13/20 4:27	394629.8			0.7			5.72			0.67			8.59			1		
07/13/20 4:28	393320.6			0.7			5.44			0.67			8.15			1		
07/13/20 4:29	392242.3			0.7			5.16			0.67			7.71			1		
07/13/20 4:30	392473.4			0.7			4.52			0.67			6.75			1		
07/13/20 4:31	390933.1			0.7			3.69			0.67			5.49			1		
07/13/20 4:32	392704.4			0.7			2.86			0.67			4.28			1		
07/13/20 4:33	391857.3			0.7			2.58			0.67			3.85			1		
07/13/20 4:34	391241.1			0.7			2.3			0.67			3.43			1		
07/13/20 4:35	393243.6			0.7			2.03			0.67			3.04			1		
07/13/20 4:36	391780.3			0.7			1.75			0.67			2.61			1		
07/13/20 4:37	393089.5			0.7			1.57			0.67			2.35			1		
07/13/20 4:38	393628.6			0.7			1.48			0.67			2.21			1		
07/13/20 4:39	392242.3			0.7			1.38			0.67			2.07			0		
07/13/20 4:40	391780.3			0.7			1.29			0.67			1.93			0		
07/13/20 4:41	393166.5			0.7			1.2			0.67			1.79			0		
07/13/20 4:42	393397.6			0.7			1.2			0.67			1.8			0		
07/13/20 4:43	393243.6			0.7			1.2			0.67			1.8			0		

CT2 SUSD EVENT 2

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 4:54	363361.3			0.7			1.72			0.61			2.39			0		
07/21/20 4:55	360973.9			0.7			1.63			0.61			2.25			0		
07/21/20 4:56	346109.8			0.7			1.72			0.58			2.27			0		
07/21/20 4:57	324237.3			0.7			1.7			0.54			2.1			0		
07/21/20 4:58	299746.2			0.8			1.59			0.55			1.81			0		
07/21/20 4:59	279568			0.8			1.56			0.51			1.66			1		
07/21/20 5:00	259851.9			0.8			1.61			0.48			1.59			1		
07/21/20 5:01	239211.6			0.8			1.91			0.45			1.74			1		
07/21/20 5:02	222730.2			0.7			4.78			0.34			4.05			1		
07/21/20 5:03	200010.5			0.5			8.8			0.23			6.7			1		
07/21/20 5:04	175981.5			0.3			15.73			0.13			10.55			1		
07/21/20 5:05	154494			5.3			17.46			1.89			10.27			1		
07/21/20 5:06	138089.6			490			19.95			156.62			10.49			1		
07/21/20 5:07	111288.1			1493.2			21.69			384.71			9.2			1		
07/21/20 5:08	0			2023.7			24.78			0			0			1		
07/21/20 5:09	0			0			11.8			0			0			0		
07/21/20 5:10	0			0			5.9			0			0			0		
07/21/20 5:11	0			0			5.9			0			0			0		
07/21/20 5:12	0			0			5.9			0			0			0		
07/21/20 5:13	0			0			0			0			0			0		

CT2 SUSD EVENT 3

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/25/20 22:38	0			0			0			0			0			0		
07/25/20 22:39	0			0			0			0			0			0		
07/25/20 22:40	0			0			0			0			0			0		
07/25/20 22:41	0			0			0			0			0			0		
07/25/20 22:42	0			0			0			0			0			0		
07/25/20 22:43	1925.4			0			0			0			0			1		
07/25/20 22:44	17636.7			0			0			0			0			1		
07/25/20 22:45	33887			29.5			14.75			2.31			1.9			1		
07/25/20 22:46	45208.4			456.9			16.23			47.76			2.79			1		
07/25/20 22:47	54912.4			415.2			17.7			52.8			3.7			1		
07/25/20 22:48	77093			239.3			22.57			42.7			6.63			1		
07/25/20 22:49	119528.8			133.1			20.77			36.83			9.46			1		
07/25/20 22:50	130773.1			50			44.05			15.12			21.94			1		
07/25/20 22:51	139784			482.8			43.49			156.16			23.15			1		
07/25/20 22:52	157266.6			1675.8			41.3			609.94			24.74			1		
07/25/20 22:53	178677.1			851			52.63			352.03			35.83			1		
07/25/20 22:54	201550.8			129.9			59.54			60.61			45.71			1		
07/25/20 22:55	223038.3			6.1			61.24			3.17			52.03			1		
07/25/20 22:56	244525.7			1.7			62.58			0.95			58.28			1		
07/25/20 22:57	268862.8			1.5			50.63			0.95			51.85			1		
07/25/20 22:58	289272			1.6			30.73			1.06			33.86			1		
07/25/20 22:59	298590.9			1.7			18.74			1.2			21.31			1		
07/25/20 23:00	308603			1.7			17.7			1.24			20.81			1		
07/25/20 23:01	322619.9			1.6			14.92			1.23			18.34			1		
07/25/20 23:02	327780			1.6			11.8			1.2			14.73			1		
07/25/20 23:03	328858.2			1.4			11.26			1.09			14.11			1		
07/25/20 23:04	328704.2			1.3			10.28			0.95			12.87			1		
07/25/20 23:05	327625.9			1.3			9.65			0.95			12.05			1		
07/25/20 23:06	327703			1.2			9.21			0.88			11.49			1		
07/25/20 23:07	326470.7			1.2			9.21	X		0.88			11.45	X		1		
07/25/20 23:08	333633.2			1.1			9.03	X		0.83			11.48	X		1		
07/25/20 23:09	348959.4			1			8.76			0.79			11.64			1		
07/25/20 23:10	370138.8			0.9			8.67			0.79			12.22			1		
07/25/20 23:11	385850			0.9			8.71			0.84			12.8			1		
07/25/20 23:12	381383.1			0.8			9.83			0.74			14.28			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/25/20 23:13	381383.1			0.8			9.5			0.73			13.79			1		
07/25/20 23:14	383385.5			0.8			9.55			0.75			13.95			1		
07/25/20 23:15	382846.4			0.8			9.65			0.75			14.07			1		
07/25/20 23:16	383000.4			0.8			9.68			0.74			14.12			1		
07/25/20 23:17	384617.8			0.8			9.77			0.74			14.32			1		
07/25/20 23:18	384309.7			0.7			10.11			0.67			14.81			1		
07/25/20 23:19	382538.3			0.7			10.3			0.66			15.01			1		
07/25/20 23:20	383077.4			0.7			10.58			0.66			15.44			1		
07/25/20 23:21	384540.8			0.7			10.77			0.67			15.78			1		
07/25/20 23:22	384232.7			0.7			10.3			0.67			15.08			1		
07/25/20 23:23	384001.6			0.7			4.79			0.66			7.01			1		
07/25/20 23:24	385156.9			0.7			3.47			0.67			5.08			1		
07/25/20 23:25	384078.7			0.7			3.28			0.67			4.8			1		
07/25/20 23:26	384463.7			0.7			3.04			0.66			4.45			1		
07/25/20 23:27	383924.6			0.7			2.95			0.66			4.31			1		
07/25/20 23:28	383231.5			0.8			2.72			0.75			3.97			1		
07/25/20 23:29	385464.9			0.7			2.4			0.66			3.52			1		
07/25/20 23:30	384925.8			0.7			2.21			0.66			3.24			1		
07/25/20 23:31	385619			0.7			1.94			0.66			2.84			1		
07/25/20 23:32	384771.8			0.7			1.75			0.66			2.57			1		
07/25/20 23:33	385773			0.7			1.57			0.66			2.3			1		
07/25/20 23:34	386158.1			0.7			1.48			0.66			2.17			0		
07/25/20 23:35	385079.9			0.7			1.38			0.66			2.03			0		
07/25/20 23:36	385233.9			0.7			1.29			0.66			1.89			0		
07/25/20 23:37	385156.9			0.7			1.29			0.66			1.89			0		
07/25/20 23:38	385002.8			0.7			1.29			0.66			1.89			0		

CT2 SUSD EVENT 4

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/05/20 21:50	311067.5			0.9			1.7			0.64			2.01			0		
08/05/20 21:51	293970			0.8			1.7			0.55			1.9			0		
08/05/20 21:52	275332.1			0.9			1.76			0.56			1.85			0		
08/05/20 21:53	270711.2			0.8			1.79			0.5			1.84			0		
08/05/20 21:54	270942.2			0.7			1.82			0.45			1.87			0		
08/05/20 21:55	263933.8			0.6			1.91			0.39			1.91			1		
08/05/20 21:56	245449.9			0.6			2.4			0.37			2.24			1		
08/05/20 21:57	226812			0.7			5.9			0.34			5.09			1		
08/05/20 21:58	206633.9			0.6			9.58			0.28			7.53			1		
08/05/20 21:59	181988.8			0.4			17.91			0.18			12.4			1		
08/05/20 22:00	159577.1			3.3			20.41			1.22			12.39			1		
08/05/20 22:01	141632.4			258.3			22.66			84.58			12.21			1		
08/05/20 22:02	125382			1194			24.84			346.11			11.85			1		
08/05/20 22:03	11244.3			1872.9			26.2			48.63			1.12			1		
08/05/20 22:04	0			0			24.91			0			0			0		
08/05/20 22:05	0			0			2.95			0			0			0		
08/05/20 22:06	0			0			5.9			0			0			0		
08/05/20 22:07	0			0			5.9			0			0			0		
08/05/20 22:08	0			0			5.9			0			0			0		

CT2 SUSD EVENT 5

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 7:39	0			0			0			0			0			0		
08/08/20 7:40	0			0			0			0			0			0		
08/08/20 7:41	0			0			0			0			0			0		
08/08/20 7:42	0			0			0			0			0			0		
08/08/20 7:43	0			0			0			0			0			0		
08/08/20 7:44	5853.2			0			0			0			0			1		
08/08/20 7:45	24106			0			0			0			0			1		
08/08/20 7:46	36351.5			18.9			21.24			1.58			2.93			1		
08/08/20 7:47	48212			495			13.87			55.18			2.54			1		
08/08/20 7:48	59225.3			390			18.54			53.42			4.18			1		
08/08/20 7:49	87952.2			225.2			22.57			45.83			7.56			1		
08/08/20 7:50	129078.8			125.3			20.77			37.39			10.2			1		
08/08/20 7:51	131235.2			43.3			45.54			13.15			22.75			1		
08/08/20 7:52	141632.4			893			43.56			292.44			23.48			1		
08/08/20 7:53	157189.6			1671.7			45.51			607.72			27.23			1		
08/08/20 7:54	178908.1			851.4			54.16			352.2			36.87			1		
08/08/20 7:55	200934.7			150.9			57.12			70.1			43.69			1		
08/08/20 7:56	223654.4			7.3			55.93			3.78			47.6			1		
08/08/20 7:57	244294.7			1.8			58.47			1.01			54.37			1		
08/08/20 7:58	269247.8			1.6			49.39			1.01			50.6			1		
08/08/20 7:59	289734.1			1.6			29.15			1.06			32.14			1		
08/08/20 8:00	309142.1			1.7			17.7			1.24			20.82			1		
08/08/20 8:01	324622.3			1.8			15.48			1.35			19.12			1		
08/08/20 8:02	343722.3			1.7			11.54			1.38			15.1			1		
08/08/20 8:03	361050.9			1.6			10.21			1.32			14.04			1		
08/08/20 8:04	384540.8			1.3			9.48			1.19			13.87			1		
08/08/20 8:05	403178.6			1.2			9.44			1.1			14.48			1		
08/08/20 8:06	398788.7			1.1			10.53			1			15.98			1		
08/08/20 8:07	399943.9			1			10.08			0.92			15.33			1		
08/08/20 8:08	398249.6			0.9			9.8			0.84			14.86			1		
08/08/20 8:09	397402.4			0.9			9.71			0.83			14.69			1		
08/08/20 8:10	398249.6			0.9			9.8			0.84			14.86			1		
08/08/20 8:11	398788.7			0.9			9.89			0.84			15.02			1		
08/08/20 8:12	398172.6			0.9			9.98			0.84			15.13			1		
08/08/20 8:13	397479.4			0.8			9.98			0.75			15.1			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/08/20 8:14	396016.1			0.8			10.08			0.75			15.18			1		
08/08/20 8:15	397094.3			0.8			10.17			0.75			15.36			1		
08/08/20 8:16	396709.3			0.8			10.23			0.76			15.45			1		
08/08/20 8:17	396247.2			0.7			10.33			0.68			15.57			1		
08/08/20 8:18	395400			0.7			10.51			0.67			15.81			1		
08/08/20 8:19	395631.1			0.7			10.69			0.67			16.1			1		
08/08/20 8:20	397017.3			0.7			10.97			0.68			16.57			1		
08/08/20 8:21	395939.1			0.8			10.33			0.76			15.56			1		
08/08/20 8:22	396478.2			0.8			4.89			0.76			7.37			1		
08/08/20 8:23	395862.1			0.7			3.32			0.68			5			1		
08/08/20 8:24	396555.3			0.7			3.13			0.68			4.73			1		
08/08/20 8:25	396093.2			0.7			2.95			0.68			4.45			1		
08/08/20 8:26	396786.3			0.7			2.86			0.68			4.32			1		
08/08/20 8:27	395323			0.7			2.77			0.67			4.16			1		
08/08/20 8:28	396401.2			0.7			2.58			0.68			3.89			1		
08/08/20 8:29	396093.2			0.7			2.21			0.68			3.34			1		
08/08/20 8:30	394629.8			0.7			2.03			0.67			3.05			1		
08/08/20 8:31	395477			0.7			1.84			0.67			2.77			1		
08/08/20 8:32	394783.9			0.7			1.66			0.67			2.49			1		
08/08/20 8:33	395400			0.7			1.54			0.66			2.32			1		
08/08/20 8:34	395323			0.7			1.48			0.67			2.22			0		
08/08/20 8:35	395477			0.7			1.38			0.67			2.08			0		
08/08/20 8:36	395400			0.7			1.29			0.67			1.94			0		
08/08/20 8:37	396478.2			0.7			1.29			0.68			1.95			0		
08/08/20 8:38	396247.2			0.7			1.29			0.68			1.95			0		

CT2 SUSD EVENT 6

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 22:49	271789.4			0.8			1.75			0.52			1.81			0		
08/30/20 22:50	270326.1			0.8			1.84			0.52			1.9			0		
08/30/20 22:51	270788.2			0.8			1.84			0.52			1.9			0		
08/30/20 22:52	270095			0.8			1.94			0.52			1.99			0		
08/30/20 22:53	270788.2			0.8			1.94			0.52			1.99			0		
08/30/20 22:54	267630.5			0.8			1.94			0.51			1.97			1		
08/30/20 22:55	253767.6			0.8			1.94			0.49			1.87			1		
08/30/20 22:56	232511.2			0.7			3.47			0.4			3.07			1		
08/30/20 22:57	216183.8			0.7			7.52			0.33			6.18			1		
08/30/20 22:58	192848			0.6			16.6			0.27			12.18			1		
08/30/20 22:59	168125.9			0.5			21.09			0.21			13.49			1		
08/30/20 23:00	147485.6			5.8			23.72			1.97			13.32			1		
08/30/20 23:01	130388			397.7			26.41			119.91			13.11			1		
08/30/20 23:02	69237.4			1392.6			26.79			222.88			7.06			1		
08/30/20 23:03	0			0			28.73			0			0			0		
08/30/20 23:04	0			0			5.9			0			0			0		
08/30/20 23:05	0			0			11.8			0			0			0		
08/30/20 23:06	0			0			5.9			0			0			0		
08/30/20 23:07	0			0			5.9			0			0			0		

CT2 SUSD EVENT 7

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 14:39	0			0			0			0			0			0		
08/31/20 14:40	0			0			0			0			0			0		
08/31/20 14:41	0			0			0			0			0			0		
08/31/20 14:42	0			0			0			0			0			0		
08/31/20 14:43	0			0			0			0			0			0		
08/31/20 14:44	8856.8			17.7			0			0.36			0			1		
08/31/20 14:45	23489.9			17.7			0			0.96			0			1		
08/31/20 14:46	36197.5			32.5			26.55			2.72			3.66			1		
08/31/20 14:47	46671.7			414.7			18.54			44.74			3.29			1		
08/31/20 14:48	57993			282.4			23.87			37.86			5.27			1		
08/31/20 14:49	85564.7			142.3			30.73			28.17			10.01			1		
08/31/20 14:50	126075.1			61.8			40.86			18.02			19.6			1		
08/31/20 14:51	130388			18.2			57.79			5.49			28.67			1		
08/31/20 14:52	141632.4			17.2			53.43			5.64			28.8			1		
08/31/20 14:53	159885.2			1063.9			51.82			393.43			31.54			1		
08/31/20 14:54	183067			302.8			55.69			128.16			38.8			1		
08/31/20 14:55	205632.6			20			57.49			9.49			44.99			1		
08/31/20 14:56	225502.8			1.9			59.78			0.99			51.29			1		
08/31/20 14:57	249839.8			1.3			60.1			0.75			57.15			1		
08/31/20 14:58	272944.6			1.4			37.67			0.86			39.12			1		
08/31/20 14:59	292506.7			1.6			17.07			1.09			19.01			1		
08/31/20 15:00	309604.2			1.7			15.67			1.2			18.47			1		
08/31/20 15:01	326624.8			1.7			12.15			1.26			15.1			1		
08/31/20 15:02	346109.8			1.5			9.98			1.23			13.15			1		
08/31/20 15:03	362514.2			1.4			9.8			1.14			13.52			1		
08/31/20 15:04	368521.4			1.1			9.5			0.94			13.32			1		
08/31/20 15:05	380767			1.1			9.5			0.97			13.76			1		
08/31/20 15:06	378995.6			1			10.44			0.88			15.06			1		
08/31/20 15:07	378841.6			1			10.44			0.87			15.05			1		
08/31/20 15:08	377224.2			1			10.33			0.88			14.82			1		
08/31/20 15:09	377455.3			1			10.42			0.89			14.96			1		
08/31/20 15:10	376839.2			0.9			10.42			0.8			14.94			1		
08/31/20 15:11	376993.2			0.9			10.51			0.8			15.08			1		
08/31/20 15:12	378225.4			0.9			10.51			0.81			15.13			1		
08/31/20 15:13	376608.1			0.9			10.69			0.8			15.32			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:14	377378.3			0.9			10.79			0.8			15.49			1		
08/31/20 15:15	379765.8			0.9			10.79			0.81			15.59			1		
08/31/20 15:16	377763.3			0.9			11.06			0.81			15.9			1		
08/31/20 15:17	376454.1			0.9			11.25			0.8			16.11			1		
08/31/20 15:18	377532.3			0.9			10.69			0.8			15.36			1		
08/31/20 15:19	378533.5			0.8			5.53			0.73			7.97			1		
08/31/20 15:20	377378.3			0.8			3.41			0.72			4.9			1		
08/31/20 15:21	376146			0.8			3.13			0.72			4.49			1		
08/31/20 15:22	377070.2			0.8			2.95			0.72			4.23			1		
08/31/20 15:23	377378.3			0.8			2.86			0.72			4.1			1		
08/31/20 15:24	377686.3			0.8			2.77			0.72			3.98			1		
08/31/20 15:25	376454.1			0.8			2.58			0.72			3.7			1		
08/31/20 15:26	376223			0.8			2.49			0.72			3.56			1		
08/31/20 15:27	376377.1			0.8			2.21			0.72			3.17			1		
08/31/20 15:28	376300			0.8			2.03			0.72			2.9			1		
08/31/20 15:29	377147.2			0.8			1.84			0.72			2.65			1		
08/31/20 15:30	377070.2			0.8			1.66			0.72			2.38			1		
08/31/20 15:31	378071.4			0.8			1.48			0.73			2.12			1		
08/31/20 15:32	370061.8			0.8			1.38			0.71			1.95			0		
08/31/20 15:33	363669.4			0.8			1.2			0.7			1.66			0		
08/31/20 15:34	348112.2			0.8			1.11			0.67			1.47			0		
08/31/20 15:35	337330			0.8			1.01			0.65			1.3			0		
08/31/20 15:36	325238.4			0.8			0.91			0.61			1.12			0		

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	**Pounds/Hour**
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT2 HOURLY EMISSIONS

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/01/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 3:00	0			0	X		0			0	X		0.09534			0.32		
07/13/20 4:00	0.7			1			1.4			0	X		0.23664			0.79		
07/13/20 5:00	0.7			1			1.7			0	X		0.24666			0.82		
07/13/20 6:00	0.7			1			1.7			0.2			0.24516			0.82		
07/13/20 7:00	0.8			1			1.7			0.4			0.18582			0.62		
07/13/20 8:00	0.8			1			1.7			0.4			0.19116			0.64		
07/13/20 9:00	0.7			1			1.7			0.44			0.21558			0.72		
07/13/20 10:00	0.8			1			1.7			0.5			0.24336			0.81		
07/13/20 11:00	0.8			2			1.7			0.61			0.2886			0.96		
07/13/20 12:00	0.5			2			1.7			0.62			0.29388			0.98		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 13:00	0.7			2			1.7			0.6			0.2826			0.94		
07/13/20 14:00	0.5			2			1.7			0.62			0.29388			0.98		
07/13/20 15:00	0.5			2			1.7			0.62			0.29352			0.98		
07/13/20 16:00	0.8			2			1.7			0.59			0.27798			0.93		
07/13/20 17:00	0.6			2			1.7			0.62			0.29202			0.97		
07/13/20 18:00	0.2			3			1.7			0.72			0.34416			1.15		
07/13/20 19:00	0.5			2			1.7			0.63			0.29796			0.99		
07/13/20 20:00	0.7			1			1.7			0.44			0.17034			0.57		
07/13/20 21:00	0.6			1			1.7			0.36			0.16854			0.56		
07/13/20 22:00	0.6			1			1.7			0.36			0.16872			0.56		
07/13/20 23:00	0.6			1			1.7			0.36			0.16896			0.56		
07/14/20 0:00	0.7			2			1.7			0.36			0.17196			0.57		
07/14/20 1:00	0.8			2			1.7			0.37			0.18102			0.6		
07/14/20 2:00	0.6			2			1.7			0.36			0.16836			0.56		
07/14/20 3:00	0.6			2			1.7			0.36			0.16854			0.56		
07/14/20 4:00	0.7			2			1.7			0.36			0.1743			0.58		
07/14/20 5:00	0.7			2			1.7			0.36			0.1686			0.56		
07/14/20 6:00	0.7			2			1.7			0.36			0.16854			0.56		
07/14/20 7:00	0.8			2			1.7			0.37			0.1782			0.59		
07/14/20 8:00	0.8			1			1.6			0.39			0.19512			0.65		
07/14/20 9:00	0.7			1			1.7			0.43			0.21546			0.72		
07/14/20 10:00	0.7			2			1.5			0.49			0.23922			0.8		
07/14/20 11:00	1.1			1			1.6			0.58			0.27018			0.9		
07/14/20 12:00	0.3			2			1.7			0.67			0.31734			1.06		
07/14/20 13:00	0	X		0	X		0	X		0.57			0.26904			0.9		
07/14/20 14:00	0.3			2			1.7			0.68			0.32364			1.08		
07/14/20 15:00	0.2			3			1.7			0.74			0.35508			1.18		
07/14/20 16:00	0.2			3			1.7			0.75			0.35694			1.19		
07/14/20 17:00	0.2			3			1.7			0.74			0.3537			1.18		
07/14/20 18:00	0.3			2			1.7			0.66			0.3165			1.06		
07/14/20 19:00	0.9			2			1.7			0.58			0.26976			0.9		
07/14/20 20:00	0.7			1			1.7			0.5			0.21444			0.71		
07/14/20 21:00	0.7			1			1.7			0.47			0.20406			0.68		
07/14/20 22:00	0.7			1			1.7			0.45			0.20166			0.67		
07/14/20 23:00	0.7			1			1.7			0.39			0.17448			0.58		
07/15/20 0:00	0.6			2			1.7			0.36			0.17148			0.57		
07/15/20 1:00	0.6			2			1.7			0.36			0.1692			0.56		
07/15/20 2:00	0.6			2			1.7			0.36			0.16854			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/15/20 3:00	0.6			2			1.7			0.36			0.16842			0.56		
07/15/20 4:00	0.6			2			1.7			0.36			0.16884			0.56		
07/15/20 5:00	0.6			2			1.7			0.36			0.16878			0.56		
07/15/20 6:00	0.6			2			1.7			0.36			0.16878			0.56		
07/15/20 7:00	0.6			2			1.7			0.36			0.16902			0.56		
07/15/20 8:00	0.8			1			1.7			0.4			0.19422			0.65		
07/15/20 9:00	0.7			1			1.7			0.43			0.21516			0.72		
07/15/20 10:00	0.7			1			1.7			0.49			0.24486			0.82		
07/15/20 11:00	0.8			2			1.7			0.61			0.2874			0.96		
07/15/20 12:00	0.3			2			1.7			0.7			0.33138			1.1		
07/15/20 13:00	0.2			3			1.7			0.7			0.33384			1.11		
07/15/20 14:00	0.2			3			1.7			0.74			0.3534			1.18		
07/15/20 15:00	0.2			3			1.7			0.75			0.35814			1.19		
07/15/20 16:00	0.2			3			1.7			0.75			0.35898			1.2		
07/15/20 17:00	0.2			3			1.7			0.75			0.35772			1.19		
07/15/20 18:00	0.2			3			1.7			0.71			0.3384			1.13		
07/15/20 19:00	1			2			1.7			0.56			0.26436			0.88		
07/15/20 20:00	0.7			1			1.7			0.48			0.19806			0.66		
07/15/20 21:00	0.6			1			1.7			0.39			0.17286			0.58		
07/15/20 22:00	0.6			1			1.7			0.36			0.16866			0.56		
07/15/20 23:00	0.6			2			1.7			0.36			0.16872			0.56		
07/16/20 0:00	0.6			2			1.7			0.36			0.16872			0.56		
07/16/20 1:00	0.6			2			1.7			0.36			0.16878			0.56		
07/16/20 2:00	0.6			2			1.7			0.36			0.16884			0.56		
07/16/20 3:00	0.6			2			1.7			0.36			0.16896			0.56		
07/16/20 4:00	0.6			2			1.7			0.36			0.16908			0.56		
07/16/20 5:00	0.6			2			1.7			0.36			0.1689			0.56		
07/16/20 6:00	0.6			2			1.7			0.36			0.1692			0.56		
07/16/20 7:00	0.6			2			1.7			0.36			0.1698			0.57		
07/16/20 8:00	0.8			1			1.7			0.39			0.18762			0.63		
07/16/20 9:00	0.7			1			1.7			0.43			0.21354			0.71		
07/16/20 10:00	0.6			1			1.7			0.48			0.24102			0.8		
07/16/20 11:00	1.2			2			1.7			0.57			0.26694			0.89		
07/16/20 12:00	0.3			2			1.7			0.69			0.3297			1.1		
07/16/20 13:00	0.4			2			1.7			0.65			0.3069			1.02		
07/16/20 14:00	0.4			2			1.7			0.66			0.31236			1.04		
07/16/20 15:00	0.2			3			1.7			0.75			0.36126			1.2		
07/16/20 16:00	0.2			3			1.7			0.75			0.36108			1.2		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/16/20 17:00	0.2			3			1.7			0.76			0.36144			1.2		
07/16/20 18:00	0.4			2			1.7			0.65			0.30846			1.03		
07/16/20 19:00	0.8			1			1.7			0.52			0.23124			0.77		
07/16/20 20:00	0.8			1			1.7			0.43			0.19308			0.64		
07/16/20 21:00	0.8			1			1.7			0.41			0.1893			0.63		
07/16/20 22:00	0.6			2			1.7			0.36			0.1695			0.57		
07/16/20 23:00	0.6			2			1.7			0.37			0.17328			0.58		
07/17/20 0:00	0.6			2			1.7			0.36			0.16968			0.57		
07/17/20 1:00	0.6			2			1.7			0.36			0.16908			0.56		
07/17/20 2:00	0.6			2			1.7			0.36			0.16908			0.56		
07/17/20 3:00	0.6			2			1.7			0.36			0.16902			0.56		
07/17/20 4:00	0.6			2			1.7			0.36			0.16908			0.56		
07/17/20 5:00	0.6			2			1.7			0.36			0.16914			0.56		
07/17/20 6:00	0.6			2			1.7			0.36			0.16914			0.56		
07/17/20 7:00	0.6			2			1.7			0.36			0.16944			0.56		
07/17/20 8:00	0.8			1			1.7			0.39			0.18606			0.62		
07/17/20 9:00	0.7			1			1.7			0.42			0.20874			0.7		
07/17/20 10:00	0.7			1			1.7			0.46			0.22926			0.76		
07/17/20 11:00	0.7			1			1.7			0.52			0.24378			0.81		
07/17/20 12:00	0.7			1			1.7			0.43			0.2046			0.68		
07/17/20 13:00	0.6			1			1.7			0.49			0.23916			0.8		
07/17/20 14:00	1.1			2			1.7			0.6			0.2634			0.88		
07/17/20 15:00	0.2			3			1.7			0.71			0.3366			1.12		
07/17/20 16:00	0.2			3			1.7			0.74			0.3558			1.19		
07/17/20 17:00	0.2			3			1.7			0.7			0.33204			1.11		
07/17/20 18:00	0.6			2			1.7			0.62			0.2928			0.98		
07/17/20 19:00	0.7			2			1.7			0.48			0.23742			0.79		
07/17/20 20:00	0.7			1			1.7			0.39			0.20232			0.67		
07/17/20 21:00	0.7			1			1.7			0.39			0.20436			0.68		
07/17/20 22:00	0.7			1			1.7			0.39			0.21342			0.71		
07/17/20 23:00	0.8			2			1.7			0.36			0.18492			0.62		
07/18/20 0:00	0.6			1			1.7			0.36			0.16848			0.56		
07/18/20 1:00	0.6			1			1.7			0.36			0.1683			0.56		
07/18/20 2:00	0.6			2			1.7			0.36			0.16836			0.56		
07/18/20 3:00	0.6			2			1.7			0.36			0.16842			0.56		
07/18/20 4:00	0.6			1			1.7			0.36			0.16842			0.56		
07/18/20 5:00	0.6			1			1.7			0.36			0.16836			0.56		
07/18/20 6:00	0.6			2			1.7			0.36			0.16848			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/18/20 7:00	0.6			1			1.7			0.36			0.16902			0.56		
07/18/20 8:00	0.8			1			1.7			0.39			0.18828			0.63		
07/18/20 9:00	0.7			1			1.7			0.43			0.21168			0.71		
07/18/20 10:00	0.7			1			1.7			0.5			0.24126			0.8		
07/18/20 11:00	0.8			2			1.7			0.61			0.28998			0.97		
07/18/20 12:00	0.7			1			1.8			0.49			0.23394			0.78		
07/18/20 13:00	0.8			2			1.6			0.61			0.2874			0.96		
07/18/20 14:00	0.2			3			1.7			0.75			0.36012			1.2		
07/18/20 15:00	0.3			3			1.7			0.76			0.3633			1.21		
07/18/20 16:00	0.2			3			1.7			0.74			0.35286			1.18		
07/18/20 17:00	0.2			3			1.7			0.73			0.35064			1.17		
07/18/20 18:00	0.2			3			1.7			0.73			0.3519			1.17		
07/18/20 19:00	0.3			2			1.7			0.66			0.31398			1.05		
07/18/20 20:00	0.7			1			1.7			0.52			0.2442			0.81		
07/18/20 21:00	0.8			1			1.7			0.5			0.23682			0.79		
07/18/20 22:00	0.9			2			1.7			0.59			0.28164			0.94		
07/18/20 23:00	0.7			1			1.7			0.36			0.1734			0.58		
07/19/20 0:00	0.6			1			1.7			0.36			0.16812			0.56		
07/19/20 1:00	0.6			1			1.7			0.36			0.16818			0.56		
07/19/20 2:00	0.6			1			1.7			0.36			0.1683			0.56		
07/19/20 3:00	0.6			2			1.7			0.36			0.16836			0.56		
07/19/20 4:00	0.6			1			1.7			0.36			0.16836			0.56		
07/19/20 5:00	0.6			1			1.7			0.36			0.16842			0.56		
07/19/20 6:00	0.6			1			1.7			0.36			0.16848			0.56		
07/19/20 7:00	0.6			1			1.7			0.36			0.16836			0.56		
07/19/20 8:00	0.6			1			1.7			0.36			0.16932			0.56		
07/19/20 9:00	0.8			1			1.7			0.41			0.19362			0.65		
07/19/20 10:00	0.7			1			1.7			0.48			0.23148			0.77		
07/19/20 11:00	1.3			2			1.7			0.58			0.27342			0.91		
07/19/20 12:00	0.5			2			1.7			0.64			0.30318			1.01		
07/19/20 13:00	0.4			2			1.7			0.66			0.3138			1.05		
07/19/20 14:00	0.2			3			1.7			0.75			0.36066			1.2		
07/19/20 15:00	0.2			3			1.7			0.75			0.3615			1.21		
07/19/20 16:00	0.2			3			1.7			0.7			0.336			1.12		
07/19/20 17:00	0.2			3			1.7			0.74			0.35334			1.18		
07/19/20 18:00	0.3			2			1.7			0.67			0.32256			1.08		
07/19/20 19:00	1.3			2			1.7			0.54			0.25428			0.85		
07/19/20 20:00	0.7			1			1.7			0.5			0.23826			0.79		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/19/20 21:00	0.7			1			1.7			0.43			0.21114			0.7		
07/19/20 22:00	0.6			1			1.7			0.37			0.17622			0.59		
07/19/20 23:00	0.7			1			1.7			0.42			0.19974			0.67		
07/20/20 0:00	0.8			2			1.7			0.36			0.18264			0.61		
07/20/20 1:00	0.6			2			1.7			0.36			0.1707			0.57		
07/20/20 2:00	0.6			2			1.7			0.36			0.16878			0.56		
07/20/20 3:00	0.6			2			1.7			0.36			0.1728			0.58		
07/20/20 4:00	0.7			2			1.6			0.37			0.17814			0.59		
07/20/20 5:00	0.6			2			1.7			0.36			0.16878			0.56		
07/20/20 6:00	0.6			2			1.7			0.36			0.16878			0.56		
07/20/20 7:00	0.6			2			1.7			0.36			0.1686			0.56		
07/20/20 8:00	0.6			1			1.7			0.36			0.16914			0.56		
07/20/20 9:00	0.7			1			1.7			0.42			0.20208			0.67		
07/20/20 10:00	0.7			1			1.7			0.51			0.24504			0.82		
07/20/20 11:00	0.7			1			1.7			0.52			0.24564			0.82		
07/20/20 12:00	0.8			1			1.7			0.52			0.24486			0.82		
07/20/20 13:00	0.6			2			1.7			0.63			0.29886			1		
07/20/20 14:00	0.2			2			1.7			0.7			0.3345			1.12		
07/20/20 15:00	0.2			3			1.7			0.72			0.34416			1.15		
07/20/20 16:00	0.2			3			1.7			0.72			0.34398			1.15		
07/20/20 17:00	0.2			3			1.7			0.7			0.33504			1.12		
07/20/20 18:00	0.6			2			1.7			0.61			0.2916			0.97		
07/20/20 19:00	0.8			2			1.7			0.59			0.28278			0.94		
07/20/20 20:00	0.8			1			1.7			0.51			0.24474			0.82		
07/20/20 21:00	0.8			1			1.7			0.38			0.19404			0.65		
07/20/20 22:00	0.7			1			1.7			0.36			0.17148			0.57		
07/20/20 23:00	0.8			1			1.7			0.4			0.19188			0.64		
07/21/20 0:00	0.7			2			1.7			0.36			0.17412			0.58		
07/21/20 1:00	0.6			2			1.7			0.36			0.17082			0.57		
07/21/20 2:00	0.6			2			1.7			0.36			0.16926			0.56		
07/21/20 3:00	0.7			2			1.7			0.36			0.17514			0.58		
07/21/20 4:00	0.7			1			1.7			0.38			0.1893			0.63		
07/21/20 5:00	0			0	X		0			0.13			0.1035			0.35		
07/21/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/23/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 22:00	0			0	X		0			0	X		0.0906			0.3		
07/25/20 23:00	0.7			1			1.5			0	X		0.23358			0.78		
07/26/20 0:00	0.7			1			1.7			0	X		0.24708			0.82		
07/26/20 1:00	0.8			1			1.7			0.2			0.21528			0.72		
07/26/20 2:00	0.8			1			1.7			0.42			0.19668			0.66		
07/26/20 3:00	0.7			1			1.7			0.36			0.17184			0.57		
07/26/20 4:00	0.6			1			1.7			0.36			0.16884			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 5:00	0.6			1			1.7			0.36			0.16944			0.56		
07/26/20 6:00	0.7			1			1.7			0.37			0.17832			0.59		
07/26/20 7:00	0.8			1			1.7			0.36			0.18162			0.61		
07/26/20 8:00	0.8			1			1.7			0.36			0.18294			0.61		
07/26/20 9:00	0.8			1			1.7			0.36			0.18312			0.61		
07/26/20 10:00	0.8			1			1.7			0.36			0.18378			0.61		
07/26/20 11:00	0.8			1			1.7			0.37			0.18798			0.63		
07/26/20 12:00	1.6			1			1.7			0.53			0.24426			0.81		
07/26/20 13:00	0.9			2			1.7			0.58			0.27366			0.91		
07/26/20 14:00	0.6			2			1.7			0.62			0.29544			0.98		
07/26/20 15:00	0.2			3			1.7			0.75			0.36036			1.2		
07/26/20 16:00	0.2			3			1.7			0.75			0.36066			1.2		
07/26/20 17:00	0.2			3			1.7			0.75			0.36018			1.2		
07/26/20 18:00	0.2			3			1.7			0.75			0.3606			1.2		
07/26/20 19:00	0.2			3			1.7			0.74			0.35292			1.18		
07/26/20 20:00	0.3			2			1.7			0.68			0.32418			1.08		
07/26/20 21:00	0.8			1			1.7			0.44			0.20928			0.7		
07/26/20 22:00	0.7			1			1.7			0.46			0.22686			0.76		
07/26/20 23:00	0.7			1			1.7			0.46			0.23256			0.78		
07/27/20 0:00	0.7			1			1.7			0.4			0.21186			0.71		
07/27/20 1:00	0.7			1			1.7			0.37			0.20436			0.68		
07/27/20 2:00	0.8			1			1.7			0.4			0.19332			0.64		
07/27/20 3:00	0.8			1			1.7			0.39			0.19506			0.65		
07/27/20 4:00	0.8			1			1.7			0.36			0.1818			0.61		
07/27/20 5:00	0.8			1			1.7			0.37			0.17814			0.59		
07/27/20 6:00	0.8			1			1.7			0.36			0.18126			0.6		
07/27/20 7:00	0.8			1			1.7			0.36			0.18342			0.61		
07/27/20 8:00	0.8			1			1.7			0.36			0.18648			0.62		
07/27/20 9:00	0.7			1			1.7			0.41			0.20958			0.7		
07/27/20 10:00	1.4			2			1.7			0.54			0.25776			0.86		
07/27/20 11:00	0.6			2			1.7			0.62			0.29574			0.99		
07/27/20 12:00	0.2			2			1.7			0.7			0.33498			1.12		
07/27/20 13:00	0.5			2			1.7			0.63			0.30048			1		
07/27/20 14:00	0.2			3			1.7			0.75			0.35838			1.19		
07/27/20 15:00	0.2			3			1.7			0.75			0.3597			1.2		
07/27/20 16:00	0.2			3			1.7			0.75			0.35958			1.2		
07/27/20 17:00	0.2			3			1.7			0.75			0.36042			1.2		
07/27/20 18:00	0.2			3			1.7			0.75			0.3582			1.19		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/27/20 19:00	0.2			2			1.7			0.68			0.32802			1.09		
07/27/20 20:00	0.4			2			1.7			0.64			0.30798			1.03		
07/27/20 21:00	0.8			1			1.7			0.39			0.1974			0.66		
07/27/20 22:00	0.7			1			1.7			0.4			0.20322			0.68		
07/27/20 23:00	0.7			1			1.7			0.41			0.19548			0.65		
07/28/20 0:00	0.6			1			1.7			0.36			0.1692			0.56		
07/28/20 1:00	0.6			1			1.7			0.36			0.16806			0.56		
07/28/20 2:00	0.6			1			1.7			0.36			0.16896			0.56		
07/28/20 3:00	0.6			1			1.7			0.36			0.16896			0.56		
07/28/20 4:00	0.6			1			1.7			0.36			0.16872			0.56		
07/28/20 5:00	0.7			2			1.7			0.36			0.16836			0.56		
07/28/20 6:00	0.7			2			1.7			0.36			0.16842			0.56		
07/28/20 7:00	0.7			2			1.7			0.37			0.17742			0.59		
07/28/20 8:00	0.8			1			1.7			0.4			0.1971			0.66		
07/28/20 9:00	0.8			1			1.7			0.51			0.24426			0.81		
07/28/20 10:00	0.5			2			1.7			0.65			0.30672			1.02		
07/28/20 11:00	0.3			2			1.7			0.68			0.32406			1.08		
07/28/20 12:00	0.2			2			1.7			0.69			0.3273			1.09		
07/28/20 13:00	0.2			3			1.7			0.75			0.35964			1.2		
07/28/20 14:00	0.2			3			1.7			0.72			0.34602			1.15		
07/28/20 15:00	0.2			3			1.7			0.71			0.33756			1.13		
07/28/20 16:00	0.2			3			1.7			0.69			0.32958			1.1		
07/28/20 17:00	0.2			3			1.7			0.68			0.32742			1.09		
07/28/20 18:00	0.6			2			1.7			0.59			0.28242			0.94		
07/28/20 19:00	0.7			2			1.7			0.59			0.27894			0.93		
07/28/20 20:00	0.5			2			1.7			0.62			0.29418			0.98		
07/28/20 21:00	0.8			1			1.7			0.43			0.20658			0.69		
07/28/20 22:00	0.7			1			1.7			0.37			0.17448			0.58		
07/28/20 23:00	0.8			1			1.7			0.4			0.1932			0.64		
07/29/20 0:00	0.7			1			1.7			0.36			0.16932			0.56		
07/29/20 1:00	0.6			1			1.7			0.36			0.16788			0.56		
07/29/20 2:00	0.7			1			1.7			0.36			0.168			0.56		
07/29/20 3:00	0.6			2			1.7			0.36			0.16812			0.56		
07/29/20 4:00	0.6			1			1.7			0.36			0.16812			0.56		
07/29/20 5:00	0.6			2			1.7			0.36			0.16824			0.56		
07/29/20 6:00	0.6			1			1.7			0.36			0.1683			0.56		
07/29/20 7:00	0.6			1			1.7			0.36			0.16806			0.56		
07/29/20 8:00	0.7			1			1.7			0.37			0.17268			0.58		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/29/20 9:00	0.8			1			1.7			0.38			0.18516			0.62		
07/29/20 10:00	0.9			1			1.7			0.5			0.23724			0.79		
07/29/20 11:00	0.9			2			1.7			0.59			0.27852			0.93		
07/29/20 12:00	0.2			3			1.7			0.71			0.33876			1.13		
07/29/20 13:00	0.2			3			1.7			0.75			0.35796			1.19		
07/29/20 14:00	0.2			3			1.7			0.75			0.35862			1.2		
07/29/20 15:00	0.2			4			1.7			0.75			0.35886			1.2		
07/29/20 16:00	0.2			4			1.7			0.75			0.3591			1.2		
07/29/20 17:00	0.2			3			1.7			0.75			0.35838			1.19		
07/29/20 18:00	0.1			3			1.7			0.74			0.35502			1.18		
07/29/20 19:00	1			2			1.7			0.55			0.26214			0.87		
07/29/20 20:00	0.4			2			1.7			0.65			0.3117			1.04		
07/29/20 21:00	0.8			1			1.7			0.42			0.19818			0.66		
07/29/20 22:00	0.7			1			1.7			0.43			0.20958			0.7		
07/29/20 23:00	0.8			1			1.7			0.37			0.19134			0.64		
07/30/20 0:00	0.6			1			1.7			0.36			0.16896			0.56		
07/30/20 1:00	0.6			1			1.7			0.36			0.16812			0.56		
07/30/20 2:00	0.6			1			1.7			0.36			0.16824			0.56		
07/30/20 3:00	0.6			2			1.7			0.36			0.16848			0.56		
07/30/20 4:00	0.6			1			1.7			0.36			0.16854			0.56		
07/30/20 5:00	0.6			2			1.7			0.36			0.1689			0.56		
07/30/20 6:00	0.6			2			1.7			0.36			0.16878			0.56		
07/30/20 7:00	0.6			2			1.7			0.36			0.16836			0.56		
07/30/20 8:00	0.6			1			1.7			0.36			0.16818			0.56		
07/30/20 9:00	0.7			1			1.7			0.37			0.17658			0.59		
07/30/20 10:00	0.7			1			1.7			0.45			0.21858			0.73		
07/30/20 11:00	0.6			2			1.6			0.62			0.29436			0.98		
07/30/20 12:00	0.8			2			1.7			0.6			0.28236			0.94		
07/30/20 13:00	0.4			2			1.7			0.65			0.30792			1.03		
07/30/20 14:00	0.2			3			1.7			0.71			0.33654			1.12		
07/30/20 15:00	0.2			3			1.7			0.72			0.34296			1.14		
07/30/20 16:00	0.2			3			1.7			0.75			0.35772			1.19		
07/30/20 17:00	0.2			3			1.7			0.75			0.35754			1.19		
07/30/20 18:00	0.2			3			1.7			0.71			0.3393			1.13		
07/30/20 19:00	0.4			2			1.7			0.65			0.31224			1.04		
07/30/20 20:00	0.5			2			1.7			0.64			0.3039			1.01		
07/30/20 21:00	0.8			1			1.7			0.5			0.23844			0.79		
07/30/20 22:00	0.7			1			1.7			0.47			0.22866			0.76		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/30/20 23:00	0.8			1			1.7			0.38			0.19062			0.64		
07/31/20 0:00	0.6			1			1.7			0.36			0.16968			0.57		
07/31/20 1:00	0.6			2			1.7			0.36			0.16824			0.56		
07/31/20 2:00	0.6			2			1.7			0.36			0.16842			0.56		
07/31/20 3:00	0.6			2			1.7			0.36			0.16848			0.56		
07/31/20 4:00	0.6			2			1.7			0.36			0.16854			0.56		
07/31/20 5:00	0.6			2			1.7			0.36			0.16866			0.56		
07/31/20 6:00	0.6			2			1.7			0.36			0.16878			0.56		
07/31/20 7:00	0.6			2			1.7			0.36			0.16854			0.56		
07/31/20 8:00	0.6			1			1.7			0.36			0.16812			0.56		
07/31/20 9:00	0.7			2			1.7			0.37			0.1773			0.59		
07/31/20 10:00	0.7			1			1.7			0.44			0.21402			0.71		
07/31/20 11:00	0.5			2			1.6			0.67			0.32088			1.07		
07/31/20 12:00	0.6			2			1.7			0.62			0.2931			0.98		
07/31/20 13:00	0.4			2			1.7			0.67			0.31626			1.05		
07/31/20 14:00	0.2			3			1.7			0.75			0.3591			1.2		
07/31/20 15:00	0.4			2			1.7			0.66			0.31314			1.04		
07/31/20 16:00	0.4			2			1.7			0.65			0.30816			1.03		
07/31/20 17:00	0.2			3			1.7			0.7			0.33594			1.12		
07/31/20 18:00	0.3			2			1.7			0.68			0.32544			1.08		
07/31/20 19:00	0.3			2			1.7			0.67			0.32172			1.07		
07/31/20 20:00	0.7			2			1.7			0.59			0.2814			0.94		
07/31/20 21:00	0.7			1			1.7			0.44			0.21648			0.72		
07/31/20 22:00	0.7			1			1.7			0.43			0.21546			0.72		
07/31/20 23:00	0.6			1			1.7			0.36			0.17478			0.58		
08/01/20 0:00	0.6			2			1.7			0.36			0.16818			0.56		
08/01/20 1:00	0.6			2			1.7			0.36			0.16818			0.56		
08/01/20 2:00	0.6			2			1.7			0.36			0.1683			0.56		
08/01/20 3:00	0.6			2			1.7			0.36			0.16842			0.56		
08/01/20 4:00	0.6			2			1.7			0.36			0.16842			0.56		
08/01/20 5:00	0.6			2			1.7			0.36			0.16854			0.56		
08/01/20 6:00	0.6			2			1.7			0.36			0.16854			0.56		
08/01/20 7:00	0.6			2			1.7			0.36			0.16842			0.56		
08/01/20 8:00	0.6			1			1.7			0.36			0.16908			0.56		
08/01/20 9:00	0.8			1			1.7			0.39			0.18948			0.63		
08/01/20 10:00	0.7			1			1.7			0.43			0.20964			0.7		
08/01/20 11:00	0.7			1			1.7			0.43			0.2154			0.72		
08/01/20 12:00	0.7			1			1.7			0.45			0.22602			0.75		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/01/20 13:00	0.7			1			1.7			0.47			0.22002			0.73		
08/01/20 14:00	0.8			1			1.8			0.46			0.213			0.71		
08/01/20 15:00	0.4			3			1.6			0.75			0.35712			1.19		
08/01/20 16:00	0.2			3			1.7			0.74			0.3552			1.18		
08/01/20 17:00	0.2			3			1.7			0.74			0.35358			1.18		
08/01/20 18:00	0.2			3			1.7			0.71			0.33828			1.13		
08/01/20 19:00	0.3			2			1.7			0.67			0.32064			1.07		
08/01/20 20:00	0.9			2			1.7			0.58			0.27432			0.91		
08/01/20 21:00	1.3			2			1.7			0.53			0.25464			0.85		
08/01/20 22:00	0.8			1			1.7			0.44			0.21186			0.71		
08/01/20 23:00	0.8			1			1.7			0.39			0.19488			0.65		
08/02/20 0:00	0.6			2			1.7			0.36			0.16944			0.56		
08/02/20 1:00	0.6			2			1.7			0.35			0.1674			0.56		
08/02/20 2:00	0.7			2			1.7			0.35			0.16728			0.56		
08/02/20 3:00	0.7			2			1.7			0.35			0.1674			0.56		
08/02/20 4:00	0.7			1			1.7			0.36			0.1683			0.56		
08/02/20 5:00	0.8			2			1.7			0.38			0.1845			0.62		
08/02/20 6:00	0.8			1			1.7			0.38			0.1884			0.63		
08/02/20 7:00	0.8			1			1.7			0.37			0.1905			0.64		
08/02/20 8:00	0.6			2			1.7			0.36			0.1686			0.56		
08/02/20 9:00	0.6			2			1.7			0.36			0.16668			0.56		
08/02/20 10:00	0.7			2			1.7			0.36			0.16668			0.56		
08/02/20 11:00	0.7			1			1.7			0.43			0.2022			0.67		
08/02/20 12:00	0.8			1			1.7			0.47			0.22596			0.75		
08/02/20 13:00	0.4			2			1.6			0.67			0.31722			1.06		
08/02/20 14:00	0.4			2			1.6			0.66			0.31596			1.05		
08/02/20 15:00	0.2			3			1.7			0.74			0.35622			1.19		
08/02/20 16:00	0.2			3			1.7			0.68			0.32616			1.09		
08/02/20 17:00	0.2			3			1.7			0.73			0.34758			1.16		
08/02/20 18:00	0.3			2			1.7			0.67			0.32052			1.07		
08/02/20 19:00	0.3			2			1.7			0.66			0.31512			1.05		
08/02/20 20:00	0.5			2			1.7			0.62			0.29718			0.99		
08/02/20 21:00	0.8			1			1.7			0.48			0.22836			0.76		
08/02/20 22:00	0.8			1			1.7			0.39			0.1926			0.64		
08/02/20 23:00	0.7			1			1.7			0.44			0.2181			0.73		
08/03/20 0:00	0.8			2			1.7			0.36			0.18216			0.61		
08/03/20 1:00	0.6			1			1.7			0.36			0.1683			0.56		
08/03/20 2:00	0.6			2			1.7			0.36			0.16758			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/03/20 3:00	0.6			2			1.7			0.36			0.1677			0.56		
08/03/20 4:00	0.7			1			1.7			0.35			0.16776			0.56		
08/03/20 5:00	0.6			2			1.7			0.36			0.168			0.56		
08/03/20 6:00	0.6			2			1.7			0.36			0.16794			0.56		
08/03/20 7:00	0.6			1			1.7			0.36			0.16824			0.56		
08/03/20 8:00	0.7			2			1.7			0.37			0.17538			0.58		
08/03/20 9:00	0.7			2			1.7			0.36			0.16974			0.57		
08/03/20 10:00	0.7			1			1.7			0.48			0.23016			0.77		
08/03/20 11:00	0.8			1			1.7			0.52			0.243			0.81		
08/03/20 12:00	0.7			2			1.7			0.61			0.29022			0.97		
08/03/20 13:00	0.6			2			1.7			0.63			0.29796			0.99		
08/03/20 14:00	0.2			3			1.7			0.74			0.35364			1.18		
08/03/20 15:00	0.2			3			1.7			0.72			0.34362			1.15		
08/03/20 16:00	0.2			3			1.7			0.71			0.3417			1.14		
08/03/20 17:00	0.2			3			1.7			0.72			0.3441			1.15		
08/03/20 18:00	0.2			3			1.7			0.75			0.35928			1.2		
08/03/20 19:00	0.4			2			1.7			0.63			0.30336			1.01		
08/03/20 20:00	0.8			1			1.7			0.44			0.21078			0.7		
08/03/20 21:00	0.7			1			1.7			0.46			0.22794			0.76		
08/03/20 22:00	0.7			1			1.7			0.37			0.19416			0.65		
08/03/20 23:00	0.7			1			1.7			0.4			0.2103			0.7		
08/04/20 0:00	0.6			1			1.7			0.36			0.1722			0.57		
08/04/20 1:00	0.6			1			1.7			0.36			0.16752			0.56		
08/04/20 2:00	0.6			2			1.7			0.36			0.16758			0.56		
08/04/20 3:00	0.6			1			1.7			0.35			0.16782			0.56		
08/04/20 4:00	0.6			1			1.7			0.36			0.16782			0.56		
08/04/20 5:00	0.6			2			1.7			0.36			0.16788			0.56		
08/04/20 6:00	0.6			2			1.7			0.36			0.16788			0.56		
08/04/20 7:00	0.6			2			1.7			0.36			0.168			0.56		
08/04/20 8:00	0.8			1			1.7			0.39			0.18588			0.62		
08/04/20 9:00	0.7			1			1.7			0.43			0.21042			0.7		
08/04/20 10:00	0.7			1			1.7			0.43			0.21636			0.72		
08/04/20 11:00	1			1			1.7			0.51			0.24192			0.81		
08/04/20 12:00	0.5			2			1.7			0.63			0.2991			1		
08/04/20 13:00	0.6			2			1.7			0.62			0.29124			0.97		
08/04/20 14:00	0.2			3			1.7			0.71			0.336			1.12		
08/04/20 15:00	0.2			3			1.7			0.75			0.35868			1.2		
08/04/20 16:00	0.2			3			1.7			0.75			0.3579			1.19		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/04/20 17:00	0.2			3			1.7			0.75			0.35868			1.2		
08/04/20 18:00	0.2			3			1.7			0.74			0.3519			1.17		
08/04/20 19:00	1			2			1.7			0.53			0.25836			0.86		
08/04/20 20:00	0.7			1			1.7			0.45			0.21744			0.72		
08/04/20 21:00	0.6			1			1.7			0.36			0.1689			0.56		
08/04/20 22:00	0.6			1			1.7			0.36			0.16788			0.56		
08/04/20 23:00	0.8			2			1.7			0.38			0.18246			0.61		
08/05/20 0:00	0.6			2			1.7			0.36			0.16776			0.56		
08/05/20 1:00	0.6			2			1.7			0.36			0.1677			0.56		
08/05/20 2:00	0.6			2			1.7			0.36			0.16782			0.56		
08/05/20 3:00	0.6			2			1.7			0.35			0.16776			0.56		
08/05/20 4:00	0.6			2			1.7			0.35			0.168			0.56		
08/05/20 5:00	0.6			2			1.7			0.35			0.16794			0.56		
08/05/20 6:00	0.6			2			1.7			0.36			0.16794			0.56		
08/05/20 7:00	0.6			1			1.7			0.36			0.16782			0.56		
08/05/20 8:00	0.6			1			1.7			0.36			0.16776			0.56		
08/05/20 9:00	0.7			1			1.7			0.36			0.17142			0.57		
08/05/20 10:00	0.8			1			1.7			0.38			0.1869			0.62		
08/05/20 11:00	1			1			1.7			0.5			0.2358			0.79		
08/05/20 12:00	0.8			2			1.7			0.61			0.28734			0.96		
08/05/20 13:00	0.5			2			1.7			0.64			0.3015			1.01		
08/05/20 14:00	0.4			2			1.7			0.65			0.30978			1.03		
08/05/20 15:00	0.4			2			1.7			0.66			0.31344			1.04		
08/05/20 16:00	0.5			2			1.7			0.64			0.30588			1.02		
08/05/20 17:00	0.9			2			1.7			0.59			0.27822			0.93		
08/05/20 18:00	0.6			2			1.7			0.61			0.29136			0.97		
08/05/20 19:00	0.8			1			1.7			0.4			0.19152			0.64		
08/05/20 20:00	0.8			1			1.7			0.41			0.20064			0.67		
08/05/20 21:00	0.8			1			1.7			0.39			0.18894			0.63		
08/05/20 22:00	0			0	X		0			0.43			0.06786			0.23		
08/05/20 23:00	0	X		0	X		0	X		0.21			0	X		0	X	
08/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 7:00	0			0	X		0			0	X		0.08628			0.29		
08/08/20 8:00	0.7			1			1.6			0	X		0.2427			0.81		
08/08/20 9:00	0.7			1			1.7			0	X		0.22716			0.76		
08/08/20 10:00	0.8			1			1.7			0	X		0.24348			0.81		
08/08/20 11:00	0.2			2			1.7			0	X		0.3399			1.13		
08/08/20 12:00	0.2			3			1.7			0	X		0.3402			1.13		
08/08/20 13:00	0.2			3			1.7			0	X		0.34002			1.13		
08/08/20 14:00	0.2			3			1.7			0	X		0.33936			1.13		
08/08/20 15:00	0.2			3			1.7			0	X		0.33894			1.13		
08/08/20 16:00	0.2			3			1.7			0	X		0.34104			1.14		
08/08/20 17:00	0.3			2			1.7			0	X		0.31536			1.05		
08/08/20 18:00	0.4			2			1.7			0	X		0.30408			1.01		
08/08/20 19:00	0.8			2			1.7			0	X		0.27492			0.92		
08/08/20 20:00	0.8			1			1.7			0	X		0.19662			0.66		
08/08/20 21:00	1.3			1			1.7			0	X		0.23832			0.79		
08/08/20 22:00	1.5			1			1.7			0.2			0.2403			0.8		
08/08/20 23:00	0.8			1			1.7			0.4			0.18822			0.63		
08/09/20 0:00	0.7			2			1.7			0.36			0.17112			0.57		
08/09/20 1:00	0.6			1			1.7			0.35			0.1671			0.56		
08/09/20 2:00	0.7			1			1.7			0.36			0.16722			0.56		
08/09/20 3:00	0.6			1			1.7			0.36			0.16734			0.56		
08/09/20 4:00	0.6			1			1.7			0.36			0.16734			0.56		
08/09/20 5:00	0.7			1			1.7			0.36			0.1674			0.56		
08/09/20 6:00	0.7			1			1.7			0.36			0.1674			0.56		
08/09/20 7:00	0.8			2			1.7			0.36			0.16884			0.56		
08/09/20 8:00	0.8			1			1.7			0.39			0.18846			0.63		
08/09/20 9:00	0.8			1			1.7			0.49			0.23892			0.8		
08/09/20 10:00	0.5			2			1.7			0.63			0.29868			1		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/09/20 11:00	0.3			2			1.7			0.68			0.32568			1.09		
08/09/20 12:00	0.2			3			1.7			0.74			0.35382			1.18		
08/09/20 13:00	0.2			3			1.7			0.75			0.35736			1.19		
08/09/20 14:00	0.2			3			1.7			0.75			0.35802			1.19		
08/09/20 15:00	0.2			3			1.7			0.74			0.35496			1.18		
08/09/20 16:00	0.2			3			1.7			0.72			0.34608			1.15		
08/09/20 17:00	0.2			3			1.7			0.74			0.35514			1.18		
08/09/20 18:00	0.5			3			1.7			0.66			0.31338			1.04		
08/09/20 19:00	0.2			3			1.7			0.75			0.35754			1.19		
08/09/20 20:00	0.2			3			1.7			0.69			0.33054			1.1		
08/09/20 21:00	0.5			2			1.7			0.62			0.29616			0.99		
08/09/20 22:00	0.6			2			1.7			0.59			0.2817			0.94		
08/09/20 23:00	0.7			1			1.7			0.42			0.20934			0.7		
08/10/20 0:00	0.8			1			1.7			0.38			0.1983			0.66		
08/10/20 1:00	0.8			1			1.7			0.36			0.19332			0.64		
08/10/20 2:00	0.8			2			1.7			0.35			0.17838			0.59		
08/10/20 3:00	0.7			2			1.7			0.36			0.17082			0.57		
08/10/20 4:00	0.8			1			1.6			0.36			0.17622			0.59		
08/10/20 5:00	0.7			1			1.7			0.35			0.1671			0.56		
08/10/20 6:00	0.7			2			1.7			0.36			0.16722			0.56		
08/10/20 7:00	0.8			2			1.7			0.37			0.17646			0.59		
08/10/20 8:00	0.7			1			1.7			0.41			0.20442			0.68		
08/10/20 9:00	0.8			1			1.7			0.49			0.23784			0.79		
08/10/20 10:00	0.7			2			1.7			0.62			0.29604			0.99		
08/10/20 11:00	0.2			3			1.7			0.71			0.33672			1.12		
08/10/20 12:00	0.2			3			1.7			0.75			0.35802			1.19		
08/10/20 13:00	0.2			3			1.7			0.75			0.35808			1.19		
08/10/20 14:00	0.2			3			1.7			0.75			0.3567			1.19		
08/10/20 15:00	0.2			3			1.7			0.74			0.35496			1.18		
08/10/20 16:00	0.2			3			1.7			0.74			0.35388			1.18		
08/10/20 17:00	0.2			3			1.7			0.73			0.34938			1.16		
08/10/20 18:00	0.5			2			1.7			0.6			0.28782			0.96		
08/10/20 19:00	0.7			1			1.7			0.46			0.219			0.73		
08/10/20 20:00	0.7			1			1.7			0.45			0.21978			0.73		
08/10/20 21:00	0.7			2			1.7			0.47			0.23172			0.77		
08/10/20 22:00	0.7			1			1.7			0.44			0.22086			0.74		
08/10/20 23:00	0.7			1			1.7			0.43			0.2199			0.73		
08/11/20 0:00	0.6			1			1.7			0.36			0.16878			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/11/20 1:00	0.6			2			1.7			0.36			0.16776			0.56		
08/11/20 2:00	0.6			2			1.7			0.36			0.16788			0.56		
08/11/20 3:00	0.6			2			1.7			0.36			0.16794			0.56		
08/11/20 4:00	0.6			2			1.7			0.36			0.16788			0.56		
08/11/20 5:00	0.6			2			1.7			0.36			0.16788			0.56		
08/11/20 6:00	0.6			2			1.7			0.36			0.168			0.56		
08/11/20 7:00	0.6			2			1.7			0.36			0.16872			0.56		
08/11/20 8:00	0.8			1			1.7			0.39			0.18546			0.62		
08/11/20 9:00	0.8			1			1.7			0.4			0.19416			0.65		
08/11/20 10:00	0.7			1			1.7			0.48			0.23718			0.79		
08/11/20 11:00	1.4			2			1.7			0.55			0.25698			0.86		
08/11/20 12:00	0.4			2			1.7			0.65			0.30768			1.03		
08/11/20 13:00	0.6			2			1.7			0.61			0.28806			0.96		
08/11/20 14:00	0.7			2			1.7			0.6			0.28248			0.94		
08/11/20 15:00	0.6			2			1.7			0.6			0.28776			0.96		
08/11/20 16:00	0.5			2			1.7			0.61			0.28896			0.96		
08/11/20 17:00	0.7			2			1.7			0.59			0.27792			0.93		
08/11/20 18:00	0.9			2			1.7			0.58			0.27414			0.91		
08/11/20 19:00	0.8			1			1.7			0.48			0.2286			0.76		
08/11/20 20:00	0.7			1			1.7			0.47			0.22332			0.74		
08/11/20 21:00	0.7			2			1.7			0.51			0.24312			0.81		
08/11/20 22:00	0.7			1			1.7			0.42			0.20268			0.68		
08/11/20 23:00	0.8			2			1.7			0.37			0.1815			0.61		
08/12/20 0:00	0.6			2			1.7			0.35			0.16734			0.56		
08/12/20 1:00	0.6			2			1.7			0.35			0.16746			0.56		
08/12/20 2:00	0.6			2			1.7			0.36			0.16788			0.56		
08/12/20 3:00	0.6			2			1.7			0.36			0.168			0.56		
08/12/20 4:00	0.6			2			1.7			0.36			0.168			0.56		
08/12/20 5:00	0.6			2			1.7			0.36			0.16806			0.56		
08/12/20 6:00	0.6			2			1.7			0.36			0.16824			0.56		
08/12/20 7:00	0.7			1			1.7			0.36			0.1719			0.57		
08/12/20 8:00	0.7			1			1.7			0.36			0.17028			0.57		
08/12/20 9:00	0.8			1			1.7			0.39			0.18924			0.63		
08/12/20 10:00	0.7			1			1.7			0.46			0.22362			0.75		
08/12/20 11:00	0.6			2			1.6			0.66			0.31284			1.04		
08/12/20 12:00	0.2			3			1.7			0.72			0.34608			1.15		
08/12/20 13:00	0.2			3			1.7			0.74			0.35412			1.18		
08/12/20 14:00	0.2			3			1.7			0.74			0.35406			1.18		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/12/20 15:00	0.2			3			1.7			0.74			0.35454			1.18		
08/12/20 16:00	0.1			3			1.7			0.74			0.3543			1.18		
08/12/20 17:00	0.1			3			1.7			0.74			0.35424			1.18		
08/12/20 18:00	0.2			3			1.7			0.74			0.35238			1.17		
08/12/20 19:00	0.2			3			1.7			0.68			0.32424			1.08		
08/12/20 20:00	0.8			2			1.7			0.59			0.27936			0.93		
08/12/20 21:00	0.7			2			1.7			0.59			0.28302			0.94		
08/12/20 22:00	1.1			2			1.7			0.54			0.2574			0.86		
08/12/20 23:00	0.8			1			1.7			0.47			0.22662			0.76		
08/13/20 0:00	0.8			1			1.7			0.38			0.18684			0.62		
08/13/20 1:00	0.7			2			1.7			0.35			0.1689			0.56		
08/13/20 2:00	0.7			2			1.7			0.36			0.16716			0.56		
08/13/20 3:00	0.6			2			1.7			0.35			0.16716			0.56		
08/13/20 4:00	0.6			1			1.7			0.35			0.16716			0.56		
08/13/20 5:00	0.6			1			1.7			0.35			0.16722			0.56		
08/13/20 6:00	0.7			2			1.7			0.37			0.174			0.58		
08/13/20 7:00	0.8			2			1.7			0.36			0.1785			0.6		
08/13/20 8:00	0.8			1			1.7			0.38			0.19098			0.64		
08/13/20 9:00	0.7			1			1.7			0.44			0.2214			0.74		
08/13/20 10:00	1			2			1.7			0.55			0.26406			0.88		
08/13/20 11:00	0.2			3			1.7			0.71			0.3396			1.13		
08/13/20 12:00	0.2			3			1.7			0.73			0.35064			1.17		
08/13/20 13:00	0.2			3			1.7			0.74			0.35178			1.17		
08/13/20 14:00	0.2			3			1.7			0.74			0.35178			1.17		
08/13/20 15:00	0.2			3			1.7			0.7			0.3345			1.12		
08/13/20 16:00	0.2			3			1.7			0.68			0.32694			1.09		
08/13/20 17:00	0.2			3			1.7			0.72			0.34734			1.16		
08/13/20 18:00	0.3			2			1.7			0.67			0.31926			1.06		
08/13/20 19:00	0.9			2			1.7			0.57			0.27018			0.9		
08/13/20 20:00	1.2			2			1.7			0.53			0.24768			0.83		
08/13/20 21:00	0.3			3			1.7			0.7			0.33408			1.11		
08/13/20 22:00	0.2			3			1.7			0.71			0.33792			1.13		
08/13/20 23:00	0.7			1			1.7			0.45			0.22422			0.75		
08/14/20 0:00	0.8			1			1.7			0.36			0.19458			0.65		
08/14/20 1:00	0.8			1			1.7			0.36			0.19656			0.66		
08/14/20 2:00	0.7			2			1.7			0.36			0.17106			0.57		
08/14/20 3:00	0.7			1			1.7			0.36			0.1671			0.56		
08/14/20 4:00	0.9			1			1.6			0.37			0.17628			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/14/20 5:00	1			1			1.7			0.41			0.20166			0.67		
08/14/20 6:00	1.2			2			1.7			0.49			0.23484			0.78		
08/14/20 7:00	1.2			2			1.7			0.57			0.26988			0.9		
08/14/20 8:00	0.2			3			1.7			0.73			0.3504			1.17		
08/14/20 9:00	0.2			3			1.7			0.74			0.3549			1.18		
08/14/20 10:00	0.2			3			1.7			0.74			0.35628			1.19		
08/14/20 11:00	0.3			3			1.7			0.68			0.32676			1.09		
08/14/20 12:00	0.4			2			1.7			0.64			0.30654			1.02		
08/14/20 13:00	0.4			2			1.7			0.65			0.3093			1.03		
08/14/20 14:00	0.4			2			1.7			0.65			0.30756			1.03		
08/14/20 15:00	0.2			3			1.7			0.74			0.35292			1.18		
08/14/20 16:00	0.2			3			1.7			0.74			0.35544			1.18		
08/14/20 17:00	0.2			3			1.7			0.73			0.35046			1.17		
08/14/20 18:00	0.2			3			1.7			0.72			0.34386			1.15		
08/14/20 19:00	0.2			3			1.7			0.74			0.35346			1.18		
08/14/20 20:00	0.3			3			1.7			0.69			0.3309			1.1		
08/14/20 21:00	0.6			2			1.7			0.61			0.29238			0.97		
08/14/20 22:00	0.5			2			1.7			0.63			0.3012			1		
08/14/20 23:00	0.9			1			1.7			0.42			0.20568			0.69		
08/15/20 0:00	0.9			1			1.7			0.38			0.19254			0.64		
08/15/20 1:00	0.8			1			1.7			0.39			0.20574			0.69		
08/15/20 2:00	0.7			1			1.7			0.36			0.17508			0.58		
08/15/20 3:00	0.6			1			1.7			0.36			0.1677			0.56		
08/15/20 4:00	0.6			1			1.7			0.36			0.16746			0.56		
08/15/20 5:00	0.7			1			1.7			0.36			0.16824			0.56		
08/15/20 6:00	0.8			1			1.7			0.42			0.2028			0.68		
08/15/20 7:00	0.7			1			1.7			0.48			0.23616			0.79		
08/15/20 8:00	0.5			2			1.7			0.68			0.32586			1.09		
08/15/20 9:00	0.2			3			1.7			0.75			0.35766			1.19		
08/15/20 10:00	0.2			3			1.7			0.74			0.3564			1.19		
08/15/20 11:00	0.2			3			1.7			0.74			0.35436			1.18		
08/15/20 12:00	0.3			3			1.7			0.68			0.32166			1.07		
08/15/20 13:00	0.3			2			1.7			0.64			0.30516			1.02		
08/15/20 14:00	0.2			3			1.7			0.72			0.342			1.14		
08/15/20 15:00	0.3			2			1.7			0.66			0.31152			1.04		
08/15/20 16:00	0.2			3			1.7			0.69			0.32736			1.09		
08/15/20 17:00	0.2			3			1.7			0.7			0.33378			1.11		
08/15/20 18:00	0.2			3			1.7			0.7			0.33534			1.12		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/15/20 19:00	0.2			4			1.7			0.74			0.35688			1.19		
08/15/20 20:00	0.1			3			1.7			0.73			0.34932			1.16		
08/15/20 21:00	0.2			3			1.7			0.72			0.3441			1.15		
08/15/20 22:00	0.2			3			1.7			0.73			0.3504			1.17		
08/15/20 23:00	0.8			2			1.7			0.57			0.279			0.93		
08/16/20 0:00	0.9			1			1.7			0.44			0.21084			0.7		
08/16/20 1:00	0.7			1			1.7			0.43			0.2106			0.7		
08/16/20 2:00	0.8			1			1.7			0.41			0.20226			0.67		
08/16/20 3:00	0.8			1			1.7			0.38			0.19638			0.65		
08/16/20 4:00	0.8			1			1.7			0.37			0.198			0.66		
08/16/20 5:00	0.7			1			1.7			0.41			0.21258			0.71		
08/16/20 6:00	0.8			1			1.7			0.43			0.2031			0.68		
08/16/20 7:00	0.7			1			1.7			0.45			0.22122			0.74		
08/16/20 8:00	0.7			1			1.7			0.44			0.21942			0.73		
08/16/20 9:00	0.9			2			1.6			0.57			0.26886			0.9		
08/16/20 10:00	0.7			2			1.6			0.59			0.28128			0.94		
08/16/20 11:00	0.6			2			1.7			0.6			0.28278			0.94		
08/16/20 12:00	0.9			2			1.7			0.55			0.26148			0.87		
08/16/20 13:00	0.4			2			1.7			0.63			0.29784			0.99		
08/16/20 14:00	0.2			3			1.7			0.73			0.34902			1.16		
08/16/20 15:00	0.2			3			1.7			0.71			0.34062			1.14		
08/16/20 16:00	0.2			3			1.7			0.7			0.33168			1.11		
08/16/20 17:00	0.4			2			1.7			0.66			0.31464			1.05		
08/16/20 18:00	0.7			2			1.7			0.59			0.2808			0.94		
08/16/20 19:00	0.5			2			1.7			0.64			0.30618			1.02		
08/16/20 20:00	0.3			3			1.7			0.74			0.35322			1.18		
08/16/20 21:00	0.2			3			1.7			0.69			0.32958			1.1		
08/16/20 22:00	0.3			3			1.7			0.69			0.32904			1.1		
08/16/20 23:00	0.9			2			1.7			0.54			0.27492			0.92		
08/17/20 0:00	0.9			1			1.7			0.43			0.22488			0.75		
08/17/20 1:00	1			1			1.7			0.4			0.19896			0.66		
08/17/20 2:00	1.2			1			1.7			0.4			0.2046			0.68		
08/17/20 3:00	1.2			1			1.7			0.39			0.2064			0.69		
08/17/20 4:00	1.1			1			1.7			0.38			0.2106			0.7		
08/17/20 5:00	1			1			1.7			0.44			0.22332			0.74		
08/17/20 6:00	1			1			1.7			0.5			0.2355			0.79		
08/17/20 7:00	0.6			2			1.5			0.64			0.30396			1.01		
08/17/20 8:00	0.3			3			1.6			0.74			0.35304			1.18		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/17/20 9:00	0.3			3			1.6			0.75			0.35916			1.2		
08/17/20 10:00	0.3			3			1.6			0.75			0.3585			1.2		
08/17/20 11:00	0.3			3			1.6			0.75			0.357			1.19		
08/17/20 12:00	0.2			3			1.6			0.7			0.33594			1.12		
08/17/20 13:00	0.4			2			1.6			0.64			0.30264			1.01		
08/17/20 14:00	0.6			2			1.6			0.6			0.28464			0.95		
08/17/20 15:00	0.8			1			1.7			0.41			0.19494			0.65		
08/17/20 16:00	0.8			2			1.7			0.56			0.2667			0.89		
08/17/20 17:00	0.3			2			1.7			0.67			0.3183			1.06		
08/17/20 18:00	0.3			2			1.7			0.67			0.31866			1.06		
08/17/20 19:00	0.3			2			1.7			0.68			0.32448			1.08		
08/17/20 20:00	0.9			2			1.7			0.6			0.28452			0.95		
08/17/20 21:00	1.1			2			1.7			0.55			0.25902			0.86		
08/17/20 22:00	1			1			1.7			0.51			0.2415			0.81		
08/17/20 23:00	1.1			1			1.7			0.47			0.21936			0.73		
08/18/20 0:00	0.9			1			1.7			0.43			0.20076			0.67		
08/18/20 1:00	0.9			1			1.7			0.4			0.1947			0.65		
08/18/20 2:00	0.8			1			1.7			0.38			0.18342			0.61		
08/18/20 3:00	0.9			1			1.7			0.38			0.18528			0.62		
08/18/20 4:00	0.9			1			1.7			0.39			0.1956			0.65		
08/18/20 5:00	0.8			1			1.7			0.36			0.16908			0.56		
08/18/20 6:00	0.8			1			1.7			0.37			0.17454			0.58		
08/18/20 7:00	0.8			1			1.7			0.43			0.20934			0.7		
08/18/20 8:00	1.5			2			1.7			0.54			0.25428			0.85		
08/18/20 9:00	0.4			2			1.7			0.66			0.3141			1.05		
08/18/20 10:00	0.3			2			1.7			0.66			0.31554			1.05		
08/18/20 11:00	0.2			3			1.7			0.7			0.3324			1.11		
08/18/20 12:00	0.2			3			1.7			0.74			0.35448			1.18		
08/18/20 13:00	0.2			3			1.7			0.71			0.3369			1.12		
08/18/20 14:00	0.2			3			1.7			0.69			0.3279			1.09		
08/18/20 15:00	0.8			2			1.7			0.56			0.2631			0.88		
08/18/20 16:00	0.5			2			1.7			0.6			0.28314			0.94		
08/18/20 17:00	0.9			2			1.7			0.55			0.26262			0.88		
08/18/20 18:00	0.7			2			1.7			0.58			0.27834			0.93		
08/18/20 19:00	0.7			2			1.7			0.57			0.27216			0.91		
08/18/20 20:00	0.8			1			1.8			0.4			0.19146			0.64		
08/18/20 21:00	0.7			2			1.7			0.57			0.27474			0.92		
08/18/20 22:00	1			2			1.7			0.56			0.26724			0.89		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/18/20 23:00	0.9			2			1.7			0.55			0.2697			0.9		
08/19/20 0:00	0.7			1			1.7			0.48			0.23274			0.78		
08/19/20 1:00	0.7			1			1.7			0.45			0.22122			0.74		
08/19/20 2:00	0.7			1			1.7			0.42			0.21222			0.71		
08/19/20 3:00	0.8			1			1.7			0.39			0.20238			0.67		
08/19/20 4:00	0.7			1			1.7			0.42			0.22338			0.74		
08/19/20 5:00	0.7			1			1.7			0.42			0.22842			0.76		
08/19/20 6:00	0.7			1			1.7			0.47			0.23568			0.79		
08/19/20 7:00	1.3			2			1.7			0.55			0.2616			0.87		
08/19/20 8:00	0.4			2			1.7			0.67			0.32046			1.07		
08/19/20 9:00	0.5			2			1.7			0.63			0.30234			1.01		
08/19/20 10:00	0.2			3			1.7			0.73			0.34992			1.17		
08/19/20 11:00	0.2			3			1.7			0.74			0.35376			1.18		
08/19/20 12:00	0.2			4			1.7			0.74			0.35646			1.19		
08/19/20 13:00	0.3			3			1.7			0.69			0.33198			1.11		
08/19/20 14:00	0.9			2			1.7			0.56			0.2685			0.9		
08/19/20 15:00	1			2			1.7			0.56			0.26712			0.89		
08/19/20 16:00	0.6			2			1.7			0.62			0.29424			0.98		
08/19/20 17:00	0.3			3			1.7			0.72			0.34536			1.15		
08/19/20 18:00	0.3			3			1.7			0.67			0.32358			1.08		
08/19/20 19:00	0.7			2			1.7			0.59			0.28392			0.95		
08/19/20 20:00	0.8			2			1.7			0.59			0.28152			0.94		
08/19/20 21:00	0.9			2			1.7			0.58			0.27834			0.93		
08/19/20 22:00	1			1			1.7			0.48			0.22806			0.76		
08/19/20 23:00	0.8			1			1.7			0.46			0.22134			0.74		
08/20/20 0:00	0.9			1			1.7			0.39			0.1941			0.65		
08/20/20 1:00	0.9			1			1.7			0.36			0.18384			0.61		
08/20/20 2:00	0.8			2			1.7			0.36			0.1671			0.56		
08/20/20 3:00	0.8			2			1.7			0.36			0.16728			0.56		
08/20/20 4:00	0.8			1			1.7			0.35			0.16734			0.56		
08/20/20 5:00	0.9			2			1.7			0.36			0.1731			0.58		
08/20/20 6:00	0.9			2			1.7			0.36			0.17988			0.6		
08/20/20 7:00	1			2			1.7			0.36			0.1749			0.58		
08/20/20 8:00	1.1			2			1.7			0.37			0.1833			0.61		
08/20/20 9:00	1			1			1.7			0.41			0.20604			0.69		
08/20/20 10:00	1.1			1			1.7			0.46			0.22752			0.76		
08/20/20 11:00	1.7			2			1.7			0.55			0.25662			0.86		
08/20/20 12:00	1.1			1			1.7			0.49			0.23736			0.79		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/20/20 13:00	1			1			1.7			0.5			0.2388			0.8		
08/20/20 14:00	1.1			1			1.7			0.42			0.20226			0.67		
08/20/20 15:00	1.2			2			1.7			0.54			0.26526			0.88		
08/20/20 16:00	1.2			1			1.7			0.45			0.21708			0.72		
08/20/20 17:00	1.2			1			1.7			0.48			0.23994			0.8		
08/20/20 18:00	1.3			2			1.7			0.55			0.26892			0.9		
08/20/20 19:00	1.2			1			1.7			0.43			0.21228			0.71		
08/20/20 20:00	1			1			1.7			0.44			0.2217			0.74		
08/20/20 21:00	0.8			1			1.7			0.45			0.23166			0.77		
08/20/20 22:00	0.9			1			1.7			0.38			0.20562			0.69		
08/20/20 23:00	0.7			1			1.7			0.36			0.16824			0.56		
08/21/20 0:00	0.7			1			1.7			0.35			0.16746			0.56		
08/21/20 1:00	0.8			1			1.7			0.35			0.1674			0.56		
08/21/20 2:00	0.7			1			1.7			0.35			0.1674			0.56		
08/21/20 3:00	0.8			2			1.7			0.37			0.17658			0.59		
08/21/20 4:00	0.9			1			1.7			0.36			0.17832			0.59		
08/21/20 5:00	0.7			2			1.7			0.35			0.16752			0.56		
08/21/20 6:00	0.9			1			1.7			0.39			0.186			0.62		
08/21/20 7:00	0.8			1			1.7			0.43			0.21138			0.7		
08/21/20 8:00	0.8			1			1.7			0.42			0.21216			0.71		
08/21/20 9:00	0.8			1			1.7			0.45			0.23124			0.77		
08/21/20 10:00	1			1			1.7			0.49			0.2418			0.81		
08/21/20 11:00	1.4			1			1.7			0.51			0.23796			0.79		
08/21/20 12:00	1.2			1			1.7			0.49			0.22134			0.74		
08/21/20 13:00	0.4			3			1.6			0.7			0.33642			1.12		
08/21/20 14:00	0.4			2			1.7			0.66			0.31284			1.04		
08/21/20 15:00	0.3			3			1.7			0.7			0.33678			1.12		
08/21/20 16:00	0.3			3			1.7			0.74			0.35496			1.18		
08/21/20 17:00	0.3			3			1.7			0.74			0.35556			1.19		
08/21/20 18:00	0.3			3			1.7			0.74			0.3552			1.18		
08/21/20 19:00	0.9			1			1.7			0.49			0.23646			0.79		
08/21/20 20:00	0.9			1			1.7			0.43			0.21006			0.7		
08/21/20 21:00	0.6			2			1.7			0.63			0.30486			1.02		
08/21/20 22:00	0.5			2			1.7			0.63			0.30354			1.01		
08/21/20 23:00	0.8			1			1.7			0.41			0.20364			0.68		
08/22/20 0:00	0.7			1			1.7			0.36			0.1689			0.56		
08/22/20 1:00	0.9			1			1.7			0.38			0.18246			0.61		
08/22/20 2:00	0.9			2			1.7			0.37			0.1785			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/22/20 3:00	0.9			1			1.7			0.36			0.16884			0.56		
08/22/20 4:00	0.9			1			1.7			0.35			0.16728			0.56		
08/22/20 5:00	0.9			2			1.7			0.35			0.16716			0.56		
08/22/20 6:00	1			2			1.7			0.36			0.17298			0.58		
08/22/20 7:00	1			1			1.7			0.39			0.19104			0.64		
08/22/20 8:00	0.9			1			1.7			0.38			0.19158			0.64		
08/22/20 9:00	0.8			1			1.7			0.44			0.2196			0.73		
08/22/20 10:00	0.9			1			1.7			0.49			0.23298			0.78		
08/22/20 11:00	1.1			2			1.7			0.57			0.26946			0.9		
08/22/20 12:00	1.4			2			1.7			0.52			0.24624			0.82		
08/22/20 13:00	1.5			1			1.7			0.5			0.23586			0.79		
08/22/20 14:00	1.4			2			1.7			0.51			0.24126			0.8		
08/22/20 15:00	0.8			2			1.7			0.58			0.27666			0.92		
08/22/20 16:00	0.3			3			1.7			0.69			0.33126			1.1		
08/22/20 17:00	0.3			3			1.7			0.73			0.3507			1.17		
08/22/20 18:00	0.3			3			1.7			0.72			0.3465			1.16		
08/22/20 19:00	0.5			2			1.7			0.61			0.29376			0.98		
08/22/20 20:00	0.7			2			1.7			0.6			0.28698			0.96		
08/22/20 21:00	1.1			2			1.7			0.55			0.26196			0.87		
08/22/20 22:00	0.9			1			1.7			0.5			0.23568			0.79		
08/22/20 23:00	0.9			1			1.7			0.44			0.21018			0.7		
08/23/20 0:00	0.9			1			1.7			0.38			0.19002			0.63		
08/23/20 1:00	0.8			2			1.7			0.36			0.17436			0.58		
08/23/20 2:00	0.7			2			1.7			0.35			0.16698			0.56		
08/23/20 3:00	0.7			2			1.7			0.35			0.16704			0.56		
08/23/20 4:00	0.7			1			1.7			0.35			0.16716			0.56		
08/23/20 5:00	0.8			1			1.7			0.35			0.16722			0.56		
08/23/20 6:00	0.8			2			1.7			0.35			0.16728			0.56		
08/23/20 7:00	0.7			2			1.7			0.36			0.16722			0.56		
08/23/20 8:00	0.8			2			1.7			0.37			0.17226			0.57		
08/23/20 9:00	0.8			1			1.7			0.45			0.21624			0.72		
08/23/20 10:00	1.7			2			1.7			0.52			0.24384			0.81		
08/23/20 11:00	0.4			2			1.7			0.66			0.31488			1.05		
08/23/20 12:00	0.3			3			1.7			0.71			0.33834			1.13		
08/23/20 13:00	0.2			3			1.7			0.7			0.33528			1.12		
08/23/20 14:00	0.4			3			1.7			0.66			0.31494			1.05		
08/23/20 15:00	0.4			2			1.7			0.65			0.3096			1.03		
08/23/20 16:00	0.3			3			1.7			0.67			0.321			1.07		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/23/20 17:00	0.3			3			1.7			0.66			0.31428			1.05		
08/23/20 18:00	0.6			2			1.7			0.61			0.29034			0.97		
08/23/20 19:00	1.2			2			1.7			0.52			0.24624			0.82		
08/23/20 20:00	0.8			1			1.7			0.5			0.23934			0.8		
08/23/20 21:00	0.8			2			1.7			0.58			0.28326			0.94		
08/23/20 22:00	1.2			2			1.7			0.53			0.24882			0.83		
08/23/20 23:00	0.9			1			1.7			0.42			0.2022			0.67		
08/24/20 0:00	0.9			1			1.7			0.37			0.18882			0.63		
08/24/20 1:00	0.8			1			1.7			0.36			0.1698			0.57		
08/24/20 2:00	0.8			1			1.7			0.36			0.1674			0.56		
08/24/20 3:00	0.8			1			1.7			0.36			0.16752			0.56		
08/24/20 4:00	1			1			1.6			0.38			0.1824			0.61		
08/24/20 5:00	1			1			1.7			0.37			0.1872			0.62		
08/24/20 6:00	0.9			1			1.7			0.39			0.2034			0.68		
08/24/20 7:00	0.9			1			1.7			0.44			0.22932			0.76		
08/24/20 8:00	1.2			2			1.7			0.54			0.26124			0.87		
08/24/20 9:00	0.5			2			1.7			0.64			0.30366			1.01		
08/24/20 10:00	0.4			2			1.7			0.66			0.31236			1.04		
08/24/20 11:00	0.3			3			1.7			0.73			0.35148			1.17		
08/24/20 12:00	0.3			3			1.7			0.68			0.327			1.09		
08/24/20 13:00	0.5			2			1.7			0.63			0.29994			1		
08/24/20 14:00	0.4			2			1.7			0.66			0.3129			1.04		
08/24/20 15:00	0.6			2			1.7			0.62			0.29448			0.98		
08/24/20 16:00	0.4			2			1.7			0.66			0.3141			1.05		
08/24/20 17:00	0.4			2			1.7			0.66			0.31416			1.05		
08/24/20 18:00	0.5			2			1.7			0.62			0.2961			0.99		
08/24/20 19:00	1.1			2			1.7			0.52			0.24918			0.83		
08/24/20 20:00	0.7			1			1.7			0.47			0.22536			0.75		
08/24/20 21:00	1.2			2			1.7			0.54			0.2574			0.86		
08/24/20 22:00	0.9			2			1.7			0.55			0.264			0.88		
08/24/20 23:00	0.8			1			1.7			0.44			0.21168			0.71		
08/25/20 0:00	0.9			1			1.7			0.38			0.19284			0.64		
08/25/20 1:00	0.8			2			1.7			0.36			0.17088			0.57		
08/25/20 2:00	0.7			2			1.7			0.36			0.1674			0.56		
08/25/20 3:00	0.7			1			1.7			0.36			0.16746			0.56		
08/25/20 4:00	0.7			1			1.7			0.36			0.16746			0.56		
08/25/20 5:00	0.7			1			1.7			0.36			0.16764			0.56		
08/25/20 6:00	0.9			1			1.7			0.38			0.18552			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/25/20 7:00	0.8			1			1.7			0.4			0.20262			0.68		
08/25/20 8:00	0.8			1			1.7			0.46			0.23262			0.78		
08/25/20 9:00	1			1			1.7			0.51			0.24114			0.8		
08/25/20 10:00	0.7			2			1.7			0.6			0.28542			0.95		
08/25/20 11:00	0.3			2			1.7			0.67			0.32142			1.07		
08/25/20 12:00	0.7			2			1.7			0.6			0.28422			0.95		
08/25/20 13:00	0.6			2			1.7			0.6			0.28446			0.95		
08/25/20 14:00	0.6			2			1.7			0.6			0.28554			0.95		
08/25/20 15:00	0.4			2			1.7			0.65			0.3117			1.04		
08/25/20 16:00	0.3			3			1.7			0.67			0.3201			1.07		
08/25/20 17:00	0.2			3			1.7			0.73			0.34872			1.16		
08/25/20 18:00	0.3			2			1.7			0.64			0.30756			1.03		
08/25/20 19:00	0.6			2			1.7			0.59			0.28356			0.95		
08/25/20 20:00	1			1			1.7			0.49			0.23358			0.78		
08/25/20 21:00	0.7			1			1.7			0.49			0.23562			0.79		
08/25/20 22:00	0.7			1			1.7			0.47			0.22758			0.76		
08/25/20 23:00	0.8			1			1.7			0.37			0.18936			0.63		
08/26/20 0:00	0.7			2			1.7			0.36			0.16872			0.56		
08/26/20 1:00	0.7			2			1.7			0.36			0.16776			0.56		
08/26/20 2:00	0.7			2			1.7			0.35			0.16746			0.56		
08/26/20 3:00	0.7			2			1.7			0.35			0.16776			0.56		
08/26/20 4:00	0.8			2			1.7			0.36			0.17388			0.58		
08/26/20 5:00	0.9			2			1.7			0.36			0.18132			0.6		
08/26/20 6:00	0.9			2			1.7			0.36			0.1833			0.61		
08/26/20 7:00	0.8			1			1.7			0.4			0.20544			0.68		
08/26/20 8:00	0.8			1			1.7			0.43			0.22794			0.76		
08/26/20 9:00	0.8			1			1.7			0.47			0.24144			0.8		
08/26/20 10:00	1.3			2			1.7			0.56			0.26508			0.88		
08/26/20 11:00	0.4			2			1.7			0.66			0.31692			1.06		
08/26/20 12:00	0.2			3			1.7			0.72			0.34458			1.15		
08/26/20 13:00	0.2			3			1.7			0.73			0.35268			1.18		
08/26/20 14:00	0.2			3			1.7			0.73			0.35202			1.17		
08/26/20 15:00	0.2			3			1.7			0.73			0.35196			1.17		
08/26/20 16:00	0.2			3			1.7			0.74			0.35274			1.18		
08/26/20 17:00	0.2			3			1.7			0.73			0.34992			1.17		
08/26/20 18:00	0.7			2			1.7			0.59			0.28212			0.94		
08/26/20 19:00	1.1			1			1.7			0.5			0.23544			0.78		
08/26/20 20:00	0.7			1			1.7			0.48			0.23334			0.78		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/26/20 21:00	0.7			1			1.7			0.48			0.23502			0.78		
08/26/20 22:00	0.8			1			1.7			0.39			0.18876			0.63		
08/26/20 23:00	0.9			1			1.7			0.36			0.1848			0.62		
08/27/20 0:00	0.7			2			1.7			0.36			0.168			0.56		
08/27/20 1:00	0.7			2			1.7			0.36			0.168			0.56		
08/27/20 2:00	0.7			2			1.7			0.35			0.16794			0.56		
08/27/20 3:00	0.7			2			1.7			0.35			0.16806			0.56		
08/27/20 4:00	0.7			2			1.7			0.35			0.16818			0.56		
08/27/20 5:00	0.7			2			1.7			0.36			0.1683			0.56		
08/27/20 6:00	0.7			2			1.7			0.36			0.1689			0.56		
08/27/20 7:00	0.7			2			1.7			0.36			0.16938			0.56		
08/27/20 8:00	0.8			2			1.7			0.37			0.17898			0.6		
08/27/20 9:00	0.8			1			1.7			0.4			0.19824			0.66		
08/27/20 10:00	0.9			1			1.7			0.49			0.24066			0.8		
08/27/20 11:00	1.2			2			1.7			0.56			0.2643			0.88		
08/27/20 12:00	1			2			1.7			0.56			0.2643			0.88		
08/27/20 13:00	0.4			2			1.7			0.65			0.31128			1.04		
08/27/20 14:00	0.4			2			1.7			0.65			0.3111			1.04		
08/27/20 15:00	0.5			2			1.7			0.63			0.29988			1		
08/27/20 16:00	0.3			2			1.7			0.66			0.3165			1.06		
08/27/20 17:00	0.2			3			1.7			0.67			0.32154			1.07		
08/27/20 18:00	0.6			2			1.7			0.6			0.28686			0.96		
08/27/20 19:00	1.1			2			1.7			0.55			0.26112			0.87		
08/27/20 20:00	0.8			1			1.7			0.47			0.22494			0.75		
08/27/20 21:00	0.8			1			1.7			0.47			0.22992			0.77		
08/27/20 22:00	0.9			1			1.7			0.39			0.19236			0.64		
08/27/20 23:00	0.9			1			1.7			0.36			0.1827			0.61		
08/28/20 0:00	0.8			1			1.7			0.35			0.1677			0.56		
08/28/20 1:00	0.7			1			1.7			0.35			0.16716			0.56		
08/28/20 2:00	0.8			1			1.7			0.35			0.16722			0.56		
08/28/20 3:00	0.8			1			1.7			0.35			0.16752			0.56		
08/28/20 4:00	0.8			1			1.7			0.35			0.16746			0.56		
08/28/20 5:00	0.8			1			1.7			0.35			0.16776			0.56		
08/28/20 6:00	0.8			1			1.7			0.36			0.16824			0.56		
08/28/20 7:00	0.9			2			1.7			0.37			0.17982			0.6		
08/28/20 8:00	0.9			1			1.7			0.4			0.2022			0.67		
08/28/20 9:00	0.8			1			1.7			0.45			0.23052			0.77		
08/28/20 10:00	1			1			1.7			0.5			0.23904			0.8		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/28/20 11:00	0.5			2			1.7			0.64			0.3042			1.01		
08/28/20 12:00	0.2			3			1.7			0.74			0.3549			1.18		
08/28/20 13:00	0.2			3			1.7			0.74			0.35322			1.18		
08/28/20 14:00	0.3			2			1.7			0.66			0.3177			1.06		
08/28/20 15:00	0.3			3			1.7			0.67			0.3222			1.07		
08/28/20 16:00	0.2			3			1.7			0.73			0.35232			1.17		
08/28/20 17:00	0.2			3			1.7			0.71			0.34122			1.14		
08/28/20 18:00	0.7			2			1.7			0.59			0.28134			0.94		
08/28/20 19:00	0.9			1			1.7			0.5			0.23754			0.79		
08/28/20 20:00	0.8			1			1.7			0.49			0.23718			0.79		
08/28/20 21:00	0.8			1			1.7			0.5			0.23856			0.8		
08/28/20 22:00	0.8			1			1.7			0.47			0.2298			0.77		
08/28/20 23:00	0.8			1			1.7			0.41			0.2046			0.68		
08/29/20 0:00	0.8			1			1.7			0.36			0.17628			0.59		
08/29/20 1:00	0.7			1			1.7			0.35			0.16794			0.56		
08/29/20 2:00	0.7			1			1.7			0.36			0.16752			0.56		
08/29/20 3:00	0.7			1			1.7			0.35			0.16746			0.56		
08/29/20 4:00	0.7			1			1.7			0.35			0.16752			0.56		
08/29/20 5:00	0.7			1			1.7			0.35			0.16776			0.56		
08/29/20 6:00	0.7			1			1.7			0.36			0.16776			0.56		
08/29/20 7:00	0.7			2			1.7			0.36			0.16812			0.56		
08/29/20 8:00	0.9			2			1.7			0.38			0.18108			0.6		
08/29/20 9:00	0.8			1			1.7			0.42			0.20724			0.69		
08/29/20 10:00	0.8			1			1.7			0.43			0.2187			0.73		
08/29/20 11:00	0.9			1			1.7			0.5			0.2385			0.8		
08/29/20 12:00	0.7			2			1.7			0.61			0.28812			0.96		
08/29/20 13:00	0.2			3			1.7			0.72			0.34614			1.15		
08/29/20 14:00	0.2			3			1.7			0.69			0.32796			1.09		
08/29/20 15:00	0.2			3			1.7			0.73			0.34956			1.17		
08/29/20 16:00	0.3			2			1.7			0.64			0.3078			1.03		
08/29/20 17:00	0.6			2			1.7			0.58			0.27924			0.93		
08/29/20 18:00	1			1			1.7			0.49			0.23292			0.78		
08/29/20 19:00	0.8			1			1.7			0.43			0.20946			0.7		
08/29/20 20:00	0.8			1			1.7			0.44			0.22212			0.74		
08/29/20 21:00	0.7			1			1.7			0.48			0.23952			0.8		
08/29/20 22:00	0.8			1			1.7			0.41			0.20742			0.69		
08/29/20 23:00	0.8			1			1.7			0.37			0.19386			0.65		
08/30/20 0:00	0.7			1			1.7			0.36			0.168			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 1:00	0.7			1			1.7			0.36			0.16752			0.56		
08/30/20 2:00	0.7			1			1.7			0.36			0.16764			0.56		
08/30/20 3:00	0.7			2			1.7			0.35			0.16776			0.56		
08/30/20 4:00	0.7			1			1.7			0.35			0.16782			0.56		
08/30/20 5:00	0.7			1			1.7			0.35			0.16788			0.56		
08/30/20 6:00	0.7			2			1.7			0.36			0.16812			0.56		
08/30/20 7:00	0.7			2			1.7			0.36			0.16818			0.56		
08/30/20 8:00	0.8			1			1.7			0.36			0.16794			0.56		
08/30/20 9:00	0.8			1			1.7			0.37			0.17718			0.59		
08/30/20 10:00	0.8			1			1.7			0.42			0.20598			0.69		
08/30/20 11:00	0.9			1			1.7			0.48			0.23694			0.79		
08/30/20 12:00	0.7			2			1.7			0.6			0.28566			0.95		
08/30/20 13:00	0.3			3			1.7			0.71			0.34176			1.14		
08/30/20 14:00	0.2			3			1.7			0.74			0.35286			1.18		
08/30/20 15:00	0.2			3			1.7			0.7			0.33282			1.11		
08/30/20 16:00	0.4			2			1.7			0.63			0.30138			1		
08/30/20 17:00	0.4			2			1.7			0.63			0.29874			1		
08/30/20 18:00	0.8			1			1.8			0.5			0.23598			0.79		
08/30/20 19:00	0.8			1			1.7			0.45			0.21462			0.72		
08/30/20 20:00	0.9			1			1.7			0.4			0.1974			0.66		
08/30/20 21:00	0.8			1			1.7			0.49			0.23532			0.78		
08/30/20 22:00	0.9			1			1.7			0.41			0.17844			0.59		
08/30/20 23:00	0			0	X		0			0.67			0.0717			0.24		
08/31/20 0:00	0	X		0	X		0	X		0.71			0	X		0	X	
08/31/20 1:00	0	X		0	X		0	X		0.65			0	X		0	X	
08/31/20 2:00	0	X		0	X		0	X		0.59			0	X		0	X	
08/31/20 3:00	0	X		0	X		0	X		0.59			0	X		0	X	
08/31/20 4:00	0	X		0	X		0	X		0.64			0	X		0	X	
08/31/20 5:00	0	X		0	X		0	X		0.6			0	X		0	X	
08/31/20 6:00	0	X		0	X		0	X		0.65			0	X		0	X	
08/31/20 7:00	0	X		0	X		0	X		0.67			0	X		0	X	
08/31/20 8:00	0	X		0	X		0	X		0.7			0	X		0	X	
08/31/20 9:00	0	X		0	X		0	X		0.65			0	X		0	X	
08/31/20 10:00	0	X		0	X		0	X		0.65			0	X		0	X	
08/31/20 11:00	0	X		0	X		0	X		0.68			0	X		0	X	
08/31/20 12:00	0	X		0	X		0	X		0.72			0	X		0	X	
08/31/20 13:00	0	X		0	X		0	X		0.71			0	X		0	X	
08/31/20 14:00	0			0	X		0			0.65			0.087			0.29		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:00	0.8			0			1.4			0.54			0.22074			0.74		
08/31/20 16:00	0.7			2			1.7			0.6			0.28518			0.95		
08/31/20 17:00	0.4			2			1.7			0.64			0.306			1.02		
08/31/20 18:00	0.6			2			1.7			0.61			0.29088			0.97		
08/31/20 19:00	0.7			2			1.7			0.59			0.28278			0.94		
08/31/20 20:00	0.9			1			1.7			0.38			0.18006			0.6		
08/31/20 21:00	0.8			1			1.6			0.49			0.23448			0.78		
08/31/20 22:00	0.9			1			1.7			0.42			0.2037			0.68		
08/31/20 23:00	0.9			1			1.7			0.41			0.20382			0.68		
09/01/20 0:00	0.9			1			1.7			0.36			0.19188			0.64		
09/01/20 1:00	0.8			2			1.7			0.36			0.1725			0.58		
09/01/20 2:00	0.7			1			1.7			0.36			0.16764			0.56		
09/01/20 3:00	0.7			2			1.7			0.36			0.1677			0.56		
09/01/20 4:00	0.8			1			1.7			0.36			0.16944			0.56		
09/01/20 5:00	0.8			1			1.7			0.42			0.2052			0.68		
09/01/20 6:00	0.8			1			1.7			0.44			0.21522			0.72		
09/01/20 7:00	0.8			1			1.7			0.47			0.2367			0.79		
09/01/20 8:00	0.8			1			1.7			0.51			0.24384			0.81		
09/01/20 9:00	0.8			1			1.7			0.51			0.24168			0.81		
09/01/20 10:00	0.8			1			1.7			0.5			0.23832			0.79		
09/01/20 11:00	1.5			2			1.6			0.54			0.2538			0.85		
09/01/20 12:00	0.2			3			1.7			0.71			0.3408			1.14		
09/01/20 13:00	0.2			3			1.7			0.71			0.34308			1.14		
09/01/20 14:00	0.2			3			1.7			0.73			0.3507			1.17		
09/01/20 15:00	0.2			3			1.7			0.73			0.35184			1.17		
09/01/20 16:00	0.2			3			1.7			0.73			0.34926			1.16		
09/01/20 17:00	0.3			3			1.7			0.68			0.32748			1.09		
09/01/20 18:00	0.4			2			1.7			0.65			0.31164			1.04		
09/01/20 19:00	0.5			2			1.7			0.63			0.29988			1		
09/01/20 20:00	0.4			2			1.7			0.66			0.31662			1.06		
09/01/20 21:00	1.1			2			1.7			0.52			0.24816			0.83		
09/01/20 22:00	0.8			1			1.7			0.41			0.19764			0.66		
09/01/20 23:00	0.8			1			1.7			0.42			0.20484			0.68		
09/02/20 0:00	0.8			1			1.7			0.42			0.20994			0.7		
09/02/20 1:00	0.8			1			1.7			0.39			0.20352			0.68		
09/02/20 2:00	0.8			1			1.7			0.37			0.20046			0.67		
09/02/20 3:00	0.8			1			1.7			0.37			0.2064			0.69		
09/02/20 4:00	0.8			1			1.7			0.37			0.21378			0.71		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/02/20 5:00	0.9			1			1.7			0.38			0.20544			0.68		
09/02/20 6:00	0.8			1			1.7			0.42			0.2034			0.68		
09/02/20 7:00	0.7			1			1.7			0.45			0.2232			0.74		
09/02/20 8:00	0.7			1			1.7			0.47			0.24372			0.81		
09/02/20 9:00	0.8			1			1.7			0.45			0.22434			0.75		
09/02/20 10:00	0.7			1			1.7			0.45			0.22188			0.74		
09/02/20 11:00	0.7			1			1.7			0.43			0.2145			0.72		
09/02/20 12:00	0.7			1			1.7			0.42			0.22014			0.73		
09/02/20 13:00	1.3			2			1.7			0.52			0.24972			0.83		
09/02/20 14:00	0.3			2			1.7			0.66			0.31614			1.05		
09/02/20 15:00	0.3			2			1.7			0.66			0.3168			1.06		
09/02/20 16:00	0.2			2			1.7			0.66			0.31686			1.06		
09/02/20 17:00	0.2			2			1.7			0.66			0.31692			1.06		
09/02/20 18:00	0.5			2			1.7			0.62			0.2952			0.98		
09/02/20 19:00	1			2			1.7			0.54			0.25896			0.86		
09/02/20 20:00	0.7			1			1.7			0.47			0.22626			0.75		
09/02/20 21:00	0.9			2			1.7			0.55			0.26742			0.89		
09/02/20 22:00	0.7			1			1.7			0.49			0.23742			0.79		
09/02/20 23:00	0.7			1			1.7			0.43			0.2154			0.72		
09/03/20 0:00	0.7			1			1.7			0.39			0.2049			0.68		
09/03/20 1:00	0.7			1			1.7			0.36			0.2013			0.67		
09/03/20 2:00	0.8			1			1.7			0.36			0.19548			0.65		
09/03/20 3:00	0.8			1			1.7			0.36			0.19908			0.66		
09/03/20 4:00	0.7			1			1.7			0.37			0.20874			0.7		
09/03/20 5:00	0.7			1			1.7			0.36			0.21216			0.71		
09/03/20 6:00	0.7			1			1.7			0.36			0.21522			0.72		
09/03/20 7:00	0.7			1			1.7			0.36			0.21552			0.72		
09/03/20 8:00	0.8			1			1.7			0.43			0.20472			0.68		
09/03/20 9:00	0.7			1			1.7			0.42			0.20874			0.7		
09/03/20 10:00	0.7			1			1.7			0.46			0.23118			0.77		
09/03/20 11:00	1.1			1			1.7			0.51			0.24216			0.81		
09/03/20 12:00	0.2			2			1.7			0.68			0.32442			1.08		
09/03/20 13:00	0.1			3			1.7			0.74			0.35442			1.18		
09/03/20 14:00	0.1			3			1.7			0.74			0.3534			1.18		
09/03/20 15:00	0.1			3			1.7			0.74			0.35334			1.18		
09/03/20 16:00	0.1			3			1.7			0.73			0.35166			1.17		
09/03/20 17:00	0.1			3			1.7			0.73			0.35196			1.17		
09/03/20 18:00	0.1			3			1.7			0.73			0.35244			1.17		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/03/20 19:00	0.1			3			1.7			0.71			0.34038			1.13		
09/03/20 20:00	0.2			3			1.7			0.7			0.33444			1.11		
09/03/20 21:00	0.2			3			1.7			0.68			0.327			1.09		
09/03/20 22:00	1.2			2			1.7			0.53			0.2505			0.84		
09/03/20 23:00	0.7			1			1.7			0.46			0.21312			0.71		
09/04/20 0:00	0.7			1			1.7			0.43			0.20388			0.68		
09/04/20 1:00	0.8			1			1.7			0.4			0.19722			0.66		
09/04/20 2:00	0.7			1			1.7			0.39			0.19992			0.67		
09/04/20 3:00	0.8			1			1.7			0.38			0.20472			0.68		
09/04/20 4:00	0.7			1			1.6			0.39			0.2136			0.71		
09/04/20 5:00	0.8			1			1.7			0.4			0.20286			0.68		
09/04/20 6:00	0.8			1			1.7			0.39			0.19734			0.66		
09/04/20 7:00	0.8			1			1.7			0.39			0.20202			0.67		
09/04/20 8:00	0.7			1			1.7			0.41			0.22008			0.73		
09/04/20 9:00	0.7			1			1.7			0.41			0.22554			0.75		
09/04/20 10:00	0.7			1			1.7			0.45			0.23946			0.8		
09/04/20 11:00	1.1			2			1.7			0.56			0.2673			0.89		
09/04/20 12:00	0.3			2			1.7			0.65			0.30948			1.03		
09/04/20 13:00	0.2			3			1.7			0.73			0.35166			1.17		
09/04/20 14:00	0.2			3			1.7			0.73			0.3525			1.18		
09/04/20 15:00	0.1			3			1.7			0.73			0.35214			1.17		
09/04/20 16:00	0.1			3			1.7			0.73			0.35124			1.17		
09/04/20 17:00	0.1			3			1.7			0.73			0.35142			1.17		
09/04/20 18:00	0.2			3			1.7			0.73			0.35214			1.17		
09/04/20 19:00	0.1			3			1.7			0.73			0.3531			1.18		
09/04/20 20:00	0.1			3			1.7			0.73			0.35376			1.18		
09/04/20 21:00	0.1			3			1.7			0.72			0.34788			1.16		
09/04/20 22:00	0.5			2			1.7			0.62			0.29724			0.99		
09/04/20 23:00	0.8			1			1.7			0.4			0.20076			0.67		
09/05/20 0:00	0.8			1			1.7			0.37			0.19314			0.64		
09/05/20 1:00	0.8			1			1.7			0.36			0.1974			0.66		
09/05/20 2:00	0.8			1			1.7			0.36			0.19728			0.66		
09/05/20 3:00	1			2			1.7			0.36			0.18342			0.61		
09/05/20 4:00	1.1			1			1.6			0.36			0.18168			0.61		
09/05/20 5:00	1			1			1.7			0.36			0.16926			0.56		
09/05/20 6:00	1			1			1.7			0.36			0.16932			0.56		
09/05/20 7:00	1			1			1.7			0.36			0.17106			0.57		
09/05/20 8:00	0.9			1			1.7			0.39			0.18858			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/20 9:00	0.8			1			1.7			0.46			0.22632			0.75		
09/05/20 10:00	1.1			1			1.6			0.56			0.26766			0.89		
09/05/20 11:00	0.2			2			1.7			0.67			0.31782			1.06		
09/05/20 12:00	0.1			3			1.7			0.71			0.34218			1.14		
09/05/20 13:00	0.1			3			1.7			0.73			0.3507			1.17		
09/05/20 14:00	0.1			3			1.7			0.73			0.35034			1.17		
09/05/20 15:00	0.1			3			1.7			0.73			0.35076			1.17		
09/05/20 16:00	0.1			3			1.7			0.72			0.34998			1.17		
09/05/20 17:00	0.1			3			1.7			0.72			0.34716			1.16		
09/05/20 18:00	0.3			2			1.7			0.64			0.30864			1.03		
09/05/20 19:00	0.2			2			1.7			0.68			0.32478			1.08		
09/05/20 20:00	0.2			3			1.7			0.73			0.35028			1.17		
09/05/20 21:00	0.2			2			1.7			0.68			0.3234			1.08		
09/05/20 22:00	1.3			2			1.7			0.54			0.2553			0.85		
09/05/20 23:00	0.9			1			1.7			0.46			0.222			0.74		
09/06/20 0:00	1			1			1.7			0.41			0.2052			0.68		
09/06/20 1:00	1.3			1			1.7			0.37			0.19116			0.64		
09/06/20 2:00	1			1			1.7			0.36			0.16908			0.56		
09/06/20 3:00	1			1			1.7			0.36			0.16914			0.56		
09/06/20 4:00	1			1			1.7			0.36			0.1692			0.56		
09/06/20 5:00	0.9			1			1.8			0.36			0.17022			0.57		
09/06/20 6:00	1			1			1.7			0.37			0.17898			0.6		
09/06/20 7:00	1			1			1.7			0.37			0.18378			0.61		
09/06/20 8:00	0.9			1			1.7			0.39			0.20262			0.68		
09/06/20 9:00	0.8			1			1.7			0.46			0.2364			0.79		
09/06/20 10:00	0.8			1			1.7			0.49			0.2328			0.78		
09/06/20 11:00	0.8			1			1.7			0.44			0.21366			0.71		
09/06/20 12:00	0.8			2			1.6			0.58			0.27354			0.91		
09/06/20 13:00	0.3			2			1.7			0.65			0.31182			1.04		
09/06/20 14:00	0.1			3			1.7			0.7			0.33768			1.13		
09/06/20 15:00	0.1			3			1.7			0.72			0.34848			1.16		
09/06/20 16:00	0.1			3			1.7			0.72			0.34812			1.16		
09/06/20 17:00	0.1			3			1.7			0.72			0.34746			1.16		
09/06/20 18:00	0.1			3			1.7			0.72			0.34416			1.15		
09/06/20 19:00	0.2			3			1.7			0.69			0.33174			1.11		
09/06/20 20:00	0.2			3			1.7			0.7			0.33546			1.12		
09/06/20 21:00	0.2			3			1.7			0.72			0.34614			1.15		
09/06/20 22:00	0.5			2			1.7			0.62			0.29748			0.99		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/06/20 23:00	0.9			1			1.7			0.49			0.23622			0.79		
09/07/20 0:00	0.8			1			1.7			0.43			0.21102			0.7		
09/07/20 1:00	1.1			1			1.7			0.38			0.19302			0.64		
09/07/20 2:00	0.9			2			1.7			0.36			0.17544			0.58		
09/07/20 3:00	0.9			2			1.7			0.36			0.17376			0.58		
09/07/20 4:00	0.9			1			1.7			0.36			0.16872			0.56		
09/07/20 5:00	0.9			1			1.7			0.36			0.16866			0.56		
09/07/20 6:00	1			1			1.7			0.36			0.16926			0.56		
09/07/20 7:00	1.3			1			1.7			0.38			0.18432			0.61		
09/07/20 8:00	0.9			1			1.7			0.45			0.22008			0.73		
09/07/20 9:00	0.8			2			1.6			0.59			0.27636			0.92		
09/07/20 10:00	0.2			3			1.7			0.72			0.34788			1.16		
09/07/20 11:00	0.1			3			1.7			0.71			0.3384			1.13		
09/07/20 12:00	0.5			2			1.7			0.61			0.29028			0.97		
09/07/20 13:00	0.1			3			1.7			0.72			0.34344			1.14		
09/07/20 14:00	0.4			2			1.7			0.61			0.29352			0.98		
09/07/20 15:00	0.6			2			1.7			0.58			0.27708			0.92		
09/07/20 16:00	0.2			2			1.7			0.65			0.312			1.04		
09/07/20 17:00	0.6			2			1.7			0.58			0.27672			0.92		
09/07/20 18:00	1.1			2			1.7			0.52			0.24744			0.82		
09/07/20 19:00	1.7			1			1.7			0.49			0.23388			0.78		
09/07/20 20:00	1.8			1			1.7			0.52			0.24852			0.83		
09/07/20 21:00	0.5			2			1.7			0.62			0.29754			0.99		
09/07/20 22:00	0.8			1			1.8			0.5			0.23634			0.79		
09/07/20 23:00	0.7			1			1.7			0.46			0.2199			0.73		
09/08/20 0:00	0.8			1			1.7			0.39			0.19668			0.66		
09/08/20 1:00	0.9			1			1.7			0.43			0.22302			0.74		
09/08/20 2:00	0.9			1			1.7			0.43			0.2289			0.76		
09/08/20 3:00	0.9			1			1.7			0.38			0.20718			0.69		
09/08/20 4:00	0.8			1			1.7			0.37			0.21144			0.7		
09/08/20 5:00	0.8			1			1.7			0.44			0.22266			0.74		
09/08/20 6:00	0.7			1			1.7			0.49			0.24318			0.81		
09/08/20 7:00	1			2			1.7			0.57			0.27228			0.91		
09/08/20 8:00	0.6			2			1.7			0.62			0.29664			0.99		
09/08/20 9:00	0.3			2			1.7			0.68			0.32382			1.08		
09/08/20 10:00	0.7			2			1.7			0.59			0.28176			0.94		
09/08/20 11:00	0.7			1			1.8			0.48			0.2298			0.77		
09/08/20 12:00	0.7			1			1.7			0.47			0.2322			0.77		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/08/20 13:00	0.8			1			1.7			0.47			0.23706			0.79		
09/08/20 14:00	0.8			1			1.7			0.38			0.20184			0.67		
09/08/20 15:00	0.7			1			1.7			0.36			0.16848			0.56		
09/08/20 16:00	0.7			2			1.7			0.36			0.1677			0.56		
09/08/20 17:00	0.8			2			1.7			0.36			0.16806			0.56		
09/08/20 18:00	0.8			2			1.7			0.37			0.177			0.59		
09/08/20 19:00	0.8			1			1.7			0.37			0.18786			0.63		
09/08/20 20:00	0.8			2			1.7			0.36			0.1734			0.58		
09/08/20 21:00	0.7			1			1.7			0.5			0.23622			0.79		
09/08/20 22:00	0.9			1			1.7			0.45			0.22002			0.73		
09/08/20 23:00	0.9			1			1.7			0.37			0.17478			0.58		
09/09/20 0:00	0.8			2			1.7			0.36			0.16848			0.56		
09/09/20 1:00	0.9			2			1.7			0.36			0.1686			0.56		
09/09/20 2:00	1			2			1.7			0.36			0.16896			0.56		
09/09/20 3:00	0.9			2			1.7			0.36			0.16896			0.56		
09/09/20 4:00	0.9			1			1.7			0.36			0.16902			0.56		
09/09/20 5:00	0.9			2			1.7			0.36			0.17028			0.57		
09/09/20 6:00	0.9			1			1.7			0.44			0.21036			0.7		
09/09/20 7:00	0.5			3			1.6			0.76			0.36228			1.21		
09/09/20 8:00	0.2			4			1.7			0.78			0.37152			1.24		
09/09/20 9:00	0.2			3			1.7			0.75			0.3675			1.23		
09/09/20 10:00	0.1			3			1.7			0.76			0.36498			1.22		
09/09/20 11:00	0.1			4			1.7			0.76			0.36444			1.21		
09/09/20 12:00	0.1			4			1.7			0.76			0.36336			1.21		
09/09/20 13:00	0.1			3			1.7			0.76			0.3624			1.21		
09/09/20 14:00	0.1			4			1.7			0.76			0.36246			1.21		
09/09/20 15:00	0.2			4			1.7			0.76			0.36276			1.21		
09/09/20 16:00	0.1			3			1.7			0.73			0.35916			1.2		
09/09/20 17:00	0.8			1			1.8			0.43			0.21534			0.72		
09/09/20 18:00	0.7			1			1.7			0.41			0.21372			0.71		
09/09/20 19:00	0.7			1			1.7			0.44			0.23022			0.77		
09/09/20 20:00	0.8			1			1.7			0.36			0.20028			0.67		
09/09/20 21:00	0.9			2			1.7			0.36			0.18558			0.62		
09/09/20 22:00	0.9			1			1.7			0.37			0.19476			0.65		
09/09/20 23:00	0.9			1			1.7			0.37			0.1983			0.66		
09/10/20 0:00	0.7			2			1.7			0.36			0.1734			0.58		
09/10/20 1:00	0.7			1			1.7			0.36			0.17418			0.58		
09/10/20 2:00	0.7			2			1.7			0.36			0.1704			0.57		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/10/20 3:00	0.7			2			1.7			0.36			0.1704			0.57		
09/10/20 4:00	0.8			1			1.7			0.37			0.17718			0.59		
09/10/20 5:00	0.8			1			1.7			0.36			0.17034			0.57		
09/10/20 6:00	1.2			2			1.7			0.36			0.17136			0.57		
09/10/20 7:00	1			2			1.7			0.37			0.1785			0.6		
09/10/20 8:00	0.8			2			1.7			0.36			0.17004			0.57		
09/10/20 9:00	0.9			1			1.7			0.39			0.18912			0.63		
09/10/20 10:00	0.9			1			1.7			0.4			0.19908			0.66		
09/10/20 11:00	0.8			1			1.7			0.47			0.24126			0.8		
09/10/20 12:00	0.8			1			1.7			0.47			0.23934			0.8		
09/10/20 13:00	1.4			1			1.7			0.52			0.25428			0.85		
09/10/20 14:00	1			1			1.7			0.5			0.24588			0.82		
09/10/20 15:00	1.7			1			1.7			0.52			0.2469			0.82		
09/10/20 16:00	0.9			1			1.7			0.5			0.24192			0.81		
09/10/20 17:00	2			1			1.7			0.53			0.25056			0.84		
09/10/20 18:00	1.1			1			1.7			0.49			0.2364			0.79		
09/10/20 19:00	0.5			2			1.7			0.67			0.31842			1.06		
09/10/20 20:00	1.2			2			1.7			0.56			0.2637			0.88		
09/10/20 21:00	1.3			1			1.7			0.53			0.25032			0.83		
09/10/20 22:00	0.8			1			1.7			0.48			0.21948			0.73		
09/10/20 23:00	0.9			1			1.7			0.41			0.19254			0.64		
09/11/20 0:00	0.9			1			1.7			0.4			0.19392			0.65		
09/11/20 1:00	1			1			1.7			0.36			0.18138			0.6		
09/11/20 2:00	0.8			1			1.7			0.36			0.16992			0.57		
09/11/20 3:00	0.8			1			1.7			0.36			0.17094			0.57		
09/11/20 4:00	1.1			1			1.6			0.4			0.19494			0.65		
09/11/20 5:00	1			2			1.7			0.36			0.17136			0.57		
09/11/20 6:00	1			2			1.7			0.36			0.1701			0.57		
09/11/20 7:00	1			1			1.7			0.37			0.17832			0.59		
09/11/20 8:00	1.1			1			1.7			0.4			0.19674			0.66		
09/11/20 9:00	0.9			1			1.7			0.46			0.23232			0.77		
09/11/20 10:00	0.8			1			1.7			0.49			0.24162			0.81		
09/11/20 11:00	0.9			1			1.7			0.5			0.24522			0.82		
09/11/20 12:00	1.6			1			1.7			0.53			0.25656			0.86		
09/11/20 13:00	1.2			2			1.7			0.58			0.27468			0.92		
09/11/20 14:00	0.6			2			1.7			0.63			0.30102			1		
09/11/20 15:00	1.1			1			1.8			0.43			0.22854			0.76		
09/11/20 16:00	1			1			1.7			0.43			0.22722			0.76		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/11/20 17:00	0.9			1			1.7			0.5			0.24288			0.81		
09/11/20 18:00	0.9			1			1.7			0.48			0.23142			0.77		
09/11/20 19:00	1			1			1.7			0.38			0.18744			0.62		
09/11/20 20:00	1			1			1.7			0.46			0.22272			0.74		
09/11/20 21:00	1			1			1.7			0.5			0.24612			0.82		
09/11/20 22:00	1.2			1			1.7			0.45			0.22452			0.75		
09/11/20 23:00	1.2			1			1.7			0.43			0.22656			0.76		
09/12/20 0:00	1.4			1			1.7			0.36			0.19746			0.66		
09/12/20 1:00	1.1			2			1.7			0.36			0.17064			0.57		
09/12/20 2:00	1.1			2			1.7			0.36			0.17058			0.57		
09/12/20 3:00	1.4			2			1.7			0.36			0.17058			0.57		
09/12/20 4:00	1.8			2			1.7			0.36			0.17058			0.57		
09/12/20 5:00	1.6			1			1.7			0.36			0.17166			0.57		
09/12/20 6:00	1.6			1			1.7			0.36			0.17826			0.59		
09/12/20 7:00	1.4			1			1.7			0.36			0.17436			0.58		
09/12/20 8:00	1.2			1			1.7			0.37			0.1836			0.61		
09/12/20 9:00	0.9			1			1.7			0.39			0.19728			0.66		
09/12/20 10:00	0.8			1			1.7			0.42			0.21828			0.73		
09/12/20 11:00	0.9			1			1.7			0.44			0.23436			0.78		
09/12/20 12:00	1.1			1			1.7			0.5			0.24132			0.8		
09/12/20 13:00	0.5			2			1.7			0.66			0.31566			1.05		
09/12/20 14:00	0.2			3			1.7			0.71			0.34362			1.15		
09/12/20 15:00	1.1			2			1.7			0.55			0.26082			0.87		
09/12/20 16:00	1.1			2			1.7			0.56			0.26838			0.89		
09/12/20 17:00	0.3			2			1.7			0.69			0.33258			1.11		
09/12/20 18:00	0.9			1			1.7			0.5			0.23922			0.8		
09/12/20 19:00	0.9			1			1.7			0.45			0.2205			0.74		
09/12/20 20:00	1			1			1.7			0.43			0.2172			0.72		
09/12/20 21:00	1.6			1			1.7			0.51			0.24282			0.81		
09/12/20 22:00	1.2			1			1.7			0.46			0.2211			0.74		
09/12/20 23:00	1.1			1			1.7			0.44			0.21342			0.71		
09/13/20 0:00	1.2			1			1.7			0.38			0.19572			0.65		
09/13/20 1:00	1.2			1			1.7			0.36			0.18096			0.6		
09/13/20 2:00	1			1			1.7			0.36			0.17178			0.57		
09/13/20 3:00	1.1			1			1.7			0.36			0.17196			0.57		
09/13/20 4:00	1.1			1			1.7			0.36			0.1719			0.57		
09/13/20 5:00	1.2			1			1.7			0.36			0.17076			0.57		
09/13/20 6:00	1.1			1			1.7			0.36			0.1704			0.57		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/13/20 7:00	1.1			1			1.7			0.36			0.1713			0.57		
09/13/20 8:00	1.2			1			1.7			0.39			0.19116			0.64		
09/13/20 9:00	1			1			1.7			0.44			0.21666			0.72		
09/13/20 10:00	1			1			1.7			0.5			0.23664			0.79		
09/13/20 11:00	1.3			1			1.7			0.56			0.26646			0.89		
09/13/20 12:00	0.9			2			1.7			0.59			0.27822			0.93		
09/13/20 13:00	0.5			3			0.8			0.64			0.3063			1.02		
09/13/20 14:00	0.3			2			1.7			0.67			0.3207			1.07		
09/13/20 15:00	0.4			2			1.7			0.64			0.30462			1.02		
09/13/20 16:00	1.4			2			1.7			0.53			0.25194			0.84		
09/13/20 17:00	1.2			1			1.7			0.54			0.25734			0.86		
09/13/20 18:00	1.2			1			1.7			0.54			0.25512			0.85		
09/13/20 19:00	1			1			1.7			0.43			0.20868			0.7		
09/13/20 20:00	0.8			2			1.6			0.58			0.27792			0.93		
09/13/20 21:00	1.3			2			1.7			0.54			0.25974			0.87		
09/13/20 22:00	1.1			1			1.7			0.48			0.23202			0.77		
09/13/20 23:00	1			1			1.7			0.4			0.19872			0.66		
09/14/20 0:00	1			1			1.7			0.36			0.1812			0.6		
09/14/20 1:00	0.8			1			1.7			0.36			0.1701			0.57		
09/14/20 2:00	0.8			1			1.7			0.36			0.17016			0.57		
09/14/20 3:00	0.8			1			1.7			0.36			0.17028			0.57		
09/14/20 4:00	0.9			1			1.7			0.36			0.17118			0.57		
09/14/20 5:00	0.9			1			1.7			0.36			0.17076			0.57		
09/14/20 6:00	0.9			1			1.7			0.36			0.17328			0.58		
09/14/20 7:00	1			1			1.7			0.38			0.1866			0.62		
09/14/20 8:00	1			1			1.7			0.41			0.20748			0.69		
09/14/20 9:00	0.9			1			1.7			0.43			0.22344			0.74		
09/14/20 10:00	1			1			1.7			0.45			0.23616			0.79		
09/14/20 11:00	1			1			1.7			0.51			0.24246			0.81		
09/14/20 12:00	1			1			1.7			0.57			0.27408			0.91		
09/14/20 13:00	0.3			2			1.7			0.68			0.32766			1.09		
09/14/20 14:00	0.2			3			1.7			0.74			0.3561			1.19		
09/14/20 15:00	0.3			2			1.7			0.67			0.32208			1.07		
09/14/20 16:00	0.2			3			1.7			0.71			0.3432			1.14		
09/14/20 17:00	0.2			3			1.7			0.74			0.35688			1.19		
09/14/20 18:00	0.3			3			1.7			0.69			0.33276			1.11		
09/14/20 19:00	0.9			1			1.7			0.46			0.21954			0.73		
09/14/20 20:00	1			1			1.7			0.47			0.22728			0.76		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/14/20 21:00	1.3			1			1.7			0.52			0.2505			0.84		
09/14/20 22:00	0.9			1			1.7			0.47			0.2274			0.76		
09/14/20 23:00	0.9			1			1.7			0.39			0.19992			0.67		
09/15/20 0:00	1			1			1.7			0.36			0.18894			0.63		
09/15/20 1:00	1			1			1.7			0.36			0.17868			0.6		
09/15/20 2:00	0.8			1			1.7			0.36			0.17046			0.57		
09/15/20 3:00	0.8			1			1.7			0.36			0.17046			0.57		
09/15/20 4:00	0.9			1			1.6			0.36			0.17376			0.58		
09/15/20 5:00	1			1			1.7			0.37			0.1842			0.61		
09/15/20 6:00	1			1			1.7			0.36			0.18654			0.62		
09/15/20 7:00	1			1			1.7			0.38			0.19986			0.67		
09/15/20 8:00	0.9			1			1.7			0.42			0.22296			0.74		
09/15/20 9:00	0.9			1			1.7			0.46			0.23832			0.79		
09/15/20 10:00	0.9			1			1.7			0.51			0.24246			0.81		
09/15/20 11:00	1.7			1			1.7			0.55			0.25728			0.86		
09/15/20 12:00	0.4			2			1.7			0.66			0.31602			1.05		
09/15/20 13:00	0.2			3			1.7			0.73			0.34998			1.17		
09/15/20 14:00	0.2			3			1.7			0.74			0.35544			1.18		
09/15/20 15:00	0.2			3			1.7			0.73			0.34968			1.17		
09/15/20 16:00	0.3			2			1.7			0.69			0.33186			1.11		
09/15/20 17:00	0.2			2			1.7			0.69			0.33264			1.11		
09/15/20 18:00	0.6			2			1.7			0.61			0.29286			0.98		
09/15/20 19:00	1			2			1.7			0.52			0.24918			0.83		
09/15/20 20:00	0.8			1			1.7			0.45			0.21504			0.72		
09/15/20 21:00	0.8			1			1.7			0.5			0.23946			0.8		
09/15/20 22:00	0.8			1			1.7			0.44			0.21492			0.72		
09/15/20 23:00	0.8			1			1.7			0.42			0.21174			0.71		
09/16/20 0:00	0.9			1			1.7			0.39			0.20526			0.68		
09/16/20 1:00	0.8			1			1.7			0.36			0.2016			0.67		
09/16/20 2:00	0.8			1			1.7			0.36			0.19356			0.65		
09/16/20 3:00	0.9			1			1.7			0.36			0.19272			0.64		
09/16/20 4:00	0.9			1			1.6			0.4			0.19362			0.65		
09/16/20 5:00	0.8			1			1.7			0.4			0.20508			0.68		
09/16/20 6:00	0.8			1			1.7			0.4			0.21354			0.71		
09/16/20 7:00	0.8			1			1.7			0.42			0.22902			0.76		
09/16/20 8:00	0.8			1			1.7			0.46			0.24054			0.8		
09/16/20 9:00	1			1			1.7			0.5			0.24156			0.81		
09/16/20 10:00	1.2			2			1.7			0.56			0.26304			0.88		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/20 11:00	0.5			2			1.7			0.64			0.30594			1.02		
09/16/20 12:00	0.2			3			1.5			0.71			0.34104			1.14		
09/16/20 13:00	0.3			2			1.7			0.69			0.32958			1.1		
09/16/20 14:00	0.2			3			1.7			0.73			0.35202			1.17		
09/16/20 15:00	0.2			3			1.7			0.73			0.35274			1.18		
09/16/20 16:00	0.2			3			1.7			0.74			0.35454			1.18		
09/16/20 17:00	0.2			3			1.7			0.73			0.3516			1.17		
09/16/20 18:00	0.3			3			1.7			0.68			0.32556			1.09		
09/16/20 19:00	0.7			2			1.7			0.59			0.28212			0.94		
09/16/20 20:00	1.1			2			1.7			0.55			0.26358			0.88		
09/16/20 21:00	1.1			2			1.7			0.55			0.26364			0.88		
09/16/20 22:00	0.8			1			1.7			0.44			0.2193			0.73		
09/16/20 23:00	0.7			1			1.7			0.41			0.21612			0.72		
09/17/20 0:00	0.8			1			1.7			0.37			0.20874			0.7		
09/17/20 1:00	0.8			1			1.7			0.36			0.20088			0.67		
09/17/20 2:00	0.8			1			1.7			0.36			0.19788			0.66		
09/17/20 3:00	0.8			1			1.7			0.36			0.19746			0.66		
09/17/20 4:00	0.8			1			1.7			0.38			0.20826			0.69		
09/17/20 5:00	0.8			1			1.7			0.37			0.21504			0.72		
09/17/20 6:00	0.8			1			1.7			0.39			0.22704			0.76		
09/17/20 7:00	0.8			1			1.7			0.41			0.24144			0.8		
09/17/20 8:00	0.8			1			1.7			0.46			0.24066			0.8		
09/17/20 9:00	0.9			1			1.7			0.51			0.24282			0.81		
09/17/20 10:00	1.6			2			1.7			0.54			0.25674			0.86		
09/17/20 11:00	1			2			1.7			0.56			0.26622			0.89		
09/17/20 12:00	0.9			2			1.7			0.57			0.27138			0.9		
09/17/20 13:00	0.6			2			1.7			0.6			0.28806			0.96		
09/17/20 14:00	0.5			2			1.7			0.64			0.30492			1.02		
09/17/20 15:00	0.2			3			1.7			0.73			0.35196			1.17		
09/17/20 16:00	0.2			3			1.7			0.73			0.35346			1.18		
09/17/20 17:00	0.3			2			1.7			0.66			0.315			1.05		
09/17/20 18:00	0.5			2			1.7			0.63			0.30096			1		
09/17/20 19:00	1			2			1.7			0.55			0.26448			0.88		
09/17/20 20:00	0.9			2			1.7			0.58			0.27576			0.92		
09/17/20 21:00	0.7			2			1.7			0.6			0.28926			0.96		
09/17/20 22:00	0.8			1			1.7			0.49			0.24138			0.8		
09/17/20 23:00	0.8			1			1.7			0.41			0.2094			0.7		
09/18/20 0:00	0.8			1			1.7			0.36			0.19686			0.66		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/18/20 1:00	0.8			2			1.7			0.36			0.18054			0.6		
09/18/20 2:00	0.7			2			1.7			0.36			0.17826			0.59		
09/18/20 3:00	0.7			2			1.7			0.36			0.17838			0.59		
09/18/20 4:00	0.9			1			1.7			0.37			0.18564			0.62		
09/18/20 5:00	0.8			1			1.7			0.39			0.20364			0.68		
09/18/20 6:00	0.8			1			1.7			0.4			0.21756			0.73		
09/18/20 7:00	0.7			1			1.7			0.43			0.23268			0.78		
09/18/20 8:00	1.2			2			1.7			0.53			0.25428			0.85		
09/18/20 9:00	1.1			2			1.7			0.53			0.25506			0.85		
09/18/20 10:00	0.8			2			1.7			0.57			0.2736			0.91		
09/18/20 11:00	0.6			2			1.7			0.59			0.28176			0.94		
09/18/20 12:00	0.6			2			1.7			0.62			0.29604			0.99		
09/18/20 13:00	0.4			2			1.7			0.66			0.31722			1.06		
09/18/20 14:00	0.3			2			1.7			0.66			0.31554			1.05		
09/18/20 15:00	1.1			2			1.7			0.54			0.25932			0.86		
09/18/20 16:00	1			2			1.7			0.57			0.26958			0.9		
09/18/20 17:00	0.5			2			1.7			0.62			0.29712			0.99		
09/18/20 18:00	1.1			2			1.7			0.54			0.25506			0.85		
09/18/20 19:00	0.8			1			1.7			0.43			0.20574			0.69		
09/18/20 20:00	0.8			2			1.7			0.56			0.27402			0.91		
09/18/20 21:00	0.8			1			1.7			0.5			0.24186			0.81		
09/18/20 22:00	0.8			1			1.7			0.43			0.21366			0.71		
09/18/20 23:00	0.8			1			1.7			0.38			0.2034			0.68		
09/19/20 0:00	0.8			1			1.7			0.36			0.18366			0.61		
09/19/20 1:00	0.8			2			1.7			0.36			0.17664			0.59		
09/19/20 2:00	0.7			2			1.7			0.36			0.16992			0.57		
09/19/20 3:00	0.7			2			1.7			0.36			0.16986			0.57		
09/19/20 4:00	0.7			1			1.7			0.36			0.1698			0.57		
09/19/20 5:00	0.8			2			1.7			0.37			0.1803			0.6		
09/19/20 6:00	0.9			1			1.7			0.36			0.18786			0.63		
09/19/20 7:00	0.8			1			1.7			0.4			0.21024			0.7		
09/19/20 8:00	0.7			1			1.7			0.42			0.228			0.76		
09/19/20 9:00	0.7			1			1.7			0.46			0.24048			0.8		
09/19/20 10:00	0.8			1			1.7			0.51			0.2442			0.81		
09/19/20 11:00	1.2			2			1.7			0.56			0.26334			0.88		
09/19/20 12:00	0.6			2			1.7			0.62			0.29358			0.98		
09/19/20 13:00	0.5			2			1.7			0.62			0.29736			0.99		
09/19/20 14:00	0.7			2			1.7			0.6			0.28524			0.95		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/19/20 15:00	0.6			2			1.7			0.61			0.2913			0.97		
09/19/20 16:00	1.5			2			1.7			0.51			0.24144			0.8		
09/19/20 17:00	0.7			1			1.7			0.49			0.23796			0.79		
09/19/20 18:00	1.1			1			1.7			0.52			0.24774			0.83		
09/19/20 19:00	0.6			2			1.7			0.62			0.29568			0.99		
09/19/20 20:00	0.9			1			1.7			0.51			0.2409			0.8		
09/19/20 21:00	0.8			1			1.7			0.47			0.23028			0.77		
09/19/20 22:00	0.8			1			1.7			0.42			0.21438			0.71		
09/19/20 23:00	0.9			1			1.7			0.37			0.20094			0.67		
09/20/20 0:00	1			1			1.7			0.36			0.17934			0.6		
09/20/20 1:00	0.8			1			1.7			0.36			0.1698			0.57		
09/20/20 2:00	0.8			1			1.7			0.36			0.16986			0.57		
09/20/20 3:00	0.8			2			1.7			0.36			0.16986			0.57		
09/20/20 4:00	0.8			1			1.7			0.36			0.1701			0.57		
09/20/20 5:00	0.8			1			1.7			0.36			0.17094			0.57		
09/20/20 6:00	0.8			1			1.7			0.36			0.17088			0.57		
09/20/20 7:00	0.7			1			1.7			0.36			0.16998			0.57		
09/20/20 8:00	0.7			1			1.7			0.36			0.17238			0.57		
09/20/20 9:00	0.9			1			1.7			0.4			0.19284			0.64		
09/20/20 10:00	0.8			1			1.7			0.43			0.21612			0.72		
09/20/20 11:00	0.9			1			1.7			0.47			0.23202			0.77		
09/20/20 12:00	0.8			2			1.7			0.61			0.28788			0.96		
09/20/20 13:00	0.4			2			1.7			0.67			0.32064			1.07		
09/20/20 14:00	0.2			3			1.7			0.72			0.34782			1.16		
09/20/20 15:00	0.2			3			1.7			0.74			0.35532			1.18		
09/20/20 16:00	0.5			2			1.7			0.63			0.30354			1.01		
09/20/20 17:00	1.1			1			1.8			0.5			0.23958			0.8		
09/20/20 18:00	0.8			1			1.7			0.5			0.23886			0.8		
09/20/20 19:00	0.9			1			1.8			0.48			0.23334			0.78		
09/20/20 20:00	1			2			1.7			0.57			0.27762			0.93		
09/20/20 21:00	0.9			1			1.7			0.48			0.23802			0.79		
09/20/20 22:00	0.9			1			1.7			0.42			0.21576			0.72		
09/20/20 23:00	0.9			1			1.7			0.37			0.20394			0.68		
09/21/20 0:00	0.9			2			1.7			0.36			0.18186			0.61		
09/21/20 1:00	0.8			1			1.7			0.36			0.1695			0.57		
09/21/20 2:00	0.7			2			1.7			0.36			0.17028			0.57		
09/21/20 3:00	0.9			2			1.7			0.36			0.1782			0.59		
09/21/20 4:00	1			1			1.6			0.36			0.18498			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/21/20 5:00	0.9			1			1.7			0.38			0.20154			0.67		
09/21/20 6:00	0.9			1			1.7			0.39			0.21348			0.71		
09/21/20 7:00	0.9			1			1.7			0.38			0.21954			0.73		
09/21/20 8:00	0.9			1			1.7			0.47			0.23484			0.78		
09/21/20 9:00	0.9			1			1.7			0.5			0.24078			0.8		
09/21/20 10:00	1.4			2			1.7			0.55			0.2568			0.86		
09/21/20 11:00	0.3			2			1.7			0.68			0.32688			1.09		
09/21/20 12:00	0.2			3			1.7			0.71			0.33936			1.13		
09/21/20 13:00	0.2			3			1.7			0.74			0.3576			1.19		
09/21/20 14:00	0.2			3			1.7			0.74			0.35736			1.19		
09/21/20 15:00	0.2			3			1.7			0.74			0.35766			1.19		
09/21/20 16:00	0.2			3			1.7			0.72			0.3441			1.15		
09/21/20 17:00	0.2			3			1.7			0.72			0.34848			1.16		
09/21/20 18:00	0.2			3			1.7			0.71			0.34128			1.14		
09/21/20 19:00	0.8			2			1.7			0.58			0.276			0.92		
09/21/20 20:00	0.7			1			1.7			0.48			0.23394			0.78		
09/21/20 21:00	1.3			2			1.7			0.54			0.25596			0.85		
09/21/20 22:00	0.7			1			1.7			0.45			0.2286			0.76		
09/21/20 23:00	0.8			1			1.7			0.4			0.20424			0.68		
09/22/20 0:00	0.9			1			1.7			0.37			0.18576			0.62		
09/22/20 1:00	0.9			2			1.7			0.36			0.18564			0.62		
09/22/20 2:00	0.8			2			1.7			0.36			0.17946			0.6		
09/22/20 3:00	0.8			2			1.7			0.36			0.17934			0.6		
09/22/20 4:00	0.9			1			1.6			0.37			0.18912			0.63		
09/22/20 5:00	0.8			1			1.7			0.41			0.21006			0.7		
09/22/20 6:00	0.8			1			1.7			0.42			0.20568			0.69		
09/22/20 7:00	0.7			1			1.7			0.45			0.22242			0.74		
09/22/20 8:00	0.8			1			1.7			0.47			0.23928			0.8		
09/22/20 9:00	1.8			1			1.7			0.53			0.25146			0.84		
09/22/20 10:00	0.7			2			1.7			0.61			0.29094			0.97		
09/22/20 11:00	0.5			2			1.7			0.63			0.30018			1		
09/22/20 12:00	0.3			2			1.7			0.69			0.33108			1.1		
09/22/20 13:00	0.2			3			1.7			0.69			0.33264			1.11		
09/22/20 14:00	0.3			2			1.7			0.66			0.31962			1.07		
09/22/20 15:00	0.4			2			1.7			0.64			0.30696			1.02		
09/22/20 16:00	0.3			2			1.7			0.68			0.32838			1.09		
09/22/20 17:00	0.4			2			1.7			0.65			0.31302			1.04		
09/22/20 18:00	0.6			2			1.7			0.6			0.2904			0.97		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/22/20 19:00	0.7			1			1.7			0.49			0.2337			0.78		
09/22/20 20:00	0.7			2			1.7			0.58			0.28932			0.96		
09/22/20 21:00	0.8			1			1.7			0.5			0.2409			0.8		
09/22/20 22:00	0.8			1			1.7			0.43			0.20904			0.7		
09/22/20 23:00	0.8			1			1.7			0.38			0.19482			0.65		
09/23/20 0:00	0.7			2			1.7			0.36			0.17262			0.58		
09/23/20 1:00	0.7			2			1.7			0.36			0.1704			0.57		
09/23/20 2:00	0.7			2			1.7			0.36			0.17034			0.57		
09/23/20 3:00	0.7			2			1.7			0.36			0.17022			0.57		
09/23/20 4:00	0.7			1			1.6			0.36			0.17136			0.57		
09/23/20 5:00	0.9			1			1.7			0.39			0.19122			0.64		
09/23/20 6:00	0.8			1			1.7			0.39			0.20058			0.67		
09/23/20 7:00	0.8			1			1.7			0.4			0.21264			0.71		
09/23/20 8:00	0.8			1			1.7			0.45			0.23694			0.79		
09/23/20 9:00	0.7			1			1.7			0.51			0.24678			0.82		
09/23/20 10:00	0.8			1			1.7			0.52			0.2448			0.82		
09/23/20 11:00	1			2			1.7			0.56			0.26748			0.89		
09/23/20 12:00	0.8			2			1.7			0.59			0.28224			0.94		
09/23/20 13:00	0.6			2			1.7			0.6			0.28962			0.97		
09/23/20 14:00	0.2			2			1.7			0.69			0.32982			1.1		
09/23/20 15:00	0.5			2			1.7			0.63			0.30414			1.01		
09/23/20 16:00	0.2			3			1.7			0.69			0.33168			1.11		
09/23/20 17:00	0.2			3			1.7			0.74			0.35724			1.19		
09/23/20 18:00	0.2			3			1.7			0.73			0.35106			1.17		
09/23/20 19:00	0.4			2			1.7			0.64			0.30564			1.02		
09/23/20 20:00	1			2			1.7			0.56			0.26808			0.89		
09/23/20 21:00	1.2			2			1.7			0.53			0.25362			0.85		
09/23/20 22:00	0.7			1			1.7			0.44			0.23496			0.78		
09/23/20 23:00	0.7			1			1.7			0.16			0.24624			0.82		
09/24/20 0:00	0.7			1			1.7			0	X		0.24582			0.82		
09/24/20 1:00	0.7			1			1.7			0	X		0.23388			0.78		
09/24/20 2:00	0.7			1			1.7			0	X		0.21804			0.73		
09/24/20 3:00	0.7			1			1.7			0	X		0.21774			0.73		
09/24/20 4:00	0.7			1			1.6			0	X		0.2316			0.77		
09/24/20 5:00	0.8			1			1.6			0	X		0.19338			0.64		
09/24/20 6:00	0.8			1			1.6			0	X		0.19182			0.64		
09/24/20 7:00	0.8			1			1.6			0	X		0.19956			0.67		
09/24/20 8:00	0.7			1			1.6			0	X		0.24162			0.81		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/24/20 9:00	0.7			1			1.6			0	X		0.24264			0.81		
09/24/20 10:00	0.7			1			1.6			0	X		0.24204			0.81		
09/24/20 11:00	0.7			1			1.6			0	X		0.24096			0.8		
09/24/20 12:00	1.2			2			1.6			0	X		0.26574			0.89		
09/24/20 13:00	0.9			2			1.6			0	X		0.27006			0.9		
09/24/20 14:00	0.9			2			1.6			0	X		0.26856			0.9		
09/24/20 15:00	0.5			3			1.6			0	X		0.32346			1.08		
09/24/20 16:00	0.2			3			1.6			0	X		0.35388			1.18		
09/24/20 17:00	0.2			3			1.7			0	X		0.35598			1.19		
09/24/20 18:00	0.2			3			1.7			0	X		0.35748			1.19		
09/24/20 19:00	0.6			2			1.7			0	X		0.29418			0.98		
09/24/20 20:00	1			2			1.7			0	X		0.2628			0.88		
09/24/20 21:00	0.7			1			1.7			0	X		0.2253			0.75		
09/24/20 22:00	0.8			1			1.7			0	X		0.23286			0.78		
09/24/20 23:00	1			1			1.7			0	X		0.24012			0.8		
09/25/20 0:00	0.7			1			1.7			0	X		0.22128			0.74		
09/25/20 1:00	0.8			1			1.7			0	X		0.20592			0.69		
09/25/20 2:00	0.8			1			1.7			0	X		0.19188			0.64		
09/25/20 3:00	0.9			1			1.7			0	X		0.19158			0.64		
09/25/20 4:00	0.8			1			1.7			0	X		0.20436			0.68		
09/25/20 5:00	0.7			2			1.7			0	X		0.17418			0.58		
09/25/20 6:00	0.8			2			1.7			0	X		0.17928			0.6		
09/25/20 7:00	0.9			1			1.7			0	X		0.1878			0.63		
09/25/20 8:00	0.7			1			1.7			0	X		0.2244			0.75		
09/25/20 9:00	0.7			1			1.7			0	X		0.2466			0.82		
09/25/20 10:00	0.7			1			1.7			0	X		0.2439			0.81		
09/25/20 11:00	0.7			1			1.7			0	X		0.23616			0.79		
09/25/20 12:00	1			1			1.7			0	X		0.23814			0.79		
09/25/20 13:00	0.7			1			1.7			0	X		0.2421			0.81		
09/25/20 14:00	0.7			1			1.7			0	X		0.24126			0.8		
09/25/20 15:00	0.7			1			1.7			0	X		0.2409			0.8		
09/25/20 16:00	0.7			1			1.7			0	X		0.23742			0.79		
09/25/20 17:00	0.7			1			1.7			0	X		0.22536			0.75		
09/25/20 18:00	0.7			1			1.7			0	X		0.22044			0.73		
09/25/20 19:00	0.7			1			1.7			0	X		0.21678			0.72		
09/25/20 20:00	1.3			2			1.7			0	X		0.25056			0.84		
09/25/20 21:00	1.4			2			1.7			0	X		0.2445			0.82		
09/25/20 22:00	1.4			2			1.7			0	X		0.24504			0.82		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/25/20 23:00	0.8			1			1.7			0	X		0.23454			0.78		
09/26/20 0:00	0.8			1			1.7			0	X		0.2061			0.69		
09/26/20 1:00	0.9			1			1.7			0	X		0.18966			0.63		
09/26/20 2:00	0.8			1			1.7			0	X		0.17598			0.59		
09/26/20 3:00	0.8			1			1.7			0	X		0.17526			0.58		
09/26/20 4:00	0.8			1			1.6			0	X		0.18102			0.6		
09/26/20 5:00	0.9			1			1.7			0	X		0.17682			0.59		
09/26/20 6:00	1.5			1			1.7			0	X		0.17748			0.59		
09/26/20 7:00	1.2			2			1.7			0	X		0.18768			0.63		
09/26/20 8:00	0.8			1			1.7			0	X		0.20682			0.69		
09/26/20 9:00	0.7			1			1.7			0	X		0.22134			0.74		
09/26/20 10:00	0.8			1			1.7			0	X		0.21354			0.71		
09/26/20 11:00	0.7			1			1.7			0	X		0.23628			0.79		
09/26/20 12:00	0.7			1			1.7			0	X		0.21366			0.71		
09/26/20 13:00	0.7			1			1.7			0	X		0.22158			0.74		
09/26/20 14:00	0.8			1			1.7			0	X		0.20028			0.67		
09/26/20 15:00	0.7			1			1.7			0	X		0.20112			0.67		
09/26/20 16:00	0.7			1			1.7			0	X		0.20442			0.68		
09/26/20 17:00	0.7			1			1.7			0	X		0.2016			0.67		
09/26/20 18:00	0.7			1			1.7			0	X		0.195			0.65		
09/26/20 19:00	0.8			1			1.7			0	X		0.19248			0.64		
09/26/20 20:00	0.9			2			1.7			0	X		0.18528			0.62		
09/26/20 21:00	0.7			1			1.7			0	X		0.21366			0.71		
09/26/20 22:00	0.8			1			1.7			0	X		0.20958			0.7		
09/26/20 23:00	0.9			1			1.7			0	X		0.19188			0.64		
09/27/20 0:00	0.8			2			1.7			0	X		0.1809			0.6		
09/27/20 1:00	0.8			2			1.7			0	X		0.1797			0.6		
09/27/20 2:00	0.8			2			1.7			0	X		0.17928			0.6		
09/27/20 3:00	0.8			2			1.7			0	X		0.1794			0.6		
09/27/20 4:00	0.8			1			1.7			0	X		0.17958			0.6		
09/27/20 5:00	0.8			2			1.7			0	X		0.17994			0.6		
09/27/20 6:00	0.9			2			1.7			0	X		0.17922			0.6		
09/27/20 7:00	0.8			2			1.7			0	X		0.18024			0.6		
09/27/20 8:00	0.7			1			1.7			0	X		0.2223			0.74		
09/27/20 9:00	0.7			1			1.7			0	X		0.21156			0.71		
09/27/20 10:00	0.8			1			1.7			0	X		0.19596			0.65		
09/27/20 11:00	1.2			1			1.7			0	X		0.24006			0.8		
09/27/20 12:00	0.8			1			1.7			0	X		0.2322			0.77		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/27/20 13:00	0.7			1			1.7			0	X		0.21888			0.73		
09/27/20 14:00	0.7			1			1.7			0	X		0.21804			0.73		
09/27/20 15:00	0.7			1			1.7			0	X		0.2232			0.74		
09/27/20 16:00	1.2			2			1.7			0	X		0.24708			0.82		
09/27/20 17:00	0.7			1			1.7			0	X		0.22974			0.77		
09/27/20 18:00	0.8			1			1.7			0	X		0.22932			0.76		
09/27/20 19:00	0.8			1			1.7			0	X		0.22116			0.74		
09/27/20 20:00	0.8			1			1.7			0	X		0.22242			0.74		
09/27/20 21:00	0.8			1			1.7			0	X		0.23052			0.77		
09/27/20 22:00	0.8			1			1.7			0	X		0.2082			0.69		
09/27/20 23:00	1.1			1			1.7			0	X		0.2088			0.7		
09/28/20 0:00	1.1			2			1.7			0	X		0.18204			0.61		
09/28/20 1:00	1			2			1.7			0	X		0.1812			0.6		
09/28/20 2:00	0.9			2			1.7			0	X		0.1812			0.6		
09/28/20 3:00	0.9			2			1.7			0	X		0.18306			0.61		
09/28/20 4:00	0.9			1			1.8			0.19			0.1854			0.62		
09/28/20 5:00	0.8			2			1.7			0.39			0.18228			0.61		
09/28/20 6:00	0.9			2			1.7			0.37			0.18102			0.6		
09/28/20 7:00	0.8			1			1.7			0.39			0.1989			0.66		
09/28/20 8:00	0.8			1			1.7			0.44			0.22806			0.76		
09/28/20 9:00	0.9			1			1.7			0.44			0.22644			0.75		
09/28/20 10:00	0.9			1			1.7			0.43			0.21138			0.7		
09/28/20 11:00	0.8			1			1.7			0.46			0.21354			0.71		
09/28/20 12:00	0.9			1			1.7			0.48			0.2331			0.78		
09/28/20 13:00	0.3			3			1.7			0.73			0.34992			1.17		
09/28/20 14:00	0.2			3			1.7			0.73			0.3486			1.16		
09/28/20 15:00	0.2			3			1.7			0.72			0.34506			1.15		
09/28/20 16:00	0.6			2			1.7			0.6			0.28818			0.96		
09/28/20 17:00	0.8			2			1.7			0.56			0.26748			0.89		
09/28/20 18:00	1.2			1			1.7			0.53			0.25032			0.83		
09/28/20 19:00	0.9			1			1.7			0.48			0.22968			0.77		
09/28/20 20:00	1			1			1.7			0.44			0.21516			0.72		
09/28/20 21:00	0.9			1			1.7			0.37			0.19158			0.64		
09/28/20 22:00	0.9			1			1.7			0.36			0.17052			0.57		
09/28/20 23:00	0.9			1			1.7			0.43			0.20976			0.7		
09/29/20 0:00	0.9			1			1.7			0.38			0.19368			0.65		
09/29/20 1:00	0.9			1			1.7			0.36			0.19518			0.65		
09/29/20 2:00	0.9			2			1.7			0.36			0.18042			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/29/20 3:00	0.9			2			1.7			0.36			0.17724			0.59		
09/29/20 4:00	1			1			1.7			0.37			0.18792			0.63		
09/29/20 5:00	1			2			1.7			0.36			0.17412			0.58		
09/29/20 6:00	1.2			1			1.7			0.36			0.17172			0.57		
09/29/20 7:00	1.4			2			1.7			0.38			0.18468			0.62		
09/29/20 8:00	1.1			1			1.7			0.42			0.20982			0.7		
09/29/20 9:00	0.9			1			1.7			0.44			0.22788			0.76		
09/29/20 10:00	0.8			1			1.7			0.49			0.24126			0.8		
09/29/20 11:00	1.3			2			1.7			0.54			0.25776			0.86		
09/29/20 12:00	0.3			2			1.7			0.68			0.32568			1.09		
09/29/20 13:00	0.3			3			1.7			0.7			0.33384			1.11		
09/29/20 14:00	0.2			3			1.7			0.71			0.34128			1.14		
09/29/20 15:00	0.3			3			1.7			0.69			0.33048			1.1		
09/29/20 16:00	0.4			2			1.7			0.66			0.31704			1.06		
09/29/20 17:00	0.4			2			1.7			0.67			0.32226			1.07		
09/29/20 18:00	1.1			2			1.7			0.56			0.26388			0.88		
09/29/20 19:00	1.3			1			1.7			0.46			0.22386			0.75		
09/29/20 20:00	2.3			2			1.7			0.53			0.2469			0.82		
09/29/20 21:00	0.8			2			1.7			0.61			0.29094			0.97		
09/29/20 22:00	1			1			1.7			0.49			0.24054			0.8		
09/29/20 23:00	1			1			1.7			0.36			0.17316			0.58		
09/30/20 0:00	1			1			1.7			0.36			0.16986			0.57		
09/30/20 1:00	1			1			1.7			0.36			0.17022			0.57		
09/30/20 2:00	1			2			1.7			0.37			0.18102			0.6		
09/30/20 3:00	1.1			2			1.7			0.36			0.18336			0.61		
09/30/20 4:00	1.1			1			1.7			0.36			0.1839			0.61		
09/30/20 5:00	1			1			1.7			0.36			0.17004			0.57		
09/30/20 6:00	1			2			1.7			0.36			0.17016			0.57		
09/30/20 7:00	1			1			1.7			0.36			0.1701			0.57		
09/30/20 8:00	1			1			1.7			0.4			0.19302			0.64		
09/30/20 9:00	1			1			1.7			0.42			0.21			0.7		
09/30/20 10:00	1.5			1			1.7			0.51			0.24456			0.82		
09/30/20 11:00	1.4			2			1.7			0.55			0.258			0.86		
09/30/20 12:00	0.6			2			1.7			0.64			0.30468			1.02		
09/30/20 13:00	0.3			3			1.7			0.73			0.35112			1.17		
09/30/20 14:00	0.2			3			1.7			0.74			0.35346			1.18		
09/30/20 15:00	0.2			3			1.7			0.7			0.33696			1.12		
09/30/20 16:00	0.2			3			1.7			0.72			0.34398			1.15		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/30/20 17:00	0.4			2			1.7			0.66			0.31542			1.05		
09/30/20 18:00	0.5			2			1.7			0.62			0.29646			0.99		
09/30/20 19:00	1.1			2			1.7			0.55			0.26178			0.87		
09/30/20 20:00	1.2			2			1.7			0.53			0.25404			0.85		
09/30/20 21:00	0.7			2			1.7			0.61			0.28884			0.96		
09/30/20 22:00	1.4			2			1.7			0.52			0.2376			0.79		
09/30/20 23:00	1			1			1.7			0.46			0.22146			0.74		

AQ57 CT1 HOURLY EMISSIONS

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**
07/01/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/01/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/02/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/03/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/04/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/05/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/10/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/11/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/12/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/13/20 6:00	0			0			0	X		0.2			0.1002			0.33		
07/13/20 7:00	0.7			1.6			3			0.4			0.19896			0.66		
07/13/20 8:00	0.8			1.7			2			0.4			0.20082			0.67		
07/13/20 9:00	0.7			1.7			2			0.44			0.22002			0.73		
07/13/20 10:00	0.7			1.7			1			0.5			0.2523			0.84		
07/13/20 11:00	0.7			1.7			2			0.61			0.30552			1.02		
07/13/20 12:00	0.5			1.7			2			0.62			0.3099			1.03		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/13/20 13:00	0.8			1.7			2			0.6			0.2988			1		
07/13/20 14:00	0.5			1.7			2			0.62			0.30996			1.03		
07/13/20 15:00	0.5			1.7			2			0.62			0.30924			1.03		
07/13/20 16:00	0.8			1.7			2			0.59			0.29346			0.98		
07/13/20 17:00	0.6			1.7			2			0.62			0.30876			1.03		
07/13/20 18:00	0.2			1.7			3			0.72			0.3597			1.2		
07/13/20 19:00	0.5			1.7			2			0.63			0.3144			1.05		
07/13/20 20:00	0.8			1.7			2			0.44			0.22224			0.74		
07/13/20 21:00	0.6			1.7			2			0.36			0.17826			0.59		
07/13/20 22:00	0.6			1.7			2			0.36			0.17862			0.6		
07/13/20 23:00	0.6			1.7			2			0.36			0.17892			0.6		
07/14/20 0:00	0.7			1.7			2			0.36			0.17886			0.6		
07/14/20 1:00	0.7			1.7			3			0.37			0.18456			0.62		
07/14/20 2:00	0.7			1.7			2			0.36			0.17796			0.59		
07/14/20 3:00	0.6			1.7			2			0.36			0.17808			0.59		
07/14/20 4:00	0.7			1.6			2			0.36			0.1809			0.6		
07/14/20 5:00	0.7			1.7			2			0.36			0.17832			0.59		
07/14/20 6:00	0.7			1.7			2			0.36			0.17862			0.6		
07/14/20 7:00	0.7			1.7			3			0.37			0.186			0.62		
07/14/20 8:00	0.8			1.7			2			0.39			0.19686			0.66		
07/14/20 9:00	0.8			1.7			2			0.43			0.2133			0.71		
07/14/20 10:00	0.7			1.7			1			0.49			0.2457			0.82		
07/14/20 11:00	1.1			1.7			1			0.58			0.28776			0.96		
07/14/20 12:00	0.3			1.7			1			0.67			0.33342			1.11		
07/14/20 13:00	1			1.7			2			0.57			0.28518			0.95		
07/14/20 14:00	0.3			1.7			3			0.68			0.3399			1.13		
07/14/20 15:00	0.1			1.7			4			0.74			0.37158			1.24		
07/14/20 16:00	0.1			1.7			4			0.75			0.3732			1.24		
07/14/20 17:00	0.1			1.7			4			0.74			0.37008			1.23		
07/14/20 18:00	0.3			1.7			2			0.66			0.33222			1.11		
07/14/20 19:00	1			1.7			2			0.58			0.28776			0.96		
07/14/20 20:00	0.8			1.7			1			0.5			0.2523			0.84		
07/14/20 21:00	0.7			1.7			2			0.47			0.2355			0.79		
07/14/20 22:00	0.7			1.7			2			0.45			0.22728			0.76		
07/14/20 23:00	0.8			1.7			2			0.39			0.19476			0.65		
07/15/20 0:00	0.7			1.7			2			0.36			0.18174			0.61		
07/15/20 1:00	0.6			1.7			2			0.36			0.17904			0.6		
07/15/20 2:00	0.6			1.7			2			0.36			0.17874			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/15/20 3:00	0.6			1.7			2			0.36			0.17874			0.6		
07/15/20 4:00	0.6			1.7			2			0.36			0.1788			0.6		
07/15/20 5:00	0.7			1.7			2			0.36			0.17892			0.6		
07/15/20 6:00	0.6			1.7			2			0.36			0.17904			0.6		
07/15/20 7:00	0.6			1.7			2			0.36			0.17994			0.6		
07/15/20 8:00	0.8			1.7			2			0.4			0.20142			0.67		
07/15/20 9:00	0.7			1.7			2			0.43			0.21726			0.72		
07/15/20 10:00	0.7			1.7			1			0.49			0.24558			0.82		
07/15/20 11:00	0.7			1.7			2			0.61			0.30438			1.01		
07/15/20 12:00	0.2			1.7			3			0.7			0.34806			1.16		
07/15/20 13:00	0.2			1.7			3			0.7			0.35076			1.17		
07/15/20 14:00	0.1			1.7			3			0.74			0.36978			1.23		
07/15/20 15:00	0.1			1.7			4			0.75			0.37476			1.25		
07/15/20 16:00	0.1			1.7			4			0.75			0.37536			1.25		
07/15/20 17:00	0.1			1.7			4			0.75			0.37416			1.25		
07/15/20 18:00	0.1			1.7			3			0.71			0.3543			1.18		
07/15/20 19:00	1			1.7			2			0.56			0.28164			0.94		
07/15/20 20:00	0.8			1.7			2			0.48			0.2406			0.8		
07/15/20 21:00	0.7			1.7			2			0.39			0.1926			0.64		
07/15/20 22:00	0.6			1.7			2			0.36			0.17976			0.6		
07/15/20 23:00	0.6			1.7			2			0.36			0.17934			0.6		
07/16/20 0:00	0.6			1.7			2			0.36			0.17928			0.6		
07/16/20 1:00	0.6			1.7			2			0.36			0.17916			0.6		
07/16/20 2:00	0.6			1.7			2			0.36			0.1791			0.6		
07/16/20 3:00	0.6			1.7			2			0.36			0.1791			0.6		
07/16/20 4:00	0.6			1.7			2			0.36			0.17904			0.6		
07/16/20 5:00	0.7			1.7			2			0.36			0.17904			0.6		
07/16/20 6:00	0.6			1.7			2			0.36			0.17946			0.6		
07/16/20 7:00	0.6			1.7			2			0.36			0.18048			0.6		
07/16/20 8:00	0.8			1.7			2			0.39			0.19572			0.65		
07/16/20 9:00	0.7			1.7			2			0.43			0.2172			0.72		
07/16/20 10:00	0.7			1.7			2			0.48			0.24036			0.8		
07/16/20 11:00	1.1			1.7			1			0.57			0.28506			0.95		
07/16/20 12:00	0.2			1.7			3			0.69			0.3465			1.16		
07/16/20 13:00	0.4			1.7			2			0.65			0.32322			1.08		
07/16/20 14:00	0.4			1.7			2			0.66			0.32868			1.1		
07/16/20 15:00	0.2			1.7			4			0.75			0.37722			1.26		
07/16/20 16:00	0.2			1.7			4			0.75			0.37704			1.26		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/16/20 17:00	0.2			1.7			4			0.76			0.37956			1.27		
07/16/20 18:00	0.4			1.7			2			0.65			0.32346			1.08		
07/16/20 19:00	0.8			1.7			1			0.52			0.258			0.86		
07/16/20 20:00	0.8			1.7			2			0.43			0.21522			0.72		
07/16/20 21:00	0.8			1.7			2			0.41			0.20466			0.68		
07/16/20 22:00	0.6			1.7			2			0.36			0.18006			0.6		
07/16/20 23:00	0.6			1.7			2			0.37			0.18276			0.61		
07/17/20 0:00	0.6			1.7			2			0.36			0.17928			0.6		
07/17/20 1:00	0.6			1.7			2			0.36			0.17928			0.6		
07/17/20 2:00	0.6			1.7			2			0.36			0.17916			0.6		
07/17/20 3:00	0.6			1.7			2			0.36			0.17916			0.6		
07/17/20 4:00	0.6			1.6			2			0.36			0.17898			0.6		
07/17/20 5:00	0.7			1.7			2			0.36			0.17898			0.6		
07/17/20 6:00	0.6			1.7			2			0.36			0.1794			0.6		
07/17/20 7:00	0.6			1.7			2			0.36			0.17874			0.6		
07/17/20 8:00	0.8			1.7			3			0.39			0.19356			0.65		
07/17/20 9:00	0.8			1.7			2			0.42			0.21234			0.71		
07/17/20 10:00	0.7			1.7			2			0.46			0.22866			0.76		
07/17/20 11:00	0.7			1.7			1			0.52			0.25932			0.86		
07/17/20 12:00	0.7			1.7			2			0.43			0.21726			0.72		
07/17/20 13:00	0.6			1.7			1			0.49			0.24678			0.82		
07/17/20 14:00	0.7			1.7			2			0.6			0.30246			1.01		
07/17/20 15:00	0.2			1.7			3			0.71			0.3525			1.18		
07/17/20 16:00	0.1			1.7			4			0.74			0.37176			1.24		
07/17/20 17:00	0.2			1.7			3			0.7			0.34794			1.16		
07/17/20 18:00	0.6			1.7			2			0.62			0.30834			1.03		
07/17/20 19:00	0.7			1.8			2			0.48			0.24174			0.81		
07/17/20 20:00	0.8			1.7			3			0.39			0.19734			0.66		
07/17/20 21:00	0.8			1.7			3			0.39			0.1932			0.64		
07/17/20 22:00	0.8			1.7			3			0.39			0.1962			0.65		
07/17/20 23:00	0.6			1.7			2			0.36			0.17934			0.6		
07/18/20 0:00	0.6			1.7			2			0.36			0.17862			0.6		
07/18/20 1:00	0.6			1.7			2			0.36			0.17868			0.6		
07/18/20 2:00	0.6			1.7			2			0.36			0.17868			0.6		
07/18/20 3:00	0.6			1.7			2			0.36			0.17862			0.6		
07/18/20 4:00	0.6			1.7			2			0.36			0.17856			0.6		
07/18/20 5:00	0.7			1.7			2			0.36			0.17856			0.6		
07/18/20 6:00	0.6			1.7			2			0.36			0.17868			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/18/20 7:00	0.6			1.7			2			0.36			0.17988			0.6		
07/18/20 8:00	0.8			1.7			3			0.39			0.195			0.65		
07/18/20 9:00	0.7			1.7			2			0.43			0.21432			0.71		
07/18/20 10:00	0.7			1.7			1			0.5			0.25224			0.84		
07/18/20 11:00	0.7			1.7			2			0.61			0.3054			1.02		
07/18/20 12:00	0.7			1.7			1			0.49			0.24636			0.82		
07/18/20 13:00	0.8			1.7			2			0.61			0.30366			1.01		
07/18/20 14:00	0.2			1.7			4			0.75			0.37698			1.26		
07/18/20 15:00	0.2			1.7			4			0.76			0.37956			1.27		
07/18/20 16:00	0.1			1.7			4			0.74			0.36864			1.23		
07/18/20 17:00	0.1			1.7			4			0.73			0.36636			1.22		
07/18/20 18:00	0.1			1.7			4			0.73			0.36726			1.22		
07/18/20 19:00	0.3			1.7			2			0.66			0.32862			1.1		
07/18/20 20:00	0.8			1.8			1			0.52			0.25776			0.86		
07/18/20 21:00	0.8			1.7			2			0.5			0.24792			0.83		
07/18/20 22:00	0.8			1.7			2			0.59			0.2946			0.98		
07/18/20 23:00	0.7			1.8			3			0.36			0.18198			0.61		
07/19/20 0:00	0.7			1.7			2			0.36			0.17856			0.6		
07/19/20 1:00	0.7			1.7			2			0.36			0.17862			0.6		
07/19/20 2:00	0.7			1.7			2			0.36			0.17844			0.59		
07/19/20 3:00	0.7			1.7			2			0.36			0.1785			0.6		
07/19/20 4:00	0.7			1.7			2			0.36			0.17832			0.59		
07/19/20 5:00	0.7			1.7			2			0.36			0.17844			0.59		
07/19/20 6:00	0.6			1.7			2			0.36			0.1788			0.6		
07/19/20 7:00	0.6			1.7			2			0.36			0.17922			0.6		
07/19/20 8:00	0.6			1.7			3			0.36			0.18024			0.6		
07/19/20 9:00	0.8			1.7			2			0.41			0.20304			0.68		
07/19/20 10:00	0.7			1.7			2			0.48			0.23766			0.79		
07/19/20 11:00	1.1			1.7			1			0.58			0.28968			0.97		
07/19/20 12:00	0.5			1.7			2			0.64			0.31854			1.06		
07/19/20 13:00	0.4			1.7			2			0.66			0.32892			1.1		
07/19/20 14:00	0.2			1.7			4			0.75			0.37614			1.25		
07/19/20 15:00	0.2			1.7			4			0.75			0.37632			1.25		
07/19/20 16:00	0.1			1.7			3			0.7			0.35058			1.17		
07/19/20 17:00	0.1			1.7			4			0.74			0.36852			1.23		
07/19/20 18:00	0.2			1.7			3			0.67			0.33726			1.12		
07/19/20 19:00	1.2			1.8			2			0.54			0.26916			0.9		
07/19/20 20:00	0.8			1.7			2			0.5			0.249			0.83		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/19/20 21:00	0.7			1.7			3			0.43			0.216			0.72		
07/19/20 22:00	0.7			1.7			2			0.37			0.18456			0.62		
07/19/20 23:00	0.8			1.7			2			0.42			0.20802			0.69		
07/20/20 0:00	0.7			1.7			3			0.36			0.1824			0.61		
07/20/20 1:00	0.6			1.7			2			0.36			0.17862			0.6		
07/20/20 2:00	0.6			1.7			3			0.36			0.17886			0.6		
07/20/20 3:00	0.7			1.7			3			0.36			0.18222			0.61		
07/20/20 4:00	0.7			1.7			2			0.37			0.18312			0.61		
07/20/20 5:00	0.7			1.7			3			0.36			0.17874			0.6		
07/20/20 6:00	0.6			1.7			3			0.36			0.17886			0.6		
07/20/20 7:00	0.6			1.7			2			0.36			0.17922			0.6		
07/20/20 8:00	0.6			1.7			2			0.36			0.17964			0.6		
07/20/20 9:00	0.7			1.7			2			0.42			0.2112			0.7		
07/20/20 10:00	0.6			1.7			1			0.51			0.25662			0.86		
07/20/20 11:00	0.7			1.7			1			0.52			0.261			0.87		
07/20/20 12:00	0.7			1.7			1			0.52			0.26064			0.87		
07/20/20 13:00	0.6			1.7			2			0.63			0.31542			1.05		
07/20/20 14:00	0.2			1.7			3			0.7			0.35064			1.17		
07/20/20 15:00	0.1			1.7			3			0.72			0.35946			1.2		
07/20/20 16:00	0.1			1.7			3			0.72			0.35928			1.2		
07/20/20 17:00	0.2			1.7			3			0.7			0.35046			1.17		
07/20/20 18:00	0.6			1.7			2			0.61			0.3057			1.02		
07/20/20 19:00	0.8			1.7			2			0.59			0.29736			0.99		
07/20/20 20:00	0.8			1.8			2			0.51			0.25272			0.84		
07/20/20 21:00	0.8			1.7			3			0.38			0.19134			0.64		
07/20/20 22:00	0.6			1.7			2			0.36			0.17922			0.6		
07/20/20 23:00	0.8			1.7			3			0.4			0.19944			0.66		
07/21/20 0:00	0.7			1.7			2			0.36			0.18168			0.61		
07/21/20 1:00	0.6			1.7			2			0.36			0.17928			0.6		
07/21/20 2:00	0.6			1.7			3			0.36			0.1788			0.6		
07/21/20 3:00	0.7			1.7			2			0.36			0.18084			0.6		
07/21/20 4:00	0.6			1.7			2			0.38			0.18894			0.63		
07/21/20 5:00	0			0			0	X		0.13			0.06288			0.21		
07/21/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/21/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/21/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/22/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/23/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/23/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
07/26/20 1:00	0			0			0	X		0.2			0.0996			0.33		
07/26/20 2:00	0.8			1.7			4			0.42			0.21006			0.7		
07/26/20 3:00	0.7			1.7			3			0.36			0.17952			0.6		
07/26/20 4:00	0.6			1.7			2			0.36			0.17826			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/26/20 5:00	0.6			1.7			2			0.36			0.17922			0.6		
07/26/20 6:00	0.7			1.7			3			0.37			0.18432			0.61		
07/26/20 7:00	0.6			1.7			2			0.36			0.18072			0.6		
07/26/20 8:00	0.6			1.7			2			0.36			0.17922			0.6		
07/26/20 9:00	0.6			1.7			2			0.36			0.17922			0.6		
07/26/20 10:00	0.6			1.7			2			0.36			0.17958			0.6		
07/26/20 11:00	0.6			1.7			2			0.37			0.18474			0.62		
07/26/20 12:00	1.2			1.7			2			0.53			0.2664			0.89		
07/26/20 13:00	0.9			1.7			2			0.58			0.2895			0.97		
07/26/20 14:00	0.6			1.7			2			0.62			0.31104			1.04		
07/26/20 15:00	0.1			1.7			4			0.75			0.3759			1.25		
07/26/20 16:00	0.1			1.7			4			0.75			0.37608			1.25		
07/26/20 17:00	0.1			1.7			4			0.75			0.37548			1.25		
07/26/20 18:00	0.1			1.7			4			0.75			0.37614			1.25		
07/26/20 19:00	0.1			1.7			4			0.74			0.36786			1.23		
07/26/20 20:00	0.3			1.7			3			0.68			0.33846			1.13		
07/26/20 21:00	0.8			1.8			2			0.44			0.21936			0.73		
07/26/20 22:00	0.7			1.7			2			0.46			0.22998			0.77		
07/26/20 23:00	0.7			1.7			3			0.46			0.22896			0.76		
07/27/20 0:00	0.8			1.7			3			0.4			0.19974			0.67		
07/27/20 1:00	0.7			1.7			3			0.37			0.183			0.61		
07/27/20 2:00	0.8			1.7			3			0.4			0.20016			0.67		
07/27/20 3:00	0.8			1.7			3			0.39			0.1968			0.66		
07/27/20 4:00	0.7			1.6			2			0.36			0.17994			0.6		
07/27/20 5:00	0.7			1.7			3			0.37			0.18402			0.61		
07/27/20 6:00	0.7			1.7			3			0.36			0.18096			0.6		
07/27/20 7:00	0.6			1.7			3			0.36			0.1791			0.6		
07/27/20 8:00	0.6			1.7			3			0.36			0.18006			0.6		
07/27/20 9:00	0.8			1.7			2			0.41			0.20316			0.68		
07/27/20 10:00	1.2			1.7			2			0.54			0.26886			0.9		
07/27/20 11:00	0.6			1.7			2			0.62			0.3111			1.04		
07/27/20 12:00	0.1			1.7			3			0.7			0.35064			1.17		
07/27/20 13:00	0.5			1.7			2			0.63			0.3159			1.05		
07/27/20 14:00	0.1			1.7			4			0.75			0.37386			1.25		
07/27/20 15:00	0.1			1.7			4			0.75			0.3747			1.25		
07/27/20 16:00	0.1			1.7			4			0.75			0.37404			1.25		
07/27/20 17:00	0.1			1.7			4			0.75			0.37548			1.25		
07/27/20 18:00	0.1			1.7			4			0.75			0.3729			1.24		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/27/20 19:00	0.2			1.7			3			0.68			0.34176			1.14		
07/27/20 20:00	0.4			1.7			2			0.64			0.31902			1.06		
07/27/20 21:00	0.8			1.8			3			0.39			0.19422			0.65		
07/27/20 22:00	0.8			1.7			3			0.4			0.20088			0.67		
07/27/20 23:00	0.8			1.7			3			0.41			0.20328			0.68		
07/28/20 0:00	0.6			1.7			3			0.36			0.17838			0.59		
07/28/20 1:00	0.7			1.7			3			0.36			0.17802			0.59		
07/28/20 2:00	0.7			1.7			2			0.36			0.17814			0.59		
07/28/20 3:00	0.7			1.7			2			0.36			0.17808			0.59		
07/28/20 4:00	0.7			1.6			2			0.36			0.17814			0.59		
07/28/20 5:00	0.7			1.7			2			0.36			0.17808			0.59		
07/28/20 6:00	0.7			1.7			3			0.36			0.1785			0.6		
07/28/20 7:00	0.7			1.7			3			0.37			0.18456			0.62		
07/28/20 8:00	0.8			1.7			3			0.4			0.19848			0.66		
07/28/20 9:00	0.8			1.7			1			0.51			0.25692			0.86		
07/28/20 10:00	0.5			1.7			2			0.65			0.3225			1.08		
07/28/20 11:00	0.3			1.7			3			0.68			0.33996			1.13		
07/28/20 12:00	0.2			1.7			3			0.69			0.34302			1.14		
07/28/20 13:00	0.2			1.7			4			0.75			0.37578			1.25		
07/28/20 14:00	0.1			1.7			3			0.72			0.36168			1.21		
07/28/20 15:00	0.1			1.7			3			0.71			0.35262			1.18		
07/28/20 16:00	0.1			1.7			3			0.69			0.3447			1.15		
07/28/20 17:00	0.1			1.7			3			0.68			0.34224			1.14		
07/28/20 18:00	0.6			1.7			2			0.59			0.29676			0.99		
07/28/20 19:00	0.7			1.7			2			0.59			0.29292			0.98		
07/28/20 20:00	0.5			1.7			2			0.62			0.30762			1.03		
07/28/20 21:00	0.8			1.7			2			0.43			0.21366			0.71		
07/28/20 22:00	0.7			1.7			2			0.37			0.18372			0.61		
07/28/20 23:00	0.8			1.7			3			0.4			0.20082			0.67		
07/29/20 0:00	0.7			1.7			2			0.36			0.17844			0.59		
07/29/20 1:00	0.7			1.7			3			0.36			0.17808			0.59		
07/29/20 2:00	0.7			1.7			2			0.36			0.17778			0.59		
07/29/20 3:00	0.7			1.7			2			0.36			0.17796			0.59		
07/29/20 4:00	0.7			1.7			2			0.36			0.17784			0.59		
07/29/20 5:00	0.7			1.7			2			0.36			0.17796			0.59		
07/29/20 6:00	0.7			1.7			3			0.36			0.1785			0.6		
07/29/20 7:00	0.7			1.7			3			0.36			0.17898			0.6		
07/29/20 8:00	0.7			1.7			3			0.37			0.18306			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/29/20 9:00	0.8			1.7			3			0.38			0.19188			0.64		
07/29/20 10:00	0.8			1.7			2			0.5			0.24972			0.83		
07/29/20 11:00	0.9			1.7			2			0.59			0.29418			0.98		
07/29/20 12:00	0.2			1.7			3			0.71			0.35466			1.18		
07/29/20 13:00	0.1			1.7			4			0.75			0.37446			1.25		
07/29/20 14:00	0.1			1.7			4			0.75			0.3747			1.25		
07/29/20 15:00	0.1			1.7			4			0.75			0.37398			1.25		
07/29/20 16:00	0.1			1.7			4			0.75			0.37446			1.25		
07/29/20 17:00	0.1			1.7			4			0.75			0.37356			1.25		
07/29/20 18:00	0.1			1.7			4			0.74			0.3699			1.23		
07/29/20 19:00	1.1			1.7			2			0.55			0.27552			0.92		
07/29/20 20:00	0.4			1.7			3			0.65			0.32556			1.09		
07/29/20 21:00	0.8			1.7			3			0.42			0.20904			0.7		
07/29/20 22:00	0.7			1.7			2			0.43			0.21456			0.72		
07/29/20 23:00	0.8			1.7			3			0.37			0.18678			0.62		
07/30/20 0:00	0.7			1.7			2			0.36			0.17814			0.59		
07/30/20 1:00	0.7			1.7			2			0.36			0.17826			0.59		
07/30/20 2:00	0.6			1.7			2			0.36			0.17838			0.59		
07/30/20 3:00	0.7			1.7			2			0.36			0.17844			0.59		
07/30/20 4:00	0	X		0	X		0	X		0.36			0.17838			0.59		
07/30/20 5:00	0	X		0	X		0	X		0.36			0.17862			0.6		
07/30/20 6:00	0.8			1.6			2			0.36			0.17904			0.6		
07/30/20 7:00	0.6			1.7			2			0.36			0.17928			0.6		
07/30/20 8:00	0.6			1.7			2			0.36			0.17874			0.6		
07/30/20 9:00	0.7			1.7			3			0.37			0.18654			0.62		
07/30/20 10:00	0.7			1.7			2			0.45			0.22662			0.76		
07/30/20 11:00	0.6			1.7			2			0.62			0.31158			1.04		
07/30/20 12:00	0.8			1.7			2			0.6			0.29856			1		
07/30/20 13:00	0.4			1.7			2			0.65			0.32466			1.08		
07/30/20 14:00	0.2			1.7			3			0.71			0.35328			1.18		
07/30/20 15:00	0.1			1.7			3			0.72			0.35916			1.2		
07/30/20 16:00	0.1			1.7			4			0.75			0.3741			1.25		
07/30/20 17:00	0.1			1.7			4			0.75			0.37374			1.25		
07/30/20 18:00	0.1			1.7			3			0.71			0.35484			1.18		
07/30/20 19:00	0.4			1.7			2			0.65			0.32712			1.09		
07/30/20 20:00	0.5			1.7			2			0.64			0.31896			1.06		
07/30/20 21:00	0.7			1.8			2			0.5			0.2481			0.83		
07/30/20 22:00	0.7			1.7			2			0.47			0.23442			0.78		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/30/20 23:00	0.8			1.7			3			0.38			0.18822			0.63		
07/31/20 0:00	0.7			1.7			2			0.36			0.1782			0.59		
07/31/20 1:00	0.7			1.7			2			0.36			0.1785			0.6		
07/31/20 2:00	0.7			1.7			2			0.36			0.17844			0.59		
07/31/20 3:00	0.7			1.7			2			0.36			0.1782			0.59		
07/31/20 4:00	0.7			1.7			2			0.36			0.17832			0.59		
07/31/20 5:00	0.7			1.7			3			0.36			0.17832			0.59		
07/31/20 6:00	0.7			1.7			3			0.36			0.17898			0.6		
07/31/20 7:00	0.7			1.7			2			0.36			0.17928			0.6		
07/31/20 8:00	0.6			1.7			3			0.36			0.17868			0.6		
07/31/20 9:00	0.7			1.7			3			0.37			0.18648			0.62		
07/31/20 10:00	0.7			1.7			2			0.44			0.22044			0.73		
07/31/20 11:00	0.4			1.7			2			0.67			0.33432			1.11		
07/31/20 12:00	0.6			1.7			2			0.62			0.309			1.03		
07/31/20 13:00	0.4			1.7			3			0.67			0.33264			1.11		
07/31/20 14:00	0.1			1.7			4			0.75			0.37572			1.25		
07/31/20 15:00	0.4			1.7			3			0.66			0.32862			1.1		
07/31/20 16:00	0.4			1.7			3			0.65			0.3237			1.08		
07/31/20 17:00	0.2			1.7			3			0.7			0.35172			1.17		
07/31/20 18:00	0.2			1.7			3			0.68			0.34062			1.14		
07/31/20 19:00	0.3			1.7			3			0.67			0.33648			1.12		
07/31/20 20:00	0.7			1.7			2			0.59			0.29388			0.98		
07/31/20 21:00	0.7			1.8			3			0.44			0.21906			0.73		
07/31/20 22:00	0.7			1.7			3			0.43			0.21252			0.71		
07/31/20 23:00	0.6			1.7			2			0.36			0.18132			0.6		
08/01/20 0:00	0.7			1.7			2			0.36			0.1782			0.59		
08/01/20 1:00	0.7			1.7			2			0.36			0.1782			0.59		
08/01/20 2:00	0.6			1.7			3			0.36			0.17802			0.59		
08/01/20 3:00	0.7			1.7			2			0.36			0.17808			0.59		
08/01/20 4:00	0.7			1.7			2			0.36			0.17796			0.59		
08/01/20 5:00	0.7			1.7			3			0.36			0.17826			0.59		
08/01/20 6:00	0.7			1.7			3			0.36			0.17862			0.6		
08/01/20 7:00	0.6			1.7			2			0.36			0.1791			0.6		
08/01/20 8:00	0.7			1.7			3			0.36			0.17922			0.6		
08/01/20 9:00	0.8			1.7			3			0.39			0.19674			0.66		
08/01/20 10:00	0.7			1.7			3			0.43			0.21276			0.71		
08/01/20 11:00	0.7			1.7			2			0.43			0.21432			0.71		
08/01/20 12:00	0.7			1.7			2			0.45			0.22272			0.74		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/01/20 13:00	0.7			1.7			1			0.47			0.23652			0.79		
08/01/20 14:00	0.7			1.7			2			0.46			0.2289			0.76		
08/01/20 15:00	0.3			1.7			4			0.75			0.37428			1.25		
08/01/20 16:00	0.1			1.7			4			0.74			0.37158			1.24		
08/01/20 17:00	0.1			1.7			4			0.74			0.3696			1.23		
08/01/20 18:00	0.1			1.7			3			0.71			0.35388			1.18		
08/01/20 19:00	0.3			1.7			3			0.67			0.3357			1.12		
08/01/20 20:00	1			1.7			2			0.58			0.28776			0.96		
08/01/20 21:00	1.4			1.7			2			0.53			0.26748			0.89		
08/01/20 22:00	0.8			1.7			3			0.44			0.22074			0.74		
08/01/20 23:00	0.8			1.7			3			0.39			0.1968			0.66		
08/02/20 0:00	0.7			1.7			2			0.36			0.17766			0.59		
08/02/20 1:00	0.7			1.7			3			0.35			0.17724			0.59		
08/02/20 2:00	0.7			1.7			2			0.35			0.17724			0.59		
08/02/20 3:00	0.7			1.7			2			0.35			0.17724			0.59		
08/02/20 4:00	0.7			1.7			2			0.36			0.17778			0.59		
08/02/20 5:00	0.9			1.7			3			0.38			0.18996			0.63		
08/02/20 6:00	0.8			1.7			3			0.38			0.18768			0.63		
08/02/20 7:00	0.7			1.7			3			0.37			0.18408			0.61		
08/02/20 8:00	0.6			1.7			3			0.36			0.17754			0.59		
08/02/20 9:00	0.6			1.7			3			0.36			0.17766			0.59		
08/02/20 10:00	0.7			1.7			3			0.36			0.17778			0.59		
08/02/20 11:00	0.7			1.7			2			0.43			0.21294			0.71		
08/02/20 12:00	0.7			1.7			1			0.47			0.23544			0.78		
08/02/20 13:00	0.4			1.7			2			0.67			0.33354			1.11		
08/02/20 14:00	0.3			1.7			2			0.66			0.33204			1.11		
08/02/20 15:00	0.1			1.7			4			0.74			0.3723			1.24		
08/02/20 16:00	0.2			1.7			3			0.68			0.34152			1.14		
08/02/20 17:00	0.1			1.7			4			0.73			0.3627			1.21		
08/02/20 18:00	0.2			1.7			3			0.67			0.33552			1.12		
08/02/20 19:00	0.3			1.7			3			0.66			0.32946			1.1		
08/02/20 20:00	0.5			1.7			2			0.62			0.31122			1.04		
08/02/20 21:00	0.7			1.8			2			0.48			0.2394			0.8		
08/02/20 22:00	0.8			1.6			3			0.39			0.1956			0.65		
08/02/20 23:00	0.7			1.6			3			0.44			0.21786			0.73		
08/03/20 0:00	0.7			1.7			2			0.36			0.1791			0.6		
08/03/20 1:00	0.7			1.7			2			0.36			0.17766			0.59		
08/03/20 2:00	0.7			1.7			2			0.36			0.17766			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/03/20 3:00	0.7			1.7			2			0.36			0.1776			0.59		
08/03/20 4:00	0.7			1.7			2			0.35			0.17742			0.59		
08/03/20 5:00	0.7			1.7			3			0.36			0.1779			0.59		
08/03/20 6:00	0.7			1.7			3			0.36			0.17838			0.59		
08/03/20 7:00	0.7			1.7			3			0.36			0.17922			0.6		
08/03/20 8:00	0.7			1.7			3			0.37			0.18372			0.61		
08/03/20 9:00	0.7			1.7			3			0.36			0.17904			0.6		
08/03/20 10:00	0.7			1.7			1			0.48			0.24048			0.8		
08/03/20 11:00	0.7			1.7			1			0.52			0.25884			0.86		
08/03/20 12:00	0.7			1.7			2			0.61			0.30618			1.02		
08/03/20 13:00	0.5			1.7			2			0.63			0.31416			1.05		
08/03/20 14:00	0.1			1.7			4			0.74			0.36996			1.23		
08/03/20 15:00	0.1			1.7			3			0.72			0.35922			1.2		
08/03/20 16:00	0.1			1.7			3			0.71			0.357			1.19		
08/03/20 17:00	0.1			1.7			3			0.72			0.35922			1.2		
08/03/20 18:00	0.1			1.7			4			0.75			0.37464			1.25		
08/03/20 19:00	0.4			1.7			2			0.63			0.31518			1.05		
08/03/20 20:00	0.8			1.8			2			0.44			0.21906			0.73		
08/03/20 21:00	0.7			1.7			2			0.46			0.22992			0.77		
08/03/20 22:00	0.7			1.7			3			0.37			0.18654			0.62		
08/03/20 23:00	0.8			1.7			2			0.4			0.19884			0.66		
08/04/20 0:00	0.6			1.7			2			0.36			0.17784			0.59		
08/04/20 1:00	0.7			1.7			2			0.36			0.17778			0.59		
08/04/20 2:00	0.7			1.7			2			0.36			0.1776			0.59		
08/04/20 3:00	0.7			1.7			2			0.35			0.17748			0.59		
08/04/20 4:00	0.7			1.7			2			0.36			0.1776			0.59		
08/04/20 5:00	0.7			1.7			2			0.36			0.17784			0.59		
08/04/20 6:00	0.7			1.7			2			0.36			0.17808			0.59		
08/04/20 7:00	0.7			1.7			2			0.36			0.17874			0.6		
08/04/20 8:00	0.8			1.7			3			0.39			0.19266			0.64		
08/04/20 9:00	0.7			1.7			2			0.43			0.21294			0.71		
08/04/20 10:00	0.7			1.7			2			0.43			0.21384			0.71		
08/04/20 11:00	0.9			1.7			1			0.51			0.25578			0.85		
08/04/20 12:00	0.5			1.7			2			0.63			0.3156			1.05		
08/04/20 13:00	0.6			1.7			2			0.62			0.30756			1.03		
08/04/20 14:00	0.2			1.7			3			0.71			0.3528			1.18		
08/04/20 15:00	0.1			1.7			4			0.75			0.37494			1.25		
08/04/20 16:00	0.1			1.7			4			0.75			0.37392			1.25		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/04/20 17:00	0.1			1.7			4			0.75			0.37452			1.25		
08/04/20 18:00	0.1			1.7			4			0.74			0.36756			1.23		
08/04/20 19:00	1.1			1.8			1			0.53			0.26628			0.89		
08/04/20 20:00	0.7			1.8			3			0.45			0.2271			0.76		
08/04/20 21:00	0.7			1.7			2			0.36			0.17856			0.6		
08/04/20 22:00	0.7			1.7			2			0.36			0.17808			0.59		
08/04/20 23:00	0.8			1.7			3			0.38			0.19068			0.64		
08/05/20 0:00	0.6			1.7			2			0.36			0.1776			0.59		
08/05/20 1:00	0.6			1.7			2			0.36			0.17754			0.59		
08/05/20 2:00	0.6			1.7			2			0.36			0.17754			0.59		
08/05/20 3:00	0.6			1.7			2			0.35			0.17748			0.59		
08/05/20 4:00	0.6			1.7			2			0.35			0.17748			0.59		
08/05/20 5:00	0.7			1.7			3			0.35			0.17748			0.59		
08/05/20 6:00	0.6			1.7			2			0.36			0.1779			0.59		
08/05/20 7:00	0.6			1.7			2			0.36			0.1779			0.59		
08/05/20 8:00	0.6			1.7			2			0.36			0.17784			0.59		
08/05/20 9:00	0.7			1.7			2			0.36			0.17958			0.6		
08/05/20 10:00	0.8			1.7			3			0.38			0.19116			0.64		
08/05/20 11:00	0.9			1.7			1			0.5			0.24822			0.83		
08/05/20 12:00	0.7			1.7			2			0.61			0.3039			1.01		
08/05/20 13:00	0.5			1.7			2			0.64			0.31788			1.06		
08/05/20 14:00	0.4			1.7			2			0.65			0.32622			1.09		
08/05/20 15:00	0.4			1.7			2			0.66			0.32952			1.1		
08/05/20 16:00	0.4			1.7			2			0.64			0.32166			1.07		
08/05/20 17:00	0.9			1.7			2			0.59			0.29376			0.98		
08/05/20 18:00	0.6			1.7			2			0.61			0.30672			1.02		
08/05/20 19:00	0.8			1.8			3			0.4			0.20124			0.67		
08/05/20 20:00	0.8			1.7			3			0.41			0.20304			0.68		
08/05/20 21:00	0.8			1.7			3			0.39			0.19338			0.64		
08/05/20 22:00	0.8			1.7			2			0.43			0.21318			0.71		
08/05/20 23:00	0			0			0	X		0.21			0.10476			0.35		
08/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
08/08/20 22:00	0			0			0	X		0.2			0.10056			0.34		
08/08/20 23:00	0.8			1.6			3			0.4			0.20004			0.67		
08/09/20 0:00	0.7			1.7			2			0.36			0.17772			0.59		
08/09/20 1:00	0.7			1.7			2			0.35			0.17748			0.59		
08/09/20 2:00	0.7			1.7			2			0.36			0.17754			0.59		
08/09/20 3:00	0.7			1.7			2			0.36			0.17754			0.59		
08/09/20 4:00	0.7			1.7			2			0.36			0.17754			0.59		
08/09/20 5:00	0.6			1.7			2			0.36			0.17772			0.59		
08/09/20 6:00	0.7			1.7			2			0.36			0.17766			0.59		
08/09/20 7:00	0.7			1.7			3			0.36			0.17934			0.6		
08/09/20 8:00	0.8			1.7			2			0.39			0.19554			0.65		
08/09/20 9:00	0.7			1.7			1			0.49			0.24378			0.81		
08/09/20 10:00	0.6			1.7			2			0.63			0.31416			1.05		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/09/20 11:00	0.3			1.7			3			0.68			0.3417			1.14		
08/09/20 12:00	0.1			1.7			4			0.74			0.37008			1.23		
08/09/20 13:00	0.1			1.7			4			0.75			0.37404			1.25		
08/09/20 14:00	0.2			1.7			4			0.75			0.37476			1.25		
08/09/20 15:00	0.1			1.7			4			0.74			0.37128			1.24		
08/09/20 16:00	0.1			1.7			4			0.72			0.3618			1.21		
08/09/20 17:00	0.1			1.7			4			0.74			0.37122			1.24		
08/09/20 18:00	0.4			1.7			3			0.66			0.32808			1.09		
08/09/20 19:00	0.2			1.7			4			0.75			0.37278			1.24		
08/09/20 20:00	0.2			1.7			3			0.69			0.34506			1.15		
08/09/20 21:00	0.5			1.7			2			0.62			0.30978			1.03		
08/09/20 22:00	0.6			1.7			2			0.59			0.29358			0.98		
08/09/20 23:00	0.8			1.8			3			0.42			0.21018			0.7		
08/10/20 0:00	0.9			1.7			3			0.38			0.1902			0.63		
08/10/20 1:00	0.7			1.7			3			0.36			0.17826			0.59		
08/10/20 2:00	0.7			1.7			3			0.35			0.17736			0.59		
08/10/20 3:00	0.7			1.7			3			0.36			0.17784			0.59		
08/10/20 4:00	0.8			1.6			2			0.36			0.18			0.6		
08/10/20 5:00	0.7			1.7			3			0.35			0.17718			0.59		
08/10/20 6:00	0.7			1.7			3			0.36			0.17754			0.59		
08/10/20 7:00	0.7			1.7			3			0.37			0.183			0.61		
08/10/20 8:00	0.8			1.7			2			0.41			0.20598			0.69		
08/10/20 9:00	0.8			1.7			1			0.49			0.24384			0.81		
08/10/20 10:00	0.6			1.7			2			0.62			0.31206			1.04		
08/10/20 11:00	0.2			1.7			3			0.71			0.35286			1.18		
08/10/20 12:00	0.2			1.7			4			0.75			0.37446			1.25		
08/10/20 13:00	0.2			1.7			4			0.75			0.375			1.25		
08/10/20 14:00	0.2			1.7			4			0.75			0.37392			1.25		
08/10/20 15:00	0.2			1.7			4			0.74			0.37104			1.24		
08/10/20 16:00	0.2			1.7			4			0.74			0.36972			1.23		
08/10/20 17:00	0.2			1.7			4			0.73			0.36552			1.22		
08/10/20 18:00	0.5			1.7			2			0.6			0.30072			1		
08/10/20 19:00	0.7			1.8			2			0.46			0.23004			0.77		
08/10/20 20:00	0.7			1.7			2			0.45			0.22524			0.75		
08/10/20 21:00	0.7			1.7			2			0.47			0.2331			0.78		
08/10/20 22:00	0.8			1.7			3			0.44			0.22242			0.74		
08/10/20 23:00	0.8			1.7			3			0.43			0.21432			0.71		
08/11/20 0:00	0.7			1.7			2			0.36			0.17778			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/11/20 1:00	0.7			1.7			2			0.36			0.17796			0.59		
08/11/20 2:00	0.7			1.7			2			0.36			0.17796			0.59		
08/11/20 3:00	0.7			1.7			2			0.36			0.1779			0.59		
08/11/20 4:00	0.7			1.7			2			0.36			0.1779			0.59		
08/11/20 5:00	0.7			1.7			2			0.36			0.1779			0.59		
08/11/20 6:00	0.7			1.7			3			0.36			0.17826			0.59		
08/11/20 7:00	0.7			1.7			2			0.36			0.17916			0.6		
08/11/20 8:00	0.8			1.7			3			0.39			0.19254			0.64		
08/11/20 9:00	0.8			1.7			3			0.4			0.2016			0.67		
08/11/20 10:00	0.7			1.7			2			0.48			0.23976			0.8		
08/11/20 11:00	1.2			1.7			2			0.55			0.27294			0.91		
08/11/20 12:00	0.4			1.7			2			0.65			0.32334			1.08		
08/11/20 13:00	0.6			1.7			2			0.61			0.30336			1.01		
08/11/20 14:00	0.7			1.7			2			0.6			0.29778			0.99		
08/11/20 15:00	0.6			1.7			2			0.6			0.30246			1.01		
08/11/20 16:00	0.5			1.7			2			0.61			0.30342			1.01		
08/11/20 17:00	0.8			1.7			2			0.59			0.29268			0.98		
08/11/20 18:00	0.9			1.7			2			0.58			0.2883			0.96		
08/11/20 19:00	0.8			1.7			2			0.48			0.23862			0.8		
08/11/20 20:00	0.7			1.7			2			0.47			0.23304			0.78		
08/11/20 21:00	0.7			1.7			1			0.51			0.25392			0.85		
08/11/20 22:00	0.8			1.7			3			0.42			0.20958			0.7		
08/11/20 23:00	0.8			1.7			3			0.37			0.18354			0.61		
08/12/20 0:00	0.7			1.7			2			0.35			0.17724			0.59		
08/12/20 1:00	0.8			1.7			3			0.35			0.17736			0.59		
08/12/20 2:00	0.7			1.7			2			0.36			0.17772			0.59		
08/12/20 3:00	0.7			1.7			2			0.36			0.17784			0.59		
08/12/20 4:00	0.7			1.7			2			0.36			0.1776			0.59		
08/12/20 5:00	0.7			1.7			2			0.36			0.1776			0.59		
08/12/20 6:00	0.7			1.7			3			0.36			0.17838			0.59		
08/12/20 7:00	0.7			1.7			2			0.36			0.17988			0.6		
08/12/20 8:00	0.7			1.7			2			0.36			0.1788			0.6		
08/12/20 9:00	0.8			1.7			3			0.39			0.19542			0.65		
08/12/20 10:00	0.7			1.7			2			0.46			0.2277			0.76		
08/12/20 11:00	0.4			1.7			2			0.66			0.32904			1.1		
08/12/20 12:00	0.1			1.7			3			0.72			0.3624			1.21		
08/12/20 13:00	0.1			1.7			4			0.74			0.37062			1.24		
08/12/20 14:00	0.1			1.7			4			0.74			0.3705			1.24		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/12/20 15:00	0.1			1.7			4			0.74			0.37032			1.23		
08/12/20 16:00	0.1			1.7			4			0.74			0.36978			1.23		
08/12/20 17:00	0.1			1.7			4			0.74			0.36996			1.23		
08/12/20 18:00	0.1			1.7			4			0.74			0.36768			1.23		
08/12/20 19:00	0.2			1.7			3			0.68			0.33864			1.13		
08/12/20 20:00	0.8			1.7			2			0.59			0.29298			0.98		
08/12/20 21:00	0.7			1.7			2			0.59			0.297			0.99		
08/12/20 22:00	1.4			1.7			2			0.54			0.27048			0.9		
08/12/20 23:00	0.9			1.8			2			0.47			0.23646			0.79		
08/13/20 0:00	0.8			1.7			3			0.38			0.18846			0.63		
08/13/20 1:00	0.8			1.7			3			0.35			0.1773			0.59		
08/13/20 2:00	0.7			1.7			3			0.36			0.17766			0.59		
08/13/20 3:00	0.7			1.7			3			0.35			0.17748			0.59		
08/13/20 4:00	0.7			1.7			3			0.35			0.17724			0.59		
08/13/20 5:00	0.7			1.7			3			0.35			0.1773			0.59		
08/13/20 6:00	0.8			1.7			3			0.37			0.1833			0.61		
08/13/20 7:00	0.7			1.7			3			0.36			0.18198			0.61		
08/13/20 8:00	0.8			1.7			3			0.38			0.18942			0.63		
08/13/20 9:00	0.7			1.7			2			0.44			0.22056			0.74		
08/13/20 10:00	1			1.7			2			0.55			0.27696			0.92		
08/13/20 11:00	0.2			1.7			3			0.71			0.35568			1.19		
08/13/20 12:00	0.1			1.7			4			0.73			0.36636			1.22		
08/13/20 13:00	0.1			1.7			4			0.74			0.36792			1.23		
08/13/20 14:00	0.1			1.7			4			0.74			0.3678			1.23		
08/13/20 15:00	0.1			1.7			3			0.7			0.34974			1.17		
08/13/20 16:00	0.1			1.7			3			0.68			0.34194			1.14		
08/13/20 17:00	0.1			1.7			4			0.72			0.36246			1.21		
08/13/20 18:00	0.2			1.7			3			0.67			0.3342			1.11		
08/13/20 19:00	0.9			1.7			2			0.57			0.2844			0.95		
08/13/20 20:00	1.3			1.7			2			0.53			0.26622			0.89		
08/13/20 21:00	0.3			1.7			3			0.7			0.34872			1.16		
08/13/20 22:00	0.2			1.7			3			0.71			0.3528			1.18		
08/13/20 23:00	0.8			1.8			3			0.45			0.22518			0.75		
08/14/20 0:00	0.8			1.7			3			0.36			0.1821			0.61		
08/14/20 1:00	0.8			1.7			3			0.36			0.17826			0.59		
08/14/20 2:00	0.7			1.7			3			0.36			0.17778			0.59		
08/14/20 3:00	0.7			1.7			3			0.36			0.1776			0.59		
08/14/20 4:00	0.9			1.7			3			0.37			0.18486			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/14/20 5:00	1.1			1.7			2			0.41			0.20574			0.69		
08/14/20 6:00	1.2			1.7			2			0.49			0.24408			0.81		
08/14/20 7:00	1.2			1.7			2			0.57			0.28524			0.95		
08/14/20 8:00	0.2			1.7			4			0.73			0.36612			1.22		
08/14/20 9:00	0.2			1.7			4			0.74			0.37056			1.24		
08/14/20 10:00	0.2			1.7			4			0.74			0.37164			1.24		
08/14/20 11:00	0.3			1.7			3			0.68			0.3423			1.14		
08/14/20 12:00	0.4			1.7			2			0.64			0.32232			1.07		
08/14/20 13:00	0.4			1.7			2			0.65			0.32466			1.08		
08/14/20 14:00	0.4			1.7			2			0.65			0.3231			1.08		
08/14/20 15:00	0.2			1.7			4			0.74			0.36954			1.23		
08/14/20 16:00	0.2			1.7			4			0.74			0.3717			1.24		
08/14/20 17:00	0.2			1.7			4			0.73			0.3666			1.22		
08/14/20 18:00	0.1			1.7			4			0.72			0.35934			1.2		
08/14/20 19:00	0.2			1.7			4			0.74			0.36846			1.23		
08/14/20 20:00	0.2			1.7			3			0.69			0.34428			1.15		
08/14/20 21:00	0.6			1.7			2			0.61			0.3057			1.02		
08/14/20 22:00	0.5			1.7			2			0.63			0.315			1.05		
08/14/20 23:00	0.9			1.8			2			0.42			0.2109			0.7		
08/15/20 0:00	0.8			1.7			3			0.38			0.18864			0.63		
08/15/20 1:00	0.9			1.7			2			0.39			0.19542			0.65		
08/15/20 2:00	0.7			1.7			2			0.36			0.1806			0.6		
08/15/20 3:00	0.7			1.7			2			0.36			0.1785			0.6		
08/15/20 4:00	0.7			1.7			2			0.36			0.17844			0.59		
08/15/20 5:00	0.8			1.7			2			0.36			0.1785			0.6		
08/15/20 6:00	0.8			1.7			2			0.42			0.21216			0.71		
08/15/20 7:00	0.7			1.7			1			0.48			0.24042			0.8		
08/15/20 8:00	0.4			1.7			3			0.68			0.34068			1.14		
08/15/20 9:00	0.2			1.7			4			0.75			0.37254			1.24		
08/15/20 10:00	0.2			1.7			4			0.74			0.3717			1.24		
08/15/20 11:00	0.2			1.7			4			0.74			0.3705			1.24		
08/15/20 12:00	0.2			1.7			3			0.68			0.3378			1.13		
08/15/20 13:00	0.3			1.7			2			0.64			0.32166			1.07		
08/15/20 14:00	0.1			1.7			4			0.72			0.35892			1.2		
08/15/20 15:00	0.2			1.7			3			0.66			0.32802			1.09		
08/15/20 16:00	0.1			1.7			3			0.69			0.34362			1.15		
08/15/20 17:00	0.1			1.7			3			0.7			0.34986			1.17		
08/15/20 18:00	0.2			1.7			3			0.7			0.35094			1.17		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/15/20 19:00	0.1			1.7			4			0.74			0.37128			1.24		
08/15/20 20:00	0.1			1.7			4			0.73			0.36426			1.21		
08/15/20 21:00	0.1			1.7			4			0.72			0.35946			1.2		
08/15/20 22:00	0.2			1.7			4			0.73			0.36648			1.22		
08/15/20 23:00	0.9			1.7			2			0.57			0.28518			0.95		
08/16/20 0:00	0.9			1.7			2			0.44			0.22224			0.74		
08/16/20 1:00	0.8			1.8			2			0.43			0.21666			0.72		
08/16/20 2:00	0.8			1.7			2			0.41			0.20268			0.68		
08/16/20 3:00	0.9			1.7			2			0.38			0.18894			0.63		
08/16/20 4:00	0.8			1.7			3			0.37			0.18288			0.61		
08/16/20 5:00	0.9			1.7			3			0.41			0.20538			0.68		
08/16/20 6:00	0.8			1.7			2			0.43			0.21444			0.71		
08/16/20 7:00	0.7			1.7			2			0.45			0.22674			0.76		
08/16/20 8:00	0.7			1.7			2			0.44			0.2187			0.73		
08/16/20 9:00	0.8			1.6			2			0.57			0.28326			0.94		
08/16/20 10:00	0.7			1.7			2			0.59			0.29598			0.99		
08/16/20 11:00	0.6			1.7			2			0.6			0.29802			0.99		
08/16/20 12:00	0.8			1.7			2			0.55			0.27702			0.92		
08/16/20 13:00	0.4			1.7			2			0.63			0.31428			1.05		
08/16/20 14:00	0.1			1.7			4			0.73			0.36678			1.22		
08/16/20 15:00	0.1			1.7			4			0.71			0.3573			1.19		
08/16/20 16:00	0.1			1.7			3			0.7			0.34776			1.16		
08/16/20 17:00	0.3			1.7			3			0.66			0.33054			1.1		
08/16/20 18:00	0.7			1.7			2			0.59			0.29544			0.98		
08/16/20 19:00	0.5			1.7			2			0.64			0.3207			1.07		
08/16/20 20:00	0.2			1.7			4			0.74			0.3693			1.23		
08/16/20 21:00	0.2			1.7			3			0.69			0.34434			1.15		
08/16/20 22:00	0.2			1.7			3			0.69			0.34452			1.15		
08/16/20 23:00	0.8			1.8			2			0.54			0.26904			0.9		
08/17/20 0:00	0.9			1.7			2			0.43			0.21582			0.72		
08/17/20 1:00	1			1.7			2			0.4			0.20076			0.67		
08/17/20 2:00	1.3			1.7			2			0.4			0.19998			0.67		
08/17/20 3:00	1.3			1.7			2			0.39			0.19518			0.65		
08/17/20 4:00	1.2			1.7			2			0.38			0.1917			0.64		
08/17/20 5:00	1.1			1.7			2			0.44			0.22026			0.73		
08/17/20 6:00	1			1.7			1			0.5			0.2481			0.83		
08/17/20 7:00	0.6			1.7			2			0.64			0.3201			1.07		
08/17/20 8:00	0.2			1.7			3			0.74			0.36852			1.23		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/17/20 9:00	0.2			1.7			4			0.75			0.37482			1.25		
08/17/20 10:00	0.2			1.7			4			0.75			0.37482			1.25		
08/17/20 11:00	0.2			1.7			4			0.75			0.37368			1.25		
08/17/20 12:00	0.2			1.7			3			0.7			0.35202			1.17		
08/17/20 13:00	0.4			1.7			2			0.64			0.31788			1.06		
08/17/20 14:00	0.6			1.7			2			0.6			0.29796			0.99		
08/17/20 15:00	0.7			1.7			2			0.41			0.20364			0.68		
08/17/20 16:00	0.7			1.7			2			0.56			0.28134			0.94		
08/17/20 17:00	0.3			1.7			2			0.67			0.33318			1.11		
08/17/20 18:00	0.3			1.7			2			0.67			0.33318			1.11		
08/17/20 19:00	0.2			1.7			3			0.68			0.33966			1.13		
08/17/20 20:00	0.9			1.7			2			0.6			0.29934			1		
08/17/20 21:00	1.2			1.7			2			0.55			0.27408			0.91		
08/17/20 22:00	1			1.7			1			0.51			0.2562			0.85		
08/17/20 23:00	1			1.7			2			0.47			0.23316			0.78		
08/18/20 0:00	0.9			1.7			2			0.43			0.21366			0.71		
08/18/20 1:00	0.9			1.7			2			0.4			0.20214			0.67		
08/18/20 2:00	0.8			1.7			2			0.38			0.19188			0.64		
08/18/20 3:00	0.9			1.7			3			0.38			0.1917			0.64		
08/18/20 4:00	0.9			1.7			2			0.39			0.19638			0.65		
08/18/20 5:00	0.8			1.7			2			0.36			0.17856			0.6		
08/18/20 6:00	0.8			1.7			2			0.37			0.18318			0.61		
08/18/20 7:00	0.8			1.7			2			0.43			0.2148			0.72		
08/18/20 8:00	1.3			1.7			1			0.54			0.26844			0.89		
08/18/20 9:00	0.4			1.7			2			0.66			0.32868			1.1		
08/18/20 10:00	0.3			1.7			2			0.66			0.33036			1.1		
08/18/20 11:00	0.2			1.7			3			0.7			0.34782			1.16		
08/18/20 12:00	0.2			1.7			4			0.74			0.37062			1.24		
08/18/20 13:00	0.2			1.7			3			0.71			0.35262			1.18		
08/18/20 14:00	0.2			1.7			3			0.69			0.3435			1.15		
08/18/20 15:00	0.8			1.7			2			0.56			0.2778			0.93		
08/18/20 16:00	0.5			1.7			2			0.6			0.29766			0.99		
08/18/20 17:00	0.9			1.7			2			0.55			0.27696			0.92		
08/18/20 18:00	0.7			1.7			2			0.58			0.29232			0.97		
08/18/20 19:00	0.7			1.7			2			0.57			0.2835			0.95		
08/18/20 20:00	0.8			1.7			2			0.4			0.2013			0.67		
08/18/20 21:00	0.7			1.6			2			0.57			0.28644			0.95		
08/18/20 22:00	1.1			1.7			2			0.56			0.27918			0.93		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/18/20 23:00	1			1.7			2			0.55			0.27732			0.92		
08/19/20 0:00	0.8			1.8			1			0.48			0.24222			0.81		
08/19/20 1:00	0.8			1.7			2			0.45			0.22656			0.76		
08/19/20 2:00	0.8			1.7			2			0.42			0.2109			0.7		
08/19/20 3:00	0.9			1.7			3			0.39			0.1935			0.65		
08/19/20 4:00	0.8			1.7			2			0.42			0.21192			0.71		
08/19/20 5:00	0.9			1.7			2			0.42			0.21102			0.7		
08/19/20 6:00	0.8			1.7			2			0.47			0.23274			0.78		
08/19/20 7:00	1.3			1.7			2			0.55			0.27516			0.92		
08/19/20 8:00	0.3			1.7			2			0.67			0.3336			1.11		
08/19/20 9:00	0.5			1.7			2			0.63			0.31626			1.05		
08/19/20 10:00	0.2			1.7			4			0.73			0.36498			1.22		
08/19/20 11:00	0.2			1.7			4			0.74			0.36906			1.23		
08/19/20 12:00	0.2			1.7			4			0.74			0.37176			1.24		
08/19/20 13:00	0.2			1.7			3			0.69			0.34722			1.16		
08/19/20 14:00	0.9			1.8			2			0.56			0.28236			0.94		
08/19/20 15:00	1			1.7			2			0.56			0.28002			0.93		
08/19/20 16:00	0.6			1.7			2			0.62			0.30804			1.03		
08/19/20 17:00	0.2			1.7			4			0.72			0.36			1.2		
08/19/20 18:00	0.3			1.7			3			0.67			0.33732			1.12		
08/19/20 19:00	0.7			1.7			2			0.59			0.29712			0.99		
08/19/20 20:00	0.8			1.7			2			0.59			0.29532			0.98		
08/19/20 21:00	0.9			1.7			2			0.58			0.2919			0.97		
08/19/20 22:00	1			1.7			2			0.48			0.23856			0.8		
08/19/20 23:00	0.9			1.7			2			0.46			0.23046			0.77		
08/20/20 0:00	0.9			1.7			2			0.39			0.19644			0.65		
08/20/20 1:00	0.8			1.7			3			0.36			0.18084			0.6		
08/20/20 2:00	0.8			1.7			2			0.36			0.1779			0.59		
08/20/20 3:00	0.8			1.7			3			0.36			0.17754			0.59		
08/20/20 4:00	0.8			1.7			2			0.35			0.17742			0.59		
08/20/20 5:00	0.9			1.7			3			0.36			0.17964			0.6		
08/20/20 6:00	0.8			1.7			3			0.36			0.17976			0.6		
08/20/20 7:00	0.9			1.7			3			0.36			0.17844			0.59		
08/20/20 8:00	1.1			1.7			3			0.37			0.18732			0.62		
08/20/20 9:00	1.1			1.7			3			0.41			0.20682			0.69		
08/20/20 10:00	1.1			1.7			2			0.46			0.22968			0.77		
08/20/20 11:00	1.6			1.7			1			0.55			0.2727			0.91		
08/20/20 12:00	1.1			1.8			2			0.49			0.2472			0.82		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/20/20 13:00	1			1.7			1			0.5			0.25104			0.84		
08/20/20 14:00	1.1			1.7			2			0.42			0.20862			0.7		
08/20/20 15:00	1.1			1.7			2			0.54			0.2709			0.9		
08/20/20 16:00	1.3			1.8			2			0.45			0.22428			0.75		
08/20/20 17:00	1.2			1.7			2			0.48			0.24174			0.81		
08/20/20 18:00	1.3			1.7			2			0.55			0.27582			0.92		
08/20/20 19:00	1.1			1.7			2			0.43			0.21534			0.72		
08/20/20 20:00	1.1			1.7			2			0.44			0.21912			0.73		
08/20/20 21:00	0.9			1.7			2			0.45			0.2229			0.74		
08/20/20 22:00	0.9			1.7			2			0.38			0.18768			0.63		
08/20/20 23:00	0.8			1.7			2			0.36			0.17802			0.59		
08/21/20 0:00	0.8			1.7			2			0.35			0.17742			0.59		
08/21/20 1:00	0.8			1.7			2			0.35			0.1773			0.59		
08/21/20 2:00	0.8			1.7			2			0.35			0.17724			0.59		
08/21/20 3:00	0.8			1.7			3			0.37			0.18354			0.61		
08/21/20 4:00	0.8			1.7			2			0.36			0.1803			0.6		
08/21/20 5:00	0.8			1.7			2			0.35			0.17724			0.59		
08/21/20 6:00	0.9			1.7			3			0.39			0.19446			0.65		
08/21/20 7:00	0.9			1.7			2			0.43			0.21564			0.72		
08/21/20 8:00	0.9			1.7			2			0.42			0.21024			0.7		
08/21/20 9:00	0.8			1.7			2			0.45			0.22458			0.75		
08/21/20 10:00	0.8			1.7			2			0.49			0.24408			0.81		
08/21/20 11:00	1.2			1.7			2			0.51			0.25566			0.85		
08/21/20 12:00	1.1			1.7			2			0.49			0.24504			0.82		
08/21/20 13:00	0.4			1.7			3			0.7			0.35196			1.17		
08/21/20 14:00	0.4			1.7			3			0.66			0.32754			1.09		
08/21/20 15:00	0.2			1.7			3			0.7			0.35148			1.17		
08/21/20 16:00	0.2			1.7			4			0.74			0.36966			1.23		
08/21/20 17:00	0.2			1.7			4			0.74			0.37002			1.23		
08/21/20 18:00	0.3			1.7			4			0.74			0.36948			1.23		
08/21/20 19:00	0.9			1.7			1			0.49			0.24462			0.82		
08/21/20 20:00	0.9			1.7			2			0.43			0.21474			0.72		
08/21/20 21:00	0.5			1.7			2			0.63			0.31488			1.05		
08/21/20 22:00	0.4			1.7			2			0.63			0.31302			1.04		
08/21/20 23:00	0.9			1.8			3			0.41			0.20616			0.69		
08/22/20 0:00	0.7			1.7			2			0.36			0.17772			0.59		
08/22/20 1:00	0.9			1.7			3			0.38			0.19134			0.64		
08/22/20 2:00	1			1.7			3			0.37			0.18654			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/22/20 3:00	0.9			1.7			2			0.36			0.17814			0.59		
08/22/20 4:00	0.9			1.7			2			0.35			0.17682			0.59		
08/22/20 5:00	1			1.7			3			0.35			0.17694			0.59		
08/22/20 6:00	1			1.7			3			0.36			0.18168			0.61		
08/22/20 7:00	1			1.7			3			0.39			0.19554			0.65		
08/22/20 8:00	0.9			1.7			3			0.38			0.19116			0.64		
08/22/20 9:00	0.9			1.7			2			0.44			0.21888			0.73		
08/22/20 10:00	0.8			1.7			1			0.49			0.2463			0.82		
08/22/20 11:00	1.1			1.7			2			0.57			0.28428			0.95		
08/22/20 12:00	1.4			1.7			2			0.52			0.26106			0.87		
08/22/20 13:00	1.2			1.7			2			0.5			0.25014			0.83		
08/22/20 14:00	1.2			1.7			2			0.51			0.2571			0.86		
08/22/20 15:00	0.8			1.7			2			0.58			0.2913			0.97		
08/22/20 16:00	0.2			1.7			3			0.69			0.34674			1.16		
08/22/20 17:00	0.2			1.7			4			0.73			0.36696			1.22		
08/22/20 18:00	0.2			1.7			4			0.72			0.36138			1.2		
08/22/20 19:00	0.5			1.7			2			0.61			0.30714			1.02		
08/22/20 20:00	0.7			1.7			2			0.6			0.30018			1		
08/22/20 21:00	1.1			1.7			2			0.55			0.27492			0.92		
08/22/20 22:00	0.9			1.7			2			0.5			0.24828			0.83		
08/22/20 23:00	0.9			1.7			3			0.44			0.21828			0.73		
08/23/20 0:00	0.9			1.7			3			0.38			0.18864			0.63		
08/23/20 1:00	0.8			1.7			3			0.36			0.17868			0.6		
08/23/20 2:00	0.8			1.7			3			0.35			0.17706			0.59		
08/23/20 3:00	0.8			1.7			3			0.35			0.17718			0.59		
08/23/20 4:00	0.8			1.6			2			0.35			0.17724			0.59		
08/23/20 5:00	0.9			1.7			3			0.35			0.17724			0.59		
08/23/20 6:00	0.8			1.7			3			0.35			0.1773			0.59		
08/23/20 7:00	0.8			1.7			3			0.36			0.17778			0.59		
08/23/20 8:00	0.8			1.7			3			0.37			0.18264			0.61		
08/23/20 9:00	0.8			1.7			2			0.45			0.22368			0.75		
08/23/20 10:00	1.4			1.7			1			0.52			0.25944			0.86		
08/23/20 11:00	0.5			1.7			3			0.66			0.32976			1.1		
08/23/20 12:00	0.2			1.7			3			0.71			0.35376			1.18		
08/23/20 13:00	0.2			1.7			3			0.7			0.35064			1.17		
08/23/20 14:00	0.4			1.7			3			0.66			0.32988			1.1		
08/23/20 15:00	0.4			1.7			3			0.65			0.32388			1.08		
08/23/20 16:00	0.3			1.7			3			0.67			0.33534			1.12		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/23/20 17:00	0.3			1.7			3			0.66			0.32778			1.09		
08/23/20 18:00	0.6			1.7			2			0.61			0.30372			1.01		
08/23/20 19:00	1.1			1.7			2			0.52			0.25896			0.86		
08/23/20 20:00	0.8			1.7			2			0.5			0.252			0.84		
08/23/20 21:00	0.8			1.7			2			0.58			0.2901			0.97		
08/23/20 22:00	1.1			1.7			2			0.53			0.26472			0.88		
08/23/20 23:00	0.9			1.7			3			0.42			0.21012			0.7		
08/24/20 0:00	1			1.7			3			0.37			0.18678			0.62		
08/24/20 1:00	0.9			1.7			2			0.36			0.17802			0.59		
08/24/20 2:00	0.8			1.7			2			0.36			0.17778			0.59		
08/24/20 3:00	0.8			1.7			2			0.36			0.17772			0.59		
08/24/20 4:00	1			1.7			2			0.38			0.18792			0.63		
08/24/20 5:00	1			1.7			3			0.37			0.18426			0.61		
08/24/20 6:00	1			1.7			2			0.39			0.19602			0.65		
08/24/20 7:00	1			1.7			2			0.44			0.21978			0.73		
08/24/20 8:00	1.2			1.7			2			0.54			0.26874			0.9		
08/24/20 9:00	0.5			1.7			2			0.64			0.31878			1.06		
08/24/20 10:00	0.4			1.7			3			0.66			0.32754			1.09		
08/24/20 11:00	0.2			1.7			4			0.73			0.36696			1.22		
08/24/20 12:00	0.3			1.7			3			0.68			0.34206			1.14		
08/24/20 13:00	0.5			1.7			2			0.63			0.31482			1.05		
08/24/20 14:00	0.4			1.7			3			0.66			0.32778			1.09		
08/24/20 15:00	0.5			1.7			2			0.62			0.30906			1.03		
08/24/20 16:00	0.4			1.7			3			0.66			0.32844			1.09		
08/24/20 17:00	0.4			1.7			3			0.66			0.32808			1.09		
08/24/20 18:00	0.5			1.7			2			0.62			0.30918			1.03		
08/24/20 19:00	1.1			1.7			2			0.52			0.26172			0.87		
08/24/20 20:00	0.8			1.7			2			0.47			0.23484			0.78		
08/24/20 21:00	1.1			1.7			2			0.54			0.26904			0.9		
08/24/20 22:00	0.9			1.7			2			0.55			0.276			0.92		
08/24/20 23:00	0.9			1.8			3			0.44			0.2199			0.73		
08/25/20 0:00	0.9			1.7			3			0.38			0.19134			0.64		
08/25/20 1:00	0.8			1.7			3			0.36			0.17778			0.59		
08/25/20 2:00	0.8			1.7			3			0.36			0.17766			0.59		
08/25/20 3:00	0.8			1.7			2			0.36			0.1776			0.59		
08/25/20 4:00	0.8			1.7			2			0.36			0.17772			0.59		
08/25/20 5:00	0.8			1.7			2			0.36			0.17772			0.59		
08/25/20 6:00	0.9			1.7			3			0.38			0.19176			0.64		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/25/20 7:00	0.9			1.7			2			0.4			0.20202			0.67		
08/25/20 8:00	0.8			1.7			2			0.46			0.22884			0.76		
08/25/20 9:00	1			1.7			1			0.51			0.25524			0.85		
08/25/20 10:00	0.7			1.7			2			0.6			0.29994			1		
08/25/20 11:00	0.3			1.7			3			0.67			0.33666			1.12		
08/25/20 12:00	0.6			1.7			2			0.6			0.29904			1		
08/25/20 13:00	0.6			1.7			2			0.6			0.29934			1		
08/25/20 14:00	0.6			1.7			2			0.6			0.30072			1		
08/25/20 15:00	0.4			1.7			3			0.65			0.32694			1.09		
08/25/20 16:00	0.3			1.7			3			0.67			0.33516			1.12		
08/25/20 17:00	0.2			1.7			4			0.73			0.36426			1.21		
08/25/20 18:00	0.4			1.7			3			0.64			0.32202			1.07		
08/25/20 19:00	0.7			1.7			2			0.59			0.29694			0.99		
08/25/20 20:00	1			1.8			2			0.49			0.24534			0.82		
08/25/20 21:00	0.8			1.7			2			0.49			0.24684			0.82		
08/25/20 22:00	0.8			1.7			2			0.47			0.2337			0.78		
08/25/20 23:00	0.8			1.7			3			0.37			0.18528			0.62		
08/26/20 0:00	0.7			1.7			2			0.36			0.17772			0.59		
08/26/20 1:00	0.8			1.7			3			0.36			0.17778			0.59		
08/26/20 2:00	0.8			1.7			3			0.35			0.17742			0.59		
08/26/20 3:00	0.8			1.7			3			0.35			0.17748			0.59		
08/26/20 4:00	0.8			1.7			2			0.36			0.17928			0.6		
08/26/20 5:00	0.9			1.7			3			0.36			0.17916			0.6		
08/26/20 6:00	0.8			1.7			3			0.36			0.17994			0.6		
08/26/20 7:00	0.9			1.7			3			0.4			0.1989			0.66		
08/26/20 8:00	0.9			1.7			2			0.43			0.21684			0.72		
08/26/20 9:00	0.8			1.7			2			0.47			0.2343			0.78		
08/26/20 10:00	1.2			1.7			2			0.56			0.28038			0.93		
08/26/20 11:00	0.3			1.7			3			0.66			0.33192			1.11		
08/26/20 12:00	0.2			1.7			4			0.72			0.35982			1.2		
08/26/20 13:00	0.2			1.7			4			0.73			0.36744			1.22		
08/26/20 14:00	0.2			1.7			4			0.73			0.36732			1.22		
08/26/20 15:00	0.2			1.7			4			0.73			0.36714			1.22		
08/26/20 16:00	0.2			1.7			4			0.74			0.36774			1.23		
08/26/20 17:00	0.2			1.7			4			0.73			0.36444			1.21		
08/26/20 18:00	0.7			1.7			2			0.59			0.29526			0.98		
08/26/20 19:00	1.2			1.7			2			0.5			0.25134			0.84		
08/26/20 20:00	0.8			1.7			2			0.48			0.23802			0.79		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/26/20 21:00	0.8			1.7			2			0.48			0.24186			0.81		
08/26/20 22:00	0.9			1.7			3			0.39			0.19344			0.64		
08/26/20 23:00	0.8			1.7			3			0.36			0.18246			0.61		
08/27/20 0:00	0.7			1.7			2			0.36			0.1776			0.59		
08/27/20 1:00	0.8			1.7			2			0.36			0.1776			0.59		
08/27/20 2:00	0.8			1.7			3			0.35			0.17748			0.59		
08/27/20 3:00	0.7			1.7			3			0.35			0.17742			0.59		
08/27/20 4:00	0.7			1.7			3			0.35			0.17748			0.59		
08/27/20 5:00	0.8			1.7			3			0.36			0.1776			0.59		
08/27/20 6:00	0.7			1.7			3			0.36			0.17784			0.59		
08/27/20 7:00	0.7			1.7			3			0.36			0.17874			0.6		
08/27/20 8:00	0.8			1.7			3			0.37			0.18552			0.62		
08/27/20 9:00	0.9			1.7			3			0.4			0.19962			0.67		
08/27/20 10:00	0.8			1.7			2			0.49			0.24408			0.81		
08/27/20 11:00	1			1.7			2			0.56			0.2799			0.93		
08/27/20 12:00	1			1.7			2			0.56			0.27804			0.93		
08/27/20 13:00	0.4			1.7			3			0.65			0.32664			1.09		
08/27/20 14:00	0.3			1.7			3			0.65			0.32616			1.09		
08/27/20 15:00	0.4			1.7			3			0.63			0.3147			1.05		
08/27/20 16:00	0.3			1.7			3			0.66			0.33096			1.1		
08/27/20 17:00	0.2			1.7			3			0.67			0.33612			1.12		
08/27/20 18:00	0.6			1.7			2			0.6			0.30096			1		
08/27/20 19:00	1.1			1.7			2			0.55			0.27528			0.92		
08/27/20 20:00	0.9			1.7			2			0.47			0.23652			0.79		
08/27/20 21:00	0.8			1.7			2			0.47			0.23616			0.79		
08/27/20 22:00	0.9			1.7			3			0.39			0.19524			0.65		
08/27/20 23:00	0.8			1.7			3			0.36			0.17766			0.59		
08/28/20 0:00	0.8			1.7			3			0.35			0.17712			0.59		
08/28/20 1:00	0.8			1.7			3			0.35			0.177			0.59		
08/28/20 2:00	0.8			1.7			3			0.35			0.177			0.59		
08/28/20 3:00	0.8			1.7			2			0.35			0.1773			0.59		
08/28/20 4:00	0.8			1.7			2			0.35			0.17736			0.59		
08/28/20 5:00	0.9			1.7			2			0.35			0.17718			0.59		
08/28/20 6:00	0.8			1.7			2			0.36			0.17778			0.59		
08/28/20 7:00	0.9			1.7			3			0.37			0.18552			0.62		
08/28/20 8:00	0.9			1.7			2			0.4			0.20244			0.67		
08/28/20 9:00	0.9			1.7			2			0.45			0.22482			0.75		
08/28/20 10:00	0.9			1.7			1			0.5			0.25056			0.84		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/28/20 11:00	0.5			1.7			2			0.64			0.31914			1.06		
08/28/20 12:00	0.2			1.7			4			0.74			0.36936			1.23		
08/28/20 13:00	0.2			1.7			4			0.74			0.36894			1.23		
08/28/20 14:00	0.3			1.7			3			0.66			0.33102			1.1		
08/28/20 15:00	0.2			1.7			3			0.67			0.33606			1.12		
08/28/20 16:00	0.2			1.7			4			0.73			0.36654			1.22		
08/28/20 17:00	0.2			1.7			4			0.71			0.3552			1.18		
08/28/20 18:00	0.7			1.7			2			0.59			0.29436			0.98		
08/28/20 19:00	0.9			1.7			1			0.5			0.24888			0.83		
08/28/20 20:00	0.8			1.7			2			0.49			0.24732			0.82		
08/28/20 21:00	0.8			1.7			1			0.5			0.25068			0.84		
08/28/20 22:00	0.8			1.7			2			0.47			0.23604			0.79		
08/28/20 23:00	0.9			1.6			2			0.41			0.2043			0.68		
08/29/20 0:00	0.8			1.7			3			0.36			0.18018			0.6		
08/29/20 1:00	0.8			1.7			2			0.35			0.17742			0.59		
08/29/20 2:00	0.8			1.7			2			0.36			0.17766			0.59		
08/29/20 3:00	0.8			1.7			2			0.35			0.17748			0.59		
08/29/20 4:00	0.8			1.7			2			0.35			0.17736			0.59		
08/29/20 5:00	0.8			1.7			3			0.35			0.1773			0.59		
08/29/20 6:00	0.8			1.7			2			0.36			0.1776			0.59		
08/29/20 7:00	0.8			1.7			2			0.36			0.17826			0.59		
08/29/20 8:00	0.9			1.7			3			0.38			0.18786			0.63		
08/29/20 9:00	0.9			1.7			2			0.42			0.20976			0.7		
08/29/20 10:00	0.8			1.7			2			0.43			0.21606			0.72		
08/29/20 11:00	0.9			1.7			1			0.5			0.25134			0.84		
08/29/20 12:00	0.6			1.7			2			0.61			0.30312			1.01		
08/29/20 13:00	0.2			1.7			4			0.72			0.36096			1.2		
08/29/20 14:00	0.2			1.7			3			0.69			0.34272			1.14		
08/29/20 15:00	0.2			1.7			4			0.73			0.36414			1.21		
08/29/20 16:00	0.3			1.7			3			0.64			0.32172			1.07		
08/29/20 17:00	0.6			1.7			2			0.58			0.29226			0.97		
08/29/20 18:00	1			1.8			2			0.49			0.2442			0.81		
08/29/20 19:00	0.8			1.6			3			0.43			0.2145			0.72		
08/29/20 20:00	0.8			1.7			2			0.44			0.22212			0.74		
08/29/20 21:00	0.8			1.7			2			0.48			0.2421			0.81		
08/29/20 22:00	0.9			1.7			3			0.41			0.20616			0.69		
08/29/20 23:00	0.8			1.7			3			0.37			0.18324			0.61		
08/30/20 0:00	0.8			1.7			2			0.36			0.17772			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/30/20 1:00	0.8			1.7			3			0.36			0.1776			0.59		
08/30/20 2:00	0.8			1.7			3			0.36			0.1776			0.59		
08/30/20 3:00	0.8			1.7			2			0.35			0.17748			0.59		
08/30/20 4:00	0.8			1.7			2			0.35			0.17742			0.59		
08/30/20 5:00	0.8			1.7			3			0.35			0.17742			0.59		
08/30/20 6:00	0.8			1.7			3			0.36			0.1782			0.59		
08/30/20 7:00	0.8			1.7			3			0.36			0.1782			0.59		
08/30/20 8:00	0.8			1.7			3			0.36			0.17814			0.59		
08/30/20 9:00	0.9			1.7			3			0.37			0.18606			0.62		
08/30/20 10:00	0.9			1.7			2			0.42			0.21042			0.7		
08/30/20 11:00	0.8			1.7			2			0.48			0.2388			0.8		
08/30/20 12:00	0.7			1.7			2			0.6			0.30042			1		
08/30/20 13:00	0.2			1.7			3			0.71			0.35682			1.19		
08/30/20 14:00	0.2			1.7			4			0.74			0.3684			1.23		
08/30/20 15:00	0.2			1.7			3			0.7			0.34764			1.16		
08/30/20 16:00	0.4			1.7			3			0.63			0.3156			1.05		
08/30/20 17:00	0.4			1.7			2			0.63			0.31296			1.04		
08/30/20 18:00	0.8			1.8			1			0.5			0.24936			0.83		
08/30/20 19:00	0.8			1.7			2			0.45			0.22578			0.75		
08/30/20 20:00	0.9			1.7			2			0.4			0.20118			0.67		
08/30/20 21:00	0.8			1.7			1			0.49			0.24258			0.81		
08/30/20 22:00	0.9			1.6			3			0.41			0.20484			0.68		
08/30/20 23:00	0.4			1.6			4			0.67			0.3363			1.12		
08/31/20 0:00	0.2			1.7			4			0.71			0.35448			1.18		
08/31/20 1:00	0.4			1.7			2			0.65			0.32292			1.08		
08/31/20 2:00	1			1.7			2			0.59			0.29376			0.98		
08/31/20 3:00	1.1			1.7			2			0.59			0.29298			0.98		
08/31/20 4:00	0.6			1.6			2			0.64			0.31818			1.06		
08/31/20 5:00	1			1.7			2			0.6			0.2982			0.99		
08/31/20 6:00	0.6			1.7			3			0.65			0.32286			1.08		
08/31/20 7:00	0.4			1.7			3			0.67			0.33684			1.12		
08/31/20 8:00	0.3			1.7			3			0.7			0.34914			1.16		
08/31/20 9:00	0.4			1.7			3			0.65			0.32328			1.08		
08/31/20 10:00	0.4			1.7			3			0.65			0.32328			1.08		
08/31/20 11:00	0.3			1.7			3			0.68			0.3408			1.14		
08/31/20 12:00	0.2			1.7			4			0.72			0.35982			1.2		
08/31/20 13:00	0.2			1.7			4			0.71			0.3546			1.18		
08/31/20 14:00	0.3			1.7			3			0.65			0.3246			1.08		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
08/31/20 15:00	1.1			1.8			1			0.54			0.26874			0.9		
08/31/20 16:00	0.6			1.7			2			0.6			0.30138			1		
08/31/20 17:00	0.4			1.7			3			0.64			0.3204			1.07		
08/31/20 18:00	0.5			1.7			2			0.61			0.30462			1.02		
08/31/20 19:00	0.7			1.7			2			0.59			0.29592			0.99		
08/31/20 20:00	0.9			1.7			2			0.38			0.18912			0.63		
08/31/20 21:00	0.8			1.7			1			0.49			0.24498			0.82		
08/31/20 22:00	0.9			1.7			2			0.42			0.21174			0.71		
08/31/20 23:00	0.9			1.7			2			0.41			0.20502			0.68		
09/01/20 0:00	0.9			1.7			3			0.36			0.18162			0.61		
09/01/20 1:00	0.8			1.7			2			0.36			0.17778			0.59		
09/01/20 2:00	0.8			1.7			2			0.36			0.17754			0.59		
09/01/20 3:00	0.8			1.7			2			0.36			0.17796			0.59		
09/01/20 4:00	0.8			1.7			2			0.36			0.1791			0.6		
09/01/20 5:00	1			1.7			3			0.42			0.21198			0.71		
09/01/20 6:00	0.9			1.7			2			0.44			0.2175			0.73		
09/01/20 7:00	0.8			1.7			3			0.47			0.23274			0.78		
09/01/20 8:00	0.8			1.7			1			0.51			0.25734			0.86		
09/01/20 9:00	0.8			1.7			2			0.51			0.25548			0.85		
09/01/20 10:00	0.8			1.7			2			0.5			0.24972			0.83		
09/01/20 11:00	1.3			1.7			2			0.54			0.26994			0.9		
09/01/20 12:00	0.2			1.7			3			0.71			0.3555			1.19		
09/01/20 13:00	0.2			1.7			4			0.71			0.35712			1.19		
09/01/20 14:00	0.2			1.7			4			0.73			0.36462			1.22		
09/01/20 15:00	0.2			1.7			4			0.73			0.36594			1.22		
09/01/20 16:00	0.2			1.7			4			0.73			0.36324			1.21		
09/01/20 17:00	0.3			1.7			3			0.68			0.34098			1.14		
09/01/20 18:00	0.4			1.7			3			0.65			0.32466			1.08		
09/01/20 19:00	0.5			1.7			2			0.63			0.31302			1.04		
09/01/20 20:00	0.4			1.7			3			0.66			0.32928			1.1		
09/01/20 21:00	1.1			1.8			2			0.52			0.25962			0.87		
09/01/20 22:00	0.9			1.7			3			0.41			0.2073			0.69		
09/01/20 23:00	0.8			1.7			2			0.42			0.20898			0.7		
09/02/20 0:00	0.8			1.7			2			0.42			0.2082			0.69		
09/02/20 1:00	0.9			1.7			3			0.39			0.19548			0.65		
09/02/20 2:00	0.8			1.7			3			0.37			0.1857			0.62		
09/02/20 3:00	0.8			1.7			3			0.37			0.18474			0.62		
09/02/20 4:00	0.8			1.7			2			0.37			0.1836			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/02/20 5:00	0.9			1.7			3			0.38			0.19236			0.64		
09/02/20 6:00	0.9			1.7			2			0.42			0.20976			0.7		
09/02/20 7:00	0.8			1.7			2			0.45			0.22326			0.74		
09/02/20 8:00	0.8			1.7			3			0.47			0.23556			0.79		
09/02/20 9:00	0.8			1.7			3			0.45			0.2262			0.75		
09/02/20 10:00	0.8			1.7			3			0.45			0.22728			0.76		
09/02/20 11:00	0.8			1.7			2			0.43			0.21258			0.71		
09/02/20 12:00	0.8			1.7			2			0.42			0.21216			0.71		
09/02/20 13:00	1			1.4			0	X		0.52			0.2604			0.87		
09/02/20 14:00	0.1			1.7			2			0.66			0.33006			1.1		
09/02/20 15:00	0.1			1.7			3			0.66			0.33084			1.1		
09/02/20 16:00	0.1			1.7			3			0.66			0.33072			1.1		
09/02/20 17:00	0.1			1.7			3			0.66			0.3306			1.1		
09/02/20 18:00	0.3			1.7			2			0.62			0.30864			1.03		
09/02/20 19:00	0.9			1.7			2			0.54			0.27228			0.91		
09/02/20 20:00	0.6			1.7			2			0.47			0.23694			0.79		
09/02/20 21:00	0.8			1.7			2			0.55			0.27606			0.92		
09/02/20 22:00	0.6			1.8			2			0.49			0.24558			0.82		
09/02/20 23:00	0.6			1.7			3			0.43			0.21732			0.72		
09/03/20 0:00	0.7			1.7			3			0.39			0.19716			0.66		
09/03/20 1:00	0.6			1.7			3			0.36			0.18204			0.61		
09/03/20 2:00	0.6			1.7			2			0.36			0.17802			0.59		
09/03/20 3:00	0.6			1.7			3			0.36			0.17952			0.6		
09/03/20 4:00	0.6			1.6			3			0.37			0.18498			0.62		
09/03/20 5:00	0.7			1.7			3			0.36			0.18162			0.61		
09/03/20 6:00	0.6			1.7			3			0.36			0.17892			0.6		
09/03/20 7:00	0.6			1.7			3			0.36			0.18078			0.6		
09/03/20 8:00	0.7			1.7			2			0.43			0.21462			0.72		
09/03/20 9:00	0.6			1.7			2			0.42			0.2118			0.71		
09/03/20 10:00	0.6			1.7			2			0.46			0.22896			0.76		
09/03/20 11:00	0.9			1.7			2			0.51			0.25626			0.85		
09/03/20 12:00	0.1			1.7			3			0.68			0.33918			1.13		
09/03/20 13:00	0.1			1.7			4			0.74			0.36954			1.23		
09/03/20 14:00	0.1			1.7			4			0.74			0.369			1.23		
09/03/20 15:00	0.1			1.7			4			0.74			0.36882			1.23		
09/03/20 16:00	0.1			1.7			4			0.73			0.3669			1.22		
09/03/20 17:00	0.1			1.7			4			0.73			0.36702			1.22		
09/03/20 18:00	0.1			1.7			4			0.73			0.36636			1.22		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/03/20 19:00	0.1			1.7			4			0.71			0.35394			1.18		
09/03/20 20:00	0.1			1.7			3			0.7			0.34752			1.16		
09/03/20 21:00	0.1			1.7			3			0.68			0.3393			1.13		
09/03/20 22:00	1.1			1.8			2			0.53			0.26346			0.88		
09/03/20 23:00	0.6			1.7			3			0.46			0.22968			0.77		
09/04/20 0:00	0.6			1.7			3			0.43			0.21492			0.72		
09/04/20 1:00	0.7			1.7			3			0.4			0.19932			0.66		
09/04/20 2:00	0.7			1.7			3			0.39			0.19344			0.64		
09/04/20 3:00	0.7			1.7			3			0.38			0.1908			0.64		
09/04/20 4:00	0.7			1.7			3			0.39			0.19326			0.64		
09/04/20 5:00	0.8			1.7			3			0.4			0.19782			0.66		
09/04/20 6:00	0.7			1.7			3			0.39			0.19656			0.66		
09/04/20 7:00	0.7			1.7			3			0.39			0.19326			0.64		
09/04/20 8:00	0.7			1.7			2			0.41			0.2073			0.69		
09/04/20 9:00	0.7			1.7			2			0.41			0.20538			0.68		
09/04/20 10:00	0.6			1.7			2			0.45			0.22686			0.76		
09/04/20 11:00	0.9			1.7			2			0.56			0.28086			0.94		
09/04/20 12:00	0.2			1.7			2			0.65			0.32358			1.08		
09/04/20 13:00	0.1			1.7			4			0.73			0.36624			1.22		
09/04/20 14:00	0.1			1.7			4			0.73			0.36732			1.22		
09/04/20 15:00	0.1			1.7			4			0.73			0.36678			1.22		
09/04/20 16:00	0.1			1.7			4			0.73			0.366			1.22		
09/04/20 17:00	0.1			1.7			4			0.73			0.36594			1.22		
09/04/20 18:00	0.1			1.7			4			0.73			0.3663			1.22		
09/04/20 19:00	0.1			1.7			4			0.73			0.3669			1.22		
09/04/20 20:00	0.1			1.7			4			0.73			0.36702			1.22		
09/04/20 21:00	0.1			1.7			4			0.72			0.36			1.2		
09/04/20 22:00	0.4			1.7			2			0.62			0.30864			1.03		
09/04/20 23:00	0.8			1.8			3			0.4			0.20112			0.67		
09/05/20 0:00	0.7			1.7			3			0.37			0.18342			0.61		
09/05/20 1:00	0.6			1.7			3			0.36			0.17922			0.6		
09/05/20 2:00	0.6			1.7			3			0.36			0.17772			0.59		
09/05/20 3:00	0.7			1.7			2			0.36			0.17922			0.6		
09/05/20 4:00	0.8			1.7			2			0.36			0.17892			0.6		
09/05/20 5:00	0.9			1.7			3			0.36			0.17862			0.6		
09/05/20 6:00	0.9			1.7			2			0.36			0.17886			0.6		
09/05/20 7:00	0.9			1.7			3			0.36			0.18144			0.6		
09/05/20 8:00	0.8			1.7			3			0.39			0.19488			0.65		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/20 9:00	0.7			1.7			2			0.46			0.23172			0.77		
09/05/20 10:00	0.9			1.7			2			0.56			0.2823			0.94		
09/05/20 11:00	0.1			1.7			3			0.67			0.33258			1.11		
09/05/20 12:00	0.1			1.7			3			0.71			0.35712			1.19		
09/05/20 13:00	0.1			1.7			4			0.73			0.36618			1.22		
09/05/20 14:00	0.1			1.7			4			0.73			0.36552			1.22		
09/05/20 15:00	0.1			1.7			4			0.73			0.36336			1.21		
09/05/20 16:00	0.1			1.7			4			0.72			0.36234			1.21		
09/05/20 17:00	0.1			1.7			4			0.72			0.35952			1.2		
09/05/20 18:00	0.2			1.7			3			0.64			0.32238			1.07		
09/05/20 19:00	0.1			1.7			3			0.68			0.33858			1.13		
09/05/20 20:00	0.1			1.7			4			0.73			0.36528			1.22		
09/05/20 21:00	0.1			1.7			3			0.68			0.33798			1.13		
09/05/20 22:00	1.1			1.7			2			0.54			0.26838			0.89		
09/05/20 23:00	0.7			1.7			2			0.46			0.23208			0.77		
09/06/20 0:00	0.9			1.7			2			0.41			0.20688			0.69		
09/06/20 1:00	1.1			1.7			3			0.37			0.183			0.61		
09/06/20 2:00	1			1.7			2			0.36			0.1794			0.6		
09/06/20 3:00	0.9			1.7			2			0.36			0.17964			0.6		
09/06/20 4:00	0.9			1.7			2			0.36			0.17946			0.6		
09/06/20 5:00	0.9			1.8			2			0.36			0.18072			0.6		
09/06/20 6:00	0.9			1.7			3			0.37			0.18516			0.62		
09/06/20 7:00	0.8			1.7			2			0.37			0.18288			0.61		
09/06/20 8:00	0.9			1.7			2			0.39			0.19698			0.66		
09/06/20 9:00	0.7			1.7			2			0.46			0.22932			0.76		
09/06/20 10:00	0.7			1.7			1			0.49			0.24426			0.81		
09/06/20 11:00	0.7			1.7			2			0.44			0.22134			0.74		
09/06/20 12:00	0.7			1.7			2			0.58			0.28872			0.96		
09/06/20 13:00	0.2			1.7			3			0.65			0.32472			1.08		
09/06/20 14:00	0.1			1.7			4			0.7			0.35076			1.17		
09/06/20 15:00	0.1			1.7			4			0.72			0.36198			1.21		
09/06/20 16:00	0.1			1.7			4			0.72			0.36102			1.2		
09/06/20 17:00	0.1			1.7			4			0.72			0.36072			1.2		
09/06/20 18:00	0.1			1.7			4			0.72			0.35778			1.19		
09/06/20 19:00	0.1			1.7			3			0.69			0.3453			1.15		
09/06/20 20:00	0.1			1.7			3			0.7			0.34992			1.17		
09/06/20 21:00	0.1			1.7			4			0.72			0.36096			1.2		
09/06/20 22:00	0.4			1.7			2			0.62			0.31074			1.04		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/06/20 23:00	0.7			1.8			2			0.49			0.24738			0.82		
09/07/20 0:00	0.7			1.7			2			0.43			0.2163			0.72		
09/07/20 1:00	0.9			1.7			3			0.38			0.18972			0.63		
09/07/20 2:00	0.7			1.7			3			0.36			0.17976			0.6		
09/07/20 3:00	0.7			1.7			3			0.36			0.17958			0.6		
09/07/20 4:00	0.8			1.7			2			0.36			0.17946			0.6		
09/07/20 5:00	0.9			1.7			2			0.36			0.17904			0.6		
09/07/20 6:00	0.9			1.7			2			0.36			0.17922			0.6		
09/07/20 7:00	1.2			1.7			3			0.38			0.19122			0.64		
09/07/20 8:00	0.8			1.7			2			0.45			0.22446			0.75		
09/07/20 9:00	0.7			1.7			2			0.59			0.29334			0.98		
09/07/20 10:00	0.1			1.7			4			0.72			0.36216			1.21		
09/07/20 11:00	0.1			1.7			4			0.71			0.35268			1.18		
09/07/20 12:00	0.4			1.7			2			0.61			0.3039			1.01		
09/07/20 13:00	0.1			1.7			4			0.72			0.35754			1.19		
09/07/20 14:00	0.3			1.7			2			0.61			0.30528			1.02		
09/07/20 15:00	0.5			1.7			2			0.58			0.28938			0.96		
09/07/20 16:00	0.1			1.7			3			0.65			0.32544			1.08		
09/07/20 17:00	0.5			1.7			2			0.58			0.28914			0.96		
09/07/20 18:00	1			1.7			1			0.52			0.26016			0.87		
09/07/20 19:00	1.4			1.7			2			0.49			0.24732			0.82		
09/07/20 20:00	1.7			1.7			2			0.52			0.26226			0.87		
09/07/20 21:00	0.4			1.7			2			0.62			0.31104			1.04		
09/07/20 22:00	0.7			1.8			1			0.5			0.24756			0.83		
09/07/20 23:00	0.7			1.7			2			0.46			0.22794			0.76		
09/08/20 0:00	0.8			1.7			2			0.39			0.19392			0.65		
09/08/20 1:00	0.9			1.7			2			0.43			0.21462			0.72		
09/08/20 2:00	0.8			1.7			2			0.43			0.21396			0.71		
09/08/20 3:00	0.8			1.7			3			0.38			0.18816			0.63		
09/08/20 4:00	0.8			1.7			3			0.37			0.1869			0.62		
09/08/20 5:00	0.7			1.7			3			0.44			0.21804			0.73		
09/08/20 6:00	0.6			1.7			2			0.49			0.24738			0.82		
09/08/20 7:00	0.8			1.7			2			0.57			0.28338			0.94		
09/08/20 8:00	0.5			1.7			3			0.62			0.3108			1.04		
09/08/20 9:00	0.1			1.7			3			0.68			0.33774			1.13		
09/08/20 10:00	0.6			1.7			2			0.59			0.29478			0.98		
09/08/20 11:00	0.6			1.8			2			0.48			0.23892			0.8		
09/08/20 12:00	0.6			1.7			2			0.47			0.2346			0.78		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/08/20 13:00	0.6			1.7			2			0.47			0.23274			0.78		
09/08/20 14:00	0.6			1.7			2			0.38			0.18924			0.63		
09/08/20 15:00	0.6			1.7			2			0.36			0.17946			0.6		
09/08/20 16:00	0.7			1.7			3			0.36			0.1785			0.6		
09/08/20 17:00	0.6			1.7			3			0.36			0.17874			0.6		
09/08/20 18:00	0.6			1.7			3			0.37			0.18282			0.61		
09/08/20 19:00	0.7			1.7			3			0.37			0.18666			0.62		
09/08/20 20:00	0.6			1.7			3			0.36			0.18204			0.61		
09/08/20 21:00	0.6			1.7			1			0.5			0.24792			0.83		
09/08/20 22:00	0.7			1.7			3			0.45			0.22716			0.76		
09/08/20 23:00	0.7			1.7			3			0.37			0.1827			0.61		
09/09/20 0:00	0.7			1.7			3			0.36			0.17856			0.6		
09/09/20 1:00	0.7			1.7			3			0.36			0.17814			0.59		
09/09/20 2:00	0.9			1.7			3			0.36			0.1782			0.59		
09/09/20 3:00	0.7			1.7			3			0.36			0.1785			0.6		
09/09/20 4:00	0.7			1.7			3			0.36			0.1785			0.6		
09/09/20 5:00	0.8			1.7			3			0.36			0.17976			0.6		
09/09/20 6:00	0.8			1.7			2			0.44			0.21894			0.73		
09/09/20 7:00	0.3			1.7			4			0.76			0.37872			1.26		
09/09/20 8:00	0.1			1.7			5			0.78			0.38886			1.3		
09/09/20 9:00	0.1			1.7			5			0.75			0.37476			1.25		
09/09/20 10:00	0.1			1.7			5			0.76			0.38016			1.27		
09/09/20 11:00	0.1			1.7			5			0.76			0.38184			1.27		
09/09/20 12:00	0.1			1.7			5			0.76			0.38022			1.27		
09/09/20 13:00	0.1			1.7			5			0.76			0.37914			1.26		
09/09/20 14:00	0.1			1.7			5			0.76			0.37884			1.26		
09/09/20 15:00	0.1			1.7			5			0.76			0.37944			1.26		
09/09/20 16:00	0			1.7			5			0.73			0.36438			1.21		
09/09/20 17:00	0.7			1.8			2			0.43			0.21666			0.72		
09/09/20 18:00	0.7			1.7			2			0.41			0.20556			0.69		
09/09/20 19:00	0.7			1.7			2			0.44			0.21768			0.73		
09/09/20 20:00	0.6			1.7			3			0.36			0.18108			0.6		
09/09/20 21:00	0.6			1.7			2			0.36			0.18036			0.6		
09/09/20 22:00	0.7			1.7			3			0.37			0.18678			0.62		
09/09/20 23:00	0.7			1.7			2			0.37			0.18342			0.61		
09/10/20 0:00	0.6			1.7			2			0.36			0.18012			0.6		
09/10/20 1:00	0.6			1.7			2			0.36			0.18096			0.6		
09/10/20 2:00	0.6			1.7			3			0.36			0.18006			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/10/20 3:00	0.6			1.7			3			0.36			0.18			0.6		
09/10/20 4:00	0.7			1.7			3			0.37			0.18528			0.62		
09/10/20 5:00	0.7			1.7			3			0.36			0.17958			0.6		
09/10/20 6:00	1.1			1.7			3			0.36			0.18042			0.6		
09/10/20 7:00	0.9			1.7			3			0.37			0.18402			0.61		
09/10/20 8:00	0.7			1.7			3			0.36			0.18024			0.6		
09/10/20 9:00	0.8			1.7			3			0.39			0.19686			0.66		
09/10/20 10:00	0.8			1.7			3			0.4			0.20004			0.67		
09/10/20 11:00	0.7			1.7			2			0.47			0.23736			0.79		
09/10/20 12:00	0.7			1.7			3			0.47			0.23682			0.79		
09/10/20 13:00	1.1			1.7			2			0.52			0.26118			0.87		
09/10/20 14:00	0.8			1.7			2			0.5			0.25122			0.84		
09/10/20 15:00	1.2			1.7			2			0.52			0.26106			0.87		
09/10/20 16:00	0.8			1.7			1			0.5			0.25248			0.84		
09/10/20 17:00	1.3			1.7			2			0.53			0.26676			0.89		
09/10/20 18:00	0.9			1.7			2			0.49			0.24582			0.82		
09/10/20 19:00	0.4			1.7			3			0.67			0.33318			1.11		
09/10/20 20:00	1.2			1.8			2			0.56			0.2775			0.93		
09/10/20 21:00	1.2			1.7			2			0.53			0.26736			0.89		
09/10/20 22:00	0.7			1.7			2			0.48			0.23772			0.79		
09/10/20 23:00	0.8			1.7			2			0.41			0.20436			0.68		
09/11/20 0:00	0.8			1.7			3			0.4			0.19752			0.66		
09/11/20 1:00	0.7			1.7			2			0.36			0.17952			0.6		
09/11/20 2:00	0.8			1.7			2			0.36			0.17934			0.6		
09/11/20 3:00	0.7			1.7			2			0.36			0.18018			0.6		
09/11/20 4:00	1			1.6			3			0.4			0.19908			0.66		
09/11/20 5:00	1			1.7			3			0.36			0.17964			0.6		
09/11/20 6:00	0.9			1.7			3			0.36			0.17952			0.6		
09/11/20 7:00	0.9			1.7			3			0.37			0.18456			0.62		
09/11/20 8:00	1			1.7			3			0.4			0.19776			0.66		
09/11/20 9:00	0.8			1.7			2			0.46			0.2286			0.76		
09/11/20 10:00	0.7			1.7			1			0.49			0.24636			0.82		
09/11/20 11:00	0.7			1.7			2			0.5			0.2502			0.83		
09/11/20 12:00	1.3			1.7			2			0.53			0.2655			0.89		
09/11/20 13:00	1.1			1.7			2			0.58			0.2895			0.97		
09/11/20 14:00	0.5			1.7			2			0.63			0.31308			1.04		
09/11/20 15:00	0.9			1.8			3			0.43			0.21366			0.71		
09/11/20 16:00	0.8			1.7			2			0.43			0.21696			0.72		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/11/20 17:00	0.8			1.7			1			0.5			0.2523			0.84		
09/11/20 18:00	0.8			1.7			2			0.48			0.23838			0.79		
09/11/20 19:00	0.8			1.7			2			0.38			0.189			0.63		
09/11/20 20:00	0.8			1.7			2			0.46			0.22926			0.76		
09/11/20 21:00	0.8			1.7			2			0.5			0.24996			0.83		
09/11/20 22:00	1			1.7			3			0.45			0.22428			0.75		
09/11/20 23:00	1.2			1.7			3			0.43			0.21714			0.72		
09/12/20 0:00	1.1			1.7			3			0.36			0.18054			0.6		
09/12/20 1:00	1			1.7			3			0.36			0.17994			0.6		
09/12/20 2:00	1			1.7			3			0.36			0.18018			0.6		
09/12/20 3:00	1.4			1.7			3			0.36			0.17976			0.6		
09/12/20 4:00	1.7			1.6			3			0.36			0.17964			0.6		
09/12/20 5:00	1.4			1.7			3			0.36			0.18012			0.6		
09/12/20 6:00	1.5			1.7			3			0.36			0.18096			0.6		
09/12/20 7:00	1.3			1.7			3			0.36			0.18132			0.6		
09/12/20 8:00	1.1			1.7			2			0.37			0.18576			0.62		
09/12/20 9:00	0.8			1.7			3			0.39			0.19254			0.64		
09/12/20 10:00	0.8			1.7			2			0.42			0.20892			0.7		
09/12/20 11:00	0.8			1.7			2			0.44			0.21972			0.73		
09/12/20 12:00	0.9			1.7			2			0.5			0.25008			0.83		
09/12/20 13:00	0.3			1.7			3			0.66			0.32928			1.1		
09/12/20 14:00	0.1			1.7			3			0.71			0.35736			1.19		
09/12/20 15:00	0.9			1.7			2			0.55			0.27354			0.91		
09/12/20 16:00	0.9			1.7			2			0.56			0.28236			0.94		
09/12/20 17:00	0.1			1.7			3			0.69			0.34584			1.15		
09/12/20 18:00	0.8			1.8			1			0.5			0.24948			0.83		
09/12/20 19:00	0.8			1.7			2			0.45			0.22452			0.75		
09/12/20 20:00	0.9			1.7			2			0.43			0.2127			0.71		
09/12/20 21:00	1.2			1.7			2			0.51			0.25374			0.85		
09/12/20 22:00	1			1.7			2			0.46			0.23178			0.77		
09/12/20 23:00	1			1.7			2			0.44			0.21786			0.73		
09/13/20 0:00	1			1.7			3			0.38			0.1899			0.63		
09/13/20 1:00	0.9			1.7			2			0.36			0.18132			0.6		
09/13/20 2:00	0.9			1.7			3			0.36			0.17988			0.6		
09/13/20 3:00	1			1.7			3			0.36			0.18054			0.6		
09/13/20 4:00	1			1.7			2			0.36			0.18042			0.6		
09/13/20 5:00	1.1			1.7			3			0.36			0.17952			0.6		
09/13/20 6:00	1			1.7			3			0.36			0.17952			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/13/20 7:00	1			1.7			2			0.36			0.18102			0.6		
09/13/20 8:00	1.1			1.7			3			0.39			0.19734			0.66		
09/13/20 9:00	0.9			1.7			2			0.44			0.21774			0.73		
09/13/20 10:00	1.2			1.7			1			0.5			0.24876			0.83		
09/13/20 11:00	1.1			1.7			2			0.56			0.28182			0.94		
09/13/20 12:00	0.9			1.7			2			0.59			0.29286			0.98		
09/13/20 13:00	0.4			1.7			2			0.64			0.32064			1.07		
09/13/20 14:00	0.2			1.7			3			0.67			0.33504			1.12		
09/13/20 15:00	0.3			1.7			2			0.64			0.31842			1.06		
09/13/20 16:00	1.1			1.7			2			0.53			0.26514			0.88		
09/13/20 17:00	1			1.7			2			0.54			0.27048			0.9		
09/13/20 18:00	1			1.7			2			0.54			0.26784			0.89		
09/13/20 19:00	0.8			1.7			3			0.43			0.21684			0.72		
09/13/20 20:00	0.6			1.6			2			0.58			0.28794			0.96		
09/13/20 21:00	1.1			1.7			2			0.54			0.2709			0.9		
09/13/20 22:00	0.9			1.7			2			0.48			0.24246			0.81		
09/13/20 23:00	0.9			1.7			3			0.4			0.20154			0.67		
09/14/20 0:00	0.7			1.7			2			0.36			0.18036			0.6		
09/14/20 1:00	0.7			1.7			2			0.36			0.17952			0.6		
09/14/20 2:00	0.7			1.7			2			0.36			0.17958			0.6		
09/14/20 3:00	0.7			1.7			2			0.36			0.17946			0.6		
09/14/20 4:00	0.7			1.7			2			0.36			0.17964			0.6		
09/14/20 5:00	0.8			1.7			3			0.36			0.17958			0.6		
09/14/20 6:00	0.8			1.7			3			0.36			0.18126			0.6		
09/14/20 7:00	0.9			1.7			3			0.38			0.18996			0.63		
09/14/20 8:00	0.9			1.7			3			0.41			0.20382			0.68		
09/14/20 9:00	0.8			1.7			2			0.43			0.21294			0.71		
09/14/20 10:00	0.8			1.7			2			0.45			0.22662			0.76		
09/14/20 11:00	0.7			1.7			1			0.51			0.25416			0.85		
09/14/20 12:00	1			1.7			2			0.57			0.28434			0.95		
09/14/20 13:00	0.1			1.7			3			0.68			0.34182			1.14		
09/14/20 14:00	0.1			1.7			4			0.74			0.37044			1.23		
09/14/20 15:00	0.2			1.7			3			0.67			0.33606			1.12		
09/14/20 16:00	0.1			1.7			3			0.71			0.35724			1.19		
09/14/20 17:00	0.1			1.7			4			0.74			0.37074			1.24		
09/14/20 18:00	0.2			1.7			3			0.69			0.34602			1.15		
09/14/20 19:00	0.7			1.8			2			0.46			0.23028			0.77		
09/14/20 20:00	0.7			1.7			2			0.47			0.237			0.79		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/14/20 21:00	1			1.7			1			0.52			0.26226			0.87		
09/14/20 22:00	0.7			1.8			3			0.47			0.23268			0.78		
09/14/20 23:00	0.8			1.7			3			0.39			0.19356			0.65		
09/15/20 0:00	0.7			1.7			2			0.36			0.17994			0.6		
09/15/20 1:00	0.7			1.7			2			0.36			0.17982			0.6		
09/15/20 2:00	0.7			1.7			2			0.36			0.17988			0.6		
09/15/20 3:00	0.7			1.7			2			0.36			0.17982			0.6		
09/15/20 4:00	0.7			1.7			2			0.36			0.18108			0.6		
09/15/20 5:00	0.8			1.7			3			0.37			0.18564			0.62		
09/15/20 6:00	0.7			1.7			3			0.36			0.18138			0.6		
09/15/20 7:00	0.8			1.7			3			0.38			0.19182			0.64		
09/15/20 8:00	0.7			1.7			2			0.42			0.21174			0.71		
09/15/20 9:00	0.7			1.7			3			0.46			0.22776			0.76		
09/15/20 10:00	0.7			1.7			1			0.51			0.25404			0.85		
09/15/20 11:00	1.1			1.7			2			0.55			0.27288			0.91		
09/15/20 12:00	0.2			1.7			3			0.66			0.33102			1.1		
09/15/20 13:00	0.1			1.7			4			0.73			0.36474			1.22		
09/15/20 14:00	0.1			1.7			4			0.74			0.37032			1.23		
09/15/20 15:00	0.1			1.7			4			0.73			0.36468			1.22		
09/15/20 16:00	0.1			1.7			3			0.69			0.34638			1.15		
09/15/20 17:00	0.1			1.7			3			0.69			0.34632			1.15		
09/15/20 18:00	0.4			1.7			2			0.61			0.3057			1.02		
09/15/20 19:00	0.8			1.8			2			0.52			0.26184			0.87		
09/15/20 20:00	0.7			1.7			3			0.45			0.22392			0.75		
09/15/20 21:00	0.6			1.7			2			0.5			0.24798			0.83		
09/15/20 22:00	0.7			1.7			3			0.44			0.2223			0.74		
09/15/20 23:00	0.7			1.7			2			0.42			0.21054			0.7		
09/16/20 0:00	0.8			1.7			3			0.39			0.1938			0.65		
09/16/20 1:00	0.6			1.7			2			0.36			0.18036			0.6		
09/16/20 2:00	0.6			1.7			2			0.36			0.17946			0.6		
09/16/20 3:00	0.6			1.7			3			0.36			0.1824			0.61		
09/16/20 4:00	0.7			1.7			3			0.4			0.19758			0.66		
09/16/20 5:00	0.8			1.7			3			0.4			0.20034			0.67		
09/16/20 6:00	0.8			1.7			3			0.4			0.20052			0.67		
09/16/20 7:00	0.7			1.7			2			0.42			0.20934			0.7		
09/16/20 8:00	0.6			1.7			2			0.46			0.23064			0.77		
09/16/20 9:00	0.7			1.7			1			0.5			0.25098			0.84		
09/16/20 10:00	1			1.7			2			0.56			0.27774			0.93		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/20 11:00	0.3			1.7			3			0.64			0.32064			1.07		
09/16/20 12:00	0.1			1.7			3			0.71			0.35568			1.19		
09/16/20 13:00	0.1			1.7			3			0.69			0.34344			1.14		
09/16/20 14:00	0			1.7			4			0.73			0.366			1.22		
09/16/20 15:00	0			1.7			4			0.73			0.3669			1.22		
09/16/20 16:00	0			1.7			4			0.74			0.36888			1.23		
09/16/20 17:00	0			1.7			4			0.73			0.36576			1.22		
09/16/20 18:00	0.1			1.7			3			0.68			0.33876			1.13		
09/16/20 19:00	0.6			1.7			2			0.59			0.29448			0.98		
09/16/20 20:00	0.9			1.7			2			0.55			0.27552			0.92		
09/16/20 21:00	0.9			1.7			2			0.55			0.27378			0.91		
09/16/20 22:00	0.6			1.8			2			0.44			0.22242			0.74		
09/16/20 23:00	0.6			1.7			2			0.41			0.2073			0.69		
09/17/20 0:00	0.7			1.7			3			0.37			0.18696			0.62		
09/17/20 1:00	0.6			1.7			2			0.36			0.17934			0.6		
09/17/20 2:00	0.6			1.7			2			0.36			0.17922			0.6		
09/17/20 3:00	0.6			1.7			2			0.36			0.17898			0.6		
09/17/20 4:00	0.7			1.7			3			0.38			0.18888			0.63		
09/17/20 5:00	0.7			1.7			3			0.37			0.1869			0.62		
09/17/20 6:00	0.7			1.7			3			0.39			0.19338			0.64		
09/17/20 7:00	0.8			1.7			3			0.41			0.2064			0.69		
09/17/20 8:00	0.6			1.7			2			0.46			0.22914			0.76		
09/17/20 9:00	0.7			1.7			1			0.51			0.25572			0.85		
09/17/20 10:00	1.1			1.7			2			0.54			0.27072			0.9		
09/17/20 11:00	0.8			1.7			2			0.56			0.28002			0.93		
09/17/20 12:00	0.7			1.7			2			0.57			0.285			0.95		
09/17/20 13:00	0.4			1.7			2			0.6			0.3015			1.01		
09/17/20 14:00	0.3			1.7			3			0.64			0.3186			1.06		
09/17/20 15:00	0			1.7			4			0.73			0.36582			1.22		
09/17/20 16:00	0			1.7			4			0.73			0.36672			1.22		
09/17/20 17:00	0.1			1.7			3			0.66			0.3279			1.09		
09/17/20 18:00	0.3			1.7			2			0.63			0.31362			1.05		
09/17/20 19:00	0.8			1.7			2			0.55			0.27648			0.92		
09/17/20 20:00	0.7			1.7			2			0.58			0.2877			0.96		
09/17/20 21:00	0.6			1.7			2			0.6			0.30084			1		
09/17/20 22:00	0.6			1.8			2			0.49			0.24264			0.81		
09/17/20 23:00	0.7			1.7			3			0.41			0.20334			0.68		
09/18/20 0:00	0.5			1.7			2			0.36			0.18138			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/18/20 1:00	0.5			1.7			2			0.36			0.17964			0.6		
09/18/20 2:00	0.5			1.7			2			0.36			0.17976			0.6		
09/18/20 3:00	0.5			1.7			2			0.36			0.17946			0.6		
09/18/20 4:00	0.6			1.7			2			0.37			0.18384			0.61		
09/18/20 5:00	0.7			1.7			2			0.39			0.19476			0.65		
09/18/20 6:00	0.7			1.7			2			0.4			0.20166			0.67		
09/18/20 7:00	0.6			1.7			2			0.43			0.21324			0.71		
09/18/20 8:00	1.1			1.7			2			0.53			0.26268			0.88		
09/18/20 9:00	0.9			1.7			2			0.53			0.26718			0.89		
09/18/20 10:00	0.7			1.7			2			0.57			0.28524			0.95		
09/18/20 11:00	0.5			1.7			2			0.59			0.2937			0.98		
09/18/20 12:00	0.4			1.7			2			0.62			0.30894			1.03		
09/18/20 13:00	0.2			1.7			3			0.66			0.33084			1.1		
09/18/20 14:00	0.1			1.7			3			0.66			0.32934			1.1		
09/18/20 15:00	0.9			1.8			2			0.54			0.27168			0.91		
09/18/20 16:00	0.8			1.7			2			0.57			0.28284			0.94		
09/18/20 17:00	0.3			1.7			2			0.62			0.31038			1.03		
09/18/20 18:00	1			1.8			2			0.54			0.26766			0.89		
09/18/20 19:00	0.7			1.7			2			0.43			0.21582			0.72		
09/18/20 20:00	0.6			1.6			2			0.56			0.28044			0.93		
09/18/20 21:00	0.7			1.8			1			0.5			0.25014			0.83		
09/18/20 22:00	0.6			1.7			2			0.43			0.2133			0.71		
09/18/20 23:00	0.7			1.7			3			0.38			0.19092			0.64		
09/19/20 0:00	0.6			1.7			2			0.36			0.17952			0.6		
09/19/20 1:00	0.6			1.7			2			0.36			0.17934			0.6		
09/19/20 2:00	0.6			1.7			2			0.36			0.17928			0.6		
09/19/20 3:00	0.6			1.7			3			0.36			0.17904			0.6		
09/19/20 4:00	0.5			1.6			2			0.36			0.17898			0.6		
09/19/20 5:00	0.7			1.7			3			0.37			0.18342			0.61		
09/19/20 6:00	0.6			1.7			3			0.36			0.1818			0.61		
09/19/20 7:00	0.7			1.7			3			0.4			0.19992			0.67		
09/19/20 8:00	0.6			1.7			2			0.42			0.21174			0.71		
09/19/20 9:00	0.6			1.7			2			0.46			0.23214			0.77		
09/19/20 10:00	0.7			1.7			1			0.51			0.25686			0.86		
09/19/20 11:00	1			1.7			2			0.56			0.27762			0.93		
09/19/20 12:00	0.4			1.7			2			0.62			0.30792			1.03		
09/19/20 13:00	0.4			1.7			2			0.62			0.31122			1.04		
09/19/20 14:00	0.5			1.7			2			0.6			0.2988			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/19/20 15:00	0.4			1.7			2			0.61			0.30456			1.02		
09/19/20 16:00	1			1.7			2			0.51			0.25626			0.85		
09/19/20 17:00	0.6			1.7			2			0.49			0.24606			0.82		
09/19/20 18:00	0.9			1.7			2			0.52			0.26154			0.87		
09/19/20 19:00	0.4			1.7			2			0.62			0.30876			1.03		
09/19/20 20:00	0.7			1.8			2			0.51			0.25266			0.84		
09/19/20 21:00	0.6			1.7			3			0.47			0.23484			0.78		
09/19/20 22:00	0.7			1.7			2			0.42			0.21066			0.7		
09/19/20 23:00	0.8			1.7			3			0.37			0.18726			0.62		
09/20/20 0:00	0.7			1.7			2			0.36			0.17946			0.6		
09/20/20 1:00	0.6			1.7			2			0.36			0.17934			0.6		
09/20/20 2:00	0.6			1.7			2			0.36			0.17934			0.6		
09/20/20 3:00	0.6			1.7			2			0.36			0.17934			0.6		
09/20/20 4:00	0.6			1.7			2			0.36			0.17934			0.6		
09/20/20 5:00	0.7			1.7			3			0.36			0.17976			0.6		
09/20/20 6:00	0.6			1.7			3			0.36			0.1797			0.6		
09/20/20 7:00	0.6			1.7			2			0.36			0.17946			0.6		
09/20/20 8:00	0.6			1.7			3			0.36			0.18192			0.61		
09/20/20 9:00	0.7			1.7			3			0.4			0.19764			0.66		
09/20/20 10:00	0.7			1.7			2			0.43			0.21402			0.71		
09/20/20 11:00	0.7			1.7			2			0.47			0.23364			0.78		
09/20/20 12:00	0.6			1.7			2			0.61			0.30258			1.01		
09/20/20 13:00	0.2			1.7			3			0.67			0.33456			1.12		
09/20/20 14:00	0.1			1.7			4			0.72			0.3618			1.21		
09/20/20 15:00	0.1			1.7			4			0.74			0.36966			1.23		
09/20/20 16:00	0.3			1.7			2			0.63			0.31626			1.05		
09/20/20 17:00	0.9			1.8			2			0.5			0.2511			0.84		
09/20/20 18:00	0.7			1.7			2			0.5			0.24984			0.83		
09/20/20 19:00	0.7			1.7			2			0.48			0.23916			0.8		
09/20/20 20:00	0.8			1.7			2			0.57			0.28632			0.95		
09/20/20 21:00	0.8			1.8			2			0.48			0.2403			0.8		
09/20/20 22:00	0.8			1.7			2			0.42			0.20904			0.7		
09/20/20 23:00	0.7			1.7			2			0.37			0.18684			0.62		
09/21/20 0:00	0.7			1.7			3			0.36			0.17958			0.6		
09/21/20 1:00	0.7			1.7			2			0.36			0.17892			0.6		
09/21/20 2:00	0.6			1.7			3			0.36			0.17964			0.6		
09/21/20 3:00	0.7			1.7			3			0.36			0.18084			0.6		
09/21/20 4:00	0.6			1.7			2			0.36			0.18078			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/21/20 5:00	0.8			1.7			3			0.38			0.19014			0.63		
09/21/20 6:00	0.8			1.7			3			0.39			0.19356			0.65		
09/21/20 7:00	0.7			1.7			3			0.38			0.19104			0.64		
09/21/20 8:00	0.7			1.7			2			0.47			0.23592			0.79		
09/21/20 9:00	0.7			1.2			0	X		0.5			0.2502			0.83		
09/21/20 10:00	1.1			1.7			2			0.55			0.27438			0.91		
09/21/20 11:00	0.2			1.7			3			0.68			0.34074			1.14		
09/21/20 12:00	0.1			1.7			3			0.71			0.3534			1.18		
09/21/20 13:00	0.1			1.7			4			0.74			0.37182			1.24		
09/21/20 14:00	0.1			1.7			4			0.74			0.37236			1.24		
09/21/20 15:00	0.1			1.7			4			0.74			0.37242			1.24		
09/21/20 16:00	0.1			1.7			4			0.72			0.3576			1.19		
09/21/20 17:00	0.1			1.7			4			0.72			0.36168			1.21		
09/21/20 18:00	0.1			1.7			4			0.71			0.35406			1.18		
09/21/20 19:00	0.7			1.7			2			0.58			0.28794			0.96		
09/21/20 20:00	0.6			1.7			2			0.48			0.24228			0.81		
09/21/20 21:00	1.1			1.7			2			0.54			0.26766			0.89		
09/21/20 22:00	0.7			1.7			2			0.45			0.22704			0.76		
09/21/20 23:00	0.7			1.7			3			0.4			0.2022			0.67		
09/22/20 0:00	0.7			1.7			3			0.37			0.18732			0.62		
09/22/20 1:00	0.6			1.7			2			0.36			0.17988			0.6		
09/22/20 2:00	0.6			1.7			2			0.36			0.17976			0.6		
09/22/20 3:00	0.6			1.7			2			0.36			0.17994			0.6		
09/22/20 4:00	0.7			1.6			3			0.37			0.18702			0.62		
09/22/20 5:00	0.8			1.7			3			0.41			0.20352			0.68		
09/22/20 6:00	0.7			1.7			2			0.42			0.21			0.7		
09/22/20 7:00	0.7			1.7			3			0.45			0.22392			0.75		
09/22/20 8:00	0.6			1.7			3			0.47			0.23424			0.78		
09/22/20 9:00	1.1			1.7			2			0.53			0.26346			0.88		
09/22/20 10:00	0.6			1.7			2			0.61			0.30474			1.02		
09/22/20 11:00	0.4			1.7			2			0.63			0.31392			1.05		
09/22/20 12:00	0.1			1.7			3			0.69			0.3447			1.15		
09/22/20 13:00	0.1			1.7			3			0.69			0.34584			1.15		
09/22/20 14:00	0.2			1.7			3			0.66			0.3324			1.11		
09/22/20 15:00	0.3			1.7			3			0.64			0.31974			1.07		
09/22/20 16:00	0.1			1.7			3			0.68			0.3411			1.14		
09/22/20 17:00	0.2			1.7			3			0.65			0.32568			1.09		
09/22/20 18:00	0.5			1.7			2			0.6			0.2991			1		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/22/20 19:00	0.6			1.7			2			0.49			0.2436			0.81		
09/22/20 20:00	0.5			1.7			2			0.58			0.29166			0.97		
09/22/20 21:00	0.6			1.8			2			0.5			0.24972			0.83		
09/22/20 22:00	0.7			1.7			3			0.43			0.21384			0.71		
09/22/20 23:00	0.7			1.7			3			0.38			0.18912			0.63		
09/23/20 0:00	0.6			1.7			3			0.36			0.18018			0.6		
09/23/20 1:00	0.6			1.7			3			0.36			0.17976			0.6		
09/23/20 2:00	0.6			1.7			3			0.36			0.17982			0.6		
09/23/20 3:00	0.6			1.7			3			0.36			0.17982			0.6		
09/23/20 4:00	0.6			1.7			3			0.36			0.18078			0.6		
09/23/20 5:00	0.8			1.7			3			0.39			0.1959			0.65		
09/23/20 6:00	0.8			1.7			3			0.39			0.19698			0.66		
09/23/20 7:00	0.8			1.7			3			0.4			0.20244			0.67		
09/23/20 8:00	0.6			1.7			3			0.45			0.22692			0.76		
09/23/20 9:00	0.6			1.7			2			0.51			0.25578			0.85		
09/23/20 10:00	0.6			1.7			2			0.52			0.25884			0.86		
09/23/20 11:00	0.9			1.7			2			0.56			0.2808			0.94		
09/23/20 12:00	0.6			1.7			2			0.59			0.29538			0.98		
09/23/20 13:00	0.5			1.7			2			0.6			0.30216			1.01		
09/23/20 14:00	0.1			1.7			3			0.69			0.34296			1.14		
09/23/20 15:00	0.3			1.7			3			0.63			0.31674			1.06		
09/23/20 16:00	0.1			1.7			3			0.69			0.34464			1.15		
09/23/20 17:00	0.1			1.7			4			0.74			0.37044			1.23		
09/23/20 18:00	0.1			1.7			4			0.73			0.36414			1.21		
09/23/20 19:00	0.3			1.7			3			0.64			0.31776			1.06		
09/23/20 20:00	0.9			1.7			2			0.56			0.27942			0.93		
09/23/20 21:00	1			1.7			2			0.53			0.26514			0.88		
09/23/20 22:00	0.6			1.7			3			0.44			0.22176			0.74		
09/23/20 23:00	0			0			0	X		0.16			0.0777			0.26		
09/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
09/28/20 4:00	0			0			0	X		0.19			0.09384			0.31		
09/28/20 5:00	0.7			1.7			4			0.39			0.1926			0.64		
09/28/20 6:00	0.7			1.7			3			0.37			0.18486			0.62		
09/28/20 7:00	0.7			1.7			3			0.39			0.1974			0.66		
09/28/20 8:00	0.7			1.7			3			0.44			0.22176			0.74		
09/28/20 9:00	0.7			1.7			3			0.44			0.22188			0.74		
09/28/20 10:00	0.7			1.7			3			0.43			0.21732			0.72		
09/28/20 11:00	0.7			1.7			2			0.46			0.22842			0.76		
09/28/20 12:00	0.7			1.7			2			0.48			0.24084			0.8		
09/28/20 13:00	0.2			1.7			4			0.73			0.36612			1.22		
09/28/20 14:00	0.1			1.7			4			0.73			0.36342			1.21		
09/28/20 15:00	0.1			1.7			4			0.72			0.35964			1.2		
09/28/20 16:00	0.4			1.7			3			0.6			0.30246			1.01		
09/28/20 17:00	0.7			1.7			2			0.56			0.28158			0.94		
09/28/20 18:00	0.9			1.7			2			0.53			0.26412			0.88		
09/28/20 19:00	0.8			1.7			2			0.48			0.2406			0.8		
09/28/20 20:00	0.8			1.7			3			0.44			0.21894			0.73		
09/28/20 21:00	0.7			1.7			3			0.37			0.18546			0.62		
09/28/20 22:00	0.7			1.7			3			0.36			0.17976			0.6		
09/28/20 23:00	0.7			1.7			3			0.43			0.21684			0.72		
09/29/20 0:00	0.7			1.7			3			0.38			0.1875			0.63		
09/29/20 1:00	0.7			1.7			3			0.36			0.17982			0.6		
09/29/20 2:00	0.6			1.7			3			0.36			0.17928			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/29/20 3:00	0.6			1.7			3			0.36			0.17964			0.6		
09/29/20 4:00	0.7			1.6			3			0.37			0.18612			0.62		
09/29/20 5:00	0.7			1.7			3			0.36			0.17916			0.6		
09/29/20 6:00	1			1.7			3			0.36			0.17856			0.6		
09/29/20 7:00	1.1			1.7			4			0.38			0.18834			0.63		
09/29/20 8:00	1			1.7			3			0.42			0.20754			0.69		
09/29/20 9:00	0.7			1.7			3			0.44			0.22008			0.73		
09/29/20 10:00	0.7			1.7			2			0.49			0.24528			0.82		
09/29/20 11:00	1.1			1.7			2			0.54			0.26928			0.9		
09/29/20 12:00	0.2			1.7			3			0.68			0.34068			1.14		
09/29/20 13:00	0.1			1.7			3			0.7			0.34866			1.16		
09/29/20 14:00	0.1			1.7			4			0.71			0.35616			1.19		
09/29/20 15:00	0.1			1.7			3			0.69			0.3453			1.15		
09/29/20 16:00	0.2			1.7			3			0.66			0.3315			1.11		
09/29/20 17:00	0.2			1.7			3			0.67			0.33708			1.12		
09/29/20 18:00	0.9			1.7			2			0.56			0.27828			0.93		
09/29/20 19:00	1.1			1.7			3			0.46			0.23076			0.77		
09/29/20 20:00	1.6			1.7			2			0.53			0.26322			0.88		
09/29/20 21:00	0.6			1.7			2			0.61			0.30498			1.02		
09/29/20 22:00	0.9			1.8			2			0.49			0.24372			0.81		
09/29/20 23:00	0.8			1.7			3			0.36			0.18162			0.61		
09/30/20 0:00	0.9			1.7			2			0.36			0.17982			0.6		
09/30/20 1:00	0.9			1.7			3			0.36			0.18036			0.6		
09/30/20 2:00	0.8			1.7			3			0.37			0.18594			0.62		
09/30/20 3:00	0.7			1.7			3			0.36			0.1803			0.6		
09/30/20 4:00	0.8			1.7			3			0.36			0.1797			0.6		
09/30/20 5:00	1			1.7			3			0.36			0.17982			0.6		
09/30/20 6:00	0.9			1.7			3			0.36			0.1797			0.6		
09/30/20 7:00	0.9			1.7			3			0.36			0.17982			0.6		
09/30/20 8:00	0.9			1.7			3			0.4			0.19974			0.67		
09/30/20 9:00	0.9			1.7			3			0.42			0.21018			0.7		
09/30/20 10:00	1.1			1.7			2			0.51			0.25578			0.85		
09/30/20 11:00	1.1			1.7			2			0.55			0.27306			0.91		
09/30/20 12:00	0.4			1.7			3			0.64			0.3192			1.06		
09/30/20 13:00	0.1			1.7			4			0.73			0.36642			1.22		
09/30/20 14:00	0.1			1.7			4			0.74			0.36966			1.23		
09/30/20 15:00	0.1			1.7			4			0.7			0.35142			1.17		
09/30/20 16:00	0.1			1.7			4			0.72			0.35916			1.2		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/30/20 17:00	0.2			1.7			3			0.66			0.33006			1.1		
09/30/20 18:00	0.4			1.7			3			0.62			0.31068			1.04		
09/30/20 19:00	0.9			1.7			2			0.55			0.2748			0.92		
09/30/20 20:00	1.1			1.7			2			0.53			0.26634			0.89		
09/30/20 21:00	0.6			1.7			2			0.61			0.30264			1.01		
09/30/20 22:00	1.1			1.7			2			0.52			0.2607			0.87		
09/30/20 23:00	0.8			1.7			3			0.46			0.22968			0.77		

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.0	0.00	0.00
07/02/2020	0.00	0.00	0.0	0.00	0.00
07/03/2020	0.00	0.00	0.0	0.00	0.00
07/04/2020	0.00	0.00	0.0	0.00	0.00
07/05/2020	0.00	0.00	0.0	0.00	0.00
07/06/2020	0.00	0.00	0.0	0.00	0.00
07/07/2020	0.00	0.00	0.0	0.00	0.00
07/08/2020	0.00	0.00	0.0	0.00	0.00
07/09/2020	0.00	0.00	0.0	0.00	0.00
07/10/2020	0.00	0.00	0.0	0.00	0.00
07/11/2020	0.00	0.00	0.0	0.00	0.00
07/12/2020	0.00	0.00	0.0	0.00	0.00
07/13/2020	36.55	56.55	4.5	8.94	14.89
07/14/2020	13.38	62.85	6.1	11.99	19.97
07/15/2020	10.76	62.90	6.3	12.06	20.10
07/16/2020	11.77	61.73	6.0	11.75	19.60
07/17/2020	12.17	57.18	5.6	10.97	18.30
07/18/2020	12.14	63.96	6.4	12.25	20.43
07/19/2020	12.58	62.11	6.1	11.88	19.75
07/20/2020	12.20	60.64	6.3	11.54	19.27
07/21/2020	12.72	10.36	1.0	1.83	3.05
07/22/2020	0.00	0.00	0.0	0.00	0.00
07/23/2020	0.00	0.00	0.0	0.00	0.00
07/24/2020	0.00	0.00	0.0	0.00	0.00
07/25/2020	0.00	0.00	0.0	0.00	0.00
07/26/2020	36.67	68.45	5.8	11.25	18.73
07/27/2020	11.29	66.06	6.5	12.54	20.90
07/28/2020	11.31	64.60	6.3	12.37	20.55
07/29/2020	11.58	64.35	6.5	12.34	20.51
07/30/2020	10.29	60.18	6.3	12.21	20.30
07/31/2020	11.29	62.66	6.0	11.94	19.83
Monthly Avg/Sum*:	226.70 *	884.58 *	85.7 *	165.86 *	276.18 *
Daily Min:	10.29	10.36	1.0	1.83	3.05
Daily Max:	36.67	68.45	6.5	12.54	20.90
Jul 2020 - Jul 2020	226.70	884.58	85.7	165.86	276.18
QTD:	226.70 *	884.58 *	85.7 *	165.86 *	276.18 *
YTD 2020:	780.58 *	1,891.85 *	179.0 *	350.87 *	584.37 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2020	12.90	60.06	5.9	11.42	18.98
08/02/2020	11.22	60.00	5.8	11.62	19.33
08/03/2020	11.51	61.26	6.2	11.78	19.58
08/04/2020	12.01	61.12	6.2	11.66	19.36
08/05/2020	22.67	55.87	5.3	10.50	17.45
08/06/2020	0.00	0.00	0.0	0.00	0.00
08/07/2020	0.00	0.00	0.0	0.00	0.00
08/08/2020	25.71	11.34	0.2	0.45	0.76
08/09/2020	10.30	69.30	6.8	13.23	21.99
08/10/2020	11.88	64.98	6.4	12.43	20.70
08/11/2020	15.40	58.05	5.7	11.19	18.53
08/12/2020	11.68	66.88	6.7	12.76	21.24
08/13/2020	11.56	67.50	6.7	12.89	21.52
08/14/2020	11.87	73.59	7.2	14.13	23.56
08/15/2020	9.21	74.68	7.3	14.30	23.84
08/16/2020	13.12	69.95	6.6	13.39	22.30
08/17/2020	15.38	71.10	6.8	13.63	22.69
08/18/2020	15.44	67.01	6.5	12.78	21.29
08/19/2020	15.72	71.49	6.7	13.63	22.77
08/20/2020	19.84	53.16	5.2	10.18	16.95
08/21/2020	14.30	63.70	6.2	12.18	20.31
08/22/2020	17.84	61.64	6.1	11.75	19.63
08/23/2020	15.16	63.01	6.3	12.06	20.09
08/24/2020	16.01	66.25	6.3	12.65	21.00
08/25/2020	14.77	63.12	6.0	12.10	20.15
08/26/2020	13.75	63.99	6.4	12.20	20.33
08/27/2020	14.82	59.50	5.7	11.33	18.88
08/28/2020	13.65	63.12	6.2	12.03	20.09
08/29/2020	14.07	58.71	5.7	11.16	18.60
08/30/2020	13.54	59.40	5.7	11.41	18.96
08/31/2020	15.05	75.77	7.1	14.54	24.21
Monthly Avg/Sum*:	420.38 *	1,815.55 *	175.9 *	345.38 *	575.09 *
Daily Min:	9.21	11.34	0.2	0.45	0.76
Daily Max:	25.71	75.77	7.3	14.54	24.21
Jul 2020 - Aug 2020	647.08	2,700.13	261.6	511.24	851.27
QTD:	647.08 *	2,700.13 *	261.6 *	511.24 *	851.27 *
YTD 2020:	1,200.96 *	3,707.40 *	354.9 *	696.25 *	1,159.46 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2020	14.35	66.65	6.6	12.77	21.29
09/02/2020	13.96	60.57	5.6	11.65	19.45
09/03/2020	8.69	68.03	6.7	12.91	21.53
09/04/2020	8.97	70.01	6.9	13.23	22.07
09/05/2020	9.47	68.44	6.8	13.04	21.73
09/06/2020	10.69	67.37	6.5	12.77	21.29
09/07/2020	14.07	64.51	6.3	12.32	20.52
09/08/2020	12.75	55.74	5.2	10.69	17.80
09/09/2020	8.42	67.46	6.8	12.92	21.49
09/10/2020	17.10	56.19	5.6	10.70	17.87
09/11/2020	17.45	55.46	5.4	10.62	17.66
09/12/2020	18.09	57.18	5.6	10.96	18.25
09/13/2020	18.28	59.72	5.8	11.37	18.95
09/14/2020	12.44	61.64	6.0	11.81	19.71
09/15/2020	11.47	63.26	6.1	12.03	20.07
09/16/2020	10.56	66.84	6.6	12.80	21.36
09/17/2020	12.64	64.39	6.3	12.26	20.41
09/18/2020	13.57	61.25	6.1	11.76	19.57
09/19/2020	13.60	59.12	5.8	11.24	18.76
09/20/2020	12.07	59.17	5.7	11.23	18.72
09/21/2020	11.20	65.95	6.7	12.68	21.16
09/22/2020	11.74	64.66	5.9	12.33	20.56
09/23/2020	19.30	62.94	6.1	11.87	19.79
09/24/2020	0.00	0.00	0.0	0.00	0.00
09/25/2020	0.00	0.00	0.0	0.00	0.00
09/26/2020	0.00	0.00	0.0	0.00	0.00
09/27/2020	0.00	0.00	0.0	0.00	0.00
09/28/2020	35.58	58.54	4.7	9.40	15.69
09/29/2020	14.48	62.52	5.9	11.94	19.91
09/30/2020	14.59	64.07	6.5	12.25	20.43
Monthly Avg/Sum*:	365.53 *	1,631.68 *	158.2 *	309.55 *	516.04 *
Daily Min:	8.42	55.46	4.7	9.40	15.69
Daily Max:	35.58	70.01	6.9	13.23	22.07
Jul 2020 - Sep 2020	1,012.61	4,331.81	419.8	820.79	1,367.31
QTD:	1,012.61 *	4,331.81 *	419.8 *	820.79 *	1,367.31 *
YTD 2020:	1,566.49 *	5,339.08 *	513.1 *	1,005.80 *	1,675.50 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.0	0.00	0.00
07/02/2020	0.00	0.00	0.0	0.00	0.00
07/03/2020	0.00	0.00	0.0	0.00	0.00
07/04/2020	0.00	0.00	0.0	0.00	0.00
07/05/2020	0.00	0.00	0.0	0.00	0.00
07/06/2020	0.00	0.00	0.0	0.00	0.00
07/07/2020	0.00	0.00	0.0	0.00	0.00
07/08/2020	0.00	0.00	0.0	0.00	0.00
07/09/2020	0.00	0.00	0.0	0.00	0.00
07/10/2020	0.00	0.00	0.0	0.00	0.00
07/11/2020	0.00	0.00	0.0	0.00	0.00
07/12/2020	0.00	0.00	0.0	0.00	0.00
07/13/2020	34.94	64.16	4.9	9.88	16.44
07/14/2020	11.59	55.97	6.0	11.32	18.84
07/15/2020	10.42	59.74	6.1	11.44	18.98
07/16/2020	11.13	58.15	5.9	11.13	18.50
07/17/2020	12.18	55.54	5.4	10.59	17.61
07/18/2020	12.11	61.19	6.2	11.68	19.43
07/19/2020	11.92	59.38	6.0	11.33	18.82
07/20/2020	12.05	58.17	5.5	11.06	18.41
07/21/2020	19.20	10.32	1.0	1.79	2.97
07/22/2020	0.00	0.00	0.0	0.00	0.00
07/23/2020	0.00	0.00	0.0	0.00	0.00
07/24/2020	0.00	0.00	0.0	0.00	0.00
07/25/2020	23.50	13.62	0.2	0.52	0.86
07/26/2020	13.00	61.16	6.1	11.75	19.55
07/27/2020	12.06	64.46	6.4	12.30	20.47
07/28/2020	11.11	62.18	6.0	11.78	19.60
07/29/2020	11.11	61.91	6.4	11.80	19.60
07/30/2020	10.88	60.65	6.0	11.65	19.32
07/31/2020	10.82	60.12	5.9	11.40	18.95
Monthly Avg/Sum*:	228.02 *	866.72 *	84.0 *	161.42 *	268.35 *
Daily Min:	10.42	10.32	0.2	0.52	0.86
Daily Max:	34.94	64.46	6.4	12.30	20.47
Jul 2020 - Jul 2020	228.02	866.72	84.0	161.42	268.35
QTD:	228.02 *	866.72 *	84.0 *	161.42 *	268.35 *
YTD 2020:	719.72 *	2,134.85 *	202.9 *	393.58 *	655.01 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2020	12.28	57.11	5.8	10.93	18.15
08/02/2020	11.14	57.79	5.7	11.12	18.58
08/03/2020	11.33	59.14	5.8	11.35	18.86
08/04/2020	11.42	58.29	6.0	11.12	18.50
08/05/2020	24.72	51.48	5.1	9.58	15.94
08/06/2020	0.00	0.00	0.0	0.00	0.00
08/07/2020	0.00	0.00	0.0	0.00	0.00
08/08/2020	35.77	58.40	4.1	9.08	15.11
08/09/2020	10.21	66.22	6.7	12.60	21.04
08/10/2020	11.70	63.60	6.2	12.07	20.09
08/11/2020	14.39	55.58	5.6	10.66	17.69
08/12/2020	10.80	63.76	6.6	12.18	20.27
08/13/2020	11.33	64.92	6.3	12.36	20.65
08/14/2020	11.83	71.08	7.1	13.60	22.71
08/15/2020	9.32	71.98	6.9	13.73	22.90
08/16/2020	13.37	67.77	6.4	12.96	21.60
08/17/2020	15.48	67.52	6.6	13.19	21.96
08/18/2020	14.85	63.86	6.4	12.23	20.38
08/19/2020	14.84	69.40	6.5	13.24	22.11
08/20/2020	19.50	52.29	5.1	9.96	16.65
08/21/2020	14.30	61.26	5.9	11.73	19.59
08/22/2020	17.51	59.12	5.7	11.23	18.78
08/23/2020	14.68	60.31	5.7	11.49	19.20
08/24/2020	15.41	64.01	6.2	12.17	20.31
08/25/2020	13.78	61.08	5.8	11.64	19.41
08/26/2020	13.16	62.01	6.1	11.87	19.76
08/27/2020	14.20	56.83	5.7	10.88	18.11
08/28/2020	13.10	60.93	5.9	11.60	19.34
08/29/2020	13.04	56.92	5.4	10.83	18.02
08/30/2020	19.32	55.15	5.3	10.25	17.04
08/31/2020	18.14	33.14	2.2	4.47	7.44
Monthly Avg/Sum*:	430.92 *	1,750.95 *	168.8 *	330.12 *	550.19 *
Daily Min:	9.32	33.14	2.2	4.47	7.44
Daily Max:	35.77	71.98	7.1	13.73	22.90
Jul 2020 - Aug 2020	658.94	2,617.67	252.8	491.54	818.54
QTD:	658.94 *	2,617.67 *	252.8 *	491.54 *	818.54 *
YTD 2020:	1,150.64 *	3,885.80 *	371.7 *	723.70 *	1,205.20 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2020	13.66	64.61	6.0	12.30	20.49
09/02/2020	14.97	60.70	5.5	11.60	19.35
09/03/2020	11.22	67.72	6.5	12.88	21.48
09/04/2020	11.07	68.62	6.8	13.08	21.82
09/05/2020	11.84	66.04	6.6	12.67	21.13
09/06/2020	12.61	64.69	5.9	12.37	20.61
09/07/2020	16.01	61.84	5.8	11.82	19.64
09/08/2020	15.11	55.10	5.2	10.56	17.60
09/09/2020	11.07	65.84	6.8	12.62	21.02
09/10/2020	19.47	53.82	5.3	10.29	17.16
09/11/2020	19.75	54.47	5.1	10.41	17.40
09/12/2020	20.40	56.04	5.3	10.71	17.85
09/13/2020	20.25	55.98	5.8	10.90	18.23
09/14/2020	15.49	60.30	5.8	11.46	19.14
09/15/2020	15.29	61.25	5.8	11.75	19.60
09/16/2020	14.96	66.11	6.4	12.68	21.13
09/17/2020	17.13	64.54	6.2	12.33	20.56
09/18/2020	17.13	60.66	6.0	11.58	19.30
09/19/2020	17.03	58.05	5.4	11.01	18.34
09/20/2020	15.14	56.72	5.5	10.91	18.17
09/21/2020	14.31	64.91	6.2	12.45	20.74
09/22/2020	14.97	63.23	5.9	12.06	20.10
09/23/2020	14.67	62.74	6.1	12.00	20.05
09/24/2020	15.83	62.42	6.0	12.31	20.53
09/25/2020	17.37	55.78	4.9	10.67	17.82
09/26/2020	15.02	50.38	4.8	9.53	15.93
09/27/2020	15.99	52.41	4.8	9.99	16.66
09/28/2020	15.44	57.18	5.4	10.90	18.17
09/29/2020	18.31	60.36	5.7	11.62	19.38
09/30/2020	17.52	61.17	6.1	11.75	19.58
Monthly Avg/Sum*:	469.03 *	1,813.68 *	173.6 *	347.21 *	578.98 *
Daily Min:	11.07	50.38	4.8	9.53	15.93
Daily Max:	20.40	68.62	6.8	13.08	21.82
Jul 2020 - Sep 2020	1,127.97	4,431.35	426.4	838.75	1,397.52
QTD:	1,127.97 *	4,431.35 *	426.4 *	838.75 *	1,397.52 *
YTD 2020:	1,619.67 *	5,699.48 *	545.3 *	1,070.91 *	1,784.18 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.00	0.00	0.00
07/02/2020	0.00	0.00	0.00	0.00	0.00
07/03/2020	0.00	0.00	0.00	0.00	0.00
07/04/2020	0.00	0.00	0.00	0.00	0.00
07/05/2020	0.00	0.00	0.00	0.00	0.00
07/06/2020	0.00	0.00	0.00	0.00	0.00
07/07/2020	0.00	0.00	0.00	0.00	0.00
07/08/2020	0.00	0.00	0.00	0.00	0.00
07/09/2020	0.00	0.00	0.00	0.00	0.00
07/10/2020	0.00	0.00	0.00	0.00	0.00
07/11/2020	0.00	0.00	0.00	0.00	0.00
07/12/2020	0.00	0.00	0.00	0.00	0.00
07/13/2020	71.49	120.71	9.39	18.82	31.33
07/14/2020	24.97	118.82	11.66	23.31	38.81
07/15/2020	21.18	122.64	11.73	23.50	39.08
07/16/2020	22.90	119.88	11.44	22.88	38.10
07/17/2020	24.35	112.72	10.79	21.56	35.91
07/18/2020	24.25	125.15	11.97	23.93	39.86
07/19/2020	24.50	121.49	11.60	23.21	38.57
07/20/2020	24.25	118.81	11.32	22.60	37.68
07/21/2020	31.92	20.68	1.82	3.62	6.02
07/22/2020	0.00	0.00	0.00	0.00	0.00
07/23/2020	0.00	0.00	0.00	0.00	0.00
07/24/2020	0.00	0.00	0.00	0.00	0.00
07/25/2020	23.50	13.62	0.26	0.52	0.86
07/26/2020	49.67	129.61	11.49	23.00	38.28
07/27/2020	23.35	130.52	12.40	24.84	41.37
07/28/2020	22.42	126.78	12.07	24.15	40.15
07/29/2020	22.69	126.26	12.05	24.14	40.11
07/30/2020	21.45	121.89	11.91	23.86	39.62
07/31/2020	22.11	122.78	11.68	23.34	38.78
Monthly Avg/Sum*:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
Daily Min:	21.18	13.62	0.26	0.52	0.86
Daily Max:	71.49	130.52	12.40	24.84	41.37
Jul 2020 - Jul 2020	455.00	1,752.36	163.58	327.28	544.53
QTD:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
YTD 2020:	1,510.06 *	4,027.76 *	372.07 *	744.45 *	1,239.38 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2020	25.18	117.17	11.17	22.35	37.13
08/02/2020	22.36	117.79	11.37	22.74	37.91
08/03/2020	22.84	120.40	11.55	23.13	38.44
08/04/2020	23.43	119.41	11.37	22.78	37.86
08/05/2020	47.39	107.35	10.05	20.08	33.39
08/06/2020	0.00	0.00	0.00	0.00	0.00
08/07/2020	0.00	0.00	0.00	0.00	0.00
08/08/2020	61.48	69.74	4.76	9.53	15.87
08/09/2020	20.51	135.52	12.91	25.83	43.03
08/10/2020	23.58	128.58	12.23	24.50	40.79
08/11/2020	29.79	113.63	10.91	21.85	36.22
08/12/2020	22.48	130.64	12.43	24.94	41.51
08/13/2020	22.89	132.42	12.62	25.25	42.17
08/14/2020	23.70	144.67	13.90	27.73	46.27
08/15/2020	18.53	146.66	14.02	28.03	46.74
08/16/2020	26.49	137.72	13.18	26.35	43.90
08/17/2020	30.86	138.62	13.35	26.82	44.65
08/18/2020	30.29	130.87	12.51	25.01	41.67
08/19/2020	30.56	140.89	13.46	26.87	44.88
08/20/2020	39.34	105.45	10.05	20.14	33.60
08/21/2020	28.60	124.96	11.96	23.91	39.90
08/22/2020	35.35	120.76	11.53	22.98	38.41
08/23/2020	29.84	123.32	11.74	23.55	39.29
08/24/2020	31.42	130.26	12.41	24.82	41.31
08/25/2020	28.55	124.20	11.88	23.74	39.56
08/26/2020	26.91	126.00	12.04	24.07	40.09
08/27/2020	29.02	116.33	11.13	22.21	36.99
08/28/2020	26.75	124.05	11.82	23.63	39.43
08/29/2020	27.11	115.63	10.99	21.99	36.62
08/30/2020	32.86	114.55	10.86	21.66	36.00
08/31/2020	33.19	108.91	9.49	19.01	31.65
Monthly Avg/Sum*:	851.30 *	3,566.50 *	337.69 *	675.50 *	1,125.28 *
Daily Min:	18.53	69.74	4.76	9.53	15.87
Daily Max:	61.48	146.66	14.02	28.03	46.74
Jul 2020 - Aug 2020	1,306.30	5,318.86	501.27	1,002.78	1,669.81
QTD:	1,306.30 *	5,318.86 *	501.27 *	1,002.78 *	1,669.81 *
YTD 2020:	2,361.36 *	7,594.26 *	709.76 *	1,419.95 *	2,364.66 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2020	28.01	131.26	12.54	25.07	41.78
09/02/2020	28.93	121.27	11.65	23.25	38.80
09/03/2020	19.91	135.75	12.87	25.79	43.01
09/04/2020	20.04	138.63	13.20	26.31	43.89
09/05/2020	21.31	134.48	12.86	25.71	42.86
09/06/2020	23.30	132.06	12.59	25.14	41.90
09/07/2020	30.08	126.35	12.07	24.14	40.16
09/08/2020	27.86	110.84	10.64	21.25	35.40
09/09/2020	19.49	133.30	12.76	25.54	42.51
09/10/2020	36.57	110.01	10.52	20.99	35.03
09/11/2020	37.20	109.93	10.50	21.03	35.06
09/12/2020	38.49	113.22	10.83	21.67	36.10
09/13/2020	38.53	115.70	11.16	22.27	37.18
09/14/2020	27.93	121.94	11.65	23.27	38.85
09/15/2020	26.76	124.51	11.90	23.78	39.67
09/16/2020	25.52	132.95	12.74	25.48	42.49
09/17/2020	29.77	128.93	12.30	24.59	40.97
09/18/2020	30.70	121.91	11.66	23.34	38.87
09/19/2020	30.63	117.17	11.12	22.25	37.10
09/20/2020	27.21	115.89	11.05	22.14	36.89
09/21/2020	25.51	130.86	12.58	25.13	41.90
09/22/2020	26.71	127.89	12.20	24.39	40.66
09/23/2020	33.97	125.68	11.96	23.87	39.84
09/24/2020	15.83	62.42	6.14	12.31	20.53
09/25/2020	17.37	55.78	5.34	10.67	17.82
09/26/2020	15.02	50.38	4.79	9.53	15.93
09/27/2020	15.99	52.41	5.00	9.99	16.66
09/28/2020	51.02	115.72	10.15	20.30	33.86
09/29/2020	32.79	122.88	11.78	23.56	39.29
09/30/2020	32.11	125.24	11.99	24.00	40.01
Monthly Avg/Sum*:	834.56 *	3,445.36 *	328.54 *	656.76 *	1,095.02 *
Daily Min:	15.02	50.38	4.79	9.53	15.93
Daily Max:	51.02	138.63	13.20	26.31	43.89
Jul 2020 - Sep 2020	2,140.86	8,764.22	829.81	1,659.54	2,764.83
QTD:	2,140.86 *	8,764.22 *	829.81 *	1,659.54 *	2,764.83 *
YTD 2020:	3,195.92 *	11,039.62 *	1,038.30 *	2,076.71 *	3,459.68 *

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NOx	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM0	16,300	13,692	17,789	17,569	32.67
SOx	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.0	0.00	0.00
07/02/2020	0.00	0.00	0.0	0.00	0.00
07/03/2020	0.00	0.00	0.0	0.00	0.00
07/04/2020	0.00	0.00	0.0	0.00	0.00
07/05/2020	0.00	0.00	0.0	0.00	0.00
07/06/2020	0.00	0.00	0.0	0.00	0.00
07/07/2020	0.00	0.00	0.0	0.00	0.00
07/08/2020	0.00	0.00	0.0	0.00	0.00
07/09/2020	0.00	0.00	0.0	0.00	0.00
07/10/2020	0.00	0.00	0.0	0.00	0.00
07/11/2020	0.00	0.00	0.0	0.00	0.00
07/12/2020	0.00	0.00	0.0	0.00	0.00
07/13/2020	36.55	56.55	4.5	8.94	14.89
07/14/2020	13.38	62.85	6.1	11.99	19.97
07/15/2020	10.76	62.90	6.3	12.06	20.10
07/16/2020	11.77	61.73	6.0	11.75	19.60
07/17/2020	12.17	57.18	5.6	10.97	18.30
07/18/2020	12.14	63.96	6.4	12.25	20.43
07/19/2020	12.58	62.11	6.1	11.88	19.75
07/20/2020	12.20	60.64	6.3	11.54	19.27
07/21/2020	12.72	10.36	1.0	1.83	3.05
07/22/2020	0.00	0.00	0.0	0.00	0.00
07/23/2020	0.00	0.00	0.0	0.00	0.00
07/24/2020	0.00	0.00	0.0	0.00	0.00
07/25/2020	0.00	0.00	0.0	0.00	0.00
07/26/2020	36.67	68.45	5.8	11.25	18.73
07/27/2020	11.29	66.06	6.5	12.54	20.90
07/28/2020	11.31	64.60	6.3	12.37	20.55
07/29/2020	11.58	64.35	6.5	12.34	20.51
07/30/2020	10.29	60.18	6.3	12.21	20.30
07/31/2020	11.29	62.66	6.0	11.94	19.83
Monthly Avg/Sum*:	226.70 *	884.58 *	85.7 *	165.86 *	276.18 *
Daily Min:	10.29	10.36	1.0	1.83	3.05
Daily Max:	36.67	68.45	6.5	12.54	20.90
Jul 2020 - Jul 2020	226.70	884.58	85.7	165.86	276.18
QTD:	226.70 *	884.58 *	85.7 *	165.86 *	276.18 *
YTD 2020:	780.58 *	1,891.85 *	179.0 *	350.87 *	584.37 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
08/01/2020	12.90	60.06	5.9	11.42	18.98
08/02/2020	11.22	60.00	5.8	11.62	19.33
08/03/2020	11.51	61.26	6.2	11.78	19.58
08/04/2020	12.01	61.12	6.2	11.66	19.36
08/05/2020	22.67	55.87	5.3	10.50	17.45
08/06/2020	0.00	0.00	0.0	0.00	0.00
08/07/2020	0.00	0.00	0.0	0.00	0.00
08/08/2020	25.71	11.34	0.2	0.45	0.76
08/09/2020	10.30	69.30	6.8	13.23	21.99
08/10/2020	11.88	64.98	6.4	12.43	20.70
08/11/2020	15.40	58.05	5.7	11.19	18.53
08/12/2020	11.68	66.88	6.7	12.76	21.24
08/13/2020	11.56	67.50	6.7	12.89	21.52
08/14/2020	11.87	73.59	7.2	14.13	23.56
08/15/2020	9.21	74.68	7.3	14.30	23.84
08/16/2020	13.12	69.95	6.6	13.39	22.30
08/17/2020	15.38	71.10	6.8	13.63	22.69
08/18/2020	15.44	67.01	6.5	12.78	21.29
08/19/2020	15.72	71.49	6.7	13.63	22.77
08/20/2020	19.84	53.16	5.2	10.18	16.95
08/21/2020	14.30	63.70	6.2	12.18	20.31
08/22/2020	17.84	61.64	6.1	11.75	19.63
08/23/2020	15.16	63.01	6.3	12.06	20.09
08/24/2020	16.01	66.25	6.3	12.65	21.00
08/25/2020	14.77	63.12	6.0	12.10	20.15
08/26/2020	13.75	63.99	6.4	12.20	20.33
08/27/2020	14.82	59.50	5.7	11.33	18.88
08/28/2020	13.65	63.12	6.2	12.03	20.09
08/29/2020	14.07	58.71	5.7	11.16	18.60
08/30/2020	13.54	59.40	5.7	11.41	18.96
08/31/2020	15.05	75.77	7.1	14.54	24.21
Monthly Avg/Sum*:	420.38 *	1,815.55 *	175.9 *	345.38 *	575.09 *
Daily Min:	9.21	11.34	0.2	0.45	0.76
Daily Max:	25.71	75.77	7.3	14.54	24.21
Jul 2020 - Aug 2020	647.08	2,700.13	261.6	511.24	851.27
QTD:	647.08 *	2,700.13 *	261.6 *	511.24 *	851.27 *
YTD 2020:	1,200.96 *	3,707.40 *	354.9 *	696.25 *	1,159.46 *

Monthly Summary By Day Report

Unit CT1

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:02 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
09/01/2020	14.35	66.65	6.6	12.77	21.29
09/02/2020	13.96	60.57	5.6	11.65	19.45
09/03/2020	8.69	68.03	6.7	12.91	21.53
09/04/2020	8.97	70.01	6.9	13.23	22.07
09/05/2020	9.47	68.44	6.8	13.04	21.73
09/06/2020	10.69	67.37	6.5	12.77	21.29
09/07/2020	14.07	64.51	6.3	12.32	20.52
09/08/2020	12.75	55.74	5.2	10.69	17.80
09/09/2020	8.42	67.46	6.8	12.92	21.49
09/10/2020	17.10	56.19	5.6	10.70	17.87
09/11/2020	17.45	55.46	5.4	10.62	17.66
09/12/2020	18.09	57.18	5.6	10.96	18.25
09/13/2020	18.28	59.72	5.8	11.37	18.95
09/14/2020	12.44	61.64	6.0	11.81	19.71
09/15/2020	11.47	63.26	6.1	12.03	20.07
09/16/2020	10.56	66.84	6.6	12.80	21.36
09/17/2020	12.64	64.39	6.3	12.26	20.41
09/18/2020	13.57	61.25	6.1	11.76	19.57
09/19/2020	13.60	59.12	5.8	11.24	18.76
09/20/2020	12.07	59.17	5.7	11.23	18.72
09/21/2020	11.20	65.95	6.7	12.68	21.16
09/22/2020	11.74	64.66	5.9	12.33	20.56
09/23/2020	19.30	62.94	6.1	11.87	19.79
09/24/2020	0.00	0.00	0.0	0.00	0.00
09/25/2020	0.00	0.00	0.0	0.00	0.00
09/26/2020	0.00	0.00	0.0	0.00	0.00
09/27/2020	0.00	0.00	0.0	0.00	0.00
09/28/2020	35.58	58.54	4.7	9.40	15.69
09/29/2020	14.48	62.52	5.9	11.94	19.91
09/30/2020	14.59	64.07	6.5	12.25	20.43
Monthly Avg/Sum*:	365.53 *	1,631.68 *	158.2 *	309.55 *	516.04 *
Daily Min:	8.42	55.46	4.7	9.40	15.69
Daily Max:	35.58	70.01	6.9	13.23	22.07
Jul 2020 - Sep 2020	1,012.61	4,331.81	419.8	820.79	1,367.31
QTD:	1,012.61 *	4,331.81 *	419.8 *	820.79 *	1,367.31 *
YTD 2020:	1,566.49 *	5,339.08 *	513.1 *	1,005.80 *	1,675.50 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.0	0.00	0.00
07/02/2020	0.00	0.00	0.0	0.00	0.00
07/03/2020	0.00	0.00	0.0	0.00	0.00
07/04/2020	0.00	0.00	0.0	0.00	0.00
07/05/2020	0.00	0.00	0.0	0.00	0.00
07/06/2020	0.00	0.00	0.0	0.00	0.00
07/07/2020	0.00	0.00	0.0	0.00	0.00
07/08/2020	0.00	0.00	0.0	0.00	0.00
07/09/2020	0.00	0.00	0.0	0.00	0.00
07/10/2020	0.00	0.00	0.0	0.00	0.00
07/11/2020	0.00	0.00	0.0	0.00	0.00
07/12/2020	0.00	0.00	0.0	0.00	0.00
07/13/2020	34.94	64.16	4.9	9.88	16.44
07/14/2020	11.59	55.97	6.0	11.32	18.84
07/15/2020	10.42	59.74	6.1	11.44	18.98
07/16/2020	11.13	58.15	5.9	11.13	18.50
07/17/2020	12.18	55.54	5.4	10.59	17.61
07/18/2020	12.11	61.19	6.2	11.68	19.43
07/19/2020	11.92	59.38	6.0	11.33	18.82
07/20/2020	12.05	58.17	5.5	11.06	18.41
07/21/2020	19.20	10.32	1.0	1.79	2.97
07/22/2020	0.00	0.00	0.0	0.00	0.00
07/23/2020	0.00	0.00	0.0	0.00	0.00
07/24/2020	0.00	0.00	0.0	0.00	0.00
07/25/2020	23.50	13.62	0.2	0.52	0.86
07/26/2020	13.00	61.16	6.1	11.75	19.55
07/27/2020	12.06	64.46	6.4	12.30	20.47
07/28/2020	11.11	62.18	6.0	11.78	19.60
07/29/2020	11.11	61.91	6.4	11.80	19.60
07/30/2020	10.88	60.65	6.0	11.65	19.32
07/31/2020	10.82	60.12	5.9	11.40	18.95
Monthly Avg/Sum*:	228.02 *	866.72 *	84.0 *	161.42 *	268.35 *
Daily Min:	10.42	10.32	0.2	0.52	0.86
Daily Max:	34.94	64.46	6.4	12.30	20.47
Jul 2020 - Jul 2020	228.02	866.72	84.0	161.42	268.35
QTD:	228.02 *	866.72 *	84.0 *	161.42 *	268.35 *
YTD 2020:	719.72 *	2,134.85 *	202.9 *	393.58 *	655.01 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2020	12.28	57.11	5.8	10.93	18.15
08/02/2020	11.14	57.79	5.7	11.12	18.58
08/03/2020	11.33	59.14	5.8	11.35	18.86
08/04/2020	11.42	58.29	6.0	11.12	18.50
08/05/2020	24.72	51.48	5.1	9.58	15.94
08/06/2020	0.00	0.00	0.0	0.00	0.00
08/07/2020	0.00	0.00	0.0	0.00	0.00
08/08/2020	35.77	58.40	4.1	9.08	15.11
08/09/2020	10.21	66.22	6.7	12.60	21.04
08/10/2020	11.70	63.60	6.2	12.07	20.09
08/11/2020	14.39	55.58	5.6	10.66	17.69
08/12/2020	10.80	63.76	6.6	12.18	20.27
08/13/2020	11.33	64.92	6.3	12.36	20.65
08/14/2020	11.83	71.08	7.1	13.60	22.71
08/15/2020	9.32	71.98	6.9	13.73	22.90
08/16/2020	13.37	67.77	6.4	12.96	21.60
08/17/2020	15.48	67.52	6.6	13.19	21.96
08/18/2020	14.85	63.86	6.4	12.23	20.38
08/19/2020	14.84	69.40	6.5	13.24	22.11
08/20/2020	19.50	52.29	5.1	9.96	16.65
08/21/2020	14.30	61.26	5.9	11.73	19.59
08/22/2020	17.51	59.12	5.7	11.23	18.78
08/23/2020	14.68	60.31	5.7	11.49	19.20
08/24/2020	15.41	64.01	6.2	12.17	20.31
08/25/2020	13.78	61.08	5.8	11.64	19.41
08/26/2020	13.16	62.01	6.1	11.87	19.76
08/27/2020	14.20	56.83	5.7	10.88	18.11
08/28/2020	13.10	60.93	5.9	11.60	19.34
08/29/2020	13.04	56.92	5.4	10.83	18.02
08/30/2020	19.32	55.15	5.3	10.25	17.04
08/31/2020	18.14	33.14	2.2	4.47	7.44
Monthly Avg/Sum*:	430.92 *	1,750.95 *	168.8 *	330.12 *	550.19 *
Daily Min:	9.32	33.14	2.2	4.47	7.44
Daily Max:	35.77	71.98	7.1	13.73	22.90
Jul 2020 - Aug 2020	658.94	2,617.67	252.8	491.54	818.54
QTD:	658.94 *	2,617.67 *	252.8 *	491.54 *	818.54 *
YTD 2020:	1,150.64 *	3,885.80 *	371.7 *	723.70 *	1,205.20 *

Monthly Summary By Day Report

Unit CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/03/2020 00:03 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2020	13.66	64.61	6.0	12.30	20.49
09/02/2020	14.97	60.70	5.5	11.60	19.35
09/03/2020	11.22	67.72	6.5	12.88	21.48
09/04/2020	11.07	68.62	6.8	13.08	21.82
09/05/2020	11.84	66.04	6.6	12.67	21.13
09/06/2020	12.61	64.69	5.9	12.37	20.61
09/07/2020	16.01	61.84	5.8	11.82	19.64
09/08/2020	15.11	55.10	5.2	10.56	17.60
09/09/2020	11.07	65.84	6.8	12.62	21.02
09/10/2020	19.47	53.82	5.3	10.29	17.16
09/11/2020	19.75	54.47	5.1	10.41	17.40
09/12/2020	20.40	56.04	5.3	10.71	17.85
09/13/2020	20.25	55.98	5.8	10.90	18.23
09/14/2020	15.49	60.30	5.8	11.46	19.14
09/15/2020	15.29	61.25	5.8	11.75	19.60
09/16/2020	14.96	66.11	6.4	12.68	21.13
09/17/2020	17.13	64.54	6.2	12.33	20.56
09/18/2020	17.13	60.66	6.0	11.58	19.30
09/19/2020	17.03	58.05	5.4	11.01	18.34
09/20/2020	15.14	56.72	5.5	10.91	18.17
09/21/2020	14.31	64.91	6.2	12.45	20.74
09/22/2020	14.97	63.23	5.9	12.06	20.10
09/23/2020	14.67	62.74	6.1	12.00	20.05
09/24/2020	15.83	62.42	6.0	12.31	20.53
09/25/2020	17.37	55.78	4.9	10.67	17.82
09/26/2020	15.02	50.38	4.8	9.53	15.93
09/27/2020	15.99	52.41	4.8	9.99	16.66
09/28/2020	15.44	57.18	5.4	10.90	18.17
09/29/2020	18.31	60.36	5.7	11.62	19.38
09/30/2020	17.52	61.17	6.1	11.75	19.58
Monthly Avg/Sum*:	469.03 *	1,813.68 *	173.6 *	347.21 *	578.98 *
Daily Min:	11.07	50.38	4.8	9.53	15.93
Daily Max:	20.40	68.62	6.8	13.08	21.82
Jul 2020 - Sep 2020	1,127.97	4,431.35	426.4	838.75	1,397.52
QTD:	1,127.97 *	4,431.35 *	426.4 *	838.75 *	1,397.52 *
YTD 2020:	1,619.67 *	5,699.48 *	545.3 *	1,070.91 *	1,784.18 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.00	0.00	0.00
07/02/2020	0.00	0.00	0.00	0.00	0.00
07/03/2020	0.00	0.00	0.00	0.00	0.00
07/04/2020	0.00	0.00	0.00	0.00	0.00
07/05/2020	0.00	0.00	0.00	0.00	0.00
07/06/2020	0.00	0.00	0.00	0.00	0.00
07/07/2020	0.00	0.00	0.00	0.00	0.00
07/08/2020	0.00	0.00	0.00	0.00	0.00
07/09/2020	0.00	0.00	0.00	0.00	0.00
07/10/2020	0.00	0.00	0.00	0.00	0.00
07/11/2020	0.00	0.00	0.00	0.00	0.00
07/12/2020	0.00	0.00	0.00	0.00	0.00
07/13/2020	71.49	120.71	9.39	18.82	31.33
07/14/2020	24.97	118.82	11.66	23.31	38.81
07/15/2020	21.18	122.64	11.73	23.50	39.08
07/16/2020	22.90	119.88	11.44	22.88	38.10
07/17/2020	24.35	112.72	10.79	21.56	35.91
07/18/2020	24.25	125.15	11.97	23.93	39.86
07/19/2020	24.50	121.49	11.60	23.21	38.57
07/20/2020	24.25	118.81	11.32	22.60	37.68
07/21/2020	31.92	20.68	1.82	3.62	6.02
07/22/2020	0.00	0.00	0.00	0.00	0.00
07/23/2020	0.00	0.00	0.00	0.00	0.00
07/24/2020	0.00	0.00	0.00	0.00	0.00
07/25/2020	23.50	13.62	0.26	0.52	0.86
07/26/2020	49.67	129.61	11.49	23.00	38.28
07/27/2020	23.35	130.52	12.40	24.84	41.37
07/28/2020	22.42	126.78	12.07	24.15	40.15
07/29/2020	22.69	126.26	12.05	24.14	40.11
07/30/2020	21.45	121.89	11.91	23.86	39.62
07/31/2020	22.11	122.78	11.68	23.34	38.78
Monthly Avg/Sum*:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
Daily Min:	21.18	13.62	0.26	0.52	0.86
Daily Max:	71.49	130.52	12.40	24.84	41.37
Jul 2020 - Jul 2020	455.00	1,752.36	163.58	327.28	544.53
QTD:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
YTD 2020:	1,510.06 *	4,027.76 *	372.07 *	744.45 *	1,239.38 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2020	25.18	117.17	11.17	22.35	37.13
08/02/2020	22.36	117.79	11.37	22.74	37.91
08/03/2020	22.84	120.40	11.55	23.13	38.44
08/04/2020	23.43	119.41	11.37	22.78	37.86
08/05/2020	47.39	107.35	10.05	20.08	33.39
08/06/2020	0.00	0.00	0.00	0.00	0.00
08/07/2020	0.00	0.00	0.00	0.00	0.00
08/08/2020	61.48	69.74	4.76	9.53	15.87
08/09/2020	20.51	135.52	12.91	25.83	43.03
08/10/2020	23.58	128.58	12.23	24.50	40.79
08/11/2020	29.79	113.63	10.91	21.85	36.22
08/12/2020	22.48	130.64	12.43	24.94	41.51
08/13/2020	22.89	132.42	12.62	25.25	42.17
08/14/2020	23.70	144.67	13.90	27.73	46.27
08/15/2020	18.53	146.66	14.02	28.03	46.74
08/16/2020	26.49	137.72	13.18	26.35	43.90
08/17/2020	30.86	138.62	13.35	26.82	44.65
08/18/2020	30.29	130.87	12.51	25.01	41.67
08/19/2020	30.56	140.89	13.46	26.87	44.88
08/20/2020	39.34	105.45	10.05	20.14	33.60
08/21/2020	28.60	124.96	11.96	23.91	39.90
08/22/2020	35.35	120.76	11.53	22.98	38.41
08/23/2020	29.84	123.32	11.74	23.55	39.29
08/24/2020	31.42	130.26	12.41	24.82	41.31
08/25/2020	28.55	124.20	11.88	23.74	39.56
08/26/2020	26.91	126.00	12.04	24.07	40.09
08/27/2020	29.02	116.33	11.13	22.21	36.99
08/28/2020	26.75	124.05	11.82	23.63	39.43
08/29/2020	27.11	115.63	10.99	21.99	36.62
08/30/2020	32.86	114.55	10.86	21.66	36.00
08/31/2020	33.19	108.91	9.49	19.01	31.65
Monthly Avg/Sum*:	851.30 *	3,566.50 *	337.69 *	675.50 *	1,125.28 *
Daily Min:	18.53	69.74	4.76	9.53	15.87
Daily Max:	61.48	146.66	14.02	28.03	46.74
Jul 2020 - Aug 2020	1,306.30	5,318.86	501.27	1,002.78	1,669.81
QTD:	1,306.30 *	5,318.86 *	501.27 *	1,002.78 *	1,669.81 *
YTD 2020:	2,361.36 *	7,594.26 *	709.76 *	1,419.95 *	2,364.66 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2020	28.01	131.26	12.54	25.07	41.78
09/02/2020	28.93	121.27	11.65	23.25	38.80
09/03/2020	19.91	135.75	12.87	25.79	43.01
09/04/2020	20.04	138.63	13.20	26.31	43.89
09/05/2020	21.31	134.48	12.86	25.71	42.86
09/06/2020	23.30	132.06	12.59	25.14	41.90
09/07/2020	30.08	126.35	12.07	24.14	40.16
09/08/2020	27.86	110.84	10.64	21.25	35.40
09/09/2020	19.49	133.30	12.76	25.54	42.51
09/10/2020	36.57	110.01	10.52	20.99	35.03
09/11/2020	37.20	109.93	10.50	21.03	35.06
09/12/2020	38.49	113.22	10.83	21.67	36.10
09/13/2020	38.53	115.70	11.16	22.27	37.18
09/14/2020	27.93	121.94	11.65	23.27	38.85
09/15/2020	26.76	124.51	11.90	23.78	39.67
09/16/2020	25.52	132.95	12.74	25.48	42.49
09/17/2020	29.77	128.93	12.30	24.59	40.97
09/18/2020	30.70	121.91	11.66	23.34	38.87
09/19/2020	30.63	117.17	11.12	22.25	37.10
09/20/2020	27.21	115.89	11.05	22.14	36.89
09/21/2020	25.51	130.86	12.58	25.13	41.90
09/22/2020	26.71	127.89	12.20	24.39	40.66
09/23/2020	33.97	125.68	11.96	23.87	39.84
09/24/2020	15.83	62.42	6.14	12.31	20.53
09/25/2020	17.37	55.78	5.34	10.67	17.82
09/26/2020	15.02	50.38	4.79	9.53	15.93
09/27/2020	15.99	52.41	5.00	9.99	16.66
09/28/2020	51.02	115.72	10.15	20.30	33.86
09/29/2020	32.79	122.88	11.78	23.56	39.29
09/30/2020	32.11	125.24	11.99	24.00	40.01
Monthly Avg/Sum*:	834.56 *	3,445.36 *	328.54 *	656.76 *	1,095.02 *
Daily Min:	15.02	50.38	4.79	9.53	15.93
Daily Max:	51.02	138.63	13.20	26.31	43.89
Jul 2020 - Sep 2020	2,140.86	8,764.22	829.81	1,659.54	2,764.83
QTD:	2,140.86 *	8,764.22 *	829.81 *	1,659.54 *	2,764.83 *
YTD 2020:	3,195.92 *	11,039.62 *	1,038.30 *	2,076.71 *	3,459.68 *

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Replace the dates with the ones you need

7/1/2020 0:00
9/30/2020 0:00

1D

TOWER AVG.

3988

	519-AIT-9504-1
7/1/20 0:00	2530.6
7/2/20 0:00	2453.7
7/3/20 0:00	2182.4
7/4/20 0:00	2040.5
7/5/20 0:00	1978.6
7/6/20 0:00	2006.7
7/7/20 0:00	1938.4
7/8/20 0:00	1964.2
7/9/20 0:00	2008.1
7/10/20 0:00	2032.2
7/11/20 0:00	1995.3
7/12/20 0:00	2020.8
7/13/20 0:00	1988.9
7/14/20 0:00	4100.4
7/15/20 0:00	4487.9
7/16/20 0:00	4770.1
7/17/20 0:00	4103.8
7/18/20 0:00	4222.2
7/19/20 0:00	4652.6
7/20/20 0:00	4806.5
7/21/20 0:00	4559.8
7/22/20 0:00	3295.2
7/23/20 0:00	3025.0
7/24/20 0:00	2859.0
7/25/20 0:00	2491.3
7/26/20 0:00	2181.8
7/27/20 0:00	3641.2
7/28/20 0:00	4343.4
7/29/20 0:00	3834.0
7/30/20 0:00	4553.9
7/31/20 0:00	4784.1
8/1/20 0:00	4891.7
8/2/20 0:00	5320.6
8/3/20 0:00	5031.3
8/4/20 0:00	5547.7
8/5/20 0:00	5279.8
8/6/20 0:00	5622.8
8/7/20 0:00	4441.2
8/8/20 0:00	3918.0
8/9/20 0:00	4677.4
8/10/20 0:00	4674.2
8/11/20 0:00	4651.4
8/12/20 0:00	5394.8
8/13/20 0:00	4883.8
8/14/20 0:00	5114.4
8/15/20 0:00	5407.6
8/16/20 0:00	4744.3
8/17/20 0:00	5097.4
8/18/20 0:00	5074.8

8/19/20 0:00	5207.1
8/20/20 0:00	5004.4
8/21/20 0:00	5046.1
8/22/20 0:00	5004.9
8/23/20 0:00	4260.5
8/24/20 0:00	4423.8
8/25/20 0:00	4603.9
8/26/20 0:00	3971.1
8/27/20 0:00	4479.4
8/28/20 0:00	4435.3
8/29/20 0:00	4409.3
8/30/20 0:00	4167.9
8/31/20 0:00	4407.0
9/1/20 0:00	3809.9
9/2/20 0:00	4231.5
9/3/20 0:00	3985.7
9/4/20 0:00	4071.1
9/5/20 0:00	4015.9
9/6/20 0:00	4336.5
9/7/20 0:00	4307.3
9/8/20 0:00	4299.1
9/9/20 0:00	4427.1
9/10/20 0:00	4366.5
9/11/20 0:00	4505.1
9/12/20 0:00	4712.2
9/13/20 0:00	4183.9
9/14/20 0:00	4139.3
9/15/20 0:00	3940.2
9/16/20 0:00	3996.5
9/17/20 0:00	4008.6
9/18/20 0:00	4015.3
9/19/20 0:00	3933.1
9/20/20 0:00	3952.5
9/21/20 0:00	4018.8
9/22/20 0:00	4010.5
9/23/20 0:00	3975.3
9/24/20 0:00	4106.7
9/25/20 0:00	3985.8
9/26/20 0:00	3042.2
9/27/20 0:00	3156.6
9/28/20 0:00	2324.9

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	3988	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00255232**	

Design drift rate	**0.005%**
PM-10 pounds per day	**8.24**
	92 Days in quarter
PM-10 pounds this quarter	**758**

2Q20

fill only these

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2020	0.00	0.00	0.00	0.00	0.00
07/02/2020	0.00	0.00	0.00	0.00	0.00
07/03/2020	0.00	0.00	0.00	0.00	0.00
07/04/2020	0.00	0.00	0.00	0.00	0.00
07/05/2020	0.00	0.00	0.00	0.00	0.00
07/06/2020	0.00	0.00	0.00	0.00	0.00
07/07/2020	0.00	0.00	0.00	0.00	0.00
07/08/2020	0.00	0.00	0.00	0.00	0.00
07/09/2020	0.00	0.00	0.00	0.00	0.00
07/10/2020	0.00	0.00	0.00	0.00	0.00
07/11/2020	0.00	0.00	0.00	0.00	0.00
07/12/2020	0.00	0.00	0.00	0.00	0.00
07/13/2020	71.49	120.71	9.39	18.82	31.33
07/14/2020	24.97	118.82	11.66	23.31	38.81
07/15/2020	21.18	122.64	11.73	23.50	39.08
07/16/2020	22.90	119.88	11.44	22.88	38.10
07/17/2020	24.35	112.72	10.79	21.56	35.91
07/18/2020	24.25	125.15	11.97	23.93	39.86
07/19/2020	24.50	121.49	11.60	23.21	38.57
07/20/2020	24.25	118.81	11.32	22.60	37.68
07/21/2020	31.92	20.68	1.82	3.62	6.02
07/22/2020	0.00	0.00	0.00	0.00	0.00
07/23/2020	0.00	0.00	0.00	0.00	0.00
07/24/2020	0.00	0.00	0.00	0.00	0.00
07/25/2020	23.50	13.62	0.26	0.52	0.86
07/26/2020	49.67	129.61	11.49	23.00	38.28
07/27/2020	23.35	130.52	12.40	24.84	41.37
07/28/2020	22.42	126.78	12.07	24.15	40.15
07/29/2020	22.69	126.26	12.05	24.14	40.11
07/30/2020	21.45	121.89	11.91	23.86	39.62
07/31/2020	22.11	122.78	11.68	23.34	38.78
Monthly Avg/Sum*:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
Daily Min:	21.18	13.62	0.26	0.52	0.86
Daily Max:	71.49	130.52	12.40	24.84	41.37
Jul 2020 - Jul 2020	455.00	1,752.36	163.58	327.28	544.53
QTD:	455.00 *	1,752.36 *	163.58 *	327.28 *	544.53 *
YTD 2020:	1,510.06 *	4,027.76 *	372.07 *	744.45 *	1,239.38 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2020	25.18	117.17	11.17	22.35	37.13
08/02/2020	22.36	117.79	11.37	22.74	37.91
08/03/2020	22.84	120.40	11.55	23.13	38.44
08/04/2020	23.43	119.41	11.37	22.78	37.86
08/05/2020	47.39	107.35	10.05	20.08	33.39
08/06/2020	0.00	0.00	0.00	0.00	0.00
08/07/2020	0.00	0.00	0.00	0.00	0.00
08/08/2020	61.48	69.74	4.76	9.53	15.87
08/09/2020	20.51	135.52	12.91	25.83	43.03
08/10/2020	23.58	128.58	12.23	24.50	40.79
08/11/2020	29.79	113.63	10.91	21.85	36.22
08/12/2020	22.48	130.64	12.43	24.94	41.51
08/13/2020	22.89	132.42	12.62	25.25	42.17
08/14/2020	23.70	144.67	13.90	27.73	46.27
08/15/2020	18.53	146.66	14.02	28.03	46.74
08/16/2020	26.49	137.72	13.18	26.35	43.90
08/17/2020	30.86	138.62	13.35	26.82	44.65
08/18/2020	30.29	130.87	12.51	25.01	41.67
08/19/2020	30.56	140.89	13.46	26.87	44.88
08/20/2020	39.34	105.45	10.05	20.14	33.60
08/21/2020	28.60	124.96	11.96	23.91	39.90
08/22/2020	35.35	120.76	11.53	22.98	38.41
08/23/2020	29.84	123.32	11.74	23.55	39.29
08/24/2020	31.42	130.26	12.41	24.82	41.31
08/25/2020	28.55	124.20	11.88	23.74	39.56
08/26/2020	26.91	126.00	12.04	24.07	40.09
08/27/2020	29.02	116.33	11.13	22.21	36.99
08/28/2020	26.75	124.05	11.82	23.63	39.43
08/29/2020	27.11	115.63	10.99	21.99	36.62
08/30/2020	32.86	114.55	10.86	21.66	36.00
08/31/2020	33.19	108.91	9.49	19.01	31.65
Monthly Avg/Sum*:	851.30 *	3,566.50 *	337.69 *	675.50 *	1,125.28 *
Daily Min:	18.53	69.74	4.76	9.53	15.87
Daily Max:	61.48	146.66	14.02	28.03	46.74
Jul 2020 - Aug 2020	1,306.30	5,318.86	501.27	1,002.78	1,669.81
QTD:	1,306.30 *	5,318.86 *	501.27 *	1,002.78 *	1,669.81 *
YTD 2020:	2,361.36 *	7,594.26 *	709.76 *	1,419.95 *	2,364.66 *

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:57 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2020	28.01	131.26	12.54	25.07	41.78
09/02/2020	28.93	121.27	11.65	23.25	38.80
09/03/2020	19.91	135.75	12.87	25.79	43.01
09/04/2020	20.04	138.63	13.20	26.31	43.89
09/05/2020	21.31	134.48	12.86	25.71	42.86
09/06/2020	23.30	132.06	12.59	25.14	41.90
09/07/2020	30.08	126.35	12.07	24.14	40.16
09/08/2020	27.86	110.84	10.64	21.25	35.40
09/09/2020	19.49	133.30	12.76	25.54	42.51
09/10/2020	36.57	110.01	10.52	20.99	35.03
09/11/2020	37.20	109.93	10.50	21.03	35.06
09/12/2020	38.49	113.22	10.83	21.67	36.10
09/13/2020	38.53	115.70	11.16	22.27	37.18
09/14/2020	27.93	121.94	11.65	23.27	38.85
09/15/2020	26.76	124.51	11.90	23.78	39.67
09/16/2020	25.52	132.95	12.74	25.48	42.49
09/17/2020	29.77	128.93	12.30	24.59	40.97
09/18/2020	30.70	121.91	11.66	23.34	38.87
09/19/2020	30.63	117.17	11.12	22.25	37.10
09/20/2020	27.21	115.89	11.05	22.14	36.89
09/21/2020	25.51	130.86	12.58	25.13	41.90
09/22/2020	26.71	127.89	12.20	24.39	40.66
09/23/2020	33.97	125.68	11.96	23.87	39.84
09/24/2020	15.83	62.42	6.14	12.31	20.53
09/25/2020	17.37	55.78	5.34	10.67	17.82
09/26/2020	15.02	50.38	4.79	9.53	15.93
09/27/2020	15.99	52.41	5.00	9.99	16.66
09/28/2020	51.02	115.72	10.15	20.30	33.86
09/29/2020	32.79	122.88	11.78	23.56	39.29
09/30/2020	32.11	125.24	11.99	24.00	40.01
Monthly Avg/Sum*:	834.56 *	3,445.36 *	328.54 *	656.76 *	1,095.02 *
Daily Min:	15.02	50.38	4.79	9.53	15.93
Daily Max:	51.02	138.63	13.20	26.31	43.89
Jul 2020 - Sep 2020	2,140.86	8,764.22	829.81	1,659.54	2,764.83
QTD:	2,140.86 *	8,764.22 *	829.81 *	1,659.54 *	2,764.83 *
YTD 2020:	3,195.92 *	11,039.62 *	1,038.30 *	2,076.71 *	3,459.68 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2020 00:00 **To:** 09/30/2020 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/02/2020 23:49 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2 CO, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 NOx, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 PM10, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 SO2, Ton 1 Day(s) Sum	Rolling Sum	Units CT1 & CT2 VOC, Ton 1 Day(s) Sum	Rolling Sum
Jul 2020	0.2276	2.3663	0.8761	5.1800	0.1638	0.9456	0.0817	0.4726	0.2723	1.5762
Aug 2020	0.4257	2.4817	1.7833	5.9949	0.3379	1.1020	0.1690	0.5507	0.5626	1.8361
Sep 2020	0.4176	2.5642	1.7227	7.1656	0.3285	1.3362	0.1645	0.6681	0.5474	2.2261
Sum/Avg	2.5642		7.1656		1.3362		0.6681		2.2261	
Limit Value										

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification; The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 1Q20 QAQR.

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

7/1/2020 0:00
9/30/2020 0:00

1D

TOWER AVG.

3988

	519-AIT-9504-1
7/1/20 0:00	2530.6
7/2/20 0:00	2453.7
7/3/20 0:00	2182.4
7/4/20 0:00	2040.5
7/5/20 0:00	1978.6
7/6/20 0:00	2006.7
7/7/20 0:00	1938.4
7/8/20 0:00	1964.2
7/9/20 0:00	2008.1
7/10/20 0:00	2032.2
7/11/20 0:00	1995.3
7/12/20 0:00	2020.8
7/13/20 0:00	1988.9
7/14/20 0:00	4100.4
7/15/20 0:00	4487.9
7/16/20 0:00	4770.1
7/17/20 0:00	4103.8
7/18/20 0:00	4222.2
7/19/20 0:00	4652.6
7/20/20 0:00	4806.5
7/21/20 0:00	4559.8
7/22/20 0:00	3295.2
7/23/20 0:00	3025.0
7/24/20 0:00	2859.0
7/25/20 0:00	2491.3
7/26/20 0:00	2181.8
7/27/20 0:00	3641.2
7/28/20 0:00	4343.4
7/29/20 0:00	3834.0
7/30/20 0:00	4553.9
7/31/20 0:00	4784.1
8/1/20 0:00	4891.7
8/2/20 0:00	5320.6
8/3/20 0:00	5031.3
8/4/20 0:00	5547.7
8/5/20 0:00	5279.8
8/6/20 0:00	5622.8
8/7/20 0:00	4441.2
8/8/20 0:00	3918.0
8/9/20 0:00	4677.4
8/10/20 0:00	4674.2
8/11/20 0:00	4651.4
8/12/20 0:00	5394.8
8/13/20 0:00	4883.8
8/14/20 0:00	5114.4
8/15/20 0:00	5407.6
8/16/20 0:00	4744.3
8/17/20 0:00	5097.4
8/18/20 0:00	5074.8

8/19/20 0:00	5207.1
8/20/20 0:00	5004.4
8/21/20 0:00	5046.1
8/22/20 0:00	5004.9
8/23/20 0:00	4260.5
8/24/20 0:00	4423.8
8/25/20 0:00	4603.9
8/26/20 0:00	3971.1
8/27/20 0:00	4479.4
8/28/20 0:00	4435.3
8/29/20 0:00	4409.3
8/30/20 0:00	4167.9
8/31/20 0:00	4407.0
9/1/20 0:00	3809.9
9/2/20 0:00	4231.5
9/3/20 0:00	3985.7
9/4/20 0:00	4071.1
9/5/20 0:00	4015.9
9/6/20 0:00	4336.5
9/7/20 0:00	4307.3
9/8/20 0:00	4299.1
9/9/20 0:00	4427.1
9/10/20 0:00	4366.5
9/11/20 0:00	4505.1
9/12/20 0:00	4712.2
9/13/20 0:00	4183.9
9/14/20 0:00	4139.3
9/15/20 0:00	3940.2
9/16/20 0:00	3996.5
9/17/20 0:00	4008.6
9/18/20 0:00	4015.3
9/19/20 0:00	3933.1
9/20/20 0:00	3952.5
9/21/20 0:00	4018.8
9/22/20 0:00	4010.5
9/23/20 0:00	3975.3
9/24/20 0:00	4106.7
9/25/20 0:00	3985.8
9/26/20 0:00	3042.2
9/27/20 0:00	3156.6
9/28/20 0:00	2324.9

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	3988	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00255232**	

Design drift rate	**0.005%**
PM-10 pounds per day	**8.24**
	92 Days in quarter
PM-10 pounds this quarter	**758**

2Q20

fill only these

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: PM-10 = cooling water recirculation rate* total dissolved solids concentration in the blow own water* design drift rate.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

7/1/2020 0:00
9/30/2020 0:00

1D

TOWER AVG.

3988

	519-AIT-9504-1
7/1/20 0:00	2530.6
7/2/20 0:00	2453.7
7/3/20 0:00	2182.4
7/4/20 0:00	2040.5
7/5/20 0:00	1978.6
7/6/20 0:00	2006.7
7/7/20 0:00	1938.4
7/8/20 0:00	1964.2
7/9/20 0:00	2008.1
7/10/20 0:00	2032.2
7/11/20 0:00	1995.3
7/12/20 0:00	2020.8
7/13/20 0:00	1988.9
7/14/20 0:00	4100.4
7/15/20 0:00	4487.9
7/16/20 0:00	4770.1
7/17/20 0:00	4103.8
7/18/20 0:00	4222.2
7/19/20 0:00	4652.6
7/20/20 0:00	4806.5
7/21/20 0:00	4559.8
7/22/20 0:00	3295.2
7/23/20 0:00	3025.0
7/24/20 0:00	2859.0
7/25/20 0:00	2491.3
7/26/20 0:00	2181.8
7/27/20 0:00	3641.2
7/28/20 0:00	4343.4
7/29/20 0:00	3834.0
7/30/20 0:00	4553.9
7/31/20 0:00	4784.1
8/1/20 0:00	4891.7
8/2/20 0:00	5320.6
8/3/20 0:00	5031.3
8/4/20 0:00	5547.7
8/5/20 0:00	5279.8
8/6/20 0:00	5622.8
8/7/20 0:00	4441.2
8/8/20 0:00	3918.0
8/9/20 0:00	4677.4
8/10/20 0:00	4674.2
8/11/20 0:00	4651.4
8/12/20 0:00	5394.8
8/13/20 0:00	4883.8
8/14/20 0:00	5114.4
8/15/20 0:00	5407.6
8/16/20 0:00	4744.3
8/17/20 0:00	5097.4
8/18/20 0:00	5074.8

8/19/20 0:00	5207.1
8/20/20 0:00	5004.4
8/21/20 0:00	5046.1
8/22/20 0:00	5004.9
8/23/20 0:00	4260.5
8/24/20 0:00	4423.8
8/25/20 0:00	4603.9
8/26/20 0:00	3971.1
8/27/20 0:00	4479.4
8/28/20 0:00	4435.3
8/29/20 0:00	4409.3
8/30/20 0:00	4167.9
8/31/20 0:00	4407.0
9/1/20 0:00	3809.9
9/2/20 0:00	4231.5
9/3/20 0:00	3985.7
9/4/20 0:00	4071.1
9/5/20 0:00	4015.9
9/6/20 0:00	4336.5
9/7/20 0:00	4307.3
9/8/20 0:00	4299.1
9/9/20 0:00	4427.1
9/10/20 0:00	4366.5
9/11/20 0:00	4505.1
9/12/20 0:00	4712.2
9/13/20 0:00	4183.9
9/14/20 0:00	4139.3
9/15/20 0:00	3940.2
9/16/20 0:00	3996.5
9/17/20 0:00	4008.6
9/18/20 0:00	4015.3
9/19/20 0:00	3933.1
9/20/20 0:00	3952.5
9/21/20 0:00	4018.8
9/22/20 0:00	4010.5
9/23/20 0:00	3975.3
9/24/20 0:00	4106.7
9/25/20 0:00	3985.8
9/26/20 0:00	3042.2
9/27/20 0:00	3156.6
9/28/20 0:00	2324.9

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	**16.3**	**1471**	**1487**	**1504**	**1504**

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown ***** design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	3988	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00255232**	

Design drift rate	**0.005%**
PM-10 pounds per day	**8.24**
	92 Days in quarter
PM-10 pounds this quarter	**758**

2Q20

fill only these

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825-0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Warm oil to Spinning	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RC	1311-1347	TEST-INTELLIGEN RESPONSE	100	195
8-22-19	RC	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	ME	1100-1124	TEST RUN / Troubleshooting	100	237
10-10-19	ME	1136-1144	TEST RUN / Troubleshooting	101	245
10-10-19	ME	1150-1158	TEST RUN / Troubleshooting	101	253
10-10-19	ME	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test		102	289
11-3-19	BP	Bi Weekly Test - Failed		102	304
11-10-19	MAB	BI-WEEKLY TEST FAILED	SHUTDOWN AFTER 5 MINS.	102	309
11-24-19	MAB	Bi-Weekly Test Run - Successful		103	339
12-8-19	MAB	BI-WEEKLY TEST RUN		103	369
12-29-19	BP	Bi-weekly test 1435 — 1509		104	399
01/04/20	BH	Bi-WEEKLY TEST 14:16 - 14:49		104	33
1/6/20	BH	Troubleshoot with CEO/CAT 13:04 13:34		104	63
1/6/20	AB	1447-1453	TEST RUN	105	69
1/6/20	AB	1512-1518	TEST RUN	105	75
1/7/20	AB	1110-1112	TEST RUN	105	77
1/7/20	AB	1114-1127	TEST RUN	105	90
1/7/20	AB	1153-1309	TEST RUN	106	166
1/7/20	AB	1317-1330	TEST RUN	106	179
01-19-2020	Ry	1355 - 1425	Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108	Bi-Weekly Test	107	239
2-11-2020	MAB	1140-1142	LACKER COUNTY TEST	107	241
7-25-2020	MAB	1304-1334	BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D		Runtime TOTAL HRS.	RUNTIME YTD minutes
8-26-2020	KDS	01:00	01:30	108	301
9-13-2020	RC	1538 - BI WEEKLY TEST - 1610		109	333
10/4/20	DE	1323 - 1400 - Test Run		109	370

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Date	Start	Reason	Stop	Initials	Total hrs	YTD
1-26-20	1310	Weekly test	1340	BP	178.1	2.0
2/2/20	1335	Weekly TEST	1405	ML	178.6	2.5
2-9-20	1133	Weekly Test	1203	DWN	179.1	3.0
2-16-20	1508	Weekly Test	1538	LH	179.6	3.5
2-23-20	1401	weekly test	1431	BP	180.1	4.0
3-8-20	1545	WEEKLY TEST RUN	1615	AB	180.6	4.5
3-23-20	23:19	COOLING TOWER DEUGE	23:22	EO	180.6	4.5
4-5-20	1620	WEEKLY TEST RUN	1650	AB	181.1	5.0
4-12-20	1438	WEEKLY TEST RUN	1508	RX	181.6	5.5
4-19-2020	1514	WEEKLY TEST Run		KBS	182.1	6.0
4-28-20	1035	WEEKLY TEST RUN	1105	AB	182.6	6.5
5-3-20	1446	WEEKLY TEST RUN	1516	AB	183.1	7.0
5-10-20	1552	WEEKLY TEST RUN	1622	RX	183.6	7.5
5-16-20	1505	Weekly test	1535	KBS	184.1	8.0
5-31-20	1516	WEEKLY TEST RUN	1546	AB	184.6	8.5
6-4-20	1309	Weekly Test Run	1339	RX	185.1	9.0
6-14-20	1325	Weekly test Run	1355	BP	185.6	9.5
6-21-20	1500	WEEKLY TEST RUN	1530	RC	186.1	10.0
6-28-20	1245	WEEKLY TEST RUN	1315	RC	186.6	10.5
7-1-20	2147	Weekly TEST Run	PM 2217	ML	187.1	11.0
7-12-20	1115	weekly test	1145	AB	187.6	11.5
7-19-20	1410	WEEKLY TEST RUN	1510	RC	188.1	12.0
7-25-2020	1429	WEEKLY TEST RUN	1459	LAB	188.6	12.5
8/3/2020	0900	WEEKLY TEST RUN	0930	KBS	189.1	13.0
8-9-2020	1350	Weekly Test Run	1420	BP	189.6	13.5
8-23-2020	1208	WEEKLY TEST Run	1238	LH	190.1	14.0
8-30-2020	1237	Weekly Test Run	1307	FG	190.6	14.5
9-6-2020	1230	Weekly Test Run	1300	KBS	191.1	15.0
9-8-2020	1310	Post Main't Test Run/Adj.	1340	ML	191.4	15.3
9/14/2020	1421	Weekly TEST Run	1451	ML	191.9	15.8
9-20-20	1133	Weekly TEST Run	1203	LH	192.4	16.3
9-27-20	1644	Weekly Test Run	1714	ZAR	192.9	16.8
10/4/20	1527	Weekly Test Run	1557	DE	193.3	17.3

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825-0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Warm oil to Spinning	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RC	1311-1347	TEST-INTELLIGEN RESPONSE	100	195
8-22-19	RC	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	ME	1100-1124	TEST RUN / Troubleshooting	100	237
10-10-19	ME	1136-1144	TEST RUN / Troubleshooting	101	245
10-10-19	ME	1150-1158	TEST RUN / Troubleshooting	101	253
10-10-19	ME	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test		102	289
11-3-19	BP	Bi Weekly Test - Failed		102	304
11-10-19	MAB	BI-WEEKLY TEST FAILED	SHUTDOWN AFTER 5 MINS.	102	309
11-24-19	MAB	Bi-Weekly Test Run - Successful		103	339
12-8-19	MAB	BI-WEEKLY TEST RUN		103	369
12-29-19	BP	Bi-weekly test 1435 — 1509		104	399
01/04/20	BH	Bi-WEEKLY TEST 14:16 - 14:49		104	33
1/6/20	BH	Troubleshoot with CEO/CAT 13:04 13:34		104	63
1/6/20	AB	1447-1453	TEST RUN	105	69
1/6/20	AB	1512-1518	TEST RUN	105	75
1/7/20	AB	1110-1112	TEST RUN	105	77
1/7/20	AB	1114-1127	TEST RUN	105	90
1/7/20	AB	1153-1309	TEST RUN	106	166
1/7/20	AB	1317-1330	TEST RUN	106	179
01-19-2020	Ry	1355 - 1425	Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108	Bi-Weekly Test	107	239
2-11-2020	MAB	1140-1142	LACKER COUNTY TEST	107	241
7-25-2020	MAB	1304-1334	BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D		Runtime TOTAL HRS.	RUNTIME YTD minutes
8-26-2020	KDS	01:00	01:30	108	301
9-13-2020	RC	1538 - BI WEEKLY TEST - 1610		109	333
10/4/20	DE	1323 - 1400 - Test Run		109	370

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825-0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Warm oil to Spinning	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RC	1311-1347	TEST-INTELLIGEN RESPONSE	100	195
8-22-19	RC	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	ME	1100-1124	TEST RUN / Troubleshooting	100	237
10-10-19	ME	1136-1144	TEST RUN / Troubleshooting	101	245
10-10-19	ME	1150-1158	TEST RUN / Troubleshooting	101	253
10-10-19	ME	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test		102	289
11-3-19	BP	Bi Weekly Test - Failed		102	304
11-10-19	MAB	BI-WEEKLY TEST FAILED	SHUTDOWN AFTER 5 MINS.	102	309
11-24-19	MAB	Bi-Weekly Test Run - Successful		103	339
12-8-19	MAB	BI-WEEKLY TEST RUN		103	369
12-29-19	BP	Bi-weekly test 1435 — 1509		104	399
01/04/20	BH	Bi-WEEKLY TEST 14:16 - 14:49		104	33
1/6/20	BH	Troubleshoot with CEO/CAT 13:04 13:34		104	63
1/6/20	AB	1447-1453	TEST RUN	105	69
1/6/20	AB	1512-1518	TEST RUN	105	75
1/7/20	AB	1110-1112	TEST RUN	105	77
1/7/20	AB	1114-1127	TEST RUN	105	90
1/7/20	AB	1153-1309	TEST RUN	106	166
1/7/20	AB	1317-1330	TEST RUN	106	179
01-19-2020	Ry	1355 - 1425	Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108	Bi-Weekly Test	107	239
2-11-2020	MAB	1140-1142	LACKER COUNTY TEST	107	241
7-25-2020	MAB	1304-1334	BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D		Runtime TOTAL HRS.	RUNTIME YTD minutes
8-26-2020	KDS	01:00	01:30	108	301
9-13-2020	RC	1538 - BI WEEKLY TEST - 1610		109	333
10/4/20	DE	1323 - 1400 - Test Run		109	370

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825-0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Warm oil to Spinning	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RC	1311-1347	TEST-INTELLIGEN RESPONSE	100	195
8-22-19	RC	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	ME	1100-1124	TEST RUN / Troubleshooting	100	237
10-10-19	ME	1136-1144	TEST RUN / Troubleshooting	101	245
10-10-19	ME	1150-1158	TEST RUN / Troubleshooting	101	253
10-10-19	ME	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test		102	289
11-3-19	BP	Bi Weekly Test - Failed		102	304
11-10-19	MAB	BI-WEEKLY TEST FAILED	SHUTDOWN AFTER 5 MINS.	102	309
11-24-19	MAB	Bi-Weekly Test Run - Successful		103	339
12-8-19	MAB	BI-WEEKLY TEST RUN		103	369
12-29-19	BP	Bi-weekly test 1435 — 1509		104	399
01/04/20	BH	Bi-WEEKLY TEST 14:16 - 14:49		104	33
1/6/20	BH	Troubleshoot with CEO/CAT 13:04 13:34		104	63
1/6/20	AB	1447-1453	TEST RUN	105	69
1/6/20	AB	1512-1518	TEST RUN	105	75
1/7/20	AB	1110-1112	TEST RUN	105	77
1/7/20	AB	1114-1127	TEST RUN	105	90
1/7/20	AB	1153-1309	TEST RUN	106	166
1/7/20	AB	1317-1330	TEST RUN	106	179
01-19-2020	Ry	1355 - 1425	Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108	Bi-Weekly Test	107	239
2-11-2020	MAB	1140-1142	LACKER COUNTY TEST	107	241
7-25-2020	MAB	1304-1334	BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D		Runtime TOTAL HRS.	RUNTIME YTD minutes
8-26-2020	KDS	01:00	01:30	108	301
9-13-2020	RC	1538 - BI WEEKLY TEST - 1610		109	333
10/4/20	DE	1323 - 1400 - Test Run		109	370

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

A. Hours of operation the engine was run for maintenance and testing
B. Hours of operation the engine was run during interruption of electrical power
C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	TECH	TIME START-S/D		RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07	BI-WEEKLY TEST	97	805
1/6/19	MAB	1241 - 1311	BI-WEEKLY TEST	97	30
1-20-19	Ray	0825-0855	Bi-Weekly Test	98	60
1-29-19	Ray	1013 - 1043	Bi Weekly Test	98	90
2-17-19	Ry	1035 - 1105	Bi Weekly Test	99	120
3-11-19	E.O.	0724 - 0730	OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920-0950	TEST / Warm oil to Spinning	99	156
4/29/2019	ME	1202-1206	Post Maint Prime/TEST	99	160
7-18-19	RC	1311-1347	TEST-INTELLIGEN RESPONSE	100	195
8-22-19	RC	DIESEL DELIVERY 16.0 GALS			
9-20-19	AB	1026-1029	TEST RUN	100	198
9-20-19	AB	1416-1421	TEST RUN	100	203
9-20-19	AB	1424-1434	TEST RUN	100	213
10-10-19	ME	1100-1124	TEST RUN / Troubleshooting	100	237
10-10-19	ME	1136-1144	TEST RUN / Troubleshooting	101	245
10-10-19	ME	1150-1158	TEST RUN / Troubleshooting	101	253
10-10-19	ME	1206-1207	TEST RUN / TROUBLESHOOTING	101	254
10-13-19	MAB	0942-0947	WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test		102	289
11-3-19	BP	Bi Weekly Test - Failed		102	304
11-10-19	MAB	BI-WEEKLY TEST FAILED	SHUTDOWN AFTER 5 MINS.	102	309
11-24-19	MAB	Bi-Weekly Test Run - Successful		103	339
12-8-19	MAB	BI-WEEKLY TEST RUN		103	369
12-29-19	BP	Bi-weekly test 1435 — 1509		104	399
01/04/20	BH	Bi-WEEKLY TEST 14:16 - 14:49		104	33
1/6/20	BH	Troubleshoot with CEO/CAT 13:04 13:34		104	63
1/6/20	AB	1447-1453	TEST RUN	105	69
1/6/20	AB	1512-1518	TEST RUN	105	75
1/7/20	AB	1110-1112	TEST RUN	105	77
1/7/20	AB	1114-1127	TEST RUN	105	90
1/7/20	AB	1153-1309	TEST RUN	106	166
1/7/20	AB	1317-1330	TEST RUN	106	179
01-19-2020	Ry	1355 - 1425	Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108	Bi-Weekly Test	107	239
2-11-2020	MAB	1140-1142	LACKER COUNTY TEST	107	241
7-25-2020	MAB	1304-1334	BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D		Runtime TOTAL HRS.	RUNTIME YTD minutes
8-26-2020	KDS	01:00	01:30	108	301
9-13-2020	RC	1538 - BI WEEKLY TEST - 1610		109	333
10/4/20	DE	1323 - 1400 - Test Run		109	370

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 3Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.