

**DOCKETED**

<b>Docket Number:</b>	20-SPPE-01
<b>Project Title:</b>	Great Oaks South Backup Generating Facility Small Power Plant Exemption
<b>TN #:</b>	236091
<b>Document Title:</b>	BAAQMD letter Re BACT Determination For Diesel Back-up Engines Greater Than or Equal to 1,000 Brake Horsepower
<b>Description:</b>	From Jack P. Broadbent, Executive Officer, APCO, Bay Area Quality Management District
<b>Filer:</b>	Lisa Worrall
<b>Organization:</b>	Bay Area Quality Management District
<b>Submitter Role:</b>	Public Agency
<b>Submission Date:</b>	12/22/2020 1:26:39 PM
<b>Docketed Date:</b>	12/22/2020



**BAY AREA  
AIR QUALITY  
MANAGEMENT  
DISTRICT**

**ALAMEDA COUNTY**  
John J. Bauters  
Pauline Russo Cutter  
Scott Haggerty  
Nate Miley

**CONTRA COSTA COUNTY**  
John Gioia  
David Hudson  
Karen Mitchoff  
(Secretary)  
Mark Ross

**MARIN COUNTY**  
Katie Rice

**NAPA COUNTY**  
Brad Wagenknecht

**SAN FRANCISCO COUNTY**  
VACANT  
Shamann Walton  
Tyrone Jue  
(SF Mayor's Appointee)

**SAN MATEO COUNTY**  
David J. Canepa  
Carole Groom  
Davina Hurt

**SANTA CLARA COUNTY**  
Margaret Abe-Koga  
Cindy Chavez  
(Vice Chair)  
Liz Kniss  
Rod G. Sinks  
(Chair)

**SOLANO COUNTY**  
James Sperring  
Lori Wilson

**SONOMA COUNTY**  
Teresa Barrett  
Shirlee Zane

Jack P. Broadbent  
EXECUTIVE OFFICER/APCO

Connect with the  
Bay Area Air District:



12/21/2020

Mr. Richard Corey  
Executive Officer *Richard*  
**California Air Resources Board**  
1001 I Street,  
Sacramento, CA 95814

Mr. Drew Bohan  
Executive Director *Drew*  
**California Energy Commission**  
1516 Ninth Street  
Sacramento, CA 95814

**RE: BACT Determination for Diesel Back-Up Engines Greater than or equal to 1,000 Brake Horsepower**

Dear Mr. Corey and Mr. Bohan,

The purpose of this letter is to inform your agencies that the Bay Area Air Quality Management District (Air District) has established a best available control technology (BACT) guideline for large (greater or equal to 1,000 brake horsepower) diesel engines used for emergency standby power that requires them to meet the U. S. EPA's Tier 4 emissions standards. This determination will apply to any new and open permit application with a diesel backup engine  $\geq$  1000 bhp that is deemed complete after 1/1/2020.

The Air District is the entity charged with permitting for stationary sources of air pollution in the nine-county region surrounding the San Francisco bay. Air District permits are required by law for:

- Any stationary equipment that may cause air pollution;
- Modifications to existing permitted equipment or their permit conditions;
- Permitted equipment that is moved to a new location;
- Transfer of permitted equipment to new owners; and
- Installation of equipment used to control emissions.

As part of our permitting processes, The Air District's New Source Review Rule - Regulation 2, Rule 2 (Regulation 2, Rule 2) - requires that new or modified sources of air pollutants undergo permit review for Best Available Control Technology (BACT). BACT2 "Achieved-In-Practice", applies to the most effective emission controls already in use or the most stringent emission limit achieved in the field for the type and capacity of equipment comprising the source under review and operating under similar conditions.

---

Regulation 2, Rule 2, states that any new or modified source which results in an increase in emissions of precursor organic compounds (POC), non-precursor organic compounds (NPOC), nitrogen oxides (NO<sub>x</sub>), sulfur dioxide (SO<sub>2</sub>), particulate matter (PM<sub>10</sub>), or carbon monoxide (CO) in excess of 10 pounds per highest day must be reviewed for possible application of BACT. California Health and Safety Code Section 42300 authorizes delegation of stationary source permitting authority from the state to the local air pollution control districts, including the setting of rules and definitions.


For the BACT Guideline, the Air District relied on its evaluations of the following projects, which are both emergency standby engines that are installed and operating in compliance with the U.S. EPA Tier 4 emissions standards:

- Air District Permit Application 27020 (San Jose – Santa Clara Regional Wastewater Facility, Four Emergency Diesel Standby Engines, each 4,376 BHP)
- Air District Permit Application 25115 (Sutro Tower, Inc., Emergency Diesel Standby Engine, 1,881 BHP).

The Air District also relied on an evaluation of the permit and source test results of the Microsoft – MWH Data Center, in Quincy, Washington. The permit limits that Microsoft complies with are in units of g/bhp-hr: 0.5 NO<sub>x</sub>, 0.14 NMHC, 0.02 PM filterable, 2.6 CO. These emergency diesel standby engines ranged from 0.75 MWe to 3.0 MWe.

Thank you for your attention and If you have any questions regarding this letter, please contact Damian Breen, Senior Deputy Executive Officer at (415) 749-5041.

Sincerely,



Jack P. Broadbent  
Executive Officer/APCO