

DOCKETED

Docket Number:	13-AFC-01
Project Title:	Alamitos Energy Center
TN #:	210533
Document Title:	AES Alamitos Response to SCAQMD Data Request No. 6
Description:	N/A
Filer:	Jerry Salamy
Organization:	CH2M HILL
Submitter Role:	Applicant Consultant
Submission Date:	2/25/2016 9:49:40 AM
Docketed Date:	2/25/2016

From: Salamy, Jerry/SAC
To: "Vicky Lee"; stephen.okane@AES.com
Cc: [John Yee](#); [Andrew Lee](#); [Engel, Elyse/SJC](#); [Beattie, Benjamin/SAC](#)
Subject: RE: AES Alamos--AEC Questions Set No. 6
Date: Thursday, February 25, 2016 9:24:00 AM

Hi Vicky,

Below are the responses to your request.

20. **Rule 1304.1 Estimated Fees**

- b. As requested in SCAQMD Letter dated 11/20/15, AES Response Letter dated 12/11/15 provided the "Average Last 2 Years of Existing Units(s) Actual Generation (MWh/yr)" for AGS Units 1, 2, and 5, which will be retired. I inadvertently left off AGS Unit 3, which will also be retired. Please provide the same data for Unit 3.

Response: Table 20-1 provides the AGS's electrical production (2013 and 2014) for the units proposed for retirement.

TABLE 20-1
AGS 2-Year Average Electrical Production

Unit	2013		2014		2-Year Average	
	MWh Gross	MWh Net	MWh Gross	MWh Net	MWh Gross	MWh Net
1	17,923	15,645	22,414	22,103	20,168	18,874
2	30,766	26,094	85,834	82,964	58,300	54,529
3	369,385	350,913	499,518	473,800	434,452	412,357
5	510,029	489,433	74,250	71,345	292,139	280,389

Source: http://energyalmanac.ca.gov/electricity/web_qfer/

- c. For the purpose of the PDOC, please select the annual payment option or single payment option.

Response: AES wants to use the annual payment option at issuance of the PTC and to convert to a single payment by the end of the first year.

- d. The MW installed will be 1,094.702, and the MW retired will be 1150 MW. Does AES have plans for the surplus 55 MW?

Response: AES has not finalized plans for the surplus 55 MWs of retirements.

Thanks,

Jerry Salamy
Principal Project Manager
CH2M HILL
2485 Natomas Park Drive, Suite 600

Sacramento, CA 95833
Office Phone: 916.286.0207
Cell Phone: 916.769.8919

From: Vicky Lee [mailto:VLee1@aqmd.gov]
Sent: Tuesday, February 23, 2016 6:16 PM
To: stephen.okane@AES.com; Salamy, Jerry/SAC <Jerry.Salamy@CH2M.com>
Cc: John Yee <JYee@aqmd.gov>; Andrew Lee <ALee@aqmd.gov>
Subject: AES Alamitos--AEC Questions Set No. 6

Stephen O'Kane and Jerry Salamy,

20. Rule 1304.1 Estimated Fees

- b. As requested in SCAQMD Letter dated 11/20/15, AES Response Letter dated 12/11/15 provided the "Average Last 2 Years of Existing Units(s) Actual Generation (MWh/yr)" for AGS Units 1, 2, and 5, which will be retired. I inadvertently left off AGS Unit 3, which will also be retired. Please provide the same data for Unit 3.
- c. For the purpose of the PDOC, please select the annual payment option or single payment option.
- d. The MW installed will be 1,094.702, and the MW retired will be 1150 MW. Does AES have plans for the surplus 55 MW?

Thanks for your assistance.

Vicky Lee
Air Quality Engineer
South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, CA 91765-4178
909-396-2284