

DOCKETED

Docket Number:	13-AFC-01
Project Title:	Alamitos Energy Center
TN #:	210766
Document Title:	AEC Data Responses, Set 8
Description:	N/A
Filer:	Cindy Salazar
Organization:	CH2M HILL
Submitter Role:	Applicant Consultant
Submission Date:	3/17/2016 1:42:31 PM
Docketed Date:	3/17/2016

Alamitos Energy Center

(13-AFC-01)

Data Responses, Set 8 (Response to Data Request 170-175)

Submitted to
California Energy Commission

Prepared by
AES Southland Development, LLC

With Assistance from

CH2MHILL®

2485 Natomas Park Drive
Suite 600
Sacramento, CA 95833

March 17, 2016

Contents

Section	Page
Contents	iii
Introduction.....	1
Transmission System Engineering (170-175)	1

Introduction

Attached are AES Southland Development, LLC's (AES or the Applicant) responses to the California Energy Commission (CEC) Staff Data Request, Set 8 (number 170-175) regarding the Alamos Energy Center (AEC) (13-AFC-01) Supplemental Application for Certification (SAFC).

Transmission System Engineering (170-175)

BACKGROUND

Staff has had discussions with Mr. Robert Sims, an engineering consultant for AES, about draft responses to Transmission System Engineering data requests (Data Requests 160-166 from Energy Commission Staff's Data Request Set #6, filed November 30, 2015). The discussions were primarily focused on the completeness of the draft data responses; however, staff did have some concerns about specific equipment proposed by the applicant that will be documented both through this data request and a separate report of conversation. AES docketed its revised responses to staff's Data Requests 160, 161 and 163 on February 8, 2016. The discussion below is in response to this February 8, 2016 filing. There is still some missing data in the response and staff is concerned that some of the specific equipment is not appropriately sized for the generators. Data Request 166 (the California ISO exemption letter) has not been provided and is still outstanding.

The proposed switchyard equipment is designed for a generator operating between 0.90 lag to 0.95 lead but the generator itself can operate to 0.85 lag. CAISO Tariff 8.2.3.3 indicates the minimum requirement of the Power Factor (PF) of a generator in the ISO system is 0.90 lag to 0.95 lead, but the tariff also states that the CAISO could set a different requirement of the PF during operation which could go from 0.85 lag to 0.95 lead, as stated in the Huntington Beach Energy Project LGIA. The proposed design would meet the minimum requirements, but the proposed generators are rated for 0.85 PF (associated with operation at 0.85 lag). It would be appropriate, and consistent with standard safe practices, to design the switchyard equipment on the basis of 0.85 PF, which would increase the current in the switchyard circuits and the generation tie (gen-tie) lines, requiring higher rated equipment.

Staff is concerned about the proposed conductor in Figure 3.1-R for the gen-tie lines. The proposed aluminum conductor, steel supported (ACSS) conductor is not used very often and then for short reconductoring projects. The ratings for the ACSS conductor are based on 200 degrees Celsius where most of the equipment and other conductors have ratings based on 75 degrees Celsius. This means the proposed conductors would be operating at higher temperature than other equipment in order to accommodate the output of the proposed generator which could affect the reliability of the other equipment. Aluminum Conductor Steel Reinforced (ACSR) is the standard conductor used for transmission and gen-tie lines; ACSR is rated based on 75 degree Celsius operation.

DATA REQUEST

170. Please provide current ratings of the Disconnect Switches in the Switching bays of the SCE 230 kV Alamitos Switching Station.

Response: The disconnect switches and switching bays of the Southern California Edison Company (SCE) 230 kV Alamitos Switching Station are owned and operated by SCE. The Applicant does not have access to this equipment and does not know the disconnect switch ratings for these utility facilities. It should be noted that the existing equipment in the SCE Switching Station is 30 to 40 years old and will likely be replaced by SCE when each AEC generating unit is connected. This detailed design engineering will be performed by SCE under the Large Generator Interconnection Agreement (LGIA) in the usual course, post-Certification. SCE has the responsibility to properly size and install this SCE equipment to facilitate AEC's interconnection.

171. In Power Block 1, please provide:

- a. The high side bus size, type and Ampere ratings,
- b. The length, size and type of the short overhead conductor between the high side of the generator step-up (GSU) transformer and the 230 kV switchyard bus.

Response: These switchyards have not yet been designed and this level of specificity will not be available until detailed design is completed post-Certification, as it is with all Commission-approved projects. These electrical facilities will be designed and constructed, with conductors selected in conformance with the then-applicable standards and codes including the National Electrical Code, National Electrical Safety code, American National

Standards Institute, IEEE, and others to assure that they are properly sized for the application. The bus and cables in question under Data Request 171 are relatively short connections (in the range of 25 to 50 feet) within the AEC 230-kV switchyards. Furthermore, the Applicant expects the Energy Commission to include a standard Condition of Certification requiring a Chief Building Official to verify that the engineering design and construction comply with then-applicable laws, ordinances, regulations, and standards.

172. In Power Blocks 2a and 2b, please provide:
- a. The high side bus size and type, Ampere ratings,
 - b. The length, size and type of the short overhead conductor between the high side of the GSU transformer and the 230 kV switchyard bus.

Response: These switchyards have not yet been designed and this level of specificity will not be available until detailed design is completed post-Certification, as it is with all Commission-approved projects. These electrical facilities will be designed and constructed in conformance with the then-applicable standards and codes including the National Electrical Code, National Electrical Safety code, American National Standards Institute, IEEE, and others to assure that they are properly sized for the application. The bus and cables in question under Data Request 172 are relatively short connections (in the range of 25 to 50 feet) within the project's 230-kV switchyards. Furthermore, the Applicant expects the Energy Commission to include a standard Condition of Certification requiring a Chief Building Official to verify that the engineering design and construction comply with then-applicable laws, ordinances, regulations, and standards.

173. Figure 3.1-1R and Figure DR161-1R are not consistent. Figure 3.1-1R shows four power blocks, 2a, 2b, 2c and 2d, connecting separately to the bus. Figure DR161-1R shows blocks 2a and 2b connecting as a pair to the bus and 2c and 2d connecting as a pair to the bus. Please provide consistent drawings.

Response: Figure DR173-1R presents a revised electrical system one-line drawing that is consistent with Figure DR161-1R. Figure 2.1-2R presents the revised general arrangement.

174. Given the discussion above and the high operating temperature ACSS conductor proposed in Figure 3.1-1R, please explain the choice of the ACSS conductor for the gen-tie line and why a more standard ACSR conductor was not chosen.

Response: The ACSS conductor was selected because it has superior mechanical properties and corrosion resistance. The electrical properties and ratings of ACSR and ACSS bare transmission conductors for any given size are nearly identical. Both types of conductors have the same area of aluminum conductor, the same alternating current (AC) resistance, and will operate at the same conductor temperature for any given conductor size and load. The ACSS type conductor is superior due to the higher quality steel support core and compressed trapezoid aluminum conductor. This allows the conductor to operate at temperatures up to 200 degrees Celsius; however, the application for the AEC will limit the maximum cable temperature to below 75 degrees Celsius. The ACSS conductor was selected because of its higher strength, lower susceptibility to sag, and more importantly it is corrosion resistant in a saline coastal environment. Given that the electrical properties and operating temperatures of ACSR and ACSS conductor are the same, the premium ACSS conductor with its superior mechanical properties and corrosion resistance are proposed for AEC.

175. Many of the circuit breakers and all of the Step-up transformers are not rated highly enough to allow the generators to operate at their rated 0.85 power factor.

Based on the equipment ratings provided in Figure 3.1-1R:

- a. Please explain the choice of underrated equipment or redesign the switchyard and gen-tie lines with equipment that would allow the generators to operate at their rated 0.85 power factor (0.85 lag). If the switchyard is redesigned, resubmit all of the diagrams with the new equipment and the associated equipment ratings.

Response: The equipment is not underrated as demonstrated by the following calculations. It appears that the CEC staff has used the nameplate rating of the combustion turbine and steam turbine generators in the calculation of the maximum electrical loads. The AEC generator loadings for the combustion turbine generators and steam turbine generator will be limited by the available shaft horsepower from the combustion turbines and steam turbine. The electrical generators are oversized and will not operate at their nameplate ratings. As noted in the SAFC Figure 2.1-4a, the maximum output of the combustion turbines in combined cycle power block is limited to 226.639 gross megawatts (MW) under cool weather conditions, and the steam turbine generator is limited 228.709 MW due to the available steam. If these generation ratings are used to calculate the maximum transformer and equipment loads for all equipment, they will be found to be sufficiently sized for operation at a 0.85 power factor should it ever be required. Please note that the current power factor requirement for generators operating in the California Independent System Operator (CAISO) has been unchanged at 0.90 lagging to 0.95 leading since the creation of the CAISO. Under the current CAISO Tariff requirement, the power factor for the Alamos Energy Center electrical equipment has a comfortable rating margin.

b. The 9,000 Amp, 18 kV Circuit Breaker 1 (CB1) in the Power Block No. 1 switchyard would not allow the STG to operate at its rated 0.85 PF.

Response: The breaker is properly rated as demonstrated by the following calculations. The maximum steam turbine generator output is 228.709 MW per SAFC Figure 2.1-4a. At a power factor of 0.85 this equals 269.069 MVA resulting in a maximum loading of 8,630 ampere at 18 kV. This is within the rating of the 9,000 ampere circuit breaker. As noted in the response to Data Request #173, the engineering design is ongoing and this breaker will be provided with a 10,000 ampere rating for consistency with the 2 – 10,000 ampere breakers on the 2 combustng turbine generators in the power block.

c. In Power Block 1, the Generator Step-up (GSU) transformers for the CTG 1 and CTG 2 generators are rated at 270 MVA. The CTGs are rated 234.5 MW, 0.85 PF. In order to accommodate the generators the GSU transformers should be rated at least 276MVA.


Response: The GSUs are properly rated as demonstrated by the following calculations. The maximum combined cycle combustion turbine generator output is 226.639 MW (gross) under cool weather conditions per SAFC Figure 2.1-4a. At a power factor of 0.85 this equals 266.634 MVA and is within the ratings of the transformer.

d. In the Power Blocks 2a and 2b, the highest rating of each transformer is 120 MVA while the generators would require a transformer with at least a 122 MVA rating in order to operate at a 0.85 power factor.


Response: The transformers are properly rated as demonstrated by the following calculations. The maximum simple cycle combustng turbine generator output is 96.353 MW (net) under cool weather conditions per SAFC Figure 2.1-4b. At a power factor of 0.85 this equals 113.36 MVA and is within the ratings of the transformer.

e. In Power Block 1, the 230 kV breaker, CB1 and associated disconnect switch are rated at 2,000 Amperes. In order to accommodate generators at 0.85 PF, the ratings of the 230 kV breaker and the disconnect switch should be at least 2, 100 ampere.

Response: The disconnect switch is properly rated as demonstrated by the following calculations. The maximum combined cycle power block 1 output is 661.210 MW (net) under cool weather conditions per SAFC Figure 2.1-4a. At a power factor of 0.85 this equals 1,660 ampere and is within the ratings of the 2,000 ampere circuit breaker and 2000 ampere disconnect switch.








- Notes:**
- If the length of a conductor is not shown, then the length of that conductor segment is less than 50 feet.
 - The Contractor is responsible to ensure that the final design complies with the Utility requirements as set in the signed Interconnection Agreement.
 - Generating Unit Gross and Net capabilities are based on Heat Balance calculations at 65.8 degrees Celsius as submitted to the California Energy Commission for facility permitting.



Transmission Tie Line, ~0.31 mile,
1113 kcmil Bluejay ACSS, 2-bundle
Z1 = 0.000025 + j 0.000307 P.U.
B = 0.001366 P.U.
Z0 = 0.000156 + j 0.000959 P.U.
B0 = 0.000731 P.U.
At 100 MVA Base
879 MVA @ 75° C

Transmission Tie Line, ~0.16 mile,
1431 kcmil Bobolink ACSS
Z1 = 0.000020 + j 0.000219 P.U.
B = 0.000509 P.U.
Z0 = 0.000088 + j 0.000556 P.U.
B0 = 0.000313 P.U.
At 100 MVA Base
512 MVA @ 75° C



Not for Construction

REV.	DATE	DESCRIPTION	DRAWN BY	CHECKED BY	APPROVED BY
0	12/11/15	Update CC & LMS Block Ratings	TI	CFM	HEM
1	03/11/16	Misc Updates	JR	CFM	HEM
2	03/15/16	Update Tie Line Specs and NGRs size	CFM	CFM	HEM

This document is released for the purpose of preliminary design for CEC submitted under the authority of Hugo E. Mena, P.E. 20368, on 03/11/16. It is not to be used for construction purposes.




"The seal appearing on this document was authorized by Hugo E. Mena, P.E. 20368, on March 11, 2016."

AES
the power of being global
AES North America Development, LLC
690 North Studebaker Rd.
Long Beach, CA 90803
(858) 573-2054
Robert.Slms@aes.com

EPC
ELECTRIC POWER ENGINEERS, INC.
#3386
13001 Highway 71, Suite G100
Austin, TX 78738
(512) 392-4700
contact@epceconsulting.com

FIGURE DR173-1R
Electrical System One-Line Diagram
Alamitos Energy Center
Long Beach, California
March 2016

PLOT SCALE:	0	1	2
ARCH ENGRG	0	1	2
PROJ. NO.:	NA		
DWG. NO.:	SHEET:	REV.:	
	2/2	1	



2X1 7FA LEGEND

NO.	DESCRIPTION	13	26
1	ADMINISTRATION BUILDING	14	27
2	WATER TREATMENT BUILDING	15	28
3	WAREHOUSE BUILDING	16	29
4	GAS COMPRESSOR BUILDING	17	30
5	OIL/WATER SEPARATOR	18	31
6	AIR COOLED CONDENSER	19	32
7	RETENTION BASIN	20	33
8	DEMIN WATER PUMPS	21	34
9	DEMIN WATER STORAGE TANK	22	35
10	SERVICE WATER STORAGE TANK	23	36
11	SERVICE WATER PUMPS	24	37
12	STEAM TURBINE AND GENERATOR	25	38

39	FUEL GAS STARTUP HEATER	52	FUEL GAS COMPRESSOR DRAINS TANK	65	NITROGEN STORAGE				
40	UNIT EXCITATION/LO EQUIPMENT	53	ISO PHASE BUS DUCT	66	AIR COOLED HEAT EXCHANGER				
41	ISOLATION TRANSFORMER	54	AUXILIARY TRANSFORMER	67	WASTE WATER TANK				
42	EXCITATION TRANSFORMER	55	CTG STEP-UP TRANSFORMER	68	TRANSFORMER WALL				
43	GENERATOR BREAKER	56	BOILER FEEDWATER PUMPS	69	ACOUSTICAL BARRIER				
44	ISO PHASE BUS DUCT	57	BLOWDOWN TANK	70	CEMS CABINET				
45	AUXILIARY TRANSFORMER	58	WATER WASH DRAINS TANK	71	CONDENSATE TRANSFER PUMPS				
46	CTG STEP-UP TRANSFORMER	59	WATER WASH SKID	72	RECYCLE SYSTEM SUMP				
47	AIR INLET FILTER	60	FUEL GAS FILTER/SEPARATOR	73	NEW 230KV TRANSMISSION LINE				
48	HYDROGEN STORAGE	61	AMMONIA STORAGE TANK	74	SWITCHYARD DISCONNECT				
49	AMMONIA STORAGE TANK	62	AMMONIA INJECTION SKID	75	COMBUSTION TURBINE				
50	AMMONIA UNLOADING CONTAINMENT AREA	63	AMMONIA UNLOADING CONTAINMENT AREA	76	CTG STEP-UP TRANSFORMER				
51	AMMONIA CONTAINMENT AREA	64	AMMONIA INJECTION SKID	77	TRANSFORMER WALL				
					121	TRANSFORMER WALL			
						122	FUEL GAS COMP. BUILDING		
							123	FUEL GAS REGULATOR	
								124	ISO-PHASE BUS DUCT

LMS 100 LEGEND

91	NEW 230KV TRANSMISSION LINE	112	AIR INLET FILTER	125	INTERCOOLER SKID
92	MEDIUM VOLTAGE ELECTRICAL ENCLOSURE	113	PACKAGED ELECTRICAL/ELECTRONIC CONTROL CENTER (PEECC)	126	CTG EXHAUST DUCT
93	FIN FAN COOLER	114	PARKING AREA	127	STACK
94	TRANSFORMER WALL	115	FUEL GAS HEATER	128	SCR
95	ACOUSTICAL BARRIER	116	CONTINUOUS EMISSIONS MONITORING SYS. EQUIP.	129	AMMONIA STORAGE TANK
96	CEMS CABINET	117	GENERATOR BREAKER	130	AMMONIA INJECTION SKID
97	CONDENSATE TRANSFER PUMPS	118	AUXILIARY TRANSFORMER	131	AMMONIA UNLOADING CONTAINMENT AREA
98	RECYCLE SYSTEM SUMP	119	CTG STEP-UP TRANSFORMER	132	AMMONIA STORAGE TANK
		120	TRANSFORMER WALL	133	AMMONIA INJECTION SKID
		121	FUEL GAS COMP. BUILDING	134	AMMONIA UNLOADING CONTAINMENT AREA
		122	FUEL GAS REGULATOR	135	CO CATALYST (BY OWNER)
		123	ISO-PHASE BUS DUCT	136	COMBUSTION TURBINE VBV SILENCER STACK
		124		137	ISO-PHASE BUS DUCT

SCALE	E SIZE	42"x30"
NDNE		
0 1/2 1		
03-11-16	UPDATE FOR AFC	
MLC	SRS	SRS
DWN	DGN	CHK
		APP

PEC
 IF THIS BAR DOES NOT MEASURE 1" THEN DRAWING IS NOT TO SCALE

Power Engineers Collaborative, L.L.C.
 100 South Wacker Drive Suite 1100 Chicago, Illinois 60606
 150 North Sunny Slope Road Suite 110 Brookfield, Wisconsin 53005
 WWW.PECLLC.COM

Figure 2.1-2R
General Arrangement
 Alamos Energy Center
 Long Beach, California
 March 2016