DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	236686
Document Title:	2020 Qtr 4 Operating Report
Description:	Operating Report
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	2/8/2021 7:32:11 AM
Docketed Date:	2/8/2021

ATTACHMENT 1

Complaints

FCD: AQ-5

Title V: #5

During the fourth quarter of 2020, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD and the CEC.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

2020 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20	Avg
Gr/100SCF	0.296	0.377	0.316	0.141	0.316	0.248	0.263	0.227	0.163	0.273	0.114	0.196	0.244

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 201859
REPORT DATE : 10/15/2020

On October 9, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-OCT-A	201859-13299	719.9

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/06/2020**
PROJECT NO.	**: 201859**	**RECEIVING DATE**	**: 10/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/12/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 10/15/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**201859-13299**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.335**
COS / SO2	**0.572**
Methyl Mercaptan	**0.301**
Ethyl Mercaptan	< 0.108
Dimethyl Sulfide	< 0.108
Carbon Disulfide	< 0.108
Isopropyl Mercaptan	< 0.108
tert-Butyl Mercaptan	**0.925**
n-Propyl Mercaptan	< 0.108
Methylethylsulfide	< 0.108
sec-Butyl Mercaptan / Thiophene	< 0.108
iso-Butyl Mercaptan	< 0.108
Diethyl Sulfide	< 0.108
n-Butyl Mercaptan	< 0.108
Dimethyl Disulfide	< 0.108
2-Methylthiophene	< 0.108
3-Methylthiophene	< 0.108
Tetrahydrothiophene	**1.17**
Bromothiophene	< 0.108
Thiophenol	< 0.108
Diethyl Disulfide	< 0.108
Total Unidentified Sulfur	< 0.108
Total Reduced Sulfurs	**2.73**
Total Sulfurs	**3.30**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/06/2020**
PROJECT NO.	**: 201859**	**RECEIVING DATE**	**: 10/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/12/2020**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 10/15/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**201859-13299**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.02041**
COS / SO2	**0.03487**
Methyl Mercaptan	**0.01835**
Ethyl Mercaptan	< 0.00660
Dimethyl Sulfide	< 0.00660
Carbon Disulfide	< 0.00660
Isopropyl Mercaptan	< 0.00660
tert-Butyl Mercaptan	**0.05633**
n-Propyl Mercaptan	< 0.00660
Methylethylsulfide	< 0.00660
sec-Butyl Mercaptan / Thiophene	< 0.00660
iso-Butyl Mercaptan	< 0.00660
Diethyl Sulfide	< 0.00660
n-Butyl Mercaptan	< 0.00660
Dimethyl Disulfide	< 0.00660
2-Methylthiophene	< 0.00660
3-Methylthiophene	< 0.00660
Tetrahydrothiophene	**0.07100**
Bromothiophene	< 0.00660
Thiophenol	< 0.00660
Diethyl Disulfide	< 0.00660
Total Unidentified Sulfur	< 0.00660
Total Reduced Sulfurs	**0.16609**
Total Sulfurs	**0.20095**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 10/12/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 9/9/2020

Opening Calibration Verification Standard

576.8 ppbV H2S (SS1227)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6017	574	99.5	0.5
Duplicate	5892	562	97.4	1.6
Triplicate	6047	577	100.0	1.0

573.3 ppbV H2S (SS1227)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6684	574	100.1	0.1
Duplicate	6736	579	100.9	0.7
Triplicate	6645	571	99.6	0.6

509.8 ppbV H2S (SS1227)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	7082	521	102.2	0.5
Duplicate	7074	520	102.1	0.4
Triplicate	6979	513	100.7	0.9

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 201859-13299

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	156.0	153.3	154.6	1.7
MeSH	134.1	143.9	139.0	7.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate Sample ID 201859-13299 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	15.5	288.4	294.2	303.8	96.8	100.0	3.2
MeSH	13.9	286.6	305.1	305.1	101.5	101.5	0.0
DMS	<PQL	254.9	259.4	256.6	101.8	100.7	1.1

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	576.8	543.6	94.3
MeSH	573.3	563.5	98.3
DMS	509.8	508.1	99.7

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

201859

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 10/8/20
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon / State: CA / Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax
Contract Number, PO Number	Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

Preparation and Analysis: Sulfur ASTM D-5504

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Sulfur ASTM D-5504
CPP-GS- OCT - A	13299	10/6/20	1138	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required: ☑ Normal ☐ Rush ☐ Other

QC Level: ☑ I. ☐ II. ☐ III.

Project Specific Requirements (Specify)

1. Relinquished By: Steve North (via GSO)	Date: 10/8/20	Time: 0900	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 10/9/20	Time: 1246

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

~~FX~~ GK 10/9/20 GSO

1x 1.0L can

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 202029
REPORT DATE : 11/12/2020

On November 9, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.4-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-NOV-A	202029-14179	680.5

This analysis is performed in accordance with AAC's Quality Manual. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 11/03/2020**
PROJECT NO.	**: 202029**	**RECEIVING DATE**	**: 11/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 11/09/2020**
UNITS	**: ppmV**	**REPORT DATE**	**: 11/12/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**202029-14179**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	< 0.114
COS / SO2	**0.594**
Methyl Mercaptan	< 0.114
Ethyl Mercaptan	< 0.114
Dimethyl Sulfide	< 0.114
Carbon Disulfide	< 0.114
Isopropyl Mercaptan	< 0.114
tert-Butyl Mercaptan	< 0.114
n-Propyl Mercaptan	< 0.114
Methylethylsulfide	< 0.114
sec-Butyl Mercaptan / Thiophene	< 0.114
iso-Butyl Mercaptan	< 0.114
Diethyl Sulfide	< 0.114
n-Butyl Mercaptan	< 0.114
Dimethyl Disulfide	< 0.114
2-Methylthiophene	< 0.114
3-Methylthiophene	< 0.114
Tetrahydrothiophene	**0.518**
Bromothiophene	< 0.114
Thiophenol	< 0.114
Diethyl Disulfide	< 0.114
Total Unidentified Sulfur	< 0.114
Total Reduced Sulfurs	**0.52**
Total Sulfurs	**1.11**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 11/03/2020**
PROJECT NO.	**: 202029**	**RECEIVING DATE**	**: 11/09/2020**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 11/09/2020**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 11/12/2020**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**202029-14179**
Canister Dil. Fac.	**2.3**
Analyte	**Result**
Hydrogen Sulfide	< 0.00692
COS / SO2	**0.03619**
Methyl Mercaptan	< 0.00692
Ethyl Mercaptan	< 0.00692
Dimethyl Sulfide	< 0.00692
Carbon Disulfide	< 0.00692
Isopropyl Mercaptan	< 0.00692
tert-Butyl Mercaptan	< 0.00692
n-Propyl Mercaptan	< 0.00692
Methylethylsulfide	< 0.00692
sec-Butyl Mercaptan / Thiophene	< 0.00692
iso-Butyl Mercaptan	< 0.00692
Diethyl Sulfide	< 0.00692
n-Butyl Mercaptan	< 0.00692
Dimethyl Disulfide	< 0.00692
2-Methylthiophene	< 0.00692
3-Methylthiophene	< 0.00692
Tetrahydrothiophene	**0.03158**
Bromothiophene	< 0.00692
Thiophenol	< 0.00692
Diethyl Disulfide	< 0.00692
Total Unidentified Sulfur	< 0.00692
Total Reduced Sulfurs	**0.03158**
Total Sulfurs	**0.06776**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 11/9/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 9/9/2020

Opening Calibration Verification Standard

576.8 ppbV H2S (SS1227)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5967	569	98.6	0.6
Duplicate	5975	570	98.8	0.4
Triplicate	6064	578	100.2	1.0

573.3 ppbV H2S (SS1227)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6785	583	101.7	1.2
Duplicate	6590	566	98.7	1.7
Triplicate	6739	579	101.0	0.5

509.8 ppbV H2S (SS1227)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	6985	514	100.8	0.2
Duplicate	6937	510	100.1	0.9
Triplicate	7071	520	102.0	1.0

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 201944-13700

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	168.1	169.2	168.7	0.7
MeSH	203.9	197.3	200.6	3.3
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate Sample ID 201944-13700 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	16.9	288.4	320.0	295.9	104.8	96.9	7.8
MeSH	20.1	286.6	309.6	320.0	101.0	104.3	3.3
DMS	<PQL	254.9	273.1	261.0	107.2	102.4	4.6

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	576.8	523.6	90.8
MeSH	573.3	595.6	103.9
DMS	509.8	541.2	106.2

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*
H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

202 029

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 11/5/20
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon / State: CA / Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax
Contract Number, PO Number	Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers Volume	Containers Type	Containers No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- NOV - A	14129	11/3/20	12:20	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required: ☑ Normal ☐ Rush ☐ Other

QC Level: ☑ I. ☐ II. ☐ III.

Project Specific Requirements (Specify)

1. Relinquished By: Steve North [signature] (via GSO)	Date: 11/5/20	Time: 0845	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By [signature]	Date: 11/9/20	Time: 0853

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GSO 1x 1.4L can

Atmospheric Analysis & Consulting, Inc.

CLIENT : PG&E
PROJECT NAME : Natural Gas Sampling
AAC PROJECT NO. : 202240
REPORT DATE : 12/17/2020

On December 10, 2020, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-DEC-A	202240-15358	706.3

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	: PG&E	SAMPLING DATE	: 12/09/2020
PROJECT NO.	: 202240	RECEIVING DATE	: 12/10/2020
MATRIX	: AIR	ANALYSIS DATE	: 12/14/2020
UNITS	: ppmV	REPORT DATE	: 12/17/2020

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-DEC-A
AAC ID	202240-15358
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.516**
COS / SO2	**0.423**
Methyl Mercaptan	< 0.111
Ethyl Mercaptan	< 0.111
Dimethyl Sulfide	< 0.111
Carbon Disulfide	< 0.111
Isopropyl Mercaptan	< 0.111
tert-Butyl Mercaptan	**0.523**
n-Propyl Mercaptan	< 0.111
Methylethylsulfide	< 0.111
sec-Butyl Mercaptan / Thiophene	< 0.111
iso-Butyl Mercaptan	< 0.111
Diethyl Sulfide	< 0.111
n-Butyl Mercaptan	< 0.111
Dimethyl Disulfide	< 0.111
2-Methylthiophene	< 0.111
3-Methylthiophene	< 0.111
Tetrahydrothiophene	**0.920**
Bromothiophene	< 0.111
Thiophenol	< 0.111
Diethyl Disulfide	< 0.111
Total Unidentified Sulfur	< 0.111
Total Reduced Sulfurs	**1.96**
Total Sulfurs	**2.38**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

LABORATORY ANALYSIS REPORT

CLIENT	: PG&E	SAMPLING DATE	: 12/09/2020
PROJECT NO.	: 202240	RECEIVING DATE	: 12/10/2020
MATRIX	: AIR	ANALYSIS DATE	: 12/14/2020
UNITS	: grains/100 dscf	REPORT DATE	: 12/17/2020

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-DEC-A
AAC ID	202240-15358
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.03141**
COS / SO2	**0.02577**
Methyl Mercaptan	< 0.00677
Ethyl Mercaptan	< 0.00677
Dimethyl Sulfide	< 0.00677
Carbon Disulfide	< 0.00677
Isopropyl Mercaptan	< 0.00677
tert-Butyl Mercaptan	**0.03184**
n-Propyl Mercaptan	< 0.00677
Methylethylsulfide	< 0.00677
sec-Butyl Mercaptan / Thiophene	< 0.00677
iso-Butyl Mercaptan	< 0.00677
Diethyl Sulfide	< 0.00677
n-Butyl Mercaptan	< 0.00677
Dimethyl Disulfide	< 0.00677
2-Methylthiophene	< 0.00677
3-Methylthiophene	< 0.00677
Tetrahydrothiophene	**0.05602**
Bromothiophene	< 0.00677
Thiophenol	< 0.00677
Diethyl Disulfide	< 0.00677
Total Unidentified Sulfur	< 0.00677
Total Reduced Sulfurs	**0.11928**
Total Sulfurs	**0.14505**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 12/14/2020
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 11/16/2020

Opening Calibration Verification Standard

576.8 ppbV H2S (SS1227)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4793	580	100.5	1.4
Duplicate	4716	570	98.9	0.2
Triplicate	4670	565	98.0	1.2

573.3 ppbV H2S (SS1227)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5491	567	98.9	0.1
Duplicate	5506	569	99.2	0.1
Triplicate	5497	568	99.0	0.0

509.8 ppbV H2S (SS1227)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	5799	495	97.2	1.2
Duplicate	5923	506	99.2	0.9
Triplicate	5882	502	98.6	0.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 202168-14946

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate Sample ID 202168-14946 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	288.4	272.6	265.0	94.5	91.9	2.8
MeSH	<PQL	286.6	283.5	280.5	98.9	97.9	1.1
DMS	<PQL	254.9	264.1	260.6	103.6	102.3	1.3

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	576.8	622.4	107.9
MeSH	573.3	617.3	107.7
DMS	509.8	533.3	104.6

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.0 ppbV, MDL = 1.60 ppbV
MeSH: PQL = 10.0 ppbV, MDL = 1.60 ppbV
DMS: PQL = 10.0 ppbV, MDL = 1.60 ppbV

Sucha Parmar, Ph.D.
Technical Director

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

202240

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services	Project Manager: Surinder Sidhu		Date: 12/9/20
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon / State: CA / Zip: 94583	Site Contacat		Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax
Contract Number, PO Number	Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- DEC -A	15358	12/9/20	1447	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via UPS)	Date: 12/9/20	Time: 1730	1. Received By	Date: 12/10/20	Time: 1020
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load
(Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/01/2020 00:00	1	1
10/01/2020 01:00	1	1
10/01/2020 02:00	1	1
10/01/2020 03:00	1	1
10/01/2020 04:00	1	1
10/01/2020 05:00	1	1
10/01/2020 06:00	1	1
10/01/2020 07:00	1	1
10/01/2020 08:00	1	1
10/01/2020 09:00	1	1
10/01/2020 10:00	1	1
10/01/2020 11:00	1	1
10/01/2020 12:00	1	1
10/01/2020 13:00	1	1
10/01/2020 14:00	1	1
10/01/2020 15:00	1	1
10/01/2020 16:00	1	1
10/01/2020 17:00	1	1
10/01/2020 18:00	1	1
10/01/2020 19:00	1	1
10/01/2020 20:00	1	1
10/01/2020 21:00	1	1
10/01/2020 22:00	1	1
10/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/02/2020 00:00	1	1
10/02/2020 01:00	1	1
10/02/2020 02:00	1	1
10/02/2020 03:00	1	1
10/02/2020 04:00	1	1
10/02/2020 05:00	1	1
10/02/2020 06:00	1	1
10/02/2020 07:00	1	1
10/02/2020 08:00	1	1
10/02/2020 09:00	1	1
10/02/2020 10:00	1	1
10/02/2020 11:00	1	1
10/02/2020 12:00	1	1
10/02/2020 13:00	1	1
10/02/2020 14:00	1	1
10/02/2020 15:00	1	1
10/02/2020 16:00	1	1
10/02/2020 17:00	1	1
10/02/2020 18:00	1	1
10/02/2020 19:00	1	1
10/02/2020 20:00	1	1
10/02/2020 21:00	1	1
10/02/2020 22:00	1	1
10/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/03/2020 00:00	1	1
10/03/2020 01:00	1	1
10/03/2020 02:00	1	1
10/03/2020 03:00	1	1
10/03/2020 04:00	1	1
10/03/2020 05:00	1	1
10/03/2020 06:00	1	1
10/03/2020 07:00	1	1
10/03/2020 08:00	10	1
10/03/2020 09:00	14	1
10/03/2020 10:00	14	1
10/03/2020 11:00	13	1
10/03/2020 12:00	4	14
10/03/2020 13:00	1	16
10/03/2020 14:00	1	16
10/03/2020 15:00	1	15
10/03/2020 16:00	1	3
10/03/2020 17:00	1	1
10/03/2020 18:00	1	1
10/03/2020 19:00	1	1
10/03/2020 20:00	1	1
10/03/2020 21:00	1	1
10/03/2020 22:00	1	1
10/03/2020 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	14	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/04/2020 00:00	1	1
10/04/2020 01:00	1	1
10/04/2020 02:00	1	1
10/04/2020 03:00	1	1
10/04/2020 04:00	1	1
10/04/2020 05:00	1	1
10/04/2020 06:00	1	1
10/04/2020 07:00	1	1
10/04/2020 08:00	1	1
10/04/2020 09:00	11	1
10/04/2020 10:00	13	1
10/04/2020 11:00	13	1
10/04/2020 12:00	12	1
10/04/2020 13:00	3	12
10/04/2020 14:00	1	13
10/04/2020 15:00	1	13
10/04/2020 16:00	1	13
10/04/2020 17:00	1	2
10/04/2020 18:00	1	1
10/04/2020 19:00	1	1
10/04/2020 20:00	1	1
10/04/2020 21:00	1	1
10/04/2020 22:00	1	1
10/04/2020 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	13	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/05/2020 00:00	1	1
10/05/2020 01:00	1	1
10/05/2020 02:00	1	1
10/05/2020 03:00	1	1
10/05/2020 04:00	1	1
10/05/2020 05:00	1	1
10/05/2020 06:00	1	1
10/05/2020 07:00	1	1
10/05/2020 08:00	1	1
10/05/2020 09:00	1	1
10/05/2020 10:00	1	1
10/05/2020 11:00	1	1
10/05/2020 12:00	1	1
10/05/2020 13:00	1	1
10/05/2020 14:00	1	1
10/05/2020 15:00	1	1
10/05/2020 16:00	1	1
10/05/2020 17:00	1	1
10/05/2020 18:00	1	1
10/05/2020 19:00	1	1
10/05/2020 20:00	1	1
10/05/2020 21:00	1	1
10/05/2020 22:00	1	2
10/05/2020 23:00	1	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/06/2020 00:00	1	2
10/06/2020 01:00	1	2
10/06/2020 02:00	1	2
10/06/2020 03:00	1	2
10/06/2020 04:00	1	2
10/06/2020 05:00	1	2
10/06/2020 06:00	13	2
10/06/2020 07:00	17	2
10/06/2020 08:00	16	2
10/06/2020 09:00	16	2
10/06/2020 10:00	5	2
10/06/2020 11:00	1	13
10/06/2020 12:00	1	15
10/06/2020 13:00	1	14
10/06/2020 14:00	1	14
10/06/2020 15:00	1	3
10/06/2020 16:00	1	1
10/06/2020 17:00	1	1
10/06/2020 18:00	1	1
10/06/2020 19:00	1	1
10/06/2020 20:00	1	1
10/06/2020 21:00	1	1
10/06/2020 22:00	1	1
10/06/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	17	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/07/2020 00:00	1	1
10/07/2020 01:00	1	1
10/07/2020 02:00	1	1
10/07/2020 03:00	1	1
10/07/2020 04:00	1	1
10/07/2020 05:00	1	1
10/07/2020 06:00	1	1
10/07/2020 07:00	1	1
10/07/2020 08:00	1	1
10/07/2020 09:00	1	1
10/07/2020 10:00	1	1
10/07/2020 11:00	1	1
10/07/2020 12:00	1	1
10/07/2020 13:00	1	1
10/07/2020 14:00	1	1
10/07/2020 15:00	1	1
10/07/2020 16:00	1	1
10/07/2020 17:00	1	1
10/07/2020 18:00	1	1
10/07/2020 19:00	1	1
10/07/2020 20:00	1	1
10/07/2020 21:00	1	1
10/07/2020 22:00	1	1
10/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/08/2020 00:00	1	1
10/08/2020 01:00	1	1
10/08/2020 02:00	1	1
10/08/2020 03:00	1	1
10/08/2020 04:00	1	1
10/08/2020 05:00	1	1
10/08/2020 06:00	1	1
10/08/2020 07:00	1	1
10/08/2020 08:00	1	1
10/08/2020 09:00	1	1
10/08/2020 10:00	1	1
10/08/2020 11:00	1	1
10/08/2020 12:00	1	1
10/08/2020 13:00	1	1
10/08/2020 14:00	1	1
10/08/2020 15:00	1	1
10/08/2020 16:00	1	1
10/08/2020 17:00	1	1
10/08/2020 18:00	1	1
10/08/2020 19:00	1	1
10/08/2020 20:00	1	1
10/08/2020 21:00	1	1
10/08/2020 22:00	1	1
10/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/09/2020 00:00	1	1
10/09/2020 01:00	1	1
10/09/2020 02:00	1	1
10/09/2020 03:00	1	1
10/09/2020 04:00	1	1
10/09/2020 05:00	1	1
10/09/2020 06:00	1	1
10/09/2020 07:00	1	1
10/09/2020 08:00	1	1
10/09/2020 09:00	1	1
10/09/2020 10:00	1	1
10/09/2020 11:00	1	1
10/09/2020 12:00	1	1
10/09/2020 13:00	1	1
10/09/2020 14:00	1	1
10/09/2020 15:00	1	1
10/09/2020 16:00	1	1
10/09/2020 17:00	1	1
10/09/2020 18:00	1	1
10/09/2020 19:00	1	1
10/09/2020 20:00	1	1
10/09/2020 21:00	1	1
10/09/2020 22:00	1	1
10/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/10/2020 00:00	1	1
10/10/2020 01:00	1	1
10/10/2020 02:00	1	1
10/10/2020 03:00	1	1
10/10/2020 04:00	1	1
10/10/2020 05:00	1	1
10/10/2020 06:00	1	1
10/10/2020 07:00	1	1
10/10/2020 08:00	1	1
10/10/2020 09:00	1	1
10/10/2020 10:00	1	1
10/10/2020 11:00	1	1
10/10/2020 12:00	1	1
10/10/2020 13:00	1	1
10/10/2020 14:00	1	1
10/10/2020 15:00	1	1
10/10/2020 16:00	1	1
10/10/2020 17:00	1	1
10/10/2020 18:00	1	1
10/10/2020 19:00	1	1
10/10/2020 20:00	1	1
10/10/2020 21:00	1	1
10/10/2020 22:00	1	1
10/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/11/2020 00:00	1	1
10/11/2020 01:00	1	14
10/11/2020 02:00	1	21
10/11/2020 03:00	1	26
10/11/2020 04:00	1	30
10/11/2020 05:00	1	17
10/11/2020 06:00	1	10
10/11/2020 07:00	1	5
10/11/2020 08:00	1	0
10/11/2020 09:00	1	1
10/11/2020 10:00	1	1
10/11/2020 11:00	1	1
10/11/2020 12:00	1	1
10/11/2020 13:00	1	1
10/11/2020 14:00	1	1
10/11/2020 15:00	1	1
10/11/2020 16:00	1	1
10/11/2020 17:00	1	1
10/11/2020 18:00	1	1
10/11/2020 19:00	1	1
10/11/2020 20:00	1	1
10/11/2020 21:00	1	1
10/11/2020 22:00	1	1
10/11/2020 23:00	1	1
Average/Sum#:	1	6
Minimum:	1	0
Maximum:	1	30
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/12/2020 00:00	1	1
10/12/2020 01:00	1	1
10/12/2020 02:00	1	1
10/12/2020 03:00	1	1
10/12/2020 04:00	1	1
10/12/2020 05:00	1	1
10/12/2020 06:00	1	1
10/12/2020 07:00	1	1
10/12/2020 08:00	1	1
10/12/2020 09:00	1	1
10/12/2020 10:00	1	1
10/12/2020 11:00	1	1
10/12/2020 12:00	18	1
10/12/2020 13:00	25	1
10/12/2020 14:00	25	1
10/12/2020 15:00	25	1
10/12/2020 16:00	8	1
10/12/2020 17:00	1	1
10/12/2020 18:00	1	1
10/12/2020 19:00	1	1
10/12/2020 20:00	1	1
10/12/2020 21:00	1	1
10/12/2020 22:00	1	1
10/12/2020 23:00	1	1
Average/Sum#:	5	1
Minimum:	1	1
Maximum:	25	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/13/2020 00:00	1	1
10/13/2020 01:00	1	1
10/13/2020 02:00	1	1
10/13/2020 03:00	1	1
10/13/2020 04:00	1	1
10/13/2020 05:00	1	1
10/13/2020 06:00	1	1
10/13/2020 07:00	1	1
10/13/2020 08:00	1	1
10/13/2020 09:00	1	1
10/13/2020 10:00	1	1
10/13/2020 11:00	1	1
10/13/2020 12:00	1	1
10/13/2020 13:00	1	1
10/13/2020 14:00	1	1
10/13/2020 15:00	1	1
10/13/2020 16:00	1	1
10/13/2020 17:00	1	1
10/13/2020 18:00	1	1
10/13/2020 19:00	1	1
10/13/2020 20:00	1	1
10/13/2020 21:00	1	1
10/13/2020 22:00	1	1
10/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/14/2020 00:00	1	1
10/14/2020 01:00	1	1
10/14/2020 02:00	1	1
10/14/2020 03:00	1	1
10/14/2020 04:00	1	1
10/14/2020 05:00	1	1
10/14/2020 06:00	1	1
10/14/2020 07:00	1	1
10/14/2020 08:00	1	1
10/14/2020 09:00	1	1
10/14/2020 10:00	1	1
10/14/2020 11:00	1	1
10/14/2020 12:00	1	1
10/14/2020 13:00	1	1
10/14/2020 14:00	1	1
10/14/2020 15:00	1	1
10/14/2020 16:00	1	1
10/14/2020 17:00	1	1
10/14/2020 18:00	1	1
10/14/2020 19:00	1	1
10/14/2020 20:00	1	1
10/14/2020 21:00	1	1
10/14/2020 22:00	1	1
10/14/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/15/2020 00:00	1	1
10/15/2020 01:00	1	1
10/15/2020 02:00	1	1
10/15/2020 03:00	1	1
10/15/2020 04:00	1	1
10/15/2020 05:00	1	1
10/15/2020 06:00	1	1
10/15/2020 07:00	1	1
10/15/2020 08:00	1	1
10/15/2020 09:00	1	1
10/15/2020 10:00	1	1
10/15/2020 11:00	1	1
10/15/2020 12:00	1	1
10/15/2020 13:00	1	1
10/15/2020 14:00	1	1
10/15/2020 15:00	1	1
10/15/2020 16:00	1	1
10/15/2020 17:00	1	1
10/15/2020 18:00	1	1
10/15/2020 19:00	1	1
10/15/2020 20:00	1	1
10/15/2020 21:00	1	1
10/15/2020 22:00	1	1
10/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/16/2020 00:00	1	1
10/16/2020 01:00	1	1
10/16/2020 02:00	1	1
10/16/2020 03:00	1	1
10/16/2020 04:00	1	1
10/16/2020 05:00	1	1
10/16/2020 06:00	1	1
10/16/2020 07:00	1	1
10/16/2020 08:00	1	1
10/16/2020 09:00	1	1
10/16/2020 10:00	1	1
10/16/2020 11:00	1	1
10/16/2020 12:00	1	1
10/16/2020 13:00	1	1
10/16/2020 14:00	1	1
10/16/2020 15:00	1	1
10/16/2020 16:00	1	1
10/16/2020 17:00	1	1
10/16/2020 18:00	1	1
10/16/2020 19:00	1	1
10/16/2020 20:00	1	1
10/16/2020 21:00	1	1
10/16/2020 22:00	1	1
10/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/17/2020 00:00	1	1
10/17/2020 01:00	1	1
10/17/2020 02:00	1	1
10/17/2020 03:00	1	1
10/17/2020 04:00	1	1
10/17/2020 05:00	1	1
10/17/2020 06:00	1	1
10/17/2020 07:00	1	1
10/17/2020 08:00	1	1
10/17/2020 09:00	1	1
10/17/2020 10:00	1	1
10/17/2020 11:00	1	1
10/17/2020 12:00	1	1
10/17/2020 13:00	1	1
10/17/2020 14:00	1	1
10/17/2020 15:00	1	1
10/17/2020 16:00	1	1
10/17/2020 17:00	1	1
10/17/2020 18:00	1	1
10/17/2020 19:00	1	1
10/17/2020 20:00	1	1
10/17/2020 21:00	1	1
10/17/2020 22:00	1	1
10/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/18/2020 00:00	1	1
10/18/2020 01:00	1	1
10/18/2020 02:00	1	1
10/18/2020 03:00	1	1
10/18/2020 04:00	1	1
10/18/2020 05:00	1	1
10/18/2020 06:00	1	1
10/18/2020 07:00	1	1
10/18/2020 08:00	1	1
10/18/2020 09:00	1	1
10/18/2020 10:00	1	1
10/18/2020 11:00	1	1
10/18/2020 12:00	1	1
10/18/2020 13:00	1	1
10/18/2020 14:00	1	1
10/18/2020 15:00	1	1
10/18/2020 16:00	1	1
10/18/2020 17:00	1	1
10/18/2020 18:00	1	1
10/18/2020 19:00	1	1
10/18/2020 20:00	1	1
10/18/2020 21:00	7	1
10/18/2020 22:00	9	1
10/18/2020 23:00	9	1
Average/Sum#:	2	1
Minimum:	1	1
Maximum:	9	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/19/2020 00:00	9	1
10/19/2020 01:00	3	1
10/19/2020 02:00	1	1
10/19/2020 03:00	1	1
10/19/2020 04:00	1	1
10/19/2020 05:00	1	1
10/19/2020 06:00	1	1
10/19/2020 07:00	1	1
10/19/2020 08:00	1	1
10/19/2020 09:00	1	1
10/19/2020 10:00	1	1
10/19/2020 11:00	1	1
10/19/2020 12:00	1	1
10/19/2020 13:00	1	1
10/19/2020 14:00	1	1
10/19/2020 15:00	1	1
10/19/2020 16:00	1	1
10/19/2020 17:00	1	1
10/19/2020 18:00	1	1
10/19/2020 19:00	1	1
10/19/2020 20:00	1	1
10/19/2020 21:00	1	1
10/19/2020 22:00	1	1
10/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	9	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/20/2020 00:00	1	1
10/20/2020 01:00	1	1
10/20/2020 02:00	1	1
10/20/2020 03:00	1	1
10/20/2020 04:00	1	1
10/20/2020 05:00	1	1
10/20/2020 06:00	1	1
10/20/2020 07:00	1	1
10/20/2020 08:00	1	1
10/20/2020 09:00	1	1
10/20/2020 10:00	1	1
10/20/2020 11:00	1	1
10/20/2020 12:00	1	1
10/20/2020 13:00	1	1
10/20/2020 14:00	1	1
10/20/2020 15:00	1	1
10/20/2020 16:00	1	1
10/20/2020 17:00	1	1
10/20/2020 18:00	1	1
10/20/2020 19:00	1	1
10/20/2020 20:00	1	1
10/20/2020 21:00	1	1
10/20/2020 22:00	1	1
10/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/21/2020 00:00	1	1
10/21/2020 01:00	1	1
10/21/2020 02:00	1	1
10/21/2020 03:00	1	1
10/21/2020 04:00	1	1
10/21/2020 05:00	1	1
10/21/2020 06:00	1	1
10/21/2020 07:00	1	1
10/21/2020 08:00	1	1
10/21/2020 09:00	1	1
10/21/2020 10:00	1	1
10/21/2020 11:00	1	1
10/21/2020 12:00	1	1
10/21/2020 13:00	1	1
10/21/2020 14:00	1	1
10/21/2020 15:00	1	1
10/21/2020 16:00	1	1
10/21/2020 17:00	1	1
10/21/2020 18:00	1	1
10/21/2020 19:00	1	1
10/21/2020 20:00	1	1
10/21/2020 21:00	1	1
10/21/2020 22:00	1	1
10/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/22/2020 00:00	1	1
10/22/2020 01:00	1	1
10/22/2020 02:00	1	1
10/22/2020 03:00	1	1
10/22/2020 04:00	1	1
10/22/2020 05:00	1	1
10/22/2020 06:00	1	1
10/22/2020 07:00	1	1
10/22/2020 08:00	1	1
10/22/2020 09:00	1	1
10/22/2020 10:00	1	1
10/22/2020 11:00	1	1
10/22/2020 12:00	1	1
10/22/2020 13:00	1	1
10/22/2020 14:00	1	1
10/22/2020 15:00	1	1
10/22/2020 16:00	1	1
10/22/2020 17:00	1	1
10/22/2020 18:00	1	1
10/22/2020 19:00	1	1
10/22/2020 20:00	1	1
10/22/2020 21:00	1	1
10/22/2020 22:00	1	1
10/22/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/23/2020 00:00	1	1
10/23/2020 01:00	1	1
10/23/2020 02:00	1	1
10/23/2020 03:00	1	1
10/23/2020 04:00	1	1
10/23/2020 05:00	1	1
10/23/2020 06:00	1	1
10/23/2020 07:00	1	1
10/23/2020 08:00	1	1
10/23/2020 09:00	1	1
10/23/2020 10:00	1	1
10/23/2020 11:00	1	1
10/23/2020 12:00	1	1
10/23/2020 13:00	1	1
10/23/2020 14:00	1	1
10/23/2020 15:00	1	1
10/23/2020 16:00	1	1
10/23/2020 17:00	1	1
10/23/2020 18:00	1	1
10/23/2020 19:00	1	1
10/23/2020 20:00	1	1
10/23/2020 21:00	1	1
10/23/2020 22:00	1	1
10/23/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/24/2020 00:00	1	1
10/24/2020 01:00	1	1
10/24/2020 02:00	1	1
10/24/2020 03:00	1	1
10/24/2020 04:00	1	1
10/24/2020 05:00	1	1
10/24/2020 06:00	1	1
10/24/2020 07:00	1	1
10/24/2020 08:00	1	1
10/24/2020 09:00	1	1
10/24/2020 10:00	1	1
10/24/2020 11:00	1	1
10/24/2020 12:00	1	1
10/24/2020 13:00	1	1
10/24/2020 14:00	1	1
10/24/2020 15:00	1	1
10/24/2020 16:00	1	1
10/24/2020 17:00	1	1
10/24/2020 18:00	1	1
10/24/2020 19:00	1	1
10/24/2020 20:00	1	1
10/24/2020 21:00	1	1
10/24/2020 22:00	1	1
10/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/25/2020 00:00	1	1
10/25/2020 01:00	1	1
10/25/2020 02:00	1	1
10/25/2020 03:00	1	1
10/25/2020 04:00	1	1
10/25/2020 05:00	1	1
10/25/2020 06:00	1	1
10/25/2020 07:00	1	1
10/25/2020 08:00	1	1
10/25/2020 09:00	1	1
10/25/2020 10:00	1	1
10/25/2020 11:00	1	1
10/25/2020 12:00	1	1
10/25/2020 13:00	1	1
10/25/2020 14:00	1	1
10/25/2020 15:00	1	1
10/25/2020 16:00	1	1
10/25/2020 17:00	1	1
10/25/2020 18:00	1	1
10/25/2020 19:00	1	1
10/25/2020 20:00	1	1
10/25/2020 21:00	1	1
10/25/2020 22:00	1	1
10/25/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/26/2020 00:00	1	1
10/26/2020 01:00	1	1
10/26/2020 02:00	1	1
10/26/2020 03:00	1	1
10/26/2020 04:00	1	1
10/26/2020 05:00	1	1
10/26/2020 06:00	1	1
10/26/2020 07:00	1	1
10/26/2020 08:00	1	1
10/26/2020 09:00	1	1
10/26/2020 10:00	1	1
10/26/2020 11:00	1	1
10/26/2020 12:00	1	1
10/26/2020 13:00	1	1
10/26/2020 14:00	1	1
10/26/2020 15:00	1	1
10/26/2020 16:00	1	1
10/26/2020 17:00	1	1
10/26/2020 18:00	1	1
10/26/2020 19:00	1	1
10/26/2020 20:00	1	1
10/26/2020 21:00	1	1
10/26/2020 22:00	1	1
10/26/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/27/2020 00:00	1	1
10/27/2020 01:00	1	1
10/27/2020 02:00	1	1
10/27/2020 03:00	1	1
10/27/2020 04:00	1	1
10/27/2020 05:00	1	1
10/27/2020 06:00	1	1
10/27/2020 07:00	1	1
10/27/2020 08:00	1	1
10/27/2020 09:00	1	1
10/27/2020 10:00	1	1
10/27/2020 11:00	1	1
10/27/2020 12:00	1	1
10/27/2020 13:00	1	1
10/27/2020 14:00	1	1
10/27/2020 15:00	1	1
10/27/2020 16:00	1	1
10/27/2020 17:00	1	1
10/27/2020 18:00	1	1
10/27/2020 19:00	1	1
10/27/2020 20:00	1	1
10/27/2020 21:00	1	1
10/27/2020 22:00	1	1
10/27/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/28/2020 00:00	1	1
10/28/2020 01:00	1	1
10/28/2020 02:00	1	1
10/28/2020 03:00	1	1
10/28/2020 04:00	1	1
10/28/2020 05:00	1	1
10/28/2020 06:00	1	1
10/28/2020 07:00	1	1
10/28/2020 08:00	1	1
10/28/2020 09:00	1	1
10/28/2020 10:00	1	0
10/28/2020 11:00	1	1
10/28/2020 12:00	1	1
10/28/2020 13:00	1	1
10/28/2020 14:00	1	1
10/28/2020 15:00	1	1
10/28/2020 16:00	1	1
10/28/2020 17:00	1	1
10/28/2020 18:00	1	1
10/28/2020 19:00	1	1
10/28/2020 20:00	1	1
10/28/2020 21:00	1	1
10/28/2020 22:00	1	1
10/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/29/2020 00:00	1	1
10/29/2020 01:00	1	1
10/29/2020 02:00	1	1
10/29/2020 03:00	1	1
10/29/2020 04:00	1	1
10/29/2020 05:00	1	1
10/29/2020 06:00	1	1
10/29/2020 07:00	1	1
10/29/2020 08:00	1	1
10/29/2020 09:00	1	1
10/29/2020 10:00	1	1
10/29/2020 11:00	1	1
10/29/2020 12:00	1	1
10/29/2020 13:00	1	1
10/29/2020 14:00	1	1
10/29/2020 15:00	1	1
10/29/2020 16:00	1	1
10/29/2020 17:00	1	1
10/29/2020 18:00	1	1
10/29/2020 19:00	1	1
10/29/2020 20:00	1	1
10/29/2020 21:00	1	1
10/29/2020 22:00	1	1
10/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/30/2020 00:00	1	1
10/30/2020 01:00	1	1
10/30/2020 02:00	1	1
10/30/2020 03:00	1	1
10/30/2020 04:00	1	1
10/30/2020 05:00	1	1
10/30/2020 06:00	1	1
10/30/2020 07:00	1	1
10/30/2020 08:00	1	1
10/30/2020 09:00	1	1
10/30/2020 10:00	1	1
10/30/2020 11:00	1	1
10/30/2020 12:00	1	1
10/30/2020 13:00	1	1
10/30/2020 14:00	1	1
10/30/2020 15:00	1	1
10/30/2020 16:00	1	1
10/30/2020 17:00	1	1
10/30/2020 18:00	1	1
10/30/2020 19:00	1	1
10/30/2020 20:00	1	1
10/30/2020 21:00	1	1
10/30/2020 22:00	1	1
10/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/31/2020 00:00	1	1
10/31/2020 01:00	1	1
10/31/2020 02:00	1	1
10/31/2020 03:00	1	1
10/31/2020 04:00	1	1
10/31/2020 05:00	1	1
10/31/2020 06:00	1	1
10/31/2020 07:00	1	1
10/31/2020 08:00	1	1
10/31/2020 09:00	1	1
10/31/2020 10:00	1	1
10/31/2020 11:00	1	1
10/31/2020 12:00	1	1
10/31/2020 13:00	1	1
10/31/2020 14:00	1	1
10/31/2020 15:00	1	1
10/31/2020 16:00	1	1
10/31/2020 17:00	1	1
10/31/2020 18:00	1	1
10/31/2020 19:00	1	1
10/31/2020 20:00	1	1
10/31/2020 21:00	1	1
10/31/2020 22:00	1	1
10/31/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/01/2020 00:00	2	1
11/01/2020 01:00	2	1
11/01/2020 02:00	1	1
11/01/2020 03:00	1	1
11/01/2020 04:00	1	1
11/01/2020 05:00	1	1
11/01/2020 06:00	1	1
11/01/2020 07:00	1	1
11/01/2020 08:00	1	1
11/01/2020 09:00	1	1
11/01/2020 10:00	1	1
11/01/2020 11:00	1	1
11/01/2020 12:00	1	1
11/01/2020 13:00	1	1
11/01/2020 14:00	1	1
11/01/2020 15:00	1	1
11/01/2020 16:00	1	1
11/01/2020 17:00	1	1
11/01/2020 18:00	1	1
11/01/2020 19:00	1	1
11/01/2020 20:00	1	1
11/01/2020 21:00	1	1
11/01/2020 22:00	1	1
11/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/02/2020 00:00	1	1
11/02/2020 01:00	1	1
11/02/2020 02:00	1	1
11/02/2020 03:00	1	1
11/02/2020 04:00	1	1
11/02/2020 05:00	1	1
11/02/2020 06:00	1	1
11/02/2020 07:00	1	1
11/02/2020 08:00	1	1
11/02/2020 09:00	1	1
11/02/2020 10:00	1	1
11/02/2020 11:00	1	1
11/02/2020 12:00	1	1
11/02/2020 13:00	1	1
11/02/2020 14:00	1	1
11/02/2020 15:00	1	1
11/02/2020 16:00	1	1
11/02/2020 17:00	1	1
11/02/2020 18:00	1	1
11/02/2020 19:00	1	1
11/02/2020 20:00	1	1
11/02/2020 21:00	1	1
11/02/2020 22:00	1	1
11/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/03/2020 00:00	1	1
11/03/2020 01:00	1	1
11/03/2020 02:00	1	1
11/03/2020 03:00	1	1
11/03/2020 04:00	1	1
11/03/2020 05:00	1	1
11/03/2020 06:00	1	1
11/03/2020 07:00	1	1
11/03/2020 08:00	1	1
11/03/2020 09:00	1	1
11/03/2020 10:00	1	1
11/03/2020 11:00	1	1
11/03/2020 12:00	1	1
11/03/2020 13:00	1	1
11/03/2020 14:00	1	1
11/03/2020 15:00	1	1
11/03/2020 16:00	1	1
11/03/2020 17:00	1	1
11/03/2020 18:00	1	1
11/03/2020 19:00	1	1
11/03/2020 20:00	1	1
11/03/2020 21:00	1	1
11/03/2020 22:00	1	1
11/03/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/04/2020 00:00	1	1
11/04/2020 01:00	1	1
11/04/2020 02:00	1	1
11/04/2020 03:00	1	1
11/04/2020 04:00	1	1
11/04/2020 05:00	1	1
11/04/2020 06:00	1	1
11/04/2020 07:00	1	1
11/04/2020 08:00	1	1
11/04/2020 09:00	1	1
11/04/2020 10:00	1	1
11/04/2020 11:00	1	1
11/04/2020 12:00	1	1
11/04/2020 13:00	1	1
11/04/2020 14:00	1	1
11/04/2020 15:00	1	1
11/04/2020 16:00	1	1
11/04/2020 17:00	1	1
11/04/2020 18:00	1	1
11/04/2020 19:00	1	1
11/04/2020 20:00	1	1
11/04/2020 21:00	1	1
11/04/2020 22:00	1	1
11/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/05/2020 00:00	1	1
11/05/2020 01:00	1	1
11/05/2020 02:00	1	1
11/05/2020 03:00	1	1
11/05/2020 04:00	1	1
11/05/2020 05:00	1	1
11/05/2020 06:00	1	1
11/05/2020 07:00	1	1
11/05/2020 08:00	1	1
11/05/2020 09:00	1	1
11/05/2020 10:00	1	1
11/05/2020 11:00	1	1
11/05/2020 12:00	1	1
11/05/2020 13:00	1	1
11/05/2020 14:00	1	1
11/05/2020 15:00	1	1
11/05/2020 16:00	1	1
11/05/2020 17:00	1	1
11/05/2020 18:00	1	1
11/05/2020 19:00	1	1
11/05/2020 20:00	1	1
11/05/2020 21:00	1	1
11/05/2020 22:00	1	1
11/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/06/2020 00:00	1	1
11/06/2020 01:00	1	1
11/06/2020 02:00	1	1
11/06/2020 03:00	1	1
11/06/2020 04:00	1	1
11/06/2020 05:00	1	1
11/06/2020 06:00	1	1
11/06/2020 07:00	1	1
11/06/2020 08:00	1	1
11/06/2020 09:00	1	1
11/06/2020 10:00	1	1
11/06/2020 11:00	1	0
11/06/2020 12:00	1	0
11/06/2020 13:00	1	0
11/06/2020 14:00	1	1
11/06/2020 15:00	1	1
11/06/2020 16:00	1	1
11/06/2020 17:00	1	1
11/06/2020 18:00	1	1
11/06/2020 19:00	1	1
11/06/2020 20:00	1	1
11/06/2020 21:00	1	1
11/06/2020 22:00	1	1
11/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/07/2020 00:00	1	1
11/07/2020 01:00	1	1
11/07/2020 02:00	1	1
11/07/2020 03:00	1	1
11/07/2020 04:00	1	1
11/07/2020 05:00	1	1
11/07/2020 06:00	1	1
11/07/2020 07:00	1	1
11/07/2020 08:00	1	1
11/07/2020 09:00	0	1
11/07/2020 10:00	0	1
11/07/2020 11:00	0	1
11/07/2020 12:00	0	1
11/07/2020 13:00	0	1
11/07/2020 14:00	0	1
11/07/2020 15:00	0	1
11/07/2020 16:00	0	1
11/07/2020 17:00	0	1
11/07/2020 18:00	0	1
11/07/2020 19:00	0	1
11/07/2020 20:00	0	1
11/07/2020 21:00	0	1
11/07/2020 22:00	0	1
11/07/2020 23:00	1	1
Average/Sum#:	0	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/08/2020 00:00	1	1
11/08/2020 01:00	1	1
11/08/2020 02:00	1	1
11/08/2020 03:00	1	1
11/08/2020 04:00	1	1
11/08/2020 05:00	1	1
11/08/2020 06:00	1	1
11/08/2020 07:00	1	1
11/08/2020 08:00	1	1
11/08/2020 09:00	1	1
11/08/2020 10:00	1	1
11/08/2020 11:00	1	1
11/08/2020 12:00	1	1
11/08/2020 13:00	1	1
11/08/2020 14:00	1	1
11/08/2020 15:00	1	1
11/08/2020 16:00	1	1
11/08/2020 17:00	1	1
11/08/2020 18:00	1	1
11/08/2020 19:00	1	1
11/08/2020 20:00	1	1
11/08/2020 21:00	1	1
11/08/2020 22:00	1	1
11/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/09/2020 00:00	1	1
11/09/2020 01:00	1	1
11/09/2020 02:00	1	1
11/09/2020 03:00	1	1
11/09/2020 04:00	1	1
11/09/2020 05:00	1	1
11/09/2020 06:00	1	1
11/09/2020 07:00	1	1
11/09/2020 08:00	1	1
11/09/2020 09:00	1	1
11/09/2020 10:00	1	1
11/09/2020 11:00	1	1
11/09/2020 12:00	1	1
11/09/2020 13:00	1	1
11/09/2020 14:00	1	1
11/09/2020 15:00	1	1
11/09/2020 16:00	1	1
11/09/2020 17:00	1	1
11/09/2020 18:00	1	1
11/09/2020 19:00	1	1
11/09/2020 20:00	1	1
11/09/2020 21:00	1	1
11/09/2020 22:00	1	1
11/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/10/2020 00:00	1	1
11/10/2020 01:00	1	1
11/10/2020 02:00	1	1
11/10/2020 03:00	1	1
11/10/2020 04:00	1	1
11/10/2020 05:00	1	1
11/10/2020 06:00	1	1
11/10/2020 07:00	1	1
11/10/2020 08:00	1	1
11/10/2020 09:00	1	1
11/10/2020 10:00	1	1
11/10/2020 11:00	1	1
11/10/2020 12:00	1	1
11/10/2020 13:00	1	1
11/10/2020 14:00	1	1
11/10/2020 15:00	1	1
11/10/2020 16:00	1	1
11/10/2020 17:00	1	1
11/10/2020 18:00	1	1
11/10/2020 19:00	1	1
11/10/2020 20:00	1	1
11/10/2020 21:00	1	1
11/10/2020 22:00	1	1
11/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/11/2020 00:00	1	1
11/11/2020 01:00	1	1
11/11/2020 02:00	1	1
11/11/2020 03:00	1	1
11/11/2020 04:00	1	1
11/11/2020 05:00	1	1
11/11/2020 06:00	1	1
11/11/2020 07:00	1	1
11/11/2020 08:00	1	1
11/11/2020 09:00	1	1
11/11/2020 10:00	1	1
11/11/2020 11:00	1	1
11/11/2020 12:00	1	1
11/11/2020 13:00	1	1
11/11/2020 14:00	1	1
11/11/2020 15:00	1	1
11/11/2020 16:00	1	1
11/11/2020 17:00	1	1
11/11/2020 18:00	1	1
11/11/2020 19:00	1	1
11/11/2020 20:00	1	1
11/11/2020 21:00	1	1
11/11/2020 22:00	1	1
11/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/12/2020 00:00	1	1
11/12/2020 01:00	1	1
11/12/2020 02:00	1	1
11/12/2020 03:00	1	1
11/12/2020 04:00	1	1
11/12/2020 05:00	1	1
11/12/2020 06:00	1	1
11/12/2020 07:00	1	1
11/12/2020 08:00	1	1
11/12/2020 09:00	1	1
11/12/2020 10:00	1	1
11/12/2020 11:00	1	1
11/12/2020 12:00	1	1
11/12/2020 13:00	1	1
11/12/2020 14:00	1	1
11/12/2020 15:00	1	1
11/12/2020 16:00	1	1
11/12/2020 17:00	1	1
11/12/2020 18:00	1	1
11/12/2020 19:00	1	1
11/12/2020 20:00	1	1
11/12/2020 21:00	1	1
11/12/2020 22:00	1	1
11/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/13/2020 00:00	1	1
11/13/2020 01:00	1	1
11/13/2020 02:00	1	1
11/13/2020 03:00	1	1
11/13/2020 04:00	1	1
11/13/2020 05:00	1	1
11/13/2020 06:00	1	1
11/13/2020 07:00	1	1
11/13/2020 08:00	1	1
11/13/2020 09:00	1	1
11/13/2020 10:00	1	1
11/13/2020 11:00	1	1
11/13/2020 12:00	1	1
11/13/2020 13:00	1	1
11/13/2020 14:00	1	1
11/13/2020 15:00	1	1
11/13/2020 16:00	1	1
11/13/2020 17:00	1	1
11/13/2020 18:00	1	1
11/13/2020 19:00	1	1
11/13/2020 20:00	1	1
11/13/2020 21:00	1	1
11/13/2020 22:00	1	1
11/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/14/2020 00:00	1	1
11/14/2020 01:00	1	1
11/14/2020 02:00	1	1
11/14/2020 03:00	1	1
11/14/2020 04:00	1	1
11/14/2020 05:00	1	6
11/14/2020 06:00	1	8
11/14/2020 07:00	1	8
11/14/2020 08:00	1	8
11/14/2020 09:00	1	3
11/14/2020 10:00	1	1
11/14/2020 11:00	1	1
11/14/2020 12:00	1	1
11/14/2020 13:00	1	1
11/14/2020 14:00	1	1
11/14/2020 15:00	1	1
11/14/2020 16:00	1	1
11/14/2020 17:00	1	1
11/14/2020 18:00	1	1
11/14/2020 19:00	1	1
11/14/2020 20:00	1	1
11/14/2020 21:00	1	1
11/14/2020 22:00	1	1
11/14/2020 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/15/2020 00:00	1	1
11/15/2020 01:00	1	1
11/15/2020 02:00	1	1
11/15/2020 03:00	1	1
11/15/2020 04:00	1	1
11/15/2020 05:00	1	1
11/15/2020 06:00	1	1
11/15/2020 07:00	1	1
11/15/2020 08:00	1	1
11/15/2020 09:00	1	1
11/15/2020 10:00	1	1
11/15/2020 11:00	1	1
11/15/2020 12:00	1	1
11/15/2020 13:00	1	1
11/15/2020 14:00	1	1
11/15/2020 15:00	1	1
11/15/2020 16:00	1	1
11/15/2020 17:00	1	1
11/15/2020 18:00	1	1
11/15/2020 19:00	1	1
11/15/2020 20:00	1	1
11/15/2020 21:00	1	1
11/15/2020 22:00	1	1
11/15/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/16/2020 00:00	1	1
11/16/2020 01:00	1	1
11/16/2020 02:00	1	1
11/16/2020 03:00	1	1
11/16/2020 04:00	1	1
11/16/2020 05:00	1	1
11/16/2020 06:00	0	1
11/16/2020 07:00	0	1
11/16/2020 08:00	0	1
11/16/2020 09:00	0	1
11/16/2020 10:00	1	1
11/16/2020 11:00	1	1
11/16/2020 12:00	1	1
11/16/2020 13:00	1	1
11/16/2020 14:00	1	1
11/16/2020 15:00	1	1
11/16/2020 16:00	1	1
11/16/2020 17:00	1	1
11/16/2020 18:00	1	1
11/16/2020 19:00	1	1
11/16/2020 20:00	1	1
11/16/2020 21:00	1	1
11/16/2020 22:00	1	1
11/16/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	16.67	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/17/2020 00:00	1	1
11/17/2020 01:00	1	1
11/17/2020 02:00	1	1
11/17/2020 03:00	1	1
11/17/2020 04:00	1	1
11/17/2020 05:00	1	1
11/17/2020 06:00	1	1
11/17/2020 07:00	1	1
11/17/2020 08:00	1	1
11/17/2020 09:00	1	1
11/17/2020 10:00	1	1
11/17/2020 11:00	1	1
11/17/2020 12:00	1	1
11/17/2020 13:00	1	1
11/17/2020 14:00	1	1
11/17/2020 15:00	1	1
11/17/2020 16:00	1	1
11/17/2020 17:00	1	1
11/17/2020 18:00	1	1
11/17/2020 19:00	1	1
11/17/2020 20:00	1	1
11/17/2020 21:00	1	1
11/17/2020 22:00	1	1
11/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/18/2020 00:00	1	1
11/18/2020 01:00	1	1
11/18/2020 02:00	1	1
11/18/2020 03:00	1	1
11/18/2020 04:00	1	1
11/18/2020 05:00	1	1
11/18/2020 06:00	1	1
11/18/2020 07:00	1	1
11/18/2020 08:00	1	1
11/18/2020 09:00	1	1
11/18/2020 10:00	1	1
11/18/2020 11:00	1	1
11/18/2020 12:00	1	1
11/18/2020 13:00	1	1
11/18/2020 14:00	1	1
11/18/2020 15:00	1	1
11/18/2020 16:00	1	1
11/18/2020 17:00	1	1
11/18/2020 18:00	1	1
11/18/2020 19:00	1	1
11/18/2020 20:00	1	1
11/18/2020 21:00	1	1
11/18/2020 22:00	1	1
11/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/19/2020 00:00	1	1
11/19/2020 01:00	1	1
11/19/2020 02:00	1	1
11/19/2020 03:00	1	1
11/19/2020 04:00	1	1
11/19/2020 05:00	1	1
11/19/2020 06:00	1	1
11/19/2020 07:00	1	1
11/19/2020 08:00	1	1
11/19/2020 09:00	1	1
11/19/2020 10:00	1	1
11/19/2020 11:00	1	1
11/19/2020 12:00	1	1
11/19/2020 13:00	1	1
11/19/2020 14:00	1	1
11/19/2020 15:00	1	1
11/19/2020 16:00	1	1
11/19/2020 17:00	1	1
11/19/2020 18:00	1	1
11/19/2020 19:00	1	1
11/19/2020 20:00	1	1
11/19/2020 21:00	1	1
11/19/2020 22:00	1	1
11/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/20/2020 00:00	1	1
11/20/2020 01:00	1	1
11/20/2020 02:00	1	1
11/20/2020 03:00	1	1
11/20/2020 04:00	1	1
11/20/2020 05:00	1	1
11/20/2020 06:00	1	1
11/20/2020 07:00	1	1
11/20/2020 08:00	1	1
11/20/2020 09:00	1	1
11/20/2020 10:00	1	1
11/20/2020 11:00	1	1
11/20/2020 12:00	1	1
11/20/2020 13:00	1	1
11/20/2020 14:00	1	1
11/20/2020 15:00	1	1
11/20/2020 16:00	1	1
11/20/2020 17:00	1	1
11/20/2020 18:00	1	1
11/20/2020 19:00	1	1
11/20/2020 20:00	1	1
11/20/2020 21:00	1	1
11/20/2020 22:00	1	1
11/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/21/2020 00:00	1	1
11/21/2020 01:00	1	1
11/21/2020 02:00	1	1
11/21/2020 03:00	1	1
11/21/2020 04:00	1	1
11/21/2020 05:00	1	1
11/21/2020 06:00	1	1
11/21/2020 07:00	1	1
11/21/2020 08:00	1	1
11/21/2020 09:00	1	1
11/21/2020 10:00	1	1
11/21/2020 11:00	1	1
11/21/2020 12:00	1	1
11/21/2020 13:00	1	1
11/21/2020 14:00	1	1
11/21/2020 15:00	1	1
11/21/2020 16:00	1	1
11/21/2020 17:00	1	1
11/21/2020 18:00	1	1
11/21/2020 19:00	1	1
11/21/2020 20:00	1	1
11/21/2020 21:00	1	1
11/21/2020 22:00	1	1
11/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/22/2020 00:00	1	1
11/22/2020 01:00	1	1
11/22/2020 02:00	1	1
11/22/2020 03:00	1	1
11/22/2020 04:00	1	1
11/22/2020 05:00	1	1
11/22/2020 06:00	1	1
11/22/2020 07:00	1	1
11/22/2020 08:00	1	1
11/22/2020 09:00	1	1
11/22/2020 10:00	1	1
11/22/2020 11:00	1	1
11/22/2020 12:00	1	1
11/22/2020 13:00	1	1
11/22/2020 14:00	1	1
11/22/2020 15:00	1	1
11/22/2020 16:00	1	1
11/22/2020 17:00	1	1
11/22/2020 18:00	1	1
11/22/2020 19:00	1	1
11/22/2020 20:00	1	1
11/22/2020 21:00	1	1
11/22/2020 22:00	1	1
11/22/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/23/2020 00:00	1	1
11/23/2020 01:00	1	1
11/23/2020 02:00	1	1
11/23/2020 03:00	1	1
11/23/2020 04:00	1	1
11/23/2020 05:00	1	3
11/23/2020 06:00	1	5
11/23/2020 07:00	1	5
11/23/2020 08:00	1	4
11/23/2020 09:00	1	3
11/23/2020 10:00	1	1
11/23/2020 11:00	1	1
11/23/2020 12:00	1	1
11/23/2020 13:00	1	1
11/23/2020 14:00	1	1
11/23/2020 15:00	1	1
11/23/2020 16:00	1	1
11/23/2020 17:00	1	1
11/23/2020 18:00	1	1
11/23/2020 19:00	1	1
11/23/2020 20:00	1	1
11/23/2020 21:00	1	1
11/23/2020 22:00	1	1
11/23/2020 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	1	5
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/24/2020 00:00	1	1
11/24/2020 01:00	1	1
11/24/2020 02:00	1	1
11/24/2020 03:00	1	1
11/24/2020 04:00	1	1
11/24/2020 05:00	1	1
11/24/2020 06:00	1	1
11/24/2020 07:00	1	1
11/24/2020 08:00	1	1
11/24/2020 09:00	1	1
11/24/2020 10:00	1	1
11/24/2020 11:00	1	1
11/24/2020 12:00	1	1
11/24/2020 13:00	1	1
11/24/2020 14:00	1	1
11/24/2020 15:00	1	1
11/24/2020 16:00	1	1
11/24/2020 17:00	1	1
11/24/2020 18:00	1	1
11/24/2020 19:00	1	1
11/24/2020 20:00	1	1
11/24/2020 21:00	1	1
11/24/2020 22:00	1	1
11/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/25/2020 00:00	1	1
11/25/2020 01:00	1	1
11/25/2020 02:00	1	1
11/25/2020 03:00	1	1
11/25/2020 04:00	1	1
11/25/2020 05:00	1	1
11/25/2020 06:00	1	1
11/25/2020 07:00	1	1
11/25/2020 08:00	1	1
11/25/2020 09:00	1	1
11/25/2020 10:00	1	1
11/25/2020 11:00	1	1
11/25/2020 12:00	1	1
11/25/2020 13:00	1	1
11/25/2020 14:00	1	1
11/25/2020 15:00	1	1
11/25/2020 16:00	1	1
11/25/2020 17:00	1	1
11/25/2020 18:00	1	1
11/25/2020 19:00	1	1
11/25/2020 20:00	1	1
11/25/2020 21:00	1	1
11/25/2020 22:00	1	1
11/25/2020 23:00	2	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/26/2020 00:00	2	2
11/26/2020 01:00	2	2
11/26/2020 02:00	2	2
11/26/2020 03:00	2	2
11/26/2020 04:00	2	2
11/26/2020 05:00	2	2
11/26/2020 06:00	2	2
11/26/2020 07:00	2	2
11/26/2020 08:00	2	2
11/26/2020 09:00	2	2
11/26/2020 10:00	2	2
11/26/2020 11:00	2	2
11/26/2020 12:00	2	2
11/26/2020 13:00	2	2
11/26/2020 14:00	2	2
11/26/2020 15:00	2	2
11/26/2020 16:00	2	2
11/26/2020 17:00	2	2
11/26/2020 18:00	2	2
11/26/2020 19:00	2	2
11/26/2020 20:00	2	2
11/26/2020 21:00	2	2
11/26/2020 22:00	2	2
11/26/2020 23:00	17	2
Average/Sum#:	3	2
Minimum:	2	2
Maximum:	17	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/27/2020 00:00	22	2
11/27/2020 01:00	25	2
11/27/2020 02:00	24	2
11/27/2020 03:00	9	2
11/27/2020 04:00	4	14
11/27/2020 05:00	1	17
11/27/2020 06:00	1	17
11/27/2020 07:00	1	16
11/27/2020 08:00	1	3
11/27/2020 09:00	1	1
11/27/2020 10:00	1	1
11/27/2020 11:00	1	1
11/27/2020 12:00	1	1
11/27/2020 13:00	1	1
11/27/2020 14:00	1	1
11/27/2020 15:00	1	1
11/27/2020 16:00	1	1
11/27/2020 17:00	1	1
11/27/2020 18:00	1	1
11/27/2020 19:00	1	1
11/27/2020 20:00	1	1
11/27/2020 21:00	1	1
11/27/2020 22:00	1	1
11/27/2020 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	25	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/28/2020 00:00	1	1
11/28/2020 01:00	1	1
11/28/2020 02:00	1	1
11/28/2020 03:00	1	1
11/28/2020 04:00	1	1
11/28/2020 05:00	1	1
11/28/2020 06:00	1	1
11/28/2020 07:00	1	1
11/28/2020 08:00	1	1
11/28/2020 09:00	1	1
11/28/2020 10:00	1	1
11/28/2020 11:00	1	1
11/28/2020 12:00	1	1
11/28/2020 13:00	1	1
11/28/2020 14:00	1	1
11/28/2020 15:00	1	1
11/28/2020 16:00	1	1
11/28/2020 17:00	1	1
11/28/2020 18:00	1	1
11/28/2020 19:00	1	1
11/28/2020 20:00	1	1
11/28/2020 21:00	1	1
11/28/2020 22:00	1	1
11/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/29/2020 00:00	1	1
11/29/2020 01:00	1	1
11/29/2020 02:00	1	1
11/29/2020 03:00	1	1
11/29/2020 04:00	1	1
11/29/2020 05:00	1	1
11/29/2020 06:00	1	1
11/29/2020 07:00	1	1
11/29/2020 08:00	1	1
11/29/2020 09:00	1	1
11/29/2020 10:00	1	1
11/29/2020 11:00	1	1
11/29/2020 12:00	1	1
11/29/2020 13:00	1	1
11/29/2020 14:00	1	1
11/29/2020 15:00	1	1
11/29/2020 16:00	1	1
11/29/2020 17:00	1	1
11/29/2020 18:00	1	1
11/29/2020 19:00	1	1
11/29/2020 20:00	1	1
11/29/2020 21:00	1	1
11/29/2020 22:00	1	1
11/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/30/2020 00:00	1	1
11/30/2020 01:00	1	1
11/30/2020 02:00	1	1
11/30/2020 03:00	1	1
11/30/2020 04:00	1	1
11/30/2020 05:00	1	1
11/30/2020 06:00	1	1
11/30/2020 07:00	1	1
11/30/2020 08:00	1	1
11/30/2020 09:00	1	1
11/30/2020 10:00	1	1
11/30/2020 11:00	1	1
11/30/2020 12:00	1	1
11/30/2020 13:00	1	1
11/30/2020 14:00	1	1
11/30/2020 15:00	1	1
11/30/2020 16:00	1	1
11/30/2020 17:00	1	1
11/30/2020 18:00	1	1
11/30/2020 19:00	1	1
11/30/2020 20:00	1	1
11/30/2020 21:00	1	1
11/30/2020 22:00	1	1
11/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/01/2020 00:00	1	1
12/01/2020 01:00	1	1
12/01/2020 02:00	1	1
12/01/2020 03:00	1	1
12/01/2020 04:00	1	1
12/01/2020 05:00	1	1
12/01/2020 06:00	1	1
12/01/2020 07:00	1	1
12/01/2020 08:00	1	1
12/01/2020 09:00	1	1
12/01/2020 10:00	1	1
12/01/2020 11:00	1	1
12/01/2020 12:00	1	1
12/01/2020 13:00	1	1
12/01/2020 14:00	1	1
12/01/2020 15:00	1	1
12/01/2020 16:00	1	1
12/01/2020 17:00	1	1
12/01/2020 18:00	1	1
12/01/2020 19:00	1	1
12/01/2020 20:00	1	1
12/01/2020 21:00	1	1
12/01/2020 22:00	1	1
12/01/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/02/2020 00:00	1	1
12/02/2020 01:00	1	1
12/02/2020 02:00	1	1
12/02/2020 03:00	1	1
12/02/2020 04:00	1	1
12/02/2020 05:00	1	1
12/02/2020 06:00	1	1
12/02/2020 07:00	1	1
12/02/2020 08:00	1	1
12/02/2020 09:00	1	1
12/02/2020 10:00	1	1
12/02/2020 11:00	1	1
12/02/2020 12:00	1	1
12/02/2020 13:00	1	1
12/02/2020 14:00	1	1
12/02/2020 15:00	1	1
12/02/2020 16:00	1	1
12/02/2020 17:00	1	1
12/02/2020 18:00	1	1
12/02/2020 19:00	1	1
12/02/2020 20:00	1	1
12/02/2020 21:00	1	1
12/02/2020 22:00	1	1
12/02/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/03/2020 00:00	1	1
12/03/2020 01:00	1	1
12/03/2020 02:00	1	1
12/03/2020 03:00	1	1
12/03/2020 04:00	1	1
12/03/2020 05:00	1	1
12/03/2020 06:00	1	1
12/03/2020 07:00	1	1
12/03/2020 08:00	1	1
12/03/2020 09:00	1	1
12/03/2020 10:00	1	1
12/03/2020 11:00	1	1
12/03/2020 12:00	1	1
12/03/2020 13:00	1	1
12/03/2020 14:00	1	1
12/03/2020 15:00	1	1
12/03/2020 16:00	1	1
12/03/2020 17:00	1	1
12/03/2020 18:00	1	1
12/03/2020 19:00	1	1
12/03/2020 20:00	1	1
12/03/2020 21:00	1	1
12/03/2020 22:00	1	1
12/03/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/04/2020 00:00	1	1
12/04/2020 01:00	1	1
12/04/2020 02:00	1	1
12/04/2020 03:00	1	1
12/04/2020 04:00	1	1
12/04/2020 05:00	1	1
12/04/2020 06:00	1	1
12/04/2020 07:00	1	1
12/04/2020 08:00	1	1
12/04/2020 09:00	1	1
12/04/2020 10:00	1	1
12/04/2020 11:00	1	1
12/04/2020 12:00	1	1
12/04/2020 13:00	1	1
12/04/2020 14:00	1	1
12/04/2020 15:00	1	1
12/04/2020 16:00	1	1
12/04/2020 17:00	1	1
12/04/2020 18:00	1	1
12/04/2020 19:00	1	1
12/04/2020 20:00	1	1
12/04/2020 21:00	1	1
12/04/2020 22:00	1	1
12/04/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/05/2020 00:00	1	1
12/05/2020 01:00	1	1
12/05/2020 02:00	1	1
12/05/2020 03:00	1	1
12/05/2020 04:00	1	1
12/05/2020 05:00	1	1
12/05/2020 06:00	1	1
12/05/2020 07:00	1	1
12/05/2020 08:00	1	1
12/05/2020 09:00	1	1
12/05/2020 10:00	1	1
12/05/2020 11:00	1	1
12/05/2020 12:00	1	1
12/05/2020 13:00	1	1
12/05/2020 14:00	1	1
12/05/2020 15:00	1	1
12/05/2020 16:00	1	1
12/05/2020 17:00	1	1
12/05/2020 18:00	1	1
12/05/2020 19:00	1	1
12/05/2020 20:00	1	1
12/05/2020 21:00	1	1
12/05/2020 22:00	1	1
12/05/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/06/2020 00:00	1	1
12/06/2020 01:00	1	1
12/06/2020 02:00	1	1
12/06/2020 03:00	1	1
12/06/2020 04:00	1	1
12/06/2020 05:00	1	1
12/06/2020 06:00	1	1
12/06/2020 07:00	1	1
12/06/2020 08:00	1	1
12/06/2020 09:00	1	1
12/06/2020 10:00	1	1
12/06/2020 11:00	1	1
12/06/2020 12:00	1	1
12/06/2020 13:00	1	1
12/06/2020 14:00	1	1
12/06/2020 15:00	1	1
12/06/2020 16:00	1	1
12/06/2020 17:00	1	1
12/06/2020 18:00	1	1
12/06/2020 19:00	1	1
12/06/2020 20:00	1	1
12/06/2020 21:00	1	1
12/06/2020 22:00	1	1
12/06/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/07/2020 00:00	1	1
12/07/2020 01:00	1	1
12/07/2020 02:00	1	1
12/07/2020 03:00	1	1
12/07/2020 04:00	1	1
12/07/2020 05:00	1	1
12/07/2020 06:00	1	1
12/07/2020 07:00	1	1
12/07/2020 08:00	1	1
12/07/2020 09:00	1	1
12/07/2020 10:00	1	1
12/07/2020 11:00	1	1
12/07/2020 12:00	1	1
12/07/2020 13:00	1	1
12/07/2020 14:00	1	1
12/07/2020 15:00	1	1
12/07/2020 16:00	1	1
12/07/2020 17:00	1	1
12/07/2020 18:00	1	1
12/07/2020 19:00	1	1
12/07/2020 20:00	1	1
12/07/2020 21:00	1	1
12/07/2020 22:00	1	1
12/07/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/08/2020 00:00	1	1
12/08/2020 01:00	1	1
12/08/2020 02:00	1	1
12/08/2020 03:00	1	1
12/08/2020 04:00	1	1
12/08/2020 05:00	1	1
12/08/2020 06:00	1	1
12/08/2020 07:00	1	1
12/08/2020 08:00	1	1
12/08/2020 09:00	1	1
12/08/2020 10:00	1	1
12/08/2020 11:00	1	1
12/08/2020 12:00	1	1
12/08/2020 13:00	1	1
12/08/2020 14:00	1	1
12/08/2020 15:00	1	1
12/08/2020 16:00	1	1
12/08/2020 17:00	1	1
12/08/2020 18:00	1	1
12/08/2020 19:00	1	1
12/08/2020 20:00	1	1
12/08/2020 21:00	1	1
12/08/2020 22:00	1	1
12/08/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/09/2020 00:00	1	1
12/09/2020 01:00	1	1
12/09/2020 02:00	1	1
12/09/2020 03:00	1	1
12/09/2020 04:00	1	1
12/09/2020 05:00	1	1
12/09/2020 06:00	1	1
12/09/2020 07:00	1	1
12/09/2020 08:00	1	1
12/09/2020 09:00	1	1
12/09/2020 10:00	1	1
12/09/2020 11:00	1	1
12/09/2020 12:00	1	1
12/09/2020 13:00	1	1
12/09/2020 14:00	1	1
12/09/2020 15:00	1	1
12/09/2020 16:00	1	1
12/09/2020 17:00	1	1
12/09/2020 18:00	1	1
12/09/2020 19:00	1	1
12/09/2020 20:00	1	1
12/09/2020 21:00	1	1
12/09/2020 22:00	1	1
12/09/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/10/2020 00:00	1	1
12/10/2020 01:00	1	1
12/10/2020 02:00	1	1
12/10/2020 03:00	1	1
12/10/2020 04:00	1	1
12/10/2020 05:00	1	1
12/10/2020 06:00	1	1
12/10/2020 07:00	1	1
12/10/2020 08:00	1	1
12/10/2020 09:00	1	1
12/10/2020 10:00	1	1
12/10/2020 11:00	1	1
12/10/2020 12:00	1	1
12/10/2020 13:00	1	1
12/10/2020 14:00	1	1
12/10/2020 15:00	1	1
12/10/2020 16:00	1	1
12/10/2020 17:00	1	1
12/10/2020 18:00	1	1
12/10/2020 19:00	1	1
12/10/2020 20:00	1	1
12/10/2020 21:00	1	1
12/10/2020 22:00	1	1
12/10/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/11/2020 00:00	1	1
12/11/2020 01:00	1	1
12/11/2020 02:00	1	1
12/11/2020 03:00	1	1
12/11/2020 04:00	1	1
12/11/2020 05:00	1	1
12/11/2020 06:00	1	1
12/11/2020 07:00	1	1
12/11/2020 08:00	1	1
12/11/2020 09:00	1	1
12/11/2020 10:00	1	1
12/11/2020 11:00	1	1
12/11/2020 12:00	1	1
12/11/2020 13:00	1	1
12/11/2020 14:00	1	1
12/11/2020 15:00	1	1
12/11/2020 16:00	1	1
12/11/2020 17:00	1	1
12/11/2020 18:00	1	1
12/11/2020 19:00	1	1
12/11/2020 20:00	1	1
12/11/2020 21:00	1	1
12/11/2020 22:00	1	1
12/11/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/12/2020 00:00	1	1
12/12/2020 01:00	1	1
12/12/2020 02:00	1	1
12/12/2020 03:00	1	1
12/12/2020 04:00	1	1
12/12/2020 05:00	1	1
12/12/2020 06:00	1	1
12/12/2020 07:00	1	1
12/12/2020 08:00	1	1
12/12/2020 09:00	1	1
12/12/2020 10:00	1	1
12/12/2020 11:00	1	1
12/12/2020 12:00	1	1
12/12/2020 13:00	1	1
12/12/2020 14:00	1	1
12/12/2020 15:00	1	1
12/12/2020 16:00	1	1
12/12/2020 17:00	1	1
12/12/2020 18:00	1	1
12/12/2020 19:00	1	1
12/12/2020 20:00	1	1
12/12/2020 21:00	1	1
12/12/2020 22:00	1	1
12/12/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/13/2020 00:00	1	1
12/13/2020 01:00	1	1
12/13/2020 02:00	1	1
12/13/2020 03:00	1	1
12/13/2020 04:00	1	1
12/13/2020 05:00	1	1
12/13/2020 06:00	1	1
12/13/2020 07:00	1	1
12/13/2020 08:00	1	1
12/13/2020 09:00	1	1
12/13/2020 10:00	1	1
12/13/2020 11:00	1	1
12/13/2020 12:00	1	1
12/13/2020 13:00	1	1
12/13/2020 14:00	1	1
12/13/2020 15:00	1	1
12/13/2020 16:00	1	1
12/13/2020 17:00	1	1
12/13/2020 18:00	1	1
12/13/2020 19:00	1	1
12/13/2020 20:00	1	1
12/13/2020 21:00	1	1
12/13/2020 22:00	1	1
12/13/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/14/2020 00:00	2	3
12/14/2020 01:00	2	3
12/14/2020 02:00	2	3
12/14/2020 03:00	2	3
12/14/2020 04:00	2	3
12/14/2020 05:00	2	8
12/14/2020 06:00	2	10
12/14/2020 07:00	2	10
12/14/2020 08:00	2	8
12/14/2020 09:00	2	2
12/14/2020 10:00	2	1
12/14/2020 11:00	2	1
12/14/2020 12:00	2	1
12/14/2020 13:00	2	1
12/14/2020 14:00	2	1
12/14/2020 15:00	2	0
12/14/2020 16:00	2	0
12/14/2020 17:00	2	0
12/14/2020 18:00	2	1
12/14/2020 19:00	2	1
12/14/2020 20:00	2	1
12/14/2020 21:00	2	1
12/14/2020 22:00	2	1
12/14/2020 23:00	2	1
Average/Sum#:	2	3
Minimum:	2	1
Maximum:	2	10
%SI	0.00	12.50

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/15/2020 00:00	2	1
12/15/2020 01:00	2	1
12/15/2020 02:00	2	1
12/15/2020 03:00	2	1
12/15/2020 04:00	2	1
12/15/2020 05:00	2	1
12/15/2020 06:00	2	1
12/15/2020 07:00	2	1
12/15/2020 08:00	2	1
12/15/2020 09:00	2	1
12/15/2020 10:00	2	1
12/15/2020 11:00	2	1
12/15/2020 12:00	2	1
12/15/2020 13:00	2	1
12/15/2020 14:00	2	1
12/15/2020 15:00	2	1
12/15/2020 16:00	2	1
12/15/2020 17:00	2	1
12/15/2020 18:00	2	1
12/15/2020 19:00	2	1
12/15/2020 20:00	2	1
12/15/2020 21:00	2	1
12/15/2020 22:00	2	1
12/15/2020 23:00	2	1
Average/Sum#:	2	1
Minimum:	2	1
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/16/2020 00:00	2	1
12/16/2020 01:00	2	1
12/16/2020 02:00	2	1
12/16/2020 03:00	2	1
12/16/2020 04:00	2	1
12/16/2020 05:00	2	1
12/16/2020 06:00	2	1
12/16/2020 07:00	2	1
12/16/2020 08:00	2	1
12/16/2020 09:00	2	1
12/16/2020 10:00	2	1
12/16/2020 11:00	2	1
12/16/2020 12:00	2	1
12/16/2020 13:00	2	1
12/16/2020 14:00	2	1
12/16/2020 15:00	15	1
12/16/2020 16:00	22	1
12/16/2020 17:00	22	1
12/16/2020 18:00	21	1
12/16/2020 19:00	8	1
12/16/2020 20:00	1	1
12/16/2020 21:00	1	1
12/16/2020 22:00	1	1
12/16/2020 23:00	1	1
Average/Sum#:	5	1
Minimum:	1	1
Maximum:	22	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/17/2020 00:00	1	1
12/17/2020 01:00	1	1
12/17/2020 02:00	1	1
12/17/2020 03:00	1	1
12/17/2020 04:00	1	1
12/17/2020 05:00	1	1
12/17/2020 06:00	1	1
12/17/2020 07:00	1	1
12/17/2020 08:00	1	1
12/17/2020 09:00	1	1
12/17/2020 10:00	1	1
12/17/2020 11:00	1	1
12/17/2020 12:00	1	1
12/17/2020 13:00	1	1
12/17/2020 14:00	1	1
12/17/2020 15:00	1	0
12/17/2020 16:00	1	1
12/17/2020 17:00	1	1
12/17/2020 18:00	1	1
12/17/2020 19:00	1	1
12/17/2020 20:00	1	1
12/17/2020 21:00	1	1
12/17/2020 22:00	1	1
12/17/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/18/2020 00:00	1	1
12/18/2020 01:00	1	1
12/18/2020 02:00	1	1
12/18/2020 03:00	1	1
12/18/2020 04:00	1	1
12/18/2020 05:00	1	1
12/18/2020 06:00	1	1
12/18/2020 07:00	1	1
12/18/2020 08:00	1	1
12/18/2020 09:00	1	1
12/18/2020 10:00	1	1
12/18/2020 11:00	1	1
12/18/2020 12:00	1	0
12/18/2020 13:00	1	0
12/18/2020 14:00	1	0
12/18/2020 15:00	1	0
12/18/2020 16:00	1	1
12/18/2020 17:00	1	1
12/18/2020 18:00	1	1
12/18/2020 19:00	1	1
12/18/2020 20:00	1	1
12/18/2020 21:00	1	1
12/18/2020 22:00	1	1
12/18/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/19/2020 00:00	1	1
12/19/2020 01:00	1	1
12/19/2020 02:00	1	1
12/19/2020 03:00	1	1
12/19/2020 04:00	1	1
12/19/2020 05:00	1	1
12/19/2020 06:00	1	1
12/19/2020 07:00	1	1
12/19/2020 08:00	1	1
12/19/2020 09:00	1	1
12/19/2020 10:00	1	0
12/19/2020 11:00	1	0
12/19/2020 12:00	1	0
12/19/2020 13:00	1	0
12/19/2020 14:00	1	1
12/19/2020 15:00	1	1
12/19/2020 16:00	1	1
12/19/2020 17:00	1	1
12/19/2020 18:00	1	1
12/19/2020 19:00	1	1
12/19/2020 20:00	1	1
12/19/2020 21:00	1	1
12/19/2020 22:00	1	1
12/19/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/20/2020 00:00	1	1
12/20/2020 01:00	1	1
12/20/2020 02:00	1	1
12/20/2020 03:00	1	1
12/20/2020 04:00	1	0
12/20/2020 05:00	1	0
12/20/2020 06:00	1	1
12/20/2020 07:00	1	1
12/20/2020 08:00	1	1
12/20/2020 09:00	1	0
12/20/2020 10:00	1	0
12/20/2020 11:00	1	0
12/20/2020 12:00	1	0
12/20/2020 13:00	1	1
12/20/2020 14:00	1	0
12/20/2020 15:00	1	1
12/20/2020 16:00	1	1
12/20/2020 17:00	1	1
12/20/2020 18:00	1	1
12/20/2020 19:00	1	1
12/20/2020 20:00	1	1
12/20/2020 21:00	1	1
12/20/2020 22:00	1	1
12/20/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/21/2020 00:00	1	1
12/21/2020 01:00	1	1
12/21/2020 02:00	1	1
12/21/2020 03:00	1	1
12/21/2020 04:00	1	1
12/21/2020 05:00	1	1
12/21/2020 06:00	1	1
12/21/2020 07:00	1	1
12/21/2020 08:00	1	1
12/21/2020 09:00	1	1
12/21/2020 10:00	1	1
12/21/2020 11:00	1	1
12/21/2020 12:00	1	0
12/21/2020 13:00	1	0
12/21/2020 14:00	1	1
12/21/2020 15:00	1	1
12/21/2020 16:00	1	1
12/21/2020 17:00	1	1
12/21/2020 18:00	1	1
12/21/2020 19:00	1	1
12/21/2020 20:00	1	1
12/21/2020 21:00	1	1
12/21/2020 22:00	1	1
12/21/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/22/2020 00:00	1	1
12/22/2020 01:00	1	1
12/22/2020 02:00	1	1
12/22/2020 03:00	1	1
12/22/2020 04:00	1	0
12/22/2020 05:00	1	1
12/22/2020 06:00	1	1
12/22/2020 07:00	1	1
12/22/2020 08:00	1	1
12/22/2020 09:00	1	1
12/22/2020 10:00	1	1
12/22/2020 11:00	1	1
12/22/2020 12:00	1	0
12/22/2020 13:00	1	0
12/22/2020 14:00	1	0
12/22/2020 15:00	1	1
12/22/2020 16:00	1	1
12/22/2020 17:00	1	1
12/22/2020 18:00	1	1
12/22/2020 19:00	1	1
12/22/2020 20:00	1	1
12/22/2020 21:00	1	1
12/22/2020 22:00	1	1
12/22/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/23/2020 00:00	1	1
12/23/2020 01:00	1	1
12/23/2020 02:00	1	1
12/23/2020 03:00	1	1
12/23/2020 04:00	1	1
12/23/2020 05:00	1	1
12/23/2020 06:00	1	1
12/23/2020 07:00	1	1
12/23/2020 08:00	1	1
12/23/2020 09:00	1	1
12/23/2020 10:00	1	1
12/23/2020 11:00	1	1
12/23/2020 12:00	1	1
12/23/2020 13:00	1	0
12/23/2020 14:00	1	0
12/23/2020 15:00	1	1
12/23/2020 16:00	1	1
12/23/2020 17:00	1	1
12/23/2020 18:00	1	1
12/23/2020 19:00	1	1
12/23/2020 20:00	1	1
12/23/2020 21:00	1	1
12/23/2020 22:00	1	1
12/23/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/24/2020 00:00	1	1
12/24/2020 01:00	1	1
12/24/2020 02:00	1	1
12/24/2020 03:00	1	1
12/24/2020 04:00	1	1
12/24/2020 05:00	1	1
12/24/2020 06:00	1	1
12/24/2020 07:00	1	1
12/24/2020 08:00	1	1
12/24/2020 09:00	1	1
12/24/2020 10:00	1	1
12/24/2020 11:00	1	1
12/24/2020 12:00	1	1
12/24/2020 13:00	1	1
12/24/2020 14:00	1	1
12/24/2020 15:00	1	1
12/24/2020 16:00	1	1
12/24/2020 17:00	1	1
12/24/2020 18:00	1	1
12/24/2020 19:00	1	1
12/24/2020 20:00	1	1
12/24/2020 21:00	1	1
12/24/2020 22:00	1	1
12/24/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/25/2020 00:00	1	1
12/25/2020 01:00	1	1
12/25/2020 02:00	1	1
12/25/2020 03:00	1	1
12/25/2020 04:00	1	1
12/25/2020 05:00	1	1
12/25/2020 06:00	1	1
12/25/2020 07:00	1	1
12/25/2020 08:00	1	1
12/25/2020 09:00	1	1
12/25/2020 10:00	1	0
12/25/2020 11:00	1	0
12/25/2020 12:00	1	1
12/25/2020 13:00	1	1
12/25/2020 14:00	1	1
12/25/2020 15:00	1	1
12/25/2020 16:00	1	1
12/25/2020 17:00	1	1
12/25/2020 18:00	1	1
12/25/2020 19:00	1	1
12/25/2020 20:00	1	1
12/25/2020 21:00	1	1
12/25/2020 22:00	1	1
12/25/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/26/2020 00:00	1	1
12/26/2020 01:00	1	1
12/26/2020 02:00	1	1
12/26/2020 03:00	1	1
12/26/2020 04:00	1	1
12/26/2020 05:00	1	1
12/26/2020 06:00	1	1
12/26/2020 07:00	1	1
12/26/2020 08:00	1	1
12/26/2020 09:00	1	1
12/26/2020 10:00	1	0
12/26/2020 11:00	1	0
12/26/2020 12:00	1	0
12/26/2020 13:00	1	0
12/26/2020 14:00	1	1
12/26/2020 15:00	1	1
12/26/2020 16:00	1	1
12/26/2020 17:00	1	1
12/26/2020 18:00	1	1
12/26/2020 19:00	1	1
12/26/2020 20:00	1	1
12/26/2020 21:00	1	1
12/26/2020 22:00	1	1
12/26/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/27/2020 00:00	1	1
12/27/2020 01:00	1	1
12/27/2020 02:00	1	1
12/27/2020 03:00	1	1
12/27/2020 04:00	1	1
12/27/2020 05:00	1	1
12/27/2020 06:00	1	1
12/27/2020 07:00	1	1
12/27/2020 08:00	1	1
12/27/2020 09:00	1	1
12/27/2020 10:00	1	0
12/27/2020 11:00	1	0
12/27/2020 12:00	1	0
12/27/2020 13:00	1	0
12/27/2020 14:00	1	1
12/27/2020 15:00	1	1
12/27/2020 16:00	1	1
12/27/2020 17:00	1	1
12/27/2020 18:00	1	1
12/27/2020 19:00	1	1
12/27/2020 20:00	1	1
12/27/2020 21:00	1	1
12/27/2020 22:00	1	1
12/27/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/28/2020 00:00	1	1
12/28/2020 01:00	1	1
12/28/2020 02:00	1	1
12/28/2020 03:00	1	1
12/28/2020 04:00	1	1
12/28/2020 05:00	1	1
12/28/2020 06:00	1	1
12/28/2020 07:00	1	1
12/28/2020 08:00	1	1
12/28/2020 09:00	1	1
12/28/2020 10:00	1	1
12/28/2020 11:00	1	1
12/28/2020 12:00	1	1
12/28/2020 13:00	1	1
12/28/2020 14:00	1	1
12/28/2020 15:00	1	1
12/28/2020 16:00	1	1
12/28/2020 17:00	1	1
12/28/2020 18:00	1	1
12/28/2020 19:00	1	1
12/28/2020 20:00	1	1
12/28/2020 21:00	1	1
12/28/2020 22:00	1	1
12/28/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/29/2020 00:00	1	1
12/29/2020 01:00	1	1
12/29/2020 02:00	1	1
12/29/2020 03:00	1	1
12/29/2020 04:00	1	1
12/29/2020 05:00	1	1
12/29/2020 06:00	1	1
12/29/2020 07:00	1	1
12/29/2020 08:00	1	1
12/29/2020 09:00	1	1
12/29/2020 10:00	1	1
12/29/2020 11:00	1	1
12/29/2020 12:00	1	1
12/29/2020 13:00	1	1
12/29/2020 14:00	1	1
12/29/2020 15:00	1	1
12/29/2020 16:00	1	1
12/29/2020 17:00	1	1
12/29/2020 18:00	1	1
12/29/2020 19:00	1	1
12/29/2020 20:00	1	1
12/29/2020 21:00	1	1
12/29/2020 22:00	1	1
12/29/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/30/2020 00:00	1	1
12/30/2020 01:00	1	1
12/30/2020 02:00	1	1
12/30/2020 03:00	1	1
12/30/2020 04:00	1	1
12/30/2020 05:00	1	1
12/30/2020 06:00	1	1
12/30/2020 07:00	1	1
12/30/2020 08:00	1	1
12/30/2020 09:00	1	1
12/30/2020 10:00	1	1
12/30/2020 11:00	1	1
12/30/2020 12:00	1	1
12/30/2020 13:00	1	1
12/30/2020 14:00	1	1
12/30/2020 15:00	1	1
12/30/2020 16:00	1	1
12/30/2020 17:00	1	1
12/30/2020 18:00	1	1
12/30/2020 19:00	1	1
12/30/2020 20:00	1	1
12/30/2020 21:00	1	1
12/30/2020 22:00	1	1
12/30/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:02 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/31/2020 00:00	1	1
12/31/2020 01:00	1	1
12/31/2020 02:00	1	1
12/31/2020 03:00	1	1
12/31/2020 04:00	1	1
12/31/2020 05:00	1	1
12/31/2020 06:00	1	1
12/31/2020 07:00	1	1
12/31/2020 08:00	1	1
12/31/2020 09:00	1	0
12/31/2020 10:00	1	0
12/31/2020 11:00	1	1
12/31/2020 12:00	1	1
12/31/2020 13:00	1	1
12/31/2020 14:00	1	1
12/31/2020 15:00	1	1
12/31/2020 16:00	1	1
12/31/2020 17:00	1	1
12/31/2020 18:00	1	1
12/31/2020 19:00	1	1
12/31/2020 20:00	1	1
12/31/2020 21:00	1	1
12/31/2020 22:00	1	1
12/31/2020 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:09 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 87.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 5.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**87.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:08 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:13 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,989.00 Hour(s)
Operating time for CMS: 1,989.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:14 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,989.00 Hour(s)
Operating time for CMS: 1,989.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:14 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,989.00 Hour(s)
Operating time for CMS: 1,989.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	4
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:14 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,989.00 Hour(s)
Operating time for CMS: 1,989.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	4
e. Unknown causes	0
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:15 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,060.00 Hour(s)
Operating time for CMS: 2,060.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:15 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,060.00 Hour(s)
Operating time for CMS: 2,060.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:16 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,060.00 Hour(s)
Operating time for CMS: 2,060.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:16 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 2,060.00 Hour(s)
Operating time for CMS: 2,060.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	2
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.10
4. Total Availability as a percentage of operating time	99.90

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:18 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:18 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:19 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:19 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:20 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:21 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:21 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:22 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:22 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,989.00 Hour(s)
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/14/2020 07:00	10/14/2020 07:59	1	3 - Quality assurance calibration	10 - Performed Linearity
2	11/07/2020 21:00	11/07/2020 21:59	1	4 - Other known causes	12 - Faluty Equipment, Equipment Replaced

Total Operating Time:	**1,989.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.90 %**
Percent Monitor Downtime:	**0.10 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	50.00
3	Reason	Quality assurance calibration	1	50.00
12	Action	Faluty Equipment, Equipment Replaced	1	50.00
10	Action	Performed Linearity	1	50.00

Invalid Data Report

CT1 - Stack NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:23 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,989.00 Hour(s)
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/14/2020 07:00	10/14/2020 07:59	1	3 - Quality assurance calibration	10 - Performed Linearity
2	11/07/2020 21:00	11/07/2020 21:59	1	4 - Other known causes	12 - Faluty Equipment, Equipment Replaced
3	11/16/2020 05:00	11/16/2020 07:59	3	4 - Other known causes	12 - Faluty Equipment, Equipment Replaced

Total Operating Time:	**1,989.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**99.75 %**
Percent Monitor Downtime:	**0.25 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	4	80.00
3	Reason	Quality assurance calibration	1	20.00
12	Action	Faluty Equipment, Equipment Replaced	4	80.00
10	Action	Performed Linearity	1	20.00

Invalid Data Report

CT2 - Stack CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:24 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 2,060.00 Hour(s)
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/14/2020 14:00	12/14/2020 15:59	2	4 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	**2,060.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.90 %**
Percent Monitor Downtime:	**0.10 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	2	100.00
8	Action	Quarterly Maintenance	2	100.00

Invalid Data Report

CT2 - Stack NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/11/2021 08:24 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 2,060.00 Hour(s)
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	12/14/2020 14:00	12/14/2020 15:59	2	4 - Other known causes	8 - Quarterly Maintenance

Total Operating Time:	**2,060.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.90 %**
Percent Monitor Downtime:	**0.10 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	2	100.00
8	Action	Quarterly Maintenance	2	100.00

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2020 00:00	0.6	13.9	1,632.6	0.6	1.1	1	1	0
10/01/2020 01:00	0.2	13.3	1,798.6	0.4	1.3	1	1	1
10/01/2020 02:00	-0.1	12.5	1,987.6	0.1	1.4	1	1	1
10/01/2020 03:00	0.1	12.3	1,996.0	0.2	1.4	1	1	1
10/01/2020 04:00	0.6	13.9	1,666.5	0.6	1.2	1	1	0
10/01/2020 05:00	-0.7	13.0	1,822.9	-0.4	1.3	1	1	1
10/01/2020 06:00	-0.8	12.3	2,073.1	-0.4	1.5	1	1	1
10/01/2020 07:00	-0.5	13.1	1,809.7	-0.2	1.3	1	1	1
10/01/2020 08:00	0.6	13.9	1,560.8	0.6	1.1	1	1	0
10/01/2020 09:00	0.6	14.1	1,327.1	0.6	0.9	1	1	0
10/01/2020 10:00	0.7	14.0	1,516.1	0.7	1.1	1	1	1
10/01/2020 11:00	-0.7	12.3	2,062.7	-0.2	1.4	1	1	1
10/01/2020 12:00	-0.5	11.8	2,142.6	-0.1	1.5	1	1	1
10/01/2020 13:00	-0.4	11.6	2,180.8	0.1	1.5	1	1	1
10/01/2020 14:00	-0.4	11.5	2,191.1	0.1	1.5	1	1	1
10/01/2020 15:00	-0.4	11.6	2,163.3	0.1	1.5	1	1	1
10/01/2020 16:00	-0.5	11.7	2,144.3	-0.1	1.5	1	1	1
10/01/2020 17:00	-0.5	11.7	2,138.3	-0.1	1.5	1	1	1
10/01/2020 18:00	-0.7	11.9	2,110.4	-0.2	1.5	1	1	1
10/01/2020 19:00	-0.5	11.9	2,114.7	-0.1	1.5	1	1	1
10/01/2020 20:00	-0.5	11.9	2,113.2	-0.1	1.5	1	1	1
10/01/2020 21:00	-0.5	11.9	2,119.0	-0.1	1.5	1	1	1
10/01/2020 22:00	-0.7	12.1	2,094.3	-0.2	1.5	1	1	1
10/01/2020 23:00	-0.7	12.4	2,011.9	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	12.5	1,949.1	0.1	1.4	24 #	24 #	20 #
Minimum:	-0.8	11.5	1,327.1	-0.4	0.9	1	1	0
Maximum:	0.7	14.1	2,191.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2020 00:00	0.6	13.9	1,589.6	0.6	1.1	1	1	0
10/02/2020 01:00	0.6	13.9	1,707.3	0.6	1.2	1	1	0
10/02/2020 02:00	0.5	13.9	1,553.1	0.5	1.1	1	1	0
10/02/2020 03:00	0.5	13.9	1,596.2	0.5	1.1	1	1	0
10/02/2020 04:00	-0.1	13.6	1,682.9	0.1	1.2	1	1	1
10/02/2020 05:00	-0.8	12.3	2,058.4	-0.4	1.4	1	1	1
10/02/2020 06:00	-0.8	12.5	2,014.7	-0.4	1.4	1	1	1
10/02/2020 07:00	0.6	13.8	1,771.1	0.6	1.2	1	1	0
10/02/2020 08:00	0.5	13.9	1,477.5	0.5	1.0	1	1	0
10/02/2020 09:00	0.6	14.0	1,595.2	0.6	1.1	1	1	0
10/02/2020 10:00	0.6	14.0	1,627.9	0.6	1.1	1	1	0
10/02/2020 11:00	0.4	13.6	1,694.5	0.4	1.2	1	1	1
10/02/2020 12:00	-0.7	11.9	2,126.7	-0.2	1.5	1	1	1
10/02/2020 13:00	-0.4	11.5	2,205.8	0.1	1.5	1	1	1
10/02/2020 14:00	-0.4	11.4	2,203.7	0.1	1.5	1	1	1
10/02/2020 15:00	-0.4	11.5	2,182.9	0.1	1.5	1	1	1
10/02/2020 16:00	-0.4	11.5	2,184.2	0.1	1.5	1	1	1
10/02/2020 17:00	-0.4	11.4	2,193.0	0.1	1.5	1	1	1
10/02/2020 18:00	-0.4	11.7	2,153.3	0.1	1.5	1	1	1
10/02/2020 19:00	-0.5	11.8	2,130.0	-0.1	1.5	1	1	1
10/02/2020 20:00	-0.5	11.7	2,159.8	-0.1	1.5	1	1	1
10/02/2020 21:00	-0.7	12.2	2,074.6	-0.2	1.5	1	1	1
10/02/2020 22:00	-0.7	12.1	2,092.5	-0.2	1.5	1	1	1
10/02/2020 23:00	-0.7	12.0	2,105.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.1	12.7	1,924.2	0.2	1.3	24 #	24 #	16 #
Minimum:	-0.8	11.4	1,477.5	-0.4	1.0	1	1	0
Maximum:	0.6	14.0	2,205.8	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2020 00:00	0.0	14.0	1,271.8	0.0	0.9	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 08:00	0.0	18.1	388.1	0.0	0.3	1	0	0
10/03/2020 09:00	0.0	15.0	979.6	0.0	0.7	1	0	0
10/03/2020 10:00	0.6	14.0	1,391.9	0.6	1.0	1	1	0
10/03/2020 11:00	0.6	14.0	1,363.8	0.6	1.0	1	1	0
10/03/2020 12:00	0.6	13.9	1,608.4	0.6	1.1	1	1	0
10/03/2020 13:00	0.6	14.0	1,481.9	0.6	1.0	1	1	0
10/03/2020 14:00	0.6	13.9	1,640.7	0.6	1.1	1	1	0
10/03/2020 15:00	0.2	13.5	1,661.9	0.4	1.2	1	1	1
10/03/2020 16:00	-0.7	11.8	2,108.5	-0.2	1.5	1	1	1
10/03/2020 17:00	-0.4	11.4	2,193.9	0.1	1.5	1	1	1
10/03/2020 18:00	-0.4	11.5	2,181.0	0.1	1.5	1	1	1
10/03/2020 19:00	-0.4	11.6	2,184.6	0.1	1.5	1	1	1
10/03/2020 20:00	-0.5	11.9	2,117.9	-0.1	1.5	1	1	1
10/03/2020 21:00	-0.7	12.3	2,045.4	-0.2	1.4	1	1	1
10/03/2020 22:00	0.0	13.8	1,460.5	0.0	1.0	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.4	1,630.0	0.2	1.1	16 #	12 #	9 #
Minimum:	-0.7	11.4	388.1	-0.2	0.3	0	0	0
Maximum:	0.6	18.1	2,193.9	0.6	1.5	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 09:00	0.0	16.9	544.9	0.0	0.4	1	0	0
10/04/2020 10:00	0.0	14.5	1,153.0	0.0	0.8	1	0	0
10/04/2020 11:00	0.6	14.0	1,372.4	0.6	1.0	1	1	0
10/04/2020 12:00	0.6	14.0	1,376.6	0.6	1.0	1	1	0
10/04/2020 13:00	0.6	13.9	1,610.8	0.6	1.1	1	1	0
10/04/2020 14:00	0.6	14.0	1,482.3	0.6	1.0	1	1	0
10/04/2020 15:00	0.6	13.8	1,712.8	0.6	1.2	1	1	0
10/04/2020 16:00	-0.5	13.0	1,842.2	-0.2	1.3	1	1	1
10/04/2020 17:00	-0.7	11.8	2,123.7	-0.2	1.5	1	1	1
10/04/2020 18:00	-0.8	12.1	2,061.3	-0.4	1.4	1	1	1
10/04/2020 19:00	-0.8	12.2	2,055.2	-0.4	1.4	1	1	1
10/04/2020 20:00	-0.8	12.2	2,059.3	-0.4	1.4	1	1	1
10/04/2020 21:00	-0.7	12.1	2,086.7	-0.2	1.5	1	1	1
10/04/2020 22:00	-0.7	12.8	1,954.6	-0.4	1.4	1	1	1
10/04/2020 23:00	-0.8	12.9	1,923.1	-0.4	1.3	1	1	1
Average/Sum#:	-0.2	13.3	1,690.6	0.0	1.2	15 #	13 #	8 #
Minimum:	-0.8	11.8	544.9	-0.4	0.4	0	0	0
Maximum:	0.6	16.9	2,123.7	0.6	1.5	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2020 00:00	0.6	13.9	1,660.5	0.6	1.2	1	1	0
10/05/2020 01:00	0.5	13.9	1,650.0	0.5	1.2	1	1	0
10/05/2020 02:00	0.5	13.9	1,603.8	0.5	1.1	1	1	0
10/05/2020 03:00	0.6	14.0	1,580.0	0.6	1.1	1	1	0
10/05/2020 04:00	0.1	13.7	1,683.2	0.2	1.2	1	1	1
10/05/2020 05:00	-0.9	12.3	2,061.7	-0.5	1.4	1	1	1
10/05/2020 06:00	-0.8	12.3	2,046.4	-0.4	1.4	1	1	1
10/05/2020 07:00	0.6	13.9	1,551.7	0.6	1.1	1	1	0
10/05/2020 08:00	0.6	13.9	1,541.3	0.6	1.1	1	1	0
10/05/2020 09:00	0.6	14.0	1,597.6	0.6	1.1	1	1	0
10/05/2020 10:00	0.6	14.0	1,587.0	0.6	1.1	1	1	0
10/05/2020 11:00	0.6	13.9	1,651.5	0.6	1.2	1	1	0
10/05/2020 12:00	0.6	13.9	1,668.5	0.6	1.2	1	1	0
10/05/2020 13:00	-0.1	13.2	1,816.3	0.1	1.3	1	1	1
10/05/2020 14:00	-0.4	11.6	2,193.4	0.1	1.5	1	1	1
10/05/2020 15:00	-0.4	11.4	2,208.7	0.1	1.5	1	1	1
10/05/2020 16:00	-0.4	11.4	2,208.0	0.1	1.5	1	1	1
10/05/2020 17:00	-0.4	11.6	2,183.1	0.1	1.5	1	1	1
10/05/2020 18:00	-0.4	11.5	2,199.9	0.1	1.5	1	1	1
10/05/2020 19:00	-0.5	12.1	2,079.1	-0.1	1.5	1	1	1
10/05/2020 20:00	-0.5	12.2	2,070.9	-0.1	1.4	1	1	1
10/05/2020 21:00	-0.7	12.2	2,075.3	-0.2	1.5	1	1	1
10/05/2020 22:00	0.0	14.1	1,244.7	0.0	0.9	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	13.0	1,833.2	0.2	1.3	23 #	22 #	13 #
Minimum:	-0.9	11.4	1,244.7	-0.5	0.9	0	0	0
Maximum:	0.6	14.1	2,208.7	0.6	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 06:00	0.0	18.1	390.7	0.0	0.3	1	0	0
10/06/2020 07:00	0.0	15.8	831.8	0.0	0.6	1	0	0
10/06/2020 08:00	0.6	14.0	1,408.7	0.6	1.0	1	1	0
10/06/2020 09:00	0.6	14.0	1,385.6	0.6	1.0	1	1	0
10/06/2020 10:00	0.6	14.0	1,399.3	0.6	1.0	1	1	0
10/06/2020 11:00	0.6	14.0	1,640.7	0.6	1.1	1	1	0
10/06/2020 12:00	0.6	14.0	1,491.8	0.6	1.0	1	1	0
10/06/2020 13:00	0.6	13.9	1,653.6	0.6	1.2	1	1	0
10/06/2020 14:00	0.2	13.6	1,752.2	0.4	1.2	1	1	1
10/06/2020 15:00	-0.7	11.8	2,133.8	-0.2	1.5	1	1	1
10/06/2020 16:00	-0.5	11.5	2,183.3	-0.1	1.5	1	1	1
10/06/2020 17:00	-0.4	11.4	2,200.7	0.1	1.5	1	1	1
10/06/2020 18:00	-0.4	11.4	2,205.4	0.1	1.5	1	1	1
10/06/2020 19:00	-0.4	11.6	2,175.9	0.1	1.5	1	1	1
10/06/2020 20:00	0.4	13.5	1,676.1	0.4	1.2	1	1	1
10/06/2020 21:00	-0.2	13.2	1,824.6	-0.1	1.3	1	1	1
10/06/2020 22:00	-0.8	12.2	2,086.4	-0.4	1.5	1	1	1
10/06/2020 23:00	-0.8	12.6	1,996.7	-0.4	1.4	1	1	1
Average/Sum#:	0.0	13.4	1,691.0	0.2	1.2	18 #	16 #	10 #
Minimum:	-0.8	11.4	390.7	-0.4	0.3	0	0	0
Maximum:	0.6	18.1	2,205.4	0.6	1.5	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2020 00:00	-0.8	12.3	2,050.3	-0.4	1.4	1	1	1
10/07/2020 01:00	-0.8	12.6	1,980.4	-0.4	1.4	1	1	1
10/07/2020 02:00	0.6	13.9	1,541.2	0.6	1.1	1	1	0
10/07/2020 03:00	0.6	14.0	1,606.7	0.6	1.1	1	1	0
10/07/2020 04:00	-0.4	13.3	1,834.3	-0.1	1.3	1	1	1
10/07/2020 05:00	-0.9	12.0	2,118.8	-0.4	1.5	1	1	1
10/07/2020 06:00	-0.8	12.4	2,038.2	-0.4	1.4	1	1	1
10/07/2020 07:00	0.5	13.9	1,602.9	0.5	1.1	1	1	0
10/07/2020 08:00	0.6	14.0	1,366.6	0.6	1.0	1	1	0
10/07/2020 09:00	0.6	14.0	1,301.4	0.6	0.9	1	1	0
10/07/2020 10:00	0.6	14.0	1,357.7	0.6	1.0	1	1	0
10/07/2020 11:00	-0.1	13.3	1,796.0	0.1	1.3	1	1	1
10/07/2020 12:00	-0.7	11.7	2,171.8	-0.2	1.5	1	1	1
10/07/2020 13:00	-0.5	11.5	2,183.5	-0.1	1.5	1	1	1
10/07/2020 14:00	0.4	13.5	1,711.1	0.4	1.2	1	1	1
10/07/2020 15:00	-0.2	13.1	1,798.7	-0.1	1.3	1	1	1
10/07/2020 16:00	-0.8	12.0	2,093.1	-0.4	1.5	1	1	1
10/07/2020 17:00	-0.7	11.6	2,163.2	-0.2	1.5	1	1	1
10/07/2020 18:00	-0.7	11.8	2,123.7	-0.2	1.5	1	1	1
10/07/2020 19:00	-0.7	12.1	2,052.4	-0.2	1.4	1	1	1
10/07/2020 20:00	0.6	13.9	1,686.3	0.6	1.2	1	1	0
10/07/2020 21:00	-0.2	13.2	1,827.0	-0.1	1.3	1	1	1
10/07/2020 22:00	-0.8	12.1	2,099.0	-0.4	1.5	1	1	1
10/07/2020 23:00	0.0	14.0	1,254.1	0.0	0.9	1	0	1
Average/Sum#:	-0.2	12.9	1,823.3	0.0	1.3	24 #	23 #	17 #
Minimum:	-0.9	11.5	1,254.1	-0.4	0.9	1	0	0
Maximum:	0.6	14.0	2,183.5	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2020 12:00	0.0	17.7	447.5	0.0	0.3	1	0	0
10/12/2020 13:00	0.0	15.7	746.4	0.0	0.5	1	0	0
10/12/2020 14:00	0.0	14.0	1,575.2	0.0	1.1	1	0	0
10/12/2020 15:00	0.7	13.7	1,668.7	0.7	1.2	1	1	1
10/12/2020 16:00	-0.7	12.3	2,046.9	-0.2	1.4	1	1	1
10/12/2020 17:00	-0.8	12.4	2,032.4	-0.4	1.4	1	1	1
10/12/2020 18:00	-0.8	12.5	2,017.0	-0.4	1.4	1	1	1
10/12/2020 19:00	-0.7	12.7	1,949.5	-0.2	1.4	1	1	1
10/12/2020 20:00	0.6	13.8	1,762.1	0.6	1.2	1	1	0
10/12/2020 21:00	-0.1	13.3	1,825.5	0.1	1.3	1	1	1
10/12/2020 22:00	-0.7	12.5	2,015.6	-0.2	1.4	1	1	1
10/12/2020 23:00	-0.7	12.7	1,971.8	-0.2	1.4	1	1	1
Average/Sum#:	-0.3	13.6	1,671.6	0.0	1.2	12 #	9 #	8 #
Minimum:	-0.8	12.3	447.5	-0.4	0.3	0	0	0
Maximum:	0.7	17.7	2,046.9	0.7	1.4	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2020 00:00	0.6	13.9	1,671.5	0.6	1.2	1	1	0
10/13/2020 01:00	0.6	13.9	1,624.8	0.6	1.1	1	1	0
10/13/2020 02:00	0.6	14.0	1,396.7	0.6	1.0	1	1	0
10/13/2020 03:00	0.6	14.0	1,603.9	0.6	1.1	1	1	0
10/13/2020 04:00	0.1	13.4	1,820.6	0.2	1.3	1	1	1
10/13/2020 05:00	-0.7	12.7	2,000.2	-0.2	1.4	1	1	1
10/13/2020 06:00	-0.7	12.9	1,944.4	-0.4	1.4	1	1	1
10/13/2020 07:00	0.6	13.9	1,653.3	0.6	1.2	1	1	0
10/13/2020 08:00	0.6	13.9	1,487.9	0.6	1.0	1	1	0
10/13/2020 09:00	0.6	14.0	1,351.7	0.6	0.9	1	1	0
10/13/2020 10:00	0.6	13.9	1,622.3	0.6	1.1	1	1	0
10/13/2020 11:00	0.6	13.9	1,501.7	0.6	1.1	1	1	0
10/13/2020 12:00	0.6	13.9	1,502.6	0.6	1.1	1	1	0
10/13/2020 13:00	0.6	14.0	1,407.8	0.6	1.0	1	1	0
10/13/2020 14:00	0.6	13.9	1,611.8	0.6	1.1	1	1	0
10/13/2020 15:00	0.4	13.6	1,663.6	0.4	1.2	1	1	1
10/13/2020 16:00	-0.7	12.3	2,056.4	-0.2	1.4	1	1	1
10/13/2020 17:00	-0.5	12.2	2,073.0	-0.1	1.5	1	1	1
10/13/2020 18:00	-0.5	12.3	2,045.1	-0.1	1.4	1	1	1
10/13/2020 19:00	-0.5	12.6	1,974.4	-0.2	1.4	1	1	1
10/13/2020 20:00	0.6	13.9	1,708.1	0.6	1.2	1	1	0
10/13/2020 21:00	0.1	13.4	1,822.4	0.2	1.3	1	1	1
10/13/2020 22:00	-0.4	12.0	2,134.7	-0.1	1.5	1	1	1
10/13/2020 23:00	-0.4	12.7	1,961.5	-0.1	1.4	1	1	1
Average/Sum#:	0.2	13.4	1,735.0	0.3	1.2	24 #	24 #	11 #
Minimum:	-0.7	12.0	1,351.7	-0.4	0.9	1	1	0
Maximum:	0.6	14.0	2,134.7	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2020 00:00	0.6	13.9	1,679.7	0.6	1.2	1	1	0
10/14/2020 01:00	0.5	13.7	1,681.9	0.5	1.2	1	1	1
10/14/2020 02:00	-0.4	12.2	2,076.5	-0.1	1.5	1	1	1
10/14/2020 03:00	-0.4	12.7	1,951.4	-0.1	1.4	1	1	1
10/14/2020 04:00	0.6	13.9	1,607.4	0.6	1.1	1	1	0
10/14/2020 05:00	-0.5	13.0	1,827.4	-0.2	1.3	1	1	1
10/14/2020 06:00	-0.5	12.5	2,025.0	-0.2	1.4	1	1	1
10/14/2020 07:00	0.7	0.0	1,931.7	0.7	1.4	1	1	1
10/14/2020 08:00	0.4	13.9	1,419.2	0.4	1.0	1	1	0
10/14/2020 09:00	0.4	14.0	1,311.0	0.4	0.9	1	1	0
10/14/2020 10:00	0.4	13.9	1,545.8	0.4	1.1	1	1	0
10/14/2020 11:00	-1.1	12.3	1,786.5	-0.5	1.3	1	1	1
10/14/2020 12:00	-1.1	12.1	2,162.9	-0.5	1.5	1	1	1
10/14/2020 13:00	-0.8	11.5	2,210.4	-0.2	1.5	1	1	1
10/14/2020 14:00	-0.8	12.6	1,766.5	-0.4	1.2	1	1	1
10/14/2020 15:00	-1.2	12.5	1,842.7	-0.7	1.3	1	1	1
10/14/2020 16:00	-1.1	11.8	2,147.2	-0.5	1.5	1	1	1
10/14/2020 17:00	-0.8	11.4	2,222.3	-0.2	1.6	1	1	1
10/14/2020 18:00	-0.9	11.8	2,139.1	-0.4	1.5	1	1	1
10/14/2020 19:00	-0.9	11.9	2,089.3	-0.4	1.5	1	1	1
10/14/2020 20:00	0.3	13.8	1,694.2	0.4	1.2	1	1	0
10/14/2020 21:00	-0.7	13.1	1,854.6	-0.4	1.3	1	1	1
10/14/2020 22:00	-0.9	11.7	2,179.8	-0.4	1.5	1	1	1
10/14/2020 23:00	-1.1	12.4	2,016.1	-0.5	1.4	1	1	1
Average/Sum#:	-0.4	12.7	1,882.0	-0.1	1.3	24 #	24 #	18 #
Minimum:	-1.2	11.4	1,311.0	-0.7	0.9	1	1	0
Maximum:	0.6	14.0	2,222.3	0.6	1.6	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2020 00:00	0.3	13.8	1,684.8	0.4	1.2	1	1	0
10/15/2020 01:00	-0.7	13.3	1,820.4	-0.4	1.3	1	1	1
10/15/2020 02:00	-1.2	11.9	2,148.2	-0.7	1.5	1	1	1
10/15/2020 03:00	-1.2	12.0	2,097.9	-0.7	1.5	1	1	1
10/15/2020 04:00	0.2	13.8	1,701.3	0.3	1.2	1	1	0
10/15/2020 05:00	-1.2	12.9	1,839.4	-0.8	1.3	1	1	1
10/15/2020 06:00	-1.4	12.2	2,079.6	-0.7	1.5	1	1	1
10/15/2020 07:00	-0.9	12.7	1,868.9	-0.5	1.3	1	1	1
10/15/2020 08:00	0.3	14.0	1,309.4	0.4	0.9	1	1	0
10/15/2020 09:00	0.4	14.0	1,305.4	0.4	0.9	1	1	0
10/15/2020 10:00	0.4	14.0	1,323.7	0.4	0.9	1	1	0
10/15/2020 11:00	0.3	13.8	1,576.9	0.4	1.1	1	1	0
10/15/2020 12:00	0.2	13.8	1,651.4	0.3	1.2	1	1	0
10/15/2020 13:00	-0.8	13.1	1,832.0	-0.5	1.3	1	1	1
10/15/2020 14:00	-1.1	11.5	2,209.0	-0.5	1.5	1	1	1
10/15/2020 15:00	-0.9	11.4	2,223.9	-0.4	1.6	1	1	1
10/15/2020 16:00	-0.9	11.4	2,220.5	-0.4	1.6	1	1	1
10/15/2020 17:00	-0.9	11.5	2,198.0	-0.4	1.5	1	1	1
10/15/2020 18:00	-0.9	11.5	2,210.5	-0.4	1.5	1	1	1
10/15/2020 19:00	-0.9	11.6	2,184.8	-0.4	1.5	1	1	1
10/15/2020 20:00	-0.9	11.6	2,203.5	-0.4	1.5	1	1	1
10/15/2020 21:00	-0.9	11.5	2,223.1	-0.4	1.6	1	1	1
10/15/2020 22:00	-0.9	11.7	2,179.0	-0.4	1.5	1	1	1
10/15/2020 23:00	-1.1	12.2	2,052.8	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.6	1,922.7	-0.2	1.3	24 #	24 #	17 #
Minimum:	-1.4	11.4	1,305.4	-0.8	0.9	1	1	0
Maximum:	0.4	14.0	2,223.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2020 00:00	0.3	13.8	1,715.7	0.4	1.2	1	1	0
10/16/2020 01:00	0.3	14.0	1,320.2	0.4	0.9	1	1	0
10/16/2020 02:00	0.3	13.8	1,694.2	0.4	1.2	1	1	0
10/16/2020 03:00	-0.8	13.2	1,839.3	-0.5	1.3	1	1	1
10/16/2020 04:00	-0.9	12.7	1,907.8	-0.5	1.3	1	1	1
10/16/2020 05:00	-0.4	13.4	1,714.5	-0.2	1.2	1	1	1
10/16/2020 06:00	-0.8	12.1	2,073.6	-0.4	1.5	1	1	1
10/16/2020 07:00	-1.1	12.7	1,970.7	-0.7	1.4	1	1	1
10/16/2020 08:00	0.3	13.8	1,609.8	0.4	1.1	1	1	0
10/16/2020 09:00	0.3	14.0	1,403.9	0.4	1.0	1	1	0
10/16/2020 10:00	0.4	14.0	1,520.0	0.4	1.1	1	1	0
10/16/2020 11:00	-0.2	13.6	1,601.7	-0.1	1.1	1	1	1
10/16/2020 12:00	-1.1	11.8	2,142.8	-0.5	1.5	1	1	1
10/16/2020 13:00	-1.1	11.9	2,110.6	-0.5	1.5	1	1	1
10/16/2020 14:00	-0.8	11.6	2,173.1	-0.2	1.5	1	1	1
10/16/2020 15:00	-0.8	11.5	2,183.0	-0.2	1.5	1	1	1
10/16/2020 16:00	-0.9	11.9	2,090.6	-0.4	1.5	1	1	1
10/16/2020 17:00	-0.9	11.8	2,140.0	-0.4	1.5	1	1	1
10/16/2020 18:00	-0.9	11.9	2,130.2	-0.4	1.5	1	1	1
10/16/2020 19:00	-0.8	11.5	2,200.5	-0.2	1.5	1	1	1
10/16/2020 20:00	-0.8	11.6	2,168.2	-0.2	1.5	1	1	1
10/16/2020 21:00	-0.9	11.8	2,136.6	-0.4	1.5	1	1	1
10/16/2020 22:00	-0.9	12.1	2,086.7	-0.4	1.5	1	1	1
10/16/2020 23:00	-1.1	12.3	2,040.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.6	1,915.6	-0.2	1.3	24 #	24 #	18 #
Minimum:	-1.1	11.5	1,320.2	-0.7	0.9	1	1	0
Maximum:	0.4	14.0	2,200.5	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2020 00:00	-0.9	12.6	1,954.1	-0.5	1.4	1	1	1
10/17/2020 01:00	0.3	13.8	1,562.9	0.4	1.1	1	1	0
10/17/2020 02:00	0.4	14.0	1,321.6	0.4	0.9	1	1	0
10/17/2020 03:00	0.4	13.9	1,620.7	0.4	1.1	1	1	0
10/17/2020 04:00	0.4	13.9	1,617.4	0.4	1.1	1	1	0
10/17/2020 05:00	0.4	13.9	1,670.8	0.4	1.2	1	1	0
10/17/2020 06:00	-0.5	13.3	1,820.2	-0.2	1.3	1	1	1
10/17/2020 07:00	-0.8	12.9	1,866.3	-0.4	1.3	1	1	1
10/17/2020 08:00	0.3	13.8	1,679.6	0.4	1.2	1	1	0
10/17/2020 09:00	0.3	13.8	1,682.9	0.4	1.2	1	1	0
10/17/2020 10:00	0.3	13.8	1,636.8	0.4	1.1	1	1	0
10/17/2020 11:00	0.3	13.8	1,493.0	0.4	1.0	1	1	0
10/17/2020 12:00	0.3	13.9	1,473.3	0.4	1.0	1	1	0
10/17/2020 13:00	0.4	14.0	1,463.4	0.4	1.0	1	1	0
10/17/2020 14:00	-0.2	13.5	1,664.1	-0.1	1.2	1	1	1
10/17/2020 15:00	-0.9	11.8	2,127.5	-0.4	1.5	1	1	1
10/17/2020 16:00	-0.7	11.4	2,203.3	-0.2	1.5	1	1	1
10/17/2020 17:00	-0.7	11.4	2,207.1	-0.2	1.5	1	1	1
10/17/2020 18:00	-0.9	12.0	2,077.5	-0.4	1.5	1	1	1
10/17/2020 19:00	-0.9	12.0	2,106.0	-0.4	1.5	1	1	1
10/17/2020 20:00	-0.9	11.9	2,119.4	-0.4	1.5	1	1	1
10/17/2020 21:00	-0.9	12.4	2,018.8	-0.5	1.4	1	1	1
10/17/2020 22:00	-0.9	12.0	2,111.8	-0.4	1.5	1	1	1
10/17/2020 23:00	-0.9	12.0	2,107.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	13.0	1,816.9	0.0	1.3	24 #	24 #	13 #
Minimum:	-0.9	11.4	1,321.6	-0.5	0.9	1	1	0
Maximum:	0.4	14.0	2,207.1	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2020 00:00	-0.2	13.5	1,703.8	-0.1	1.2	1	1	1
10/18/2020 01:00	-0.5	13.1	1,837.0	-0.2	1.3	1	1	1
10/18/2020 02:00	-0.8	11.5	2,212.7	-0.2	1.5	1	1	1
10/18/2020 03:00	-0.8	11.8	2,136.2	-0.2	1.5	1	1	1
10/18/2020 04:00	0.3	13.8	1,674.6	0.4	1.2	1	1	0
10/18/2020 05:00	0.3	13.8	1,609.1	0.4	1.1	1	1	0
10/18/2020 06:00	0.3	13.8	1,567.6	0.4	1.1	1	1	0
10/18/2020 07:00	0.2	13.9	1,512.7	0.3	1.1	1	1	0
10/18/2020 08:00	0.4	13.9	1,610.8	0.4	1.1	1	1	0
10/18/2020 09:00	0.4	13.9	1,617.4	0.4	1.1	1	1	0
10/18/2020 10:00	0.4	13.9	1,583.4	0.4	1.1	1	1	0
10/18/2020 11:00	0.4	13.9	1,614.7	0.4	1.1	1	1	0
10/18/2020 12:00	0.3	13.8	1,628.8	0.4	1.1	1	1	0
10/18/2020 13:00	0.3	13.8	1,606.8	0.4	1.1	1	1	0
10/18/2020 14:00	0.3	13.8	1,641.9	0.4	1.1	1	1	0
10/18/2020 15:00	-0.8	13.2	1,795.2	-0.5	1.3	1	1	1
10/18/2020 16:00	-1.4	11.7	2,152.2	-0.7	1.5	1	1	1
10/18/2020 17:00	-0.2	13.5	1,725.4	-0.1	1.2	1	1	1
10/18/2020 18:00	0.0	15.0	886.1	0.0	0.6	1	0	0
10/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2020 21:00	0.0	17.9	397.4	0.0	0.3	1	0	0
10/18/2020 22:00	0.0	14.7	1,185.4	0.0	0.8	1	0	0
10/18/2020 23:00	-0.5	13.2	1,825.1	-0.2	1.3	1	1	1
Average/Sum#:	-0.1	13.7	1,614.7	0.1	1.1	22 #	19 #	8 #
Minimum:	-1.4	11.5	397.4	-0.7	0.3	0	0	0
Maximum:	0.4	17.9	2,212.7	0.4	1.5	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2020 00:00	-0.8	13.0	1,852.4	-0.4	1.3	1	1	1
10/19/2020 01:00	0.3	13.8	1,636.1	0.4	1.1	1	1	0
10/19/2020 02:00	0.3	13.8	1,589.9	0.4	1.1	1	1	0
10/19/2020 03:00	0.3	13.8	1,690.0	0.4	1.2	1	1	0
10/19/2020 04:00	-0.8	13.3	1,825.8	-0.5	1.3	1	1	1
10/19/2020 05:00	-1.1	12.0	2,129.1	-0.5	1.5	1	1	1
10/19/2020 06:00	-0.8	12.1	2,093.8	-0.4	1.5	1	1	1
10/19/2020 07:00	0.3	13.8	1,696.5	0.4	1.2	1	1	0
10/19/2020 08:00	0.3	13.9	1,565.1	0.4	1.1	1	1	0
10/19/2020 09:00	0.3	13.8	1,632.5	0.4	1.1	1	1	0
10/19/2020 10:00	0.3	13.8	1,620.5	0.4	1.1	1	1	0
10/19/2020 11:00	0.4	13.9	1,589.6	0.4	1.1	1	1	0
10/19/2020 12:00	0.4	13.9	1,456.3	0.4	1.0	1	1	0
10/19/2020 13:00	0.4	14.0	1,431.0	0.4	1.0	1	1	0
10/19/2020 14:00	-0.1	13.5	1,670.8	0.1	1.2	1	1	1
10/19/2020 15:00	-0.9	12.2	2,053.8	-0.4	1.4	1	1	1
10/19/2020 16:00	-0.8	11.6	2,170.1	-0.2	1.5	1	1	1
10/19/2020 17:00	-0.7	11.4	2,212.3	-0.2	1.5	1	1	1
10/19/2020 18:00	-0.8	11.7	2,141.1	-0.2	1.5	1	1	1
10/19/2020 19:00	-0.7	11.5	2,195.9	-0.2	1.5	1	1	1
10/19/2020 20:00	-0.4	12.9	1,786.1	-0.1	1.3	1	1	1
10/19/2020 21:00	-0.5	13.2	1,814.9	-0.2	1.3	1	1	1
10/19/2020 22:00	-0.9	12.2	2,070.7	-0.4	1.4	1	1	1
10/19/2020 23:00	-0.9	12.8	1,944.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.0	1,827.8	0.0	1.3	24 #	24 #	14 #
Minimum:	-1.1	11.4	1,431.0	-0.5	1.0	1	1	0
Maximum:	0.4	14.0	2,212.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2020 00:00	0.4	13.8	1,538.9	0.4	1.1	1	1	0
10/20/2020 01:00	0.4	14.0	1,294.8	0.4	0.9	1	1	0
10/20/2020 02:00	0.4	13.9	1,392.4	0.4	1.0	1	1	0
10/20/2020 03:00	-0.5	13.4	1,808.3	-0.2	1.3	1	1	1
10/20/2020 04:00	-1.1	12.3	2,059.3	-0.5	1.4	1	1	1
10/20/2020 05:00	-0.9	12.1	2,088.8	-0.4	1.5	1	1	1
10/20/2020 06:00	-0.9	12.2	2,048.3	-0.4	1.4	1	1	1
10/20/2020 07:00	0.3	13.8	1,666.9	0.4	1.2	1	1	0
10/20/2020 08:00	0.4	14.0	1,333.0	0.4	0.9	1	1	0
10/20/2020 09:00	0.4	13.9	1,463.2	0.4	1.0	1	1	0
10/20/2020 10:00	0.4	13.9	1,637.6	0.4	1.1	1	1	0
10/20/2020 11:00	-0.2	13.5	1,721.8	-0.1	1.2	1	1	1
10/20/2020 12:00	-0.9	12.1	2,080.0	-0.4	1.5	1	1	1
10/20/2020 13:00	-0.8	11.9	2,081.8	-0.4	1.5	1	1	1
10/20/2020 14:00	0.3	13.8	1,698.9	0.4	1.2	1	1	0
10/20/2020 15:00	-0.5	12.9	1,844.3	-0.2	1.3	1	1	1
10/20/2020 16:00	-0.7	11.4	2,195.8	-0.2	1.5	1	1	1
10/20/2020 17:00	-0.8	11.6	2,156.0	-0.2	1.5	1	1	1
10/20/2020 18:00	-0.8	11.9	2,102.2	-0.4	1.5	1	1	1
10/20/2020 19:00	-0.9	12.2	2,037.0	-0.4	1.4	1	1	1
10/20/2020 20:00	-0.7	12.4	1,935.2	-0.2	1.4	1	1	1
10/20/2020 21:00	-0.2	13.4	1,752.1	-0.1	1.2	1	1	1
10/20/2020 22:00	-0.9	12.1	2,088.6	-0.4	1.5	1	1	1
10/20/2020 23:00	-0.8	11.6	2,166.5	-0.2	1.5	1	1	1
Average/Sum#:	-0.4	12.8	1,841.3	-0.1	1.3	24 #	24 #	16 #
Minimum:	-1.1	11.4	1,294.8	-0.5	0.9	1	1	0
Maximum:	0.4	14.0	2,195.8	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2020 00:00	-0.8	11.9	2,087.1	-0.4	1.5	1	1	1
10/21/2020 01:00	0.4	13.8	1,695.0	0.4	1.2	1	1	0
10/21/2020 02:00	-0.2	13.2	1,771.2	-0.1	1.2	1	1	1
10/21/2020 03:00	-0.8	11.7	2,176.8	-0.2	1.5	1	1	1
10/21/2020 04:00	-0.8	11.9	2,121.9	-0.4	1.5	1	1	1
10/21/2020 05:00	-0.9	12.4	2,049.5	-0.5	1.4	1	1	1
10/21/2020 06:00	-0.9	11.9	2,139.5	-0.4	1.5	1	1	1
10/21/2020 07:00	0.1	13.7	1,557.2	0.2	1.1	1	1	1
10/21/2020 08:00	0.4	13.9	1,533.5	0.4	1.1	1	1	0
10/21/2020 09:00	0.4	13.9	1,362.4	0.4	1.0	1	1	0
10/21/2020 10:00	0.4	13.9	1,576.2	0.4	1.1	1	1	0
10/21/2020 11:00	0.4	13.9	1,529.3	0.4	1.1	1	1	0
10/21/2020 12:00	0.4	13.9	1,602.4	0.4	1.1	1	1	0
10/21/2020 13:00	-0.2	13.5	1,687.3	-0.1	1.2	1	1	1
10/21/2020 14:00	-0.8	11.8	2,130.1	-0.2	1.5	1	1	1
10/21/2020 15:00	-0.9	12.0	2,073.2	-0.4	1.5	1	1	1
10/21/2020 16:00	-0.8	11.6	2,162.6	-0.2	1.5	1	1	1
10/21/2020 17:00	-0.7	11.4	2,197.7	-0.2	1.5	1	1	1
10/21/2020 18:00	-0.7	11.4	2,198.2	-0.2	1.5	1	1	1
10/21/2020 19:00	-0.8	11.7	2,153.5	-0.2	1.5	1	1	1
10/21/2020 20:00	-0.7	11.6	2,170.0	-0.2	1.5	1	1	1
10/21/2020 21:00	-0.5	11.8	2,108.9	-0.1	1.5	1	1	1
10/21/2020 22:00	-0.5	11.8	2,130.5	-0.1	1.5	1	1	1
10/21/2020 23:00	-0.7	12.2	2,030.6	-0.2	1.4	1	1	1
Average/Sum#:	-0.4	12.5	1,926.9	-0.1	1.4	24 #	24 #	18 #
Minimum:	-0.9	11.4	1,362.4	-0.5	1.0	1	1	0
Maximum:	0.4	13.9	2,198.2	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2020 00:00	0.4	13.9	1,693.3	0.4	1.2	1	1	0
10/22/2020 01:00	-0.4	13.2	1,828.3	-0.1	1.3	1	1	1
10/22/2020 02:00	-0.7	12.4	1,996.5	-0.2	1.4	1	1	1
10/22/2020 03:00	-0.7	12.5	1,968.2	-0.2	1.4	1	1	1
10/22/2020 04:00	0.4	13.9	1,689.9	0.4	1.2	1	1	0
10/22/2020 05:00	-0.8	13.0	1,767.7	-0.4	1.2	1	1	1
10/22/2020 06:00	-0.9	11.9	2,176.0	-0.4	1.5	1	1	1
10/22/2020 07:00	-0.8	12.0	2,099.5	-0.4	1.5	1	1	1
10/22/2020 08:00	0.4	13.9	1,489.7	0.4	1.0	1	1	0
10/22/2020 09:00	0.4	13.9	1,589.5	0.4	1.1	1	1	0
10/22/2020 10:00	0.4	13.9	1,618.1	0.4	1.1	1	1	0
10/22/2020 11:00	-0.7	13.3	1,829.4	-0.4	1.3	1	1	1
10/22/2020 12:00	-1.2	12.0	2,132.3	-0.7	1.5	1	1	1
10/22/2020 13:00	-1.2	12.5	1,999.9	-0.7	1.4	1	1	1
10/22/2020 14:00	0.3	13.8	1,589.1	0.4	1.1	1	1	0
10/22/2020 15:00	-0.5	13.6	1,685.4	-0.2	1.2	1	1	1
10/22/2020 16:00	-1.2	12.0	2,131.8	-0.7	1.5	1	1	1
10/22/2020 17:00	-1.1	11.9	2,144.5	-0.5	1.5	1	1	1
10/22/2020 18:00	-1.1	12.5	2,020.1	-0.5	1.4	1	1	1
10/22/2020 19:00	-1.2	12.2	2,090.3	-0.7	1.5	1	1	1
10/22/2020 20:00	-1.2	12.3	2,061.9	-0.7	1.4	1	1	1
10/22/2020 21:00	-1.1	12.4	2,062.5	-0.5	1.4	1	1	1
10/22/2020 22:00	-0.9	12.5	2,020.5	-0.5	1.4	1	1	1
10/22/2020 23:00	-0.7	12.6	1,969.7	-0.2	1.4	1	1	1
Average/Sum#:	-0.6	12.8	1,902.3	-0.2	1.3	24 #	24 #	18 #
Minimum:	-1.2	11.9	1,489.7	-0.7	1.0	1	1	0
Maximum:	0.4	13.9	2,176.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2020 00:00	0.4	13.9	1,637.3	0.4	1.1	1	1	0
10/23/2020 01:00	-0.4	13.3	1,817.5	-0.1	1.3	1	1	1
10/23/2020 02:00	-0.9	12.2	2,108.7	-0.4	1.5	1	1	1
10/23/2020 03:00	-1.1	12.6	2,003.8	-0.7	1.4	1	1	1
10/23/2020 04:00	0.3	13.9	1,684.8	0.4	1.2	1	1	0
10/23/2020 05:00	-0.8	13.1	1,826.2	-0.5	1.3	1	1	1
10/23/2020 06:00	-1.2	12.0	2,156.6	-0.7	1.5	1	1	1
10/23/2020 07:00	-1.1	12.2	2,114.2	-0.5	1.5	1	1	1
10/23/2020 08:00	-1.1	12.7	2,000.8	-0.7	1.4	1	1	1
10/23/2020 09:00	-0.1	13.6	1,717.0	0.1	1.2	1	1	1
10/23/2020 10:00	0.3	13.8	1,689.6	0.4	1.2	1	1	0
10/23/2020 11:00	-0.1	13.7	1,737.8	0.1	1.2	1	1	1
10/23/2020 12:00	-1.2	12.3	2,075.6	-0.7	1.5	1	1	1
10/23/2020 13:00	-0.9	12.7	1,962.9	-0.5	1.4	1	1	1
10/23/2020 14:00	0.3	13.9	1,607.9	0.4	1.1	1	1	0
10/23/2020 15:00	-0.2	13.6	1,751.8	-0.1	1.2	1	1	1
10/23/2020 16:00	-1.1	12.3	2,066.9	-0.5	1.4	1	1	1
10/23/2020 17:00	-0.9	12.0	2,119.8	-0.4	1.5	1	1	1
10/23/2020 18:00	-0.9	12.9	1,936.0	-0.5	1.4	1	1	1
10/23/2020 19:00	0.3	13.8	1,701.4	0.4	1.2	1	1	0
10/23/2020 20:00	-0.8	13.3	1,838.5	-0.5	1.3	1	1	1
10/23/2020 21:00	-1.2	12.3	2,067.8	-0.7	1.4	1	1	1
10/23/2020 22:00	-1.1	12.6	2,034.1	-0.7	1.4	1	1	1
10/23/2020 23:00	-0.9	12.1	2,131.9	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	13.0	1,907.9	-0.3	1.3	24 #	24 #	19 #
Minimum:	-1.2	12.0	1,607.9	-0.7	1.1	1	1	0
Maximum:	0.4	13.9	2,156.6	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2020 00:00	-0.1	13.6	1,724.3	0.1	1.2	1	1	1
10/24/2020 01:00	0.3	13.8	1,694.2	0.4	1.2	1	1	0
10/24/2020 02:00	-0.5	13.3	1,835.8	-0.2	1.3	1	1	1
10/24/2020 03:00	-0.9	12.2	2,111.6	-0.4	1.5	1	1	1
10/24/2020 04:00	-0.9	12.8	1,953.9	-0.5	1.4	1	1	1
10/24/2020 05:00	0.3	13.8	1,680.8	0.4	1.2	1	1	0
10/24/2020 06:00	0.3	13.8	1,676.3	0.4	1.2	1	1	0
10/24/2020 07:00	0.3	13.8	1,631.4	0.4	1.1	1	1	0
10/24/2020 08:00	0.3	13.8	1,577.1	0.4	1.1	1	1	0
10/24/2020 09:00	0.3	13.8	1,622.2	0.4	1.1	1	1	0
10/24/2020 10:00	0.3	13.8	1,678.7	0.4	1.2	1	1	0
10/24/2020 11:00	0.3	13.8	1,637.4	0.4	1.1	1	1	0
10/24/2020 12:00	0.3	13.9	1,437.7	0.4	1.0	1	1	0
10/24/2020 13:00	0.3	13.9	1,433.0	0.4	1.0	1	1	0
10/24/2020 14:00	0.3	13.9	1,633.5	0.4	1.1	1	1	0
10/24/2020 15:00	0.3	13.9	1,698.1	0.4	1.2	1	1	0
10/24/2020 16:00	-0.7	13.2	1,825.9	-0.4	1.3	1	1	1
10/24/2020 17:00	-1.4	11.9	2,136.8	-0.7	1.5	1	1	1
10/24/2020 18:00	-1.4	12.8	1,944.2	-0.8	1.4	1	1	1
10/24/2020 19:00	0.2	13.8	1,700.8	0.3	1.2	1	1	0
10/24/2020 20:00	0.2	13.8	1,692.6	0.3	1.2	1	1	0
10/24/2020 21:00	-0.9	13.3	1,817.8	-0.7	1.3	1	1	1
10/24/2020 22:00	-1.4	12.5	2,018.4	-0.8	1.4	1	1	1
10/24/2020 23:00	-0.9	12.6	1,968.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.2	13.4	1,755.4	0.0	1.2	24 #	24 #	10 #
Minimum:	-1.4	11.9	1,433.0	-0.8	1.0	1	1	0
Maximum:	0.3	13.9	2,136.8	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2020 00:00	0.3	13.8	1,681.8	0.4	1.2	1	1	0
10/25/2020 01:00	0.3	13.8	1,669.3	0.4	1.2	1	1	0
10/25/2020 02:00	0.3	13.8	1,654.8	0.4	1.2	1	1	0
10/25/2020 03:00	0.3	13.8	1,653.7	0.4	1.2	1	1	0
10/25/2020 04:00	0.3	13.8	1,652.7	0.4	1.2	1	1	0
10/25/2020 05:00	0.3	13.8	1,628.9	0.4	1.1	1	1	0
10/25/2020 06:00	0.3	13.8	1,595.1	0.4	1.1	1	1	0
10/25/2020 07:00	0.3	13.8	1,619.8	0.4	1.1	1	1	0
10/25/2020 08:00	0.3	13.9	1,615.0	0.4	1.1	1	1	0
10/25/2020 09:00	0.3	13.9	1,564.9	0.4	1.1	1	1	0
10/25/2020 10:00	0.3	13.9	1,423.2	0.4	1.0	1	1	0
10/25/2020 11:00	0.3	14.0	1,352.0	0.4	0.9	1	1	0
10/25/2020 12:00	0.3	13.9	1,556.7	0.4	1.1	1	1	0
10/25/2020 13:00	0.3	13.9	1,606.2	0.4	1.1	1	1	0
10/25/2020 14:00	0.3	13.9	1,662.3	0.4	1.2	1	1	0
10/25/2020 15:00	0.3	14.0	1,613.3	0.4	1.1	1	1	0
10/25/2020 16:00	-0.8	13.4	1,848.6	-0.5	1.3	1	1	1
10/25/2020 17:00	-1.5	12.5	2,084.2	-0.9	1.5	1	1	1
10/25/2020 18:00	-1.4	12.5	2,035.4	-0.8	1.4	1	1	1
10/25/2020 19:00	0.3	13.9	1,672.5	0.4	1.2	1	1	0
10/25/2020 20:00	-0.5	13.3	1,833.0	-0.2	1.3	1	1	1
10/25/2020 21:00	-0.8	12.0	2,171.6	-0.4	1.5	1	1	1
10/25/2020 22:00	-0.7	11.9	2,195.3	-0.2	1.5	1	1	1
10/25/2020 23:00	-0.5	11.7	2,239.9	-0.1	1.6	1	1	1
Average/Sum#:	0.0	13.5	1,734.6	0.2	1.2	24 #	24 #	7 #
Minimum:	-1.5	11.7	1,352.0	-0.9	0.9	1	1	0
Maximum:	0.3	14.0	2,239.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2020 00:00	-0.7	12.5	2,059.9	-0.2	1.4	1	1	1
10/26/2020 01:00	-0.7	12.9	1,990.9	-0.4	1.4	1	1	1
10/26/2020 02:00	-0.7	12.5	2,059.2	-0.2	1.4	1	1	1
10/26/2020 03:00	0.2	13.8	1,690.7	0.4	1.2	1	1	1
10/26/2020 04:00	-0.7	13.3	1,875.0	-0.4	1.3	1	1	1
10/26/2020 05:00	-0.8	11.9	2,169.8	-0.4	1.5	1	1	1
10/26/2020 06:00	-0.7	12.1	2,129.9	-0.2	1.5	1	1	1
10/26/2020 07:00	0.4	13.8	1,789.8	0.4	1.3	1	1	0
10/26/2020 08:00	0.4	13.9	1,762.0	0.4	1.2	1	1	0
10/26/2020 09:00	0.4	13.9	1,750.1	0.4	1.2	1	1	0
10/26/2020 10:00	0.4	13.9	1,688.4	0.4	1.2	1	1	0
10/26/2020 11:00	0.4	14.0	1,389.8	0.4	1.0	1	1	0
10/26/2020 12:00	0.4	14.0	1,538.7	0.4	1.1	1	1	0
10/26/2020 13:00	0.4	14.0	1,515.7	0.4	1.1	1	1	0
10/26/2020 14:00	0.3	14.0	1,699.0	0.4	1.2	1	1	0
10/26/2020 15:00	0.4	14.0	1,651.4	0.4	1.2	1	1	0
10/26/2020 16:00	-0.8	13.2	1,870.3	-0.5	1.3	1	1	1
10/26/2020 17:00	-1.4	12.0	2,186.7	-0.7	1.5	1	1	1
10/26/2020 18:00	-1.2	11.7	2,238.1	-0.5	1.6	1	1	1
10/26/2020 19:00	-1.2	12.3	2,111.9	-0.7	1.5	1	1	1
10/26/2020 20:00	-1.2	12.1	2,162.7	-0.7	1.5	1	1	1
10/26/2020 21:00	-1.2	12.2	2,127.1	-0.7	1.5	1	1	1
10/26/2020 22:00	-1.2	12.3	2,113.0	-0.7	1.5	1	1	1
10/26/2020 23:00	-1.1	12.4	2,082.3	-0.5	1.5	1	1	1
Average/Sum#:	-0.4	13.0	1,902.2	-0.1	1.3	24 #	24 #	15 #
Minimum:	-1.4	11.7	1,389.8	-0.7	1.0	1	1	0
Maximum:	0.4	14.0	2,238.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2020 00:00	0.1	13.9	1,693.1	0.2	1.2	1	1	1
10/27/2020 01:00	-0.2	13.5	1,801.7	-0.1	1.3	1	1	1
10/27/2020 02:00	-0.8	12.2	2,095.4	-0.4	1.5	1	1	1
10/27/2020 03:00	-0.7	12.5	2,025.8	-0.2	1.4	1	1	1
10/27/2020 04:00	0.4	13.9	1,663.1	0.4	1.2	1	1	0
10/27/2020 05:00	-0.7	13.0	1,753.9	-0.4	1.2	1	1	1
10/27/2020 06:00	-0.8	11.7	2,210.8	-0.2	1.5	1	1	1
10/27/2020 07:00	-1.1	11.8	2,211.1	-0.5	1.5	1	1	1
10/27/2020 08:00	-1.1	12.1	2,148.0	-0.5	1.5	1	1	1
10/27/2020 09:00	-1.1	11.9	2,160.6	-0.5	1.5	1	1	1
10/27/2020 10:00	-1.1	11.9	2,167.7	-0.5	1.5	1	1	1
10/27/2020 11:00	-1.2	11.8	2,166.0	-0.5	1.5	1	1	1
10/27/2020 12:00	-1.2	11.9	2,155.6	-0.7	1.5	1	1	1
10/27/2020 13:00	-1.1	11.7	2,171.9	-0.5	1.5	1	1	1
10/27/2020 14:00	-1.1	11.7	2,176.5	-0.5	1.5	1	1	1
10/27/2020 15:00	-1.1	12.5	2,002.6	-0.5	1.4	1	1	1
10/27/2020 16:00	-1.1	11.7	2,174.1	-0.5	1.5	1	1	1
10/27/2020 17:00	-0.9	11.5	2,219.9	-0.4	1.6	1	1	1
10/27/2020 18:00	-0.9	11.5	2,221.6	-0.4	1.6	1	1	1
10/27/2020 19:00	-0.9	11.6	2,220.9	-0.4	1.6	1	1	1
10/27/2020 20:00	-0.9	11.7	2,202.1	-0.4	1.5	1	1	1
10/27/2020 21:00	-1.2	12.3	2,078.8	-0.7	1.5	1	1	1
10/27/2020 22:00	-1.2	12.4	2,075.6	-0.7	1.5	1	1	1
10/27/2020 23:00	-0.9	12.3	2,060.5	-0.5	1.4	1	1	1
Average/Sum#:	-0.9	12.2	2,077.4	-0.4	1.5	24 #	24 #	23 #
Minimum:	-1.2	11.5	1,663.1	-0.7	1.2	1	1	0
Maximum:	0.4	13.9	2,221.6	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2020 00:00	0.3	13.9	1,682.5	0.4	1.2	1	1	0
10/28/2020 01:00	0.3	13.9	1,670.4	0.4	1.2	1	1	0
10/28/2020 02:00	0.3	13.9	1,659.0	0.4	1.2	1	1	0
10/28/2020 03:00	0.3	13.9	1,656.1	0.4	1.2	1	1	0
10/28/2020 04:00	-0.5	13.4	1,835.8	-0.2	1.3	1	1	1
10/28/2020 05:00	-0.9	12.0	2,143.8	-0.4	1.5	1	1	1
10/28/2020 06:00	-0.7	11.8	2,179.4	-0.2	1.5	1	1	1
10/28/2020 07:00	0.3	13.7	1,809.3	0.4	1.3	1	1	0
10/28/2020 08:00	0.3	13.7	1,738.9	0.4	1.2	1	1	0
10/28/2020 09:00	0.2	13.8	1,635.2	0.3	1.1	1	1	0
10/28/2020 10:00	0.1	13.8	1,662.0	0.2	1.2	1	1	0
10/28/2020 11:00	0.1	13.9	1,305.9	0.2	0.9	1	1	0
10/28/2020 12:00	0.2	14.0	1,268.9	0.3	0.9	1	1	0
10/28/2020 13:00	0.2	13.9	1,476.7	0.3	1.0	1	1	0
10/28/2020 14:00	0.2	13.9	1,554.7	0.3	1.1	1	1	0
10/28/2020 15:00	0.2	14.0	1,295.6	0.3	0.9	1	1	0
10/28/2020 16:00	0.1	13.8	1,640.7	0.2	1.1	1	1	0
10/28/2020 17:00	-0.4	13.8	1,712.0	-0.2	1.2	1	1	1
10/28/2020 18:00	-1.5	12.6	2,009.7	-0.9	1.4	1	1	1
10/28/2020 19:00	-1.4	12.3	2,064.4	-0.8	1.4	1	1	1
10/28/2020 20:00	-1.4	12.2	2,089.0	-0.7	1.5	1	1	1
10/28/2020 21:00	-1.4	12.3	2,088.6	-0.8	1.5	1	1	1
10/28/2020 22:00	-1.2	12.4	2,062.8	-0.7	1.4	1	1	1
10/28/2020 23:00	-1.1	12.9	1,921.3	-0.7	1.3	1	1	1
Average/Sum#:	-0.3	13.3	1,756.8	0.0	1.2	24 #	24 #	10 #
Minimum:	-1.5	11.8	1,268.9	-0.9	0.9	1	1	0
Maximum:	0.3	14.0	2,179.4	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2020 00:00	0.2	13.9	1,698.1	0.3	1.2	1	1	0
10/29/2020 01:00	0.2	13.9	1,687.8	0.3	1.2	1	1	0
10/29/2020 02:00	0.2	13.9	1,545.9	0.3	1.1	1	1	0
10/29/2020 03:00	0.2	13.9	1,691.2	0.3	1.2	1	1	0
10/29/2020 04:00	-0.7	13.4	1,803.4	-0.4	1.3	1	1	1
10/29/2020 05:00	-1.1	12.5	2,057.9	-0.5	1.4	1	1	1
10/29/2020 06:00	-1.1	12.4	2,065.5	-0.5	1.4	1	1	1
10/29/2020 07:00	0.2	13.9	1,278.4	0.3	0.9	1	1	0
10/29/2020 08:00	0.2	13.9	1,295.7	0.3	0.9	1	1	0
10/29/2020 09:00	0.2	13.9	1,500.4	0.3	1.1	1	1	0
10/29/2020 10:00	0.2	13.9	1,501.2	0.3	1.1	1	1	0
10/29/2020 11:00	0.1	13.6	1,788.3	0.2	1.3	1	1	0
10/29/2020 12:00	0.1	13.6	1,807.6	0.2	1.3	1	1	0
10/29/2020 13:00	0.1	13.6	1,801.4	0.2	1.3	1	1	0
10/29/2020 14:00	0.1	13.6	1,801.6	0.2	1.3	1	1	0
10/29/2020 15:00	0.1	13.6	1,799.9	0.2	1.3	1	1	0
10/29/2020 16:00	0.1	13.7	1,762.9	0.2	1.2	1	1	0
10/29/2020 17:00	-0.4	13.8	1,759.5	-0.2	1.2	1	1	1
10/29/2020 18:00	-1.7	12.5	2,029.9	-0.9	1.4	1	1	1
10/29/2020 19:00	-1.5	12.3	2,074.9	-0.8	1.5	1	1	1
10/29/2020 20:00	-1.5	12.2	2,097.7	-0.8	1.5	1	1	1
10/29/2020 21:00	-1.5	12.2	2,091.7	-0.8	1.5	1	1	1
10/29/2020 22:00	-1.5	12.3	2,088.8	-0.8	1.5	1	1	1
10/29/2020 23:00	-1.5	12.9	1,941.2	-0.9	1.4	1	1	1
Average/Sum#:	-0.4	13.3	1,790.5	-0.1	1.3	24 #	24 #	10 #
Minimum:	-1.7	12.2	1,278.4	-0.9	0.9	1	1	0
Maximum:	0.2	13.9	2,097.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2020 00:00	0.2	13.9	1,620.6	0.3	1.1	1	1	0
10/30/2020 01:00	-0.5	13.6	1,696.1	-0.2	1.2	1	1	1
10/30/2020 02:00	-1.1	12.9	1,948.5	-0.7	1.4	1	1	1
10/30/2020 03:00	-0.9	12.8	1,949.6	-0.5	1.4	1	1	1
10/30/2020 04:00	0.2	13.9	1,698.2	0.3	1.2	1	1	0
10/30/2020 05:00	-1.1	12.9	1,829.6	-0.7	1.3	1	1	1
10/30/2020 06:00	-1.1	12.3	2,100.8	-0.5	1.5	1	1	1
10/30/2020 07:00	-0.9	11.7	2,241.2	-0.4	1.6	1	1	1
10/30/2020 08:00	-0.8	11.6	2,249.3	-0.2	1.6	1	1	1
10/30/2020 09:00	-0.8	11.6	2,210.3	-0.2	1.5	1	1	1
10/30/2020 10:00	-0.7	11.6	2,193.4	-0.2	1.5	1	1	1
10/30/2020 11:00	-0.8	12.5	1,992.9	-0.4	1.4	1	1	1
10/30/2020 12:00	0.3	13.9	1,653.3	0.4	1.2	1	1	0
10/30/2020 13:00	-0.8	13.3	1,813.2	-0.5	1.3	1	1	1
10/30/2020 14:00	-1.4	12.4	2,050.0	-0.8	1.4	1	1	1
10/30/2020 15:00	-1.4	12.0	2,117.3	-0.7	1.5	1	1	1
10/30/2020 16:00	-1.4	12.2	2,083.7	-0.7	1.5	1	1	1
10/30/2020 17:00	-1.4	11.8	2,169.3	-0.7	1.5	1	1	1
10/30/2020 18:00	-1.2	11.8	2,171.2	-0.5	1.5	1	1	1
10/30/2020 19:00	-1.2	11.7	2,205.8	-0.5	1.5	1	1	1
10/30/2020 20:00	-0.8	13.1	1,823.3	-0.5	1.3	1	1	1
10/30/2020 21:00	-0.9	13.3	1,838.3	-0.7	1.3	1	1	1
10/30/2020 22:00	-1.4	12.1	2,115.0	-0.7	1.5	1	1	1
10/30/2020 23:00	-1.4	12.9	1,934.7	-0.8	1.4	1	1	1
Average/Sum#:	-0.9	12.6	1,987.7	-0.4	1.4	24 #	24 #	21 #
Minimum:	-1.4	11.6	1,620.6	-0.8	1.1	1	1	0
Maximum:	0.3	13.9	2,249.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2020 00:00	0.2	13.9	1,569.3	0.3	1.1	1	1	0
10/31/2020 01:00	0.2	13.8	1,663.9	0.3	1.2	1	1	0
10/31/2020 02:00	-0.5	13.6	1,660.3	-0.2	1.2	1	1	1
10/31/2020 03:00	-1.1	12.4	2,054.8	-0.5	1.4	1	1	1
10/31/2020 04:00	-1.1	12.9	1,928.1	-0.7	1.3	1	1	1
10/31/2020 05:00	0.2	13.8	1,693.1	0.3	1.2	1	1	0
10/31/2020 06:00	0.2	13.8	1,693.8	0.3	1.2	1	1	0
10/31/2020 07:00	0.2	13.8	1,651.9	0.3	1.2	1	1	0
10/31/2020 08:00	0.1	13.8	1,532.2	0.2	1.1	1	1	0
10/31/2020 09:00	0.2	13.9	1,509.1	0.3	1.1	1	1	0
10/31/2020 10:00	0.2	13.9	1,639.5	0.3	1.1	1	1	0
10/31/2020 11:00	0.2	13.9	1,558.5	0.3	1.1	1	1	0
10/31/2020 12:00	0.2	13.9	1,556.5	0.3	1.1	1	1	0
10/31/2020 13:00	0.2	13.9	1,568.8	0.3	1.1	1	1	0
10/31/2020 14:00	0.2	13.9	1,604.4	0.3	1.1	1	1	0
10/31/2020 15:00	0.2	13.8	1,684.3	0.3	1.2	1	1	0
10/31/2020 16:00	-0.7	13.3	1,819.6	-0.4	1.3	1	1	1
10/31/2020 17:00	-1.4	12.5	2,010.0	-0.8	1.4	1	1	1
10/31/2020 18:00	-1.4	12.4	2,035.1	-0.8	1.4	1	1	1
10/31/2020 19:00	0.1	13.8	1,698.6	0.2	1.2	1	1	0
10/31/2020 20:00	-0.9	13.3	1,825.0	-0.7	1.3	1	1	1
10/31/2020 21:00	-1.4	12.4	2,067.2	-0.8	1.4	1	1	1
10/31/2020 22:00	-1.2	12.5	2,044.4	-0.7	1.4	1	1	1
10/31/2020 23:00	-0.9	12.5	2,032.4	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.4	1,754.2	-0.1	1.2	24 #	24 #	10 #
Minimum:	-1.4	12.4	1,509.1	-0.8	1.1	1	1	0
Maximum:	0.2	13.9	2,067.2	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2020 00:00	-0.9	12.5	2,030.9	-0.5	1.4	1	1	1
11/01/2020 01:00	-0.9	12.5	2,012.0	-0.5	1.4	1	1	1
11/01/2020 02:00	-0.1	13.8	1,681.1	0.1	1.2	1	1	1
11/01/2020 03:00	0.2	13.9	1,693.1	0.3	1.2	1	1	0
11/01/2020 04:00	-0.7	13.3	1,832.1	-0.4	1.3	1	1	1
11/01/2020 05:00	-1.1	12.3	2,066.3	-0.5	1.4	1	1	1
11/01/2020 06:00	-0.9	12.5	2,033.0	-0.5	1.4	1	1	1
11/01/2020 07:00	0.3	13.9	1,548.4	0.4	1.1	1	1	0
11/01/2020 08:00	0.2	13.9	1,695.4	0.3	1.2	1	1	0
11/01/2020 09:00	0.2	13.9	1,505.4	0.3	1.1	1	1	0
11/01/2020 10:00	0.2	13.9	1,576.7	0.3	1.1	1	1	0
11/01/2020 11:00	0.2	13.9	1,494.0	0.3	1.0	1	1	0
11/01/2020 12:00	0.2	13.9	1,578.6	0.3	1.1	1	1	0
11/01/2020 13:00	0.2	13.9	1,665.9	0.3	1.2	1	1	0
11/01/2020 14:00	0.2	13.8	1,681.2	0.3	1.2	1	1	0
11/01/2020 15:00	-0.4	13.6	1,678.2	-0.2	1.2	1	1	1
11/01/2020 16:00	-1.4	12.4	2,040.1	-0.8	1.4	1	1	1
11/01/2020 17:00	-1.2	11.9	2,154.4	-0.7	1.5	1	1	1
11/01/2020 18:00	-1.1	11.7	2,195.5	-0.5	1.5	1	1	1
11/01/2020 19:00	-1.1	11.9	2,157.7	-0.5	1.5	1	1	1
11/01/2020 20:00	-1.2	11.9	2,142.2	-0.7	1.5	1	1	1
11/01/2020 21:00	-1.1	11.6	2,208.0	-0.5	1.5	1	1	1
11/01/2020 22:00	-1.2	12.2	2,103.5	-0.7	1.5	1	1	1
11/01/2020 23:00	-1.1	12.3	2,105.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.5	13.0	1,870.0	-0.2	1.3	24 #	24 #	15 #
Minimum:	-1.4	11.6	1,494.0	-0.8	1.0	1	1	0
Maximum:	0.3	13.9	2,208.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2020 00:00	-0.9	12.1	2,123.3	-0.4	1.5	1	1	1
11/02/2020 01:00	-0.9	12.3	2,036.6	-0.5	1.4	1	1	1
11/02/2020 02:00	0.2	13.9	1,654.9	0.3	1.2	1	1	0
11/02/2020 03:00	-0.5	13.3	1,813.6	-0.2	1.3	1	1	1
11/02/2020 04:00	-1.1	12.1	2,120.5	-0.5	1.5	1	1	1
11/02/2020 05:00	-0.9	12.0	2,148.3	-0.4	1.5	1	1	1
11/02/2020 06:00	-0.9	12.1	2,093.4	-0.4	1.5	1	1	1
11/02/2020 07:00	0.3	13.9	1,636.3	0.4	1.1	1	1	0
11/02/2020 08:00	0.2	13.9	1,668.5	0.3	1.2	1	1	0
11/02/2020 09:00	0.2	13.9	1,692.6	0.3	1.2	1	1	0
11/02/2020 10:00	0.2	13.9	1,657.3	0.3	1.2	1	1	0
11/02/2020 11:00	0.2	13.9	1,665.0	0.3	1.2	1	1	0
11/02/2020 12:00	0.2	13.8	1,692.2	0.3	1.2	1	1	0
11/02/2020 13:00	0.2	13.7	1,699.1	0.3	1.2	1	1	0
11/02/2020 14:00	-0.5	13.6	1,727.4	-0.2	1.2	1	1	1
11/02/2020 15:00	-1.2	12.3	2,060.5	-0.7	1.4	1	1	1
11/02/2020 16:00	-0.9	11.5	2,202.3	-0.4	1.5	1	1	1
11/02/2020 17:00	-1.1	11.7	2,176.1	-0.5	1.5	1	1	1
11/02/2020 18:00	-0.9	11.6	2,201.8	-0.4	1.5	1	1	1
11/02/2020 19:00	-0.9	11.5	2,217.8	-0.4	1.6	1	1	1
11/02/2020 20:00	-0.9	11.6	2,206.5	-0.4	1.5	1	1	1
11/02/2020 21:00	-1.1	11.9	2,145.1	-0.5	1.5	1	1	1
11/02/2020 22:00	-1.1	12.0	2,125.3	-0.5	1.5	1	1	1
11/02/2020 23:00	-1.1	12.4	2,056.0	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.7	1,950.9	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.2	11.5	1,636.3	-0.7	1.1	1	1	0
Maximum:	0.3	13.9	2,217.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2020 00:00	-0.9	12.1	2,097.3	-0.4	1.5	1	1	1
11/03/2020 01:00	-0.9	12.5	1,974.6	-0.5	1.4	1	1	1
11/03/2020 02:00	0.2	13.8	1,695.2	0.3	1.2	1	1	0
11/03/2020 03:00	-0.7	13.3	1,829.4	-0.4	1.3	1	1	1
11/03/2020 04:00	-1.1	12.0	2,129.9	-0.5	1.5	1	1	1
11/03/2020 05:00	-0.9	11.9	2,151.7	-0.4	1.5	1	1	1
11/03/2020 06:00	-0.9	11.7	2,172.7	-0.4	1.5	1	1	1
11/03/2020 07:00	-0.8	12.3	2,045.9	-0.4	1.4	1	1	1
11/03/2020 08:00	0.2	13.8	1,664.5	0.3	1.2	1	1	0
11/03/2020 09:00	0.2	13.9	1,683.0	0.3	1.2	1	1	0
11/03/2020 10:00	0.2	13.9	1,686.4	0.3	1.2	1	1	0
11/03/2020 11:00	0.2	13.9	1,536.2	0.3	1.1	1	1	0
11/03/2020 12:00	0.2	13.9	1,535.5	0.3	1.1	1	1	0
11/03/2020 13:00	0.2	13.9	1,605.1	0.3	1.1	1	1	0
11/03/2020 14:00	0.2	13.9	1,676.2	0.3	1.2	1	1	0
11/03/2020 15:00	-0.8	13.3	1,812.8	-0.5	1.3	1	1	1
11/03/2020 16:00	-1.2	11.9	2,151.6	-0.7	1.5	1	1	1
11/03/2020 17:00	-1.1	11.7	2,189.1	-0.5	1.5	1	1	1
11/03/2020 18:00	-1.1	11.6	2,201.6	-0.5	1.5	1	1	1
11/03/2020 19:00	-0.9	11.6	2,210.4	-0.4	1.5	1	1	1
11/03/2020 20:00	-1.1	11.8	2,172.2	-0.5	1.5	1	1	1
11/03/2020 21:00	-1.1	11.9	2,155.4	-0.5	1.5	1	1	1
11/03/2020 22:00	-1.1	12.1	2,124.8	-0.5	1.5	1	1	1
11/03/2020 23:00	-1.2	12.5	2,058.4	-0.7	1.4	1	1	1
Average/Sum#:	-0.6	12.7	1,940.0	-0.2	1.4	24 #	24 #	16 #
Minimum:	-1.2	11.6	1,535.5	-0.7	1.1	1	1	0
Maximum:	0.2	13.9	2,210.4	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2020 00:00	-1.1	12.4	2,066.9	-0.5	1.4	1	1	1
11/04/2020 01:00	-0.9	12.8	1,935.3	-0.5	1.4	1	1	1
11/04/2020 02:00	0.2	13.8	1,695.0	0.3	1.2	1	1	0
11/04/2020 03:00	-0.7	13.3	1,825.3	-0.4	1.3	1	1	1
11/04/2020 04:00	-1.1	12.2	2,106.2	-0.5	1.5	1	1	1
11/04/2020 05:00	-1.1	12.0	2,155.7	-0.5	1.5	1	1	1
11/04/2020 06:00	-1.1	12.0	2,175.0	-0.5	1.5	1	1	1
11/04/2020 07:00	-0.9	12.4	2,041.5	-0.5	1.4	1	1	1
11/04/2020 08:00	0.2	13.8	1,696.7	0.3	1.2	1	1	0
11/04/2020 09:00	0.2	13.9	1,645.6	0.3	1.2	1	1	0
11/04/2020 10:00	0.2	13.9	1,545.1	0.3	1.1	1	1	0
11/04/2020 11:00	0.2	13.9	1,672.3	0.3	1.2	1	1	0
11/04/2020 12:00	0.2	13.9	1,694.7	0.3	1.2	1	1	0
11/04/2020 13:00	0.2	13.9	1,699.3	0.3	1.2	1	1	0
11/04/2020 14:00	-0.4	13.7	1,737.7	-0.2	1.2	1	1	1
11/04/2020 15:00	-1.2	12.4	2,047.7	-0.7	1.4	1	1	1
11/04/2020 16:00	-1.1	11.9	2,147.3	-0.5	1.5	1	1	1
11/04/2020 17:00	-1.1	11.7	2,182.3	-0.5	1.5	1	1	1
11/04/2020 18:00	-0.9	11.5	2,235.9	-0.4	1.6	1	1	1
11/04/2020 19:00	-0.9	11.6	2,220.7	-0.4	1.6	1	1	1
11/04/2020 20:00	-1.1	11.7	2,183.1	-0.5	1.5	1	1	1
11/04/2020 21:00	-1.1	11.8	2,172.0	-0.5	1.5	1	1	1
11/04/2020 22:00	-1.1	11.8	2,169.8	-0.5	1.5	1	1	1
11/04/2020 23:00	-1.1	12.1	2,133.6	-0.5	1.5	1	1	1
Average/Sum#:	-0.6	12.7	1,966.0	-0.3	1.4	24 #	24 #	17 #
Minimum:	-1.2	11.5	1,545.1	-0.7	1.1	1	1	0
Maximum:	0.2	13.9	2,235.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2020 00:00	-0.9	12.0	2,118.5	-0.4	1.5	1	1	1
11/05/2020 01:00	-0.8	12.2	2,047.8	-0.4	1.4	1	1	1
11/05/2020 02:00	0.2	13.9	1,647.4	0.3	1.2	1	1	0
11/05/2020 03:00	-0.7	13.2	1,826.4	-0.4	1.3	1	1	1
11/05/2020 04:00	-1.1	12.2	2,099.1	-0.5	1.5	1	1	1
11/05/2020 05:00	-0.9	11.9	2,139.3	-0.4	1.5	1	1	1
11/05/2020 06:00	-0.9	12.1	2,120.0	-0.4	1.5	1	1	1
11/05/2020 07:00	-0.9	12.6	2,002.8	-0.5	1.4	1	1	1
11/05/2020 08:00	0.2	13.8	1,601.2	0.3	1.1	1	1	0
11/05/2020 09:00	0.2	13.8	1,683.6	0.3	1.2	1	1	0
11/05/2020 10:00	0.2	13.9	1,592.1	0.3	1.1	1	1	0
11/05/2020 11:00	0.2	13.9	1,585.9	0.3	1.1	1	1	0
11/05/2020 12:00	0.2	13.8	1,680.8	0.3	1.2	1	1	0
11/05/2020 13:00	0.2	13.8	1,574.8	0.3	1.1	1	1	0
11/05/2020 14:00	-0.5	13.4	1,760.5	-0.2	1.2	1	1	1
11/05/2020 15:00	-1.1	11.7	2,158.2	-0.5	1.5	1	1	1
11/05/2020 16:00	-1.2	12.1	2,067.2	-0.7	1.4	1	1	1
11/05/2020 17:00	-1.1	11.8	2,150.2	-0.5	1.5	1	1	1
11/05/2020 18:00	-1.1	11.7	2,156.6	-0.5	1.5	1	1	1
11/05/2020 19:00	-1.2	12.1	2,083.2	-0.7	1.5	1	1	1
11/05/2020 20:00	-1.1	11.6	2,191.1	-0.5	1.5	1	1	1
11/05/2020 21:00	-1.1	11.5	2,218.8	-0.5	1.6	1	1	1
11/05/2020 22:00	-1.2	12.0	2,109.5	-0.7	1.5	1	1	1
11/05/2020 23:00	-1.2	12.0	2,114.9	-0.7	1.5	1	1	1
Average/Sum#:	-0.7	12.6	1,947.1	-0.3	1.4	24 #	24 #	17 #
Minimum:	-1.2	11.5	1,574.8	-0.7	1.1	1	1	0
Maximum:	0.2	13.9	2,218.8	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2020 00:00	-1.2	12.0	2,101.9	-0.7	1.5	1	1	1
11/06/2020 01:00	-1.4	12.8	1,928.1	-0.8	1.3	1	1	1
11/06/2020 02:00	0.1	13.8	1,651.1	0.1	1.2	1	1	0
11/06/2020 03:00	0.1	13.8	1,611.0	0.2	1.1	1	1	0
11/06/2020 04:00	-0.9	13.2	1,828.4	-0.5	1.3	1	1	1
11/06/2020 05:00	-1.2	11.9	2,131.3	-0.7	1.5	1	1	1
11/06/2020 06:00	-1.1	12.4	2,044.5	-0.5	1.4	1	1	1
11/06/2020 07:00	-0.9	12.0	2,099.5	-0.4	1.5	1	1	1
11/06/2020 08:00	0.2	13.9	1,428.8	0.3	1.0	1	1	0
11/06/2020 09:00	0.2	13.9	1,347.2	0.3	0.9	1	1	0
11/06/2020 10:00	0.2	13.9	1,318.4	0.3	0.9	1	1	0
11/06/2020 11:00	0.2	13.9	1,299.4	0.3	0.9	1	1	0
11/06/2020 12:00	0.2	13.9	1,433.6	0.3	1.0	1	1	0
11/06/2020 13:00	0.2	13.9	1,412.2	0.3	1.0	1	1	0
11/06/2020 14:00	0.1	13.9	1,332.7	0.2	0.9	1	1	0
11/06/2020 15:00	-0.9	13.2	1,832.6	-0.5	1.3	1	1	1
11/06/2020 16:00	-1.4	11.9	2,142.0	-0.7	1.5	1	1	1
11/06/2020 17:00	-1.1	11.8	2,152.8	-0.5	1.5	1	1	1
11/06/2020 18:00	-0.9	11.8	2,162.2	-0.4	1.5	1	1	1
11/06/2020 19:00	-1.1	12.5	2,011.8	-0.5	1.4	1	1	1
11/06/2020 20:00	-1.1	12.8	1,937.7	-0.7	1.4	1	1	1
11/06/2020 21:00	0.2	13.8	1,534.8	0.3	1.1	1	1	0
11/06/2020 22:00	-0.4	13.6	1,751.2	-0.2	1.2	1	1	1
11/06/2020 23:00	-0.9	12.6	1,998.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.5	13.1	1,770.5	-0.2	1.2	24 #	24 #	14 #
Minimum:	-1.4	11.8	1,299.4	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,162.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2020 00:00	-0.9	13.0	1,915.2	-0.5	1.3	1	1	1
11/07/2020 01:00	0.2	13.8	1,690.1	0.3	1.2	1	1	0
11/07/2020 02:00	-0.5	13.6	1,724.6	-0.2	1.2	1	1	1
11/07/2020 03:00	-1.2	13.0	1,931.8	-0.8	1.4	1	1	1
11/07/2020 04:00	-1.2	13.0	1,924.6	-0.8	1.3	1	1	1
11/07/2020 05:00	0.1	13.8	1,645.2	0.2	1.2	1	1	0
11/07/2020 06:00	0.1	13.8	1,613.7	0.2	1.1	1	1	0
11/07/2020 07:00	0.2	13.8	1,596.3	0.3	1.1	1	1	0
11/07/2020 08:00	0.1	13.8	1,659.6	0.2	1.2	1	1	0
11/07/2020 09:00	0.1	13.8	1,558.0	0.2	1.1	1	1	0
11/07/2020 10:00	0.1	13.9	1,414.6	0.2	1.0	1	1	0
11/07/2020 11:00	0.1	13.8	1,400.9	0.2	1.0	1	1	0
11/07/2020 12:00	0.2	13.8	1,582.3	0.3	1.1	1	1	0
11/07/2020 13:00	0.2	13.8	1,489.2	0.3	1.0	1	1	0
11/07/2020 14:00	0.1	13.8	1,480.7	0.2	1.0	1	1	0
11/07/2020 15:00	-0.2	13.8	1,555.7	-0.1	1.1	1	1	1
11/07/2020 16:00	-1.5	12.3	2,064.3	-0.8	1.4	1	1	1
11/07/2020 17:00	-1.2	11.9	2,137.0	-0.7	1.5	1	1	1
11/07/2020 18:00	-1.1	12.1	2,069.1	-0.5	1.4	1	1	1
11/07/2020 19:00	-1.2	12.3	2,053.4	-0.7	1.4	1	1	1
11/07/2020 20:00	-1.1	12.6	1,959.0	-0.7	1.4	1	1	1
11/07/2020 21:00	0.6	0.0	1,580.6	0.6	1.1	1	1	0
11/07/2020 22:00	-0.4	12.8	1,827.7	-0.1	1.3	1	1	1
11/07/2020 23:00	-0.4	11.9	2,113.8	-0.1	1.5	1	1	1
Average/Sum#:	-0.4	13.2	1,749.5	-0.1	1.2	24 #	24 #	12 #
Minimum:	-1.5	11.9	1,400.9	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,137.0	0.3	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2020 00:00	-0.4	12.5	1,977.1	-0.1	1.4	1	1	1
11/08/2020 01:00	0.4	13.7	1,578.5	0.4	1.1	1	1	1
11/08/2020 02:00	0.4	13.7	1,561.9	0.4	1.1	1	1	1
11/08/2020 03:00	-0.9	12.9	1,930.9	-0.5	1.4	1	1	1
11/08/2020 04:00	-0.8	12.9	1,917.7	-0.4	1.3	1	1	1
11/08/2020 05:00	0.4	13.7	1,689.1	0.4	1.2	1	1	0
11/08/2020 06:00	0.4	13.7	1,655.8	0.4	1.2	1	1	0
11/08/2020 07:00	0.4	13.7	1,579.4	0.4	1.1	1	1	0
11/08/2020 08:00	0.4	13.7	1,663.9	0.4	1.2	1	1	0
11/08/2020 09:00	0.4	13.7	1,661.0	0.4	1.2	1	1	0
11/08/2020 10:00	0.4	13.8	1,701.4	0.4	1.2	1	1	0
11/08/2020 11:00	0.4	13.8	1,552.2	0.4	1.1	1	1	0
11/08/2020 12:00	0.4	13.8	1,444.4	0.4	1.0	1	1	0
11/08/2020 13:00	0.4	13.8	1,664.0	0.4	1.2	1	1	0
11/08/2020 14:00	0.4	13.8	1,670.4	0.4	1.2	1	1	0
11/08/2020 15:00	0.4	13.8	1,694.5	0.4	1.2	1	1	0
11/08/2020 16:00	-0.2	13.1	1,853.1	-0.1	1.3	1	1	1
11/08/2020 17:00	-0.5	11.7	2,195.3	-0.1	1.5	1	1	1
11/08/2020 18:00	-0.5	12.1	2,098.5	-0.1	1.5	1	1	1
11/08/2020 19:00	-0.5	12.2	2,058.7	-0.1	1.4	1	1	1
11/08/2020 20:00	0.5	13.7	1,667.7	0.5	1.2	1	1	0
11/08/2020 21:00	0.4	13.7	1,594.7	0.4	1.1	1	1	0
11/08/2020 22:00	-0.2	13.3	1,821.2	-0.1	1.3	1	1	1
11/08/2020 23:00	-0.7	12.1	2,118.9	-0.2	1.5	1	1	1
Average/Sum#:	0.1	13.3	1,764.6	0.2	1.2	24 #	24 #	11 #
Minimum:	-0.9	11.7	1,444.4	-0.5	1.0	1	1	0
Maximum:	0.5	13.8	2,195.3	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2020 00:00	-0.5	12.8	1,941.3	-0.2	1.4	1	1	1
11/09/2020 01:00	0.5	13.7	1,534.4	0.5	1.1	1	1	0
11/09/2020 02:00	0.4	13.8	1,305.0	0.4	0.9	1	1	0
11/09/2020 03:00	0.4	13.8	1,321.4	0.4	0.9	1	1	0
11/09/2020 04:00	-0.1	13.2	1,766.4	0.1	1.2	1	1	1
11/09/2020 05:00	-0.2	11.8	2,179.0	0.1	1.5	1	1	1
11/09/2020 06:00	-0.4	11.5	2,274.0	0.1	1.6	1	1	1
11/09/2020 07:00	-0.4	12.3	2,093.1	-0.1	1.5	1	1	1
11/09/2020 08:00	-0.5	12.9	1,947.9	-0.2	1.4	1	1	1
11/09/2020 09:00	0.5	13.8	1,525.6	0.5	1.1	1	1	0
11/09/2020 10:00	0.4	13.8	1,551.7	0.4	1.1	1	1	0
11/09/2020 11:00	0.5	13.8	1,448.0	0.5	1.0	1	1	0
11/09/2020 12:00	0.5	13.8	1,479.3	0.5	1.0	1	1	0
11/09/2020 13:00	0.4	13.8	1,419.4	0.4	1.0	1	1	0
11/09/2020 14:00	0.4	13.8	1,625.1	0.4	1.1	1	1	0
11/09/2020 15:00	-0.1	13.3	1,815.6	0.1	1.3	1	1	1
11/09/2020 16:00	-0.4	12.4	2,049.4	-0.1	1.4	1	1	1
11/09/2020 17:00	-0.2	12.3	2,076.2	0.1	1.5	1	1	1
11/09/2020 18:00	-0.2	12.1	2,123.0	0.1	1.5	1	1	1
11/09/2020 19:00	-0.2	12.1	2,127.6	0.1	1.5	1	1	1
11/09/2020 20:00	-0.4	11.6	2,243.7	0.1	1.6	1	1	1
11/09/2020 21:00	-0.4	11.7	2,201.7	0.1	1.5	1	1	1
11/09/2020 22:00	-0.4	12.3	2,080.3	-0.1	1.5	1	1	1
11/09/2020 23:00	-0.5	12.6	2,039.9	-0.2	1.4	1	1	1
Average/Sum#:	0.0	12.9	1,840.4	0.2	1.3	24 #	24 #	15 #
Minimum:	-0.5	11.5	1,305.0	-0.2	0.9	1	1	0
Maximum:	0.5	13.8	2,274.0	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2020 00:00	-0.5	12.6	2,047.2	-0.2	1.4	1	1	1
11/10/2020 01:00	-0.7	12.9	1,947.2	-0.4	1.4	1	1	1
11/10/2020 02:00	0.5	13.7	1,687.3	0.5	1.2	1	1	0
11/10/2020 03:00	-0.1	13.4	1,822.5	0.1	1.3	1	1	1
11/10/2020 04:00	-0.4	12.7	2,019.9	-0.1	1.4	1	1	1
11/10/2020 05:00	-0.4	12.6	2,037.0	-0.1	1.4	1	1	1
11/10/2020 06:00	-0.7	12.6	2,050.0	-0.2	1.4	1	1	1
11/10/2020 07:00	-0.5	12.8	2,018.1	-0.2	1.4	1	1	1
11/10/2020 08:00	-0.8	13.0	1,953.1	-0.4	1.4	1	1	1
11/10/2020 09:00	0.4	13.7	1,655.9	0.4	1.2	1	1	0
11/10/2020 10:00	0.4	13.7	1,664.5	0.4	1.2	1	1	0
11/10/2020 11:00	0.4	13.8	1,392.8	0.4	1.0	1	1	0
11/10/2020 12:00	0.4	13.8	1,511.0	0.4	1.1	1	1	0
11/10/2020 13:00	0.4	13.8	1,530.4	0.4	1.1	1	1	0
11/10/2020 14:00	0.4	13.8	1,412.2	0.4	1.0	1	1	0
11/10/2020 15:00	0.1	13.5	1,667.2	0.2	1.2	1	1	1
11/10/2020 16:00	-0.7	12.5	2,014.8	-0.2	1.4	1	1	1
11/10/2020 17:00	-0.5	12.1	2,112.6	-0.1	1.5	1	1	1
11/10/2020 18:00	-0.4	11.5	2,234.0	0.1	1.6	1	1	1
11/10/2020 19:00	-0.4	11.5	2,222.4	0.1	1.6	1	1	1
11/10/2020 20:00	-0.5	11.9	2,150.5	-0.1	1.5	1	1	1
11/10/2020 21:00	-0.5	12.0	2,128.9	-0.1	1.5	1	1	1
11/10/2020 22:00	-0.5	12.3	2,079.9	-0.1	1.5	1	1	1
11/10/2020 23:00	-0.5	12.4	2,061.4	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	12.9	1,892.5	0.0	1.3	24 #	24 #	17 #
Minimum:	-0.8	11.5	1,392.8	-0.4	1.0	1	1	0
Maximum:	0.5	13.8	2,234.0	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2020 00:00	-0.5	12.4	2,060.5	-0.2	1.4	1	1	1
11/11/2020 01:00	-0.7	12.9	1,941.0	-0.4	1.4	1	1	1
11/11/2020 02:00	0.4	13.7	1,590.7	0.4	1.1	1	1	0
11/11/2020 03:00	-0.2	13.3	1,846.9	-0.1	1.3	1	1	1
11/11/2020 04:00	-0.5	12.6	2,034.3	-0.2	1.4	1	1	1
11/11/2020 05:00	-0.7	12.3	2,072.8	-0.2	1.5	1	1	1
11/11/2020 06:00	-0.7	11.9	2,171.3	-0.2	1.5	1	1	1
11/11/2020 07:00	-0.7	12.7	1,996.5	-0.2	1.4	1	1	1
11/11/2020 08:00	0.4	13.7	1,684.4	0.4	1.2	1	1	0
11/11/2020 09:00	0.4	13.7	1,682.7	0.4	1.2	1	1	0
11/11/2020 10:00	0.4	13.7	1,653.9	0.4	1.2	1	1	0
11/11/2020 11:00	0.4	13.7	1,571.0	0.4	1.1	1	1	0
11/11/2020 12:00	0.4	13.7	1,657.8	0.4	1.2	1	1	0
11/11/2020 13:00	0.4	13.8	1,528.0	0.4	1.1	1	1	0
11/11/2020 14:00	0.4	13.7	1,688.7	0.4	1.2	1	1	0
11/11/2020 15:00	0.4	13.8	1,385.8	0.4	1.0	1	1	0
11/11/2020 16:00	-0.5	13.0	1,869.7	-0.2	1.3	1	1	1
11/11/2020 17:00	-0.7	12.4	2,030.0	-0.2	1.4	1	1	1
11/11/2020 18:00	-0.7	12.1	2,091.9	-0.2	1.5	1	1	1
11/11/2020 19:00	-0.7	12.3	2,066.1	-0.2	1.4	1	1	1
11/11/2020 20:00	-0.7	12.5	2,017.6	-0.2	1.4	1	1	1
11/11/2020 21:00	0.4	13.7	1,665.5	0.4	1.2	1	1	0
11/11/2020 22:00	-0.2	13.3	1,829.8	-0.1	1.3	1	1	1
11/11/2020 23:00	-0.7	12.6	2,034.8	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	13.1	1,840.5	0.1	1.3	24 #	24 #	14 #
Minimum:	-0.7	11.9	1,385.8	-0.4	1.0	1	1	0
Maximum:	0.4	13.8	2,171.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2020 00:00	-0.7	12.5	2,045.9	-0.2	1.4	1	1	1
11/12/2020 01:00	-0.8	13.1	1,919.8	-0.5	1.3	1	1	1
11/12/2020 02:00	0.4	13.7	1,570.9	0.4	1.1	1	1	0
11/12/2020 03:00	0.1	13.5	1,698.9	0.2	1.2	1	1	1
11/12/2020 04:00	-0.7	12.6	2,044.8	-0.2	1.4	1	1	1
11/12/2020 05:00	-0.8	12.2	2,081.5	-0.4	1.5	1	1	1
11/12/2020 06:00	-0.7	11.6	2,246.7	-0.2	1.6	1	1	1
11/12/2020 07:00	-0.5	12.2	2,106.4	-0.1	1.5	1	1	1
11/12/2020 08:00	0.4	13.7	1,630.1	0.4	1.1	1	1	0
11/12/2020 09:00	0.4	13.7	1,638.6	0.4	1.1	1	1	0
11/12/2020 10:00	0.4	13.7	1,678.2	0.4	1.2	1	1	0
11/12/2020 11:00	0.4	13.7	1,609.2	0.4	1.1	1	1	0
11/12/2020 12:00	0.4	13.7	1,697.4	0.4	1.2	1	1	0
11/12/2020 13:00	0.4	13.8	1,577.7	0.4	1.1	1	1	0
11/12/2020 14:00	0.4	13.8	1,568.2	0.4	1.1	1	1	0
11/12/2020 15:00	-0.1	13.5	1,691.9	0.1	1.2	1	1	1
11/12/2020 16:00	-0.8	12.2	2,070.4	-0.4	1.4	1	1	1
11/12/2020 17:00	-0.7	12.1	2,091.8	-0.2	1.5	1	1	1
11/12/2020 18:00	-0.7	12.0	2,114.3	-0.2	1.5	1	1	1
11/12/2020 19:00	-0.7	11.9	2,140.2	-0.2	1.5	1	1	1
11/12/2020 20:00	-0.7	12.3	2,030.4	-0.2	1.4	1	1	1
11/12/2020 21:00	0.4	13.7	1,665.3	0.4	1.2	1	1	0
11/12/2020 22:00	-0.4	13.3	1,829.8	-0.1	1.3	1	1	1
11/12/2020 23:00	-0.8	12.5	2,038.6	-0.4	1.4	1	1	1
Average/Sum#:	-0.2	13.0	1,866.1	0.0	1.3	24 #	24 #	15 #
Minimum:	-0.8	11.6	1,568.2	-0.5	1.1	1	1	0
Maximum:	0.4	13.8	2,246.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2020 00:00	-1.1	13.0	1,924.6	-0.7	1.3	1	1	1
11/13/2020 01:00	-0.2	13.6	1,503.0	-0.1	1.1	1	1	1
11/13/2020 02:00	0.4	13.8	1,295.4	0.4	0.9	1	1	0
11/13/2020 03:00	0.3	13.7	1,362.8	0.4	1.0	1	1	0
11/13/2020 04:00	0.3	13.7	1,325.7	0.4	0.9	1	1	0
11/13/2020 05:00	0.4	13.7	1,593.2	0.4	1.1	1	1	0
11/13/2020 06:00	0.4	13.7	1,726.3	0.4	1.2	1	1	0
11/13/2020 07:00	-0.7	13.3	1,825.5	-0.4	1.3	1	1	1
11/13/2020 08:00	-0.7	12.9	1,870.3	-0.4	1.3	1	1	1
11/13/2020 09:00	0.4	13.7	1,682.3	0.4	1.2	1	1	0
11/13/2020 10:00	0.4	13.7	1,682.1	0.4	1.2	1	1	0
11/13/2020 11:00	0.4	13.7	1,657.5	0.4	1.2	1	1	0
11/13/2020 12:00	0.4	13.7	1,536.3	0.4	1.1	1	1	0
11/13/2020 13:00	0.4	13.7	1,655.6	0.4	1.2	1	1	0
11/13/2020 14:00	0.4	13.7	1,664.2	0.4	1.2	1	1	0
11/13/2020 15:00	-0.2	13.2	1,769.9	-0.1	1.2	1	1	1
11/13/2020 16:00	-0.8	11.9	2,098.0	-0.4	1.5	1	1	1
11/13/2020 17:00	-0.7	12.0	2,071.9	-0.2	1.5	1	1	1
11/13/2020 18:00	-0.7	12.2	2,054.7	-0.2	1.4	1	1	1
11/13/2020 19:00	-0.8	12.8	1,924.3	-0.4	1.3	1	1	1
11/13/2020 20:00	0.4	13.6	1,687.3	0.4	1.2	1	1	0
11/13/2020 21:00	-0.2	13.4	1,692.1	-0.1	1.2	1	1	1
11/13/2020 22:00	-0.8	12.4	2,032.4	-0.4	1.4	1	1	1
11/13/2020 23:00	-0.2	13.3	1,645.2	-0.1	1.2	1	1	1
Average/Sum#:	-0.1	13.3	1,720.0	0.1	1.2	24 #	24 #	12 #
Minimum:	-1.1	11.9	1,295.4	-0.7	0.9	1	1	0
Maximum:	0.4	13.8	2,098.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2020 00:00	0.4	13.7	1,360.0	0.4	1.0	1	1	0
11/14/2020 01:00	0.4	13.7	1,360.4	0.4	1.0	1	1	0
11/14/2020 02:00	0.4	13.7	1,353.7	0.4	0.9	1	1	0
11/14/2020 03:00	0.4	13.7	1,359.9	0.4	1.0	1	1	0
11/14/2020 04:00	0.4	13.8	1,349.6	0.4	0.9	1	1	0
11/14/2020 05:00	0.4	13.6	1,663.6	0.4	1.2	1	1	0
11/14/2020 06:00	0.4	13.7	1,519.5	0.4	1.1	1	1	0
11/14/2020 07:00	0.4	13.7	1,605.7	0.4	1.1	1	1	0
11/14/2020 08:00	0.4	13.6	1,690.7	0.4	1.2	1	1	0
11/14/2020 09:00	0.4	13.6	1,682.6	0.4	1.2	1	1	0
11/14/2020 10:00	0.4	13.7	1,691.2	0.4	1.2	1	1	0
11/14/2020 11:00	0.4	13.7	1,696.5	0.4	1.2	1	1	0
11/14/2020 12:00	0.4	13.7	1,687.0	0.4	1.2	1	1	0
11/14/2020 13:00	0.4	13.7	1,688.9	0.4	1.2	1	1	0
11/14/2020 14:00	0.4	13.7	1,659.1	0.4	1.2	1	1	0
11/14/2020 15:00	0.1	13.5	1,707.7	0.2	1.2	1	1	1
11/14/2020 16:00	-0.7	12.4	2,043.4	-0.2	1.4	1	1	1
11/14/2020 17:00	-0.7	12.3	2,064.1	-0.2	1.4	1	1	1
11/14/2020 18:00	-0.7	12.3	2,064.6	-0.2	1.4	1	1	1
11/14/2020 19:00	-0.7	12.5	2,010.5	-0.2	1.4	1	1	1
11/14/2020 20:00	0.4	13.7	1,668.5	0.4	1.2	1	1	0
11/14/2020 21:00	-0.2	13.3	1,831.7	-0.1	1.3	1	1	1
11/14/2020 22:00	-0.5	12.5	2,043.4	-0.2	1.4	1	1	1
11/14/2020 23:00	-0.5	12.9	1,956.0	-0.2	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,698.3	0.2	1.2	24 #	24 #	8 #
Minimum:	-0.7	12.3	1,349.6	-0.2	0.9	1	1	0
Maximum:	0.4	13.8	2,064.6	0.4	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2020 00:00	-0.5	12.5	2,037.6	-0.2	1.4	1	1	1
11/15/2020 01:00	-0.5	12.9	1,938.8	-0.2	1.4	1	1	1
11/15/2020 02:00	0.4	13.7	1,624.8	0.4	1.1	1	1	0
11/15/2020 03:00	-0.2	13.5	1,701.5	-0.1	1.2	1	1	1
11/15/2020 04:00	-0.8	12.6	2,018.8	-0.4	1.4	1	1	1
11/15/2020 05:00	-1.1	13.1	1,926.5	-0.7	1.3	1	1	1
11/15/2020 06:00	0.4	13.7	1,656.2	0.4	1.2	1	1	0
11/15/2020 07:00	0.4	13.7	1,484.6	0.4	1.0	1	1	0
11/15/2020 08:00	0.4	13.7	1,669.9	0.4	1.2	1	1	0
11/15/2020 09:00	0.4	13.7	1,689.5	0.4	1.2	1	1	0
11/15/2020 10:00	0.4	13.7	1,708.3	0.4	1.2	1	1	0
11/15/2020 11:00	0.4	13.7	1,698.8	0.4	1.2	1	1	0
11/15/2020 12:00	0.4	13.7	1,694.5	0.4	1.2	1	1	0
11/15/2020 13:00	0.4	13.7	1,696.4	0.4	1.2	1	1	0
11/15/2020 14:00	0.4	13.7	1,690.7	0.4	1.2	1	1	0
11/15/2020 15:00	0.4	13.7	1,462.4	0.4	1.0	1	1	0
11/15/2020 16:00	0.4	13.7	1,572.8	0.4	1.1	1	1	0
11/15/2020 17:00	0.4	13.7	1,573.2	0.4	1.1	1	1	0
11/15/2020 18:00	0.4	13.7	1,605.1	0.4	1.1	1	1	0
11/15/2020 19:00	0.4	13.7	1,637.7	0.4	1.1	1	1	0
11/15/2020 20:00	-0.2	13.3	1,824.8	-0.1	1.3	1	1	1
11/15/2020 21:00	-0.4	12.8	1,901.8	-0.1	1.3	1	1	1
11/15/2020 22:00	-0.1	13.5	1,746.4	0.1	1.2	1	1	1
11/15/2020 23:00	-0.7	12.5	2,029.5	-0.2	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,732.9	0.2	1.2	24 #	24 #	9 #
Minimum:	-1.1	12.5	1,462.4	-0.7	1.0	1	1	0
Maximum:	0.4	13.7	2,037.6	0.4	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2020 00:00	-0.5	13.1	1,826.1	-0.2	1.3	1	1	1
11/16/2020 01:00	0.4	13.8	1,301.4	0.4	0.9	1	1	0
11/16/2020 02:00	0.4	13.8	1,294.8	0.4	0.9	1	1	0
11/16/2020 03:00	0.4	13.8	1,293.8	0.4	0.9	1	1	0
11/16/2020 04:00	0.1	13.6	1,687.7	0.2	1.2	1	1	1
11/16/2020 05:00	-0.5	12.3	2,034.0	-0.1	1.4	1	1	1
11/16/2020 06:00	-0.4	12.1	2,089.2	-0.1	1.5	1	1	1
11/16/2020 07:00	-0.4	12.4	1,988.0	-0.1	1.4	1	1	1
11/16/2020 08:00	0.4	13.7	1,695.1	0.4	1.2	1	1	0
11/16/2020 09:00	0.4	13.7	1,640.3	0.4	1.1	1	1	0
11/16/2020 10:00	0.4	13.7	1,681.2	0.4	1.2	1	1	0
11/16/2020 11:00	0.5	13.7	1,695.0	0.5	1.2	1	1	0
11/16/2020 12:00	0.5	13.7	1,683.5	0.5	1.2	1	1	0
11/16/2020 13:00	0.4	13.7	1,684.8	0.4	1.2	1	1	0
11/16/2020 14:00	0.4	13.7	1,629.0	0.4	1.1	1	1	0
11/16/2020 15:00	0.1	13.4	1,723.3	0.2	1.2	1	1	1
11/16/2020 16:00	-0.7	12.2	2,040.9	-0.2	1.4	1	1	1
11/16/2020 17:00	-0.5	11.9	2,111.4	-0.1	1.5	1	1	1
11/16/2020 18:00	-0.5	11.7	2,140.3	-0.1	1.5	1	1	1
11/16/2020 19:00	-0.5	11.8	2,128.9	-0.1	1.5	1	1	1
11/16/2020 20:00	-0.5	11.8	2,122.4	-0.1	1.5	1	1	1
11/16/2020 21:00	-0.5	12.1	2,072.0	-0.1	1.5	1	1	1
11/16/2020 22:00	-0.5	12.1	2,084.2	-0.1	1.5	1	1	1
11/16/2020 23:00	-0.5	12.3	2,056.5	-0.1	1.4	1	1	1
Average/Sum#:	-0.1	12.9	1,821.0	0.1	1.3	24 #	24 #	14 #
Minimum:	-0.7	11.7	1,293.8	-0.2	0.9	1	1	0
Maximum:	0.5	13.8	2,140.3	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2020 00:00	-0.5	12.2	2,059.7	-0.1	1.4	1	1	1
11/17/2020 01:00	-0.4	12.4	1,992.0	-0.1	1.4	1	1	1
11/17/2020 02:00	0.4	13.7	1,542.4	0.4	1.1	1	1	0
11/17/2020 03:00	0.4	13.7	1,529.5	0.4	1.1	1	1	0
11/17/2020 04:00	-0.1	13.5	1,732.3	0.1	1.2	1	1	1
11/17/2020 05:00	-0.8	12.2	2,051.1	-0.4	1.4	1	1	1
11/17/2020 06:00	-0.8	11.8	2,150.8	-0.2	1.5	1	1	1
11/17/2020 07:00	-0.8	12.4	2,002.6	-0.4	1.4	1	1	1
11/17/2020 08:00	0.4	13.7	1,671.8	0.4	1.2	1	1	0
11/17/2020 09:00	0.4	13.7	1,569.2	0.4	1.1	1	1	0
11/17/2020 10:00	0.4	13.7	1,557.1	0.4	1.1	1	1	0
11/17/2020 11:00	0.4	13.6	1,699.5	0.4	1.2	1	1	0
11/17/2020 12:00	0.4	13.7	1,469.9	0.4	1.0	1	1	0
11/17/2020 13:00	0.4	13.6	1,576.0	0.4	1.1	1	1	0
11/17/2020 14:00	0.4	13.6	1,608.8	0.4	1.1	1	1	0
11/17/2020 15:00	-0.4	13.0	1,825.2	-0.1	1.3	1	1	1
11/17/2020 16:00	-0.8	11.7	2,130.3	-0.2	1.5	1	1	1
11/17/2020 17:00	-0.5	11.5	2,163.1	-0.1	1.5	1	1	1
11/17/2020 18:00	-0.5	11.6	2,164.5	-0.1	1.5	1	1	1
11/17/2020 19:00	-0.5	11.7	2,130.3	-0.1	1.5	1	1	1
11/17/2020 20:00	-0.7	12.0	2,072.1	-0.2	1.5	1	1	1
11/17/2020 21:00	-0.7	12.0	2,071.0	-0.2	1.4	1	1	1
11/17/2020 22:00	-0.7	12.0	2,074.9	-0.2	1.5	1	1	1
11/17/2020 23:00	-0.7	12.5	1,982.2	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	12.7	1,867.8	0.0	1.3	24 #	24 #	15 #
Minimum:	-0.8	11.5	1,469.9	-0.4	1.0	1	1	0
Maximum:	0.4	13.7	2,164.5	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2020 00:00	-0.7	12.1	2,066.0	-0.2	1.4	1	1	1
11/18/2020 01:00	-0.5	12.9	1,822.8	-0.2	1.3	1	1	1
11/18/2020 02:00	0.4	13.7	1,405.2	0.4	1.0	1	1	0
11/18/2020 03:00	0.4	13.7	1,304.1	0.4	0.9	1	1	0
11/18/2020 04:00	-0.1	13.4	1,700.6	0.1	1.2	1	1	1
11/18/2020 05:00	-0.8	12.0	2,069.5	-0.4	1.4	1	1	1
11/18/2020 06:00	-0.7	11.7	2,134.3	-0.2	1.5	1	1	1
11/18/2020 07:00	-0.5	12.4	1,983.4	-0.2	1.4	1	1	1
11/18/2020 08:00	0.4	13.7	1,518.7	0.4	1.1	1	1	0
11/18/2020 09:00	0.4	13.7	1,522.7	0.4	1.1	1	1	0
11/18/2020 10:00	0.4	13.7	1,584.9	0.4	1.1	1	1	0
11/18/2020 11:00	0.4	13.7	1,694.7	0.4	1.2	1	1	0
11/18/2020 12:00	0.4	13.7	1,674.7	0.4	1.2	1	1	0
11/18/2020 13:00	0.4	13.8	1,591.5	0.4	1.1	1	1	0
11/18/2020 14:00	0.4	13.8	1,522.5	0.4	1.1	1	1	0
11/18/2020 15:00	-0.1	13.5	1,712.2	0.1	1.2	1	1	1
11/18/2020 16:00	-1.1	12.6	2,012.3	-0.7	1.4	1	1	1
11/18/2020 17:00	-0.9	12.3	2,061.3	-0.5	1.4	1	1	1
11/18/2020 18:00	-0.8	12.1	2,112.2	-0.4	1.5	1	1	1
11/18/2020 19:00	-0.7	12.6	1,975.3	-0.2	1.4	1	1	1
11/18/2020 20:00	-0.9	12.9	1,940.7	-0.5	1.4	1	1	1
11/18/2020 21:00	-0.9	12.9	1,943.0	-0.5	1.4	1	1	1
11/18/2020 22:00	-0.9	12.9	1,949.8	-0.5	1.4	1	1	1
11/18/2020 23:00	-0.9	13.0	1,945.2	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	13.0	1,802.0	-0.1	1.3	24 #	24 #	15 #
Minimum:	-1.1	11.7	1,304.1	-0.7	0.9	1	1	0
Maximum:	0.4	13.8	2,134.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2020 00:00	-0.9	13.0	1,922.1	-0.5	1.3	1	1	1
11/19/2020 01:00	0.4	13.7	1,533.2	0.4	1.1	1	1	0
11/19/2020 02:00	0.4	13.8	1,377.0	0.4	1.0	1	1	0
11/19/2020 03:00	0.4	13.8	1,306.5	0.4	0.9	1	1	0
11/19/2020 04:00	0.4	13.8	1,302.7	0.4	0.9	1	1	0
11/19/2020 05:00	0.2	13.7	1,557.0	0.4	1.1	1	1	1
11/19/2020 06:00	-1.1	12.8	2,016.0	-0.7	1.4	1	1	1
11/19/2020 07:00	-0.9	12.9	1,970.0	-0.5	1.4	1	1	1
11/19/2020 08:00	0.4	13.7	1,608.5	0.4	1.1	1	1	0
11/19/2020 09:00	0.4	13.7	1,671.0	0.4	1.2	1	1	0
11/19/2020 10:00	0.4	13.7	1,699.0	0.4	1.2	1	1	0
11/19/2020 11:00	0.4	13.7	1,599.0	0.4	1.1	1	1	0
11/19/2020 12:00	0.4	13.7	1,703.4	0.4	1.2	1	1	0
11/19/2020 13:00	0.5	13.8	1,652.7	0.5	1.2	1	1	0
11/19/2020 14:00	0.5	13.8	1,687.2	0.5	1.2	1	1	0
11/19/2020 15:00	0.4	13.9	1,322.7	0.4	0.9	1	1	0
11/19/2020 16:00	0.4	13.8	1,601.2	0.4	1.1	1	1	0
11/19/2020 17:00	0.4	13.7	1,720.9	0.4	1.2	1	1	1
11/19/2020 18:00	-0.8	12.4	2,068.3	-0.4	1.4	1	1	1
11/19/2020 19:00	-0.7	12.0	2,141.6	-0.2	1.5	1	1	1
11/19/2020 20:00	-0.7	12.2	2,102.1	-0.2	1.5	1	1	1
11/19/2020 21:00	-0.7	12.6	2,011.4	-0.2	1.4	1	1	1
11/19/2020 22:00	-0.7	12.4	2,064.2	-0.2	1.4	1	1	1
11/19/2020 23:00	-0.7	12.9	1,956.2	-0.4	1.4	1	1	1
Average/Sum#:	-0.1	13.3	1,733.1	0.1	1.2	24 #	24 #	11 #
Minimum:	-1.1	12.0	1,302.7	-0.7	0.9	1	1	0
Maximum:	0.5	13.9	2,141.6	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2020 00:00	-0.7	12.4	2,054.1	-0.2	1.4	1	1	1
11/20/2020 01:00	-0.7	13.0	1,923.3	-0.4	1.3	1	1	1
11/20/2020 02:00	0.5	13.8	1,595.7	0.5	1.1	1	1	0
11/20/2020 03:00	0.4	13.7	1,595.1	0.4	1.1	1	1	0
11/20/2020 04:00	0.1	13.5	1,740.2	0.2	1.2	1	1	1
11/20/2020 05:00	-0.7	12.2	2,079.1	-0.2	1.5	1	1	1
11/20/2020 06:00	-0.7	12.1	2,132.9	-0.2	1.5	1	1	1
11/20/2020 07:00	-0.5	12.2	2,097.1	-0.1	1.5	1	1	1
11/20/2020 08:00	-0.5	12.5	2,033.6	-0.2	1.4	1	1	1
11/20/2020 09:00	-0.5	12.6	1,986.1	-0.2	1.4	1	1	1
11/20/2020 10:00	0.5	13.8	1,667.7	0.5	1.2	1	1	0
11/20/2020 11:00	0.5	13.8	1,590.4	0.5	1.1	1	1	0
11/20/2020 12:00	0.5	13.8	1,650.0	0.5	1.2	1	1	0
11/20/2020 13:00	0.5	13.8	1,515.2	0.5	1.1	1	1	0
11/20/2020 14:00	0.5	13.8	1,550.5	0.5	1.1	1	1	0
11/20/2020 15:00	-0.2	13.2	1,838.1	-0.1	1.3	1	1	1
11/20/2020 16:00	-0.9	12.3	2,090.9	-0.5	1.5	1	1	1
11/20/2020 17:00	-0.7	12.1	2,129.0	-0.2	1.5	1	1	1
11/20/2020 18:00	-0.5	12.0	2,123.5	-0.1	1.5	1	1	1
11/20/2020 19:00	-0.5	12.0	2,124.6	-0.1	1.5	1	1	1
11/20/2020 20:00	-0.5	12.0	2,132.9	-0.1	1.5	1	1	1
11/20/2020 21:00	-0.5	12.0	2,122.3	-0.1	1.5	1	1	1
11/20/2020 22:00	-0.5	12.0	2,133.8	-0.1	1.5	1	1	1
11/20/2020 23:00	-0.5	12.3	2,078.8	-0.1	1.5	1	1	1
Average/Sum#:	-0.2	12.8	1,916.0	0.0	1.4	24 #	24 #	17 #
Minimum:	-0.9	12.0	1,515.2	-0.5	1.1	1	1	0
Maximum:	0.5	13.8	2,133.8	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2020 00:00	-0.5	12.4	2,063.4	-0.2	1.4	1	1	1
11/21/2020 01:00	-0.7	12.9	1,949.7	-0.4	1.4	1	1	1
11/21/2020 02:00	-0.7	13.0	1,919.4	-0.4	1.3	1	1	1
11/21/2020 03:00	0.4	13.8	1,752.8	0.4	1.2	1	1	0
11/21/2020 04:00	-0.2	13.2	1,840.5	-0.1	1.3	1	1	1
11/21/2020 05:00	-0.7	12.1	2,102.9	-0.2	1.5	1	1	1
11/21/2020 06:00	-0.5	12.0	2,143.1	-0.1	1.5	1	1	1
11/21/2020 07:00	0.2	13.5	1,622.5	0.4	1.1	1	1	1
11/21/2020 08:00	0.5	13.8	1,615.9	0.5	1.1	1	1	0
11/21/2020 09:00	0.4	13.8	1,622.1	0.4	1.1	1	1	0
11/21/2020 10:00	0.4	13.8	1,476.6	0.4	1.0	1	1	0
11/21/2020 11:00	0.5	13.8	1,672.2	0.5	1.2	1	1	0
11/21/2020 12:00	0.5	13.8	1,675.6	0.5	1.2	1	1	0
11/21/2020 13:00	0.5	13.8	1,697.4	0.5	1.2	1	1	0
11/21/2020 14:00	0.5	13.8	1,604.9	0.5	1.1	1	1	0
11/21/2020 15:00	-0.4	13.2	1,850.8	-0.1	1.3	1	1	1
11/21/2020 16:00	-0.8	12.2	2,085.5	-0.4	1.5	1	1	1
11/21/2020 17:00	-0.8	12.1	2,116.5	-0.4	1.5	1	1	1
11/21/2020 18:00	-0.8	11.9	2,153.8	-0.4	1.5	1	1	1
11/21/2020 19:00	-0.8	12.0	2,144.2	-0.4	1.5	1	1	1
11/21/2020 20:00	-0.8	12.1	2,090.3	-0.4	1.5	1	1	1
11/21/2020 21:00	0.4	13.7	1,686.8	0.4	1.2	1	1	0
11/21/2020 22:00	-0.2	13.2	1,838.2	-0.1	1.3	1	1	1
11/21/2020 23:00	-0.7	12.3	2,079.8	-0.2	1.5	1	1	1
Average/Sum#:	-0.2	13.0	1,866.9	0.0	1.3	24 #	24 #	15 #
Minimum:	-0.8	11.9	1,476.6	-0.4	1.0	1	1	0
Maximum:	0.5	13.8	2,153.8	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2020 00:00	-0.7	12.4	2,056.5	-0.2	1.4	1	1	1
11/22/2020 01:00	-0.2	13.0	1,806.1	0.1	1.3	1	1	1
11/22/2020 02:00	0.4	13.8	1,305.9	0.4	0.9	1	1	0
11/22/2020 03:00	0.4	13.8	1,363.8	0.4	1.0	1	1	0
11/22/2020 04:00	0.4	13.7	1,623.9	0.4	1.1	1	1	0
11/22/2020 05:00	-0.8	13.1	1,844.5	-0.5	1.3	1	1	1
11/22/2020 06:00	-0.7	13.1	1,879.0	-0.4	1.3	1	1	1
11/22/2020 07:00	0.4	13.7	1,518.2	0.4	1.1	1	1	0
11/22/2020 08:00	0.4	13.7	1,678.7	0.4	1.2	1	1	0
11/22/2020 09:00	0.4	13.7	1,691.0	0.4	1.2	1	1	0
11/22/2020 10:00	0.4	13.7	1,623.1	0.4	1.1	1	1	0
11/22/2020 11:00	0.4	13.7	1,674.4	0.4	1.2	1	1	0
11/22/2020 12:00	0.4	13.7	1,649.7	0.4	1.2	1	1	0
11/22/2020 13:00	0.4	13.7	1,644.2	0.4	1.2	1	1	0
11/22/2020 14:00	0.4	13.7	1,698.4	0.4	1.2	1	1	0
11/22/2020 15:00	-0.2	13.2	1,838.0	-0.1	1.3	1	1	1
11/22/2020 16:00	-0.8	12.1	2,097.6	-0.4	1.5	1	1	1
11/22/2020 17:00	-0.7	12.0	2,112.3	-0.2	1.5	1	1	1
11/22/2020 18:00	-0.7	12.1	2,099.2	-0.2	1.5	1	1	1
11/22/2020 19:00	-0.7	12.2	2,044.1	-0.2	1.4	1	1	1
11/22/2020 20:00	0.4	13.7	1,690.1	0.4	1.2	1	1	0
11/22/2020 21:00	-0.2	13.1	1,856.5	-0.1	1.3	1	1	1
11/22/2020 22:00	-0.8	12.1	2,091.4	-0.4	1.5	1	1	1
11/22/2020 23:00	-0.4	13.0	1,856.3	-0.1	1.3	1	1	1
Average/Sum#:	-0.1	13.2	1,781.0	0.1	1.3	24 #	24 #	12 #
Minimum:	-0.8	12.0	1,305.9	-0.5	0.9	1	1	0
Maximum:	0.4	13.8	2,112.3	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2020 00:00	0.1	13.4	1,712.3	0.2	1.2	1	1	1
11/23/2020 01:00	-0.7	12.9	1,912.4	-0.4	1.3	1	1	1
11/23/2020 02:00	0.4	13.7	1,475.3	0.4	1.0	1	1	0
11/23/2020 03:00	0.4	13.7	1,385.9	0.4	1.0	1	1	0
11/23/2020 04:00	0.4	13.8	1,395.9	0.4	1.0	1	1	0
11/23/2020 05:00	0.4	13.7	1,708.4	0.4	1.2	1	1	0
11/23/2020 06:00	0.4	13.8	1,398.5	0.4	1.0	1	1	0
11/23/2020 07:00	0.4	13.7	1,696.7	0.4	1.2	1	1	0
11/23/2020 08:00	0.4	13.7	1,629.3	0.4	1.1	1	1	0
11/23/2020 09:00	0.4	13.7	1,660.5	0.4	1.2	1	1	0
11/23/2020 10:00	0.4	13.7	1,586.9	0.4	1.1	1	1	0
11/23/2020 11:00	0.4	13.7	1,669.8	0.4	1.2	1	1	0
11/23/2020 12:00	0.4	13.8	1,692.9	0.4	1.2	1	1	0
11/23/2020 13:00	0.4	13.8	1,646.7	0.4	1.2	1	1	0
11/23/2020 14:00	0.4	13.8	1,691.1	0.4	1.2	1	1	0
11/23/2020 15:00	0.1	13.5	1,764.4	0.2	1.2	1	1	1
11/23/2020 16:00	-0.8	12.2	2,086.6	-0.4	1.5	1	1	1
11/23/2020 17:00	-0.8	12.1	2,106.2	-0.4	1.5	1	1	1
11/23/2020 18:00	-0.8	12.1	2,112.2	-0.4	1.5	1	1	1
11/23/2020 19:00	-0.7	12.6	1,964.2	-0.2	1.4	1	1	1
11/23/2020 20:00	0.4	13.7	1,668.7	0.4	1.2	1	1	0
11/23/2020 21:00	0.1	13.5	1,700.0	0.2	1.2	1	1	1
11/23/2020 22:00	-0.7	12.4	2,048.7	-0.2	1.4	1	1	1
11/23/2020 23:00	-0.7	12.7	1,972.8	-0.2	1.4	1	1	1
Average/Sum#:	0.0	13.3	1,736.9	0.2	1.2	24 #	24 #	10 #
Minimum:	-0.8	12.1	1,385.9	-0.4	1.0	1	1	0
Maximum:	0.4	13.8	2,112.2	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2020 00:00	-0.7	12.8	1,942.9	-0.4	1.4	1	1	1
11/24/2020 01:00	0.4	13.7	1,560.7	0.4	1.1	1	1	0
11/24/2020 02:00	0.4	13.7	1,566.3	0.4	1.1	1	1	0
11/24/2020 03:00	0.4	13.7	1,582.6	0.4	1.1	1	1	0
11/24/2020 04:00	-0.2	13.3	1,834.3	-0.1	1.3	1	1	1
11/24/2020 05:00	-0.7	12.2	2,092.5	-0.2	1.5	1	1	1
11/24/2020 06:00	-0.7	11.7	2,222.2	-0.2	1.6	1	1	1
11/24/2020 07:00	-0.5	12.0	2,148.1	-0.1	1.5	1	1	1
11/24/2020 08:00	-0.2	13.0	1,891.4	0.1	1.3	1	1	1
11/24/2020 09:00	0.4	13.7	1,689.6	0.4	1.2	1	1	0
11/24/2020 10:00	0.4	13.8	1,672.5	0.4	1.2	1	1	1
11/24/2020 11:00	0.4	13.8	1,683.7	0.4	1.2	1	1	0
11/24/2020 12:00	0.5	13.8	1,670.4	0.5	1.2	1	1	0
11/24/2020 13:00	0.4	13.8	1,680.2	0.4	1.2	1	1	0
11/24/2020 14:00	0.4	13.8	1,599.2	0.4	1.1	1	1	0
11/24/2020 15:00	-0.1	13.6	1,576.8	0.1	1.1	1	1	1
11/24/2020 16:00	-1.7	12.2	2,088.0	-0.9	1.5	1	1	1
11/24/2020 17:00	-1.1	12.1	2,124.5	-0.5	1.5	1	1	1
11/24/2020 18:00	-1.1	12.0	2,143.0	-0.5	1.5	1	1	1
11/24/2020 19:00	-1.1	11.9	2,167.3	-0.5	1.5	1	1	1
11/24/2020 20:00	-0.8	11.9	2,174.8	-0.4	1.5	1	1	1
11/24/2020 21:00	-0.5	12.1	2,145.0	-0.1	1.5	1	1	1
11/24/2020 22:00	-0.5	12.2	2,125.8	-0.1	1.5	1	1	1
11/24/2020 23:00	-0.5	12.4	2,076.0	-0.2	1.5	1	1	1
Average/Sum#:	-0.3	12.9	1,894.1	0.0	1.3	24 #	24 #	16 #
Minimum:	-1.7	11.7	1,560.7	-0.9	1.1	1	1	0
Maximum:	0.5	13.8	2,222.2	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2020 00:00	-0.5	12.4	2,077.0	-0.2	1.5	1	1	1
11/25/2020 01:00	-0.5	13.0	1,930.7	-0.2	1.4	1	1	1
11/25/2020 02:00	0.4	13.7	1,572.2	0.4	1.1	1	1	0
11/25/2020 03:00	0.3	13.7	1,378.7	0.4	1.0	1	1	0
11/25/2020 04:00	0.1	13.7	1,566.3	0.2	1.1	1	1	1
11/25/2020 05:00	-0.8	12.5	2,021.7	-0.4	1.4	1	1	1
11/25/2020 06:00	-0.9	12.7	2,015.8	-0.5	1.4	1	1	1
11/25/2020 07:00	-0.9	12.6	2,013.3	-0.5	1.4	1	1	1
11/25/2020 08:00	0.4	13.7	1,677.1	0.4	1.2	1	1	0
11/25/2020 09:00	0.4	13.7	1,640.7	0.4	1.1	1	1	0
11/25/2020 10:00	0.4	13.7	1,702.9	0.4	1.2	1	1	0
11/25/2020 11:00	0.4	13.7	1,702.6	0.4	1.2	1	1	0
11/25/2020 12:00	0.4	13.8	1,699.7	0.4	1.2	1	1	0
11/25/2020 13:00	0.4	13.8	1,688.1	0.4	1.2	1	1	0
11/25/2020 14:00	0.4	13.8	1,661.8	0.4	1.2	1	1	0
11/25/2020 15:00	0.4	13.8	1,357.2	0.4	1.0	1	1	0
11/25/2020 16:00	0.4	13.8	1,639.3	0.4	1.1	1	1	0
11/25/2020 17:00	0.4	13.7	1,615.1	0.4	1.1	1	1	0
11/25/2020 18:00	0.4	13.7	1,701.9	0.4	1.2	1	1	0
11/25/2020 19:00	-0.4	13.1	1,863.3	-0.1	1.3	1	1	1
11/25/2020 20:00	-0.5	12.6	1,937.7	-0.2	1.4	1	1	1
11/25/2020 21:00	-0.1	13.5	1,795.2	0.1	1.3	1	1	1
11/25/2020 22:00	-0.8	12.5	2,038.1	-0.4	1.4	1	1	1
11/25/2020 23:00	0.0	14.1	1,276.9	0.0	0.9	1	0	1
Average/Sum#:	0.0	13.4	1,732.2	0.1	1.2	24 #	23 #	11 #
Minimum:	-0.9	12.4	1,276.9	-0.5	0.9	1	0	0
Maximum:	0.4	14.1	2,077.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 23:00	0.0	17.5	466.7	0.0	0.3	1	0	0
Average/Sum#:	0.0	17.5	466.7	0.0	0.3	1 #	0 #	0 #
Minimum:	0.0	17.5	466.7	0.0	0.3	0	0	0
Maximum:	0.0	17.5	466.7	0.0	0.3	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2020 00:00	0.0	16.6	585.0	0.0	0.4	1	0	0
11/27/2020 01:00	0.0	14.9	977.7	0.0	0.7	1	0	0
11/27/2020 02:00	0.4	13.8	1,452.8	0.4	1.0	1	1	0
11/27/2020 03:00	0.4	13.8	1,409.6	0.4	1.0	1	1	0
11/27/2020 04:00	0.4	13.7	1,659.8	0.4	1.2	1	1	0
11/27/2020 05:00	0.4	13.8	1,458.1	0.4	1.0	1	1	0
11/27/2020 06:00	0.4	13.7	1,707.4	0.4	1.2	1	1	0
11/27/2020 07:00	0.4	13.8	1,613.2	0.4	1.1	1	1	0
11/27/2020 08:00	0.4	13.7	1,622.4	0.4	1.1	1	1	0
11/27/2020 09:00	0.4	13.7	1,709.8	0.4	1.2	1	1	0
11/27/2020 10:00	0.4	13.8	1,694.5	0.4	1.2	1	1	0
11/27/2020 11:00	0.4	13.8	1,708.8	0.4	1.2	1	1	0
11/27/2020 12:00	0.4	13.8	1,698.0	0.4	1.2	1	1	0
11/27/2020 13:00	0.4	13.8	1,627.0	0.4	1.1	1	1	0
11/27/2020 14:00	0.4	13.8	1,666.4	0.4	1.2	1	1	0
11/27/2020 15:00	0.2	13.8	1,586.1	0.4	1.1	1	1	1
11/27/2020 16:00	-0.8	12.7	1,998.3	-0.4	1.4	1	1	1
11/27/2020 17:00	-0.8	12.1	2,109.7	-0.4	1.5	1	1	1
11/27/2020 18:00	-0.7	12.3	2,073.4	-0.2	1.5	1	1	1
11/27/2020 19:00	-0.8	12.3	2,069.1	-0.4	1.4	1	1	1
11/27/2020 20:00	-0.8	12.6	1,992.5	-0.4	1.4	1	1	1
11/27/2020 21:00	0.4	13.7	1,714.3	0.4	1.2	1	1	0
11/27/2020 22:00	-0.4	13.3	1,854.4	-0.1	1.3	1	1	1
11/27/2020 23:00	-0.8	12.6	2,052.6	-0.4	1.4	1	1	1
Average/Sum#:	0.0	13.6	1,668.4	0.2	1.2	24 #	22 #	8 #
Minimum:	-0.8	12.1	585.0	-0.4	0.4	1	0	0
Maximum:	0.4	16.6	2,109.7	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2020 00:00	-0.8	12.5	2,061.2	-0.4	1.4	1	1	1
11/28/2020 01:00	-0.8	13.0	1,949.1	-0.4	1.4	1	1	1
11/28/2020 02:00	0.4	13.7	1,595.5	0.4	1.1	1	1	0
11/28/2020 03:00	-0.4	13.3	1,833.1	-0.1	1.3	1	1	1
11/28/2020 04:00	-0.9	13.0	1,951.0	-0.5	1.4	1	1	1
11/28/2020 05:00	-0.8	12.9	1,971.0	-0.4	1.4	1	1	1
11/28/2020 06:00	0.4	13.7	1,704.0	0.4	1.2	1	1	0
11/28/2020 07:00	0.4	13.7	1,647.9	0.4	1.2	1	1	0
11/28/2020 08:00	0.4	13.7	1,691.6	0.4	1.2	1	1	0
11/28/2020 09:00	0.4	13.7	1,565.8	0.4	1.1	1	1	0
11/28/2020 10:00	0.4	13.7	1,637.2	0.4	1.1	1	1	0
11/28/2020 11:00	0.4	13.8	1,701.0	0.4	1.2	1	1	0
11/28/2020 12:00	0.4	13.8	1,706.6	0.4	1.2	1	1	0
11/28/2020 13:00	0.4	13.8	1,559.0	0.4	1.1	1	1	0
11/28/2020 14:00	0.4	13.8	1,639.1	0.4	1.1	1	1	0
11/28/2020 15:00	0.1	13.5	1,710.6	0.2	1.2	1	1	1
11/28/2020 16:00	-0.7	12.4	2,050.1	-0.2	1.4	1	1	1
11/28/2020 17:00	-0.7	12.0	2,113.6	-0.2	1.5	1	1	1
11/28/2020 18:00	-0.7	11.9	2,153.6	-0.2	1.5	1	1	1
11/28/2020 19:00	-0.7	11.9	2,150.3	-0.2	1.5	1	1	1
11/28/2020 20:00	-0.5	11.6	2,213.0	-0.1	1.5	1	1	1
11/28/2020 21:00	-0.1	13.1	1,824.4	0.1	1.3	1	1	1
11/28/2020 22:00	-0.2	13.3	1,848.3	-0.1	1.3	1	1	1
11/28/2020 23:00	-0.7	12.5	2,068.5	-0.2	1.4	1	1	1
Average/Sum#:	-0.2	13.1	1,847.7	0.1	1.3	24 #	24 #	14 #
Minimum:	-0.9	11.6	1,559.0	-0.5	1.1	1	1	0
Maximum:	0.4	13.8	2,213.0	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2020 00:00	-0.8	13.0	1,933.3	-0.4	1.4	1	1	1
11/29/2020 01:00	0.4	13.7	1,578.7	0.4	1.1	1	1	0
11/29/2020 02:00	-0.2	13.2	1,866.9	-0.1	1.3	1	1	1
11/29/2020 03:00	-0.8	12.5	2,063.5	-0.4	1.4	1	1	1
11/29/2020 04:00	-0.7	12.4	2,048.2	-0.2	1.4	1	1	1
11/29/2020 05:00	0.4	13.7	1,712.2	0.4	1.2	1	1	0
11/29/2020 06:00	0.4	13.7	1,684.9	0.4	1.2	1	1	0
11/29/2020 07:00	0.4	13.7	1,609.4	0.4	1.1	1	1	0
11/29/2020 08:00	0.4	13.7	1,651.6	0.4	1.2	1	1	0
11/29/2020 09:00	0.4	13.7	1,599.7	0.4	1.1	1	1	0
11/29/2020 10:00	0.4	13.7	1,702.1	0.4	1.2	1	1	0
11/29/2020 11:00	0.4	13.7	1,677.9	0.4	1.2	1	1	0
11/29/2020 12:00	0.4	13.7	1,692.3	0.4	1.2	1	1	0
11/29/2020 13:00	0.4	13.7	1,689.0	0.4	1.2	1	1	0
11/29/2020 14:00	0.4	13.8	1,669.0	0.4	1.2	1	1	0
11/29/2020 15:00	0.4	13.8	1,687.4	0.4	1.2	1	1	0
11/29/2020 16:00	-0.2	13.1	1,850.5	-0.1	1.3	1	1	1
11/29/2020 17:00	-0.8	12.0	2,138.8	-0.4	1.5	1	1	1
11/29/2020 18:00	-0.7	11.6	2,218.5	-0.2	1.6	1	1	1
11/29/2020 19:00	-0.5	11.9	2,120.9	-0.1	1.5	1	1	1
11/29/2020 20:00	0.4	13.7	1,701.6	0.4	1.2	1	1	0
11/29/2020 21:00	-0.4	13.2	1,853.3	-0.1	1.3	1	1	1
11/29/2020 22:00	-0.7	12.0	2,148.8	-0.2	1.5	1	1	1
11/29/2020 23:00	-0.7	12.4	2,080.6	-0.2	1.5	1	1	1
Average/Sum#:	-0.1	13.2	1,832.5	0.1	1.3	24 #	24 #	11 #
Minimum:	-0.8	11.6	1,578.7	-0.4	1.1	1	1	0
Maximum:	0.4	13.8	2,218.5	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2020 00:00	-0.7	12.4	2,096.4	-0.2	1.5	1	1	1
11/30/2020 01:00	-0.7	12.4	2,059.8	-0.2	1.4	1	1	1
11/30/2020 02:00	0.4	13.7	1,582.3	0.4	1.1	1	1	0
11/30/2020 03:00	0.4	13.7	1,555.1	0.4	1.1	1	1	0
11/30/2020 04:00	-0.2	13.3	1,784.1	-0.1	1.2	1	1	1
11/30/2020 05:00	-0.8	12.2	2,132.5	-0.4	1.5	1	1	1
11/30/2020 06:00	-0.8	12.1	2,143.8	-0.4	1.5	1	1	1
11/30/2020 07:00	-0.7	12.1	2,129.8	-0.2	1.5	1	1	1
11/30/2020 08:00	-0.8	12.7	1,987.0	-0.4	1.4	1	1	1
11/30/2020 09:00	0.4	13.7	1,682.6	0.4	1.2	1	1	0
11/30/2020 10:00	0.4	13.7	1,576.8	0.4	1.1	1	1	0
11/30/2020 11:00	0.4	13.7	1,646.4	0.4	1.2	1	1	0
11/30/2020 12:00	0.4	13.8	1,631.4	0.4	1.1	1	1	0
11/30/2020 13:00	0.4	13.8	1,432.0	0.4	1.0	1	1	0
11/30/2020 14:00	0.4	13.8	1,680.7	0.4	1.2	1	1	0
11/30/2020 15:00	0.1	13.5	1,708.9	0.2	1.2	1	1	1
11/30/2020 16:00	-0.8	12.3	2,073.0	-0.4	1.5	1	1	1
11/30/2020 17:00	-0.7	11.8	2,157.9	-0.2	1.5	1	1	1
11/30/2020 18:00	-0.7	11.8	2,171.2	-0.2	1.5	1	1	1
11/30/2020 19:00	-0.5	11.5	2,231.9	-0.1	1.6	1	1	1
11/30/2020 20:00	-0.5	11.9	2,164.9	-0.1	1.5	1	1	1
11/30/2020 21:00	-0.5	11.9	2,158.9	-0.1	1.5	1	1	1
11/30/2020 22:00	-0.5	12.1	2,124.4	-0.1	1.5	1	1	1
11/30/2020 23:00	-0.5	12.4	2,050.8	-0.2	1.4	1	1	1
Average/Sum#:	-0.3	12.8	1,915.1	0.0	1.3	24 #	24 #	16 #
Minimum:	-0.8	11.5	1,432.0	-0.4	1.0	1	1	0
Maximum:	0.4	13.8	2,231.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2020 00:00	-0.7	12.3	2,077.2	-0.2	1.5	1	1	1
12/01/2020 01:00	-0.7	12.2	2,064.5	-0.2	1.4	1	1	1
12/01/2020 02:00	0.4	13.7	1,571.7	0.4	1.1	1	1	0
12/01/2020 03:00	-0.2	13.2	1,850.1	-0.1	1.3	1	1	1
12/01/2020 04:00	-0.7	12.0	2,133.5	-0.2	1.5	1	1	1
12/01/2020 05:00	-0.5	11.4	2,218.4	-0.1	1.6	1	1	1
12/01/2020 06:00	-0.5	11.3	2,265.3	-0.1	1.6	1	1	1
12/01/2020 07:00	-0.5	11.8	2,183.5	-0.1	1.5	1	1	1
12/01/2020 08:00	-0.5	12.0	2,126.0	-0.1	1.5	1	1	1
12/01/2020 09:00	0.2	13.6	1,717.6	0.4	1.2	1	1	1
12/01/2020 10:00	0.4	13.8	1,702.3	0.4	1.2	1	1	0
12/01/2020 11:00	0.4	13.8	1,675.6	0.4	1.2	1	1	0
12/01/2020 12:00	0.5	13.8	1,687.4	0.5	1.2	1	1	0
12/01/2020 13:00	0.5	13.9	1,408.9	0.5	1.0	1	1	0
12/01/2020 14:00	0.4	13.8	1,613.8	0.4	1.1	1	1	0
12/01/2020 15:00	0.4	13.8	1,551.8	0.4	1.1	1	1	1
12/01/2020 16:00	-0.7	12.4	2,028.0	-0.2	1.4	1	1	1
12/01/2020 17:00	-0.5	11.6	2,186.7	-0.1	1.5	1	1	1
12/01/2020 18:00	-0.4	11.4	2,236.7	0.1	1.6	1	1	1
12/01/2020 19:00	-0.4	11.4	2,236.8	0.1	1.6	1	1	1
12/01/2020 20:00	-0.4	11.4	2,246.8	0.1	1.6	1	1	1
12/01/2020 21:00	-0.5	11.4	2,247.8	-0.1	1.6	1	1	1
12/01/2020 22:00	-0.5	11.5	2,235.6	-0.1	1.6	1	1	1
12/01/2020 23:00	-0.7	11.9	2,175.3	-0.2	1.5	1	1	1
Average/Sum#:	-0.2	12.5	1,976.7	0.1	1.4	24 #	24 #	18 #
Minimum:	-0.7	11.3	1,408.9	-0.2	1.0	1	1	0
Maximum:	0.5	13.9	2,265.3	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2020 00:00	-0.7	12.1	2,148.2	-0.2	1.5	1	1	1
12/02/2020 01:00	-0.7	12.6	2,007.3	-0.2	1.4	1	1	1
12/02/2020 02:00	0.4	13.7	1,579.9	0.4	1.1	1	1	0
12/02/2020 03:00	-0.2	13.1	1,857.9	-0.1	1.3	1	1	1
12/02/2020 04:00	-0.7	12.3	2,091.8	-0.2	1.5	1	1	1
12/02/2020 05:00	-0.7	12.1	2,123.3	-0.2	1.5	1	1	1
12/02/2020 06:00	-0.7	12.0	2,158.0	-0.2	1.5	1	1	1
12/02/2020 07:00	-0.7	12.1	2,142.3	-0.2	1.5	1	1	1
12/02/2020 08:00	-0.7	12.4	2,079.9	-0.2	1.5	1	1	1
12/02/2020 09:00	0.4	13.7	1,598.4	0.4	1.1	1	1	1
12/02/2020 10:00	0.4	13.8	1,676.4	0.4	1.2	1	1	0
12/02/2020 11:00	0.4	13.8	1,712.8	0.4	1.2	1	1	0
12/02/2020 12:00	0.4	13.8	1,667.4	0.4	1.2	1	1	0
12/02/2020 13:00	0.4	13.8	1,557.6	0.4	1.1	1	1	0
12/02/2020 14:00	0.4	13.8	1,591.0	0.4	1.1	1	1	0
12/02/2020 15:00	-0.5	13.1	1,856.7	-0.2	1.3	1	1	1
12/02/2020 16:00	-1.1	12.0	2,132.0	-0.5	1.5	1	1	1
12/02/2020 17:00	-0.9	11.7	2,199.7	-0.4	1.5	1	1	1
12/02/2020 18:00	-0.8	11.5	2,243.2	-0.2	1.6	1	1	1
12/02/2020 19:00	-0.7	11.5	2,230.9	-0.2	1.6	1	1	1
12/02/2020 20:00	-0.7	11.7	2,188.7	-0.2	1.5	1	1	1
12/02/2020 21:00	-0.7	11.8	2,168.4	-0.2	1.5	1	1	1
12/02/2020 22:00	-0.7	12.0	2,148.4	-0.2	1.5	1	1	1
12/02/2020 23:00	-0.7	12.0	2,144.9	-0.2	1.5	1	1	1
Average/Sum#:	-0.4	12.6	1,971.0	0.0	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.5	1,557.6	-0.5	1.1	1	1	0
Maximum:	0.4	13.8	2,243.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2020 00:00	-0.7	12.1	2,129.4	-0.2	1.5	1	1	1
12/03/2020 01:00	-0.7	12.2	2,129.1	-0.2	1.5	1	1	1
12/03/2020 02:00	-0.7	12.3	2,055.8	-0.2	1.4	1	1	1
12/03/2020 03:00	0.4	13.7	1,610.8	0.4	1.1	1	1	0
12/03/2020 04:00	-0.2	13.2	1,856.8	-0.1	1.3	1	1	1
12/03/2020 05:00	-0.8	12.0	2,150.4	-0.4	1.5	1	1	1
12/03/2020 06:00	-0.7	11.5	2,264.7	-0.2	1.6	1	1	1
12/03/2020 07:00	-0.7	12.1	2,138.4	-0.2	1.5	1	1	1
12/03/2020 08:00	-0.7	12.3	2,102.3	-0.2	1.5	1	1	1
12/03/2020 09:00	-0.7	12.8	1,978.6	-0.4	1.4	1	1	1
12/03/2020 10:00	0.4	13.7	1,705.2	0.4	1.2	1	1	0
12/03/2020 11:00	0.4	13.7	1,655.5	0.4	1.2	1	1	0
12/03/2020 12:00	0.4	13.8	1,690.9	0.4	1.2	1	1	0
12/03/2020 13:00	0.4	13.8	1,691.6	0.4	1.2	1	1	0
12/03/2020 14:00	-0.4	13.3	1,845.9	-0.1	1.3	1	1	1
12/03/2020 15:00	-0.8	12.3	2,092.7	-0.4	1.5	1	1	1
12/03/2020 16:00	-0.8	11.9	2,177.5	-0.4	1.5	1	1	1
12/03/2020 17:00	-0.7	11.6	2,223.1	-0.2	1.6	1	1	1
12/03/2020 18:00	-0.4	11.4	2,255.1	0.1	1.6	1	1	1
12/03/2020 19:00	-0.4	11.4	2,257.9	0.1	1.6	1	1	1
12/03/2020 20:00	-0.5	11.7	2,184.0	-0.1	1.5	1	1	1
12/03/2020 21:00	-0.5	11.6	2,218.2	-0.1	1.6	1	1	1
12/03/2020 22:00	-0.5	11.7	2,196.3	-0.1	1.5	1	1	1
12/03/2020 23:00	-0.7	12.0	2,154.2	-0.2	1.5	1	1	1
Average/Sum#:	-0.4	12.4	2,031.9	-0.1	1.4	24 #	24 #	19 #
Minimum:	-0.8	11.4	1,610.8	-0.4	1.1	1	1	0
Maximum:	0.4	13.8	2,264.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2020 00:00	-0.7	12.2	2,147.2	-0.2	1.5	1	1	1
12/04/2020 01:00	-0.7	12.3	2,071.6	-0.2	1.5	1	1	1
12/04/2020 02:00	0.4	13.7	1,698.9	0.4	1.2	1	1	0
12/04/2020 03:00	-0.2	13.2	1,864.1	-0.1	1.3	1	1	1
12/04/2020 04:00	-0.8	12.1	2,142.8	-0.4	1.5	1	1	1
12/04/2020 05:00	-0.5	11.4	2,242.0	-0.1	1.6	1	1	1
12/04/2020 06:00	-0.5	11.4	2,281.3	-0.1	1.6	1	1	1
12/04/2020 07:00	-0.7	11.7	2,225.3	-0.2	1.6	1	1	1
12/04/2020 08:00	-0.7	12.4	2,105.3	-0.2	1.5	1	1	1
12/04/2020 09:00	-0.8	12.7	1,988.5	-0.4	1.4	1	1	1
12/04/2020 10:00	0.4	13.8	1,630.4	0.4	1.1	1	1	0
12/04/2020 11:00	0.4	13.8	1,613.2	0.4	1.1	1	1	0
12/04/2020 12:00	-1.1	13.0	1,935.7	-0.7	1.4	1	1	1
12/04/2020 13:00	-1.2	13.0	1,919.5	-0.8	1.3	1	1	1
12/04/2020 14:00	0.4	13.7	1,675.5	0.4	1.2	1	1	0
12/04/2020 15:00	-0.4	13.2	1,819.5	-0.1	1.3	1	1	1
12/04/2020 16:00	-0.9	12.1	2,130.5	-0.4	1.5	1	1	1
12/04/2020 17:00	-0.8	11.6	2,216.2	-0.2	1.6	1	1	1
12/04/2020 18:00	-0.7	11.6	2,210.7	-0.2	1.5	1	1	1
12/04/2020 19:00	-0.5	11.5	2,219.1	-0.1	1.6	1	1	1
12/04/2020 20:00	-0.5	11.6	2,216.2	-0.1	1.6	1	1	1
12/04/2020 21:00	-0.5	11.5	2,232.9	-0.1	1.6	1	1	1
12/04/2020 22:00	-0.7	11.8	2,186.1	-0.2	1.5	1	1	1
12/04/2020 23:00	-0.7	12.0	2,153.3	-0.2	1.5	1	1	1
Average/Sum#:	-0.5	12.4	2,038.6	-0.1	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.4	1,613.2	-0.8	1.1	1	1	0
Maximum:	0.4	13.8	2,281.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2020 00:00	-0.8	12.0	2,163.2	-0.4	1.5	1	1	1
12/05/2020 01:00	-0.7	12.1	2,126.2	-0.2	1.5	1	1	1
12/05/2020 02:00	-0.8	12.1	2,143.6	-0.4	1.5	1	1	1
12/05/2020 03:00	-0.8	12.1	2,147.9	-0.4	1.5	1	1	1
12/05/2020 04:00	-0.8	12.1	2,143.4	-0.4	1.5	1	1	1
12/05/2020 05:00	-0.8	12.1	2,149.4	-0.4	1.5	1	1	1
12/05/2020 06:00	-0.8	12.3	2,085.0	-0.4	1.5	1	1	1
12/05/2020 07:00	0.4	13.7	1,676.5	0.4	1.2	1	1	0
12/05/2020 08:00	0.4	13.7	1,630.4	0.4	1.1	1	1	0
12/05/2020 09:00	0.4	13.7	1,687.8	0.4	1.2	1	1	0
12/05/2020 10:00	0.4	13.7	1,684.3	0.4	1.2	1	1	0
12/05/2020 11:00	0.4	13.7	1,712.3	0.4	1.2	1	1	0
12/05/2020 12:00	0.4	13.7	1,702.9	0.4	1.2	1	1	0
12/05/2020 13:00	0.4	13.7	1,666.0	0.4	1.2	1	1	0
12/05/2020 14:00	0.4	13.7	1,650.1	0.4	1.2	1	1	0
12/05/2020 15:00	-0.5	13.2	1,839.7	-0.2	1.3	1	1	1
12/05/2020 16:00	-0.8	12.3	2,081.9	-0.4	1.5	1	1	1
12/05/2020 17:00	-0.8	11.8	2,186.2	-0.2	1.5	1	1	1
12/05/2020 18:00	-0.7	11.5	2,235.4	-0.2	1.6	1	1	1
12/05/2020 19:00	-0.7	11.4	2,255.9	-0.2	1.6	1	1	1
12/05/2020 20:00	-0.7	11.5	2,254.2	-0.2	1.6	1	1	1
12/05/2020 21:00	-0.7	11.6	2,241.3	-0.2	1.6	1	1	1
12/05/2020 22:00	-0.8	12.0	2,147.7	-0.4	1.5	1	1	1
12/05/2020 23:00	-0.8	12.1	2,139.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	12.6	1,989.6	-0.1	1.4	24 #	24 #	16 #
Minimum:	-0.8	11.4	1,630.4	-0.4	1.1	1	1	0
Maximum:	0.4	13.7	2,255.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2020 00:00	-0.8	12.2	2,135.5	-0.4	1.5	1	1	1
12/06/2020 01:00	-0.8	12.4	2,094.2	-0.4	1.5	1	1	1
12/06/2020 02:00	-0.8	12.4	2,085.7	-0.4	1.5	1	1	1
12/06/2020 03:00	-0.8	13.1	1,892.5	-0.5	1.3	1	1	1
12/06/2020 04:00	-0.1	13.5	1,807.3	0.1	1.3	1	1	1
12/06/2020 05:00	-0.8	12.4	2,045.1	-0.4	1.4	1	1	1
12/06/2020 06:00	-0.7	12.7	1,965.7	-0.2	1.4	1	1	1
12/06/2020 07:00	0.4	13.7	1,569.9	0.4	1.1	1	1	0
12/06/2020 08:00	0.4	13.7	1,571.6	0.4	1.1	1	1	0
12/06/2020 09:00	0.4	13.7	1,705.2	0.4	1.2	1	1	0
12/06/2020 10:00	0.4	13.7	1,702.2	0.4	1.2	1	1	0
12/06/2020 11:00	0.4	13.8	1,705.2	0.4	1.2	1	1	0
12/06/2020 12:00	0.4	13.8	1,630.6	0.4	1.1	1	1	0
12/06/2020 13:00	0.4	13.8	1,693.3	0.4	1.2	1	1	0
12/06/2020 14:00	0.4	13.8	1,666.3	0.4	1.2	1	1	0
12/06/2020 15:00	-0.5	13.3	1,846.5	-0.2	1.3	1	1	1
12/06/2020 16:00	-0.9	12.3	2,104.0	-0.5	1.5	1	1	1
12/06/2020 17:00	-0.8	11.7	2,215.0	-0.2	1.6	1	1	1
12/06/2020 18:00	-0.8	11.5	2,252.2	-0.2	1.6	1	1	1
12/06/2020 19:00	-0.8	11.5	2,256.7	-0.2	1.6	1	1	1
12/06/2020 20:00	-0.7	11.5	2,254.9	-0.2	1.6	1	1	1
12/06/2020 21:00	-0.8	11.7	2,208.8	-0.2	1.5	1	1	1
12/06/2020 22:00	-0.8	12.0	2,142.4	-0.4	1.5	1	1	1
12/06/2020 23:00	-0.7	12.4	2,057.6	-0.2	1.4	1	1	1
Average/Sum#:	-0.4	12.8	1,942.0	-0.1	1.4	24 #	24 #	16 #
Minimum:	-0.9	11.5	1,569.9	-0.5	1.1	1	1	0
Maximum:	0.4	13.8	2,256.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2020 00:00	-0.7	12.2	2,100.1	-0.2	1.5	1	1	1
12/07/2020 01:00	-0.7	12.6	1,990.2	-0.2	1.4	1	1	1
12/07/2020 02:00	0.4	13.7	1,622.7	0.4	1.1	1	1	0
12/07/2020 03:00	-0.2	13.2	1,835.0	-0.1	1.3	1	1	1
12/07/2020 04:00	-0.8	12.3	2,073.9	-0.4	1.5	1	1	1
12/07/2020 05:00	-0.8	12.2	2,099.5	-0.4	1.5	1	1	1
12/07/2020 06:00	-0.7	11.7	2,199.7	-0.2	1.5	1	1	1
12/07/2020 07:00	-0.7	11.7	2,193.3	-0.2	1.5	1	1	1
12/07/2020 08:00	-0.7	11.8	2,174.1	-0.2	1.5	1	1	1
12/07/2020 09:00	-0.5	11.8	2,157.8	-0.1	1.5	1	1	1
12/07/2020 10:00	0.2	13.5	1,704.8	0.4	1.2	1	1	1
12/07/2020 11:00	0.4	13.8	1,604.4	0.4	1.1	1	1	0
12/07/2020 12:00	0.4	13.8	1,602.4	0.4	1.1	1	1	0
12/07/2020 13:00	0.4	13.8	1,680.5	0.4	1.2	1	1	0
12/07/2020 14:00	0.1	13.4	1,685.4	0.2	1.2	1	1	1
12/07/2020 15:00	-0.7	12.1	2,075.2	-0.2	1.5	1	1	1
12/07/2020 16:00	-0.5	11.9	2,121.3	-0.1	1.5	1	1	1
12/07/2020 17:00	-0.5	11.5	2,197.4	-0.1	1.5	1	1	1
12/07/2020 18:00	-0.7	11.8	2,177.1	-0.2	1.5	1	1	1
12/07/2020 19:00	-0.8	11.8	2,184.5	-0.2	1.5	1	1	1
12/07/2020 20:00	-0.8	11.7	2,207.5	-0.2	1.5	1	1	1
12/07/2020 21:00	-0.7	11.6	2,233.7	-0.2	1.6	1	1	1
12/07/2020 22:00	-0.7	11.8	2,193.8	-0.2	1.5	1	1	1
12/07/2020 23:00	-0.8	12.2	2,104.2	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	12.4	2,009.1	-0.1	1.4	24 #	24 #	20 #
Minimum:	-0.8	11.5	1,602.4	-0.4	1.1	1	1	0
Maximum:	0.4	13.8	2,233.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2020 00:00	-0.8	12.3	2,079.0	-0.4	1.5	1	1	1
12/08/2020 01:00	-1.1	12.9	1,951.8	-0.7	1.4	1	1	1
12/08/2020 02:00	0.4	13.7	1,668.2	0.4	1.2	1	1	0
12/08/2020 03:00	-0.2	13.3	1,813.6	-0.1	1.3	1	1	1
12/08/2020 04:00	-0.8	12.5	2,048.6	-0.4	1.4	1	1	1
12/08/2020 05:00	-1.1	12.9	1,984.4	-0.7	1.4	1	1	1
12/08/2020 06:00	-0.8	12.3	2,094.8	-0.4	1.5	1	1	1
12/08/2020 07:00	-0.7	11.9	2,138.8	-0.2	1.5	1	1	1
12/08/2020 08:00	-0.7	12.2	2,084.8	-0.2	1.5	1	1	1
12/08/2020 09:00	-0.7	12.8	1,961.6	-0.4	1.4	1	1	1
12/08/2020 10:00	0.4	13.8	1,661.7	0.4	1.2	1	1	0
12/08/2020 11:00	0.4	13.8	1,592.7	0.4	1.1	1	1	0
12/08/2020 12:00	0.4	13.8	1,613.6	0.4	1.1	1	1	0
12/08/2020 13:00	0.4	13.8	1,579.2	0.4	1.1	1	1	0
12/08/2020 14:00	0.4	13.8	1,556.5	0.4	1.1	1	1	0
12/08/2020 15:00	0.1	13.4	1,717.2	0.2	1.2	1	1	1
12/08/2020 16:00	-0.8	12.3	2,045.4	-0.4	1.4	1	1	1
12/08/2020 17:00	-0.7	11.6	2,198.7	-0.2	1.5	1	1	1
12/08/2020 18:00	-0.7	11.5	2,220.4	-0.2	1.6	1	1	1
12/08/2020 19:00	-0.5	11.3	2,252.9	-0.1	1.6	1	1	1
12/08/2020 20:00	-0.7	11.6	2,207.5	-0.2	1.5	1	1	1
12/08/2020 21:00	-0.7	11.9	2,171.5	-0.2	1.5	1	1	1
12/08/2020 22:00	-0.8	12.2	2,128.8	-0.4	1.5	1	1	1
12/08/2020 23:00	-0.8	12.4	2,084.1	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	12.7	1,952.3	-0.1	1.4	24 #	24 #	18 #
Minimum:	-1.1	11.3	1,556.5	-0.7	1.1	1	1	0
Maximum:	0.4	13.8	2,252.9	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2020 00:00	-0.8	12.3	2,084.1	-0.4	1.5	1	1	1
12/09/2020 01:00	-0.8	12.4	2,068.8	-0.4	1.4	1	1	1
12/09/2020 02:00	-0.8	12.9	1,941.6	-0.4	1.4	1	1	1
12/09/2020 03:00	0.4	13.7	1,757.3	0.4	1.2	1	1	0
12/09/2020 04:00	-0.4	13.2	1,852.2	-0.1	1.3	1	1	1
12/09/2020 05:00	-0.8	12.5	2,055.9	-0.4	1.4	1	1	1
12/09/2020 06:00	-0.8	12.1	2,127.6	-0.4	1.5	1	1	1
12/09/2020 07:00	-0.8	12.2	2,132.4	-0.4	1.5	1	1	1
12/09/2020 08:00	-0.8	12.3	2,095.0	-0.4	1.5	1	1	1
12/09/2020 09:00	-0.9	12.9	1,941.7	-0.5	1.4	1	1	1
12/09/2020 10:00	0.4	13.7	1,762.4	0.4	1.2	1	1	0
12/09/2020 11:00	0.4	13.7	1,765.5	0.4	1.2	1	1	0
12/09/2020 12:00	0.4	13.7	1,762.2	0.4	1.2	1	1	0
12/09/2020 13:00	0.4	13.7	1,758.7	0.4	1.2	1	1	0
12/09/2020 14:00	0.4	13.6	1,759.5	0.4	1.2	1	1	0
12/09/2020 15:00	-0.2	13.1	1,836.5	-0.1	1.3	1	1	1
12/09/2020 16:00	-0.7	11.8	2,127.8	-0.2	1.5	1	1	1
12/09/2020 17:00	-0.5	11.6	2,184.3	-0.1	1.5	1	1	1
12/09/2020 18:00	-0.5	11.6	2,181.1	-0.1	1.5	1	1	1
12/09/2020 19:00	-0.7	11.5	2,231.5	-0.2	1.6	1	1	1
12/09/2020 20:00	-0.8	11.7	2,197.2	-0.2	1.5	1	1	1
12/09/2020 21:00	-0.7	11.4	2,265.4	-0.2	1.6	1	1	1
12/09/2020 22:00	-0.7	11.5	2,241.5	-0.2	1.6	1	1	1
12/09/2020 23:00	-0.8	12.0	2,139.7	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	12.5	2,011.2	-0.1	1.4	24 #	24 #	18 #
Minimum:	-0.9	11.4	1,757.3	-0.5	1.2	1	1	0
Maximum:	0.4	13.7	2,265.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2020 00:00	-0.8	12.0	2,131.0	-0.4	1.5	1	1	1
12/10/2020 01:00	-0.7	12.3	2,062.3	-0.2	1.4	1	1	1
12/10/2020 02:00	-0.7	12.1	2,068.2	-0.2	1.4	1	1	1
12/10/2020 03:00	0.4	13.8	1,709.6	0.4	1.2	1	1	0
12/10/2020 04:00	-0.2	13.2	1,842.5	-0.1	1.3	1	1	1
12/10/2020 05:00	-0.7	11.5	2,203.7	-0.2	1.5	1	1	1
12/10/2020 06:00	-0.7	11.7	2,181.0	-0.2	1.5	1	1	1
12/10/2020 07:00	-0.7	11.8	2,161.5	-0.2	1.5	1	1	1
12/10/2020 08:00	-0.7	11.8	2,174.4	-0.2	1.5	1	1	1
12/10/2020 09:00	-0.5	11.7	2,183.1	-0.1	1.5	1	1	1
12/10/2020 10:00	0.2	13.5	1,712.9	0.4	1.2	1	1	1
12/10/2020 11:00	0.4	13.8	1,641.3	0.4	1.1	1	1	0
12/10/2020 12:00	0.4	13.8	1,544.9	0.4	1.1	1	1	0
12/10/2020 13:00	0.4	13.8	1,583.7	0.4	1.1	1	1	0
12/10/2020 14:00	0.4	13.8	1,547.8	0.4	1.1	1	1	0
12/10/2020 15:00	-0.4	13.2	1,849.8	-0.1	1.3	1	1	1
12/10/2020 16:00	-0.9	12.3	2,088.4	-0.5	1.5	1	1	1
12/10/2020 17:00	-0.8	11.8	2,186.1	-0.2	1.5	1	1	1
12/10/2020 18:00	-0.5	11.4	2,251.7	-0.1	1.6	1	1	1
12/10/2020 19:00	-0.7	11.5	2,219.2	-0.2	1.6	1	1	1
12/10/2020 20:00	-0.7	11.9	2,154.1	-0.2	1.5	1	1	1
12/10/2020 21:00	-0.7	11.8	2,174.0	-0.2	1.5	1	1	1
12/10/2020 22:00	-0.7	11.8	2,168.1	-0.2	1.5	1	1	1
12/10/2020 23:00	-0.8	12.1	2,107.6	-0.4	1.5	1	1	1
Average/Sum#:	-0.4	12.4	1,997.8	-0.1	1.4	24 #	24 #	19 #
Minimum:	-0.9	11.4	1,544.9	-0.5	1.1	1	1	0
Maximum:	0.4	13.8	2,251.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2020 00:00	-0.8	12.9	1,944.7	-0.4	1.4	1	1	1
12/11/2020 01:00	0.4	13.7	1,710.0	0.4	1.2	1	1	0
12/11/2020 02:00	0.4	13.7	1,613.0	0.4	1.1	1	1	0
12/11/2020 03:00	0.4	13.7	1,606.6	0.4	1.1	1	1	0
12/11/2020 04:00	-0.4	13.3	1,782.6	-0.1	1.2	1	1	1
12/11/2020 05:00	-0.8	12.4	2,081.7	-0.4	1.5	1	1	1
12/11/2020 06:00	-0.8	12.0	2,176.7	-0.4	1.5	1	1	1
12/11/2020 07:00	-0.8	12.1	2,140.4	-0.4	1.5	1	1	1
12/11/2020 08:00	-0.8	12.1	2,101.0	-0.4	1.5	1	1	1
12/11/2020 09:00	0.4	13.7	1,680.2	0.4	1.2	1	1	0
12/11/2020 10:00	0.4	13.7	1,677.3	0.4	1.2	1	1	0
12/11/2020 11:00	0.4	13.7	1,660.2	0.4	1.2	1	1	0
12/11/2020 12:00	0.4	13.7	1,637.1	0.4	1.1	1	1	0
12/11/2020 13:00	0.4	13.7	1,677.3	0.4	1.2	1	1	0
12/11/2020 14:00	0.4	13.7	1,683.3	0.4	1.2	1	1	0
12/11/2020 15:00	-0.4	13.3	1,840.1	-0.1	1.3	1	1	1
12/11/2020 16:00	-0.9	12.0	2,138.3	-0.4	1.5	1	1	1
12/11/2020 17:00	-0.9	11.8	2,182.0	-0.4	1.5	1	1	1
12/11/2020 18:00	-0.8	11.4	2,284.7	-0.2	1.6	1	1	1
12/11/2020 19:00	-0.7	11.3	2,294.0	-0.2	1.6	1	1	1
12/11/2020 20:00	-0.7	11.3	2,292.7	-0.2	1.6	1	1	1
12/11/2020 21:00	-0.7	11.3	2,291.1	-0.2	1.6	1	1	1
12/11/2020 22:00	-0.8	11.9	2,178.2	-0.4	1.5	1	1	1
12/11/2020 23:00	-0.8	12.1	2,138.1	-0.4	1.5	1	1	1
Average/Sum#:	-0.3	12.7	1,950.5	0.0	1.4	24 #	24 #	15 #
Minimum:	-0.9	11.3	1,606.6	-0.4	1.1	1	1	0
Maximum:	0.4	13.7	2,294.0	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2020 00:00	-0.8	12.0	2,159.3	-0.4	1.5	1	1	1
12/12/2020 01:00	-0.8	12.2	2,109.2	-0.4	1.5	1	1	1
12/12/2020 02:00	-0.9	12.8	1,958.8	-0.5	1.4	1	1	1
12/12/2020 03:00	0.4	13.6	1,633.7	0.4	1.1	1	1	0
12/12/2020 04:00	-0.5	13.3	1,829.9	-0.2	1.3	1	1	1
12/12/2020 05:00	-1.2	13.0	1,961.2	-0.8	1.4	1	1	1
12/12/2020 06:00	-1.2	13.0	1,948.7	-0.8	1.4	1	1	1
12/12/2020 07:00	0.2	13.6	1,702.2	0.4	1.2	1	1	1
12/12/2020 08:00	0.4	13.7	1,680.5	0.4	1.2	1	1	0
12/12/2020 09:00	0.4	13.7	1,693.1	0.4	1.2	1	1	0
12/12/2020 10:00	0.4	13.7	1,677.5	0.4	1.2	1	1	0
12/12/2020 11:00	0.4	13.7	1,593.5	0.4	1.1	1	1	0
12/12/2020 12:00	0.4	13.7	1,654.8	0.4	1.2	1	1	0
12/12/2020 13:00	0.4	13.7	1,712.2	0.4	1.2	1	1	0
12/12/2020 14:00	0.4	13.7	1,684.6	0.4	1.2	1	1	0
12/12/2020 15:00	-0.4	13.2	1,845.1	-0.1	1.3	1	1	1
12/12/2020 16:00	-0.9	12.1	2,108.9	-0.4	1.5	1	1	1
12/12/2020 17:00	-0.8	11.7	2,194.3	-0.2	1.5	1	1	1
12/12/2020 18:00	-0.7	11.4	2,264.0	-0.2	1.6	1	1	1
12/12/2020 19:00	-0.7	11.3	2,270.1	-0.2	1.6	1	1	1
12/12/2020 20:00	-0.5	11.3	2,267.3	-0.1	1.6	1	1	1
12/12/2020 21:00	-0.5	11.4	2,264.8	-0.1	1.6	1	1	1
12/12/2020 22:00	-0.5	11.4	2,256.3	-0.1	1.6	1	1	1
12/12/2020 23:00	-0.7	11.9	2,156.9	-0.2	1.5	1	1	1
Average/Sum#:	-0.3	12.7	1,942.8	0.0	1.4	24 #	24 #	16 #
Minimum:	-1.2	11.3	1,593.5	-0.8	1.1	1	1	0
Maximum:	0.4	13.7	2,270.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2020 00:00	-0.8	11.9	2,163.4	-0.4	1.5	1	1	1
12/13/2020 01:00	-0.8	12.2	2,094.8	-0.4	1.5	1	1	1
12/13/2020 02:00	-0.8	12.9	1,954.5	-0.4	1.4	1	1	1
12/13/2020 03:00	-0.8	12.9	1,952.7	-0.4	1.4	1	1	1
12/13/2020 04:00	-0.9	12.9	1,962.7	-0.5	1.4	1	1	1
12/13/2020 05:00	-0.8	12.4	2,061.3	-0.4	1.4	1	1	1
12/13/2020 06:00	-0.8	12.3	2,065.4	-0.4	1.4	1	1	1
12/13/2020 07:00	0.4	13.6	1,614.1	0.4	1.1	1	1	0
12/13/2020 08:00	0.2	13.7	1,306.7	0.3	0.9	1	1	0
12/13/2020 09:00	0.2	13.7	1,307.5	0.3	0.9	1	1	0
12/13/2020 10:00	0.2	13.7	1,321.0	0.3	0.9	1	1	0
12/13/2020 11:00	0.4	13.7	1,510.4	0.4	1.1	1	1	0
12/13/2020 12:00	0.4	13.6	1,681.5	0.4	1.2	1	1	0
12/13/2020 13:00	0.4	13.6	1,695.4	0.4	1.2	1	1	0
12/13/2020 14:00	0.4	13.6	1,706.0	0.4	1.2	1	1	0
12/13/2020 15:00	-0.5	13.2	1,825.9	-0.2	1.3	1	1	1
12/13/2020 16:00	-0.9	12.2	2,079.4	-0.4	1.5	1	1	1
12/13/2020 17:00	-0.8	11.5	2,234.2	-0.2	1.6	1	1	1
12/13/2020 18:00	-0.7	11.5	2,220.8	-0.2	1.6	1	1	1
12/13/2020 19:00	-0.8	11.9	2,159.6	-0.4	1.5	1	1	1
12/13/2020 20:00	-0.8	11.8	2,177.1	-0.2	1.5	1	1	1
12/13/2020 21:00	-0.8	12.1	2,121.9	-0.4	1.5	1	1	1
12/13/2020 22:00	-0.8	12.4	2,061.9	-0.4	1.4	1	1	1
12/13/2020 23:00	-0.8	12.5	2,041.7	-0.4	1.4	1	1	1
Average/Sum#:	-0.4	12.7	1,888.3	-0.1	1.3	24 #	24 #	16 #
Minimum:	-0.9	11.5	1,306.7	-0.5	0.9	1	1	0
Maximum:	0.4	13.7	2,234.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2020 00:00	0.0	15.4	722.1	0.0	0.5	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.4	722.1	0.0	0.5	1 #	0 #	0 #
Minimum:	0.0	15.4	722.1	0.0	0.5	0	0	0
Maximum:	0.0	15.4	722.1	0.0	0.5	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/16/2020 15:00	0.0	17.6	453.9	0.0	0.3	1	0	0
12/16/2020 16:00	0.0	15.6	820.6	0.0	0.6	1	0	0
12/16/2020 17:00	0.6	13.5	1,784.6	0.6	1.2	1	1	0
12/16/2020 18:00	0.4	13.0	1,925.8	0.5	1.3	1	1	1
12/16/2020 19:00	0.2	11.9	2,196.3	0.4	1.5	1	1	1
12/16/2020 20:00	0.4	11.6	2,241.9	0.5	1.6	1	1	1
12/16/2020 21:00	0.4	11.6	2,239.8	0.5	1.6	1	1	1
12/16/2020 22:00	0.4	11.7	2,232.4	0.5	1.6	1	1	1
12/16/2020 23:00	0.4	11.7	2,210.6	0.5	1.5	1	1	1
Average/Sum#:	0.3	13.1	1,789.5	0.4	1.2	9 #	7 #	6 #
Minimum:	0.0	11.6	453.9	0.0	0.3	0	0	0
Maximum:	0.6	17.6	2,241.9	0.6	1.6	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2020 00:00	0.2	12.2	2,075.5	0.4	1.5	1	1	1
12/17/2020 01:00	0.5	12.7	1,911.4	0.5	1.3	1	1	1
12/17/2020 02:00	0.7	13.4	1,797.3	0.7	1.3	1	1	1
12/17/2020 03:00	0.2	12.4	2,057.6	0.4	1.4	1	1	1
12/17/2020 04:00	0.2	12.2	2,083.9	0.4	1.5	1	1	1
12/17/2020 05:00	0.2	12.2	2,105.8	0.4	1.5	1	1	1
12/17/2020 06:00	0.2	12.5	2,033.1	0.4	1.4	1	1	1
12/17/2020 07:00	0.4	11.9	2,157.4	0.5	1.5	1	1	1
12/17/2020 08:00	0.4	12.2	2,088.9	0.5	1.5	1	1	1
12/17/2020 09:00	0.2	12.6	1,988.7	0.4	1.4	1	1	1
12/17/2020 10:00	0.6	13.7	1,650.9	0.6	1.2	1	1	0
12/17/2020 11:00	0.6	13.7	1,694.7	0.6	1.2	1	1	0
12/17/2020 12:00	0.6	13.7	1,680.3	0.6	1.2	1	1	0
12/17/2020 13:00	0.6	13.7	1,691.8	0.6	1.2	1	1	0
12/17/2020 14:00	0.6	13.7	1,670.5	0.6	1.2	1	1	0
12/17/2020 15:00	0.6	13.7	1,660.3	0.6	1.2	1	1	0
12/17/2020 16:00	0.5	13.2	1,829.8	0.5	1.3	1	1	1
12/17/2020 17:00	-0.1	12.1	2,139.4	0.2	1.5	1	1	1
12/17/2020 18:00	0.1	12.0	2,142.1	0.2	1.5	1	1	1
12/17/2020 19:00	0.1	12.2	2,096.3	0.2	1.5	1	1	1
12/17/2020 20:00	0.1	12.3	2,079.4	0.2	1.5	1	1	1
12/17/2020 21:00	0.1	12.0	2,155.6	0.2	1.5	1	1	1
12/17/2020 22:00	0.1	12.2	2,106.2	0.2	1.5	1	1	1
12/17/2020 23:00	0.1	12.4	2,075.4	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.7	1,957.2	0.4	1.4	24 #	24 #	18 #
Minimum:	-0.1	11.9	1,650.9	0.2	1.2	1	1	0
Maximum:	0.7	13.7	2,157.4	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2020 00:00	0.1	12.4	2,085.7	0.2	1.5	1	1	1
12/18/2020 01:00	-0.2	12.9	1,951.1	0.1	1.4	1	1	1
12/18/2020 02:00	0.6	13.7	1,712.9	0.6	1.2	1	1	0
12/18/2020 03:00	0.6	13.7	1,480.2	0.6	1.0	1	1	0
12/18/2020 04:00	0.5	13.5	1,713.6	0.5	1.2	1	1	1
12/18/2020 05:00	-0.2	12.7	1,990.1	0.1	1.4	1	1	1
12/18/2020 06:00	-0.1	12.0	2,176.1	0.2	1.5	1	1	1
12/18/2020 07:00	-0.1	12.1	2,148.5	0.2	1.5	1	1	1
12/18/2020 08:00	-0.2	13.0	1,944.7	0.1	1.4	1	1	1
12/18/2020 09:00	0.6	13.7	1,714.4	0.6	1.2	1	1	0
12/18/2020 10:00	0.6	13.7	1,570.1	0.6	1.1	1	1	0
12/18/2020 11:00	0.6	13.8	1,409.7	0.6	1.0	1	1	0
12/18/2020 12:00	0.6	13.8	1,507.3	0.6	1.1	1	1	0
12/18/2020 13:00	0.6	13.8	1,609.5	0.6	1.1	1	1	0
12/18/2020 14:00	0.6	13.8	1,420.8	0.6	1.0	1	1	0
12/18/2020 15:00	0.6	13.8	1,440.2	0.6	1.0	1	1	0
12/18/2020 16:00	0.1	13.1	1,892.3	0.2	1.3	1	1	1
12/18/2020 17:00	0.1	11.6	2,215.1	0.2	1.6	1	1	1
12/18/2020 18:00	0.2	11.3	2,291.3	0.4	1.6	1	1	1
12/18/2020 19:00	0.2	11.3	2,295.0	0.4	1.6	1	1	1
12/18/2020 20:00	0.2	11.4	2,270.3	0.4	1.6	1	1	1
12/18/2020 21:00	0.1	11.7	2,228.0	0.2	1.6	1	1	1
12/18/2020 22:00	0.1	12.1	2,150.4	0.2	1.5	1	1	1
12/18/2020 23:00	0.1	12.5	2,072.7	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.8	1,887.1	0.4	1.3	24 #	24 #	15 #
Minimum:	-0.2	11.3	1,409.7	0.1	1.0	1	1	0
Maximum:	0.6	13.8	2,295.0	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2020 00:00	0.1	12.5	2,061.6	0.2	1.4	1	1	1
12/19/2020 01:00	-0.1	12.7	2,001.3	0.1	1.4	1	1	1
12/19/2020 02:00	0.6	13.7	1,666.1	0.6	1.2	1	1	0
12/19/2020 03:00	0.6	13.7	1,561.0	0.6	1.1	1	1	0
12/19/2020 04:00	0.5	13.3	1,875.9	0.5	1.3	1	1	1
12/19/2020 05:00	-0.1	12.4	2,101.1	0.2	1.5	1	1	1
12/19/2020 06:00	-0.2	12.7	2,023.7	0.1	1.4	1	1	1
12/19/2020 07:00	0.6	13.7	1,683.4	0.6	1.2	1	1	0
12/19/2020 08:00	0.6	13.7	1,598.8	0.6	1.1	1	1	0
12/19/2020 09:00	0.6	13.7	1,643.4	0.6	1.2	1	1	0
12/19/2020 10:00	0.6	13.7	1,706.6	0.6	1.2	1	1	0
12/19/2020 11:00	0.6	13.7	1,713.1	0.6	1.2	1	1	0
12/19/2020 12:00	0.6	13.7	1,713.8	0.6	1.2	1	1	0
12/19/2020 13:00	0.6	13.7	1,699.9	0.6	1.2	1	1	0
12/19/2020 14:00	0.6	13.7	1,713.0	0.6	1.2	1	1	0
12/19/2020 15:00	0.7	13.5	1,771.7	0.7	1.2	1	1	1
12/19/2020 16:00	-0.1	12.4	2,093.0	0.2	1.5	1	1	1
12/19/2020 17:00	-0.1	12.0	2,174.5	0.2	1.5	1	1	1
12/19/2020 18:00	0.1	11.5	2,271.5	0.2	1.6	1	1	1
12/19/2020 19:00	0.2	11.4	2,301.8	0.4	1.6	1	1	1
12/19/2020 20:00	0.1	11.7	2,231.9	0.2	1.6	1	1	1
12/19/2020 21:00	0.1	11.9	2,171.0	0.2	1.5	1	1	1
12/19/2020 22:00	0.1	12.3	2,096.5	0.2	1.5	1	1	1
12/19/2020 23:00	0.1	12.7	2,012.1	0.2	1.4	1	1	1
Average/Sum#:	0.3	12.9	1,911.9	0.4	1.3	24 #	24 #	14 #
Minimum:	-0.2	11.4	1,561.0	0.1	1.1	1	1	0
Maximum:	0.7	13.7	2,301.8	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2020 00:00	-0.1	12.9	1,968.1	0.1	1.4	1	1	1
12/20/2020 01:00	0.6	13.7	1,666.2	0.6	1.2	1	1	0
12/20/2020 02:00	0.6	13.7	1,550.0	0.6	1.1	1	1	0
12/20/2020 03:00	0.4	13.7	1,378.9	0.4	1.0	1	1	0
12/20/2020 04:00	0.6	13.7	1,583.3	0.6	1.1	1	1	0
12/20/2020 05:00	-0.1	13.1	1,850.7	0.1	1.3	1	1	1
12/20/2020 06:00	0.2	13.1	1,895.0	0.4	1.3	1	1	1
12/20/2020 07:00	0.6	13.7	1,715.7	0.6	1.2	1	1	0
12/20/2020 08:00	0.6	13.7	1,692.8	0.6	1.2	1	1	0
12/20/2020 09:00	0.6	13.7	1,710.3	0.6	1.2	1	1	0
12/20/2020 10:00	0.6	13.7	1,710.6	0.6	1.2	1	1	0
12/20/2020 11:00	0.6	13.7	1,709.4	0.6	1.2	1	1	0
12/20/2020 12:00	0.6	13.7	1,714.9	0.6	1.2	1	1	0
12/20/2020 13:00	0.6	13.7	1,700.9	0.6	1.2	1	1	0
12/20/2020 14:00	0.6	13.7	1,638.4	0.6	1.1	1	1	0
12/20/2020 15:00	0.7	13.5	1,711.7	0.7	1.2	1	1	1
12/20/2020 16:00	-0.1	12.4	2,050.7	0.2	1.4	1	1	1
12/20/2020 17:00	-0.1	11.9	2,158.3	0.2	1.5	1	1	1
12/20/2020 18:00	0.1	11.8	2,183.9	0.2	1.5	1	1	1
12/20/2020 19:00	0.1	11.8	2,185.2	0.2	1.5	1	1	1
12/20/2020 20:00	0.1	11.5	2,243.7	0.2	1.6	1	1	1
12/20/2020 21:00	0.1	11.8	2,160.3	0.2	1.5	1	1	1
12/20/2020 22:00	0.1	12.0	2,147.4	0.2	1.5	1	1	1
12/20/2020 23:00	0.1	12.5	2,074.2	0.2	1.5	1	1	1
Average/Sum#:	0.3	13.0	1,850.0	0.4	1.3	24 #	24 #	12 #
Minimum:	-0.1	11.5	1,378.9	0.1	1.0	1	1	0
Maximum:	0.7	13.7	2,243.7	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2020 00:00	-0.4	13.0	1,932.4	-0.1	1.4	1	1	1
12/21/2020 01:00	0.6	13.6	1,682.7	0.6	1.2	1	1	0
12/21/2020 02:00	0.6	13.6	1,616.3	0.6	1.1	1	1	0
12/21/2020 03:00	0.6	13.7	1,561.7	0.6	1.1	1	1	0
12/21/2020 04:00	0.2	13.2	1,866.5	0.4	1.3	1	1	1
12/21/2020 05:00	-0.2	12.3	2,101.9	0.1	1.5	1	1	1
12/21/2020 06:00	-0.1	12.3	2,125.2	0.2	1.5	1	1	1
12/21/2020 07:00	-0.1	12.3	2,116.8	0.2	1.5	1	1	1
12/21/2020 08:00	-0.2	12.7	2,012.6	0.1	1.4	1	1	1
12/21/2020 09:00	0.6	13.6	1,696.4	0.6	1.2	1	1	0
12/21/2020 10:00	0.6	13.6	1,707.6	0.6	1.2	1	1	0
12/21/2020 11:00	0.6	13.6	1,710.5	0.6	1.2	1	1	0
12/21/2020 12:00	0.6	13.6	1,700.4	0.6	1.2	1	1	0
12/21/2020 13:00	0.6	13.6	1,707.3	0.6	1.2	1	1	0
12/21/2020 14:00	0.6	13.6	1,695.2	0.6	1.2	1	1	0
12/21/2020 15:00	0.5	13.2	1,846.3	0.5	1.3	1	1	1
12/21/2020 16:00	-0.2	12.1	2,120.5	0.1	1.5	1	1	1
12/21/2020 17:00	-0.2	12.1	2,136.7	0.1	1.5	1	1	1
12/21/2020 18:00	-0.2	11.8	2,203.6	0.1	1.5	1	1	1
12/21/2020 19:00	-0.2	11.9	2,179.3	0.1	1.5	1	1	1
12/21/2020 20:00	-0.1	12.1	2,143.0	0.2	1.5	1	1	1
12/21/2020 21:00	-0.1	12.3	2,105.7	0.2	1.5	1	1	1
12/21/2020 22:00	-0.1	12.2	2,115.1	0.2	1.5	1	1	1
12/21/2020 23:00	-0.1	12.5	2,060.5	0.1	1.4	1	1	1
Average/Sum#:	0.2	12.9	1,922.7	0.3	1.4	24 #	24 #	15 #
Minimum:	-0.4	11.8	1,561.7	-0.1	1.1	1	1	0
Maximum:	0.6	13.7	2,203.6	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2020 00:00	-0.5	12.9	1,952.8	-0.2	1.4	1	1	1
12/22/2020 01:00	0.5	13.6	1,672.4	0.5	1.2	1	1	0
12/22/2020 02:00	0.4	13.6	1,552.5	0.4	1.1	1	1	0
12/22/2020 03:00	0.4	13.6	1,531.0	0.4	1.1	1	1	0
12/22/2020 04:00	0.1	13.4	1,728.7	0.2	1.2	1	1	1
12/22/2020 05:00	-0.2	12.5	2,066.2	0.1	1.4	1	1	1
12/22/2020 06:00	-0.2	12.4	2,103.3	0.1	1.5	1	1	1
12/22/2020 07:00	-0.2	12.1	2,173.9	0.1	1.5	1	1	1
12/22/2020 08:00	0.5	13.5	1,737.4	0.5	1.2	1	1	1
12/22/2020 09:00	0.5	13.6	1,627.0	0.5	1.1	1	1	0
12/22/2020 10:00	0.6	13.7	1,708.3	0.6	1.2	1	1	0
12/22/2020 11:00	0.6	13.7	1,646.9	0.6	1.2	1	1	0
12/22/2020 12:00	0.6	13.7	1,595.4	0.6	1.1	1	1	0
12/22/2020 13:00	0.6	13.7	1,661.6	0.6	1.2	1	1	0
12/22/2020 14:00	0.6	13.7	1,694.4	0.6	1.2	1	1	0
12/22/2020 15:00	0.7	13.5	1,717.8	0.7	1.2	1	1	1
12/22/2020 16:00	-0.1	12.6	2,045.2	0.1	1.4	1	1	1
12/22/2020 17:00	-0.1	11.9	2,173.7	0.2	1.5	1	1	1
12/22/2020 18:00	-0.1	11.8	2,204.5	0.2	1.5	1	1	1
12/22/2020 19:00	0.1	11.8	2,211.9	0.2	1.5	1	1	1
12/22/2020 20:00	0.1	11.7	2,229.0	0.2	1.6	1	1	1
12/22/2020 21:00	0.1	12.0	2,177.0	0.2	1.5	1	1	1
12/22/2020 22:00	0.1	12.1	2,142.1	0.2	1.5	1	1	1
12/22/2020 23:00	0.1	12.3	2,105.9	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.9	1,894.1	0.3	1.3	24 #	24 #	15 #
Minimum:	-0.5	11.7	1,531.0	-0.2	1.1	1	1	0
Maximum:	0.7	13.7	2,229.0	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2020 00:00	0.1	12.6	2,020.5	0.2	1.4	1	1	1
12/23/2020 01:00	0.6	13.7	1,716.9	0.6	1.2	1	1	0
12/23/2020 02:00	0.5	13.4	1,841.5	0.5	1.3	1	1	1
12/23/2020 03:00	0.1	13.0	1,956.4	0.2	1.4	1	1	1
12/23/2020 04:00	-0.1	12.6	2,023.8	0.1	1.4	1	1	1
12/23/2020 05:00	0.6	13.7	1,709.6	0.6	1.2	1	1	0
12/23/2020 06:00	0.5	13.3	1,855.4	0.5	1.3	1	1	1
12/23/2020 07:00	-0.1	12.1	2,169.0	0.2	1.5	1	1	1
12/23/2020 08:00	-0.1	12.1	2,149.0	0.2	1.5	1	1	1
12/23/2020 09:00	0.1	12.6	2,019.1	0.2	1.4	1	1	1
12/23/2020 10:00	0.6	13.7	1,690.9	0.6	1.2	1	1	0
12/23/2020 11:00	0.6	13.8	1,626.3	0.6	1.1	1	1	0
12/23/2020 12:00	0.6	13.8	1,661.5	0.6	1.2	1	1	0
12/23/2020 13:00	0.6	13.8	1,692.3	0.6	1.2	1	1	0
12/23/2020 14:00	0.6	13.8	1,697.7	0.6	1.2	1	1	0
12/23/2020 15:00	0.7	13.5	1,695.4	0.7	1.2	1	1	1
12/23/2020 16:00	-0.1	12.2	2,105.1	0.2	1.5	1	1	1
12/23/2020 17:00	-0.1	11.5	2,259.4	0.2	1.6	1	1	1
12/23/2020 18:00	0.1	11.4	2,296.2	0.4	1.6	1	1	1
12/23/2020 19:00	0.1	11.4	2,306.9	0.4	1.6	1	1	1
12/23/2020 20:00	0.1	11.4	2,301.7	0.4	1.6	1	1	1
12/23/2020 21:00	-0.1	12.0	2,178.2	0.2	1.5	1	1	1
12/23/2020 22:00	-0.1	12.1	2,155.9	0.2	1.5	1	1	1
12/23/2020 23:00	-0.1	12.3	2,140.3	0.2	1.5	1	1	1
Average/Sum#:	0.2	12.7	1,969.5	0.4	1.4	24 #	24 #	17 #
Minimum:	-0.1	11.4	1,626.3	0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,306.9	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2020 00:00	-0.1	12.7	2,080.1	0.1	1.5	1	1	1
12/24/2020 01:00	-0.4	12.9	1,987.5	-0.1	1.4	1	1	1
12/24/2020 02:00	0.6	13.6	1,758.3	0.6	1.2	1	1	0
12/24/2020 03:00	0.1	13.3	1,847.2	0.2	1.3	1	1	1
12/24/2020 04:00	-0.4	13.1	1,947.0	-0.1	1.4	1	1	1
12/24/2020 05:00	-0.2	13.0	1,962.1	0.1	1.4	1	1	1
12/24/2020 06:00	0.6	13.7	1,720.7	0.6	1.2	1	1	0
12/24/2020 07:00	0.4	13.7	1,710.5	0.4	1.2	1	1	0
12/24/2020 08:00	0.4	13.6	1,706.9	0.4	1.2	1	1	0
12/24/2020 09:00	-0.2	13.0	1,967.8	0.1	1.4	1	1	1
12/24/2020 10:00	-0.2	12.5	2,068.8	0.1	1.4	1	1	1
12/24/2020 11:00	0.6	13.7	1,656.9	0.6	1.2	1	1	0
12/24/2020 12:00	0.6	13.7	1,650.5	0.6	1.2	1	1	0
12/24/2020 13:00	0.6	13.7	1,674.5	0.6	1.2	1	1	0
12/24/2020 14:00	0.6	13.7	1,697.5	0.6	1.2	1	1	0
12/24/2020 15:00	0.4	13.2	1,823.1	0.4	1.3	1	1	1
12/24/2020 16:00	-0.1	12.3	2,081.4	0.2	1.5	1	1	1
12/24/2020 17:00	-0.1	11.9	2,166.7	0.2	1.5	1	1	1
12/24/2020 18:00	-0.1	11.7	2,209.1	0.2	1.5	1	1	1
12/24/2020 19:00	-0.1	11.8	2,202.6	0.2	1.5	1	1	1
12/24/2020 20:00	-0.1	11.6	2,232.8	0.2	1.6	1	1	1
12/24/2020 21:00	-0.1	12.0	2,162.0	0.2	1.5	1	1	1
12/24/2020 22:00	-0.1	11.8	2,196.3	0.2	1.5	1	1	1
12/24/2020 23:00	-0.1	12.2	2,120.7	0.2	1.5	1	1	1
Average/Sum#:	0.1	12.9	1,943.0	0.3	1.4	24 #	24 #	16 #
Minimum:	-0.4	11.6	1,650.5	-0.1	1.2	1	1	0
Maximum:	0.6	13.7	2,232.8	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2020 00:00	-0.1	12.2	2,103.3	0.2	1.5	1	1	1
12/25/2020 01:00	-0.1	12.2	2,095.3	0.2	1.5	1	1	1
12/25/2020 02:00	-0.1	12.4	2,037.2	0.2	1.4	1	1	1
12/25/2020 03:00	0.6	13.7	1,716.1	0.6	1.2	1	1	0
12/25/2020 04:00	0.2	13.2	1,853.4	0.4	1.3	1	1	1
12/25/2020 05:00	-0.2	12.2	2,085.6	0.1	1.5	1	1	1
12/25/2020 06:00	-0.2	12.4	2,052.0	0.1	1.4	1	1	1
12/25/2020 07:00	0.6	13.6	1,674.1	0.6	1.2	1	1	0
12/25/2020 08:00	0.5	13.6	1,637.7	0.5	1.1	1	1	0
12/25/2020 09:00	0.5	13.6	1,635.5	0.5	1.1	1	1	0
12/25/2020 10:00	0.4	13.6	1,611.6	0.4	1.1	1	1	0
12/25/2020 11:00	0.5	13.6	1,692.9	0.5	1.2	1	1	0
12/25/2020 12:00	0.5	13.6	1,698.4	0.5	1.2	1	1	0
12/25/2020 13:00	0.5	13.6	1,699.7	0.5	1.2	1	1	0
12/25/2020 14:00	0.5	13.6	1,653.5	0.5	1.2	1	1	0
12/25/2020 15:00	0.4	13.4	1,754.2	0.4	1.2	1	1	1
12/25/2020 16:00	-0.4	12.3	2,060.1	-0.1	1.4	1	1	1
12/25/2020 17:00	-0.2	12.0	2,120.1	0.1	1.5	1	1	1
12/25/2020 18:00	-0.2	12.2	2,084.3	0.1	1.5	1	1	1
12/25/2020 19:00	-0.1	11.9	2,139.0	0.2	1.5	1	1	1
12/25/2020 20:00	-0.2	12.7	1,944.5	0.1	1.4	1	1	1
12/25/2020 21:00	0.6	13.6	1,713.2	0.6	1.2	1	1	0
12/25/2020 22:00	0.2	13.2	1,833.8	0.4	1.3	1	1	1
12/25/2020 23:00	-0.2	12.8	1,965.9	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.0	1,869.2	0.3	1.3	24 #	24 #	14 #
Minimum:	-0.4	11.9	1,611.6	-0.1	1.1	1	1	0
Maximum:	0.6	13.7	2,139.0	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2020 00:00	-0.1	12.3	2,052.3	0.2	1.4	1	1	1
12/26/2020 01:00	-0.2	12.8	1,917.7	0.1	1.3	1	1	1
12/26/2020 02:00	0.6	13.6	1,703.0	0.6	1.2	1	1	0
12/26/2020 03:00	0.5	13.4	1,788.8	0.5	1.3	1	1	1
12/26/2020 04:00	-0.2	12.3	2,051.2	0.1	1.4	1	1	1
12/26/2020 05:00	-0.2	12.9	1,949.9	0.1	1.4	1	1	1
12/26/2020 06:00	0.6	13.7	1,712.1	0.6	1.2	1	1	0
12/26/2020 07:00	0.6	13.7	1,676.7	0.6	1.2	1	1	0
12/26/2020 08:00	0.6	13.7	1,621.9	0.6	1.1	1	1	0
12/26/2020 09:00	0.6	13.7	1,677.0	0.6	1.2	1	1	0
12/26/2020 10:00	0.6	13.7	1,577.0	0.6	1.1	1	1	0
12/26/2020 11:00	0.6	13.7	1,467.6	0.6	1.0	1	1	0
12/26/2020 12:00	0.6	13.7	1,594.3	0.6	1.1	1	1	0
12/26/2020 13:00	0.6	13.7	1,702.3	0.6	1.2	1	1	0
12/26/2020 14:00	0.6	13.7	1,676.4	0.6	1.2	1	1	0
12/26/2020 15:00	0.6	13.7	1,595.0	0.6	1.1	1	1	0
12/26/2020 16:00	0.5	13.5	1,699.8	0.5	1.2	1	1	1
12/26/2020 17:00	-0.2	12.4	2,073.9	0.1	1.5	1	1	1
12/26/2020 18:00	-0.1	12.7	2,006.4	0.1	1.4	1	1	1
12/26/2020 19:00	-0.1	12.3	2,085.2	0.2	1.5	1	1	1
12/26/2020 20:00	-0.1	12.4	2,087.7	0.2	1.5	1	1	1
12/26/2020 21:00	-0.1	12.4	2,072.5	0.2	1.5	1	1	1
12/26/2020 22:00	-0.1	12.3	2,100.8	0.2	1.5	1	1	1
12/26/2020 23:00	-0.1	12.4	2,073.9	0.2	1.5	1	1	1
Average/Sum#:	0.3	13.1	1,831.8	0.4	1.3	24 #	24 #	13 #
Minimum:	-0.2	12.3	1,467.6	0.1	1.0	1	1	0
Maximum:	0.6	13.7	2,100.8	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2020 00:00	-0.1	12.4	2,072.8	0.2	1.5	1	1	1
12/27/2020 01:00	-0.1	12.4	2,065.2	0.2	1.4	1	1	1
12/27/2020 02:00	-0.1	13.0	1,924.8	0.1	1.3	1	1	1
12/27/2020 03:00	0.6	13.7	1,718.1	0.6	1.2	1	1	0
12/27/2020 04:00	0.4	13.4	1,738.2	0.4	1.2	1	1	1
12/27/2020 05:00	-0.2	12.2	2,075.3	0.1	1.5	1	1	1
12/27/2020 06:00	-0.1	12.3	2,072.3	0.2	1.5	1	1	1
12/27/2020 07:00	0.7	13.6	1,709.0	0.7	1.2	1	1	1
12/27/2020 08:00	0.6	13.7	1,705.6	0.6	1.2	1	1	0
12/27/2020 09:00	0.6	13.6	1,676.0	0.6	1.2	1	1	0
12/27/2020 10:00	0.6	13.7	1,620.6	0.6	1.1	1	1	0
12/27/2020 11:00	0.6	13.7	1,653.1	0.6	1.2	1	1	0
12/27/2020 12:00	0.6	13.7	1,698.9	0.6	1.2	1	1	0
12/27/2020 13:00	0.6	13.7	1,622.9	0.6	1.1	1	1	0
12/27/2020 14:00	0.6	13.7	1,695.8	0.6	1.2	1	1	0
12/27/2020 15:00	0.4	13.5	1,735.3	0.4	1.2	1	1	1
12/27/2020 16:00	-0.2	12.3	2,081.3	0.1	1.5	1	1	1
12/27/2020 17:00	-0.2	11.9	2,164.3	0.1	1.5	1	1	1
12/27/2020 18:00	-0.1	11.8	2,180.7	0.2	1.5	1	1	1
12/27/2020 19:00	0.1	11.4	2,257.6	0.4	1.6	1	1	1
12/27/2020 20:00	0.1	11.8	2,132.8	0.2	1.5	1	1	1
12/27/2020 21:00	0.6	13.7	1,718.6	0.6	1.2	1	1	0
12/27/2020 22:00	0.4	13.1	1,863.6	0.4	1.3	1	1	1
12/27/2020 23:00	-0.1	12.0	2,130.0	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.9	1,888.0	0.4	1.3	24 #	24 #	15 #
Minimum:	-0.2	11.4	1,620.6	0.1	1.1	1	1	0
Maximum:	0.7	13.7	2,257.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2020 00:00	-0.1	12.5	1,992.2	0.1	1.4	1	1	1
12/28/2020 01:00	0.6	13.7	1,667.1	0.6	1.2	1	1	0
12/28/2020 02:00	0.5	13.2	1,853.2	0.5	1.3	1	1	1
12/28/2020 03:00	-0.1	12.3	2,077.2	0.2	1.5	1	1	1
12/28/2020 04:00	-0.1	12.7	1,943.2	0.1	1.4	1	1	1
12/28/2020 05:00	0.6	13.7	1,722.4	0.6	1.2	1	1	0
12/28/2020 06:00	0.4	13.2	1,844.7	0.4	1.3	1	1	1
12/28/2020 07:00	-0.1	11.6	2,208.7	0.2	1.5	1	1	1
12/28/2020 08:00	0.1	11.8	2,170.8	0.2	1.5	1	1	1
12/28/2020 09:00	0.1	12.4	2,020.5	0.2	1.4	1	1	1
12/28/2020 10:00	0.6	13.7	1,677.1	0.6	1.2	1	1	0
12/28/2020 11:00	0.6	13.7	1,685.5	0.6	1.2	1	1	0
12/28/2020 12:00	0.6	13.7	1,707.0	0.6	1.2	1	1	0
12/28/2020 13:00	0.6	13.7	1,685.5	0.6	1.2	1	1	0
12/28/2020 14:00	0.6	13.7	1,704.9	0.6	1.2	1	1	0
12/28/2020 15:00	0.5	13.3	1,792.3	0.5	1.3	1	1	1
12/28/2020 16:00	-0.1	12.3	2,081.9	0.2	1.5	1	1	1
12/28/2020 17:00	0.1	11.3	2,274.7	0.4	1.6	1	1	1
12/28/2020 18:00	0.2	11.3	2,278.9	0.4	1.6	1	1	1
12/28/2020 19:00	0.2	11.3	2,282.4	0.4	1.6	1	1	1
12/28/2020 20:00	0.2	11.3	2,272.8	0.4	1.6	1	1	1
12/28/2020 21:00	0.2	11.4	2,250.2	0.4	1.6	1	1	1
12/28/2020 22:00	0.1	11.6	2,216.6	0.2	1.6	1	1	1
12/28/2020 23:00	0.1	11.9	2,157.0	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.6	1,982.0	0.4	1.4	24 #	24 #	17 #
Minimum:	-0.1	11.3	1,667.1	0.1	1.2	1	1	0
Maximum:	0.6	13.7	2,282.4	0.6	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2020 00:00	0.1	11.9	2,152.9	0.2	1.5	1	1	1
12/29/2020 01:00	0.1	12.2	2,071.7	0.2	1.5	1	1	1
12/29/2020 02:00	0.6	13.7	1,725.2	0.6	1.2	1	1	0
12/29/2020 03:00	0.4	13.3	1,860.4	0.4	1.3	1	1	1
12/29/2020 04:00	-0.1	12.1	2,131.0	0.2	1.5	1	1	1
12/29/2020 05:00	-0.1	12.1	2,154.0	0.2	1.5	1	1	1
12/29/2020 06:00	0.1	11.5	2,278.5	0.2	1.6	1	1	1
12/29/2020 07:00	0.1	11.7	2,235.2	0.2	1.6	1	1	1
12/29/2020 08:00	0.1	11.8	2,209.9	0.2	1.5	1	1	1
12/29/2020 09:00	0.5	13.2	1,807.9	0.5	1.3	1	1	1
12/29/2020 10:00	0.6	13.7	1,702.2	0.6	1.2	1	1	0
12/29/2020 11:00	0.6	13.7	1,684.2	0.6	1.2	1	1	0
12/29/2020 12:00	0.6	13.8	1,706.6	0.6	1.2	1	1	0
12/29/2020 13:00	0.6	13.8	1,658.9	0.6	1.2	1	1	0
12/29/2020 14:00	0.6	13.8	1,695.0	0.6	1.2	1	1	0
12/29/2020 15:00	0.6	13.8	1,688.9	0.6	1.2	1	1	0
12/29/2020 16:00	0.7	13.5	1,711.9	0.7	1.2	1	1	1
12/29/2020 17:00	-0.1	11.9	2,171.7	0.2	1.5	1	1	1
12/29/2020 18:00	0.2	11.4	2,267.8	0.4	1.6	1	1	1
12/29/2020 19:00	0.2	11.4	2,270.1	0.4	1.6	1	1	1
12/29/2020 20:00	0.1	11.9	2,173.5	0.2	1.5	1	1	1
12/29/2020 21:00	0.1	12.2	2,106.8	0.2	1.5	1	1	1
12/29/2020 22:00	0.1	12.2	2,108.8	0.2	1.5	1	1	1
12/29/2020 23:00	0.1	12.5	2,073.1	0.2	1.5	1	1	1
Average/Sum#:	0.3	12.6	1,985.3	0.4	1.4	24 #	24 #	17 #
Minimum:	-0.1	11.4	1,658.9	0.2	1.2	1	1	0
Maximum:	0.7	13.8	2,278.5	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2020 00:00	0.1	12.6	2,062.9	0.2	1.4	1	1	1
12/30/2020 01:00	-0.2	13.1	1,930.0	-0.1	1.4	1	1	1
12/30/2020 02:00	0.6	13.7	1,711.6	0.6	1.2	1	1	0
12/30/2020 03:00	0.2	13.5	1,732.5	0.4	1.2	1	1	1
12/30/2020 04:00	-0.2	12.8	2,041.6	0.1	1.4	1	1	1
12/30/2020 05:00	-0.1	12.5	2,068.3	0.1	1.4	1	1	1
12/30/2020 06:00	-0.2	12.0	2,204.9	0.1	1.5	1	1	1
12/30/2020 07:00	-0.2	12.4	2,112.0	0.1	1.5	1	1	1
12/30/2020 08:00	-0.2	12.7	2,041.4	0.1	1.4	1	1	1
12/30/2020 09:00	-0.7	13.0	1,952.5	-0.4	1.4	1	1	1
12/30/2020 10:00	0.6	13.7	1,721.6	0.6	1.2	1	1	0
12/30/2020 11:00	0.6	13.7	1,703.1	0.6	1.2	1	1	0
12/30/2020 12:00	0.6	13.7	1,700.5	0.6	1.2	1	1	0
12/30/2020 13:00	0.6	13.7	1,660.7	0.6	1.2	1	1	0
12/30/2020 14:00	0.6	13.7	1,660.4	0.6	1.2	1	1	0
12/30/2020 15:00	0.4	13.5	1,735.1	0.4	1.2	1	1	1
12/30/2020 16:00	-0.2	12.5	2,046.4	0.1	1.4	1	1	1
12/30/2020 17:00	-0.2	11.9	2,165.5	0.1	1.5	1	1	1
12/30/2020 18:00	-0.1	11.9	2,154.1	0.2	1.5	1	1	1
12/30/2020 19:00	-0.1	12.3	2,077.2	0.2	1.5	1	1	1
12/30/2020 20:00	-0.1	12.2	2,100.2	0.2	1.5	1	1	1
12/30/2020 21:00	-0.1	12.2	2,092.7	0.2	1.5	1	1	1
12/30/2020 22:00	-0.1	12.3	2,065.3	0.2	1.4	1	1	1
12/30/2020 23:00	-0.1	12.5	2,055.5	0.1	1.4	1	1	1
Average/Sum#:	0.1	12.8	1,949.8	0.2	1.4	24 #	24 #	18 #
Minimum:	-0.7	11.9	1,660.4	-0.4	1.2	1	1	0
Maximum:	0.6	13.7	2,204.9	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:36 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2020 00:00	-0.4	13.0	1,924.4	-0.1	1.3	1	1	1
12/31/2020 01:00	0.6	13.6	1,644.1	0.6	1.2	1	1	0
12/31/2020 02:00	0.1	13.3	1,843.4	0.2	1.3	1	1	1
12/31/2020 03:00	-0.5	13.0	1,948.6	-0.2	1.4	1	1	1
12/31/2020 04:00	-0.5	13.0	1,928.5	-0.2	1.3	1	1	1
12/31/2020 05:00	0.6	13.6	1,712.4	0.6	1.2	1	1	0
12/31/2020 06:00	0.5	13.6	1,702.8	0.5	1.2	1	1	0
12/31/2020 07:00	0.5	13.6	1,661.0	0.5	1.2	1	1	0
12/31/2020 08:00	0.5	13.7	1,616.7	0.5	1.1	1	1	0
12/31/2020 09:00	0.6	13.7	1,683.3	0.6	1.2	1	1	0
12/31/2020 10:00	0.6	13.7	1,705.5	0.6	1.2	1	1	0
12/31/2020 11:00	0.6	13.7	1,700.2	0.6	1.2	1	1	0
12/31/2020 12:00	0.6	13.7	1,664.4	0.6	1.2	1	1	0
12/31/2020 13:00	0.6	13.7	1,650.5	0.6	1.2	1	1	0
12/31/2020 14:00	0.6	13.7	1,663.6	0.6	1.2	1	1	0
12/31/2020 15:00	0.6	13.7	1,708.6	0.6	1.2	1	1	0
12/31/2020 16:00	0.4	13.2	1,845.1	0.4	1.3	1	1	1
12/31/2020 17:00	-0.2	12.1	2,115.1	0.1	1.5	1	1	1
12/31/2020 18:00	-0.1	11.9	2,170.2	0.2	1.5	1	1	1
12/31/2020 19:00	-0.1	11.9	2,169.0	0.2	1.5	1	1	1
12/31/2020 20:00	-0.1	11.9	2,170.8	0.2	1.5	1	1	1
12/31/2020 21:00	-0.1	11.9	2,167.5	0.2	1.5	1	1	1
12/31/2020 22:00	-0.1	12.1	2,135.4	0.2	1.5	1	1	1
12/31/2020 23:00	-0.1	12.2	2,096.1	0.2	1.5	1	1	1
Average/Sum#:	0.2	13.1	1,859.5	0.3	1.3	24 #	24 #	12 #
Minimum:	-0.5	11.9	1,616.7	-0.2	1.1	1	1	0
Maximum:	0.6	13.7	2,170.8	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2020 00:00	0.4	13.9	1,618.5	0.4	0.5	1	1	0
10/01/2020 01:00	0.1	13.3	1,765.8	0.2	0.5	1	1	1
10/01/2020 02:00	0.2	12.6	1,963.0	0.4	0.6	1	1	1
10/01/2020 03:00	0.4	12.4	1,975.4	0.5	0.6	1	1	1
10/01/2020 04:00	0.4	13.9	1,648.7	0.4	0.5	1	1	0
10/01/2020 05:00	-0.1	13.4	1,805.5	0.1	0.5	1	1	1
10/01/2020 06:00	-0.1	12.5	2,048.9	0.1	0.6	1	1	1
10/01/2020 07:00	-0.1	13.0	1,834.6	0.1	0.6	1	1	1
10/01/2020 08:00	0.4	13.9	1,538.0	0.4	0.5	1	1	0
10/01/2020 09:00	0.4	14.0	1,318.5	0.4	0.4	1	1	0
10/01/2020 10:00	0.4	13.9	1,496.3	0.4	0.4	1	1	1
10/01/2020 11:00	-0.1	12.5	2,026.6	0.1	0.6	1	1	1
10/01/2020 12:00	0.1	12.1	2,106.3	0.2	0.6	1	1	1
10/01/2020 13:00	0.1	11.9	2,141.9	0.2	0.6	1	1	1
10/01/2020 14:00	0.1	11.8	2,147.8	0.2	0.6	1	1	1
10/01/2020 15:00	0.1	11.9	2,120.4	0.2	0.6	1	1	1
10/01/2020 16:00	0.1	12.0	2,103.1	0.2	0.6	1	1	1
10/01/2020 17:00	0.1	12.0	2,097.1	0.2	0.6	1	1	1
10/01/2020 18:00	0.1	12.2	2,071.7	0.2	0.6	1	1	1
10/01/2020 19:00	0.1	12.1	2,076.0	0.2	0.6	1	1	1
10/01/2020 20:00	0.1	12.1	2,087.3	0.2	0.6	1	1	1
10/01/2020 21:00	0.1	12.2	2,088.7	0.2	0.6	1	1	1
10/01/2020 22:00	-0.1	12.3	2,065.0	0.2	0.6	1	1	1
10/01/2020 23:00	-0.1	12.6	1,987.4	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.7	1,922.2	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.8	1,318.5	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,147.8	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2020 00:00	0.4	13.8	1,574.6	0.4	0.5	1	1	0
10/02/2020 01:00	0.4	13.8	1,698.7	0.4	0.5	1	1	0
10/02/2020 02:00	0.4	13.9	1,537.3	0.4	0.5	1	1	0
10/02/2020 03:00	0.4	13.9	1,579.8	0.4	0.5	1	1	0
10/02/2020 04:00	0.1	13.6	1,665.0	0.2	0.5	1	1	1
10/02/2020 05:00	-0.2	12.6	2,033.1	0.1	0.6	1	1	1
10/02/2020 06:00	-0.2	12.7	1,991.3	0.1	0.6	1	1	1
10/02/2020 07:00	0.4	13.8	1,751.4	0.4	0.5	1	1	0
10/02/2020 08:00	0.4	13.9	1,464.0	0.4	0.4	1	1	0
10/02/2020 09:00	0.4	14.0	1,584.4	0.4	0.5	1	1	0
10/02/2020 10:00	0.4	14.0	1,617.5	0.4	0.5	1	1	0
10/02/2020 11:00	0.2	13.6	1,668.7	0.4	0.5	1	1	1
10/02/2020 12:00	-0.1	12.2	2,072.1	0.2	0.6	1	1	1
10/02/2020 13:00	0.1	11.8	2,164.4	0.2	0.6	1	1	1
10/02/2020 14:00	0.1	11.7	2,157.9	0.2	0.6	1	1	1
10/02/2020 15:00	0.1	11.8	2,137.7	0.2	0.6	1	1	1
10/02/2020 16:00	0.1	11.8	2,139.0	0.2	0.6	1	1	1
10/02/2020 17:00	0.2	11.8	2,142.9	0.4	0.6	1	1	1
10/02/2020 18:00	0.1	12.0	2,110.0	0.2	0.6	1	1	1
10/02/2020 19:00	0.1	12.1	2,085.0	0.2	0.6	1	1	1
10/02/2020 20:00	0.1	12.1	2,090.1	0.2	0.6	1	1	1
10/02/2020 21:00	-0.1	12.4	2,028.9	0.2	0.6	1	1	1
10/02/2020 22:00	-0.1	12.4	2,047.1	0.2	0.6	1	1	1
10/02/2020 23:00	-0.1	12.3	2,056.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,891.6	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.2	11.7	1,464.0	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,164.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2020 00:00	0.0	14.1	1,257.5	0.0	0.4	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 12:00	0.0	17.7	455.8	0.0	0.1	1	0	0
10/03/2020 13:00	0.0	14.6	1,149.2	0.0	0.3	1	0	0
10/03/2020 14:00	0.4	13.9	1,610.8	0.4	0.5	1	1	0
10/03/2020 15:00	0.2	13.6	1,631.8	0.4	0.5	1	1	1
10/03/2020 16:00	0.1	12.1	2,072.1	0.2	0.6	1	1	1
10/03/2020 17:00	0.2	11.8	2,152.4	0.4	0.6	1	1	1
10/03/2020 18:00	0.2	11.9	2,135.4	0.4	0.6	1	1	1
10/03/2020 19:00	0.1	11.9	2,138.9	0.2	0.6	1	1	1
10/03/2020 20:00	0.1	12.2	2,076.3	0.2	0.6	1	1	1
10/03/2020 21:00	-0.1	12.5	2,009.6	0.1	0.6	1	1	1
10/03/2020 22:00	0.0	13.8	1,437.2	0.0	0.4	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.1	13.3	1,677.3	0.2	0.5	12 #	8 #	9 #
Minimum:	-0.1	11.8	455.8	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,152.4	0.4	0.6	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 13:00	0.0	17.0	534.1	0.0	0.2	1	0	0
10/04/2020 14:00	0.0	14.1	1,394.0	0.0	0.4	1	0	0
10/04/2020 15:00	0.4	13.8	1,700.8	0.4	0.5	1	1	0
10/04/2020 16:00	-0.1	13.1	1,814.1	0.1	0.5	1	1	1
10/04/2020 17:00	-0.1	12.1	2,087.0	0.2	0.6	1	1	1
10/04/2020 18:00	-0.1	12.4	2,024.0	0.2	0.6	1	1	1
10/04/2020 19:00	-0.1	12.5	2,017.4	0.1	0.6	1	1	1
10/04/2020 20:00	-0.1	12.4	2,020.3	0.2	0.6	1	1	1
10/04/2020 21:00	-0.1	12.3	2,047.7	0.2	0.6	1	1	1
10/04/2020 22:00	-0.2	12.9	1,926.2	0.1	0.6	1	1	1
10/04/2020 23:00	-0.2	13.0	1,899.0	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,769.5	0.1	0.5	11 #	9 #	8 #
Minimum:	-0.2	12.1	534.1	0.0	0.2	0	0	0
Maximum:	0.4	17.0	2,087.0	0.4	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2020 00:00	0.4	13.9	1,649.9	0.4	0.5	1	1	0
10/05/2020 01:00	0.4	13.9	1,639.6	0.4	0.5	1	1	0
10/05/2020 02:00	0.4	13.9	1,590.4	0.4	0.5	1	1	0
10/05/2020 03:00	0.4	14.0	1,566.2	0.4	0.5	1	1	0
10/05/2020 04:00	0.1	13.7	1,664.3	0.2	0.5	1	1	1
10/05/2020 05:00	-0.2	12.6	2,041.3	0.1	0.6	1	1	1
10/05/2020 06:00	-0.1	12.5	2,025.0	0.1	0.6	1	1	1
10/05/2020 07:00	0.4	13.9	1,538.7	0.4	0.5	1	1	0
10/05/2020 08:00	0.4	13.9	1,529.4	0.4	0.5	1	1	0
10/05/2020 09:00	0.4	13.9	1,587.6	0.4	0.5	1	1	0
10/05/2020 10:00	0.4	14.0	1,577.6	0.4	0.5	1	1	0
10/05/2020 11:00	0.4	13.9	1,623.9	0.4	0.5	1	1	0
10/05/2020 12:00	0.4	13.9	1,653.1	0.4	0.5	1	1	0
10/05/2020 13:00	-0.1	13.2	1,791.3	0.1	0.5	1	1	1
10/05/2020 14:00	0.1	11.9	2,153.9	0.2	0.6	1	1	1
10/05/2020 15:00	0.2	11.8	2,164.4	0.4	0.6	1	1	1
10/05/2020 16:00	0.2	11.8	2,160.9	0.4	0.6	1	1	1
10/05/2020 17:00	0.2	11.9	2,137.8	0.4	0.6	1	1	1
10/05/2020 18:00	0.2	11.8	2,151.7	0.4	0.6	1	1	1
10/05/2020 19:00	0.1	12.4	2,040.2	0.2	0.6	1	1	1
10/05/2020 20:00	0.1	12.4	2,038.1	0.2	0.6	1	1	1
10/05/2020 21:00	-0.1	12.5	2,042.9	0.1	0.6	1	1	1
10/05/2020 22:00	0.0	14.1	1,243.9	0.0	0.4	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.1	1,809.2	0.3	0.5	23 #	22 #	13 #
Minimum:	-0.2	11.8	1,243.9	0.0	0.4	0	0	0
Maximum:	0.4	14.1	2,164.4	0.4	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 11:00	0.0	17.2	504.7	0.0	0.2	1	0	0
10/06/2020 12:00	0.0	14.3	1,333.6	0.0	0.4	1	0	0
10/06/2020 13:00	0.4	13.9	1,639.2	0.4	0.5	1	1	0
10/06/2020 14:00	0.1	13.6	1,732.8	0.2	0.5	1	1	1
10/06/2020 15:00	-0.1	12.2	2,090.8	0.2	0.6	1	1	1
10/06/2020 16:00	0.2	11.9	2,135.4	0.4	0.6	1	1	1
10/06/2020 17:00	0.2	11.8	2,151.9	0.4	0.6	1	1	1
10/06/2020 18:00	0.2	11.8	2,152.4	0.4	0.6	1	1	1
10/06/2020 19:00	0.1	11.9	2,125.6	0.2	0.6	1	1	1
10/06/2020 20:00	0.2	13.6	1,657.4	0.4	0.5	1	1	1
10/06/2020 21:00	-0.1	13.3	1,800.0	0.1	0.5	1	1	1
10/06/2020 22:00	-0.1	12.4	2,057.1	0.2	0.6	1	1	1
10/06/2020 23:00	-0.2	12.8	1,972.4	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,796.4	0.2	0.5	13 #	11 #	10 #
Minimum:	-0.2	11.8	504.7	0.0	0.2	0	0	0
Maximum:	0.4	17.2	2,152.4	0.4	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2020 00:00	-0.1	12.6	2,020.8	0.1	0.6	1	1	1
10/07/2020 01:00	-0.1	12.8	1,953.3	0.1	0.6	1	1	1
10/07/2020 02:00	0.4	13.9	1,524.9	0.4	0.5	1	1	0
10/07/2020 03:00	0.4	14.0	1,592.4	0.4	0.5	1	1	0
10/07/2020 04:00	-0.1	13.3	1,815.9	0.1	0.5	1	1	1
10/07/2020 05:00	-0.1	12.3	2,095.6	0.2	0.6	1	1	1
10/07/2020 06:00	-0.1	12.7	2,017.7	0.1	0.6	1	1	1
10/07/2020 07:00	0.4	13.9	1,587.0	0.4	0.5	1	1	0
10/07/2020 08:00	0.4	14.0	1,356.8	0.4	0.4	1	1	0
10/07/2020 09:00	0.4	14.0	1,292.7	0.4	0.4	1	1	0
10/07/2020 10:00	0.5	14.0	1,349.1	0.5	0.4	1	1	0
10/07/2020 11:00	0.1	13.4	1,759.4	0.2	0.5	1	1	1
10/07/2020 12:00	0.1	12.0	2,126.6	0.2	0.6	1	1	1
10/07/2020 13:00	0.1	11.9	2,135.4	0.2	0.6	1	1	1
10/07/2020 14:00	0.2	13.5	1,690.8	0.4	0.5	1	1	1
10/07/2020 15:00	-0.1	13.2	1,774.8	0.1	0.5	1	1	1
10/07/2020 16:00	-0.1	12.2	2,058.2	0.2	0.6	1	1	1
10/07/2020 17:00	0.1	11.9	2,125.6	0.2	0.6	1	1	1
10/07/2020 18:00	0.1	12.1	2,083.9	0.2	0.6	1	1	1
10/07/2020 19:00	-0.1	12.3	2,015.1	0.2	0.6	1	1	1
10/07/2020 20:00	0.4	13.9	1,669.8	0.4	0.5	1	1	0
10/07/2020 21:00	-0.1	13.3	1,804.7	0.1	0.5	1	1	1
10/07/2020 22:00	-0.1	12.3	2,073.8	0.2	0.6	1	1	1
10/07/2020 23:00	0.0	14.2	1,205.7	0.0	0.4	1	0	1
Average/Sum#:	0.1	13.1	1,797.1	0.2	0.5	24 #	23 #	17 #
Minimum:	-0.1	11.9	1,205.7	0.0	0.4	1	0	0
Maximum:	0.5	14.2	2,135.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 01:00	0.0	17.6	450.9	0.0	0.1	1	0	0
10/11/2020 02:00	0.0	16.3	628.2	0.0	0.2	1	0	0
10/11/2020 03:00	0.0	15.7	709.1	0.0	0.2	1	0	0
10/11/2020 04:00	0.0	15.4	869.3	0.0	0.3	1	0	0
10/11/2020 05:00	0.4	14.0	1,351.9	0.4	0.4	1	1	0
10/11/2020 06:00	0.4	14.0	1,340.8	0.4	0.4	1	1	0
10/11/2020 07:00	0.4	14.0	1,337.8	0.4	0.4	1	1	0
10/11/2020 08:00	0.4	14.0	1,338.1	0.4	0.4	1	1	0
10/11/2020 09:00	0.5	14.0	1,340.5	0.5	0.4	1	1	0
10/11/2020 10:00	0.5	14.0	1,343.3	0.5	0.4	1	1	0
10/11/2020 11:00	0.5	14.0	1,346.4	0.5	0.4	1	1	0
10/11/2020 12:00	0.5	14.0	1,348.2	0.5	0.4	1	1	0
10/11/2020 13:00	0.5	14.1	1,349.6	0.5	0.4	1	1	0
10/11/2020 14:00	0.5	14.1	1,351.7	0.5	0.4	1	1	0
10/11/2020 15:00	0.5	14.1	1,366.6	0.5	0.4	1	1	0
10/11/2020 16:00	-0.5	13.0	1,928.8	-0.2	0.6	1	1	1
10/11/2020 17:00	-0.5	13.0	1,938.8	-0.2	0.6	1	1	1
10/11/2020 18:00	-0.5	13.0	1,926.5	-0.2	0.6	1	1	1
10/11/2020 19:00	-0.5	13.0	1,907.7	-0.2	0.6	1	1	1
10/11/2020 20:00	0.4	14.0	1,352.7	0.4	0.4	1	1	0
10/11/2020 21:00	0.4	14.0	1,335.6	0.4	0.4	1	1	0
10/11/2020 22:00	0.4	14.0	1,335.7	0.4	0.4	1	1	0
10/11/2020 23:00	0.4	14.0	1,335.0	0.4	0.4	1	1	0
Average/Sum#:	0.2	14.2	1,327.5	0.3	0.4	23 #	19 #	4 #
Minimum:	-0.5	13.0	450.9	-0.2	0.1	0	0	0
Maximum:	0.5	17.6	1,938.8	0.5	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2020 00:00	0.4	14.0	1,335.1	0.4	0.4	1	1	0
10/12/2020 01:00	0.4	14.0	1,335.8	0.4	0.4	1	1	0
10/12/2020 02:00	0.4	14.0	1,335.6	0.4	0.4	1	1	0
10/12/2020 03:00	0.4	14.0	1,334.0	0.4	0.4	1	1	0
10/12/2020 04:00	0.4	14.0	1,334.5	0.4	0.4	1	1	0
10/12/2020 05:00	0.4	14.0	1,333.0	0.4	0.4	1	1	0
10/12/2020 06:00	0.4	14.0	1,332.0	0.4	0.4	1	1	0
10/12/2020 07:00	0.4	14.0	1,337.7	0.4	0.4	1	1	0
10/12/2020 08:00	0.4	14.0	1,337.5	0.4	0.4	1	1	0
10/12/2020 09:00	0.4	14.0	1,342.6	0.4	0.4	1	1	0
10/12/2020 10:00	0.4	14.0	1,346.6	0.4	0.4	1	1	0
10/12/2020 11:00	0.5	14.0	1,347.3	0.5	0.4	1	1	0
10/12/2020 12:00	0.4	14.0	1,604.1	0.4	0.5	1	1	0
10/12/2020 13:00	0.4	14.0	1,533.8	0.4	0.5	1	1	0
10/12/2020 14:00	0.4	14.0	1,563.5	0.4	0.5	1	1	0
10/12/2020 15:00	0.1	13.6	1,651.4	0.2	0.5	1	1	1
10/12/2020 16:00	-0.2	12.6	2,006.2	0.1	0.6	1	1	1
10/12/2020 17:00	-0.2	12.6	1,992.1	0.1	0.6	1	1	1
10/12/2020 18:00	-0.2	12.7	1,979.4	0.1	0.6	1	1	1
10/12/2020 19:00	-0.2	12.9	1,914.1	0.1	0.6	1	1	1
10/12/2020 20:00	0.4	13.8	1,742.0	0.4	0.5	1	1	0
10/12/2020 21:00	-0.1	13.4	1,787.9	0.1	0.5	1	1	1
10/12/2020 22:00	-0.2	12.7	1,987.3	0.1	0.6	1	1	1
10/12/2020 23:00	-0.2	12.9	1,949.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.6	1,573.5	0.3	0.5	24 #	24 #	8 #
Minimum:	-0.2	12.6	1,332.0	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,006.2	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2020 00:00	0.4	13.9	1,656.6	0.4	0.5	1	1	0
10/13/2020 01:00	0.4	13.9	1,609.3	0.4	0.5	1	1	0
10/13/2020 02:00	0.4	13.9	1,386.6	0.4	0.4	1	1	0
10/13/2020 03:00	0.4	13.9	1,592.3	0.4	0.5	1	1	0
10/13/2020 04:00	-0.1	13.4	1,797.1	0.1	0.5	1	1	1
10/13/2020 05:00	-0.2	12.8	1,978.1	0.1	0.6	1	1	1
10/13/2020 06:00	-0.2	13.0	1,931.3	0.1	0.6	1	1	1
10/13/2020 07:00	0.4	13.9	1,637.2	0.4	0.5	1	1	0
10/13/2020 08:00	0.4	13.9	1,474.1	0.4	0.4	1	1	0
10/13/2020 09:00	0.4	14.0	1,343.1	0.4	0.4	1	1	0
10/13/2020 10:00	0.4	13.9	1,610.2	0.4	0.5	1	1	0
10/13/2020 11:00	0.4	13.9	1,489.4	0.4	0.4	1	1	0
10/13/2020 12:00	0.4	13.9	1,490.4	0.4	0.4	1	1	0
10/13/2020 13:00	0.4	14.0	1,397.9	0.4	0.4	1	1	0
10/13/2020 14:00	0.4	13.9	1,602.2	0.4	0.5	1	1	0
10/13/2020 15:00	0.1	13.6	1,639.2	0.2	0.5	1	1	1
10/13/2020 16:00	-0.2	12.5	2,022.3	0.1	0.6	1	1	1
10/13/2020 17:00	-0.1	12.4	2,035.1	0.2	0.6	1	1	1
10/13/2020 18:00	-0.1	12.5	2,007.6	0.1	0.6	1	1	1
10/13/2020 19:00	-0.1	12.8	1,940.0	0.1	0.6	1	1	1
10/13/2020 20:00	0.4	13.9	1,690.7	0.4	0.5	1	1	0
10/13/2020 21:00	0.1	13.4	1,800.7	0.2	0.5	1	1	1
10/13/2020 22:00	0.1	12.2	2,106.2	0.2	0.6	1	1	1
10/13/2020 23:00	-0.1	12.8	1,938.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,715.7	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	12.2	1,343.1	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,106.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2020 00:00	0.4	13.9	1,664.7	0.4	0.5	1	1	0
10/14/2020 01:00	0.2	13.7	1,657.8	0.4	0.5	1	1	1
10/14/2020 02:00	-0.1	12.5	2,046.2	0.1	0.6	1	1	1
10/14/2020 03:00	-0.1	12.9	1,927.8	0.1	0.6	1	1	1
10/14/2020 04:00	0.4	13.9	1,595.8	0.4	0.5	1	1	0
10/14/2020 05:00	0.1	13.5	1,801.3	0.2	0.5	1	1	1
10/14/2020 06:00	-0.1	12.7	2,001.0	0.1	0.6	1	1	1
10/14/2020 07:00	-0.1	12.9	1,913.1	0.1	0.6	1	1	1
10/14/2020 08:00	0.5	13.9	1,409.5	0.5	0.4	1	1	0
10/14/2020 09:00	0.5	14.0	1,303.6	0.5	0.4	1	1	0
10/14/2020 10:00	0.5	14.0	1,531.6	0.5	0.5	1	1	0
10/14/2020 11:00	0.2	13.5	1,754.8	0.4	0.5	1	1	1
10/14/2020 12:00	0.1	12.1	2,097.1	0.2	0.6	1	1	1
10/14/2020 13:00	0.2	11.9	2,129.3	0.4	0.6	1	1	1
10/14/2020 14:00	0.4	13.8	1,741.2	0.4	0.5	1	1	1
10/14/2020 15:00	0.4	13.7	1,813.9	0.4	0.5	1	1	1
10/14/2020 16:00	-0.1	12.1	2,106.5	0.2	0.6	1	1	1
10/14/2020 17:00	0.2	11.8	2,177.4	0.4	0.7	1	1	1
10/14/2020 18:00	0.1	12.1	2,100.8	0.2	0.6	1	1	1
10/14/2020 19:00	0.1	12.2	2,044.5	0.2	0.6	1	1	1
10/14/2020 20:00	0.4	13.9	1,680.5	0.4	0.5	1	1	0
10/14/2020 21:00	0.1	13.2	1,832.9	0.2	0.5	1	1	1
10/14/2020 22:00	0.1	12.0	2,151.6	0.2	0.6	1	1	1
10/14/2020 23:00	-0.1	12.6	1,989.7	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,853.0	0.3	0.5	24 #	24 #	18 #
Minimum:	-0.1	11.8	1,303.6	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,177.4	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2020 00:00	0.4	13.9	1,670.7	0.4	0.5	1	1	0
10/15/2020 01:00	0.1	13.4	1,802.1	0.2	0.5	1	1	1
10/15/2020 02:00	-0.1	12.2	2,121.8	0.2	0.6	1	1	1
10/15/2020 03:00	-0.1	12.3	2,071.3	0.2	0.6	1	1	1
10/15/2020 04:00	0.4	13.9	1,688.0	0.4	0.5	1	1	0
10/15/2020 05:00	-0.1	13.5	1,822.9	0.1	0.5	1	1	1
10/15/2020 06:00	-0.2	12.5	2,056.6	0.1	0.6	1	1	1
10/15/2020 07:00	-0.1	12.9	1,849.1	0.1	0.6	1	1	1
10/15/2020 08:00	0.4	14.0	1,300.9	0.4	0.4	1	1	0
10/15/2020 09:00	0.5	14.0	1,297.9	0.5	0.4	1	1	0
10/15/2020 10:00	0.5	14.0	1,316.1	0.5	0.4	1	1	0
10/15/2020 11:00	0.4	13.9	1,561.7	0.4	0.5	1	1	0
10/15/2020 12:00	0.4	13.9	1,635.0	0.4	0.5	1	1	0
10/15/2020 13:00	-0.1	13.3	1,804.6	0.1	0.5	1	1	1
10/15/2020 14:00	0.1	11.9	2,164.7	0.2	0.6	1	1	1
10/15/2020 15:00	0.1	11.8	2,175.2	0.2	0.7	1	1	1
10/15/2020 16:00	0.2	11.8	2,168.1	0.4	0.7	1	1	1
10/15/2020 17:00	0.1	11.9	2,145.0	0.2	0.6	1	1	1
10/15/2020 18:00	0.1	11.9	2,155.3	0.2	0.6	1	1	1
10/15/2020 19:00	0.1	12.0	2,132.4	0.2	0.6	1	1	1
10/15/2020 20:00	0.1	11.9	2,155.8	0.2	0.6	1	1	1
10/15/2020 21:00	0.2	11.8	2,175.1	0.4	0.7	1	1	1
10/15/2020 22:00	0.1	12.0	2,136.9	0.2	0.6	1	1	1
10/15/2020 23:00	0.1	12.4	2,014.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,892.6	0.3	0.6	24 #	24 #	17 #
Minimum:	-0.2	11.8	1,297.9	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,175.2	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2020 00:00	0.4	13.8	1,702.4	0.4	0.5	1	1	0
10/16/2020 01:00	0.4	14.0	1,312.2	0.4	0.4	1	1	0
10/16/2020 02:00	0.4	13.8	1,680.6	0.4	0.5	1	1	0
10/16/2020 03:00	-0.1	13.4	1,804.3	0.1	0.5	1	1	1
10/16/2020 04:00	-0.1	12.9	1,883.6	0.1	0.6	1	1	1
10/16/2020 05:00	0.4	13.8	1,690.3	0.4	0.5	1	1	1
10/16/2020 06:00	0.1	12.4	2,029.9	0.2	0.6	1	1	1
10/16/2020 07:00	-0.1	12.8	1,944.4	0.1	0.6	1	1	1
10/16/2020 08:00	0.4	13.9	1,592.7	0.4	0.5	1	1	0
10/16/2020 09:00	0.4	14.0	1,393.6	0.4	0.4	1	1	0
10/16/2020 10:00	0.5	14.0	1,504.5	0.5	0.5	1	1	0
10/16/2020 11:00	0.2	13.7	1,579.5	0.4	0.5	1	1	1
10/16/2020 12:00	0.1	12.1	2,104.8	0.2	0.6	1	1	1
10/16/2020 13:00	0.1	12.2	2,071.4	0.2	0.6	1	1	1
10/16/2020 14:00	0.2	11.9	2,126.5	0.4	0.6	1	1	1
10/16/2020 15:00	0.2	11.9	2,131.6	0.4	0.6	1	1	1
10/16/2020 16:00	0.1	12.3	2,044.6	0.2	0.6	1	1	1
10/16/2020 17:00	0.1	12.1	2,090.7	0.2	0.6	1	1	1
10/16/2020 18:00	0.1	12.2	2,079.8	0.2	0.6	1	1	1
10/16/2020 19:00	0.2	11.9	2,146.3	0.4	0.6	1	1	1
10/16/2020 20:00	0.2	12.0	2,121.0	0.4	0.6	1	1	1
10/16/2020 21:00	0.1	12.1	2,093.4	0.2	0.6	1	1	1
10/16/2020 22:00	0.1	12.3	2,048.1	0.2	0.6	1	1	1
10/16/2020 23:00	0.1	12.5	2,007.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,882.7	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.1	11.9	1,312.2	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,146.3	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2020 00:00	-0.1	12.8	1,927.3	0.1	0.6	1	1	1
10/17/2020 01:00	0.4	13.9	1,546.0	0.4	0.5	1	1	0
10/17/2020 02:00	0.4	14.0	1,312.2	0.4	0.4	1	1	0
10/17/2020 03:00	0.4	14.0	1,607.7	0.4	0.5	1	1	0
10/17/2020 04:00	0.4	14.0	1,602.7	0.4	0.5	1	1	0
10/17/2020 05:00	0.4	13.9	1,656.1	0.4	0.5	1	1	0
10/17/2020 06:00	-0.1	13.3	1,795.5	0.1	0.5	1	1	1
10/17/2020 07:00	0.1	13.0	1,842.5	0.2	0.6	1	1	1
10/17/2020 08:00	0.4	13.8	1,669.7	0.4	0.5	1	1	0
10/17/2020 09:00	0.4	13.8	1,675.8	0.4	0.5	1	1	0
10/17/2020 10:00	0.4	13.9	1,625.3	0.4	0.5	1	1	0
10/17/2020 11:00	0.4	13.9	1,479.6	0.4	0.4	1	1	0
10/17/2020 12:00	0.4	14.0	1,463.6	0.4	0.4	1	1	0
10/17/2020 13:00	0.5	14.0	1,453.4	0.5	0.4	1	1	0
10/17/2020 14:00	0.2	13.6	1,642.4	0.4	0.5	1	1	1
10/17/2020 15:00	0.1	12.1	2,088.5	0.2	0.6	1	1	1
10/17/2020 16:00	0.2	11.8	2,155.1	0.4	0.6	1	1	1
10/17/2020 17:00	0.2	11.8	2,156.5	0.4	0.6	1	1	1
10/17/2020 18:00	0.1	12.3	2,031.7	0.2	0.6	1	1	1
10/17/2020 19:00	0.1	12.3	2,048.0	0.2	0.6	1	1	1
10/17/2020 20:00	0.1	12.3	2,062.9	0.2	0.6	1	1	1
10/17/2020 21:00	0.1	12.7	1,983.4	0.2	0.6	1	1	1
10/17/2020 22:00	0.1	12.3	2,060.7	0.2	0.6	1	1	1
10/17/2020 23:00	0.1	12.3	2,058.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,789.4	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.1	11.8	1,312.2	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,156.5	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2020 00:00	0.2	13.6	1,686.2	0.4	0.5	1	1	1
10/18/2020 01:00	0.1	13.3	1,799.9	0.2	0.5	1	1	1
10/18/2020 02:00	0.2	12.0	2,148.4	0.4	0.6	1	1	1
10/18/2020 03:00	0.2	12.1	2,081.3	0.4	0.6	1	1	1
10/18/2020 04:00	0.4	13.8	1,659.3	0.4	0.5	1	1	0
10/18/2020 05:00	0.4	13.8	1,595.8	0.4	0.5	1	1	0
10/18/2020 06:00	0.4	13.8	1,553.3	0.4	0.5	1	1	0
10/18/2020 07:00	0.4	13.9	1,499.9	0.4	0.4	1	1	0
10/18/2020 08:00	0.4	13.9	1,599.2	0.4	0.5	1	1	0
10/18/2020 09:00	0.5	13.9	1,607.8	0.5	0.5	1	1	0
10/18/2020 10:00	0.5	14.0	1,573.1	0.5	0.5	1	1	0
10/18/2020 11:00	0.5	14.0	1,606.9	0.5	0.5	1	1	0
10/18/2020 12:00	0.4	13.9	1,618.8	0.4	0.5	1	1	0
10/18/2020 13:00	0.4	13.8	1,596.6	0.4	0.5	1	1	0
10/18/2020 14:00	0.4	13.8	1,629.2	0.4	0.5	1	1	0
10/18/2020 15:00	0.1	13.5	1,737.8	0.2	0.5	1	1	1
10/18/2020 16:00	0.1	12.1	2,057.6	0.2	0.6	1	1	1
10/18/2020 17:00	0.1	13.1	1,757.7	0.2	0.5	1	1	1
10/18/2020 18:00	0.5	14.0	1,284.1	0.5	0.4	1	1	0
10/18/2020 19:00	0.5	14.0	1,377.8	0.5	0.4	1	1	0
10/18/2020 20:00	0.4	13.8	1,688.6	0.4	0.5	1	1	0
10/18/2020 21:00	0.4	13.9	1,681.8	0.4	0.5	1	1	0
10/18/2020 22:00	0.5	13.9	1,485.3	0.5	0.4	1	1	0
10/18/2020 23:00	0.1	13.4	1,795.7	0.2	0.5	1	1	1
Average/Sum#:	0.3	13.6	1,671.8	0.4	0.5	24 #	24 #	8 #
Minimum:	0.1	12.0	1,284.1	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,148.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2020 00:00	0.1	13.1	1,830.2	0.2	0.5	1	1	1
10/19/2020 01:00	0.4	13.8	1,621.3	0.4	0.5	1	1	0
10/19/2020 02:00	0.4	13.8	1,573.3	0.4	0.5	1	1	0
10/19/2020 03:00	0.4	13.8	1,673.4	0.4	0.5	1	1	0
10/19/2020 04:00	0.1	13.4	1,804.0	0.2	0.5	1	1	1
10/19/2020 05:00	0.1	12.3	2,087.1	0.2	0.6	1	1	1
10/19/2020 06:00	0.1	12.4	2,052.5	0.2	0.6	1	1	1
10/19/2020 07:00	0.4	13.8	1,681.4	0.4	0.5	1	1	0
10/19/2020 08:00	0.4	13.9	1,550.3	0.4	0.5	1	1	0
10/19/2020 09:00	0.4	13.9	1,623.3	0.4	0.5	1	1	0
10/19/2020 10:00	0.5	14.0	1,615.3	0.5	0.5	1	1	0
10/19/2020 11:00	0.5	14.0	1,580.4	0.5	0.5	1	1	0
10/19/2020 12:00	0.5	14.0	1,447.0	0.5	0.4	1	1	0
10/19/2020 13:00	0.5	14.0	1,423.2	0.5	0.4	1	1	0
10/19/2020 14:00	0.2	13.7	1,636.8	0.4	0.5	1	1	1
10/19/2020 15:00	0.1	12.4	2,010.8	0.2	0.6	1	1	1
10/19/2020 16:00	0.2	12.0	2,094.6	0.4	0.6	1	1	1
10/19/2020 17:00	0.2	11.9	2,125.5	0.4	0.6	1	1	1
10/19/2020 18:00	0.2	12.1	2,073.5	0.4	0.6	1	1	1
10/19/2020 19:00	0.2	12.0	2,115.6	0.4	0.6	1	1	1
10/19/2020 20:00	0.2	13.1	1,758.0	0.4	0.5	1	1	1
10/19/2020 21:00	0.2	13.3	1,790.8	0.4	0.5	1	1	1
10/19/2020 22:00	0.1	12.4	2,039.5	0.2	0.6	1	1	1
10/19/2020 23:00	0.1	12.9	1,927.1	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.2	1,797.3	0.4	0.5	24 #	24 #	14 #
Minimum:	0.1	11.9	1,423.2	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,125.5	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2020 00:00	0.4	13.9	1,523.8	0.4	0.5	1	1	0
10/20/2020 01:00	0.5	14.0	1,294.6	0.5	0.4	1	1	0
10/20/2020 02:00	0.5	14.0	1,380.4	0.5	0.4	1	1	0
10/20/2020 03:00	0.1	13.4	1,788.3	0.2	0.5	1	1	1
10/20/2020 04:00	-0.1	12.5	2,030.2	0.1	0.6	1	1	1
10/20/2020 05:00	0.1	12.5	2,055.4	0.2	0.6	1	1	1
10/20/2020 06:00	0.1	12.5	2,013.7	0.2	0.6	1	1	1
10/20/2020 07:00	0.4	13.8	1,651.6	0.4	0.5	1	1	0
10/20/2020 08:00	0.5	14.0	1,324.7	0.5	0.4	1	1	0
10/20/2020 09:00	0.5	14.0	1,451.2	0.5	0.4	1	1	0
10/20/2020 10:00	0.4	14.0	1,626.8	0.4	0.5	1	1	0
10/20/2020 11:00	0.2	13.6	1,699.7	0.4	0.5	1	1	1
10/20/2020 12:00	0.1	12.3	2,032.9	0.2	0.6	1	1	1
10/20/2020 13:00	0.1	12.2	2,029.9	0.2	0.6	1	1	1
10/20/2020 14:00	0.4	13.8	1,685.2	0.4	0.5	1	1	0
10/20/2020 15:00	0.2	13.0	1,812.9	0.4	0.5	1	1	1
10/20/2020 16:00	0.2	11.9	2,116.0	0.4	0.6	1	1	1
10/20/2020 17:00	0.2	12.0	2,087.3	0.4	0.6	1	1	1
10/20/2020 18:00	0.2	12.2	2,044.2	0.4	0.6	1	1	1
10/20/2020 19:00	0.1	12.5	1,989.8	0.2	0.6	1	1	1
10/20/2020 20:00	0.2	12.7	1,890.3	0.4	0.6	1	1	1
10/20/2020 21:00	0.4	13.5	1,722.0	0.4	0.5	1	1	1
10/20/2020 22:00	0.1	12.4	2,030.2	0.2	0.6	1	1	1
10/20/2020 23:00	0.2	12.1	2,092.8	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.0	1,807.2	0.3	0.5	24 #	24 #	16 #
Minimum:	-0.1	11.9	1,294.6	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,116.0	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2020 00:00	0.2	12.3	2,038.9	0.4	0.6	1	1	1
10/21/2020 01:00	0.5	13.8	1,682.8	0.5	0.5	1	1	0
10/21/2020 02:00	0.4	13.3	1,737.4	0.4	0.5	1	1	1
10/21/2020 03:00	0.2	12.1	2,083.5	0.4	0.6	1	1	1
10/21/2020 04:00	0.2	12.3	2,052.9	0.4	0.6	1	1	1
10/21/2020 05:00	0.1	12.5	2,021.8	0.2	0.6	1	1	1
10/21/2020 06:00	0.1	12.2	2,090.9	0.2	0.6	1	1	1
10/21/2020 07:00	0.4	13.8	1,542.0	0.4	0.5	1	1	1
10/21/2020 08:00	0.4	13.9	1,520.2	0.4	0.5	1	1	0
10/21/2020 09:00	0.5	14.0	1,352.9	0.5	0.4	1	1	0
10/21/2020 10:00	0.5	14.0	1,566.2	0.5	0.5	1	1	0
10/21/2020 11:00	0.5	14.0	1,517.4	0.5	0.5	1	1	0
10/21/2020 12:00	0.5	14.0	1,592.8	0.5	0.5	1	1	0
10/21/2020 13:00	0.2	13.6	1,665.5	0.4	0.5	1	1	1
10/21/2020 14:00	0.1	12.1	2,071.4	0.2	0.6	1	1	1
10/21/2020 15:00	0.1	12.3	2,024.0	0.2	0.6	1	1	1
10/21/2020 16:00	0.2	12.0	2,088.4	0.4	0.6	1	1	1
10/21/2020 17:00	0.2	11.9	2,112.4	0.4	0.6	1	1	1
10/21/2020 18:00	0.2	11.9	2,111.3	0.4	0.6	1	1	1
10/21/2020 19:00	0.2	12.1	2,065.4	0.4	0.6	1	1	1
10/21/2020 20:00	0.2	12.1	2,095.6	0.4	0.6	1	1	1
10/21/2020 21:00	0.2	12.2	2,074.2	0.4	0.6	1	1	1
10/21/2020 22:00	0.2	12.2	2,059.2	0.4	0.6	1	1	1
10/21/2020 23:00	0.4	12.5	1,960.9	0.5	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,880.3	0.4	0.6	24 #	24 #	18 #
Minimum:	0.1	11.9	1,352.9	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,112.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	0.5	13.9	1,678.3	0.5	0.5	1	1	0
10/22/2020 01:00	0.2	13.3	1,800.3	0.4	0.5	1	1	1
10/22/2020 02:00	0.1	12.5	2,019.5	0.2	0.6	1	1	1
10/22/2020 03:00	0.1	12.6	1,998.4	0.2	0.6	1	1	1
10/22/2020 04:00	0.4	13.8	1,666.8	0.4	0.5	1	1	0
10/22/2020 05:00	0.2	13.6	1,742.4	0.4	0.5	1	1	1
10/22/2020 06:00	0.1	12.1	2,131.3	0.2	0.6	1	1	1
10/22/2020 07:00	0.1	12.3	2,062.2	0.2	0.6	1	1	1
10/22/2020 08:00	0.5	13.9	1,475.7	0.5	0.4	1	1	0
10/22/2020 09:00	0.5	14.0	1,574.9	0.5	0.5	1	1	0
10/22/2020 10:00	0.4	14.0	1,604.9	0.4	0.5	1	1	0
10/22/2020 11:00	0.1	13.4	1,793.6	0.2	0.5	1	1	1
10/22/2020 12:00	-0.1	12.3	2,091.0	0.2	0.6	1	1	1
10/22/2020 13:00	-0.1	12.7	1,960.2	0.1	0.6	1	1	1
10/22/2020 14:00	0.4	13.9	1,574.3	0.4	0.5	1	1	0
10/22/2020 15:00	0.2	13.7	1,669.7	0.4	0.5	1	1	1
10/22/2020 16:00	-0.1	12.3	2,105.5	0.2	0.6	1	1	1
10/22/2020 17:00	0.1	12.2	2,122.1	0.2	0.6	1	1	1
10/22/2020 18:00	-0.1	12.7	2,001.5	0.1	0.6	1	1	1
10/22/2020 19:00	-0.1	12.5	2,066.1	0.1	0.6	1	1	1
10/22/2020 20:00	-0.1	12.6	2,038.0	0.1	0.6	1	1	1
10/22/2020 21:00	-0.1	12.6	2,037.7	0.1	0.6	1	1	1
10/22/2020 22:00	0.1	12.7	1,994.8	0.2	0.6	1	1	1
10/22/2020 23:00	0.2	12.8	1,943.8	0.4	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,881.4	0.3	0.6	24 #	24 #	18 #
Minimum:	-0.1	12.1	1,475.7	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,131.3	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2020 00:00	0.5	14.0	1,624.7	0.5	0.5	1	1	0
10/23/2020 01:00	0.2	13.4	1,797.4	0.4	0.5	1	1	1
10/23/2020 02:00	0.1	12.4	2,077.8	0.2	0.6	1	1	1
10/23/2020 03:00	-0.1	12.8	1,985.3	0.1	0.6	1	1	1
10/23/2020 04:00	0.4	13.9	1,678.3	0.4	0.5	1	1	0
10/23/2020 05:00	0.2	13.6	1,810.3	0.4	0.5	1	1	1
10/23/2020 06:00	-0.1	12.2	2,138.1	0.2	0.6	1	1	1
10/23/2020 07:00	-0.1	12.4	2,097.4	0.2	0.6	1	1	1
10/23/2020 08:00	-0.1	12.9	1,986.3	0.1	0.6	1	1	1
10/23/2020 09:00	0.4	13.7	1,706.5	0.4	0.5	1	1	1
10/23/2020 10:00	0.4	13.9	1,677.0	0.4	0.5	1	1	0
10/23/2020 11:00	0.4	13.8	1,724.7	0.4	0.5	1	1	1
10/23/2020 12:00	-0.1	12.5	2,053.7	0.1	0.6	1	1	1
10/23/2020 13:00	-0.1	12.9	1,946.0	0.1	0.6	1	1	1
10/23/2020 14:00	0.4	13.9	1,595.6	0.4	0.5	1	1	0
10/23/2020 15:00	0.2	13.7	1,733.3	0.4	0.5	1	1	1
10/23/2020 16:00	-0.1	12.6	2,035.0	0.1	0.6	1	1	1
10/23/2020 17:00	0.1	12.3	2,089.8	0.2	0.6	1	1	1
10/23/2020 18:00	0.1	13.0	1,914.2	0.2	0.6	1	1	1
10/23/2020 19:00	0.4	13.8	1,687.1	0.4	0.5	1	1	0
10/23/2020 20:00	0.1	13.3	1,824.8	0.2	0.5	1	1	1
10/23/2020 21:00	-0.1	12.6	2,047.0	0.1	0.6	1	1	1
10/23/2020 22:00	-0.1	12.7	2,011.5	0.1	0.6	1	1	1
10/23/2020 23:00	0.1	12.4	2,110.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,889.7	0.3	0.6	24 #	24 #	19 #
Minimum:	-0.1	12.2	1,595.6	0.1	0.5	1	1	0
Maximum:	0.5	14.0	2,138.1	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	0.4	13.6	1,710.2	0.4	0.5	1	1	1
10/24/2020 01:00	0.4	13.9	1,685.2	0.4	0.5	1	1	0
10/24/2020 02:00	0.1	13.4	1,815.9	0.2	0.5	1	1	1
10/24/2020 03:00	0.1	12.4	2,084.9	0.2	0.6	1	1	1
10/24/2020 04:00	0.1	12.9	1,943.6	0.2	0.6	1	1	1
10/24/2020 05:00	0.4	13.8	1,670.4	0.4	0.5	1	1	0
10/24/2020 06:00	0.4	13.8	1,665.7	0.4	0.5	1	1	0
10/24/2020 07:00	0.4	13.8	1,620.3	0.4	0.5	1	1	0
10/24/2020 08:00	0.4	13.9	1,565.9	0.4	0.5	1	1	0
10/24/2020 09:00	0.4	13.9	1,611.1	0.4	0.5	1	1	0
10/24/2020 10:00	0.4	13.9	1,669.5	0.4	0.5	1	1	0
10/24/2020 11:00	0.4	13.9	1,627.8	0.4	0.5	1	1	0
10/24/2020 12:00	0.4	13.9	1,425.2	0.4	0.4	1	1	0
10/24/2020 13:00	0.4	13.9	1,420.6	0.4	0.4	1	1	0
10/24/2020 14:00	0.4	13.9	1,620.5	0.4	0.5	1	1	0
10/24/2020 15:00	0.4	13.9	1,685.3	0.4	0.5	1	1	0
10/24/2020 16:00	-0.1	13.3	1,794.7	0.1	0.5	1	1	1
10/24/2020 17:00	-0.1	12.1	2,114.9	0.2	0.6	1	1	1
10/24/2020 18:00	-0.1	12.9	1,929.2	0.1	0.6	1	1	1
10/24/2020 19:00	0.4	13.8	1,685.4	0.4	0.5	1	1	0
10/24/2020 20:00	0.4	13.8	1,677.3	0.4	0.5	1	1	0
10/24/2020 21:00	-0.1	13.3	1,805.0	0.1	0.5	1	1	1
10/24/2020 22:00	-0.2	12.7	1,999.8	0.1	0.6	1	1	1
10/24/2020 23:00	-0.1	12.7	1,962.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,741.3	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	12.1	1,420.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,114.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2020 00:00	0.4	13.8	1,672.5	0.4	0.5	1	1	0
10/25/2020 01:00	0.4	13.8	1,663.7	0.4	0.5	1	1	0
10/25/2020 02:00	0.4	13.8	1,648.1	0.4	0.5	1	1	0
10/25/2020 03:00	0.4	13.8	1,646.2	0.4	0.5	1	1	0
10/25/2020 04:00	0.4	13.8	1,641.5	0.4	0.5	1	1	0
10/25/2020 05:00	0.4	13.8	1,616.9	0.4	0.5	1	1	0
10/25/2020 06:00	0.4	13.8	1,583.6	0.4	0.5	1	1	0
10/25/2020 07:00	0.4	13.8	1,607.5	0.4	0.5	1	1	0
10/25/2020 08:00	0.4	13.9	1,608.1	0.4	0.5	1	1	0
10/25/2020 09:00	0.4	13.9	1,557.1	0.4	0.5	1	1	0
10/25/2020 10:00	0.4	14.0	1,413.8	0.4	0.4	1	1	0
10/25/2020 11:00	0.4	14.0	1,343.0	0.4	0.4	1	1	0
10/25/2020 12:00	0.4	14.0	1,543.4	0.4	0.5	1	1	0
10/25/2020 13:00	0.4	14.0	1,591.8	0.4	0.5	1	1	0
10/25/2020 14:00	0.4	14.0	1,650.7	0.4	0.5	1	1	0
10/25/2020 15:00	0.4	14.0	1,602.2	0.4	0.5	1	1	0
10/25/2020 16:00	-0.1	13.5	1,826.6	0.1	0.5	1	1	1
10/25/2020 17:00	-0.2	12.7	2,055.4	0.1	0.6	1	1	1
10/25/2020 18:00	-0.2	12.7	2,013.8	0.1	0.6	1	1	1
10/25/2020 19:00	0.4	13.8	1,658.3	0.4	0.5	1	1	0
10/25/2020 20:00	0.1	13.3	1,821.1	0.2	0.5	1	1	1
10/25/2020 21:00	0.1	12.3	2,128.5	0.2	0.6	1	1	1
10/25/2020 22:00	0.2	12.2	2,142.1	0.4	0.6	1	1	1
10/25/2020 23:00	0.2	12.1	2,172.4	0.4	0.7	1	1	1
Average/Sum#:	0.3	13.5	1,717.0	0.3	0.5	24 #	24 #	7 #
Minimum:	-0.2	12.1	1,343.0	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,172.4	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2020 00:00	0.2	12.7	2,037.0	0.4	0.6	1	1	1
10/26/2020 01:00	0.1	13.0	1,982.5	0.2	0.6	1	1	1
10/26/2020 02:00	0.1	12.7	2,032.7	0.2	0.6	1	1	1
10/26/2020 03:00	0.4	13.8	1,674.1	0.4	0.5	1	1	1
10/26/2020 04:00	0.2	13.4	1,856.6	0.4	0.6	1	1	1
10/26/2020 05:00	0.1	12.4	2,131.3	0.2	0.6	1	1	1
10/26/2020 06:00	0.2	12.4	2,092.6	0.4	0.6	1	1	1
10/26/2020 07:00	0.4	13.8	1,783.5	0.4	0.5	1	1	0
10/26/2020 08:00	0.4	13.9	1,744.2	0.4	0.5	1	1	0
10/26/2020 09:00	0.4	13.9	1,734.3	0.4	0.5	1	1	0
10/26/2020 10:00	0.4	14.0	1,679.3	0.4	0.5	1	1	0
10/26/2020 11:00	0.5	14.0	1,378.8	0.5	0.4	1	1	0
10/26/2020 12:00	0.4	14.0	1,524.0	0.4	0.5	1	1	0
10/26/2020 13:00	0.4	14.0	1,503.0	0.4	0.5	1	1	0
10/26/2020 14:00	0.4	14.0	1,692.4	0.4	0.5	1	1	0
10/26/2020 15:00	0.4	14.0	1,640.3	0.4	0.5	1	1	0
10/26/2020 16:00	-0.1	13.4	1,844.9	0.1	0.6	1	1	1
10/26/2020 17:00	-0.1	12.3	2,141.4	0.2	0.6	1	1	1
10/26/2020 18:00	-0.1	12.1	2,179.9	0.2	0.7	1	1	1
10/26/2020 19:00	-0.1	12.5	2,078.5	0.1	0.6	1	1	1
10/26/2020 20:00	-0.1	12.4	2,117.6	0.2	0.6	1	1	1
10/26/2020 21:00	-0.1	12.5	2,088.1	0.1	0.6	1	1	1
10/26/2020 22:00	-0.2	12.6	2,075.4	0.1	0.6	1	1	1
10/26/2020 23:00	-0.1	12.6	2,058.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,877.9	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.2	12.1	1,378.8	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,179.9	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2020 00:00	0.4	13.9	1,687.6	0.4	0.5	1	1	1
10/27/2020 01:00	0.2	13.5	1,783.3	0.4	0.5	1	1	1
10/27/2020 02:00	0.1	12.5	2,051.2	0.2	0.6	1	1	1
10/27/2020 03:00	0.2	12.7	1,991.3	0.4	0.6	1	1	1
10/27/2020 04:00	0.4	14.0	1,645.6	0.4	0.5	1	1	0
10/27/2020 05:00	0.2	13.6	1,729.5	0.4	0.5	1	1	1
10/27/2020 06:00	0.2	12.1	2,142.6	0.4	0.6	1	1	1
10/27/2020 07:00	0.1	12.2	2,157.2	0.2	0.6	1	1	1
10/27/2020 08:00	-0.1	12.4	2,106.7	0.2	0.6	1	1	1
10/27/2020 09:00	0.1	12.3	2,114.6	0.2	0.6	1	1	1
10/27/2020 10:00	0.1	12.2	2,115.2	0.2	0.6	1	1	1
10/27/2020 11:00	0.1	12.1	2,141.2	0.2	0.6	1	1	1
10/27/2020 12:00	0.1	12.0	2,148.5	0.2	0.6	1	1	1
10/27/2020 13:00	0.1	12.0	2,145.5	0.2	0.6	1	1	1
10/27/2020 14:00	0.1	12.0	2,130.9	0.2	0.6	1	1	1
10/27/2020 15:00	-0.1	12.7	1,980.7	0.1	0.6	1	1	1
10/27/2020 16:00	0.1	12.2	2,116.3	0.2	0.6	1	1	1
10/27/2020 17:00	0.1	12.0	2,149.3	0.2	0.6	1	1	1
10/27/2020 18:00	0.1	12.0	2,149.9	0.2	0.6	1	1	1
10/27/2020 19:00	0.1	12.0	2,147.3	0.2	0.6	1	1	1
10/27/2020 20:00	0.1	12.1	2,133.3	0.2	0.6	1	1	1
10/27/2020 21:00	-0.1	12.5	2,045.5	0.1	0.6	1	1	1
10/27/2020 22:00	-0.1	12.6	2,044.8	0.1	0.6	1	1	1
10/27/2020 23:00	-0.1	12.5	2,053.8	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.5	2,038.0	0.2	0.6	24 #	24 #	23 #
Minimum:	-0.1	12.0	1,645.6	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,157.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2020 00:00	0.4	13.8	1,674.9	0.4	0.5	1	1	0
10/28/2020 01:00	0.4	13.8	1,660.6	0.4	0.5	1	1	0
10/28/2020 02:00	0.4	13.8	1,645.3	0.4	0.5	1	1	0
10/28/2020 03:00	0.4	13.9	1,640.5	0.4	0.5	1	1	0
10/28/2020 04:00	0.1	13.5	1,818.3	0.2	0.5	1	1	1
10/28/2020 05:00	0.1	12.4	2,111.2	0.2	0.6	1	1	1
10/28/2020 06:00	0.2	12.1	2,135.4	0.4	0.6	1	1	1
10/28/2020 07:00	0.5	13.9	1,275.4	0.5	0.4	1	1	0
10/28/2020 08:00	0.5	13.9	1,280.4	0.5	0.4	1	1	0
10/28/2020 09:00	0.4	13.9	1,482.6	0.4	0.4	1	1	0
10/28/2020 10:00	0.4	13.9	1,525.4	0.4	0.5	1	1	0
10/28/2020 11:00	0.4	13.7	1,799.3	0.4	0.5	1	1	0
10/28/2020 12:00	0.4	13.7	1,786.0	0.4	0.5	1	1	0
10/28/2020 13:00	0.4	13.7	1,782.2	0.4	0.5	1	1	0
10/28/2020 14:00	0.4	13.7	1,776.7	0.4	0.5	1	1	0
10/28/2020 15:00	0.4	13.7	1,773.9	0.4	0.5	1	1	0
10/28/2020 16:00	0.4	13.8	1,649.9	0.4	0.5	1	1	0
10/28/2020 17:00	0.2	13.8	1,697.8	0.4	0.5	1	1	1
10/28/2020 18:00	-0.2	12.8	1,990.9	0.1	0.6	1	1	1
10/28/2020 19:00	-0.1	12.6	2,043.2	0.1	0.6	1	1	1
10/28/2020 20:00	-0.1	12.5	2,062.9	0.1	0.6	1	1	1
10/28/2020 21:00	-0.1	12.5	2,062.0	0.1	0.6	1	1	1
10/28/2020 22:00	-0.1	12.7	2,033.3	0.1	0.6	1	1	1
10/28/2020 23:00	0.1	13.1	1,902.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,775.4	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	12.1	1,275.4	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,135.4	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2020 00:00	0.4	13.9	1,682.1	0.4	0.5	1	1	0
10/29/2020 01:00	0.4	13.9	1,673.3	0.4	0.5	1	1	0
10/29/2020 02:00	0.4	13.9	1,531.6	0.4	0.5	1	1	0
10/29/2020 03:00	0.4	13.9	1,680.0	0.4	0.5	1	1	0
10/29/2020 04:00	0.1	13.5	1,783.7	0.2	0.5	1	1	1
10/29/2020 05:00	-0.1	12.7	2,042.9	0.1	0.6	1	1	1
10/29/2020 06:00	0.1	12.6	2,055.2	0.2	0.6	1	1	1
10/29/2020 07:00	0.4	13.8	1,783.4	0.4	0.5	1	1	0
10/29/2020 08:00	0.4	13.9	1,311.0	0.4	0.4	1	1	0
10/29/2020 09:00	0.5	14.0	1,264.1	0.5	0.4	1	1	0
10/29/2020 10:00	0.4	14.0	1,277.7	0.4	0.4	1	1	0
10/29/2020 11:00	0.5	14.0	1,262.8	0.5	0.4	1	1	0
10/29/2020 12:00	0.5	14.0	1,262.5	0.5	0.4	1	1	0
10/29/2020 13:00	0.5	14.0	1,263.0	0.5	0.4	1	1	0
10/29/2020 14:00	0.5	14.0	1,263.0	0.5	0.4	1	1	0
10/29/2020 15:00	0.5	14.0	1,359.5	0.5	0.4	1	1	0
10/29/2020 16:00	0.4	13.9	1,535.9	0.4	0.5	1	1	0
10/29/2020 17:00	0.2	13.8	1,745.1	0.4	0.5	1	1	1
10/29/2020 18:00	-0.2	12.8	2,007.3	0.1	0.6	1	1	1
10/29/2020 19:00	-0.2	12.5	2,051.0	0.1	0.6	1	1	1
10/29/2020 20:00	-0.2	12.5	2,072.3	0.1	0.6	1	1	1
10/29/2020 21:00	-0.1	12.5	2,064.0	0.1	0.6	1	1	1
10/29/2020 22:00	-0.1	12.5	2,059.1	0.1	0.6	1	1	1
10/29/2020 23:00	-0.4	13.1	1,920.3	-0.1	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,664.6	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.4	12.5	1,262.5	-0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,072.3	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2020 00:00	0.4	13.9	1,604.9	0.4	0.5	1	1	0
10/30/2020 01:00	0.2	13.7	1,678.5	0.4	0.5	1	1	1
10/30/2020 02:00	0.1	13.0	1,928.0	0.2	0.6	1	1	1
10/30/2020 03:00	0.1	13.0	1,923.5	0.2	0.6	1	1	1
10/30/2020 04:00	0.4	13.9	1,687.9	0.4	0.5	1	1	0
10/30/2020 05:00	0.2	13.6	1,799.8	0.4	0.5	1	1	1
10/30/2020 06:00	0.1	12.5	2,061.7	0.2	0.6	1	1	1
10/30/2020 07:00	0.1	12.8	2,012.0	0.2	0.6	1	1	1
10/30/2020 08:00	0.1	12.8	2,003.0	0.2	0.6	1	1	1
10/30/2020 09:00	0.1	12.8	1,967.1	0.2	0.6	1	1	1
10/30/2020 10:00	0.2	12.7	2,000.2	0.4	0.6	1	1	1
10/30/2020 11:00	0.2	12.7	1,944.2	0.4	0.6	1	1	1
10/30/2020 12:00	0.5	14.0	1,642.2	0.5	0.5	1	1	0
10/30/2020 13:00	0.1	13.4	1,784.4	0.2	0.5	1	1	1
10/30/2020 14:00	-0.1	12.6	2,013.1	0.1	0.6	1	1	1
10/30/2020 15:00	-0.1	12.3	2,065.6	0.2	0.6	1	1	1
10/30/2020 16:00	-0.1	12.5	2,037.7	0.1	0.6	1	1	1
10/30/2020 17:00	0.1	12.2	2,105.4	0.2	0.6	1	1	1
10/30/2020 18:00	0.1	12.2	2,106.9	0.2	0.6	1	1	1
10/30/2020 19:00	0.1	12.1	2,134.3	0.2	0.6	1	1	1
10/30/2020 20:00	0.2	13.2	1,798.7	0.4	0.5	1	1	1
10/30/2020 21:00	0.1	13.4	1,821.4	0.2	0.5	1	1	1
10/30/2020 22:00	-0.1	12.4	2,080.7	0.2	0.6	1	1	1
10/30/2020 23:00	-0.1	13.0	1,929.7	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.9	1,922.1	0.3	0.6	24 #	24 #	21 #
Minimum:	-0.1	12.1	1,604.9	0.1	0.5	1	1	0
Maximum:	0.5	14.0	2,134.3	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2020 00:00	0.4	13.9	1,556.8	0.4	0.5	1	1	0
10/31/2020 01:00	0.4	13.9	1,655.0	0.4	0.5	1	1	0
10/31/2020 02:00	0.2	13.7	1,646.8	0.4	0.5	1	1	1
10/31/2020 03:00	0.1	12.6	2,025.8	0.2	0.6	1	1	1
10/31/2020 04:00	0.1	13.0	1,908.0	0.2	0.6	1	1	1
10/31/2020 05:00	0.4	13.9	1,688.3	0.4	0.5	1	1	0
10/31/2020 06:00	0.4	13.9	1,686.5	0.4	0.5	1	1	0
10/31/2020 07:00	0.4	13.9	1,641.9	0.4	0.5	1	1	0
10/31/2020 08:00	0.4	13.9	1,519.8	0.4	0.5	1	1	0
10/31/2020 09:00	0.4	13.9	1,494.6	0.4	0.4	1	1	0
10/31/2020 10:00	0.4	13.9	1,630.8	0.4	0.5	1	1	0
10/31/2020 11:00	0.4	14.0	1,545.5	0.4	0.5	1	1	0
10/31/2020 12:00	0.4	14.0	1,544.3	0.4	0.5	1	1	0
10/31/2020 13:00	0.4	14.0	1,555.3	0.4	0.5	1	1	0
10/31/2020 14:00	0.4	13.9	1,588.7	0.4	0.5	1	1	0
10/31/2020 15:00	0.4	13.9	1,667.8	0.4	0.5	1	1	0
10/31/2020 16:00	0.1	13.4	1,784.8	0.2	0.5	1	1	1
10/31/2020 17:00	-0.1	12.8	1,979.8	0.1	0.6	1	1	1
10/31/2020 18:00	-0.1	12.7	2,004.7	0.1	0.6	1	1	1
10/31/2020 19:00	0.4	13.8	1,684.5	0.4	0.5	1	1	0
10/31/2020 20:00	0.1	13.4	1,810.6	0.2	0.5	1	1	1
10/31/2020 21:00	-0.1	12.6	2,037.6	0.1	0.6	1	1	1
10/31/2020 22:00	-0.1	12.7	2,037.5	0.1	0.6	1	1	1
10/31/2020 23:00	-0.1	12.6	2,045.7	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,739.2	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.1	12.6	1,494.6	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,045.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2020 00:00	0.1	12.8	2,015.2	0.2	0.6	1	1	1
11/01/2020 01:00	0.1	12.8	1,982.7	0.2	0.6	1	1	1
11/01/2020 02:00	0.4	13.8	1,668.6	0.4	0.5	1	1	1
11/01/2020 03:00	0.4	13.9	1,679.1	0.4	0.5	1	1	0
11/01/2020 04:00	0.2	13.4	1,812.7	0.4	0.5	1	1	1
11/01/2020 05:00	0.1	12.7	2,032.9	0.2	0.6	1	1	1
11/01/2020 06:00	0.1	12.7	2,001.6	0.2	0.6	1	1	1
11/01/2020 07:00	0.5	13.9	1,536.2	0.5	0.5	1	1	0
11/01/2020 08:00	0.4	13.9	1,682.4	0.4	0.5	1	1	0
11/01/2020 09:00	0.4	13.9	1,491.5	0.4	0.4	1	1	0
11/01/2020 10:00	0.4	13.9	1,564.2	0.4	0.5	1	1	0
11/01/2020 11:00	0.4	14.0	1,482.3	0.4	0.4	1	1	0
11/01/2020 12:00	0.4	14.0	1,567.9	0.4	0.5	1	1	0
11/01/2020 13:00	0.4	13.9	1,656.6	0.4	0.5	1	1	0
11/01/2020 14:00	0.4	13.9	1,663.1	0.4	0.5	1	1	0
11/01/2020 15:00	0.2	13.7	1,647.6	0.4	0.5	1	1	1
11/01/2020 16:00	-0.1	12.6	2,012.8	0.1	0.6	1	1	1
11/01/2020 17:00	0.1	12.3	2,100.1	0.2	0.6	1	1	1
11/01/2020 18:00	0.1	12.1	2,131.1	0.2	0.6	1	1	1
11/01/2020 19:00	0.1	12.3	2,105.1	0.2	0.6	1	1	1
11/01/2020 20:00	0.1	12.3	2,094.8	0.2	0.6	1	1	1
11/01/2020 21:00	0.1	12.1	2,142.5	0.2	0.6	1	1	1
11/01/2020 22:00	0.1	12.5	2,064.2	0.2	0.6	1	1	1
11/01/2020 23:00	-0.1	12.5	2,077.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,842.2	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	12.1	1,482.3	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,142.5	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	0.1	12.4	2,089.6	0.2	0.6	1	1	1
11/02/2020 01:00	0.2	12.6	2,002.9	0.4	0.6	1	1	1
11/02/2020 02:00	0.4	13.9	1,640.6	0.4	0.5	1	1	0
11/02/2020 03:00	0.2	13.4	1,793.3	0.4	0.5	1	1	1
11/02/2020 04:00	0.1	12.4	2,080.6	0.2	0.6	1	1	1
11/02/2020 05:00	0.2	12.3	2,102.4	0.4	0.6	1	1	1
11/02/2020 06:00	0.1	12.5	2,050.3	0.2	0.6	1	1	1
11/02/2020 07:00	0.4	13.9	1,621.3	0.4	0.5	1	1	0
11/02/2020 08:00	0.4	13.9	1,656.5	0.4	0.5	1	1	0
11/02/2020 09:00	0.4	13.9	1,676.9	0.4	0.5	1	1	0
11/02/2020 10:00	0.4	14.0	1,643.3	0.4	0.5	1	1	0
11/02/2020 11:00	0.4	14.0	1,652.0	0.4	0.5	1	1	0
11/02/2020 12:00	0.4	13.8	1,676.1	0.4	0.5	1	1	0
11/02/2020 13:00	0.4	13.9	1,668.5	0.4	0.5	1	1	0
11/02/2020 14:00	0.2	13.7	1,696.9	0.4	0.5	1	1	1
11/02/2020 15:00	-0.1	12.5	2,019.1	0.1	0.6	1	1	1
11/02/2020 16:00	0.2	12.0	2,133.1	0.4	0.6	1	1	1
11/02/2020 17:00	0.1	12.1	2,113.6	0.2	0.6	1	1	1
11/02/2020 18:00	0.1	12.0	2,128.6	0.2	0.6	1	1	1
11/02/2020 19:00	0.2	12.0	2,139.0	0.4	0.6	1	1	1
11/02/2020 20:00	0.1	12.1	2,134.9	0.2	0.6	1	1	1
11/02/2020 21:00	0.1	12.3	2,094.7	0.2	0.6	1	1	1
11/02/2020 22:00	0.1	12.3	2,084.1	0.2	0.6	1	1	1
11/02/2020 23:00	0.1	12.6	2,035.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,913.9	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.0	1,621.3	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,139.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2020 00:00	0.1	12.4	2,054.7	0.2	0.6	1	1	1
11/03/2020 01:00	0.1	12.8	1,945.1	0.2	0.6	1	1	1
11/03/2020 02:00	0.4	13.9	1,677.9	0.4	0.5	1	1	0
11/03/2020 03:00	0.1	13.4	1,817.0	0.2	0.5	1	1	1
11/03/2020 04:00	0.1	12.3	2,088.1	0.2	0.6	1	1	1
11/03/2020 05:00	0.2	12.2	2,098.9	0.4	0.6	1	1	1
11/03/2020 06:00	0.2	12.2	2,114.3	0.4	0.6	1	1	1
11/03/2020 07:00	0.2	12.6	2,008.8	0.4	0.6	1	1	1
11/03/2020 08:00	0.4	13.9	1,651.3	0.4	0.5	1	1	0
11/03/2020 09:00	0.4	13.9	1,665.8	0.4	0.5	1	1	0
11/03/2020 10:00	0.4	13.9	1,671.5	0.4	0.5	1	1	0
11/03/2020 11:00	0.4	14.0	1,522.5	0.4	0.5	1	1	0
11/03/2020 12:00	0.4	14.0	1,522.1	0.4	0.5	1	1	0
11/03/2020 13:00	0.4	13.9	1,591.7	0.4	0.5	1	1	0
11/03/2020 14:00	0.4	13.9	1,660.3	0.4	0.5	1	1	0
11/03/2020 15:00	0.2	13.4	1,785.8	0.4	0.5	1	1	1
11/03/2020 16:00	0.1	12.2	2,103.2	0.2	0.6	1	1	1
11/03/2020 17:00	0.1	12.1	2,129.4	0.2	0.6	1	1	1
11/03/2020 18:00	0.1	12.1	2,138.7	0.2	0.6	1	1	1
11/03/2020 19:00	0.1	12.1	2,142.9	0.2	0.6	1	1	1
11/03/2020 20:00	0.1	12.2	2,117.8	0.2	0.6	1	1	1
11/03/2020 21:00	0.1	12.2	2,107.4	0.2	0.6	1	1	1
11/03/2020 22:00	0.1	12.4	2,081.9	0.2	0.6	1	1	1
11/03/2020 23:00	-0.1	12.7	2,038.5	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,905.7	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.1	1,522.1	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,142.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2020 00:00	0.1	12.6	2,048.8	0.2	0.6	1	1	1
11/04/2020 01:00	0.1	13.0	1,921.7	0.2	0.6	1	1	1
11/04/2020 02:00	0.4	13.9	1,688.1	0.4	0.5	1	1	0
11/04/2020 03:00	0.1	13.4	1,807.4	0.2	0.5	1	1	1
11/04/2020 04:00	0.1	12.4	2,061.2	0.2	0.6	1	1	1
11/04/2020 05:00	0.1	12.3	2,101.7	0.2	0.6	1	1	1
11/04/2020 06:00	0.1	12.3	2,121.7	0.2	0.6	1	1	1
11/04/2020 07:00	0.1	12.7	2,006.0	0.2	0.6	1	1	1
11/04/2020 08:00	0.4	13.9	1,684.5	0.4	0.5	1	1	0
11/04/2020 09:00	0.4	13.9	1,630.7	0.4	0.5	1	1	0
11/04/2020 10:00	0.4	13.9	1,532.9	0.4	0.5	1	1	0
11/04/2020 11:00	0.4	13.9	1,658.9	0.4	0.5	1	1	0
11/04/2020 12:00	0.4	14.0	1,679.9	0.4	0.5	1	1	0
11/04/2020 13:00	0.4	13.9	1,683.8	0.4	0.5	1	1	0
11/04/2020 14:00	0.2	13.8	1,715.7	0.4	0.5	1	1	1
11/04/2020 15:00	-0.1	12.7	2,012.6	0.1	0.6	1	1	1
11/04/2020 16:00	0.1	12.2	2,099.1	0.2	0.6	1	1	1
11/04/2020 17:00	0.1	12.2	2,120.2	0.2	0.6	1	1	1
11/04/2020 18:00	0.1	12.0	2,155.9	0.2	0.6	1	1	1
11/04/2020 19:00	0.2	12.1	2,144.6	0.4	0.6	1	1	1
11/04/2020 20:00	0.1	12.2	2,122.0	0.2	0.6	1	1	1
11/04/2020 21:00	0.1	12.2	2,113.1	0.2	0.6	1	1	1
11/04/2020 22:00	0.1	12.2	2,112.8	0.2	0.6	1	1	1
11/04/2020 23:00	0.1	12.4	2,101.4	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,930.2	0.3	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.0	1,532.9	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,155.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2020 00:00	0.1	12.3	2,122.4	0.2	0.6	1	1	1
11/05/2020 01:00	0.1	12.4	2,068.5	0.2	0.6	1	1	1
11/05/2020 02:00	0.4	13.8	1,628.2	0.4	0.5	1	1	0
11/05/2020 03:00	0.2	13.3	1,806.8	0.4	0.5	1	1	1
11/05/2020 04:00	0.1	12.4	2,067.5	0.2	0.6	1	1	1
11/05/2020 05:00	0.1	12.3	2,092.5	0.2	0.6	1	1	1
11/05/2020 06:00	0.1	12.4	2,075.9	0.2	0.6	1	1	1
11/05/2020 07:00	0.1	12.8	1,975.2	0.2	0.6	1	1	1
11/05/2020 08:00	0.4	13.9	1,586.0	0.4	0.5	1	1	0
11/05/2020 09:00	0.4	13.9	1,668.6	0.4	0.5	1	1	0
11/05/2020 10:00	0.4	13.9	1,581.1	0.4	0.5	1	1	0
11/05/2020 11:00	0.4	13.9	1,576.7	0.4	0.5	1	1	0
11/05/2020 12:00	0.4	13.9	1,670.6	0.4	0.5	1	1	0
11/05/2020 13:00	0.4	13.9	1,561.0	0.4	0.5	1	1	0
11/05/2020 14:00	0.2	13.5	1,724.1	0.4	0.5	1	1	1
11/05/2020 15:00	0.1	12.1	2,103.5	0.2	0.6	1	1	1
11/05/2020 16:00	0.1	12.4	2,030.5	0.2	0.6	1	1	1
11/05/2020 17:00	0.1	12.2	2,092.4	0.2	0.6	1	1	1
11/05/2020 18:00	0.1	12.1	2,095.7	0.2	0.6	1	1	1
11/05/2020 19:00	0.1	12.4	2,040.9	0.2	0.6	1	1	1
11/05/2020 20:00	0.1	12.1	2,119.5	0.2	0.6	1	1	1
11/05/2020 21:00	0.1	12.0	2,144.8	0.2	0.6	1	1	1
11/05/2020 22:00	0.1	12.4	2,065.0	0.2	0.6	1	1	1
11/05/2020 23:00	0.1	12.3	2,071.0	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,915.4	0.3	0.6	24 #	24 #	17 #
Minimum:	0.1	12.0	1,561.0	0.2	0.5	1	1	0
Maximum:	0.4	13.9	2,144.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2020 00:00	0.1	12.3	2,061.7	0.2	0.6	1	1	1
11/06/2020 01:00	-0.1	13.0	1,911.5	0.1	0.6	1	1	1
11/06/2020 02:00	0.4	13.8	1,636.5	0.4	0.5	1	1	0
11/06/2020 03:00	0.4	13.8	1,596.7	0.4	0.5	1	1	0
11/06/2020 04:00	0.1	13.3	1,808.1	0.2	0.5	1	1	1
11/06/2020 05:00	-0.1	12.3	2,093.5	0.2	0.6	1	1	1
11/06/2020 06:00	0.1	12.5	2,018.3	0.2	0.6	1	1	1
11/06/2020 07:00	0.1	12.4	2,057.0	0.2	0.6	1	1	1
11/06/2020 08:00	0.5	13.9	1,417.9	0.5	0.4	1	1	0
11/06/2020 09:00	0.4	14.0	1,335.8	0.4	0.4	1	1	0
11/06/2020 10:00	0.4	14.0	1,307.2	0.4	0.4	1	1	0
11/06/2020 11:00	0.5	14.0	1,287.5	0.5	0.4	1	1	0
11/06/2020 12:00	0.4	14.0	1,418.6	0.4	0.4	1	1	0
11/06/2020 13:00	0.4	14.0	1,398.7	0.4	0.4	1	1	0
11/06/2020 14:00	0.4	14.0	1,321.3	0.4	0.4	1	1	0
11/06/2020 15:00	0.1	13.3	1,808.3	0.2	0.5	1	1	1
11/06/2020 16:00	-0.1	12.3	2,095.9	0.2	0.6	1	1	1
11/06/2020 17:00	0.1	12.2	2,116.1	0.2	0.6	1	1	1
11/06/2020 18:00	0.1	12.2	2,109.7	0.2	0.6	1	1	1
11/06/2020 19:00	0.1	12.8	1,974.3	0.2	0.6	1	1	1
11/06/2020 20:00	0.1	13.0	1,912.8	0.2	0.6	1	1	1
11/06/2020 21:00	0.4	13.9	1,522.7	0.4	0.5	1	1	0
11/06/2020 22:00	0.2	13.6	1,740.0	0.4	0.5	1	1	1
11/06/2020 23:00	-0.1	12.8	1,985.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,747.3	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.2	1,287.5	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,116.1	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2020 00:00	-0.1	13.1	1,901.1	0.1	0.6	1	1	1
11/07/2020 01:00	0.4	13.9	1,681.4	0.4	0.5	1	1	0
11/07/2020 02:00	0.2	13.6	1,714.0	0.4	0.5	1	1	1
11/07/2020 03:00	-0.1	13.1	1,911.8	0.1	0.6	1	1	1
11/07/2020 04:00	-0.1	13.1	1,909.2	0.1	0.6	1	1	1
11/07/2020 05:00	0.4	13.9	1,636.6	0.4	0.5	1	1	0
11/07/2020 06:00	0.4	13.9	1,606.2	0.4	0.5	1	1	0
11/07/2020 07:00	0.4	13.9	1,586.3	0.4	0.5	1	1	0
11/07/2020 08:00	0.4	13.9	1,650.0	0.4	0.5	1	1	0
11/07/2020 09:00	0.4	13.9	1,549.3	0.4	0.5	1	1	0
11/07/2020 10:00	0.4	13.9	1,404.5	0.4	0.4	1	1	0
11/07/2020 11:00	0.4	13.9	1,389.9	0.4	0.4	1	1	0
11/07/2020 12:00	0.4	13.9	1,572.5	0.4	0.5	1	1	0
11/07/2020 13:00	0.4	13.9	1,476.7	0.4	0.4	1	1	0
11/07/2020 14:00	0.4	13.9	1,468.0	0.4	0.4	1	1	0
11/07/2020 15:00	0.4	13.9	1,544.4	0.4	0.5	1	1	1
11/07/2020 16:00	-0.2	12.6	2,031.9	0.1	0.6	1	1	1
11/07/2020 17:00	0.1	12.2	2,097.9	0.2	0.6	1	1	1
11/07/2020 18:00	0.1	12.5	2,037.4	0.2	0.6	1	1	1
11/07/2020 19:00	-0.1	12.6	2,023.6	0.1	0.6	1	1	1
11/07/2020 20:00	-0.1	12.9	1,939.2	0.1	0.6	1	1	1
11/07/2020 21:00	0.4	13.9	1,570.7	0.4	0.5	1	1	0
11/07/2020 22:00	0.1	13.4	1,804.7	0.2	0.5	1	1	1
11/07/2020 23:00	0.1	12.3	2,089.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,733.2	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	12.2	1,389.9	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,097.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	0.1	12.8	1,961.7	0.2	0.6	1	1	1
11/08/2020 01:00	0.2	13.8	1,570.0	0.4	0.5	1	1	1
11/08/2020 02:00	0.4	13.9	1,552.0	0.4	0.5	1	1	0
11/08/2020 03:00	-0.1	13.1	1,899.9	0.1	0.6	1	1	1
11/08/2020 04:00	-0.1	13.1	1,901.0	0.1	0.6	1	1	1
11/08/2020 05:00	0.4	13.9	1,689.8	0.4	0.5	1	1	0
11/08/2020 06:00	0.4	13.9	1,653.1	0.4	0.5	1	1	0
11/08/2020 07:00	0.4	13.9	1,571.5	0.4	0.5	1	1	0
11/08/2020 08:00	0.4	13.9	1,656.7	0.4	0.5	1	1	0
11/08/2020 09:00	0.4	13.9	1,646.8	0.4	0.5	1	1	0
11/08/2020 10:00	0.4	13.9	1,680.9	0.4	0.5	1	1	0
11/08/2020 11:00	0.4	13.9	1,539.8	0.4	0.5	1	1	0
11/08/2020 12:00	0.4	14.0	1,436.2	0.4	0.4	1	1	0
11/08/2020 13:00	0.4	13.9	1,649.9	0.4	0.5	1	1	0
11/08/2020 14:00	0.4	13.9	1,657.3	0.4	0.5	1	1	0
11/08/2020 15:00	0.4	13.9	1,675.3	0.4	0.5	1	1	0
11/08/2020 16:00	0.1	13.3	1,832.0	0.2	0.5	1	1	1
11/08/2020 17:00	0.1	12.2	2,143.9	0.2	0.6	1	1	1
11/08/2020 18:00	0.1	12.5	2,066.7	0.2	0.6	1	1	1
11/08/2020 19:00	0.1	12.6	2,027.3	0.2	0.6	1	1	1
11/08/2020 20:00	0.4	13.9	1,657.9	0.4	0.5	1	1	0
11/08/2020 21:00	0.4	13.9	1,582.5	0.4	0.5	1	1	0
11/08/2020 22:00	0.1	13.5	1,811.5	0.2	0.5	1	1	1
11/08/2020 23:00	0.1	12.5	2,073.3	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.5	1,747.4	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.1	12.2	1,436.2	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,143.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2020 00:00	0.1	13.1	1,932.3	0.2	0.6	1	1	1
11/09/2020 01:00	0.4	13.9	1,525.4	0.4	0.5	1	1	0
11/09/2020 02:00	0.5	13.9	1,297.3	0.5	0.4	1	1	0
11/09/2020 03:00	0.4	13.9	1,313.9	0.4	0.4	1	1	0
11/09/2020 04:00	0.2	13.5	1,738.1	0.4	0.5	1	1	1
11/09/2020 05:00	-0.1	12.4	2,132.5	0.2	0.6	1	1	1
11/09/2020 06:00	0.1	12.2	2,175.7	0.2	0.7	1	1	1
11/09/2020 07:00	0.1	12.7	2,060.5	0.2	0.6	1	1	1
11/09/2020 08:00	0.1	13.1	1,941.7	0.2	0.6	1	1	1
11/09/2020 09:00	0.4	13.9	1,515.7	0.4	0.5	1	1	0
11/09/2020 10:00	0.4	13.9	1,539.1	0.4	0.5	1	1	0
11/09/2020 11:00	0.4	14.0	1,438.3	0.4	0.4	1	1	0
11/09/2020 12:00	0.4	14.0	1,470.3	0.4	0.4	1	1	0
11/09/2020 13:00	0.4	14.0	1,410.8	0.4	0.4	1	1	0
11/09/2020 14:00	0.4	13.9	1,617.6	0.4	0.5	1	1	0
11/09/2020 15:00	0.1	13.5	1,800.1	0.2	0.5	1	1	1
11/09/2020 16:00	0.1	12.8	2,030.3	0.2	0.6	1	1	1
11/09/2020 17:00	0.1	12.6	2,058.2	0.2	0.6	1	1	1
11/09/2020 18:00	0.1	12.5	2,104.8	0.2	0.6	1	1	1
11/09/2020 19:00	0.1	12.4	2,106.2	0.2	0.6	1	1	1
11/09/2020 20:00	0.2	12.1	2,177.3	0.4	0.7	1	1	1
11/09/2020 21:00	0.1	12.3	2,145.5	0.2	0.6	1	1	1
11/09/2020 22:00	0.1	12.7	2,046.2	0.2	0.6	1	1	1
11/09/2020 23:00	0.1	12.9	2,014.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,816.4	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	12.1	1,297.3	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,177.3	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2020 00:00	0.1	12.9	2,022.1	0.2	0.6	1	1	1
11/10/2020 01:00	-0.1	13.2	1,940.3	0.1	0.6	1	1	1
11/10/2020 02:00	0.4	13.9	1,678.0	0.4	0.5	1	1	0
11/10/2020 03:00	0.2	13.5	1,816.8	0.4	0.5	1	1	1
11/10/2020 04:00	-0.1	12.9	2,013.2	0.1	0.6	1	1	1
11/10/2020 05:00	-0.1	12.9	2,022.8	0.1	0.6	1	1	1
11/10/2020 06:00	-0.1	13.0	2,028.1	0.1	0.6	1	1	1
11/10/2020 07:00	-0.1	13.0	2,001.0	0.1	0.6	1	1	1
11/10/2020 08:00	-0.1	13.2	1,943.9	0.1	0.6	1	1	1
11/10/2020 09:00	0.4	13.9	1,646.9	0.4	0.5	1	1	0
11/10/2020 10:00	0.4	13.9	1,652.5	0.4	0.5	1	1	0
11/10/2020 11:00	0.4	14.0	1,385.2	0.4	0.4	1	1	0
11/10/2020 12:00	0.4	13.9	1,501.7	0.4	0.5	1	1	0
11/10/2020 13:00	0.4	13.9	1,522.1	0.4	0.5	1	1	0
11/10/2020 14:00	0.4	14.0	1,403.1	0.4	0.4	1	1	0
11/10/2020 15:00	0.2	13.7	1,654.1	0.4	0.5	1	1	1
11/10/2020 16:00	-0.1	12.9	1,991.0	0.1	0.6	1	1	1
11/10/2020 17:00	0.1	12.5	2,075.5	0.2	0.6	1	1	1
11/10/2020 18:00	0.1	12.1	2,167.5	0.2	0.7	1	1	1
11/10/2020 19:00	0.2	12.1	2,159.2	0.4	0.6	1	1	1
11/10/2020 20:00	0.1	12.4	2,108.7	0.2	0.6	1	1	1
11/10/2020 21:00	0.1	12.5	2,093.4	0.2	0.6	1	1	1
11/10/2020 22:00	0.1	12.7	2,049.9	0.2	0.6	1	1	1
11/10/2020 23:00	0.1	12.8	2,030.0	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,871.1	0.3	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.1	1,385.2	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,167.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2020 00:00	-0.1	12.8	2,024.7	0.1	0.6	1	1	1
11/11/2020 01:00	-0.1	13.2	1,926.3	0.1	0.6	1	1	1
11/11/2020 02:00	0.4	13.9	1,580.3	0.4	0.5	1	1	0
11/11/2020 03:00	0.1	13.5	1,837.5	0.2	0.6	1	1	1
11/11/2020 04:00	-0.1	13.0	1,988.7	0.1	0.6	1	1	1
11/11/2020 05:00	-0.1	12.7	2,059.4	0.1	0.6	1	1	1
11/11/2020 06:00	0.1	12.3	2,138.4	0.2	0.6	1	1	1
11/11/2020 07:00	-0.1	13.0	1,979.2	0.1	0.6	1	1	1
11/11/2020 08:00	0.4	13.9	1,678.2	0.4	0.5	1	1	0
11/11/2020 09:00	0.4	13.9	1,670.5	0.4	0.5	1	1	0
11/11/2020 10:00	0.4	13.9	1,645.0	0.4	0.5	1	1	0
11/11/2020 11:00	0.4	13.9	1,560.7	0.4	0.5	1	1	0
11/11/2020 12:00	0.4	13.9	1,648.1	0.4	0.5	1	1	0
11/11/2020 13:00	0.4	13.9	1,516.6	0.4	0.5	1	1	0
11/11/2020 14:00	0.4	13.9	1,676.6	0.4	0.5	1	1	0
11/11/2020 15:00	0.4	14.0	1,375.8	0.4	0.4	1	1	0
11/11/2020 16:00	0.1	13.3	1,854.1	0.2	0.6	1	1	1
11/11/2020 17:00	-0.1	12.8	2,008.2	0.1	0.6	1	1	1
11/11/2020 18:00	0.1	12.5	2,059.7	0.2	0.6	1	1	1
11/11/2020 19:00	-0.1	12.7	2,035.9	0.1	0.6	1	1	1
11/11/2020 20:00	0.1	12.8	1,999.1	0.2	0.6	1	1	1
11/11/2020 21:00	0.4	13.9	1,652.6	0.4	0.5	1	1	0
11/11/2020 22:00	0.1	13.5	1,822.8	0.2	0.5	1	1	1
11/11/2020 23:00	-0.1	12.9	2,016.4	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,823.1	0.3	0.6	24 #	24 #	14 #
Minimum:	-0.1	12.3	1,375.8	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,138.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2020 00:00	-0.1	12.8	2,023.8	0.1	0.6	1	1	1
11/12/2020 01:00	-0.1	13.2	1,918.6	0.1	0.6	1	1	1
11/12/2020 02:00	0.4	13.9	1,563.0	0.4	0.5	1	1	0
11/12/2020 03:00	0.2	13.7	1,680.8	0.4	0.5	1	1	1
11/12/2020 04:00	-0.1	12.9	2,021.0	0.1	0.6	1	1	1
11/12/2020 05:00	-0.1	12.8	2,057.4	0.1	0.6	1	1	1
11/12/2020 06:00	0.1	12.2	2,188.7	0.2	0.7	1	1	1
11/12/2020 07:00	0.1	12.6	2,053.0	0.2	0.6	1	1	1
11/12/2020 08:00	0.4	13.9	1,623.9	0.4	0.5	1	1	0
11/12/2020 09:00	0.4	13.9	1,634.5	0.4	0.5	1	1	0
11/12/2020 10:00	0.4	13.9	1,662.5	0.4	0.5	1	1	0
11/12/2020 11:00	0.4	13.9	1,597.3	0.4	0.5	1	1	0
11/12/2020 12:00	0.4	13.9	1,693.2	0.4	0.5	1	1	0
11/12/2020 13:00	0.4	13.9	1,565.8	0.4	0.5	1	1	0
11/12/2020 14:00	0.4	13.9	1,554.9	0.4	0.5	1	1	0
11/12/2020 15:00	0.2	13.7	1,679.4	0.4	0.5	1	1	1
11/12/2020 16:00	-0.1	12.6	2,033.0	0.1	0.6	1	1	1
11/12/2020 17:00	-0.1	12.5	2,057.5	0.1	0.6	1	1	1
11/12/2020 18:00	-0.1	12.4	2,074.2	0.2	0.6	1	1	1
11/12/2020 19:00	0.1	12.4	2,092.1	0.2	0.6	1	1	1
11/12/2020 20:00	0.1	12.7	1,998.0	0.2	0.6	1	1	1
11/12/2020 21:00	0.4	13.9	1,657.0	0.4	0.5	1	1	0
11/12/2020 22:00	0.1	13.5	1,816.0	0.2	0.5	1	1	1
11/12/2020 23:00	-0.1	12.8	2,013.1	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,844.1	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.1	12.2	1,554.9	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,188.7	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2020 00:00	-0.1	13.2	1,922.4	0.1	0.6	1	1	1
11/13/2020 01:00	0.2	13.7	1,494.9	0.4	0.4	1	1	1
11/13/2020 02:00	0.4	13.9	1,288.7	0.4	0.4	1	1	0
11/13/2020 03:00	0.4	13.9	1,357.3	0.4	0.4	1	1	0
11/13/2020 04:00	0.4	13.9	1,319.5	0.4	0.4	1	1	0
11/13/2020 05:00	0.4	13.9	1,583.7	0.4	0.5	1	1	0
11/13/2020 06:00	0.4	13.8	1,707.1	0.4	0.5	1	1	0
11/13/2020 07:00	0.1	13.5	1,809.2	0.2	0.5	1	1	1
11/13/2020 08:00	-0.1	13.2	1,853.5	0.1	0.6	1	1	1
11/13/2020 09:00	0.4	13.9	1,668.6	0.4	0.5	1	1	0
11/13/2020 10:00	0.4	13.9	1,671.9	0.4	0.5	1	1	0
11/13/2020 11:00	0.4	13.9	1,646.2	0.4	0.5	1	1	0
11/13/2020 12:00	0.4	13.9	1,529.3	0.4	0.5	1	1	0
11/13/2020 13:00	0.4	13.8	1,642.5	0.4	0.5	1	1	0
11/13/2020 14:00	0.4	13.9	1,653.5	0.4	0.5	1	1	0
11/13/2020 15:00	0.1	13.4	1,756.1	0.2	0.5	1	1	1
11/13/2020 16:00	-0.1	12.4	2,064.8	0.2	0.6	1	1	1
11/13/2020 17:00	-0.1	12.5	2,045.5	0.1	0.6	1	1	1
11/13/2020 18:00	-0.1	12.6	2,023.3	0.1	0.6	1	1	1
11/13/2020 19:00	-0.1	13.1	1,869.8	0.1	0.6	1	1	1
11/13/2020 20:00	0.4	13.8	1,671.2	0.4	0.5	1	1	0
11/13/2020 21:00	0.2	13.6	1,683.9	0.4	0.5	1	1	1
11/13/2020 22:00	-0.1	12.8	2,015.5	0.1	0.6	1	1	1
11/13/2020 23:00	0.2	13.5	1,637.6	0.4	0.5	1	1	1
Average/Sum#:	0.2	13.5	1,704.8	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.1	12.4	1,288.7	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,064.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2020 00:00	0.0	14.9	901.9	0.0	0.3	1	0	0
11/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 05:00	0.0	17.7	441.4	0.0	0.1	1	0	0
11/14/2020 06:00	0.0	15.3	946.5	0.0	0.3	1	0	0
11/14/2020 07:00	0.4	13.8	1,597.2	0.4	0.5	1	1	0
11/14/2020 08:00	0.4	13.8	1,693.4	0.4	0.5	1	1	0
11/14/2020 09:00	0.4	13.8	1,684.3	0.4	0.5	1	1	0
11/14/2020 10:00	0.4	13.8	1,693.4	0.4	0.5	1	1	0
11/14/2020 11:00	0.4	13.9	1,688.5	0.4	0.5	1	1	0
11/14/2020 12:00	0.4	13.9	1,678.3	0.4	0.5	1	1	0
11/14/2020 13:00	0.4	13.9	1,678.0	0.4	0.5	1	1	0
11/14/2020 14:00	0.4	13.9	1,646.3	0.4	0.5	1	1	0
11/14/2020 15:00	0.2	13.7	1,694.6	0.4	0.5	1	1	1
11/14/2020 16:00	-0.1	12.8	2,007.9	0.1	0.6	1	1	1
11/14/2020 17:00	-0.1	12.7	2,025.6	0.1	0.6	1	1	1
11/14/2020 18:00	0.1	12.7	2,023.9	0.2	0.6	1	1	1
11/14/2020 19:00	0.1	12.8	1,984.5	0.2	0.6	1	1	1
11/14/2020 20:00	0.4	13.9	1,657.1	0.4	0.5	1	1	0
11/14/2020 21:00	0.1	13.5	1,820.9	0.2	0.5	1	1	1
11/14/2020 22:00	-0.1	12.8	2,022.5	0.1	0.6	1	1	1
11/14/2020 23:00	-0.1	13.2	1,950.0	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.8	1,641.8	0.3	0.5	20 #	17 #	8 #
Minimum:	-0.1	12.7	441.4	0.0	0.1	0	0	0
Maximum:	0.4	17.7	2,025.6	0.4	0.6	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2020 00:00	-0.1	12.8	2,016.2	0.1	0.6	1	1	1
11/15/2020 01:00	-0.1	13.1	1,926.3	0.1	0.6	1	1	1
11/15/2020 02:00	0.4	13.9	1,614.7	0.4	0.5	1	1	0
11/15/2020 03:00	0.2	13.7	1,695.4	0.4	0.5	1	1	1
11/15/2020 04:00	-0.1	12.9	2,004.0	0.1	0.6	1	1	1
11/15/2020 05:00	-0.1	13.3	1,881.6	0.1	0.6	1	1	1
11/15/2020 06:00	0.4	13.8	1,652.9	0.4	0.5	1	1	0
11/15/2020 07:00	0.4	13.9	1,477.7	0.4	0.4	1	1	0
11/15/2020 08:00	0.4	13.8	1,664.6	0.4	0.5	1	1	0
11/15/2020 09:00	0.4	13.8	1,682.3	0.4	0.5	1	1	0
11/15/2020 10:00	0.4	13.9	1,687.8	0.4	0.5	1	1	0
11/15/2020 11:00	0.4	13.9	1,683.7	0.4	0.5	1	1	0
11/15/2020 12:00	0.4	13.9	1,685.5	0.4	0.5	1	1	0
11/15/2020 13:00	0.4	13.9	1,686.7	0.4	0.5	1	1	0
11/15/2020 14:00	0.4	13.9	1,678.4	0.4	0.5	1	1	0
11/15/2020 15:00	0.4	13.9	1,449.6	0.4	0.4	1	1	0
11/15/2020 16:00	0.4	13.9	1,558.6	0.4	0.5	1	1	0
11/15/2020 17:00	0.4	13.9	1,563.5	0.4	0.5	1	1	0
11/15/2020 18:00	0.4	13.9	1,594.2	0.4	0.5	1	1	0
11/15/2020 19:00	0.4	13.9	1,626.8	0.4	0.5	1	1	0
11/15/2020 20:00	0.1	13.5	1,815.0	0.2	0.5	1	1	1
11/15/2020 21:00	-0.1	13.1	1,884.5	0.1	0.6	1	1	1
11/15/2020 22:00	0.2	13.8	1,730.5	0.4	0.5	1	1	1
11/15/2020 23:00	-0.1	12.8	2,009.3	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.6	1,719.6	0.3	0.5	24 #	24 #	9 #
Minimum:	-0.1	12.8	1,449.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,016.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	0.1	13.3	1,819.9	0.2	0.5	1	1	1
11/16/2020 01:00	0.4	13.9	1,293.1	0.4	0.4	1	1	0
11/16/2020 02:00	0.4	13.9	1,286.9	0.4	0.4	1	1	0
11/16/2020 03:00	0.4	13.9	1,285.8	0.4	0.4	1	1	0
11/16/2020 04:00	0.2	13.7	1,682.9	0.4	0.5	1	1	1
11/16/2020 05:00	-0.1	12.8	2,008.4	0.1	0.6	1	1	1
11/16/2020 06:00	0.1	12.6	2,052.6	0.2	0.6	1	1	1
11/16/2020 07:00	0.1	12.8	1,962.8	0.2	0.6	1	1	1
11/16/2020 08:00	0.4	13.9	1,685.3	0.4	0.5	1	1	0
11/16/2020 09:00	0.4	13.9	1,628.3	0.4	0.5	1	1	0
11/16/2020 10:00	0.4	13.9	1,668.4	0.4	0.5	1	1	0
11/16/2020 11:00	0.4	13.9	1,678.4	0.4	0.5	1	1	0
11/16/2020 12:00	0.4	13.9	1,669.6	0.4	0.5	1	1	0
11/16/2020 13:00	0.4	13.9	1,672.8	0.4	0.5	1	1	0
11/16/2020 14:00	0.4	13.9	1,618.7	0.4	0.5	1	1	0
11/16/2020 15:00	0.2	13.6	1,703.6	0.4	0.5	1	1	1
11/16/2020 16:00	-0.1	12.6	2,017.0	0.1	0.6	1	1	1
11/16/2020 17:00	0.1	12.3	2,080.5	0.2	0.6	1	1	1
11/16/2020 18:00	0.1	12.2	2,107.1	0.2	0.6	1	1	1
11/16/2020 19:00	0.1	12.2	2,094.7	0.2	0.6	1	1	1
11/16/2020 20:00	0.1	12.3	2,090.3	0.2	0.6	1	1	1
11/16/2020 21:00	0.1	12.5	2,040.9	0.2	0.6	1	1	1
11/16/2020 22:00	0.1	12.5	2,050.2	0.2	0.6	1	1	1
11/16/2020 23:00	-0.1	12.7	2,025.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,801.0	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.2	1,285.8	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,107.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2020 00:00	-0.1	12.6	2,024.3	0.1	0.6	1	1	1
11/17/2020 01:00	-0.1	12.8	1,966.1	0.1	0.6	1	1	1
11/17/2020 02:00	0.4	13.9	1,533.2	0.4	0.5	1	1	0
11/17/2020 03:00	0.4	13.9	1,519.1	0.4	0.5	1	1	0
11/17/2020 04:00	0.1	13.6	1,719.2	0.2	0.5	1	1	1
11/17/2020 05:00	-0.1	12.7	2,021.4	0.1	0.6	1	1	1
11/17/2020 06:00	-0.1	12.4	2,091.2	0.2	0.6	1	1	1
11/17/2020 07:00	-0.1	12.8	1,975.1	0.1	0.6	1	1	1
11/17/2020 08:00	0.4	13.9	1,663.4	0.4	0.5	1	1	0
11/17/2020 09:00	0.4	13.9	1,561.7	0.4	0.5	1	1	0
11/17/2020 10:00	0.4	13.9	1,548.7	0.4	0.5	1	1	0
11/17/2020 11:00	0.4	13.8	1,693.8	0.4	0.5	1	1	0
11/17/2020 12:00	0.4	13.9	1,462.7	0.4	0.4	1	1	0
11/17/2020 13:00	0.4	13.8	1,567.6	0.4	0.5	1	1	0
11/17/2020 14:00	0.4	13.8	1,598.9	0.4	0.5	1	1	0
11/17/2020 15:00	-0.1	13.3	1,814.4	0.1	0.5	1	1	1
11/17/2020 16:00	0.1	12.3	2,073.4	0.2	0.6	1	1	1
11/17/2020 17:00	0.1	12.2	2,092.3	0.2	0.6	1	1	1
11/17/2020 18:00	0.1	12.2	2,088.3	0.2	0.6	1	1	1
11/17/2020 19:00	0.1	12.3	2,063.5	0.2	0.6	1	1	1
11/17/2020 20:00	0.1	12.5	2,023.7	0.2	0.6	1	1	1
11/17/2020 21:00	0.1	12.5	2,021.6	0.2	0.6	1	1	1
11/17/2020 22:00	0.1	12.5	2,024.6	0.2	0.6	1	1	1
11/17/2020 23:00	-0.1	12.9	1,954.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,837.6	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.1	12.2	1,462.7	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,092.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	-0.1	12.5	2,020.2	0.1	0.6	1	1	1
11/18/2020 01:00	0.1	13.2	1,803.7	0.2	0.5	1	1	1
11/18/2020 02:00	0.4	13.9	1,394.9	0.4	0.4	1	1	0
11/18/2020 03:00	0.4	13.9	1,296.0	0.4	0.4	1	1	0
11/18/2020 04:00	0.2	13.6	1,688.1	0.4	0.5	1	1	1
11/18/2020 05:00	-0.1	12.5	2,037.2	0.1	0.6	1	1	1
11/18/2020 06:00	0.1	12.2	2,088.9	0.2	0.6	1	1	1
11/18/2020 07:00	0.1	12.7	1,957.5	0.2	0.6	1	1	1
11/18/2020 08:00	0.4	13.9	1,507.4	0.4	0.5	1	1	0
11/18/2020 09:00	0.4	13.9	1,510.1	0.4	0.5	1	1	0
11/18/2020 10:00	0.4	13.9	1,572.7	0.4	0.5	1	1	0
11/18/2020 11:00	0.4	13.9	1,690.4	0.4	0.5	1	1	0
11/18/2020 12:00	0.4	13.9	1,668.3	0.4	0.5	1	1	0
11/18/2020 13:00	0.4	13.9	1,579.8	0.4	0.5	1	1	0
11/18/2020 14:00	0.4	13.9	1,509.1	0.4	0.5	1	1	0
11/18/2020 15:00	0.2	13.9	1,689.9	0.2	0.5	1	1	1
11/18/2020 16:00	-0.2	12.9	1,981.5	0.1	0.6	1	1	1
11/18/2020 17:00	-0.1	12.7	2,029.0	0.1	0.6	1	1	1
11/18/2020 18:00	-0.1	12.5	2,079.2	0.1	0.6	1	1	1
11/18/2020 19:00	0.1	12.9	1,959.9	0.2	0.6	1	1	1
11/18/2020 20:00	-0.1	13.1	1,924.1	0.1	0.6	1	1	1
11/18/2020 21:00	-0.1	13.2	1,919.2	0.1	0.6	1	1	1
11/18/2020 22:00	-0.1	13.2	1,928.2	0.1	0.6	1	1	1
11/18/2020 23:00	-0.1	13.2	1,927.7	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,781.8	0.2	0.5	24 #	24 #	15 #
Minimum:	-0.2	12.2	1,296.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,088.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2020 00:00	-0.1	13.2	1,909.1	0.1	0.6	1	1	1
11/19/2020 01:00	0.4	13.9	1,522.8	0.4	0.5	1	1	0
11/19/2020 02:00	0.4	13.9	1,370.4	0.4	0.4	1	1	0
11/19/2020 03:00	0.4	13.9	1,297.7	0.4	0.4	1	1	0
11/19/2020 04:00	0.4	13.9	1,294.9	0.4	0.4	1	1	0
11/19/2020 05:00	0.2	13.8	1,549.3	0.4	0.5	1	1	1
11/19/2020 06:00	-0.2	13.0	1,996.8	0.1	0.6	1	1	1
11/19/2020 07:00	-0.1	13.1	1,957.6	0.1	0.6	1	1	1
11/19/2020 08:00	0.4	13.9	1,601.7	0.4	0.5	1	1	0
11/19/2020 09:00	0.4	13.9	1,662.9	0.4	0.5	1	1	0
11/19/2020 10:00	0.4	13.9	1,691.0	0.4	0.5	1	1	0
11/19/2020 11:00	0.4	13.9	1,588.4	0.4	0.5	1	1	0
11/19/2020 12:00	0.4	13.9	1,695.3	0.4	0.5	1	1	0
11/19/2020 13:00	0.4	13.9	1,640.1	0.4	0.5	1	1	0
11/19/2020 14:00	0.4	13.9	1,673.6	0.4	0.5	1	1	0
11/19/2020 15:00	0.4	14.0	1,313.2	0.4	0.4	1	1	0
11/19/2020 16:00	0.4	13.9	1,590.2	0.4	0.5	1	1	0
11/19/2020 17:00	0.4	13.9	1,712.7	0.4	0.5	1	1	1
11/19/2020 18:00	-0.1	12.7	2,037.8	0.1	0.6	1	1	1
11/19/2020 19:00	0.1	12.4	2,101.9	0.2	0.6	1	1	1
11/19/2020 20:00	0.1	12.6	2,066.5	0.2	0.6	1	1	1
11/19/2020 21:00	0.1	12.9	1,991.8	0.2	0.6	1	1	1
11/19/2020 22:00	0.1	12.7	2,034.0	0.2	0.6	1	1	1
11/19/2020 23:00	0.1	13.1	1,948.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.5	1,718.7	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.2	12.4	1,294.9	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,101.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2020 00:00	-0.1	12.8	2,030.6	0.1	0.6	1	1	1
11/20/2020 01:00	-0.1	13.2	1,916.7	0.1	0.6	1	1	1
11/20/2020 02:00	0.4	13.9	1,585.2	0.4	0.5	1	1	0
11/20/2020 03:00	0.4	13.9	1,583.8	0.4	0.5	1	1	0
11/20/2020 04:00	0.2	13.8	1,723.5	0.4	0.5	1	1	1
11/20/2020 05:00	-0.1	12.7	2,056.5	0.1	0.6	1	1	1
11/20/2020 06:00	0.1	12.5	2,101.2	0.2	0.6	1	1	1
11/20/2020 07:00	0.1	12.6	2,069.7	0.2	0.6	1	1	1
11/20/2020 08:00	0.1	12.8	2,011.3	0.2	0.6	1	1	1
11/20/2020 09:00	0.1	12.9	1,963.5	0.2	0.6	1	1	1
11/20/2020 10:00	0.4	13.9	1,655.8	0.4	0.5	1	1	0
11/20/2020 11:00	0.4	14.0	1,581.6	0.4	0.5	1	1	0
11/20/2020 12:00	0.4	14.0	1,641.3	0.4	0.5	1	1	0
11/20/2020 13:00	0.4	14.0	1,501.7	0.4	0.5	1	1	0
11/20/2020 14:00	0.4	14.0	1,539.4	0.4	0.5	1	1	0
11/20/2020 15:00	0.1	13.5	1,816.6	0.2	0.5	1	1	1
11/20/2020 16:00	-0.1	12.7	2,060.0	0.1	0.6	1	1	1
11/20/2020 17:00	-0.1	12.5	2,106.5	0.1	0.6	1	1	1
11/20/2020 18:00	0.1	12.4	2,121.9	0.2	0.6	1	1	1
11/20/2020 19:00	0.1	12.4	2,117.1	0.2	0.6	1	1	1
11/20/2020 20:00	0.1	12.4	2,121.2	0.2	0.6	1	1	1
11/20/2020 21:00	0.1	12.5	2,110.7	0.2	0.6	1	1	1
11/20/2020 22:00	0.1	12.5	2,082.2	0.2	0.6	1	1	1
11/20/2020 23:00	0.1	12.7	2,038.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,897.3	0.2	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.4	1,501.7	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,121.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2020 00:00	0.1	12.7	2,026.7	0.2	0.6	1	1	1
11/21/2020 01:00	0.1	13.1	1,932.7	0.2	0.6	1	1	1
11/21/2020 02:00	-0.1	13.2	1,901.5	0.1	0.6	1	1	1
11/21/2020 03:00	0.4	13.9	1,748.4	0.4	0.5	1	1	0
11/21/2020 04:00	0.2	13.4	1,830.9	0.4	0.5	1	1	1
11/21/2020 05:00	0.1	12.6	2,062.3	0.2	0.6	1	1	1
11/21/2020 06:00	0.1	12.5	2,088.0	0.2	0.6	1	1	1
11/21/2020 07:00	0.4	13.7	1,613.1	0.4	0.5	1	1	1
11/21/2020 08:00	0.4	13.9	1,604.7	0.4	0.5	1	1	0
11/21/2020 09:00	0.4	13.9	1,611.1	0.4	0.5	1	1	0
11/21/2020 10:00	0.4	14.0	1,469.0	0.4	0.4	1	1	0
11/21/2020 11:00	0.4	14.0	1,666.3	0.4	0.5	1	1	0
11/21/2020 12:00	0.4	14.0	1,665.7	0.4	0.5	1	1	0
11/21/2020 13:00	0.4	14.0	1,685.5	0.4	0.5	1	1	0
11/21/2020 14:00	0.4	14.0	1,592.8	0.4	0.5	1	1	0
11/21/2020 15:00	0.1	13.4	1,835.2	0.2	0.6	1	1	1
11/21/2020 16:00	-0.1	12.6	2,056.8	0.1	0.6	1	1	1
11/21/2020 17:00	-0.1	12.5	2,084.1	0.1	0.6	1	1	1
11/21/2020 18:00	-0.1	12.4	2,111.1	0.2	0.6	1	1	1
11/21/2020 19:00	-0.1	12.4	2,099.8	0.2	0.6	1	1	1
11/21/2020 20:00	-0.1	12.5	2,051.4	0.1	0.6	1	1	1
11/21/2020 21:00	0.4	13.9	1,676.8	0.4	0.5	1	1	0
11/21/2020 22:00	0.1	13.4	1,816.6	0.2	0.5	1	1	1
11/21/2020 23:00	0.1	12.6	2,055.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,845.2	0.3	0.5	24 #	24 #	15 #
Minimum:	-0.1	12.4	1,469.0	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,111.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	0.1	12.7	2,032.8	0.2	0.6	1	1	1
11/22/2020 01:00	0.2	13.3	1,798.1	0.4	0.5	1	1	1
11/22/2020 02:00	0.5	13.9	1,297.5	0.5	0.4	1	1	0
11/22/2020 03:00	0.4	13.9	1,354.4	0.4	0.4	1	1	0
11/22/2020 04:00	0.4	13.9	1,614.4	0.4	0.5	1	1	0
11/22/2020 05:00	0.1	13.5	1,830.8	0.2	0.5	1	1	1
11/22/2020 06:00	0.1	13.5	1,864.6	0.2	0.6	1	1	1
11/22/2020 07:00	0.4	13.9	1,510.8	0.4	0.5	1	1	0
11/22/2020 08:00	0.4	13.9	1,669.7	0.4	0.5	1	1	0
11/22/2020 09:00	0.4	13.9	1,685.7	0.4	0.5	1	1	0
11/22/2020 10:00	0.4	13.9	1,614.2	0.4	0.5	1	1	0
11/22/2020 11:00	0.4	13.9	1,667.8	0.4	0.5	1	1	0
11/22/2020 12:00	0.4	13.9	1,635.6	0.4	0.5	1	1	0
11/22/2020 13:00	0.4	13.9	1,629.1	0.4	0.5	1	1	0
11/22/2020 14:00	0.4	13.9	1,687.0	0.4	0.5	1	1	0
11/22/2020 15:00	0.1	13.4	1,819.1	0.2	0.5	1	1	1
11/22/2020 16:00	-0.1	12.5	2,061.9	0.1	0.6	1	1	1
11/22/2020 17:00	0.1	12.4	2,076.2	0.2	0.6	1	1	1
11/22/2020 18:00	0.1	12.5	2,061.0	0.2	0.6	1	1	1
11/22/2020 19:00	0.1	12.6	2,014.1	0.2	0.6	1	1	1
11/22/2020 20:00	0.4	13.9	1,680.5	0.4	0.5	1	1	0
11/22/2020 21:00	0.1	13.3	1,838.9	0.2	0.6	1	1	1
11/22/2020 22:00	-0.1	12.5	2,064.1	0.1	0.6	1	1	1
11/22/2020 23:00	0.1	13.3	1,854.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,765.1	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.1	12.4	1,297.5	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,076.2	0.5	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2020 00:00	0.2	13.7	1,696.5	0.4	0.5	1	1	1
11/23/2020 01:00	-0.1	13.0	1,944.8	0.1	0.6	1	1	1
11/23/2020 02:00	0.0	14.4	1,218.8	0.0	0.4	1	0	0
11/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/23/2020 05:00	0.0	17.3	501.4	0.0	0.2	1	0	0
11/23/2020 06:00	0.0	14.5	1,170.2	0.0	0.4	1	0	0
11/23/2020 07:00	0.4	13.9	1,695.1	0.4	0.5	1	1	0
11/23/2020 08:00	0.4	13.9	1,621.8	0.4	0.5	1	1	0
11/23/2020 09:00	0.4	13.9	1,651.7	0.4	0.5	1	1	0
11/23/2020 10:00	0.4	13.9	1,579.2	0.4	0.5	1	1	0
11/23/2020 11:00	0.4	13.9	1,660.8	0.4	0.5	1	1	0
11/23/2020 12:00	0.4	13.9	1,681.9	0.4	0.5	1	1	0
11/23/2020 13:00	0.4	13.9	1,634.1	0.4	0.5	1	1	0
11/23/2020 14:00	0.4	13.9	1,680.8	0.4	0.5	1	1	0
11/23/2020 15:00	0.2	13.7	1,749.2	0.4	0.5	1	1	1
11/23/2020 16:00	-0.1	12.6	2,052.0	0.1	0.6	1	1	1
11/23/2020 17:00	-0.1	12.5	2,072.1	0.1	0.6	1	1	1
11/23/2020 18:00	0.1	12.5	2,079.3	0.2	0.6	1	1	1
11/23/2020 19:00	0.1	12.9	1,943.9	0.2	0.6	1	1	1
11/23/2020 20:00	0.4	13.9	1,658.4	0.4	0.5	1	1	0
11/23/2020 21:00	0.2	13.7	1,686.5	0.4	0.5	1	1	1
11/23/2020 22:00	0.1	12.7	2,009.5	0.2	0.6	1	1	1
11/23/2020 23:00	0.1	13.0	1,952.4	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.7	1,679.1	0.3	0.5	22 #	19 #	10 #
Minimum:	-0.1	12.5	501.4	0.0	0.2	0	0	0
Maximum:	0.4	17.3	2,079.3	0.4	0.6	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	0.1	13.0	1,925.1	0.2	0.6	1	1	1
11/24/2020 01:00	0.4	13.9	1,553.3	0.4	0.5	1	1	0
11/24/2020 02:00	0.4	13.9	1,558.0	0.4	0.5	1	1	0
11/24/2020 03:00	0.4	13.9	1,575.0	0.4	0.5	1	1	0
11/24/2020 04:00	0.1	13.4	1,813.2	0.2	0.5	1	1	1
11/24/2020 05:00	-0.1	12.6	2,059.5	0.1	0.6	1	1	1
11/24/2020 06:00	0.1	12.1	2,176.5	0.2	0.7	1	1	1
11/24/2020 07:00	0.1	12.4	2,109.4	0.2	0.6	1	1	1
11/24/2020 08:00	0.2	13.2	1,862.2	0.4	0.6	1	1	1
11/24/2020 09:00	0.4	13.9	1,683.0	0.4	0.5	1	1	0
11/24/2020 10:00	0.4	13.9	1,662.4	0.4	0.5	1	1	0
11/24/2020 11:00	0.4	13.9	1,669.3	0.4	0.5	1	1	0
11/24/2020 12:00	0.4	14.0	1,656.6	0.4	0.5	1	1	0
11/24/2020 13:00	0.4	14.0	1,667.5	0.4	0.5	1	1	0
11/24/2020 14:00	0.4	14.0	1,586.2	0.4	0.5	1	1	0
11/24/2020 15:00	0.2	13.8	1,565.7	0.4	0.5	1	1	1
11/24/2020 16:00	0.1	12.5	2,073.0	0.2	0.6	1	1	1
11/24/2020 17:00	-0.1	12.3	2,121.3	0.2	0.6	1	1	1
11/24/2020 18:00	0.1	12.2	2,143.7	0.2	0.6	1	1	1
11/24/2020 19:00	0.1	12.2	2,138.2	0.2	0.6	1	1	1
11/24/2020 20:00	0.1	12.2	2,146.4	0.2	0.6	1	1	1
11/24/2020 21:00	0.1	12.4	2,122.4	0.2	0.6	1	1	1
11/24/2020 22:00	0.1	12.4	2,109.5	0.2	0.6	1	1	1
11/24/2020 23:00	-0.1	12.7	2,067.2	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,876.9	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.1	12.1	1,553.3	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,176.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2020 00:00	-0.1	12.6	2,070.0	0.1	0.6	1	1	1
11/25/2020 01:00	-0.1	13.1	1,935.8	0.1	0.6	1	1	1
11/25/2020 02:00	0.4	13.9	1,561.3	0.4	0.5	1	1	0
11/25/2020 03:00	0.4	13.9	1,373.5	0.4	0.4	1	1	0
11/25/2020 04:00	0.2	13.9	1,558.2	0.2	0.5	1	1	1
11/25/2020 05:00	-0.2	12.9	2,008.5	0.1	0.6	1	1	1
11/25/2020 06:00	-0.2	13.0	1,995.7	0.1	0.6	1	1	1
11/25/2020 07:00	-0.1	12.9	1,987.1	0.1	0.6	1	1	1
11/25/2020 08:00	0.4	13.8	1,671.0	0.4	0.5	1	1	0
11/25/2020 09:00	0.4	13.9	1,632.6	0.4	0.5	1	1	0
11/25/2020 10:00	0.4	13.9	1,693.6	0.4	0.5	1	1	0
11/25/2020 11:00	0.4	13.9	1,694.8	0.4	0.5	1	1	0
11/25/2020 12:00	0.4	13.9	1,694.5	0.4	0.5	1	1	0
11/25/2020 13:00	0.4	13.9	1,678.8	0.4	0.5	1	1	0
11/25/2020 14:00	0.4	14.0	1,646.8	0.4	0.5	1	1	0
11/25/2020 15:00	0.4	14.0	1,347.0	0.4	0.4	1	1	0
11/25/2020 16:00	0.4	13.9	1,629.8	0.4	0.5	1	1	0
11/25/2020 17:00	0.4	13.9	1,603.7	0.4	0.5	1	1	0
11/25/2020 18:00	0.4	13.9	1,687.1	0.4	0.5	1	1	0
11/25/2020 19:00	0.1	13.4	1,848.1	0.2	0.6	1	1	1
11/25/2020 20:00	0.1	13.0	1,914.7	0.2	0.6	1	1	1
11/25/2020 21:00	0.2	13.7	1,788.8	0.4	0.5	1	1	1
11/25/2020 22:00	-0.1	12.8	2,025.6	0.1	0.6	1	1	1
11/25/2020 23:00	0.0	14.4	1,234.1	0.0	0.4	1	0	1
Average/Sum#:	0.2	13.6	1,720.0	0.3	0.5	24 #	23 #	11 #
Minimum:	-0.2	12.6	1,234.1	0.0	0.4	1	0	0
Maximum:	0.4	14.4	2,070.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 04:00	0.0	17.5	477.8	0.0	0.1	1	0	0
11/27/2020 05:00	0.0	14.9	1,074.5	0.0	0.3	1	0	0
11/27/2020 06:00	0.4	13.9	1,704.6	0.4	0.5	1	1	0
11/27/2020 07:00	0.4	13.9	1,609.8	0.4	0.5	1	1	0
11/27/2020 08:00	0.4	13.9	1,616.5	0.4	0.5	1	1	0
11/27/2020 09:00	0.4	13.9	1,694.9	0.4	0.5	1	1	0
11/27/2020 10:00	0.4	13.9	1,687.0	0.4	0.5	1	1	0
11/27/2020 11:00	0.4	13.9	1,703.0	0.4	0.5	1	1	0
11/27/2020 12:00	0.4	14.0	1,687.2	0.4	0.5	1	1	0
11/27/2020 13:00	0.4	14.0	1,613.9	0.4	0.5	1	1	0
11/27/2020 14:00	0.4	14.0	1,656.4	0.4	0.5	1	1	0
11/27/2020 15:00	0.4	13.9	1,578.9	0.4	0.5	1	1	1
11/27/2020 16:00	-0.1	12.9	1,999.5	0.1	0.6	1	1	1
11/27/2020 17:00	0.1	12.6	2,084.2	0.2	0.6	1	1	1
11/27/2020 18:00	0.1	12.7	2,048.0	0.2	0.6	1	1	1
11/27/2020 19:00	-0.1	12.7	2,042.4	0.1	0.6	1	1	1
11/27/2020 20:00	-0.1	12.9	1,981.1	0.1	0.6	1	1	1
11/27/2020 21:00	0.4	13.9	1,706.5	0.4	0.5	1	1	0
11/27/2020 22:00	0.1	13.5	1,842.8	0.2	0.6	1	1	1
11/27/2020 23:00	-0.1	12.9	2,030.6	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.8	1,692.0	0.3	0.5	20 #	18 #	8 #
Minimum:	-0.1	12.6	477.8	0.0	0.1	0	0	0
Maximum:	0.4	17.5	2,084.2	0.4	0.6	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2020 00:00	-0.1	12.9	2,038.3	0.1	0.6	1	1	1
11/28/2020 01:00	-0.1	13.2	1,942.0	0.1	0.6	1	1	1
11/28/2020 02:00	0.4	13.9	1,586.4	0.4	0.5	1	1	0
11/28/2020 03:00	0.1	13.5	1,827.2	0.2	0.5	1	1	1
11/28/2020 04:00	-0.1	13.2	1,946.1	0.1	0.6	1	1	1
11/28/2020 05:00	-0.1	13.1	1,966.3	0.1	0.6	1	1	1
11/28/2020 06:00	0.4	13.9	1,693.9	0.4	0.5	1	1	0
11/28/2020 07:00	0.4	13.9	1,643.2	0.4	0.5	1	1	0
11/28/2020 08:00	0.4	13.9	1,688.2	0.4	0.5	1	1	0
11/28/2020 09:00	0.4	13.9	1,556.0	0.4	0.5	1	1	0
11/28/2020 10:00	0.4	13.9	1,628.1	0.4	0.5	1	1	0
11/28/2020 11:00	0.4	13.9	1,694.4	0.4	0.5	1	1	0
11/28/2020 12:00	0.4	13.9	1,696.2	0.4	0.5	1	1	0
11/28/2020 13:00	0.4	14.0	1,546.7	0.4	0.5	1	1	0
11/28/2020 14:00	0.4	14.0	1,626.7	0.4	0.5	1	1	0
11/28/2020 15:00	0.2	13.7	1,698.4	0.4	0.5	1	1	1
11/28/2020 16:00	0.1	12.7	2,020.4	0.2	0.6	1	1	1
11/28/2020 17:00	0.1	12.5	2,073.3	0.2	0.6	1	1	1
11/28/2020 18:00	0.1	12.4	2,105.4	0.2	0.6	1	1	1
11/28/2020 19:00	0.1	12.4	2,104.7	0.2	0.6	1	1	1
11/28/2020 20:00	0.1	12.2	2,151.8	0.2	0.6	1	1	1
11/28/2020 21:00	0.2	13.3	1,806.0	0.4	0.5	1	1	1
11/28/2020 22:00	0.1	13.5	1,840.5	0.2	0.6	1	1	1
11/28/2020 23:00	-0.1	12.8	2,047.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,830.3	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.2	1,546.7	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,151.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2020 00:00	-0.1	13.2	1,934.1	0.1	0.6	1	1	1
11/29/2020 01:00	0.4	13.9	1,569.8	0.4	0.5	1	1	0
11/29/2020 02:00	0.1	13.4	1,855.0	0.2	0.6	1	1	1
11/29/2020 03:00	-0.1	12.8	2,040.9	0.1	0.6	1	1	1
11/29/2020 04:00	-0.1	12.8	2,024.9	0.1	0.6	1	1	1
11/29/2020 05:00	0.4	13.9	1,706.1	0.4	0.5	1	1	0
11/29/2020 06:00	0.4	13.9	1,685.2	0.4	0.5	1	1	0
11/29/2020 07:00	0.4	13.9	1,609.4	0.4	0.5	1	1	0
11/29/2020 08:00	0.4	13.9	1,640.1	0.4	0.5	1	1	0
11/29/2020 09:00	0.4	13.9	1,587.6	0.4	0.5	1	1	0
11/29/2020 10:00	0.4	13.9	1,690.8	0.4	0.5	1	1	0
11/29/2020 11:00	0.4	13.9	1,669.9	0.4	0.5	1	1	0
11/29/2020 12:00	0.4	13.9	1,682.5	0.4	0.5	1	1	0
11/29/2020 13:00	0.4	13.9	1,679.0	0.4	0.5	1	1	0
11/29/2020 14:00	0.4	13.9	1,660.0	0.4	0.5	1	1	0
11/29/2020 15:00	0.4	13.9	1,677.7	0.4	0.5	1	1	0
11/29/2020 16:00	0.1	13.4	1,830.4	0.2	0.5	1	1	1
11/29/2020 17:00	0.1	12.5	2,093.2	0.2	0.6	1	1	1
11/29/2020 18:00	0.1	12.2	2,154.9	0.2	0.6	1	1	1
11/29/2020 19:00	0.1	12.4	2,074.8	0.2	0.6	1	1	1
11/29/2020 20:00	0.4	13.9	1,694.2	0.4	0.5	1	1	0
11/29/2020 21:00	0.1	13.4	1,834.9	0.2	0.6	1	1	1
11/29/2020 22:00	-0.1	12.5	2,104.8	0.1	0.6	1	1	1
11/29/2020 23:00	-0.1	12.8	2,042.9	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,814.3	0.3	0.5	24 #	24 #	11 #
Minimum:	-0.1	12.2	1,569.8	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,154.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2020 00:00	-0.1	12.8	2,059.1	0.1	0.6	1	1	1
11/30/2020 01:00	-0.1	12.8	2,025.3	0.1	0.6	1	1	1
11/30/2020 02:00	0.4	13.9	1,572.7	0.4	0.5	1	1	0
11/30/2020 03:00	0.4	13.9	1,545.8	0.4	0.5	1	1	0
11/30/2020 04:00	0.1	13.6	1,775.2	0.2	0.5	1	1	1
11/30/2020 05:00	-0.1	12.7	2,103.2	0.1	0.6	1	1	1
11/30/2020 06:00	-0.1	12.6	2,111.9	0.1	0.6	1	1	1
11/30/2020 07:00	-0.1	12.6	2,098.6	0.1	0.6	1	1	1
11/30/2020 08:00	0.1	13.1	1,933.6	0.2	0.6	1	1	1
11/30/2020 09:00	0.4	13.9	1,668.1	0.4	0.5	1	1	0
11/30/2020 10:00	0.4	13.9	1,567.9	0.4	0.5	1	1	0
11/30/2020 11:00	0.4	13.9	1,637.5	0.4	0.5	1	1	0
11/30/2020 12:00	0.4	13.9	1,618.2	0.4	0.5	1	1	0
11/30/2020 13:00	0.4	14.0	1,420.3	0.4	0.4	1	1	0
11/30/2020 14:00	0.4	13.9	1,672.3	0.4	0.5	1	1	0
11/30/2020 15:00	0.2	13.7	1,696.2	0.4	0.5	1	1	1
11/30/2020 16:00	-0.1	12.7	2,036.7	0.1	0.6	1	1	1
11/30/2020 17:00	0.1	12.3	2,111.4	0.2	0.6	1	1	1
11/30/2020 18:00	0.1	12.3	2,120.4	0.2	0.6	1	1	1
11/30/2020 19:00	0.1	12.1	2,164.1	0.2	0.6	1	1	1
11/30/2020 20:00	0.1	12.4	2,113.2	0.2	0.6	1	1	1
11/30/2020 21:00	0.1	12.4	2,105.8	0.2	0.6	1	1	1
11/30/2020 22:00	0.1	12.5	2,077.7	0.2	0.6	1	1	1
11/30/2020 23:00	0.1	12.8	2,017.1	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,885.5	0.3	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.1	1,420.3	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,164.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2020 00:00	0.1	12.7	2,041.9	0.2	0.6	1	1	1
12/01/2020 01:00	0.1	12.6	2,026.4	0.2	0.6	1	1	1
12/01/2020 02:00	0.4	13.9	1,562.1	0.4	0.5	1	1	0
12/01/2020 03:00	0.1	13.4	1,839.5	0.2	0.6	1	1	1
12/01/2020 04:00	0.1	12.5	2,097.3	0.2	0.6	1	1	1
12/01/2020 05:00	0.1	12.2	2,163.8	0.2	0.6	1	1	1
12/01/2020 06:00	0.2	12.0	2,197.6	0.4	0.7	1	1	1
12/01/2020 07:00	0.1	12.3	2,138.7	0.2	0.6	1	1	1
12/01/2020 08:00	0.1	12.5	2,086.5	0.2	0.6	1	1	1
12/01/2020 09:00	0.4	13.7	1,711.6	0.4	0.5	1	1	1
12/01/2020 10:00	0.4	14.0	1,698.2	0.4	0.5	1	1	0
12/01/2020 11:00	0.4	14.0	1,665.3	0.4	0.5	1	1	0
12/01/2020 12:00	0.4	14.0	1,675.5	0.4	0.5	1	1	0
12/01/2020 13:00	0.5	14.0	1,398.6	0.5	0.4	1	1	0
12/01/2020 14:00	0.4	14.0	1,603.5	0.4	0.5	1	1	0
12/01/2020 15:00	0.4	13.9	1,547.3	0.4	0.5	1	1	1
12/01/2020 16:00	0.1	12.8	1,999.4	0.2	0.6	1	1	1
12/01/2020 17:00	0.2	12.2	2,120.3	0.4	0.6	1	1	1
12/01/2020 18:00	0.2	12.1	2,156.5	0.4	0.6	1	1	1
12/01/2020 19:00	0.2	12.1	2,152.9	0.4	0.6	1	1	1
12/01/2020 20:00	0.2	12.1	2,164.3	0.4	0.6	1	1	1
12/01/2020 21:00	0.2	12.1	2,165.7	0.4	0.6	1	1	1
12/01/2020 22:00	0.2	12.2	2,162.6	0.4	0.6	1	1	1
12/01/2020 23:00	0.1	12.4	2,122.6	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,937.4	0.3	0.6	24 #	24 #	18 #
Minimum:	0.1	12.0	1,398.6	0.2	0.4	1	1	0
Maximum:	0.5	14.0	2,197.6	0.5	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2020 00:00	0.1	12.6	2,101.6	0.2	0.6	1	1	1
12/02/2020 01:00	-0.1	12.9	1,984.0	0.1	0.6	1	1	1
12/02/2020 02:00	0.4	13.9	1,571.3	0.4	0.5	1	1	0
12/02/2020 03:00	0.1	13.4	1,847.6	0.2	0.6	1	1	1
12/02/2020 04:00	-0.1	12.6	2,072.8	0.1	0.6	1	1	1
12/02/2020 05:00	-0.1	12.6	2,090.4	0.1	0.6	1	1	1
12/02/2020 06:00	0.1	12.4	2,117.4	0.2	0.6	1	1	1
12/02/2020 07:00	0.1	12.5	2,102.8	0.2	0.6	1	1	1
12/02/2020 08:00	0.1	12.7	2,045.9	0.2	0.6	1	1	1
12/02/2020 09:00	0.4	13.9	1,585.8	0.4	0.5	1	1	1
12/02/2020 10:00	0.4	13.9	1,666.8	0.4	0.5	1	1	0
12/02/2020 11:00	0.4	14.0	1,699.9	0.4	0.5	1	1	0
12/02/2020 12:00	0.4	14.0	1,652.9	0.4	0.5	1	1	0
12/02/2020 13:00	0.4	14.0	1,548.5	0.4	0.5	1	1	0
12/02/2020 14:00	0.4	14.0	1,583.5	0.4	0.5	1	1	0
12/02/2020 15:00	-0.1	13.4	1,840.6	0.1	0.6	1	1	1
12/02/2020 16:00	-0.1	12.5	2,105.6	0.1	0.6	1	1	1
12/02/2020 17:00	-0.1	12.2	2,157.6	0.2	0.6	1	1	1
12/02/2020 18:00	0.1	12.1	2,186.9	0.2	0.7	1	1	1
12/02/2020 19:00	0.1	12.1	2,185.4	0.2	0.7	1	1	1
12/02/2020 20:00	0.1	12.3	2,124.3	0.2	0.6	1	1	1
12/02/2020 21:00	0.1	12.4	2,109.7	0.2	0.6	1	1	1
12/02/2020 22:00	0.1	12.5	2,100.4	0.2	0.6	1	1	1
12/02/2020 23:00	0.1	12.5	2,097.3	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,940.8	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.1	12.1	1,548.5	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,186.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0.1	12.6	2,084.1	0.2	0.6	1	1	1
12/03/2020 01:00	-0.1	12.6	2,085.5	0.1	0.6	1	1	1
12/03/2020 02:00	-0.1	12.7	2,021.0	0.1	0.6	1	1	1
12/03/2020 03:00	0.4	13.9	1,600.8	0.4	0.5	1	1	0
12/03/2020 04:00	0.1	13.5	1,848.2	0.2	0.6	1	1	1
12/03/2020 05:00	-0.1	12.5	2,126.8	0.1	0.6	1	1	1
12/03/2020 06:00	0.1	12.1	2,214.2	0.2	0.7	1	1	1
12/03/2020 07:00	-0.1	12.5	2,105.4	0.1	0.6	1	1	1
12/03/2020 08:00	-0.1	12.7	2,073.3	0.1	0.6	1	1	1
12/03/2020 09:00	-0.1	13.0	1,968.2	0.1	0.6	1	1	1
12/03/2020 10:00	0.4	13.9	1,696.7	0.4	0.5	1	1	0
12/03/2020 11:00	0.4	13.9	1,645.0	0.4	0.5	1	1	0
12/03/2020 12:00	0.4	13.9	1,678.3	0.4	0.5	1	1	0
12/03/2020 13:00	0.4	13.9	1,677.0	0.4	0.5	1	1	0
12/03/2020 14:00	0.1	13.5	1,833.6	0.2	0.6	1	1	1
12/03/2020 15:00	-0.1	12.6	2,063.9	0.1	0.6	1	1	1
12/03/2020 16:00	-0.1	12.3	2,133.9	0.2	0.6	1	1	1
12/03/2020 17:00	0.1	12.1	2,168.2	0.2	0.7	1	1	1
12/03/2020 18:00	0.2	12.0	2,181.3	0.4	0.7	1	1	1
12/03/2020 19:00	0.2	12.0	2,181.6	0.4	0.7	1	1	1
12/03/2020 20:00	0.1	12.3	2,127.5	0.2	0.6	1	1	1
12/03/2020 21:00	0.1	12.2	2,151.6	0.2	0.6	1	1	1
12/03/2020 22:00	0.1	12.3	2,133.1	0.2	0.6	1	1	1
12/03/2020 23:00	0.1	12.5	2,105.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,996.0	0.2	0.6	24 #	24 #	19 #
Minimum:	-0.1	12.0	1,600.8	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,214.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2020 00:00	0.1	12.6	2,104.5	0.2	0.6	1	1	1
12/04/2020 01:00	0.1	12.7	2,035.8	0.2	0.6	1	1	1
12/04/2020 02:00	0.4	13.9	1,687.4	0.4	0.5	1	1	0
12/04/2020 03:00	0.1	13.4	1,852.5	0.2	0.6	1	1	1
12/04/2020 04:00	-0.1	12.5	2,109.8	0.1	0.6	1	1	1
12/04/2020 05:00	0.1	12.2	2,180.7	0.2	0.7	1	1	1
12/04/2020 06:00	0.1	12.0	2,204.9	0.2	0.7	1	1	1
12/04/2020 07:00	0.1	12.2	2,165.4	0.2	0.6	1	1	1
12/04/2020 08:00	-0.1	12.7	2,066.6	0.1	0.6	1	1	1
12/04/2020 09:00	-0.1	13.0	1,969.7	0.1	0.6	1	1	1
12/04/2020 10:00	0.4	13.9	1,620.2	0.4	0.5	1	1	0
12/04/2020 11:00	0.4	13.9	1,600.7	0.4	0.5	1	1	0
12/04/2020 12:00	-0.1	13.2	1,929.1	0.1	0.6	1	1	1
12/04/2020 13:00	-0.1	13.1	1,938.7	0.1	0.6	1	1	1
12/04/2020 14:00	0.4	13.9	1,663.3	0.4	0.5	1	1	0
12/04/2020 15:00	0.1	13.5	1,801.7	0.2	0.5	1	1	1
12/04/2020 16:00	-0.1	12.5	2,098.6	0.1	0.6	1	1	1
12/04/2020 17:00	0.1	12.2	2,165.5	0.2	0.6	1	1	1
12/04/2020 18:00	0.1	12.2	2,173.7	0.2	0.7	1	1	1
12/04/2020 19:00	0.1	12.1	2,191.2	0.2	0.7	1	1	1
12/04/2020 20:00	0.1	12.2	2,155.8	0.2	0.6	1	1	1
12/04/2020 21:00	0.1	12.1	2,166.0	0.2	0.6	1	1	1
12/04/2020 22:00	0.1	12.3	2,133.9	0.2	0.6	1	1	1
12/04/2020 23:00	0.1	12.5	2,105.5	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.8	2,005.1	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.1	12.0	1,600.7	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,204.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2020 00:00	0.1	12.5	2,111.5	0.2	0.6	1	1	1
12/05/2020 01:00	-0.1	12.6	2,085.4	0.1	0.6	1	1	1
12/05/2020 02:00	-0.1	12.6	2,101.7	0.1	0.6	1	1	1
12/05/2020 03:00	-0.1	12.6	2,104.1	0.1	0.6	1	1	1
12/05/2020 04:00	-0.1	12.6	2,102.4	0.1	0.6	1	1	1
12/05/2020 05:00	-0.1	12.5	2,107.1	0.1	0.6	1	1	1
12/05/2020 06:00	-0.1	12.8	2,051.3	0.1	0.6	1	1	1
12/05/2020 07:00	0.4	13.9	1,670.3	0.4	0.5	1	1	0
12/05/2020 08:00	0.4	13.9	1,629.1	0.4	0.5	1	1	0
12/05/2020 09:00	0.4	13.9	1,682.4	0.4	0.5	1	1	0
12/05/2020 10:00	0.4	13.9	1,674.4	0.4	0.5	1	1	0
12/05/2020 11:00	0.4	13.9	1,706.1	0.4	0.5	1	1	0
12/05/2020 12:00	0.4	13.9	1,697.3	0.4	0.5	1	1	0
12/05/2020 13:00	0.4	13.9	1,656.1	0.4	0.5	1	1	0
12/05/2020 14:00	0.4	13.9	1,640.7	0.4	0.5	1	1	0
12/05/2020 15:00	-0.1	13.4	1,842.4	0.1	0.6	1	1	1
12/05/2020 16:00	-0.1	12.6	2,088.0	0.1	0.6	1	1	1
12/05/2020 17:00	-0.1	12.3	2,150.7	0.2	0.6	1	1	1
12/05/2020 18:00	0.1	12.1	2,184.2	0.2	0.7	1	1	1
12/05/2020 19:00	0.1	12.0	2,207.9	0.2	0.7	1	1	1
12/05/2020 20:00	0.1	12.1	2,192.9	0.2	0.7	1	1	1
12/05/2020 21:00	0.1	12.2	2,186.7	0.2	0.7	1	1	1
12/05/2020 22:00	-0.1	12.5	2,116.2	0.1	0.6	1	1	1
12/05/2020 23:00	-0.1	12.6	2,111.9	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,962.5	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.0	1,629.1	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,207.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2020 00:00	-0.1	12.6	2,109.1	0.1	0.6	1	1	1
12/06/2020 01:00	-0.1	12.8	2,071.0	0.1	0.6	1	1	1
12/06/2020 02:00	-0.1	12.8	2,070.6	0.1	0.6	1	1	1
12/06/2020 03:00	-0.1	13.3	1,891.3	0.1	0.6	1	1	1
12/06/2020 04:00	0.2	13.7	1,800.5	0.4	0.5	1	1	1
12/06/2020 05:00	-0.1	12.8	2,031.3	0.1	0.6	1	1	1
12/06/2020 06:00	-0.1	13.0	1,955.2	0.1	0.6	1	1	1
12/06/2020 07:00	0.4	13.9	1,559.6	0.4	0.5	1	1	0
12/06/2020 08:00	0.4	13.9	1,564.2	0.4	0.5	1	1	0
12/06/2020 09:00	0.4	13.9	1,689.1	0.4	0.5	1	1	0
12/06/2020 10:00	0.4	13.9	1,688.9	0.4	0.5	1	1	0
12/06/2020 11:00	0.4	13.9	1,698.4	0.4	0.5	1	1	0
12/06/2020 12:00	0.4	14.0	1,617.5	0.4	0.5	1	1	0
12/06/2020 13:00	0.4	14.0	1,684.3	0.4	0.5	1	1	0
12/06/2020 14:00	0.4	14.0	1,654.6	0.4	0.5	1	1	0
12/06/2020 15:00	0.1	13.5	1,839.1	0.2	0.6	1	1	1
12/06/2020 16:00	-0.1	12.6	2,077.2	0.1	0.6	1	1	1
12/06/2020 17:00	0.1	12.2	2,168.7	0.2	0.7	1	1	1
12/06/2020 18:00	0.1	12.1	2,193.8	0.2	0.7	1	1	1
12/06/2020 19:00	0.1	12.1	2,194.5	0.2	0.7	1	1	1
12/06/2020 20:00	0.1	12.1	2,191.8	0.2	0.7	1	1	1
12/06/2020 21:00	0.1	12.3	2,154.9	0.2	0.6	1	1	1
12/06/2020 22:00	0.1	12.5	2,100.7	0.2	0.6	1	1	1
12/06/2020 23:00	-0.1	12.7	2,044.3	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,918.8	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.1	1,559.6	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,194.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2020 00:00	0.1	12.6	2,064.1	0.2	0.6	1	1	1
12/07/2020 01:00	0.1	12.9	1,966.0	0.2	0.6	1	1	1
12/07/2020 02:00	0.4	13.9	1,609.0	0.4	0.5	1	1	0
12/07/2020 03:00	0.1	13.5	1,819.8	0.2	0.5	1	1	1
12/07/2020 04:00	-0.1	12.7	2,051.9	0.1	0.6	1	1	1
12/07/2020 05:00	0.1	12.6	2,073.5	0.2	0.6	1	1	1
12/07/2020 06:00	0.1	12.2	2,152.0	0.2	0.6	1	1	1
12/07/2020 07:00	0.1	12.2	2,146.6	0.2	0.6	1	1	1
12/07/2020 08:00	0.1	12.3	2,126.8	0.2	0.6	1	1	1
12/07/2020 09:00	0.2	12.3	2,108.4	0.4	0.6	1	1	1
12/07/2020 10:00	0.4	13.7	1,691.7	0.4	0.5	1	1	1
12/07/2020 11:00	0.4	14.0	1,595.5	0.4	0.5	1	1	0
12/07/2020 12:00	0.4	14.0	1,589.1	0.4	0.5	1	1	0
12/07/2020 13:00	0.4	14.0	1,668.9	0.4	0.5	1	1	0
12/07/2020 14:00	0.2	13.6	1,659.9	0.4	0.5	1	1	1
12/07/2020 15:00	0.1	12.5	2,029.3	0.2	0.6	1	1	1
12/07/2020 16:00	0.2	12.4	2,070.9	0.4	0.6	1	1	1
12/07/2020 17:00	0.2	12.2	2,130.0	0.4	0.6	1	1	1
12/07/2020 18:00	0.1	12.3	2,129.7	0.2	0.6	1	1	1
12/07/2020 19:00	0.1	12.3	2,133.4	0.2	0.6	1	1	1
12/07/2020 20:00	0.1	12.3	2,149.2	0.2	0.6	1	1	1
12/07/2020 21:00	0.1	12.2	2,169.2	0.2	0.7	1	1	1
12/07/2020 22:00	0.1	12.3	2,138.0	0.2	0.6	1	1	1
12/07/2020 23:00	0.1	12.7	2,064.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.8	1,972.4	0.3	0.6	24 #	24 #	20 #
Minimum:	-0.1	12.2	1,589.1	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,169.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2020 00:00	0.1	12.8	2,041.9	0.2	0.6	1	1	1
12/08/2020 01:00	-0.1	13.1	1,938.2	0.1	0.6	1	1	1
12/08/2020 02:00	0.4	13.9	1,660.2	0.4	0.5	1	1	0
12/08/2020 03:00	0.2	13.5	1,793.9	0.4	0.5	1	1	1
12/08/2020 04:00	-0.1	12.8	2,025.4	0.1	0.6	1	1	1
12/08/2020 05:00	-0.1	13.1	1,972.8	0.1	0.6	1	1	1
12/08/2020 06:00	-0.1	12.6	2,072.0	0.1	0.6	1	1	1
12/08/2020 07:00	0.1	12.3	2,149.5	0.2	0.6	1	1	1
12/08/2020 08:00	0.1	12.5	2,097.7	0.2	0.6	1	1	1
12/08/2020 09:00	-0.1	13.0	1,961.8	0.1	0.6	1	1	1
12/08/2020 10:00	0.4	13.9	1,653.3	0.4	0.5	1	1	0
12/08/2020 11:00	0.4	14.0	1,579.3	0.4	0.5	1	1	0
12/08/2020 12:00	0.4	14.0	1,601.5	0.4	0.5	1	1	0
12/08/2020 13:00	0.4	14.0	1,566.8	0.4	0.5	1	1	0
12/08/2020 14:00	0.4	14.0	1,544.9	0.4	0.5	1	1	0
12/08/2020 15:00	0.2	13.7	1,708.2	0.4	0.5	1	1	1
12/08/2020 16:00	-0.1	12.7	2,020.8	0.1	0.6	1	1	1
12/08/2020 17:00	0.1	12.2	2,141.1	0.2	0.6	1	1	1
12/08/2020 18:00	0.1	12.1	2,153.4	0.2	0.6	1	1	1
12/08/2020 19:00	0.1	12.0	2,180.5	0.2	0.7	1	1	1
12/08/2020 20:00	0.1	12.2	2,155.9	0.2	0.6	1	1	1
12/08/2020 21:00	0.1	12.4	2,117.1	0.2	0.6	1	1	1
12/08/2020 22:00	-0.1	12.6	2,084.9	0.1	0.6	1	1	1
12/08/2020 23:00	-0.1	12.8	2,050.4	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,928.0	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.1	12.0	1,544.9	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,180.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2020 00:00	-0.1	12.7	2,055.3	0.1	0.6	1	1	1
12/09/2020 01:00	-0.1	12.8	2,036.2	0.1	0.6	1	1	1
12/09/2020 02:00	-0.1	13.2	1,932.9	0.1	0.6	1	1	1
12/09/2020 03:00	0.4	13.9	1,752.2	0.4	0.5	1	1	0
12/09/2020 04:00	0.1	13.5	1,824.7	0.2	0.5	1	1	1
12/09/2020 05:00	-0.1	12.8	2,037.2	0.1	0.6	1	1	1
12/09/2020 06:00	-0.1	12.5	2,090.5	0.1	0.6	1	1	1
12/09/2020 07:00	-0.1	12.6	2,087.7	0.1	0.6	1	1	1
12/09/2020 08:00	-0.1	12.7	2,072.4	0.1	0.6	1	1	1
12/09/2020 09:00	-0.1	13.2	1,904.2	0.1	0.6	1	1	1
12/09/2020 10:00	0.4	13.9	1,753.3	0.4	0.5	1	1	0
12/09/2020 11:00	0.4	13.9	1,754.1	0.4	0.5	1	1	0
12/09/2020 12:00	0.4	13.8	1,751.3	0.4	0.5	1	1	0
12/09/2020 13:00	0.4	13.8	1,754.8	0.4	0.5	1	1	0
12/09/2020 14:00	0.4	13.8	1,751.7	0.4	0.5	1	1	0
12/09/2020 15:00	0.1	13.3	1,816.3	0.2	0.5	1	1	1
12/09/2020 16:00	0.1	12.4	2,054.6	0.2	0.6	1	1	1
12/09/2020 17:00	0.2	12.3	2,088.2	0.4	0.6	1	1	1
12/09/2020 18:00	0.2	12.3	2,087.2	0.4	0.6	1	1	1
12/09/2020 19:00	0.1	12.3	2,132.6	0.2	0.6	1	1	1
12/09/2020 20:00	0.1	12.4	2,111.0	0.2	0.6	1	1	1
12/09/2020 21:00	0.1	12.2	2,149.4	0.2	0.6	1	1	1
12/09/2020 22:00	0.1	12.2	2,141.9	0.2	0.6	1	1	1
12/09/2020 23:00	0.1	12.5	2,081.5	0.2	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,967.6	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.1	12.2	1,751.3	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,149.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2020 00:00	0.1	12.6	2,074.4	0.2	0.6	1	1	1
12/10/2020 01:00	-0.1	12.7	2,045.2	0.1	0.6	1	1	1
12/10/2020 02:00	-0.1	12.6	2,058.3	0.1	0.6	1	1	1
12/10/2020 03:00	0.4	13.9	1,695.1	0.4	0.5	1	1	0
12/10/2020 04:00	0.2	13.4	1,830.0	0.4	0.5	1	1	1
12/10/2020 05:00	0.1	12.3	2,122.5	0.2	0.6	1	1	1
12/10/2020 06:00	0.1	12.4	2,109.0	0.2	0.6	1	1	1
12/10/2020 07:00	0.1	12.4	2,096.7	0.2	0.6	1	1	1
12/10/2020 08:00	0.1	12.4	2,101.1	0.2	0.6	1	1	1
12/10/2020 09:00	0.1	12.4	2,100.4	0.2	0.6	1	1	1
12/10/2020 10:00	0.4	13.7	1,696.2	0.4	0.5	1	1	1
12/10/2020 11:00	0.4	14.0	1,626.8	0.4	0.5	1	1	0
12/10/2020 12:00	0.4	14.0	1,532.4	0.4	0.5	1	1	0
12/10/2020 13:00	0.4	14.0	1,574.9	0.4	0.5	1	1	0
12/10/2020 14:00	0.4	14.0	1,536.7	0.4	0.5	1	1	0
12/10/2020 15:00	0.2	13.5	1,819.1	0.4	0.5	1	1	1
12/10/2020 16:00	-0.1	12.7	2,059.5	0.1	0.6	1	1	1
12/10/2020 17:00	-0.1	12.4	2,132.7	0.2	0.6	1	1	1
12/10/2020 18:00	0.1	12.2	2,150.8	0.2	0.6	1	1	1
12/10/2020 19:00	0.1	12.3	2,125.9	0.2	0.6	1	1	1
12/10/2020 20:00	0.1	12.5	2,096.4	0.2	0.6	1	1	1
12/10/2020 21:00	0.1	12.4	2,113.2	0.2	0.6	1	1	1
12/10/2020 22:00	0.1	12.4	2,107.0	0.2	0.6	1	1	1
12/10/2020 23:00	-0.1	12.7	2,070.0	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.9	1,953.1	0.3	0.6	24 #	24 #	19 #
Minimum:	-0.1	12.2	1,532.4	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,150.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2020 00:00	-0.1	13.1	1,943.2	0.1	0.6	1	1	1
12/11/2020 01:00	0.4	13.9	1,702.9	0.4	0.5	1	1	0
12/11/2020 02:00	0.4	13.9	1,603.5	0.4	0.5	1	1	0
12/11/2020 03:00	0.4	13.9	1,594.9	0.4	0.5	1	1	0
12/11/2020 04:00	0.1	13.5	1,774.4	0.2	0.5	1	1	1
12/11/2020 05:00	-0.1	12.8	2,063.6	0.1	0.6	1	1	1
12/11/2020 06:00	-0.1	12.5	2,134.0	0.1	0.6	1	1	1
12/11/2020 07:00	-0.1	12.5	2,112.2	0.1	0.6	1	1	1
12/11/2020 08:00	-0.1	12.6	2,075.6	0.1	0.6	1	1	1
12/11/2020 09:00	0.4	13.9	1,668.3	0.4	0.5	1	1	0
12/11/2020 10:00	0.4	13.9	1,667.1	0.4	0.5	1	1	0
12/11/2020 11:00	0.4	13.9	1,650.1	0.4	0.5	1	1	0
12/11/2020 12:00	0.4	13.9	1,627.3	0.4	0.5	1	1	0
12/11/2020 13:00	0.4	13.9	1,670.4	0.4	0.5	1	1	0
12/11/2020 14:00	0.4	13.9	1,675.3	0.4	0.5	1	1	0
12/11/2020 15:00	0.1	13.5	1,823.4	0.2	0.5	1	1	1
12/11/2020 16:00	-0.2	12.5	2,092.7	0.1	0.6	1	1	1
12/11/2020 17:00	-0.1	12.4	2,120.0	0.2	0.6	1	1	1
12/11/2020 18:00	0.1	12.1	2,177.2	0.2	0.7	1	1	1
12/11/2020 19:00	0.1	12.1	2,182.0	0.2	0.7	1	1	1
12/11/2020 20:00	0.1	12.1	2,181.6	0.2	0.7	1	1	1
12/11/2020 21:00	0.1	12.1	2,179.2	0.2	0.7	1	1	1
12/11/2020 22:00	-0.1	12.4	2,113.9	0.2	0.6	1	1	1
12/11/2020 23:00	-0.1	12.6	2,084.2	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,913.2	0.2	0.6	24 #	24 #	15 #
Minimum:	-0.2	12.1	1,594.9	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,182.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	-0.1	12.5	2,098.2	0.1	0.6	1	1	1
12/12/2020 01:00	-0.1	12.6	2,064.1	0.1	0.6	1	1	1
12/12/2020 02:00	-0.1	13.1	1,946.1	0.1	0.6	1	1	1
12/12/2020 03:00	0.4	13.8	1,622.9	0.4	0.5	1	1	0
12/12/2020 04:00	0.1	13.5	1,817.4	0.2	0.5	1	1	1
12/12/2020 05:00	-0.2	13.2	1,947.0	-0.1	0.6	1	1	1
12/12/2020 06:00	-0.2	13.2	1,936.7	-0.1	0.6	1	1	1
12/12/2020 07:00	0.4	13.8	1,690.5	0.4	0.5	1	1	1
12/12/2020 08:00	0.4	13.8	1,675.2	0.4	0.5	1	1	0
12/12/2020 09:00	0.4	13.8	1,687.3	0.4	0.5	1	1	0
12/12/2020 10:00	0.4	13.9	1,672.3	0.4	0.5	1	1	0
12/12/2020 11:00	0.4	13.9	1,582.7	0.4	0.5	1	1	0
12/12/2020 12:00	0.4	13.9	1,644.0	0.4	0.5	1	1	0
12/12/2020 13:00	0.4	13.9	1,701.2	0.4	0.5	1	1	0
12/12/2020 14:00	0.4	13.9	1,672.1	0.4	0.5	1	1	0
12/12/2020 15:00	0.1	13.4	1,825.5	0.2	0.5	1	1	1
12/12/2020 16:00	-0.1	12.6	2,069.8	0.1	0.6	1	1	1
12/12/2020 17:00	0.1	12.3	2,128.6	0.2	0.6	1	1	1
12/12/2020 18:00	0.1	12.2	2,163.9	0.2	0.6	1	1	1
12/12/2020 19:00	0.1	12.2	2,164.6	0.2	0.6	1	1	1
12/12/2020 20:00	0.1	12.2	2,162.7	0.2	0.6	1	1	1
12/12/2020 21:00	0.1	12.2	2,159.5	0.2	0.6	1	1	1
12/12/2020 22:00	0.1	12.2	2,145.1	0.2	0.6	1	1	1
12/12/2020 23:00	0.1	12.5	2,089.3	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,902.8	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.2	12.2	1,582.7	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,164.6	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2020 00:00	0.1	12.5	2,094.3	0.2	0.6	1	1	1
12/13/2020 01:00	-0.1	12.7	2,049.3	0.1	0.6	1	1	1
12/13/2020 02:00	-0.1	13.2	1,945.5	0.1	0.6	1	1	1
12/13/2020 03:00	-0.1	13.2	1,945.8	0.1	0.6	1	1	1
12/13/2020 04:00	-0.1	13.2	1,957.7	0.1	0.6	1	1	1
12/13/2020 05:00	-0.1	12.8	2,035.9	0.1	0.6	1	1	1
12/13/2020 06:00	-0.1	12.8	2,026.4	0.1	0.6	1	1	1
12/13/2020 07:00	0.4	13.8	1,606.2	0.4	0.5	1	1	0
12/13/2020 08:00	0.4	13.9	1,299.5	0.4	0.4	1	1	0
12/13/2020 09:00	0.4	13.9	1,300.2	0.4	0.4	1	1	0
12/13/2020 10:00	0.4	13.9	1,314.2	0.4	0.4	1	1	0
12/13/2020 11:00	0.4	13.9	1,500.8	0.4	0.5	1	1	0
12/13/2020 12:00	0.4	13.8	1,668.3	0.4	0.5	1	1	0
12/13/2020 13:00	0.4	13.8	1,683.1	0.4	0.5	1	1	0
12/13/2020 14:00	0.4	13.8	1,693.8	0.4	0.5	1	1	0
12/13/2020 15:00	-0.1	13.4	1,806.9	0.1	0.5	1	1	1
12/13/2020 16:00	-0.2	12.6	2,042.3	0.1	0.6	1	1	1
12/13/2020 17:00	0.1	12.2	2,140.8	0.2	0.6	1	1	1
12/13/2020 18:00	0.1	12.2	2,137.1	0.2	0.6	1	1	1
12/13/2020 19:00	-0.1	12.4	2,108.1	0.2	0.6	1	1	1
12/13/2020 20:00	-0.1	12.4	2,120.4	0.2	0.6	1	1	1
12/13/2020 21:00	-0.1	12.6	2,081.7	0.1	0.6	1	1	1
12/13/2020 22:00	-0.1	12.8	2,038.0	0.1	0.6	1	1	1
12/13/2020 23:00	-0.1	12.8	2,012.3	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,858.7	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.2	12.2	1,299.5	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,140.8	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2020 00:00	0.0	15.5	715.7	0.0	0.2	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 05:00	0.0	17.5	497.1	0.0	0.1	1	0	0
12/14/2020 06:00	0.0	13.9	1,539.7	0.0	0.5	1	0	1
12/14/2020 07:00	-0.2	12.8	2,066.9	0.1	0.6	1	1	1
12/14/2020 08:00	-0.2	12.9	2,053.3	0.1	0.6	1	1	1
12/14/2020 09:00	-0.2	13.0	2,019.6	0.1	0.6	1	1	1
12/14/2020 10:00	0.4	13.9	1,526.8	0.4	0.5	1	1	0
12/14/2020 11:00	0.4	13.9	1,544.1	0.4	0.5	1	1	0
12/14/2020 12:00	0.4	13.9	1,421.5	0.4	0.4	1	1	0
12/14/2020 13:00	0.4	14.0	1,375.4	0.4	0.4	1	1	0
12/14/2020 14:00	0.6	0.0	1,426.7	0.6	0.4	1	1	0
12/14/2020 15:00	0.7	0.0	1,852.2	0.7	0.6	1	1	1
12/14/2020 16:00	-0.2	12.6	1,988.4	0.1	0.6	1	1	1
12/14/2020 17:00	-0.1	12.2	2,161.3	0.2	0.6	1	1	1
12/14/2020 18:00	-0.1	12.2	2,174.8	0.2	0.7	1	1	1
12/14/2020 19:00	-0.1	12.2	2,172.2	0.2	0.7	1	1	1
12/14/2020 20:00	-0.1	12.2	2,172.7	0.2	0.7	1	1	1
12/14/2020 21:00	-0.1	12.2	2,171.4	0.2	0.7	1	1	1
12/14/2020 22:00	-0.1	12.4	2,108.0	0.2	0.6	1	1	1
12/14/2020 23:00	-0.2	13.2	1,938.6	-0.1	0.6	1	1	1
Average/Sum#:	0.0	13.4	1,746.3	0.2	0.5	20 #	17 #	13 #
Minimum:	-0.2	12.2	497.1	-0.1	0.1	0	0	0
Maximum:	0.4	17.5	2,174.8	0.4	0.7	1	1	1
%SI	25.00	25.00	16.67	25.00	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2020 00:00	-0.2	12.9	2,009.6	0.1	0.6	1	1	1
12/15/2020 01:00	-0.2	13.2	1,940.9	-0.1	0.6	1	1	1
12/15/2020 02:00	-0.2	13.2	1,940.2	-0.1	0.6	1	1	1
12/15/2020 03:00	-0.2	13.3	1,935.0	-0.1	0.6	1	1	1
12/15/2020 04:00	-0.2	12.9	2,029.4	0.1	0.6	1	1	1
12/15/2020 05:00	-0.2	12.3	2,158.1	0.1	0.6	1	1	1
12/15/2020 06:00	-0.2	12.3	2,168.5	0.1	0.7	1	1	1
12/15/2020 07:00	-0.2	12.4	2,134.9	0.1	0.6	1	1	1
12/15/2020 08:00	-0.2	12.9	2,019.0	0.1	0.6	1	1	1
12/15/2020 09:00	-0.2	13.2	1,957.2	-0.1	0.6	1	1	1
12/15/2020 10:00	-0.2	13.3	1,930.5	-0.1	0.6	1	1	1
12/15/2020 11:00	-0.2	13.3	1,941.1	-0.1	0.6	1	1	1
12/15/2020 12:00	-0.2	13.2	1,943.1	-0.1	0.6	1	1	1
12/15/2020 13:00	-0.2	13.2	1,941.8	-0.1	0.6	1	1	1
12/15/2020 14:00	-0.2	13.2	1,945.4	-0.1	0.6	1	1	1
12/15/2020 15:00	-0.2	13.2	1,946.1	-0.1	0.6	1	1	1
12/15/2020 16:00	-0.2	12.9	2,017.1	0.1	0.6	1	1	1
12/15/2020 17:00	-0.2	12.3	2,159.2	0.1	0.6	1	1	1
12/15/2020 18:00	-0.2	12.2	2,174.2	0.1	0.7	1	1	1
12/15/2020 19:00	-0.2	12.3	2,168.9	0.1	0.7	1	1	1
12/15/2020 20:00	-0.2	12.3	2,160.0	0.1	0.6	1	1	1
12/15/2020 21:00	-0.2	12.4	2,150.1	0.1	0.6	1	1	1
12/15/2020 22:00	-0.2	12.4	2,139.6	0.1	0.6	1	1	1
12/15/2020 23:00	-0.2	12.7	2,065.7	0.1	0.6	1	1	1
Average/Sum#:	-0.2	12.8	2,040.7	0.0	0.6	24 #	24 #	24 #
Minimum:	-0.2	12.2	1,930.5	-0.1	0.6	1	1	1
Maximum:	-0.2	13.3	2,174.2	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2020 00:00	-0.2	12.8	2,038.4	0.1	0.6	1	1	1
12/16/2020 01:00	-0.2	13.0	1,993.0	0.1	0.6	1	1	1
12/16/2020 02:00	-0.2	13.3	1,941.5	-0.1	0.6	1	1	1
12/16/2020 03:00	-0.2	13.3	1,944.0	-0.1	0.6	1	1	1
12/16/2020 04:00	-0.4	13.1	1,981.3	-0.1	0.6	1	1	1
12/16/2020 05:00	-0.2	12.6	2,094.3	0.1	0.6	1	1	1
12/16/2020 06:00	-0.2	12.4	2,126.3	0.1	0.6	1	1	1
12/16/2020 07:00	-0.2	12.4	2,154.6	0.1	0.6	1	1	1
12/16/2020 08:00	-0.2	12.7	2,092.8	0.1	0.6	1	1	1
12/16/2020 09:00	-0.2	13.3	1,938.6	-0.1	0.6	1	1	1
12/16/2020 10:00	-0.4	13.3	1,934.1	-0.1	0.6	1	1	1
12/16/2020 11:00	-0.2	13.2	1,940.5	-0.1	0.6	1	1	1
12/16/2020 12:00	-0.4	13.2	1,937.4	-0.1	0.6	1	1	1
12/16/2020 13:00	-0.2	13.1	1,940.0	-0.1	0.6	1	1	1
12/16/2020 14:00	-0.2	13.1	1,933.2	-0.1	0.6	1	1	1
12/16/2020 15:00	0.4	13.9	1,688.3	0.4	0.5	1	1	0
12/16/2020 16:00	0.4	13.9	1,508.1	0.4	0.5	1	1	0
12/16/2020 17:00	0.4	13.7	1,774.6	0.4	0.5	1	1	0
12/16/2020 18:00	-0.1	13.2	1,909.3	0.1	0.6	1	1	1
12/16/2020 19:00	-0.1	12.3	2,134.9	0.2	0.6	1	1	1
12/16/2020 20:00	0.1	12.1	2,167.0	0.2	0.7	1	1	1
12/16/2020 21:00	0.1	12.1	2,164.6	0.2	0.6	1	1	1
12/16/2020 22:00	0.1	12.1	2,161.2	0.2	0.6	1	1	1
12/16/2020 23:00	0.1	12.2	2,147.4	0.2	0.6	1	1	1
Average/Sum#:	-0.1	12.9	1,985.2	0.1	0.6	24 #	24 #	21 #
Minimum:	-0.4	12.1	1,508.1	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,167.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	-0.1	12.5	2,073.1	0.1	0.6	1	1	1
12/17/2020 01:00	0.1	13.0	1,893.2	0.2	0.6	1	1	1
12/17/2020 02:00	0.2	13.6	1,784.7	0.4	0.5	1	1	1
12/17/2020 03:00	-0.1	12.7	2,035.1	0.1	0.6	1	1	1
12/17/2020 04:00	-0.1	12.6	2,056.8	0.1	0.6	1	1	1
12/17/2020 05:00	-0.1	12.5	2,074.1	0.1	0.6	1	1	1
12/17/2020 06:00	-0.1	12.7	2,013.4	0.1	0.6	1	1	1
12/17/2020 07:00	-0.1	12.4	2,113.9	0.2	0.6	1	1	1
12/17/2020 08:00	-0.1	12.6	2,061.6	0.1	0.6	1	1	1
12/17/2020 09:00	-0.1	12.9	1,976.5	0.1	0.6	1	1	1
12/17/2020 10:00	0.4	13.9	1,637.6	0.4	0.5	1	1	0
12/17/2020 11:00	0.4	13.9	1,686.0	0.4	0.5	1	1	0
12/17/2020 12:00	0.4	13.9	1,671.8	0.4	0.5	1	1	0
12/17/2020 13:00	0.4	13.9	1,685.6	0.4	0.5	1	1	0
12/17/2020 14:00	0.4	13.9	1,660.7	0.4	0.5	1	1	0
12/17/2020 15:00	0.4	13.9	1,654.1	0.4	0.5	1	1	0
12/17/2020 16:00	0.1	13.5	1,810.0	0.2	0.5	1	1	1
12/17/2020 17:00	-0.1	12.6	2,085.0	0.1	0.6	1	1	1
12/17/2020 18:00	0.1	12.5	2,093.9	0.2	0.6	1	1	1
12/17/2020 19:00	-0.1	12.6	2,068.2	0.1	0.6	1	1	1
12/17/2020 20:00	-0.1	12.7	2,058.0	0.1	0.6	1	1	1
12/17/2020 21:00	-0.1	12.5	2,112.6	0.1	0.6	1	1	1
12/17/2020 22:00	-0.1	12.7	2,078.4	0.1	0.6	1	1	1
12/17/2020 23:00	-0.1	12.8	2,052.8	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.0	1,934.9	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.1	12.4	1,637.6	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,113.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2020 00:00	-0.1	12.8	2,060.5	0.1	0.6	1	1	1
12/18/2020 01:00	-0.1	13.2	1,956.3	0.1	0.6	1	1	1
12/18/2020 02:00	0.4	13.9	1,694.8	0.4	0.5	1	1	0
12/18/2020 03:00	0.4	13.9	1,467.8	0.4	0.4	1	1	0
12/18/2020 04:00	0.2	13.8	1,689.6	0.4	0.5	1	1	1
12/18/2020 05:00	-0.1	13.1	1,977.9	0.1	0.6	1	1	1
12/18/2020 06:00	-0.1	12.5	2,121.0	0.1	0.6	1	1	1
12/18/2020 07:00	-0.1	12.6	2,109.8	0.1	0.6	1	1	1
12/18/2020 08:00	-0.1	13.2	1,944.1	0.1	0.6	1	1	1
12/18/2020 09:00	0.4	13.9	1,698.5	0.4	0.5	1	1	0
12/18/2020 10:00	0.4	13.9	1,560.0	0.4	0.5	1	1	0
12/18/2020 11:00	0.4	14.0	1,405.1	0.4	0.4	1	1	0
12/18/2020 12:00	0.4	13.9	1,499.7	0.4	0.4	1	1	0
12/18/2020 13:00	0.4	13.9	1,596.7	0.4	0.5	1	1	0
12/18/2020 14:00	0.4	14.0	1,410.7	0.4	0.4	1	1	0
12/18/2020 15:00	0.4	14.0	1,430.1	0.4	0.4	1	1	0
12/18/2020 16:00	0.1	13.4	1,859.6	0.2	0.6	1	1	1
12/18/2020 17:00	0.1	12.3	2,145.7	0.2	0.6	1	1	1
12/18/2020 18:00	0.1	12.1	2,195.2	0.2	0.7	1	1	1
12/18/2020 19:00	0.1	12.1	2,202.0	0.2	0.7	1	1	1
12/18/2020 20:00	0.1	12.2	2,186.5	0.2	0.7	1	1	1
12/18/2020 21:00	0.1	12.3	2,161.8	0.2	0.6	1	1	1
12/18/2020 22:00	-0.1	12.6	2,114.9	0.1	0.6	1	1	1
12/18/2020 23:00	-0.1	12.8	2,056.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,856.0	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.1	12.1	1,405.1	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,202.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2020 00:00	-0.1	12.9	2,046.4	0.1	0.6	1	1	1
12/19/2020 01:00	-0.1	13.0	1,996.8	0.1	0.6	1	1	1
12/19/2020 02:00	0.4	13.8	1,649.9	0.4	0.5	1	1	0
12/19/2020 03:00	0.4	13.9	1,546.5	0.4	0.5	1	1	0
12/19/2020 04:00	0.1	13.5	1,863.9	0.2	0.6	1	1	1
12/19/2020 05:00	-0.1	12.8	2,071.0	0.1	0.6	1	1	1
12/19/2020 06:00	-0.1	13.0	2,006.2	0.1	0.6	1	1	1
12/19/2020 07:00	0.4	13.8	1,669.1	0.4	0.5	1	1	0
12/19/2020 08:00	0.4	13.8	1,584.7	0.4	0.5	1	1	0
12/19/2020 09:00	0.4	13.8	1,629.3	0.4	0.5	1	1	0
12/19/2020 10:00	0.4	13.8	1,694.1	0.4	0.5	1	1	0
12/19/2020 11:00	0.4	13.9	1,703.6	0.4	0.5	1	1	0
12/19/2020 12:00	0.4	13.9	1,705.0	0.4	0.5	1	1	0
12/19/2020 13:00	0.4	13.9	1,694.8	0.4	0.5	1	1	0
12/19/2020 14:00	0.4	13.9	1,703.9	0.4	0.5	1	1	0
12/19/2020 15:00	0.2	13.7	1,760.6	0.4	0.5	1	1	1
12/19/2020 16:00	-0.1	12.7	2,047.2	0.1	0.6	1	1	1
12/19/2020 17:00	-0.1	12.5	2,112.1	0.1	0.6	1	1	1
12/19/2020 18:00	0.1	12.2	2,168.6	0.2	0.7	1	1	1
12/19/2020 19:00	0.1	12.2	2,183.5	0.2	0.7	1	1	1
12/19/2020 20:00	0.1	12.3	2,153.8	0.2	0.6	1	1	1
12/19/2020 21:00	0.1	12.5	2,119.8	0.2	0.6	1	1	1
12/19/2020 22:00	0.1	12.7	2,068.5	0.2	0.6	1	1	1
12/19/2020 23:00	-0.1	13.0	2,001.6	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,882.5	0.3	0.6	24 #	24 #	14 #
Minimum:	-0.1	12.2	1,546.5	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,183.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2020 00:00	-0.1	13.1	1,967.3	0.1	0.6	1	1	1
12/20/2020 01:00	0.4	13.9	1,654.5	0.4	0.5	1	1	0
12/20/2020 02:00	0.4	13.9	1,544.0	0.4	0.5	1	1	0
12/20/2020 03:00	0.4	13.9	1,373.6	0.4	0.4	1	1	0
12/20/2020 04:00	0.4	13.8	1,570.8	0.4	0.5	1	1	0
12/20/2020 05:00	0.1	13.5	1,848.0	0.2	0.6	1	1	1
12/20/2020 06:00	0.1	13.4	1,881.2	0.2	0.6	1	1	1
12/20/2020 07:00	0.4	13.8	1,695.8	0.4	0.5	1	1	0
12/20/2020 08:00	0.4	13.8	1,672.4	0.4	0.5	1	1	0
12/20/2020 09:00	0.4	13.8	1,690.2	0.4	0.5	1	1	0
12/20/2020 10:00	0.4	13.8	1,690.4	0.4	0.5	1	1	0
12/20/2020 11:00	0.4	13.9	1,689.4	0.4	0.5	1	1	0
12/20/2020 12:00	0.4	13.9	1,698.6	0.4	0.5	1	1	0
12/20/2020 13:00	0.4	13.9	1,680.8	0.4	0.5	1	1	0
12/20/2020 14:00	0.4	13.9	1,620.0	0.4	0.5	1	1	0
12/20/2020 15:00	0.2	13.7	1,701.9	0.4	0.5	1	1	1
12/20/2020 16:00	-0.1	12.8	2,019.1	0.1	0.6	1	1	1
12/20/2020 17:00	-0.1	12.4	2,102.7	0.2	0.6	1	1	1
12/20/2020 18:00	0.1	12.4	2,118.0	0.2	0.6	1	1	1
12/20/2020 19:00	0.1	12.4	2,120.9	0.2	0.6	1	1	1
12/20/2020 20:00	0.1	12.2	2,153.0	0.2	0.6	1	1	1
12/20/2020 21:00	0.1	12.4	2,103.0	0.2	0.6	1	1	1
12/20/2020 22:00	-0.1	12.5	2,092.3	0.1	0.6	1	1	1
12/20/2020 23:00	-0.1	12.8	2,037.5	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,821.9	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.1	12.2	1,373.6	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,153.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	VOC, Ppm	O2, Dry, Pct	HI, MBtuPerHr	VOC, Ppmvdc	VOC, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	-0.1	13.2	1,928.9	0.1	0.6	1	1	1
12/21/2020 01:00	0.4	13.8	1,665.1	0.4	0.5	1	1	0
12/21/2020 02:00	0.4	13.8	1,601.8	0.4	0.5	1	1	0
12/21/2020 03:00	0.4	13.8	1,550.2	0.4	0.5	1	1	0
12/21/2020 04:00	-0.1	13.5	1,855.9	0.1	0.6	1	1	1
12/21/2020 05:00	-0.2	12.8	2,073.0	0.1	0.6	1	1	1
12/21/2020 06:00	-0.1	12.7	2,088.8	0.1	0.6	1	1	1
12/21/2020 07:00	-0.1	12.7	2,092.5	0.1	0.6	1	1	1
12/21/2020 08:00	-0.1	13.0	2,002.1	0.1	0.6	1	1	1
12/21/2020 09:00	0.4	13.8	1,681.8	0.4	0.5	1	1	0
12/21/2020 10:00	0.4	13.8	1,690.7	0.4	0.5	1	1	0
12/21/2020 11:00	0.4	13.8	1,690.4	0.4	0.5	1	1	0
12/21/2020 12:00	0.4	13.8	1,680.4	0.4	0.5	1	1	0
12/21/2020 13:00	0.4	13.8	1,689.3	0.4	0.5	1	1	0
12/21/2020 14:00	0.4	13.9	1,682.8	0.4	0.5	1	1	0
12/21/2020 15:00	0.1	13.5	1,810.1	0.2	0.5	1	1	1
12/21/2020 16:00	-0.1	12.6	2,076.7	0.1	0.6	1	1	1
12/21/2020 17:00	-0.1	12.5	2,092.6	0.1	0.6	1	1	1
12/21/2020 18:00	-0.1	12.4	2,141.3	0.2	0.6	1	1	1
12/21/2020 19:00	-0.1	12.5	2,119.8	0.1	0.6	1	1	1
12/21/2020 20:00	-0.1	12.6	2,090.8	0.1	0.6	1	1	1
12/21/2020 21:00	-0.1	12.7	2,067.4	0.1	0.6	1	1	1
12/21/2020 22:00	-0.1	12.7	2,065.7	0.1	0.6	1	1	1
12/21/2020 23:00	-0.1	12.9	2,022.9	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,894.2	0.2	0.6	24 #	24 #	15 #
Minimum:	-0.2	12.4	1,550.2	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,141.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2020 00:00	-0.2	13.2	1,944.2	-0.1	0.6	1	1	1
12/22/2020 01:00	0.4	13.8	1,654.9	0.4	0.5	1	1	0
12/22/2020 02:00	0.4	13.8	1,539.7	0.4	0.5	1	1	0
12/22/2020 03:00	0.4	13.8	1,519.5	0.4	0.5	1	1	0
12/22/2020 04:00	0.1	13.7	1,715.0	0.2	0.5	1	1	1
12/22/2020 05:00	-0.2	12.9	2,044.5	0.1	0.6	1	1	1
12/22/2020 06:00	-0.2	12.7	2,071.3	0.1	0.6	1	1	1
12/22/2020 07:00	-0.1	12.5	2,123.3	0.1	0.6	1	1	1
12/22/2020 08:00	0.2	13.6	1,722.7	0.4	0.5	1	1	1
12/22/2020 09:00	0.4	13.8	1,611.8	0.4	0.5	1	1	0
12/22/2020 10:00	0.4	13.9	1,691.1	0.4	0.5	1	1	0
12/22/2020 11:00	0.4	13.9	1,630.8	0.4	0.5	1	1	0
12/22/2020 12:00	0.4	13.9	1,585.7	0.4	0.5	1	1	0
12/22/2020 13:00	0.4	13.9	1,651.0	0.4	0.5	1	1	0
12/22/2020 14:00	0.4	13.9	1,685.0	0.4	0.5	1	1	0
12/22/2020 15:00	0.2	13.8	1,697.0	0.4	0.5	1	1	1
12/22/2020 16:00	-0.1	12.9	2,003.8	0.1	0.6	1	1	1
12/22/2020 17:00	0.1	12.5	2,104.5	0.2	0.6	1	1	1
12/22/2020 18:00	0.1	12.4	2,122.2	0.2	0.6	1	1	1
12/22/2020 19:00	0.1	12.4	2,125.2	0.2	0.6	1	1	1
12/22/2020 20:00	0.1	12.4	2,135.4	0.2	0.6	1	1	1
12/22/2020 21:00	0.1	12.5	2,104.4	0.2	0.6	1	1	1
12/22/2020 22:00	0.1	12.6	2,087.9	0.2	0.6	1	1	1
12/22/2020 23:00	-0.1	12.8	2,061.4	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,859.7	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.2	12.4	1,519.5	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,135.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2020 00:00	-0.1	12.9	1,993.7	0.1	0.6	1	1	1
12/23/2020 01:00	0.4	13.9	1,699.9	0.4	0.5	1	1	0
12/23/2020 02:00	0.1	13.5	1,835.5	0.2	0.6	1	1	1
12/23/2020 03:00	-0.1	13.2	1,955.2	0.1	0.6	1	1	1
12/23/2020 04:00	-0.1	12.9	1,998.6	0.1	0.6	1	1	1
12/23/2020 05:00	0.4	13.9	1,692.0	0.4	0.5	1	1	0
12/23/2020 06:00	0.1	13.3	1,833.8	0.2	0.6	1	1	1
12/23/2020 07:00	-0.1	12.6	2,092.0	0.1	0.6	1	1	1
12/23/2020 08:00	0.1	12.6	2,079.8	0.2	0.6	1	1	1
12/23/2020 09:00	0.1	12.9	1,990.0	0.2	0.6	1	1	1
12/23/2020 10:00	0.4	13.9	1,674.9	0.4	0.5	1	1	0
12/23/2020 11:00	0.4	14.0	1,617.6	0.4	0.5	1	1	0
12/23/2020 12:00	0.4	14.0	1,657.1	0.4	0.5	1	1	0
12/23/2020 13:00	0.4	14.0	1,685.4	0.4	0.5	1	1	0
12/23/2020 14:00	0.4	14.0	1,687.4	0.4	0.5	1	1	0
12/23/2020 15:00	0.2	13.8	1,671.8	0.4	0.5	1	1	1
12/23/2020 16:00	-0.1	12.6	2,069.0	0.1	0.6	1	1	1
12/23/2020 17:00	0.1	12.1	2,196.0	0.2	0.7	1	1	1
12/23/2020 18:00	0.1	12.0	2,217.8	0.2	0.7	1	1	1
12/23/2020 19:00	0.1	12.0	2,222.9	0.2	0.7	1	1	1
12/23/2020 20:00	0.1	12.1	2,223.4	0.2	0.7	1	1	1
12/23/2020 21:00	-0.1	12.5	2,102.1	0.1	0.6	1	1	1
12/23/2020 22:00	-0.1	12.6	2,111.4	0.1	0.6	1	1	1
12/23/2020 23:00	-0.1	12.7	2,096.5	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,933.5	0.2	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.0	1,617.6	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,223.4	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2020 00:00	-0.1	12.9	2,051.2	0.1	0.6	1	1	1
12/24/2020 01:00	-0.1	13.2	1,978.3	0.1	0.6	1	1	1
12/24/2020 02:00	0.4	13.8	1,747.0	0.4	0.5	1	1	0
12/24/2020 03:00	0.1	13.5	1,844.1	0.2	0.6	1	1	1
12/24/2020 04:00	-0.1	13.3	1,949.1	0.1	0.6	1	1	1
12/24/2020 05:00	-0.1	13.2	1,954.0	0.1	0.6	1	1	1
12/24/2020 06:00	0.4	13.8	1,703.4	0.4	0.5	1	1	0
12/24/2020 07:00	0.4	13.8	1,693.7	0.4	0.5	1	1	0
12/24/2020 08:00	0.4	13.8	1,689.7	0.4	0.5	1	1	0
12/24/2020 09:00	-0.1	13.3	1,937.8	0.1	0.6	1	1	1
12/24/2020 10:00	-0.1	12.9	2,006.5	0.1	0.6	1	1	1
12/24/2020 11:00	0.4	13.9	1,642.4	0.4	0.5	1	1	0
12/24/2020 12:00	0.4	13.9	1,641.4	0.4	0.5	1	1	0
12/24/2020 13:00	0.4	13.9	1,670.1	0.4	0.5	1	1	0
12/24/2020 14:00	0.4	13.9	1,692.8	0.4	0.5	1	1	0
12/24/2020 15:00	0.1	13.5	1,806.6	0.2	0.5	1	1	1
12/24/2020 16:00	-0.1	12.7	2,053.1	0.1	0.6	1	1	1
12/24/2020 17:00	-0.1	12.5	2,116.6	0.1	0.6	1	1	1
12/24/2020 18:00	0.1	12.4	2,142.9	0.2	0.6	1	1	1
12/24/2020 19:00	0.1	12.4	2,139.8	0.2	0.6	1	1	1
12/24/2020 20:00	0.1	12.3	2,157.7	0.2	0.6	1	1	1
12/24/2020 21:00	-0.1	12.5	2,113.2	0.1	0.6	1	1	1
12/24/2020 22:00	-0.1	12.5	2,133.4	0.1	0.6	1	1	1
12/24/2020 23:00	-0.1	12.7	2,082.7	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.2	1,914.5	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.1	12.3	1,641.4	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,157.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2020 00:00	-0.1	12.7	2,065.4	0.1	0.6	1	1	1
12/25/2020 01:00	-0.1	12.7	2,060.2	0.1	0.6	1	1	1
12/25/2020 02:00	-0.1	12.8	2,005.4	0.1	0.6	1	1	1
12/25/2020 03:00	0.4	13.8	1,696.4	0.4	0.5	1	1	0
12/25/2020 04:00	0.1	13.5	1,836.1	0.2	0.6	1	1	1
12/25/2020 05:00	-0.1	12.8	2,046.1	0.1	0.6	1	1	1
12/25/2020 06:00	-0.1	12.9	2,020.5	0.1	0.6	1	1	1
12/25/2020 07:00	0.4	13.8	1,657.6	0.4	0.5	1	1	0
12/25/2020 08:00	0.4	13.8	1,622.8	0.4	0.5	1	1	0
12/25/2020 09:00	0.4	13.8	1,620.7	0.4	0.5	1	1	0
12/25/2020 10:00	0.4	13.8	1,597.4	0.4	0.5	1	1	0
12/25/2020 11:00	0.4	13.8	1,680.1	0.4	0.5	1	1	0
12/25/2020 12:00	0.4	13.8	1,684.2	0.4	0.5	1	1	0
12/25/2020 13:00	0.4	13.8	1,681.5	0.4	0.5	1	1	0
12/25/2020 14:00	0.4	13.8	1,636.4	0.4	0.5	1	1	0
12/25/2020 15:00	0.2	13.8	1,728.5	0.4	0.5	1	1	1
12/25/2020 16:00	-0.2	12.8	2,021.9	0.1	0.6	1	1	1
12/25/2020 17:00	-0.1	12.5	2,071.8	0.1	0.6	1	1	1
12/25/2020 18:00	-0.1	12.6	2,042.2	0.1	0.6	1	1	1
12/25/2020 19:00	-0.1	12.4	2,080.7	0.2	0.6	1	1	1
12/25/2020 20:00	-0.1	13.0	1,938.1	0.1	0.6	1	1	1
12/25/2020 21:00	0.4	13.8	1,700.8	0.4	0.5	1	1	0
12/25/2020 22:00	0.1	13.5	1,818.3	0.2	0.5	1	1	1
12/25/2020 23:00	-0.1	13.1	1,942.2	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.3	1,844.0	0.3	0.6	24 #	24 #	14 #
Minimum:	-0.2	12.4	1,597.4	0.1	0.5	1	1	0
Maximum:	0.4	13.8	2,080.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2020 00:00	-0.1	12.7	2,023.3	0.1	0.6	1	1	1
12/26/2020 01:00	-0.1	13.1	1,915.7	0.1	0.6	1	1	1
12/26/2020 02:00	0.4	13.8	1,691.0	0.4	0.5	1	1	0
12/26/2020 03:00	0.2	13.7	1,766.8	0.4	0.5	1	1	1
12/26/2020 04:00	-0.1	12.7	2,028.1	0.1	0.6	1	1	1
12/26/2020 05:00	-0.1	13.0	1,943.7	0.1	0.6	1	1	1
12/26/2020 06:00	0.4	13.9	1,697.0	0.4	0.5	1	1	0
12/26/2020 07:00	0.4	13.9	1,660.9	0.4	0.5	1	1	0
12/26/2020 08:00	0.4	13.9	1,609.1	0.4	0.5	1	1	0
12/26/2020 09:00	0.4	13.9	1,665.9	0.4	0.5	1	1	0
12/26/2020 10:00	0.4	13.9	1,566.2	0.4	0.5	1	1	0
12/26/2020 11:00	0.4	13.9	1,456.1	0.4	0.4	1	1	0
12/26/2020 12:00	0.4	13.9	1,580.6	0.4	0.5	1	1	0
12/26/2020 13:00	0.4	13.9	1,694.4	0.4	0.5	1	1	0
12/26/2020 14:00	0.4	13.9	1,668.8	0.4	0.5	1	1	0
12/26/2020 15:00	0.4	13.9	1,580.4	0.4	0.5	1	1	0
12/26/2020 16:00	0.2	13.7	1,686.2	0.4	0.5	1	1	1
12/26/2020 17:00	-0.1	12.7	2,041.2	0.1	0.6	1	1	1
12/26/2020 18:00	-0.1	13.0	1,980.8	0.1	0.6	1	1	1
12/26/2020 19:00	-0.1	12.7	2,049.7	0.1	0.6	1	1	1
12/26/2020 20:00	-0.1	12.7	2,061.0	0.1	0.6	1	1	1
12/26/2020 21:00	-0.1	12.7	2,046.7	0.1	0.6	1	1	1
12/26/2020 22:00	-0.1	12.6	2,070.7	0.1	0.6	1	1	1
12/26/2020 23:00	-0.1	12.8	2,044.8	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,813.7	0.3	0.5	24 #	24 #	13 #
Minimum:	-0.1	12.6	1,456.1	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,070.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2020 00:00	-0.1	12.8	2,042.5	0.1	0.6	1	1	1
12/27/2020 01:00	-0.1	12.8	2,034.8	0.1	0.6	1	1	1
12/27/2020 02:00	-0.2	13.2	1,922.2	-0.1	0.6	1	1	1
12/27/2020 03:00	0.4	13.9	1,699.5	0.4	0.5	1	1	0
12/27/2020 04:00	0.2	13.7	1,724.1	0.4	0.5	1	1	1
12/27/2020 05:00	-0.1	12.7	2,045.8	0.1	0.6	1	1	1
12/27/2020 06:00	-0.1	12.8	2,041.2	0.1	0.6	1	1	1
12/27/2020 07:00	0.4	13.8	1,687.8	0.4	0.5	1	1	1
12/27/2020 08:00	0.4	13.9	1,686.7	0.4	0.5	1	1	0
12/27/2020 09:00	0.4	13.8	1,657.2	0.4	0.5	1	1	0
12/27/2020 10:00	0.4	13.9	1,607.2	0.4	0.5	1	1	0
12/27/2020 11:00	0.4	13.9	1,640.6	0.4	0.5	1	1	0
12/27/2020 12:00	0.4	13.9	1,688.8	0.4	0.5	1	1	0
12/27/2020 13:00	0.4	13.9	1,610.7	0.4	0.5	1	1	0
12/27/2020 14:00	0.4	13.9	1,689.7	0.4	0.5	1	1	0
12/27/2020 15:00	0.2	13.7	1,725.7	0.4	0.5	1	1	1
12/27/2020 16:00	-0.2	12.7	2,059.0	0.1	0.6	1	1	1
12/27/2020 17:00	-0.1	12.4	2,129.0	0.2	0.6	1	1	1
12/27/2020 18:00	-0.1	12.3	2,142.0	0.2	0.6	1	1	1
12/27/2020 19:00	0.1	12.0	2,193.5	0.2	0.7	1	1	1
12/27/2020 20:00	0.1	12.3	2,090.1	0.2	0.6	1	1	1
12/27/2020 21:00	0.4	13.9	1,701.7	0.4	0.5	1	1	0
12/27/2020 22:00	0.1	13.4	1,846.1	0.2	0.6	1	1	1
12/27/2020 23:00	0.1	12.5	2,082.5	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,864.5	0.3	0.6	24 #	24 #	15 #
Minimum:	-0.2	12.0	1,607.2	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,193.5	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2020 00:00	-0.1	12.9	1,972.7	0.1	0.6	1	1	1
12/28/2020 01:00	0.4	13.9	1,650.3	0.4	0.5	1	1	0
12/28/2020 02:00	0.1	13.4	1,841.9	0.2	0.6	1	1	1
12/28/2020 03:00	-0.1	12.6	2,036.9	0.1	0.6	1	1	1
12/28/2020 04:00	-0.1	13.0	1,928.0	0.1	0.6	1	1	1
12/28/2020 05:00	0.4	13.9	1,703.3	0.4	0.5	1	1	0
12/28/2020 06:00	-0.1	13.2	1,835.1	0.1	0.6	1	1	1
12/28/2020 07:00	0.1	12.2	2,161.4	0.2	0.6	1	1	1
12/28/2020 08:00	0.1	12.3	2,134.6	0.2	0.6	1	1	1
12/28/2020 09:00	-0.1	12.8	2,000.0	0.1	0.6	1	1	1
12/28/2020 10:00	0.4	13.9	1,662.9	0.4	0.5	1	1	0
12/28/2020 11:00	0.4	13.9	1,676.9	0.4	0.5	1	1	0
12/28/2020 12:00	0.4	13.9	1,694.7	0.4	0.5	1	1	0
12/28/2020 13:00	0.4	13.9	1,673.6	0.4	0.5	1	1	0
12/28/2020 14:00	0.4	13.9	1,694.0	0.4	0.5	1	1	0
12/28/2020 15:00	0.2	13.5	1,773.6	0.4	0.5	1	1	1
12/28/2020 16:00	-0.1	12.7	2,020.7	0.1	0.6	1	1	1
12/28/2020 17:00	0.1	12.0	2,195.4	0.2	0.7	1	1	1
12/28/2020 18:00	0.1	12.0	2,197.0	0.2	0.7	1	1	1
12/28/2020 19:00	0.1	12.0	2,202.8	0.2	0.7	1	1	1
12/28/2020 20:00	0.1	12.0	2,200.8	0.2	0.7	1	1	1
12/28/2020 21:00	0.1	12.1	2,184.9	0.2	0.7	1	1	1
12/28/2020 22:00	0.1	12.2	2,159.8	0.2	0.6	1	1	1
12/28/2020 23:00	0.1	12.4	2,112.0	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.9	1,946.4	0.2	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.0	1,650.3	0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,202.8	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2020 00:00	0.1	12.5	2,106.8	0.2	0.6	1	1	1
12/29/2020 01:00	0.1	12.6	2,041.2	0.2	0.6	1	1	1
12/29/2020 02:00	0.4	13.9	1,706.4	0.4	0.5	1	1	0
12/29/2020 03:00	0.1	13.5	1,837.2	0.2	0.6	1	1	1
12/29/2020 04:00	-0.1	12.6	2,096.6	0.1	0.6	1	1	1
12/29/2020 05:00	-0.1	12.5	2,115.5	0.1	0.6	1	1	1
12/29/2020 06:00	0.1	12.1	2,212.1	0.2	0.7	1	1	1
12/29/2020 07:00	0.1	12.2	2,182.9	0.2	0.7	1	1	1
12/29/2020 08:00	0.1	12.3	2,161.5	0.2	0.6	1	1	1
12/29/2020 09:00	0.2	13.4	1,790.9	0.4	0.5	1	1	1
12/29/2020 10:00	0.4	13.9	1,683.9	0.4	0.5	1	1	0
12/29/2020 11:00	0.4	13.9	1,669.1	0.4	0.5	1	1	0
12/29/2020 12:00	0.4	13.9	1,694.9	0.4	0.5	1	1	0
12/29/2020 13:00	0.4	14.0	1,649.5	0.4	0.5	1	1	0
12/29/2020 14:00	0.4	14.0	1,679.9	0.4	0.5	1	1	0
12/29/2020 15:00	0.4	14.0	1,673.6	0.4	0.5	1	1	0
12/29/2020 16:00	0.2	13.8	1,698.0	0.4	0.5	1	1	1
12/29/2020 17:00	-0.1	12.4	2,122.8	0.2	0.6	1	1	1
12/29/2020 18:00	0.1	12.0	2,201.4	0.2	0.7	1	1	1
12/29/2020 19:00	0.1	12.0	2,200.4	0.2	0.7	1	1	1
12/29/2020 20:00	0.1	12.4	2,128.6	0.2	0.6	1	1	1
12/29/2020 21:00	0.1	12.6	2,073.1	0.2	0.6	1	1	1
12/29/2020 22:00	0.1	12.6	2,078.1	0.2	0.6	1	1	1
12/29/2020 23:00	-0.1	12.8	2,038.4	0.1	0.6	1	1	1
Average/Sum#:	0.2	13.0	1,951.8	0.3	0.6	24 #	24 #	17 #
Minimum:	-0.1	12.0	1,649.5	0.1	0.5	1	1	0
Maximum:	0.4	14.0	2,212.1	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2020 00:00	-0.1	12.9	2,032.1	0.1	0.6	1	1	1
12/30/2020 01:00	-0.1	13.3	1,929.1	0.1	0.6	1	1	1
12/30/2020 02:00	0.4	13.9	1,692.9	0.4	0.5	1	1	0
12/30/2020 03:00	0.2	13.7	1,722.2	0.4	0.5	1	1	1
12/30/2020 04:00	0.1	13.1	2,016.7	0.2	0.6	1	1	1
12/30/2020 05:00	-0.1	12.9	2,046.3	0.1	0.6	1	1	1
12/30/2020 06:00	-0.1	12.4	2,160.1	0.2	0.6	1	1	1
12/30/2020 07:00	-0.1	12.8	2,068.2	0.1	0.6	1	1	1
12/30/2020 08:00	-0.1	13.0	2,029.7	0.1	0.6	1	1	1
12/30/2020 09:00	-0.2	13.2	1,945.2	-0.1	0.6	1	1	1
12/30/2020 10:00	0.4	13.8	1,705.8	0.4	0.5	1	1	0
12/30/2020 11:00	0.4	13.9	1,693.0	0.4	0.5	1	1	0
12/30/2020 12:00	0.4	13.9	1,689.5	0.4	0.5	1	1	0
12/30/2020 13:00	0.4	13.9	1,647.2	0.4	0.5	1	1	0
12/30/2020 14:00	0.4	13.9	1,645.9	0.4	0.5	1	1	0
12/30/2020 15:00	0.1	13.7	1,721.3	0.2	0.5	1	1	1
12/30/2020 16:00	-0.2	12.9	2,020.7	0.1	0.6	1	1	1
12/30/2020 17:00	-0.1	12.4	2,112.9	0.2	0.6	1	1	1
12/30/2020 18:00	-0.1	12.4	2,102.7	0.2	0.6	1	1	1
12/30/2020 19:00	-0.1	12.7	2,045.4	0.1	0.6	1	1	1
12/30/2020 20:00	-0.1	12.6	2,063.7	0.1	0.6	1	1	1
12/30/2020 21:00	-0.1	12.6	2,055.0	0.1	0.6	1	1	1
12/30/2020 22:00	-0.1	12.7	2,032.2	0.1	0.6	1	1	1
12/30/2020 23:00	-0.1	12.8	2,021.0	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.1	1,925.0	0.2	0.6	24 #	24 #	18 #
Minimum:	-0.2	12.4	1,645.9	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,160.1	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:38 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2020 00:00	-0.2	13.2	1,919.8	-0.1	0.6	1	1	1
12/31/2020 01:00	0.4	13.8	1,625.6	0.4	0.5	1	1	0
12/31/2020 02:00	0.1	13.5	1,823.7	0.2	0.5	1	1	1
12/31/2020 03:00	-0.2	13.2	1,946.0	-0.1	0.6	1	1	1
12/31/2020 04:00	-0.2	13.2	1,929.3	-0.1	0.6	1	1	1
12/31/2020 05:00	0.4	13.8	1,696.0	0.4	0.5	1	1	0
12/31/2020 06:00	0.4	13.8	1,691.7	0.4	0.5	1	1	0
12/31/2020 07:00	0.4	13.8	1,646.2	0.4	0.5	1	1	0
12/31/2020 08:00	0.4	13.8	1,598.0	0.4	0.5	1	1	0
12/31/2020 09:00	0.4	13.8	1,664.9	0.4	0.5	1	1	0
12/31/2020 10:00	0.4	13.9	1,689.3	0.4	0.5	1	1	0
12/31/2020 11:00	0.4	13.9	1,686.4	0.4	0.5	1	1	0
12/31/2020 12:00	0.4	13.9	1,652.5	0.4	0.5	1	1	0
12/31/2020 13:00	0.4	13.9	1,645.1	0.4	0.5	1	1	0
12/31/2020 14:00	0.4	13.9	1,652.9	0.4	0.5	1	1	0
12/31/2020 15:00	0.4	13.9	1,701.0	0.4	0.5	1	1	0
12/31/2020 16:00	0.1	13.4	1,822.2	0.2	0.5	1	1	1
12/31/2020 17:00	-0.1	12.6	2,061.0	0.1	0.6	1	1	1
12/31/2020 18:00	0.1	12.4	2,100.4	0.2	0.6	1	1	1
12/31/2020 19:00	0.1	12.5	2,100.9	0.2	0.6	1	1	1
12/31/2020 20:00	0.1	12.5	2,100.4	0.2	0.6	1	1	1
12/31/2020 21:00	0.1	12.5	2,098.9	0.2	0.6	1	1	1
12/31/2020 22:00	0.1	12.6	2,097.5	0.2	0.6	1	1	1
12/31/2020 23:00	0.1	12.7	2,066.9	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.4	1,834.0	0.3	0.5	24 #	24 #	12 #
Minimum:	-0.2	12.4	1,598.0	-0.1	0.5	1	1	0
Maximum:	0.4	13.9	2,100.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:42 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D

Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:39 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,966.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 242.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,966.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:42 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,966.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 242.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,966.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:44 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D

Total Operating Time: 88.00 Day(s) **No Exclusions Allowed**

Non-Operating Time: 4.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**88.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:46 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 2,034.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 174.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,034.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:48 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 2,034.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 174.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,034.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:51 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D

Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2020 00:00	1.1	13.9	1,632.6	0.9	4.90	1	1	0
10/01/2020 01:00	1.2	13.3	1,798.6	0.9	5.40	1	1	1
10/01/2020 02:00	1.3	12.5	1,987.6	0.9	6.00	1	1	1
10/01/2020 03:00	1.2	12.3	1,996.0	0.8	6.00	1	1	1
10/01/2020 04:00	0.9	13.9	1,666.5	0.8	5.00	1	1	0
10/01/2020 05:00	1.3	13.0	1,822.9	1.0	7.30	1	1	1
10/01/2020 06:00	1.3	12.3	2,073.1	0.9	6.20	1	1	1
10/01/2020 07:00	1.2	13.1	1,809.7	0.9	5.40	1	1	1
10/01/2020 08:00	0.9	13.9	1,560.8	0.8	4.70	1	1	0
10/01/2020 09:00	0.7	14.1	1,327.1	0.6	2.70	1	1	0
10/01/2020 10:00	0.9	14.0	1,516.1	0.8	4.50	1	1	1
10/01/2020 11:00	1.4	12.3	2,062.7	1.0	8.30	1	1	1
10/01/2020 12:00	1.4	11.8	2,142.6	0.9	6.40	1	1	1
10/01/2020 13:00	1.4	11.6	2,180.8	0.9	6.50	1	1	1
10/01/2020 14:00	1.4	11.5	2,191.1	0.9	6.60	1	1	1
10/01/2020 15:00	1.4	11.6	2,163.3	0.9	6.50	1	1	1
10/01/2020 16:00	1.4	11.7	2,144.3	0.9	6.40	1	1	1
10/01/2020 17:00	1.4	11.7	2,138.3	0.9	6.40	1	1	1
10/01/2020 18:00	1.4	11.9	2,110.4	0.9	6.30	1	1	1
10/01/2020 19:00	1.4	11.9	2,114.7	0.9	6.30	1	1	1
10/01/2020 20:00	1.4	11.9	2,113.2	0.9	6.30	1	1	1
10/01/2020 21:00	1.4	11.9	2,119.0	0.9	6.40	1	1	1
10/01/2020 22:00	1.4	12.1	2,094.3	0.9	6.30	1	1	1
10/01/2020 23:00	1.3	12.4	2,011.9	0.9	6.00	1	1	1
Average/Sum#:	1.3	12.5	1,949.1	0.9	142.80 #	24 #	24 #	20 #
Minimum:	0.7	11.5	1,327.1	0.6	2.70	1	1	0
Maximum:	1.4	14.1	2,191.1	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2020 00:00	1.1	13.9	1,589.6	0.9	4.80	1	1	0
10/02/2020 01:00	1.1	13.9	1,707.3	0.9	5.10	1	1	0
10/02/2020 02:00	1.1	13.9	1,553.1	0.9	4.70	1	1	0
10/02/2020 03:00	1.1	13.9	1,596.2	0.9	4.80	1	1	0
10/02/2020 04:00	1.1	13.6	1,682.9	0.9	5.00	1	1	1
10/02/2020 05:00	1.2	12.3	2,058.4	0.8	6.20	1	1	1
10/02/2020 06:00	1.3	12.5	2,014.7	0.9	6.00	1	1	1
10/02/2020 07:00	1.1	13.8	1,771.1	0.9	5.30	1	1	0
10/02/2020 08:00	1.0	13.9	1,477.5	0.8	4.40	1	1	0
10/02/2020 09:00	1.1	14.0	1,595.2	0.9	4.80	1	1	0
10/02/2020 10:00	1.1	14.0	1,627.9	0.9	4.90	1	1	0
10/02/2020 11:00	1.1	13.6	1,694.5	0.9	5.10	1	1	1
10/02/2020 12:00	1.4	11.9	2,126.7	0.9	6.40	1	1	1
10/02/2020 13:00	1.4	11.5	2,205.8	0.9	6.60	1	1	1
10/02/2020 14:00	1.4	11.4	2,203.7	0.9	6.60	1	1	1
10/02/2020 15:00	1.4	11.5	2,182.9	0.9	6.50	1	1	1
10/02/2020 16:00	1.4	11.5	2,184.2	0.9	6.60	1	1	1
10/02/2020 17:00	1.4	11.4	2,193.0	0.9	6.60	1	1	1
10/02/2020 18:00	1.4	11.7	2,153.3	0.9	6.50	1	1	1
10/02/2020 19:00	1.4	11.8	2,130.0	0.9	6.40	1	1	1
10/02/2020 20:00	1.4	11.7	2,159.8	0.9	6.50	1	1	1
10/02/2020 21:00	1.3	12.2	2,074.6	0.9	6.20	1	1	1
10/02/2020 22:00	1.4	12.1	2,092.5	0.9	6.30	1	1	1
10/02/2020 23:00	1.4	12.0	2,105.5	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.7	1,924.2	0.9	138.60 #	24 #	24 #	16 #
Minimum:	1.0	11.4	1,477.5	0.8	4.40	1	1	0
Maximum:	1.4	14.0	2,205.8	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2020 00:00	2.0	14.0	1,271.8	1.7	3.80	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 08:00	17.8	18.1	388.1	37.5	19.83	1	0	0
10/03/2020 09:00	14.3	15.0	979.6	14.3	51.90	1	0	0
10/03/2020 10:00	0.7	14.0	1,391.9	0.6	2.80	1	1	0
10/03/2020 11:00	0.9	14.0	1,363.8	0.8	4.10	1	1	0
10/03/2020 12:00	1.5	13.9	1,608.4	1.3	8.00	1	1	0
10/03/2020 13:00	1.0	14.0	1,481.9	0.9	4.40	1	1	0
10/03/2020 14:00	1.1	13.9	1,640.7	0.9	4.90	1	1	0
10/03/2020 15:00	1.0	13.5	1,661.9	0.8	5.00	1	1	1
10/03/2020 16:00	1.4	11.8	2,108.5	0.9	6.30	1	1	1
10/03/2020 17:00	1.4	11.4	2,193.9	0.9	6.60	1	1	1
10/03/2020 18:00	1.4	11.5	2,181.0	0.9	6.50	1	1	1
10/03/2020 19:00	1.4	11.6	2,184.6	0.9	6.60	1	1	1
10/03/2020 20:00	1.4	11.9	2,117.9	0.9	6.40	1	1	1
10/03/2020 21:00	1.3	12.3	2,045.4	0.9	6.10	1	1	1
10/03/2020 22:00	1.9	13.8	1,460.5	1.6	6.60	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.2	13.4	1,630.0	4.1	149.83 #	16 #	12 #	9 #
Minimum:	0.7	11.4	388.1	0.6	2.80	0	0	0
Maximum:	17.8	18.1	2,193.9	37.5	51.90	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 09:00	26.3	16.9	544.9	38.8	74.01	1	0	0
10/04/2020 10:00	9.9	14.5	1,153.0	9.1	39.20	1	0	0
10/04/2020 11:00	0.8	14.0	1,372.4	0.7	4.10	1	1	0
10/04/2020 12:00	1.0	14.0	1,376.6	0.9	4.10	1	1	0
10/04/2020 13:00	1.6	13.9	1,610.8	1.3	8.10	1	1	0
10/04/2020 14:00	0.8	14.0	1,482.3	0.7	4.40	1	1	0
10/04/2020 15:00	1.1	13.8	1,712.8	0.9	5.10	1	1	0
10/04/2020 16:00	1.3	13.0	1,842.2	1.0	7.40	1	1	1
10/04/2020 17:00	1.4	11.8	2,123.7	0.9	6.40	1	1	1
10/04/2020 18:00	1.3	12.1	2,061.3	0.9	6.20	1	1	1
10/04/2020 19:00	1.3	12.2	2,055.2	0.9	6.20	1	1	1
10/04/2020 20:00	1.3	12.2	2,059.3	0.9	6.20	1	1	1
10/04/2020 21:00	1.4	12.1	2,086.7	0.9	6.30	1	1	1
10/04/2020 22:00	1.3	12.8	1,954.6	0.9	5.90	1	1	1
10/04/2020 23:00	1.3	12.9	1,923.1	1.0	7.70	1	1	1
Average/Sum#:	3.5	13.3	1,690.6	4.0	191.31 #	15 #	13 #	8 #
Minimum:	0.8	11.8	544.9	0.7	4.10	0	0	0
Maximum:	26.3	16.9	2,123.7	38.8	74.01	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2020 00:00	1.0	13.9	1,660.5	0.8	5.00	1	1	0
10/05/2020 01:00	1.1	13.9	1,650.0	0.9	5.00	1	1	0
10/05/2020 02:00	1.1	13.9	1,603.8	0.9	4.80	1	1	0
10/05/2020 03:00	1.0	14.0	1,580.0	0.9	4.70	1	1	0
10/05/2020 04:00	1.0	13.7	1,683.2	0.8	5.00	1	1	1
10/05/2020 05:00	1.3	12.3	2,061.7	0.9	6.20	1	1	1
10/05/2020 06:00	1.3	12.3	2,046.4	0.9	6.10	1	1	1
10/05/2020 07:00	1.0	13.9	1,551.7	0.8	4.70	1	1	0
10/05/2020 08:00	1.1	13.9	1,541.3	0.9	4.60	1	1	0
10/05/2020 09:00	1.1	14.0	1,597.6	0.9	4.80	1	1	0
10/05/2020 10:00	1.0	14.0	1,587.0	0.9	4.80	1	1	0
10/05/2020 11:00	1.0	13.9	1,651.5	0.8	5.00	1	1	0
10/05/2020 12:00	1.0	13.9	1,668.5	0.8	5.00	1	1	0
10/05/2020 13:00	1.2	13.2	1,816.3	0.9	5.40	1	1	1
10/05/2020 14:00	1.4	11.6	2,193.4	0.9	6.60	1	1	1
10/05/2020 15:00	1.4	11.4	2,208.7	0.9	6.60	1	1	1
10/05/2020 16:00	1.4	11.4	2,208.0	0.9	6.60	1	1	1
10/05/2020 17:00	1.4	11.6	2,183.1	0.9	6.50	1	1	1
10/05/2020 18:00	1.4	11.5	2,199.9	0.9	6.60	1	1	1
10/05/2020 19:00	1.4	12.1	2,079.1	0.9	6.20	1	1	1
10/05/2020 20:00	1.3	12.2	2,070.9	0.9	6.20	1	1	1
10/05/2020 21:00	1.3	12.2	2,075.3	0.9	6.20	1	1	1
10/05/2020 22:00	2.3	14.1	1,244.7	2.0	4.35	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.0	1,833.2	0.9	126.95 #	23 #	22 #	13 #
Minimum:	1.0	11.4	1,244.7	0.8	4.35	0	0	0
Maximum:	2.3	14.1	2,208.7	2.0	6.60	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 06:00	22.0	18.1	390.7	46.4	24.72	1	0	0
10/06/2020 07:00	14.5	15.8	831.8	16.8	51.60	1	0	0
10/06/2020 08:00	0.6	14.0	1,408.7	0.5	2.80	1	1	0
10/06/2020 09:00	0.9	14.0	1,385.6	0.8	4.20	1	1	0
10/06/2020 10:00	1.0	14.0	1,399.3	0.9	4.20	1	1	0
10/06/2020 11:00	0.9	14.0	1,640.7	0.8	4.90	1	1	0
10/06/2020 12:00	0.8	14.0	1,491.8	0.7	4.50	1	1	0
10/06/2020 13:00	1.1	13.9	1,653.6	0.9	5.00	1	1	0
10/06/2020 14:00	1.1	13.6	1,752.2	0.9	5.30	1	1	1
10/06/2020 15:00	1.4	11.8	2,133.8	0.9	6.40	1	1	1
10/06/2020 16:00	1.4	11.5	2,183.3	0.9	6.50	1	1	1
10/06/2020 17:00	1.4	11.4	2,200.7	0.9	6.60	1	1	1
10/06/2020 18:00	1.4	11.4	2,205.4	0.9	6.60	1	1	1
10/06/2020 19:00	1.4	11.6	2,175.9	0.9	6.50	1	1	1
10/06/2020 20:00	1.1	13.5	1,676.1	0.9	5.00	1	1	1
10/06/2020 21:00	1.2	13.2	1,824.6	0.9	5.50	1	1	1
10/06/2020 22:00	1.4	12.2	2,086.4	0.9	6.30	1	1	1
10/06/2020 23:00	1.3	12.6	1,996.7	0.9	6.00	1	1	1
Average/Sum#:	3.1	13.4	1,691.0	4.3	162.62 #	18 #	16 #	10 #
Minimum:	0.6	11.4	390.7	0.5	2.80	0	0	0
Maximum:	22.0	18.1	2,205.4	46.4	51.60	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2020 00:00	1.3	12.3	2,050.3	0.9	6.20	1	1	1
10/07/2020 01:00	1.3	12.6	1,980.4	0.9	5.90	1	1	1
10/07/2020 02:00	1.0	13.9	1,541.2	0.8	4.60	1	1	0
10/07/2020 03:00	0.9	14.0	1,606.7	0.8	4.80	1	1	0
10/07/2020 04:00	1.1	13.3	1,834.3	0.9	5.50	1	1	1
10/07/2020 05:00	1.4	12.0	2,118.8	0.9	6.40	1	1	1
10/07/2020 06:00	1.3	12.4	2,038.2	0.9	6.10	1	1	1
10/07/2020 07:00	1.1	13.9	1,602.9	0.9	4.80	1	1	0
10/07/2020 08:00	1.0	14.0	1,366.6	0.9	4.10	1	1	0
10/07/2020 09:00	0.9	14.0	1,301.4	0.8	3.90	1	1	0
10/07/2020 10:00	0.9	14.0	1,357.7	0.8	4.10	1	1	0
10/07/2020 11:00	1.2	13.3	1,796.0	0.9	5.40	1	1	1
10/07/2020 12:00	1.4	11.7	2,171.8	0.9	6.50	1	1	1
10/07/2020 13:00	1.4	11.5	2,183.5	0.9	6.60	1	1	1
10/07/2020 14:00	1.2	13.5	1,711.1	1.0	6.80	1	1	1
10/07/2020 15:00	1.2	13.1	1,798.7	0.9	5.40	1	1	1
10/07/2020 16:00	1.4	12.0	2,093.1	0.9	6.30	1	1	1
10/07/2020 17:00	1.4	11.6	2,163.2	0.9	6.50	1	1	1
10/07/2020 18:00	1.4	11.8	2,123.7	0.9	6.40	1	1	1
10/07/2020 19:00	1.3	12.1	2,052.4	0.9	6.20	1	1	1
10/07/2020 20:00	1.1	13.9	1,686.3	0.9	5.10	1	1	0
10/07/2020 21:00	1.2	13.2	1,827.0	0.9	5.50	1	1	1
10/07/2020 22:00	1.4	12.1	2,099.0	0.9	6.30	1	1	1
10/07/2020 23:00	2.2	14.0	1,254.1	1.9	4.22	1	0	1
Average/Sum#:	1.3	12.9	1,823.3	0.9	133.62 #	24 #	23 #	17 #
Minimum:	0.9	11.5	1,254.1	0.8	3.90	1	0	0
Maximum:	2.2	14.0	2,183.5	1.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2020 12:00	36.8	17.7	447.5	67.9	78.33	1	0	0
10/12/2020 13:00	25.9	15.7	746.4	29.4	80.60	1	0	0
10/12/2020 14:00	0.7	14.0	1,575.2	0.6	3.20	1	0	0
10/12/2020 15:00	1.0	13.7	1,668.7	0.8	5.00	1	1	1
10/12/2020 16:00	1.4	12.3	2,046.9	1.0	8.20	1	1	1
10/12/2020 17:00	1.3	12.4	2,032.4	0.9	6.10	1	1	1
10/12/2020 18:00	1.3	12.5	2,017.0	0.9	6.10	1	1	1
10/12/2020 19:00	1.3	12.7	1,949.5	0.9	5.80	1	1	1
10/12/2020 20:00	1.1	13.8	1,762.1	0.9	5.30	1	1	0
10/12/2020 21:00	1.2	13.3	1,825.5	0.9	5.50	1	1	1
10/12/2020 22:00	1.3	12.5	2,015.6	0.9	6.00	1	1	1
10/12/2020 23:00	1.3	12.7	1,971.8	0.9	5.90	1	1	1
Average/Sum#:	6.2	13.6	1,671.6	8.8	216.03 #	12 #	9 #	8 #
Minimum:	0.7	12.3	447.5	0.6	3.20	0	0	0
Maximum:	36.8	17.7	2,046.9	67.9	80.60	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2020 00:00	1.0	13.9	1,671.5	0.8	5.00	1	1	0
10/13/2020 01:00	1.1	13.9	1,624.8	0.9	4.90	1	1	0
10/13/2020 02:00	0.9	14.0	1,396.7	0.8	4.20	1	1	0
10/13/2020 03:00	0.9	14.0	1,603.9	0.8	4.80	1	1	0
10/13/2020 04:00	1.1	13.4	1,820.6	0.9	5.50	1	1	1
10/13/2020 05:00	1.2	12.7	2,000.2	0.9	6.00	1	1	1
10/13/2020 06:00	1.3	12.9	1,944.4	1.0	7.80	1	1	1
10/13/2020 07:00	1.1	13.9	1,653.3	0.9	5.00	1	1	0
10/13/2020 08:00	1.0	13.9	1,487.9	0.8	4.50	1	1	0
10/13/2020 09:00	0.8	14.0	1,351.7	0.7	4.10	1	1	0
10/13/2020 10:00	1.1	13.9	1,622.3	0.9	4.90	1	1	0
10/13/2020 11:00	1.1	13.9	1,501.7	0.9	4.50	1	1	0
10/13/2020 12:00	1.1	13.9	1,502.6	0.9	4.50	1	1	0
10/13/2020 13:00	0.9	14.0	1,407.8	0.8	4.20	1	1	0
10/13/2020 14:00	1.1	13.9	1,611.8	0.9	4.80	1	1	0
10/13/2020 15:00	1.1	13.6	1,663.6	0.9	5.00	1	1	1
10/13/2020 16:00	1.4	12.3	2,056.4	1.0	8.20	1	1	1
10/13/2020 17:00	1.3	12.2	2,073.0	0.9	6.20	1	1	1
10/13/2020 18:00	1.3	12.3	2,045.1	0.9	6.10	1	1	1
10/13/2020 19:00	1.3	12.6	1,974.4	0.9	5.90	1	1	1
10/13/2020 20:00	1.0	13.9	1,708.1	0.8	5.10	1	1	0
10/13/2020 21:00	1.2	13.4	1,822.4	0.9	5.50	1	1	1
10/13/2020 22:00	1.4	12.0	2,134.7	0.9	6.40	1	1	1
10/13/2020 23:00	1.3	12.7	1,961.5	0.9	5.90	1	1	1
Average/Sum#:	1.1	13.4	1,735.0	0.9	129.00 #	24 #	24 #	11 #
Minimum:	0.8	12.0	1,351.7	0.7	4.10	1	1	0
Maximum:	1.4	14.0	2,134.7	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2020 00:00	1.0	13.9	1,679.7	0.8	5.00	1	1	0
10/14/2020 01:00	1.1	13.7	1,681.9	0.9	5.00	1	1	1
10/14/2020 02:00	1.3	12.2	2,076.5	0.9	6.20	1	1	1
10/14/2020 03:00	1.3	12.7	1,951.4	0.9	5.90	1	1	1
10/14/2020 04:00	1.0	13.9	1,607.4	0.8	4.80	1	1	0
10/14/2020 05:00	1.3	13.0	1,827.4	1.0	7.30	1	1	1
10/14/2020 06:00	1.3	12.5	2,025.0	0.9	6.10	1	1	1
10/14/2020 07:00	0.0	0.0	1,931.7	0.0	0.00	1	1	1
10/14/2020 08:00	1.0	13.9	1,419.2	0.8	4.30	1	1	0
10/14/2020 09:00	0.9	14.0	1,311.0	0.8	3.90	1	1	0
10/14/2020 10:00	1.1	13.9	1,545.8	0.9	4.60	1	1	0
10/14/2020 11:00	1.4	12.3	1,786.5	1.0	7.10	1	1	1
10/14/2020 12:00	1.3	12.1	2,162.9	0.9	6.50	1	1	1
10/14/2020 13:00	1.4	11.5	2,210.4	0.9	6.60	1	1	1
10/14/2020 14:00	1.2	12.6	1,766.5	0.9	5.30	1	1	1
10/14/2020 15:00	1.3	12.5	1,842.7	0.9	5.50	1	1	1
10/14/2020 16:00	1.4	11.8	2,147.2	0.9	6.40	1	1	1
10/14/2020 17:00	1.5	11.4	2,222.3	0.9	6.70	1	1	1
10/14/2020 18:00	1.4	11.8	2,139.1	0.9	6.40	1	1	1
10/14/2020 19:00	1.4	11.9	2,089.3	0.9	6.30	1	1	1
10/14/2020 20:00	1.1	13.8	1,694.2	0.9	5.10	1	1	0
10/14/2020 21:00	1.2	13.1	1,854.6	0.9	5.60	1	1	1
10/14/2020 22:00	1.4	11.7	2,179.8	0.9	6.50	1	1	1
10/14/2020 23:00	1.4	12.4	2,016.1	1.0	8.10	1	1	1
Average/Sum#:	1.2	12.7	1,882.0	0.9	135.20 #	24 #	24 #	18 #
Minimum:	0.9	11.4	1,311.0	0.8	3.90	1	1	0
Maximum:	1.5	14.0	2,222.3	1.0	8.10	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2020 00:00	1.1	13.8	1,684.8	0.9	5.10	1	1	0
10/15/2020 01:00	1.2	13.3	1,820.4	0.9	5.50	1	1	1
10/15/2020 02:00	1.4	11.9	2,148.2	0.9	6.40	1	1	1
10/15/2020 03:00	1.4	12.0	2,097.9	0.9	6.30	1	1	1
10/15/2020 04:00	1.1	13.8	1,701.3	0.9	5.10	1	1	0
10/15/2020 05:00	1.4	12.9	1,839.4	1.0	7.40	1	1	1
10/15/2020 06:00	1.3	12.2	2,079.6	0.9	6.20	1	1	1
10/15/2020 07:00	1.3	12.7	1,868.9	0.9	5.60	1	1	1
10/15/2020 08:00	0.9	14.0	1,309.4	0.8	3.90	1	1	0
10/15/2020 09:00	0.9	14.0	1,305.4	0.8	3.90	1	1	0
10/15/2020 10:00	0.9	14.0	1,323.7	0.8	4.00	1	1	0
10/15/2020 11:00	1.1	13.8	1,576.9	0.9	4.70	1	1	0
10/15/2020 12:00	1.2	13.8	1,651.4	1.0	6.60	1	1	0
10/15/2020 13:00	1.2	13.1	1,832.0	0.9	5.50	1	1	1
10/15/2020 14:00	1.5	11.5	2,209.0	0.9	6.60	1	1	1
10/15/2020 15:00	1.5	11.4	2,223.9	0.9	6.70	1	1	1
10/15/2020 16:00	1.5	11.4	2,220.5	0.9	6.70	1	1	1
10/15/2020 17:00	1.5	11.5	2,198.0	0.9	6.60	1	1	1
10/15/2020 18:00	1.5	11.5	2,210.5	0.9	6.60	1	1	1
10/15/2020 19:00	1.5	11.6	2,184.8	1.0	8.70	1	1	1
10/15/2020 20:00	1.5	11.6	2,203.5	1.0	8.80	1	1	1
10/15/2020 21:00	1.5	11.5	2,223.1	0.9	6.70	1	1	1
10/15/2020 22:00	1.4	11.7	2,179.0	0.9	6.50	1	1	1
10/15/2020 23:00	1.4	12.2	2,052.8	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.6	1,922.7	0.9	146.30 #	24 #	24 #	17 #
Minimum:	0.9	11.4	1,305.4	0.8	3.90	1	1	0
Maximum:	1.5	14.0	2,223.9	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2020 00:00	1.1	13.8	1,715.7	0.9	5.10	1	1	0
10/16/2020 01:00	0.9	14.0	1,320.2	0.8	4.00	1	1	0
10/16/2020 02:00	1.1	13.8	1,694.2	0.9	5.10	1	1	0
10/16/2020 03:00	1.2	13.2	1,839.3	0.9	5.50	1	1	1
10/16/2020 04:00	1.3	12.7	1,907.8	0.9	5.70	1	1	1
10/16/2020 05:00	1.3	13.4	1,714.5	1.0	6.90	1	1	1
10/16/2020 06:00	1.3	12.1	2,073.6	0.9	6.20	1	1	1
10/16/2020 07:00	1.3	12.7	1,970.7	0.9	5.90	1	1	1
10/16/2020 08:00	1.1	13.8	1,609.8	0.9	4.80	1	1	0
10/16/2020 09:00	1.1	14.0	1,403.9	0.9	4.20	1	1	0
10/16/2020 10:00	1.1	14.0	1,520.0	0.9	4.60	1	1	0
10/16/2020 11:00	1.2	13.6	1,601.7	1.0	6.40	1	1	1
10/16/2020 12:00	1.4	11.8	2,142.8	0.9	6.40	1	1	1
10/16/2020 13:00	1.4	11.9	2,110.6	0.9	6.30	1	1	1
10/16/2020 14:00	1.4	11.6	2,173.1	0.9	6.50	1	1	1
10/16/2020 15:00	1.5	11.5	2,183.0	0.9	6.50	1	1	1
10/16/2020 16:00	1.4	11.9	2,090.6	0.9	6.30	1	1	1
10/16/2020 17:00	1.4	11.8	2,140.0	0.9	6.40	1	1	1
10/16/2020 18:00	1.4	11.9	2,130.2	0.9	6.40	1	1	1
10/16/2020 19:00	1.5	11.5	2,200.5	0.9	6.60	1	1	1
10/16/2020 20:00	1.4	11.6	2,168.2	0.9	6.50	1	1	1
10/16/2020 21:00	1.4	11.8	2,136.6	0.9	6.40	1	1	1
10/16/2020 22:00	1.4	12.1	2,086.7	0.9	6.30	1	1	1
10/16/2020 23:00	1.4	12.3	2,040.6	1.0	8.20	1	1	1
Average/Sum#:	1.3	12.6	1,915.6	0.9	143.20 #	24 #	24 #	18 #
Minimum:	0.9	11.5	1,320.2	0.8	4.00	1	1	0
Maximum:	1.5	14.0	2,200.5	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	1.3	12.6	1,954.1	0.9	5.90	1	1	1
10/17/2020 01:00	1.1	13.8	1,562.9	0.9	4.70	1	1	0
10/17/2020 02:00	0.9	14.0	1,321.6	0.8	4.00	1	1	0
10/17/2020 03:00	1.1	13.9	1,620.7	0.9	4.90	1	1	0
10/17/2020 04:00	1.1	13.9	1,617.4	0.9	4.90	1	1	0
10/17/2020 05:00	1.1	13.9	1,670.8	0.9	5.00	1	1	0
10/17/2020 06:00	1.2	13.3	1,820.2	0.9	5.50	1	1	1
10/17/2020 07:00	1.2	12.9	1,866.3	0.9	5.60	1	1	1
10/17/2020 08:00	1.2	13.8	1,679.6	1.0	6.70	1	1	0
10/17/2020 09:00	1.2	13.8	1,682.9	1.0	6.70	1	1	0
10/17/2020 10:00	1.2	13.8	1,636.8	1.0	6.50	1	1	0
10/17/2020 11:00	1.2	13.8	1,493.0	1.0	6.00	1	1	0
10/17/2020 12:00	1.1	13.9	1,473.3	0.9	4.40	1	1	0
10/17/2020 13:00	1.1	14.0	1,463.4	0.9	4.40	1	1	0
10/17/2020 14:00	1.1	13.5	1,664.1	0.9	5.00	1	1	1
10/17/2020 15:00	1.4	11.8	2,127.5	0.9	6.40	1	1	1
10/17/2020 16:00	1.5	11.4	2,203.3	0.9	6.60	1	1	1
10/17/2020 17:00	1.5	11.4	2,207.1	0.9	6.60	1	1	1
10/17/2020 18:00	1.4	12.0	2,077.5	0.9	6.20	1	1	1
10/17/2020 19:00	1.4	12.0	2,106.0	0.9	6.30	1	1	1
10/17/2020 20:00	1.4	11.9	2,119.4	0.9	6.40	1	1	1
10/17/2020 21:00	1.3	12.4	2,018.8	0.9	6.10	1	1	1
10/17/2020 22:00	1.4	12.0	2,111.8	0.9	6.30	1	1	1
10/17/2020 23:00	1.4	12.0	2,107.6	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.0	1,816.9	0.9	137.40 #	24 #	24 #	13 #
Minimum:	0.9	11.4	1,321.6	0.8	4.00	1	1	0
Maximum:	1.5	14.0	2,207.1	1.0	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	1.1	13.5	1,703.8	0.9	5.10	1	1	1
10/18/2020 01:00	1.2	13.1	1,837.0	0.9	5.50	1	1	1
10/18/2020 02:00	1.5	11.5	2,212.7	0.9	6.60	1	1	1
10/18/2020 03:00	1.4	11.8	2,136.2	0.9	6.40	1	1	1
10/18/2020 04:00	1.1	13.8	1,674.6	0.9	5.00	1	1	0
10/18/2020 05:00	1.1	13.8	1,609.1	0.9	4.80	1	1	0
10/18/2020 06:00	1.2	13.8	1,567.6	1.0	6.30	1	1	0
10/18/2020 07:00	1.1	13.9	1,512.7	0.9	4.50	1	1	0
10/18/2020 08:00	1.1	13.9	1,610.8	0.9	4.80	1	1	0
10/18/2020 09:00	1.1	13.9	1,617.4	0.9	4.90	1	1	0
10/18/2020 10:00	1.1	13.9	1,583.4	0.9	4.80	1	1	0
10/18/2020 11:00	1.1	13.9	1,614.7	0.9	4.80	1	1	0
10/18/2020 12:00	1.1	13.8	1,628.8	0.9	4.90	1	1	0
10/18/2020 13:00	1.1	13.8	1,606.8	0.9	4.80	1	1	0
10/18/2020 14:00	1.1	13.8	1,641.9	0.9	4.90	1	1	0
10/18/2020 15:00	1.2	13.2	1,795.2	0.9	5.40	1	1	1
10/18/2020 16:00	1.5	11.7	2,152.2	1.0	8.60	1	1	1
10/18/2020 17:00	1.2	13.5	1,725.4	1.0	6.90	1	1	1
10/18/2020 18:00	1.6	15.0	886.1	1.6	2.28	1	0	0
10/18/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2020 21:00	13.3	17.9	397.4	26.2	17.19	1	0	0
10/18/2020 22:00	8.8	14.7	1,185.4	8.4	36.70	1	0	0
10/18/2020 23:00	1.2	13.2	1,825.1	0.9	5.50	1	1	1
Average/Sum#:	2.1	13.7	1,614.7	2.4	160.67 #	22 #	19 #	8 #
Minimum:	1.1	11.5	397.4	0.9	2.28	0	0	0
Maximum:	13.3	17.9	2,212.7	26.2	36.70	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	1.2	13.0	1,852.4	0.9	5.60	1	1	1
10/19/2020 01:00	1.1	13.8	1,636.1	0.9	4.90	1	1	0
10/19/2020 02:00	1.1	13.8	1,589.9	0.9	4.80	1	1	0
10/19/2020 03:00	1.1	13.8	1,690.0	0.9	5.10	1	1	0
10/19/2020 04:00	1.2	13.3	1,825.8	0.9	5.50	1	1	1
10/19/2020 05:00	1.5	12.0	2,129.1	1.0	8.50	1	1	1
10/19/2020 06:00	1.3	12.1	2,093.8	0.9	6.30	1	1	1
10/19/2020 07:00	1.1	13.8	1,696.5	0.9	5.10	1	1	0
10/19/2020 08:00	1.1	13.9	1,565.1	0.9	4.70	1	1	0
10/19/2020 09:00	1.2	13.8	1,632.5	1.0	6.50	1	1	0
10/19/2020 10:00	1.2	13.8	1,620.5	1.0	6.50	1	1	0
10/19/2020 11:00	1.1	13.9	1,589.6	0.9	4.80	1	1	0
10/19/2020 12:00	1.1	13.9	1,456.3	0.9	4.40	1	1	0
10/19/2020 13:00	1.1	14.0	1,431.0	0.9	4.30	1	1	0
10/19/2020 14:00	1.2	13.5	1,670.8	1.0	6.70	1	1	1
10/19/2020 15:00	1.4	12.2	2,053.8	0.9	6.20	1	1	1
10/19/2020 16:00	1.4	11.6	2,170.1	0.9	6.50	1	1	1
10/19/2020 17:00	1.5	11.4	2,212.3	0.9	6.60	1	1	1
10/19/2020 18:00	1.4	11.7	2,141.1	0.9	6.40	1	1	1
10/19/2020 19:00	1.4	11.5	2,195.9	0.9	6.60	1	1	1
10/19/2020 20:00	1.2	12.9	1,786.1	0.9	5.40	1	1	1
10/19/2020 21:00	1.2	13.2	1,814.9	0.9	5.40	1	1	1
10/19/2020 22:00	1.4	12.2	2,070.7	0.9	6.20	1	1	1
10/19/2020 23:00	1.3	12.8	1,944.0	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.0	1,827.8	0.9	138.80 #	24 #	24 #	14 #
Minimum:	1.1	11.4	1,431.0	0.9	4.30	1	1	0
Maximum:	1.5	14.0	2,212.3	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2020 00:00	1.1	13.8	1,538.9	0.9	4.60	1	1	0
10/20/2020 01:00	0.9	14.0	1,294.8	0.8	3.90	1	1	0
10/20/2020 02:00	1.1	13.9	1,392.4	0.9	4.20	1	1	0
10/20/2020 03:00	1.2	13.4	1,808.3	0.9	5.40	1	1	1
10/20/2020 04:00	1.4	12.3	2,059.3	1.0	8.20	1	1	1
10/20/2020 05:00	1.5	12.1	2,088.8	1.0	8.40	1	1	1
10/20/2020 06:00	1.3	12.2	2,048.3	0.9	6.10	1	1	1
10/20/2020 07:00	1.1	13.8	1,666.9	0.9	5.00	1	1	0
10/20/2020 08:00	1.0	14.0	1,333.0	0.9	4.00	1	1	0
10/20/2020 09:00	1.1	13.9	1,463.2	0.9	4.40	1	1	0
10/20/2020 10:00	1.1	13.9	1,637.6	0.9	4.90	1	1	0
10/20/2020 11:00	1.1	13.5	1,721.8	0.9	5.20	1	1	1
10/20/2020 12:00	1.4	12.1	2,080.0	0.9	6.20	1	1	1
10/20/2020 13:00	1.4	11.9	2,081.8	0.9	6.20	1	1	1
10/20/2020 14:00	1.1	13.8	1,698.9	0.9	5.10	1	1	0
10/20/2020 15:00	1.3	12.9	1,844.3	1.0	7.40	1	1	1
10/20/2020 16:00	1.5	11.4	2,195.8	0.9	6.60	1	1	1
10/20/2020 17:00	1.4	11.6	2,156.0	0.9	6.50	1	1	1
10/20/2020 18:00	1.4	11.9	2,102.2	0.9	6.30	1	1	1
10/20/2020 19:00	1.4	12.2	2,037.0	0.9	6.10	1	1	1
10/20/2020 20:00	1.3	12.4	1,935.2	0.9	5.80	1	1	1
10/20/2020 21:00	1.2	13.4	1,752.1	0.9	5.30	1	1	1
10/20/2020 22:00	1.4	12.1	2,088.6	0.9	6.30	1	1	1
10/20/2020 23:00	1.5	11.6	2,166.5	1.0	8.70	1	1	1
Average/Sum#:	1.3	12.8	1,841.3	0.9	140.80 #	24 #	24 #	16 #
Minimum:	0.9	11.4	1,294.8	0.8	3.90	1	1	0
Maximum:	1.5	14.0	2,195.8	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2020 00:00	1.4	11.9	2,087.1	0.9	6.30	1	1	1
10/21/2020 01:00	1.1	13.8	1,695.0	0.9	5.10	1	1	0
10/21/2020 02:00	1.2	13.2	1,771.2	0.9	5.30	1	1	1
10/21/2020 03:00	1.4	11.7	2,176.8	0.9	6.50	1	1	1
10/21/2020 04:00	1.4	11.9	2,121.9	0.9	6.40	1	1	1
10/21/2020 05:00	1.4	12.4	2,049.5	1.0	8.20	1	1	1
10/21/2020 06:00	1.4	11.9	2,139.5	0.9	6.40	1	1	1
10/21/2020 07:00	1.1	13.7	1,557.2	0.9	4.70	1	1	1
10/21/2020 08:00	1.1	13.9	1,533.5	0.9	4.60	1	1	0
10/21/2020 09:00	1.0	13.9	1,362.4	0.8	4.10	1	1	0
10/21/2020 10:00	1.1	13.9	1,576.2	0.9	4.70	1	1	0
10/21/2020 11:00	1.1	13.9	1,529.3	0.9	4.60	1	1	0
10/21/2020 12:00	1.1	13.9	1,602.4	0.9	4.80	1	1	0
10/21/2020 13:00	1.1	13.5	1,687.3	0.9	5.10	1	1	1
10/21/2020 14:00	1.4	11.8	2,130.1	0.9	6.40	1	1	1
10/21/2020 15:00	1.4	12.0	2,073.2	0.9	6.20	1	1	1
10/21/2020 16:00	1.5	11.6	2,162.6	1.0	8.70	1	1	1
10/21/2020 17:00	1.5	11.4	2,197.7	0.9	6.60	1	1	1
10/21/2020 18:00	1.5	11.4	2,198.2	0.9	6.60	1	1	1
10/21/2020 19:00	1.4	11.7	2,153.5	0.9	6.50	1	1	1
10/21/2020 20:00	1.4	11.6	2,170.0	0.9	6.50	1	1	1
10/21/2020 21:00	1.4	11.8	2,108.9	0.9	6.30	1	1	1
10/21/2020 22:00	1.4	11.8	2,130.5	0.9	6.40	1	1	1
10/21/2020 23:00	1.3	12.2	2,030.6	0.9	6.10	1	1	1
Average/Sum#:	1.3	12.5	1,926.9	0.9	143.10 #	24 #	24 #	18 #
Minimum:	1.0	11.4	1,362.4	0.8	4.10	1	1	0
Maximum:	1.5	13.9	2,198.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2020 00:00	1.0	13.9	1,693.3	0.8	5.10	1	1	0
10/22/2020 01:00	1.2	13.2	1,828.3	0.9	5.50	1	1	1
10/22/2020 02:00	1.3	12.4	1,996.5	0.9	6.00	1	1	1
10/22/2020 03:00	1.3	12.5	1,968.2	0.9	5.90	1	1	1
10/22/2020 04:00	1.0	13.9	1,689.9	0.8	5.10	1	1	0
10/22/2020 05:00	1.3	13.0	1,767.7	1.0	7.10	1	1	1
10/22/2020 06:00	1.4	11.9	2,176.0	0.9	6.50	1	1	1
10/22/2020 07:00	1.4	12.0	2,099.5	0.9	6.30	1	1	1
10/22/2020 08:00	0.9	13.9	1,489.7	0.8	4.50	1	1	0
10/22/2020 09:00	1.0	13.9	1,589.5	0.8	4.80	1	1	0
10/22/2020 10:00	1.0	13.9	1,618.1	0.8	4.90	1	1	0
10/22/2020 11:00	1.2	13.3	1,829.4	0.9	5.50	1	1	1
10/22/2020 12:00	1.4	12.0	2,132.3	0.9	6.40	1	1	1
10/22/2020 13:00	1.3	12.5	1,999.9	0.9	6.00	1	1	1
10/22/2020 14:00	1.0	13.8	1,589.1	0.8	4.80	1	1	0
10/22/2020 15:00	1.1	13.6	1,685.4	0.9	5.10	1	1	1
10/22/2020 16:00	1.4	12.0	2,131.8	0.9	6.40	1	1	1
10/22/2020 17:00	1.4	11.9	2,144.5	0.9	6.40	1	1	1
10/22/2020 18:00	1.3	12.5	2,020.1	0.9	6.10	1	1	1
10/22/2020 19:00	1.4	12.2	2,090.3	0.9	6.30	1	1	1
10/22/2020 20:00	1.4	12.3	2,061.9	1.0	8.20	1	1	1
10/22/2020 21:00	1.4	12.4	2,062.5	1.0	8.30	1	1	1
10/22/2020 22:00	1.3	12.5	2,020.5	0.9	6.10	1	1	1
10/22/2020 23:00	1.3	12.6	1,969.7	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.8	1,902.3	0.9	143.20 #	24 #	24 #	18 #
Minimum:	0.9	11.9	1,489.7	0.8	4.50	1	1	0
Maximum:	1.4	13.9	2,176.0	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	0.9	13.9	1,637.3	0.8	4.90	1	1	0
10/23/2020 01:00	1.2	13.3	1,817.5	0.9	5.50	1	1	1
10/23/2020 02:00	1.4	12.2	2,108.7	0.9	6.30	1	1	1
10/23/2020 03:00	1.3	12.6	2,003.8	0.9	6.00	1	1	1
10/23/2020 04:00	1.0	13.9	1,684.8	0.8	5.10	1	1	0
10/23/2020 05:00	1.3	13.1	1,826.2	1.0	7.30	1	1	1
10/23/2020 06:00	1.4	12.0	2,156.6	0.9	6.50	1	1	1
10/23/2020 07:00	1.4	12.2	2,114.2	0.9	6.30	1	1	1
10/23/2020 08:00	1.3	12.7	2,000.8	0.9	6.00	1	1	1
10/23/2020 09:00	1.1	13.6	1,717.0	0.9	5.20	1	1	1
10/23/2020 10:00	1.1	13.8	1,689.6	0.9	5.10	1	1	0
10/23/2020 11:00	1.1	13.7	1,737.8	0.9	5.20	1	1	1
10/23/2020 12:00	1.4	12.3	2,075.6	1.0	8.30	1	1	1
10/23/2020 13:00	1.3	12.7	1,962.9	0.9	5.90	1	1	1
10/23/2020 14:00	1.1	13.9	1,607.9	0.9	4.80	1	1	0
10/23/2020 15:00	1.1	13.6	1,751.8	0.9	5.30	1	1	1
10/23/2020 16:00	1.4	12.3	2,066.9	1.0	8.30	1	1	1
10/23/2020 17:00	1.4	12.0	2,119.8	0.9	6.40	1	1	1
10/23/2020 18:00	1.3	12.9	1,936.0	1.0	7.70	1	1	1
10/23/2020 19:00	1.1	13.8	1,701.4	0.9	5.10	1	1	0
10/23/2020 20:00	1.2	13.3	1,838.5	0.9	5.50	1	1	1
10/23/2020 21:00	1.4	12.3	2,067.8	1.0	8.30	1	1	1
10/23/2020 22:00	1.3	12.6	2,034.1	0.9	6.10	1	1	1
10/23/2020 23:00	1.4	12.1	2,131.9	0.9	6.40	1	1	1
Average/Sum#:	1.2	13.0	1,907.9	0.9	147.50 #	24 #	24 #	19 #
Minimum:	0.9	12.0	1,607.9	0.8	4.80	1	1	0
Maximum:	1.4	13.9	2,156.6	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2020 00:00	1.1	13.6	1,724.3	0.9	5.20	1	1	1
10/24/2020 01:00	1.1	13.8	1,694.2	0.9	5.10	1	1	0
10/24/2020 02:00	1.2	13.3	1,835.8	0.9	5.50	1	1	1
10/24/2020 03:00	1.4	12.2	2,111.6	0.9	6.30	1	1	1
10/24/2020 04:00	1.3	12.8	1,953.9	0.9	5.90	1	1	1
10/24/2020 05:00	1.0	13.8	1,680.8	0.8	5.00	1	1	0
10/24/2020 06:00	1.0	13.8	1,676.3	0.8	5.00	1	1	0
10/24/2020 07:00	1.1	13.8	1,631.4	0.9	4.90	1	1	0
10/24/2020 08:00	1.0	13.8	1,577.1	0.8	4.70	1	1	0
10/24/2020 09:00	1.1	13.8	1,622.2	0.9	4.90	1	1	0
10/24/2020 10:00	1.1	13.8	1,678.7	0.9	5.00	1	1	0
10/24/2020 11:00	1.1	13.8	1,637.4	0.9	4.90	1	1	0
10/24/2020 12:00	1.1	13.9	1,437.7	0.9	4.30	1	1	0
10/24/2020 13:00	1.1	13.9	1,433.0	0.9	4.30	1	1	0
10/24/2020 14:00	1.1	13.9	1,633.5	0.9	4.90	1	1	0
10/24/2020 15:00	1.1	13.9	1,698.1	0.9	5.10	1	1	0
10/24/2020 16:00	1.2	13.2	1,825.9	0.9	5.50	1	1	1
10/24/2020 17:00	1.4	11.9	2,136.8	0.9	6.40	1	1	1
10/24/2020 18:00	1.3	12.8	1,944.2	0.9	5.80	1	1	1
10/24/2020 19:00	1.2	13.8	1,700.8	1.0	6.80	1	1	0
10/24/2020 20:00	1.2	13.8	1,692.6	1.0	6.80	1	1	0
10/24/2020 21:00	1.2	13.3	1,817.8	0.9	5.50	1	1	1
10/24/2020 22:00	1.3	12.5	2,018.4	0.9	6.10	1	1	1
10/24/2020 23:00	1.3	12.6	1,968.0	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.4	1,755.4	0.9	129.80 #	24 #	24 #	10 #
Minimum:	1.0	11.9	1,433.0	0.8	4.30	1	1	0
Maximum:	1.4	13.9	2,136.8	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2020 00:00	1.0	13.8	1,681.8	0.8	5.00	1	1	0
10/25/2020 01:00	1.1	13.8	1,669.3	0.9	5.00	1	1	0
10/25/2020 02:00	1.1	13.8	1,654.8	0.9	5.00	1	1	0
10/25/2020 03:00	1.1	13.8	1,653.7	0.9	5.00	1	1	0
10/25/2020 04:00	1.1	13.8	1,652.7	0.9	5.00	1	1	0
10/25/2020 05:00	1.1	13.8	1,628.9	0.9	4.90	1	1	0
10/25/2020 06:00	1.1	13.8	1,595.1	0.9	4.80	1	1	0
10/25/2020 07:00	1.1	13.8	1,619.8	0.9	4.90	1	1	0
10/25/2020 08:00	1.0	13.9	1,615.0	0.8	4.80	1	1	0
10/25/2020 09:00	1.0	13.9	1,564.9	0.8	4.70	1	1	0
10/25/2020 10:00	1.0	13.9	1,423.2	0.8	4.30	1	1	0
10/25/2020 11:00	0.9	14.0	1,352.0	0.8	4.10	1	1	0
10/25/2020 12:00	1.0	13.9	1,556.7	0.8	4.70	1	1	0
10/25/2020 13:00	1.0	13.9	1,606.2	0.8	4.80	1	1	0
10/25/2020 14:00	1.0	13.9	1,662.3	0.8	5.00	1	1	0
10/25/2020 15:00	1.0	14.0	1,613.3	0.9	4.80	1	1	0
10/25/2020 16:00	1.1	13.4	1,848.6	0.9	5.50	1	1	1
10/25/2020 17:00	1.4	12.5	2,084.2	1.0	8.30	1	1	1
10/25/2020 18:00	1.3	12.5	2,035.4	0.9	6.10	1	1	1
10/25/2020 19:00	1.0	13.9	1,672.5	0.8	5.00	1	1	0
10/25/2020 20:00	1.2	13.3	1,833.0	0.9	5.50	1	1	1
10/25/2020 21:00	1.4	12.0	2,171.6	0.9	6.50	1	1	1
10/25/2020 22:00	1.4	11.9	2,195.3	0.9	6.60	1	1	1
10/25/2020 23:00	1.4	11.7	2,239.9	0.9	6.70	1	1	1
Average/Sum#:	1.1	13.5	1,734.6	0.9	127.00 #	24 #	24 #	7 #
Minimum:	0.9	11.7	1,352.0	0.8	4.10	1	1	0
Maximum:	1.4	14.0	2,239.9	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2020 00:00	1.3	12.5	2,059.9	0.9	6.20	1	1	1
10/26/2020 01:00	1.3	12.9	1,990.9	1.0	8.00	1	1	1
10/26/2020 02:00	1.3	12.5	2,059.2	0.9	6.20	1	1	1
10/26/2020 03:00	1.0	13.8	1,690.7	0.8	5.10	1	1	1
10/26/2020 04:00	1.1	13.3	1,875.0	0.9	5.60	1	1	1
10/26/2020 05:00	1.6	11.9	2,169.8	1.0	8.70	1	1	1
10/26/2020 06:00	1.3	12.1	2,129.9	0.9	6.40	1	1	1
10/26/2020 07:00	1.1	13.8	1,789.8	0.9	5.40	1	1	0
10/26/2020 08:00	1.0	13.9	1,762.0	0.8	5.30	1	1	0
10/26/2020 09:00	1.1	13.9	1,750.1	0.9	5.30	1	1	0
10/26/2020 10:00	1.0	13.9	1,688.4	0.8	5.10	1	1	0
10/26/2020 11:00	0.8	14.0	1,389.8	0.7	4.20	1	1	0
10/26/2020 12:00	1.0	14.0	1,538.7	0.9	4.60	1	1	0
10/26/2020 13:00	1.0	14.0	1,515.7	0.9	4.50	1	1	0
10/26/2020 14:00	1.1	14.0	1,699.0	0.9	5.10	1	1	0
10/26/2020 15:00	1.1	14.0	1,651.4	0.9	5.00	1	1	0
10/26/2020 16:00	1.2	13.2	1,870.3	0.9	5.60	1	1	1
10/26/2020 17:00	1.4	12.0	2,186.7	0.9	6.60	1	1	1
10/26/2020 18:00	1.5	11.7	2,238.1	1.0	9.00	1	1	1
10/26/2020 19:00	1.4	12.3	2,111.9	1.0	8.40	1	1	1
10/26/2020 20:00	1.4	12.1	2,162.7	0.9	6.50	1	1	1
10/26/2020 21:00	1.4	12.2	2,127.1	0.9	6.40	1	1	1
10/26/2020 22:00	1.4	12.3	2,113.0	1.0	8.50	1	1	1
10/26/2020 23:00	1.4	12.4	2,082.3	1.0	8.30	1	1	1
Average/Sum#:	1.2	13.0	1,902.2	0.9	150.00 #	24 #	24 #	15 #
Minimum:	0.8	11.7	1,389.8	0.7	4.20	1	1	0
Maximum:	1.6	14.0	2,238.1	1.0	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2020 00:00	0.9	13.9	1,693.1	0.8	5.10	1	1	1
10/27/2020 01:00	1.1	13.5	1,801.7	0.9	5.40	1	1	1
10/27/2020 02:00	1.3	12.2	2,095.4	0.9	6.30	1	1	1
10/27/2020 03:00	1.3	12.5	2,025.8	0.9	6.10	1	1	1
10/27/2020 04:00	0.9	13.9	1,663.1	0.8	5.00	1	1	0
10/27/2020 05:00	1.2	13.0	1,753.9	0.9	5.30	1	1	1
10/27/2020 06:00	1.4	11.7	2,210.8	0.9	6.60	1	1	1
10/27/2020 07:00	1.4	11.8	2,211.1	0.9	6.60	1	1	1
10/27/2020 08:00	1.4	12.1	2,148.0	0.9	6.40	1	1	1
10/27/2020 09:00	1.4	11.9	2,160.6	0.9	6.50	1	1	1
10/27/2020 10:00	1.4	11.9	2,167.7	0.9	6.50	1	1	1
10/27/2020 11:00	1.4	11.8	2,166.0	0.9	6.50	1	1	1
10/27/2020 12:00	1.4	11.9	2,155.6	0.9	6.50	1	1	1
10/27/2020 13:00	1.4	11.7	2,171.9	0.9	6.50	1	1	1
10/27/2020 14:00	1.5	11.7	2,176.5	1.0	8.70	1	1	1
10/27/2020 15:00	1.3	12.5	2,002.6	0.9	6.00	1	1	1
10/27/2020 16:00	1.5	11.7	2,174.1	1.0	8.70	1	1	1
10/27/2020 17:00	1.5	11.5	2,219.9	0.9	6.70	1	1	1
10/27/2020 18:00	1.5	11.5	2,221.6	0.9	6.70	1	1	1
10/27/2020 19:00	1.5	11.6	2,220.9	1.0	8.90	1	1	1
10/27/2020 20:00	1.4	11.7	2,202.1	0.9	6.60	1	1	1
10/27/2020 21:00	1.4	12.3	2,078.8	1.0	8.30	1	1	1
10/27/2020 22:00	1.4	12.4	2,075.6	1.0	8.30	1	1	1
10/27/2020 23:00	1.4	12.3	2,060.5	1.0	8.20	1	1	1
Average/Sum#:	1.3	12.2	2,077.4	0.9	162.40 #	24 #	24 #	23 #
Minimum:	0.9	11.5	1,663.1	0.8	5.00	1	1	0
Maximum:	1.5	13.9	2,221.6	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2020 00:00	0.9	13.9	1,682.5	0.8	5.00	1	1	0
10/28/2020 01:00	1.0	13.9	1,670.4	0.8	5.00	1	1	0
10/28/2020 02:00	1.0	13.9	1,659.0	0.8	5.00	1	1	0
10/28/2020 03:00	1.0	13.9	1,656.1	0.8	5.00	1	1	0
10/28/2020 04:00	1.2	13.4	1,835.8	0.9	5.50	1	1	1
10/28/2020 05:00	1.4	12.0	2,143.8	0.9	6.40	1	1	1
10/28/2020 06:00	1.4	11.8	2,179.4	0.9	6.50	1	1	1
10/28/2020 07:00	1.2	13.7	1,809.3	1.0	7.20	1	1	0
10/28/2020 08:00	1.0	13.7	1,738.9	0.8	5.20	1	1	0
10/28/2020 09:00	0.9	13.8	1,635.2	0.7	4.90	1	1	0
10/28/2020 10:00	1.0	13.8	1,662.0	0.8	5.00	1	1	0
10/28/2020 11:00	0.8	13.9	1,305.9	0.7	2.60	1	1	0
10/28/2020 12:00	0.8	14.0	1,268.9	0.7	3.80	1	1	0
10/28/2020 13:00	1.0	13.9	1,476.7	0.8	4.40	1	1	0
10/28/2020 14:00	1.1	13.9	1,554.7	0.9	4.70	1	1	0
10/28/2020 15:00	0.9	14.0	1,295.6	0.8	3.90	1	1	0
10/28/2020 16:00	1.1	13.8	1,640.7	0.9	4.90	1	1	0
10/28/2020 17:00	1.1	13.8	1,712.0	0.9	5.10	1	1	1
10/28/2020 18:00	1.3	12.6	2,009.7	0.9	6.00	1	1	1
10/28/2020 19:00	1.3	12.3	2,064.4	0.9	6.20	1	1	1
10/28/2020 20:00	1.4	12.2	2,089.0	0.9	6.30	1	1	1
10/28/2020 21:00	1.4	12.3	2,088.6	1.0	8.40	1	1	1
10/28/2020 22:00	1.3	12.4	2,062.8	0.9	6.20	1	1	1
10/28/2020 23:00	1.3	12.9	1,921.3	1.0	7.70	1	1	1
Average/Sum#:	1.1	13.3	1,756.8	0.9	130.90 #	24 #	24 #	10 #
Minimum:	0.8	11.8	1,268.9	0.7	2.60	1	1	0
Maximum:	1.4	14.0	2,179.4	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2020 00:00	1.0	13.9	1,698.1	0.8	5.10	1	1	0
10/29/2020 01:00	1.0	13.9	1,687.8	0.8	5.10	1	1	0
10/29/2020 02:00	1.0	13.9	1,545.9	0.8	4.60	1	1	0
10/29/2020 03:00	1.1	13.9	1,691.2	0.9	5.10	1	1	0
10/29/2020 04:00	1.1	13.4	1,803.4	0.9	5.40	1	1	1
10/29/2020 05:00	1.3	12.5	2,057.9	0.9	6.20	1	1	1
10/29/2020 06:00	1.3	12.4	2,065.5	0.9	6.20	1	1	1
10/29/2020 07:00	0.7	13.9	1,278.4	0.6	2.60	1	1	0
10/29/2020 08:00	0.8	13.9	1,295.7	0.7	2.60	1	1	0
10/29/2020 09:00	1.1	13.9	1,500.4	0.9	4.50	1	1	0
10/29/2020 10:00	1.1	13.9	1,501.2	0.9	4.50	1	1	0
10/29/2020 11:00	1.2	13.6	1,788.3	1.0	7.20	1	1	0
10/29/2020 12:00	1.2	13.6	1,807.6	1.0	7.20	1	1	0
10/29/2020 13:00	1.2	13.6	1,801.4	1.0	7.20	1	1	0
10/29/2020 14:00	1.2	13.6	1,801.6	1.0	7.20	1	1	0
10/29/2020 15:00	1.2	13.6	1,799.9	1.0	7.20	1	1	0
10/29/2020 16:00	1.1	13.7	1,762.9	0.9	5.30	1	1	0
10/29/2020 17:00	1.1	13.8	1,759.5	0.9	5.30	1	1	1
10/29/2020 18:00	1.3	12.5	2,029.9	0.9	6.10	1	1	1
10/29/2020 19:00	1.4	12.3	2,074.9	1.0	8.30	1	1	1
10/29/2020 20:00	1.4	12.2	2,097.7	0.9	6.30	1	1	1
10/29/2020 21:00	1.4	12.2	2,091.7	0.9	6.30	1	1	1
10/29/2020 22:00	1.4	12.3	2,088.8	1.0	8.40	1	1	1
10/29/2020 23:00	1.3	12.9	1,941.2	1.0	7.80	1	1	1
Average/Sum#:	1.2	13.3	1,790.5	0.9	141.70 #	24 #	24 #	10 #
Minimum:	0.7	12.2	1,278.4	0.6	2.60	1	1	0
Maximum:	1.4	13.9	2,097.7	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2020 00:00	1.0	13.9	1,620.6	0.8	4.90	1	1	0
10/30/2020 01:00	1.1	13.6	1,696.1	0.9	5.10	1	1	1
10/30/2020 02:00	1.3	12.9	1,948.5	1.0	7.80	1	1	1
10/30/2020 03:00	1.3	12.8	1,949.6	0.9	5.80	1	1	1
10/30/2020 04:00	1.0	13.9	1,698.2	0.8	5.10	1	1	0
10/30/2020 05:00	1.3	12.9	1,829.6	1.0	7.30	1	1	1
10/30/2020 06:00	1.3	12.3	2,100.8	0.9	6.30	1	1	1
10/30/2020 07:00	1.4	11.7	2,241.2	0.9	6.70	1	1	1
10/30/2020 08:00	1.4	11.6	2,249.3	0.9	6.70	1	1	1
10/30/2020 09:00	1.4	11.6	2,210.3	0.9	6.60	1	1	1
10/30/2020 10:00	1.4	11.6	2,193.4	0.9	6.60	1	1	1
10/30/2020 11:00	1.3	12.5	1,992.9	0.9	6.00	1	1	1
10/30/2020 12:00	1.0	13.9	1,653.3	0.8	5.00	1	1	0
10/30/2020 13:00	1.2	13.3	1,813.2	0.9	5.40	1	1	1
10/30/2020 14:00	1.3	12.4	2,050.0	0.9	6.20	1	1	1
10/30/2020 15:00	1.4	12.0	2,117.3	0.9	6.40	1	1	1
10/30/2020 16:00	1.4	12.2	2,083.7	0.9	6.30	1	1	1
10/30/2020 17:00	1.4	11.8	2,169.3	0.9	6.50	1	1	1
10/30/2020 18:00	1.4	11.8	2,171.2	0.9	6.50	1	1	1
10/30/2020 19:00	1.4	11.7	2,205.8	0.9	6.60	1	1	1
10/30/2020 20:00	1.2	13.1	1,823.3	0.9	5.50	1	1	1
10/30/2020 21:00	1.2	13.3	1,838.3	0.9	5.50	1	1	1
10/30/2020 22:00	1.4	12.1	2,115.0	0.9	6.30	1	1	1
10/30/2020 23:00	1.3	12.9	1,934.7	1.0	7.70	1	1	1
Average/Sum#:	1.3	12.6	1,987.7	0.9	148.80 #	24 #	24 #	21 #
Minimum:	1.0	11.6	1,620.6	0.8	4.90	1	1	0
Maximum:	1.4	13.9	2,249.3	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2020 00:00	0.9	13.9	1,569.3	0.8	4.70	1	1	0
10/31/2020 01:00	1.0	13.8	1,663.9	0.8	5.00	1	1	0
10/31/2020 02:00	1.0	13.6	1,660.3	0.8	5.00	1	1	1
10/31/2020 03:00	1.3	12.4	2,054.8	0.9	6.20	1	1	1
10/31/2020 04:00	1.2	12.9	1,928.1	0.9	5.80	1	1	1
10/31/2020 05:00	1.0	13.8	1,693.1	0.8	5.10	1	1	0
10/31/2020 06:00	1.0	13.8	1,693.8	0.8	5.10	1	1	0
10/31/2020 07:00	1.0	13.8	1,651.9	0.8	5.00	1	1	0
10/31/2020 08:00	1.0	13.8	1,532.2	0.8	4.60	1	1	0
10/31/2020 09:00	1.0	13.9	1,509.1	0.8	4.50	1	1	0
10/31/2020 10:00	1.1	13.9	1,639.5	0.9	4.90	1	1	0
10/31/2020 11:00	1.0	13.9	1,558.5	0.8	4.70	1	1	0
10/31/2020 12:00	1.0	13.9	1,556.5	0.8	4.70	1	1	0
10/31/2020 13:00	1.1	13.9	1,568.8	0.9	4.70	1	1	0
10/31/2020 14:00	1.2	13.9	1,604.4	1.0	6.40	1	1	0
10/31/2020 15:00	1.5	13.8	1,684.3	1.2	8.40	1	1	0
10/31/2020 16:00	1.7	13.3	1,819.6	1.3	9.10	1	1	1
10/31/2020 17:00	2.2	12.5	2,010.0	1.5	12.10	1	1	1
10/31/2020 18:00	2.3	12.4	2,035.1	1.6	12.20	1	1	1
10/31/2020 19:00	1.3	13.8	1,698.6	1.1	6.80	1	1	0
10/31/2020 20:00	1.5	13.3	1,825.0	1.2	7.30	1	1	1
10/31/2020 21:00	2.2	12.4	2,067.2	1.5	12.40	1	1	1
10/31/2020 22:00	2.3	12.5	2,044.4	1.6	12.30	1	1	1
10/31/2020 23:00	1.7	12.5	2,032.4	1.2	8.10	1	1	1
Average/Sum#:	1.4	13.4	1,754.2	1.0	165.10 #	24 #	24 #	10 #
Minimum:	0.9	12.4	1,509.1	0.8	4.50	1	1	0
Maximum:	2.3	13.9	2,067.2	1.6	12.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2020 00:00	2.4	12.5	2,030.9	1.7	12.20	1	1	1
11/01/2020 01:00	2.6	12.5	2,012.0	1.8	14.10	1	1	1
11/01/2020 02:00	1.2	13.8	1,681.1	1.0	6.70	1	1	1
11/01/2020 03:00	1.0	13.9	1,693.1	0.8	5.10	1	1	0
11/01/2020 04:00	1.5	13.3	1,832.1	1.2	7.30	1	1	1
11/01/2020 05:00	1.4	12.3	2,066.3	1.0	8.30	1	1	1
11/01/2020 06:00	1.3	12.5	2,033.0	0.9	6.10	1	1	1
11/01/2020 07:00	0.9	13.9	1,548.4	0.8	4.60	1	1	0
11/01/2020 08:00	1.1	13.9	1,695.4	0.9	5.10	1	1	0
11/01/2020 09:00	1.0	13.9	1,505.4	0.8	4.50	1	1	0
11/01/2020 10:00	1.0	13.9	1,576.7	0.8	4.70	1	1	0
11/01/2020 11:00	1.0	13.9	1,494.0	0.8	4.50	1	1	0
11/01/2020 12:00	1.1	13.9	1,578.6	0.9	4.70	1	1	0
11/01/2020 13:00	1.0	13.9	1,665.9	0.8	5.00	1	1	0
11/01/2020 14:00	1.0	13.8	1,681.2	0.8	5.00	1	1	0
11/01/2020 15:00	1.1	13.6	1,678.2	0.9	5.00	1	1	1
11/01/2020 16:00	1.3	12.4	2,040.1	0.9	6.10	1	1	1
11/01/2020 17:00	1.4	11.9	2,154.4	0.9	6.50	1	1	1
11/01/2020 18:00	1.4	11.7	2,195.5	0.9	6.60	1	1	1
11/01/2020 19:00	1.4	11.9	2,157.7	0.9	6.50	1	1	1
11/01/2020 20:00	1.4	11.9	2,142.2	0.9	6.40	1	1	1
11/01/2020 21:00	1.4	11.6	2,208.0	0.9	6.60	1	1	1
11/01/2020 22:00	1.4	12.2	2,103.5	0.9	6.30	1	1	1
11/01/2020 23:00	1.4	12.3	2,105.5	1.0	8.40	1	1	1
Average/Sum#:	1.3	13.0	1,870.0	1.0	156.30 #	24 #	24 #	15 #
Minimum:	0.9	11.6	1,494.0	0.8	4.50	1	1	0
Maximum:	2.6	13.9	2,208.0	1.8	14.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2020 00:00	1.4	12.1	2,123.3	0.9	6.40	1	1	1
11/02/2020 01:00	1.3	12.3	2,036.6	0.9	6.10	1	1	1
11/02/2020 02:00	0.9	13.9	1,654.9	0.8	5.00	1	1	0
11/02/2020 03:00	1.1	13.3	1,813.6	0.9	5.40	1	1	1
11/02/2020 04:00	1.3	12.1	2,120.5	0.9	6.40	1	1	1
11/02/2020 05:00	1.6	12.0	2,148.3	1.1	8.60	1	1	1
11/02/2020 06:00	1.3	12.1	2,093.4	0.9	6.30	1	1	1
11/02/2020 07:00	0.9	13.9	1,636.3	0.8	4.90	1	1	0
11/02/2020 08:00	1.0	13.9	1,668.5	0.8	5.00	1	1	0
11/02/2020 09:00	1.1	13.9	1,692.6	0.9	5.10	1	1	0
11/02/2020 10:00	1.1	13.9	1,657.3	0.9	5.00	1	1	0
11/02/2020 11:00	1.1	13.9	1,665.0	0.9	5.00	1	1	0
11/02/2020 12:00	1.0	13.8	1,692.2	0.8	5.10	1	1	0
11/02/2020 13:00	1.1	13.7	1,699.1	0.9	5.10	1	1	0
11/02/2020 14:00	1.1	13.6	1,727.4	0.9	5.20	1	1	1
11/02/2020 15:00	1.3	12.3	2,060.5	0.9	6.20	1	1	1
11/02/2020 16:00	1.4	11.5	2,202.3	0.9	6.60	1	1	1
11/02/2020 17:00	1.4	11.7	2,176.1	0.9	6.50	1	1	1
11/02/2020 18:00	1.5	11.6	2,201.8	1.0	8.80	1	1	1
11/02/2020 19:00	1.5	11.5	2,217.8	0.9	6.70	1	1	1
11/02/2020 20:00	1.4	11.6	2,206.5	0.9	6.60	1	1	1
11/02/2020 21:00	1.4	11.9	2,145.1	0.9	6.40	1	1	1
11/02/2020 22:00	1.4	12.0	2,125.3	0.9	6.40	1	1	1
11/02/2020 23:00	1.3	12.4	2,056.0	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.7	1,950.9	0.9	145.00 #	24 #	24 #	16 #
Minimum:	0.9	11.5	1,636.3	0.8	4.90	1	1	0
Maximum:	1.6	13.9	2,217.8	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2020 00:00	1.4	12.1	2,097.3	0.9	6.30	1	1	1
11/03/2020 01:00	1.3	12.5	1,974.6	0.9	5.90	1	1	1
11/03/2020 02:00	1.0	13.8	1,695.2	0.8	5.10	1	1	0
11/03/2020 03:00	1.1	13.3	1,829.4	0.9	5.50	1	1	1
11/03/2020 04:00	1.4	12.0	2,129.9	0.9	6.40	1	1	1
11/03/2020 05:00	1.6	11.9	2,151.7	1.0	8.60	1	1	1
11/03/2020 06:00	1.4	11.7	2,172.7	0.9	6.50	1	1	1
11/03/2020 07:00	1.3	12.3	2,045.9	0.9	6.10	1	1	1
11/03/2020 08:00	1.0	13.8	1,664.5	0.8	5.00	1	1	0
11/03/2020 09:00	1.0	13.9	1,683.0	0.8	5.00	1	1	0
11/03/2020 10:00	1.1	13.9	1,686.4	0.9	5.10	1	1	0
11/03/2020 11:00	1.0	13.9	1,536.2	0.8	4.60	1	1	0
11/03/2020 12:00	1.0	13.9	1,535.5	0.8	4.60	1	1	0
11/03/2020 13:00	1.1	13.9	1,605.1	0.9	4.80	1	1	0
11/03/2020 14:00	1.1	13.9	1,676.2	0.9	5.00	1	1	0
11/03/2020 15:00	1.2	13.3	1,812.8	0.9	5.40	1	1	1
11/03/2020 16:00	1.4	11.9	2,151.6	0.9	6.50	1	1	1
11/03/2020 17:00	1.4	11.7	2,189.1	0.9	6.60	1	1	1
11/03/2020 18:00	1.4	11.6	2,201.6	0.9	6.60	1	1	1
11/03/2020 19:00	1.4	11.6	2,210.4	0.9	6.60	1	1	1
11/03/2020 20:00	1.4	11.8	2,172.2	0.9	6.50	1	1	1
11/03/2020 21:00	1.4	11.9	2,155.4	0.9	6.50	1	1	1
11/03/2020 22:00	1.4	12.1	2,124.8	0.9	6.40	1	1	1
11/03/2020 23:00	1.3	12.5	2,058.4	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.7	1,940.0	0.9	141.80 #	24 #	24 #	16 #
Minimum:	1.0	11.6	1,535.5	0.8	4.60	1	1	0
Maximum:	1.6	13.9	2,210.4	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2020 00:00	1.3	12.4	2,066.9	0.9	6.20	1	1	1
11/04/2020 01:00	1.2	12.8	1,935.3	0.9	5.80	1	1	1
11/04/2020 02:00	0.9	13.8	1,695.0	0.7	5.10	1	1	0
11/04/2020 03:00	1.2	13.3	1,825.3	0.9	5.50	1	1	1
11/04/2020 04:00	1.3	12.2	2,106.2	0.9	6.30	1	1	1
11/04/2020 05:00	1.4	12.0	2,155.7	0.9	6.50	1	1	1
11/04/2020 06:00	1.4	12.0	2,175.0	0.9	6.50	1	1	1
11/04/2020 07:00	1.3	12.4	2,041.5	0.9	6.10	1	1	1
11/04/2020 08:00	1.0	13.8	1,696.7	0.8	5.10	1	1	0
11/04/2020 09:00	1.0	13.9	1,645.6	0.8	4.90	1	1	0
11/04/2020 10:00	1.0	13.9	1,545.1	0.8	4.60	1	1	0
11/04/2020 11:00	1.1	13.9	1,672.3	0.9	5.00	1	1	0
11/04/2020 12:00	1.1	13.9	1,694.7	0.9	5.10	1	1	0
11/04/2020 13:00	1.1	13.9	1,699.3	0.9	5.10	1	1	0
11/04/2020 14:00	1.0	13.7	1,737.7	0.8	5.20	1	1	1
11/04/2020 15:00	1.3	12.4	2,047.7	0.9	6.10	1	1	1
11/04/2020 16:00	1.4	11.9	2,147.3	0.9	6.40	1	1	1
11/04/2020 17:00	1.4	11.7	2,182.3	0.9	6.50	1	1	1
11/04/2020 18:00	1.4	11.5	2,235.9	0.9	6.70	1	1	1
11/04/2020 19:00	1.4	11.6	2,220.7	0.9	6.70	1	1	1
11/04/2020 20:00	1.4	11.7	2,183.1	0.9	6.50	1	1	1
11/04/2020 21:00	1.4	11.8	2,172.0	0.9	6.50	1	1	1
11/04/2020 22:00	1.4	11.8	2,169.8	0.9	6.50	1	1	1
11/04/2020 23:00	1.4	12.1	2,133.6	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.7	1,966.0	0.9	141.30 #	24 #	24 #	17 #
Minimum:	0.9	11.5	1,545.1	0.7	4.60	1	1	0
Maximum:	1.4	13.9	2,235.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	1.4	12.0	2,118.5	0.9	6.40	1	1	1
11/05/2020 01:00	1.3	12.2	2,047.8	0.9	6.10	1	1	1
11/05/2020 02:00	0.9	13.9	1,647.4	0.8	4.90	1	1	0
11/05/2020 03:00	1.2	13.2	1,826.4	0.9	5.50	1	1	1
11/05/2020 04:00	1.3	12.2	2,099.1	0.9	6.30	1	1	1
11/05/2020 05:00	1.4	11.9	2,139.3	0.9	6.40	1	1	1
11/05/2020 06:00	1.3	12.1	2,120.0	0.9	6.40	1	1	1
11/05/2020 07:00	1.3	12.6	2,002.8	0.9	6.00	1	1	1
11/05/2020 08:00	0.9	13.8	1,601.2	0.7	4.80	1	1	0
11/05/2020 09:00	1.0	13.8	1,683.6	0.8	5.10	1	1	0
11/05/2020 10:00	1.0	13.9	1,592.1	0.8	4.80	1	1	0
11/05/2020 11:00	1.0	13.9	1,585.9	0.8	4.80	1	1	0
11/05/2020 12:00	1.1	13.8	1,680.8	0.9	5.00	1	1	0
11/05/2020 13:00	0.9	13.8	1,574.8	0.7	4.70	1	1	0
11/05/2020 14:00	1.2	13.4	1,760.5	0.9	5.30	1	1	1
11/05/2020 15:00	1.4	11.7	2,158.2	0.9	6.50	1	1	1
11/05/2020 16:00	1.4	12.1	2,067.2	0.9	6.20	1	1	1
11/05/2020 17:00	1.4	11.8	2,150.2	0.9	6.50	1	1	1
11/05/2020 18:00	1.4	11.7	2,156.6	0.9	6.50	1	1	1
11/05/2020 19:00	1.4	12.1	2,083.2	0.9	6.20	1	1	1
11/05/2020 20:00	1.4	11.6	2,191.1	0.9	6.60	1	1	1
11/05/2020 21:00	1.4	11.5	2,218.8	0.9	6.70	1	1	1
11/05/2020 22:00	1.4	12.0	2,109.5	0.9	6.30	1	1	1
11/05/2020 23:00	1.4	12.0	2,114.9	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.6	1,947.1	0.9	140.30 #	24 #	24 #	17 #
Minimum:	0.9	11.5	1,574.8	0.7	4.70	1	1	0
Maximum:	1.4	13.9	2,218.8	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2020 00:00	1.4	12.0	2,101.9	0.9	6.30	1	1	1
11/06/2020 01:00	1.3	12.8	1,928.1	0.9	5.80	1	1	1
11/06/2020 02:00	1.1	13.8	1,651.1	0.9	5.00	1	1	0
11/06/2020 03:00	1.1	13.8	1,611.0	0.9	4.80	1	1	0
11/06/2020 04:00	1.2	13.2	1,828.4	0.9	5.50	1	1	1
11/06/2020 05:00	1.6	11.9	2,131.3	1.0	8.50	1	1	1
11/06/2020 06:00	1.3	12.4	2,044.5	0.9	6.10	1	1	1
11/06/2020 07:00	1.4	12.0	2,099.5	0.9	6.30	1	1	1
11/06/2020 08:00	0.8	13.9	1,428.8	0.7	2.90	1	1	0
11/06/2020 09:00	0.8	13.9	1,347.2	0.7	2.70	1	1	0
11/06/2020 10:00	0.8	13.9	1,318.4	0.7	2.60	1	1	0
11/06/2020 11:00	0.8	13.9	1,299.4	0.7	2.60	1	1	0
11/06/2020 12:00	1.0	13.9	1,433.6	0.8	4.30	1	1	0
11/06/2020 13:00	1.0	13.9	1,412.2	0.8	4.20	1	1	0
11/06/2020 14:00	0.9	13.9	1,332.7	0.8	4.00	1	1	0
11/06/2020 15:00	1.2	13.2	1,832.6	0.9	5.50	1	1	1
11/06/2020 16:00	1.4	11.9	2,142.0	0.9	6.40	1	1	1
11/06/2020 17:00	1.4	11.8	2,152.8	0.9	6.50	1	1	1
11/06/2020 18:00	1.4	11.8	2,162.2	0.9	6.50	1	1	1
11/06/2020 19:00	1.3	12.5	2,011.8	0.9	6.00	1	1	1
11/06/2020 20:00	1.2	12.8	1,937.7	0.9	5.80	1	1	1
11/06/2020 21:00	0.9	13.8	1,534.8	0.7	4.60	1	1	0
11/06/2020 22:00	1.1	13.6	1,751.2	0.9	5.30	1	1	1
11/06/2020 23:00	1.3	12.6	1,998.6	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.1	1,770.5	0.9	124.20 #	24 #	24 #	14 #
Minimum:	0.8	11.8	1,299.4	0.7	2.60	1	1	0
Maximum:	1.6	13.9	2,162.2	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2020 00:00	1.2	13.0	1,915.2	0.9	5.70	1	1	1
11/07/2020 01:00	1.0	13.8	1,690.1	0.8	5.10	1	1	0
11/07/2020 02:00	1.1	13.6	1,724.6	0.9	5.20	1	1	1
11/07/2020 03:00	1.2	13.0	1,931.8	0.9	5.80	1	1	1
11/07/2020 04:00	1.3	13.0	1,924.6	1.0	7.70	1	1	1
11/07/2020 05:00	0.8	13.8	1,645.2	0.7	3.30	1	1	0
11/07/2020 06:00	1.0	13.8	1,613.7	0.8	4.80	1	1	0
11/07/2020 07:00	0.9	13.8	1,596.3	0.7	4.80	1	1	0
11/07/2020 08:00	0.0	13.8	1,659.6	0.0	0.00	1	1	0
11/07/2020 09:00	0.0	13.8	1,558.0	0.0	0.00	1	1	0
11/07/2020 10:00	0.0	13.9	1,414.6	0.0	0.00	1	1	0
11/07/2020 11:00	0.0	13.8	1,400.9	0.0	0.00	1	1	0
11/07/2020 12:00	0.0	13.8	1,582.3	0.0	0.00	1	1	0
11/07/2020 13:00	0.0	13.8	1,489.2	0.0	0.00	1	1	0
11/07/2020 14:00	0.0	13.8	1,480.7	0.0	0.00	1	1	0
11/07/2020 15:00	0.1	13.8	1,555.7	0.1	0.00	1	1	1
11/07/2020 16:00	0.1	12.3	2,064.3	0.1	0.00	1	1	1
11/07/2020 17:00	0.0	11.9	2,137.0	0.0	0.00	1	1	1
11/07/2020 18:00	0.0	12.1	2,069.1	0.0	0.00	1	1	1
11/07/2020 19:00	0.0	12.3	2,053.4	0.0	0.00	1	1	1
11/07/2020 20:00	0.0	12.6	1,959.0	0.0	0.00	1	1	1
11/07/2020 21:00	0.0	0.0	1,580.6	0.0	0.00	1	1	0
11/07/2020 22:00	1.1	12.8	1,827.7	0.8	5.50	1	1	1
11/07/2020 23:00	1.4	11.9	2,113.8	0.9	6.30	1	1	1
Average/Sum#:	0.5	13.2	1,749.5	0.4	54.20 #	24 #	24 #	12 #
Minimum:	0.0	11.9	1,400.9	0.0	0.00	1	1	0
Maximum:	1.4	13.9	2,137.0	1.0	7.70	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	1.3	12.5	1,977.1	0.9	5.90	1	1	1
11/08/2020 01:00	0.7	13.7	1,578.5	0.6	3.20	1	1	1
11/08/2020 02:00	0.8	13.7	1,561.9	0.7	3.10	1	1	1
11/08/2020 03:00	1.3	12.9	1,930.9	1.0	7.70	1	1	1
11/08/2020 04:00	1.2	12.9	1,917.7	0.9	5.80	1	1	1
11/08/2020 05:00	0.7	13.7	1,689.1	0.6	3.40	1	1	0
11/08/2020 06:00	0.7	13.7	1,655.8	0.6	3.30	1	1	0
11/08/2020 07:00	0.7	13.7	1,579.4	0.6	3.20	1	1	0
11/08/2020 08:00	0.8	13.7	1,663.9	0.7	3.30	1	1	0
11/08/2020 09:00	0.8	13.7	1,661.0	0.7	3.30	1	1	0
11/08/2020 10:00	0.8	13.8	1,701.4	0.7	3.40	1	1	0
11/08/2020 11:00	0.7	13.8	1,552.2	0.6	3.10	1	1	0
11/08/2020 12:00	0.7	13.8	1,444.4	0.6	2.90	1	1	0
11/08/2020 13:00	0.8	13.8	1,664.0	0.7	3.30	1	1	0
11/08/2020 14:00	0.8	13.8	1,670.4	0.7	3.30	1	1	0
11/08/2020 15:00	0.8	13.8	1,694.5	0.7	3.40	1	1	0
11/08/2020 16:00	1.1	13.1	1,853.1	0.8	5.60	1	1	1
11/08/2020 17:00	1.4	11.7	2,195.3	0.9	6.60	1	1	1
11/08/2020 18:00	1.3	12.1	2,098.5	0.9	6.30	1	1	1
11/08/2020 19:00	1.3	12.2	2,058.7	0.9	6.20	1	1	1
11/08/2020 20:00	0.7	13.7	1,667.7	0.6	3.30	1	1	0
11/08/2020 21:00	0.7	13.7	1,594.7	0.6	3.20	1	1	0
11/08/2020 22:00	1.0	13.3	1,821.2	0.8	5.50	1	1	1
11/08/2020 23:00	1.3	12.1	2,118.9	0.9	6.40	1	1	1
Average/Sum#:	0.9	13.3	1,764.6	0.7	104.70 #	24 #	24 #	11 #
Minimum:	0.7	11.7	1,444.4	0.6	2.90	1	1	0
Maximum:	1.4	13.8	2,195.3	1.0	7.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2020 00:00	1.2	12.8	1,941.3	0.9	5.80	1	1	1
11/09/2020 01:00	0.7	13.7	1,534.4	0.6	3.10	1	1	0
11/09/2020 02:00	0.6	13.8	1,305.0	0.5	2.60	1	1	0
11/09/2020 03:00	0.6	13.8	1,321.4	0.5	2.60	1	1	0
11/09/2020 04:00	1.0	13.2	1,766.4	0.8	5.30	1	1	1
11/09/2020 05:00	1.4	11.8	2,179.0	0.9	6.50	1	1	1
11/09/2020 06:00	1.4	11.5	2,274.0	0.9	6.80	1	1	1
11/09/2020 07:00	1.3	12.3	2,093.1	0.9	6.30	1	1	1
11/09/2020 08:00	1.2	12.9	1,947.9	0.9	5.80	1	1	1
11/09/2020 09:00	0.7	13.8	1,525.6	0.6	3.10	1	1	0
11/09/2020 10:00	0.8	13.8	1,551.7	0.7	3.10	1	1	0
11/09/2020 11:00	0.7	13.8	1,448.0	0.6	2.90	1	1	0
11/09/2020 12:00	0.8	13.8	1,479.3	0.7	3.00	1	1	0
11/09/2020 13:00	0.7	13.8	1,419.4	0.6	2.80	1	1	0
11/09/2020 14:00	0.8	13.8	1,625.1	0.7	3.30	1	1	0
11/09/2020 15:00	1.0	13.3	1,815.6	0.8	5.40	1	1	1
11/09/2020 16:00	1.3	12.4	2,049.4	0.9	6.10	1	1	1
11/09/2020 17:00	1.3	12.3	2,076.2	0.9	6.20	1	1	1
11/09/2020 18:00	1.3	12.1	2,123.0	0.9	6.40	1	1	1
11/09/2020 19:00	1.3	12.1	2,127.6	0.9	6.40	1	1	1
11/09/2020 20:00	1.4	11.6	2,243.7	0.9	6.70	1	1	1
11/09/2020 21:00	1.3	11.7	2,201.7	0.8	6.60	1	1	1
11/09/2020 22:00	1.3	12.3	2,080.3	0.9	6.20	1	1	1
11/09/2020 23:00	1.3	12.6	2,039.9	0.9	6.10	1	1	1
Average/Sum#:	1.1	12.9	1,840.4	0.8	119.10 #	24 #	24 #	15 #
Minimum:	0.6	11.5	1,305.0	0.5	2.60	1	1	0
Maximum:	1.4	13.8	2,274.0	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	1.3	12.6	2,047.2	0.9	6.10	1	1	1
11/10/2020 01:00	1.1	12.9	1,947.2	0.8	5.80	1	1	1
11/10/2020 02:00	0.7	13.7	1,687.3	0.6	3.40	1	1	0
11/10/2020 03:00	0.9	13.4	1,822.5	0.7	5.50	1	1	1
11/10/2020 04:00	1.3	12.7	2,019.9	0.9	6.10	1	1	1
11/10/2020 05:00	1.1	12.6	2,037.0	0.8	6.10	1	1	1
11/10/2020 06:00	1.3	12.6	2,050.0	0.9	6.20	1	1	1
11/10/2020 07:00	1.2	12.8	2,018.1	0.9	6.10	1	1	1
11/10/2020 08:00	1.1	13.0	1,953.1	0.8	5.90	1	1	1
11/10/2020 09:00	0.8	13.7	1,655.9	0.7	3.30	1	1	0
11/10/2020 10:00	0.8	13.7	1,664.5	0.7	3.30	1	1	0
11/10/2020 11:00	0.6	13.8	1,392.8	0.5	2.80	1	1	0
11/10/2020 12:00	0.8	13.8	1,511.0	0.7	3.00	1	1	0
11/10/2020 13:00	0.8	13.8	1,530.4	0.7	3.10	1	1	0
11/10/2020 14:00	0.7	13.8	1,412.2	0.6	2.80	1	1	0
11/10/2020 15:00	0.9	13.5	1,667.2	0.7	5.00	1	1	1
11/10/2020 16:00	1.3	12.5	2,014.8	0.9	6.00	1	1	1
11/10/2020 17:00	1.3	12.1	2,112.6	0.9	6.30	1	1	1
11/10/2020 18:00	1.4	11.5	2,234.0	0.9	6.70	1	1	1
11/10/2020 19:00	1.3	11.5	2,222.4	0.8	6.70	1	1	1
11/10/2020 20:00	1.3	11.9	2,150.5	0.9	6.50	1	1	1
11/10/2020 21:00	1.3	12.0	2,128.9	0.9	6.40	1	1	1
11/10/2020 22:00	1.3	12.3	2,079.9	0.9	6.20	1	1	1
11/10/2020 23:00	1.3	12.4	2,061.4	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.9	1,892.5	0.8	125.50 #	24 #	24 #	17 #
Minimum:	0.6	11.5	1,392.8	0.5	2.80	1	1	0
Maximum:	1.4	13.8	2,234.0	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	1.3	12.4	2,060.5	0.9	6.20	1	1	1
11/11/2020 01:00	1.2	12.9	1,941.0	0.9	5.80	1	1	1
11/11/2020 02:00	0.7	13.7	1,590.7	0.6	3.20	1	1	0
11/11/2020 03:00	1.0	13.3	1,846.9	0.8	5.50	1	1	1
11/11/2020 04:00	1.3	12.6	2,034.3	0.9	6.10	1	1	1
11/11/2020 05:00	1.3	12.3	2,072.8	0.9	6.20	1	1	1
11/11/2020 06:00	1.3	11.9	2,171.3	0.9	6.50	1	1	1
11/11/2020 07:00	1.2	12.7	1,996.5	0.9	6.00	1	1	1
11/11/2020 08:00	0.7	13.7	1,684.4	0.6	3.40	1	1	0
11/11/2020 09:00	0.7	13.7	1,682.7	0.6	3.40	1	1	0
11/11/2020 10:00	0.7	13.7	1,653.9	0.6	3.30	1	1	0
11/11/2020 11:00	0.8	13.7	1,571.0	0.7	3.10	1	1	0
11/11/2020 12:00	0.8	13.7	1,657.8	0.7	3.30	1	1	0
11/11/2020 13:00	0.7	13.8	1,528.0	0.6	3.10	1	1	0
11/11/2020 14:00	0.8	13.7	1,688.7	0.7	3.40	1	1	0
11/11/2020 15:00	0.7	13.8	1,385.8	0.6	2.80	1	1	0
11/11/2020 16:00	1.2	13.0	1,869.7	0.9	5.60	1	1	1
11/11/2020 17:00	1.3	12.4	2,030.0	0.9	6.10	1	1	1
11/11/2020 18:00	1.3	12.1	2,091.9	0.9	6.30	1	1	1
11/11/2020 19:00	1.3	12.3	2,066.1	0.9	6.20	1	1	1
11/11/2020 20:00	1.3	12.5	2,017.6	0.9	6.10	1	1	1
11/11/2020 21:00	0.7	13.7	1,665.5	0.6	3.30	1	1	0
11/11/2020 22:00	1.0	13.3	1,829.8	0.8	5.50	1	1	1
11/11/2020 23:00	1.3	12.6	2,034.8	0.9	6.10	1	1	1
Average/Sum#:	1.0	13.1	1,840.5	0.8	116.50 #	24 #	24 #	14 #
Minimum:	0.7	11.9	1,385.8	0.6	2.80	1	1	0
Maximum:	1.3	13.8	2,171.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2020 00:00	1.3	12.5	2,045.9	0.9	6.10	1	1	1
11/12/2020 01:00	1.1	13.1	1,919.8	0.8	5.80	1	1	1
11/12/2020 02:00	0.7	13.7	1,570.9	0.6	3.10	1	1	0
11/12/2020 03:00	0.9	13.5	1,698.9	0.7	5.10	1	1	1
11/12/2020 04:00	1.3	12.6	2,044.8	0.9	6.10	1	1	1
11/12/2020 05:00	1.4	12.2	2,081.5	0.9	6.20	1	1	1
11/12/2020 06:00	1.4	11.6	2,246.7	0.9	6.70	1	1	1
11/12/2020 07:00	1.3	12.2	2,106.4	0.9	6.30	1	1	1
11/12/2020 08:00	0.7	13.7	1,630.1	0.6	3.30	1	1	0
11/12/2020 09:00	0.8	13.7	1,638.6	0.7	3.30	1	1	0
11/12/2020 10:00	0.8	13.7	1,678.2	0.7	3.40	1	1	0
11/12/2020 11:00	0.7	13.7	1,609.2	0.6	3.20	1	1	0
11/12/2020 12:00	0.8	13.7	1,697.4	0.7	3.40	1	1	0
11/12/2020 13:00	0.7	13.8	1,577.7	0.6	3.20	1	1	0
11/12/2020 14:00	0.8	13.8	1,568.2	0.7	3.10	1	1	0
11/12/2020 15:00	0.9	13.5	1,691.9	0.7	5.10	1	1	1
11/12/2020 16:00	1.3	12.2	2,070.4	0.9	6.20	1	1	1
11/12/2020 17:00	1.3	12.1	2,091.8	0.9	6.30	1	1	1
11/12/2020 18:00	1.3	12.0	2,114.3	0.9	6.30	1	1	1
11/12/2020 19:00	1.3	11.9	2,140.2	0.9	6.40	1	1	1
11/12/2020 20:00	1.3	12.3	2,030.4	0.9	6.10	1	1	1
11/12/2020 21:00	0.8	13.7	1,665.3	0.7	3.30	1	1	0
11/12/2020 22:00	1.0	13.3	1,829.8	0.8	5.50	1	1	1
11/12/2020 23:00	1.3	12.5	2,038.6	0.9	6.10	1	1	1
Average/Sum#:	1.1	13.0	1,866.1	0.8	119.60 #	24 #	24 #	15 #
Minimum:	0.7	11.6	1,568.2	0.6	3.10	1	1	0
Maximum:	1.4	13.8	2,246.7	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2020 00:00	1.2	13.0	1,924.6	0.9	5.80	1	1	1
11/13/2020 01:00	0.9	13.6	1,503.0	0.7	4.50	1	1	1
11/13/2020 02:00	0.6	13.8	1,295.4	0.5	2.60	1	1	0
11/13/2020 03:00	0.7	13.7	1,362.8	0.6	2.70	1	1	0
11/13/2020 04:00	0.7	13.7	1,325.7	0.6	2.70	1	1	0
11/13/2020 05:00	0.9	13.7	1,593.2	0.7	4.80	1	1	0
11/13/2020 06:00	0.9	13.7	1,726.3	0.7	5.20	1	1	0
11/13/2020 07:00	1.1	13.3	1,825.5	0.9	5.50	1	1	1
11/13/2020 08:00	1.1	12.9	1,870.3	0.8	5.60	1	1	1
11/13/2020 09:00	0.8	13.7	1,682.3	0.7	3.40	1	1	0
11/13/2020 10:00	0.8	13.7	1,682.1	0.7	3.40	1	1	0
11/13/2020 11:00	0.8	13.7	1,657.5	0.7	3.30	1	1	0
11/13/2020 12:00	0.8	13.7	1,536.3	0.7	3.10	1	1	0
11/13/2020 13:00	0.9	13.7	1,655.6	0.7	5.00	1	1	0
11/13/2020 14:00	0.8	13.7	1,664.2	0.7	3.30	1	1	0
11/13/2020 15:00	1.1	13.2	1,769.9	0.8	5.30	1	1	1
11/13/2020 16:00	1.4	11.9	2,098.0	0.9	6.30	1	1	1
11/13/2020 17:00	1.3	12.0	2,071.9	0.9	6.20	1	1	1
11/13/2020 18:00	1.3	12.2	2,054.7	0.9	6.20	1	1	1
11/13/2020 19:00	1.2	12.8	1,924.3	0.9	5.80	1	1	1
11/13/2020 20:00	0.8	13.6	1,687.3	0.6	3.40	1	1	0
11/13/2020 21:00	0.9	13.4	1,692.1	0.7	5.10	1	1	1
11/13/2020 22:00	1.3	12.4	2,032.4	0.9	6.10	1	1	1
11/13/2020 23:00	1.0	13.3	1,645.2	0.8	4.90	1	1	1
Average/Sum#:	1.0	13.3	1,720.0	0.8	110.20 #	24 #	24 #	12 #
Minimum:	0.6	11.9	1,295.4	0.5	2.60	1	1	0
Maximum:	1.4	13.8	2,098.0	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	0.7	13.7	1,360.0	0.6	2.70	1	1	0
11/14/2020 01:00	0.7	13.7	1,360.4	0.6	2.70	1	1	0
11/14/2020 02:00	0.7	13.7	1,353.7	0.6	2.70	1	1	0
11/14/2020 03:00	0.7	13.7	1,359.9	0.6	2.70	1	1	0
11/14/2020 04:00	0.7	13.8	1,349.6	0.6	2.70	1	1	0
11/14/2020 05:00	0.9	13.6	1,663.6	0.7	5.00	1	1	0
11/14/2020 06:00	0.7	13.7	1,519.5	0.6	3.00	1	1	0
11/14/2020 07:00	0.8	13.7	1,605.7	0.7	3.20	1	1	0
11/14/2020 08:00	0.8	13.6	1,690.7	0.6	3.40	1	1	0
11/14/2020 09:00	0.8	13.6	1,682.6	0.6	3.40	1	1	0
11/14/2020 10:00	0.8	13.7	1,691.2	0.7	3.40	1	1	0
11/14/2020 11:00	0.8	13.7	1,696.5	0.7	3.40	1	1	0
11/14/2020 12:00	0.8	13.7	1,687.0	0.7	3.40	1	1	0
11/14/2020 13:00	0.8	13.7	1,688.9	0.7	3.40	1	1	0
11/14/2020 14:00	0.8	13.7	1,659.1	0.7	3.30	1	1	0
11/14/2020 15:00	0.9	13.5	1,707.7	0.7	5.10	1	1	1
11/14/2020 16:00	1.3	12.4	2,043.4	0.9	6.10	1	1	1
11/14/2020 17:00	1.3	12.3	2,064.1	0.9	6.20	1	1	1
11/14/2020 18:00	1.3	12.3	2,064.6	0.9	6.20	1	1	1
11/14/2020 19:00	1.3	12.5	2,010.5	0.9	6.00	1	1	1
11/14/2020 20:00	0.8	13.7	1,668.5	0.7	3.30	1	1	0
11/14/2020 21:00	1.0	13.3	1,831.7	0.8	5.50	1	1	1
11/14/2020 22:00	1.3	12.5	2,043.4	0.9	6.10	1	1	1
11/14/2020 23:00	1.1	12.9	1,956.0	0.8	5.90	1	1	1
Average/Sum#:	0.9	13.4	1,698.3	0.7	98.80 #	24 #	24 #	8 #
Minimum:	0.7	12.3	1,349.6	0.6	2.70	1	1	0
Maximum:	1.3	13.8	2,064.6	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2020 00:00	1.3	12.5	2,037.6	0.9	6.10	1	1	1
11/15/2020 01:00	1.2	12.9	1,938.8	0.9	5.80	1	1	1
11/15/2020 02:00	0.8	13.7	1,624.8	0.7	3.20	1	1	0
11/15/2020 03:00	0.9	13.5	1,701.5	0.7	5.10	1	1	1
11/15/2020 04:00	1.3	12.6	2,018.8	0.9	6.10	1	1	1
11/15/2020 05:00	0.9	13.1	1,926.5	0.7	5.80	1	1	1
11/15/2020 06:00	0.7	13.7	1,656.2	0.6	3.30	1	1	0
11/15/2020 07:00	0.8	13.7	1,484.6	0.7	3.00	1	1	0
11/15/2020 08:00	0.9	13.7	1,669.9	0.7	5.00	1	1	0
11/15/2020 09:00	0.9	13.7	1,689.5	0.7	5.10	1	1	0
11/15/2020 10:00	0.9	13.7	1,708.3	0.7	5.10	1	1	0
11/15/2020 11:00	0.9	13.7	1,698.8	0.7	5.10	1	1	0
11/15/2020 12:00	0.9	13.7	1,694.5	0.7	5.10	1	1	0
11/15/2020 13:00	0.8	13.7	1,696.4	0.7	3.40	1	1	0
11/15/2020 14:00	0.8	13.7	1,690.7	0.7	3.40	1	1	0
11/15/2020 15:00	0.8	13.7	1,462.4	0.7	2.90	1	1	0
11/15/2020 16:00	0.8	13.7	1,572.8	0.7	3.10	1	1	0
11/15/2020 17:00	0.8	13.7	1,573.2	0.7	3.10	1	1	0
11/15/2020 18:00	0.8	13.7	1,605.1	0.7	3.20	1	1	0
11/15/2020 19:00	0.8	13.7	1,637.7	0.7	3.30	1	1	0
11/15/2020 20:00	1.0	13.3	1,824.8	0.8	5.50	1	1	1
11/15/2020 21:00	1.2	12.8	1,901.8	0.9	5.70	1	1	1
11/15/2020 22:00	0.9	13.5	1,746.4	0.7	5.20	1	1	1
11/15/2020 23:00	1.3	12.5	2,029.5	0.9	6.10	1	1	1
Average/Sum#:	0.9	13.4	1,732.9	0.7	108.70 #	24 #	24 #	9 #
Minimum:	0.7	12.5	1,462.4	0.6	2.90	1	1	0
Maximum:	1.3	13.7	2,037.6	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2020 00:00	1.1	13.1	1,826.1	0.8	5.50	1	1	1
11/16/2020 01:00	0.6	13.8	1,301.4	0.5	2.60	1	1	0
11/16/2020 02:00	0.6	13.8	1,294.8	0.5	2.60	1	1	0
11/16/2020 03:00	0.6	13.8	1,293.8	0.5	2.60	1	1	0
11/16/2020 04:00	0.9	13.6	1,687.7	0.7	5.10	1	1	1
11/16/2020 05:00	0.0	12.3	2,034.0	0.0	0.00	1	1	1
11/16/2020 06:00	0.0	12.1	2,089.2	0.0	0.00	1	1	1
11/16/2020 07:00	0.0	12.4	1,988.0	0.0	0.00	1	1	1
11/16/2020 08:00	0.9	13.7	1,695.1	0.7	5.10	1	1	0
11/16/2020 09:00	0.8	13.7	1,640.3	0.7	3.30	1	1	0
11/16/2020 10:00	0.9	13.7	1,681.2	0.7	5.00	1	1	0
11/16/2020 11:00	0.9	13.7	1,695.0	0.7	5.10	1	1	0
11/16/2020 12:00	0.9	13.7	1,683.5	0.7	5.10	1	1	0
11/16/2020 13:00	0.9	13.7	1,684.8	0.7	5.10	1	1	0
11/16/2020 14:00	0.9	13.7	1,629.0	0.7	4.90	1	1	0
11/16/2020 15:00	1.0	13.4	1,723.3	0.8	5.20	1	1	1
11/16/2020 16:00	1.4	12.2	2,040.9	0.9	6.10	1	1	1
11/16/2020 17:00	1.4	11.9	2,111.4	0.9	6.30	1	1	1
11/16/2020 18:00	1.4	11.7	2,140.3	0.9	6.40	1	1	1
11/16/2020 19:00	1.4	11.8	2,128.9	0.9	6.40	1	1	1
11/16/2020 20:00	1.4	11.8	2,122.4	0.9	6.40	1	1	1
11/16/2020 21:00	1.3	12.1	2,072.0	0.9	6.20	1	1	1
11/16/2020 22:00	1.3	12.1	2,084.2	0.9	6.30	1	1	1
11/16/2020 23:00	1.3	12.3	2,056.5	0.9	6.20	1	1	1
Average/Sum#:	1.0	12.9	1,821.0	0.8	107.50 #	24 #	24 #	14 #
Minimum:	0.6	11.7	1,293.8	0.5	2.60	1	1	0
Maximum:	1.4	13.8	2,140.3	0.9	6.40	1	1	1
%SI	12.50	0.00	0.00	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	1.3	12.2	2,059.7	0.9	6.20	1	1	1
11/17/2020 01:00	1.3	12.4	1,992.0	0.9	6.00	1	1	1
11/17/2020 02:00	0.8	13.7	1,542.4	0.7	3.10	1	1	0
11/17/2020 03:00	0.9	13.7	1,529.5	0.7	4.60	1	1	0
11/17/2020 04:00	1.0	13.5	1,732.3	0.8	5.20	1	1	1
11/17/2020 05:00	1.3	12.2	2,051.1	0.9	6.20	1	1	1
11/17/2020 06:00	1.4	11.8	2,150.8	0.9	6.50	1	1	1
11/17/2020 07:00	1.3	12.4	2,002.6	0.9	6.00	1	1	1
11/17/2020 08:00	0.8	13.7	1,671.8	0.7	3.30	1	1	0
11/17/2020 09:00	0.8	13.7	1,569.2	0.7	3.10	1	1	0
11/17/2020 10:00	0.8	13.7	1,557.1	0.7	3.10	1	1	0
11/17/2020 11:00	0.9	13.6	1,699.5	0.7	5.10	1	1	0
11/17/2020 12:00	0.8	13.7	1,469.9	0.7	2.90	1	1	0
11/17/2020 13:00	0.9	13.6	1,576.0	0.7	4.70	1	1	0
11/17/2020 14:00	0.9	13.6	1,608.8	0.7	4.80	1	1	0
11/17/2020 15:00	1.2	13.0	1,825.2	0.9	5.50	1	1	1
11/17/2020 16:00	1.4	11.7	2,130.3	0.9	6.40	1	1	1
11/17/2020 17:00	1.4	11.5	2,163.1	0.9	6.50	1	1	1
11/17/2020 18:00	1.4	11.6	2,164.5	0.9	6.50	1	1	1
11/17/2020 19:00	1.4	11.7	2,130.3	0.9	6.40	1	1	1
11/17/2020 20:00	1.3	12.0	2,072.1	0.9	6.20	1	1	1
11/17/2020 21:00	1.3	12.0	2,071.0	0.9	6.20	1	1	1
11/17/2020 22:00	1.4	12.0	2,074.9	0.9	6.20	1	1	1
11/17/2020 23:00	1.3	12.5	1,982.2	0.9	5.90	1	1	1
Average/Sum#:	1.1	12.7	1,867.8	0.8	126.60 #	24 #	24 #	15 #
Minimum:	0.8	11.5	1,469.9	0.7	2.90	1	1	0
Maximum:	1.4	13.7	2,164.5	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2020 00:00	1.3	12.1	2,066.0	0.9	6.20	1	1	1
11/18/2020 01:00	1.1	12.9	1,822.8	0.8	5.50	1	1	1
11/18/2020 02:00	0.7	13.7	1,405.2	0.6	2.80	1	1	0
11/18/2020 03:00	0.7	13.7	1,304.1	0.6	2.60	1	1	0
11/18/2020 04:00	1.0	13.4	1,700.6	0.8	5.10	1	1	1
11/18/2020 05:00	1.4	12.0	2,069.5	0.9	6.20	1	1	1
11/18/2020 06:00	1.3	11.7	2,134.3	0.8	6.40	1	1	1
11/18/2020 07:00	1.3	12.4	1,983.4	0.9	6.00	1	1	1
11/18/2020 08:00	0.8	13.7	1,518.7	0.7	3.00	1	1	0
11/18/2020 09:00	0.9	13.7	1,522.7	0.7	4.60	1	1	0
11/18/2020 10:00	0.9	13.7	1,584.9	0.7	4.80	1	1	0
11/18/2020 11:00	0.9	13.7	1,694.7	0.7	5.10	1	1	0
11/18/2020 12:00	0.8	13.7	1,674.7	0.7	3.30	1	1	0
11/18/2020 13:00	0.8	13.8	1,591.5	0.7	3.20	1	1	0
11/18/2020 14:00	0.8	13.8	1,522.5	0.7	3.00	1	1	0
11/18/2020 15:00	0.9	13.5	1,712.2	0.7	5.10	1	1	1
11/18/2020 16:00	1.3	12.6	2,012.3	0.9	6.00	1	1	1
11/18/2020 17:00	1.3	12.3	2,061.3	0.9	6.20	1	1	1
11/18/2020 18:00	1.3	12.1	2,112.2	0.9	6.30	1	1	1
11/18/2020 19:00	1.3	12.6	1,975.3	0.9	5.90	1	1	1
11/18/2020 20:00	1.2	12.9	1,940.7	0.9	5.80	1	1	1
11/18/2020 21:00	1.2	12.9	1,943.0	0.9	5.80	1	1	1
11/18/2020 22:00	1.2	12.9	1,949.8	0.9	5.80	1	1	1
11/18/2020 23:00	1.2	13.0	1,945.2	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.0	1,802.0	0.8	120.50 #	24 #	24 #	15 #
Minimum:	0.7	11.7	1,304.1	0.6	2.60	1	1	0
Maximum:	1.4	13.8	2,134.3	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2020 00:00	1.2	13.0	1,922.1	0.9	5.80	1	1	1
11/19/2020 01:00	0.8	13.7	1,533.2	0.7	3.10	1	1	0
11/19/2020 02:00	0.7	13.8	1,377.0	0.6	2.80	1	1	0
11/19/2020 03:00	0.6	13.8	1,306.5	0.5	2.60	1	1	0
11/19/2020 04:00	0.6	13.8	1,302.7	0.5	2.60	1	1	0
11/19/2020 05:00	0.8	13.7	1,557.0	0.7	3.10	1	1	1
11/19/2020 06:00	1.2	12.8	2,016.0	0.9	6.00	1	1	1
11/19/2020 07:00	1.2	12.9	1,970.0	0.9	5.90	1	1	1
11/19/2020 08:00	0.8	13.7	1,608.5	0.7	3.20	1	1	0
11/19/2020 09:00	0.9	13.7	1,671.0	0.7	5.00	1	1	0
11/19/2020 10:00	0.9	13.7	1,699.0	0.7	5.10	1	1	0
11/19/2020 11:00	0.8	13.7	1,599.0	0.7	3.20	1	1	0
11/19/2020 12:00	0.8	13.7	1,703.4	0.7	3.40	1	1	0
11/19/2020 13:00	0.8	13.8	1,652.7	0.7	3.30	1	1	0
11/19/2020 14:00	0.8	13.8	1,687.2	0.7	3.40	1	1	0
11/19/2020 15:00	0.6	13.9	1,322.7	0.5	2.60	1	1	0
11/19/2020 16:00	0.8	13.8	1,601.2	0.7	3.20	1	1	0
11/19/2020 17:00	0.8	13.7	1,720.9	0.7	3.40	1	1	1
11/19/2020 18:00	1.3	12.4	2,068.3	0.9	6.20	1	1	1
11/19/2020 19:00	1.3	12.0	2,141.6	0.9	6.40	1	1	1
11/19/2020 20:00	1.3	12.2	2,102.1	0.9	6.30	1	1	1
11/19/2020 21:00	1.2	12.6	2,011.4	0.9	6.00	1	1	1
11/19/2020 22:00	1.3	12.4	2,064.2	0.9	6.20	1	1	1
11/19/2020 23:00	1.2	12.9	1,956.2	0.9	5.90	1	1	1
Average/Sum#:	0.9	13.3	1,733.1	0.7	104.70 #	24 #	24 #	11 #
Minimum:	0.6	12.0	1,302.7	0.5	2.60	1	1	0
Maximum:	1.3	13.9	2,141.6	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	1.3	12.4	2,054.1	0.9	6.20	1	1	1
11/20/2020 01:00	1.2	13.0	1,923.3	0.9	5.80	1	1	1
11/20/2020 02:00	0.8	13.8	1,595.7	0.7	3.20	1	1	0
11/20/2020 03:00	0.8	13.7	1,595.1	0.7	3.20	1	1	0
11/20/2020 04:00	0.9	13.5	1,740.2	0.7	5.20	1	1	1
11/20/2020 05:00	1.3	12.2	2,079.1	0.9	6.20	1	1	1
11/20/2020 06:00	1.3	12.1	2,132.9	0.9	6.40	1	1	1
11/20/2020 07:00	1.3	12.2	2,097.1	0.9	6.30	1	1	1
11/20/2020 08:00	1.3	12.5	2,033.6	0.9	6.10	1	1	1
11/20/2020 09:00	1.3	12.6	1,986.1	0.9	6.00	1	1	1
11/20/2020 10:00	0.8	13.8	1,667.7	0.7	3.30	1	1	0
11/20/2020 11:00	0.7	13.8	1,590.4	0.6	3.20	1	1	0
11/20/2020 12:00	0.8	13.8	1,650.0	0.7	3.30	1	1	0
11/20/2020 13:00	0.8	13.8	1,515.2	0.7	3.00	1	1	0
11/20/2020 14:00	0.8	13.8	1,550.5	0.7	3.10	1	1	0
11/20/2020 15:00	1.1	13.2	1,838.1	0.8	5.50	1	1	1
11/20/2020 16:00	1.3	12.3	2,090.9	0.9	6.30	1	1	1
11/20/2020 17:00	1.4	12.1	2,129.0	0.9	6.40	1	1	1
11/20/2020 18:00	1.3	12.0	2,123.5	0.9	6.40	1	1	1
11/20/2020 19:00	1.3	12.0	2,124.6	0.9	6.40	1	1	1
11/20/2020 20:00	1.3	12.0	2,132.9	0.9	6.40	1	1	1
11/20/2020 21:00	1.3	12.0	2,122.3	0.9	6.40	1	1	1
11/20/2020 22:00	1.3	12.0	2,133.8	0.9	6.40	1	1	1
11/20/2020 23:00	1.3	12.3	2,078.8	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.8	1,916.0	0.8	126.90 #	24 #	24 #	17 #
Minimum:	0.7	12.0	1,515.2	0.6	3.00	1	1	0
Maximum:	1.4	13.8	2,133.8	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2020 00:00	1.3	12.4	2,063.4	0.9	6.20	1	1	1
11/21/2020 01:00	1.2	12.9	1,949.7	0.9	5.80	1	1	1
11/21/2020 02:00	1.2	13.0	1,919.4	0.9	5.80	1	1	1
11/21/2020 03:00	0.8	13.8	1,752.8	0.7	3.50	1	1	0
11/21/2020 04:00	1.1	13.2	1,840.5	0.8	5.50	1	1	1
11/21/2020 05:00	1.4	12.1	2,102.9	0.9	6.30	1	1	1
11/21/2020 06:00	1.3	12.0	2,143.1	0.9	6.40	1	1	1
11/21/2020 07:00	0.7	13.5	1,622.5	0.6	3.20	1	1	1
11/21/2020 08:00	0.7	13.8	1,615.9	0.6	3.20	1	1	0
11/21/2020 09:00	0.7	13.8	1,622.1	0.6	3.20	1	1	0
11/21/2020 10:00	0.7	13.8	1,476.6	0.6	3.00	1	1	0
11/21/2020 11:00	0.7	13.8	1,672.2	0.6	3.30	1	1	0
11/21/2020 12:00	0.7	13.8	1,675.6	0.6	3.40	1	1	0
11/21/2020 13:00	0.8	13.8	1,697.4	0.7	3.40	1	1	0
11/21/2020 14:00	0.7	13.8	1,604.9	0.6	3.20	1	1	0
11/21/2020 15:00	1.1	13.2	1,850.8	0.8	5.60	1	1	1
11/21/2020 16:00	1.3	12.2	2,085.5	0.9	6.30	1	1	1
11/21/2020 17:00	1.3	12.1	2,116.5	0.9	6.30	1	1	1
11/21/2020 18:00	1.4	11.9	2,153.8	0.9	6.50	1	1	1
11/21/2020 19:00	1.4	12.0	2,144.2	0.9	6.40	1	1	1
11/21/2020 20:00	1.3	12.1	2,090.3	0.9	6.30	1	1	1
11/21/2020 21:00	0.9	13.7	1,686.8	0.7	5.10	1	1	0
11/21/2020 22:00	1.1	13.2	1,838.2	0.8	5.50	1	1	1
11/21/2020 23:00	1.3	12.3	2,079.8	0.9	6.20	1	1	1
Average/Sum#:	1.0	13.0	1,866.9	0.8	119.60 #	24 #	24 #	15 #
Minimum:	0.7	11.9	1,476.6	0.6	3.00	1	1	0
Maximum:	1.4	13.8	2,153.8	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	1.3	12.4	2,056.5	0.9	6.20	1	1	1
11/22/2020 01:00	1.1	13.0	1,806.1	0.8	5.40	1	1	1
11/22/2020 02:00	0.6	13.8	1,305.9	0.5	2.60	1	1	0
11/22/2020 03:00	0.7	13.8	1,363.8	0.6	2.70	1	1	0
11/22/2020 04:00	0.8	13.7	1,623.9	0.7	3.20	1	1	0
11/22/2020 05:00	1.1	13.1	1,844.5	0.8	5.50	1	1	1
11/22/2020 06:00	1.1	13.1	1,879.0	0.8	5.60	1	1	1
11/22/2020 07:00	0.7	13.7	1,518.2	0.6	3.00	1	1	0
11/22/2020 08:00	0.8	13.7	1,678.7	0.7	3.40	1	1	0
11/22/2020 09:00	0.8	13.7	1,691.0	0.7	3.40	1	1	0
11/22/2020 10:00	0.8	13.7	1,623.1	0.7	3.20	1	1	0
11/22/2020 11:00	0.8	13.7	1,674.4	0.7	3.30	1	1	0
11/22/2020 12:00	0.8	13.7	1,649.7	0.7	3.30	1	1	0
11/22/2020 13:00	0.8	13.7	1,644.2	0.7	3.30	1	1	0
11/22/2020 14:00	0.8	13.7	1,698.4	0.7	3.40	1	1	0
11/22/2020 15:00	1.1	13.2	1,838.0	0.8	5.50	1	1	1
11/22/2020 16:00	1.4	12.1	2,097.6	0.9	6.30	1	1	1
11/22/2020 17:00	1.3	12.0	2,112.3	0.9	6.30	1	1	1
11/22/2020 18:00	1.3	12.1	2,099.2	0.9	6.30	1	1	1
11/22/2020 19:00	1.3	12.2	2,044.1	0.9	6.10	1	1	1
11/22/2020 20:00	0.8	13.7	1,690.1	0.7	3.40	1	1	0
11/22/2020 21:00	1.1	13.1	1,856.5	0.8	5.60	1	1	1
11/22/2020 22:00	1.3	12.1	2,091.4	0.9	6.30	1	1	1
11/22/2020 23:00	1.1	13.0	1,856.3	0.8	5.60	1	1	1
Average/Sum#:	1.0	13.2	1,781.0	0.8	108.90 #	24 #	24 #	12 #
Minimum:	0.6	12.0	1,305.9	0.5	2.60	1	1	0
Maximum:	1.4	13.8	2,112.3	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2020 00:00	1.0	13.4	1,712.3	0.8	5.10	1	1	1
11/23/2020 01:00	1.2	12.9	1,912.4	0.9	5.70	1	1	1
11/23/2020 02:00	0.8	13.7	1,475.3	0.7	3.00	1	1	0
11/23/2020 03:00	0.7	13.7	1,385.9	0.6	2.80	1	1	0
11/23/2020 04:00	0.7	13.8	1,395.9	0.6	2.80	1	1	0
11/23/2020 05:00	0.9	13.7	1,708.4	0.7	5.10	1	1	0
11/23/2020 06:00	0.6	13.8	1,398.5	0.5	2.80	1	1	0
11/23/2020 07:00	0.8	13.7	1,696.7	0.7	3.40	1	1	0
11/23/2020 08:00	0.8	13.7	1,629.3	0.7	3.30	1	1	0
11/23/2020 09:00	0.8	13.7	1,660.5	0.7	3.30	1	1	0
11/23/2020 10:00	0.8	13.7	1,586.9	0.7	3.20	1	1	0
11/23/2020 11:00	0.8	13.7	1,669.8	0.7	3.30	1	1	0
11/23/2020 12:00	0.8	13.8	1,692.9	0.7	3.40	1	1	0
11/23/2020 13:00	0.8	13.8	1,646.7	0.7	3.30	1	1	0
11/23/2020 14:00	0.8	13.8	1,691.1	0.7	3.40	1	1	0
11/23/2020 15:00	1.0	13.5	1,764.4	0.8	5.30	1	1	1
11/23/2020 16:00	1.3	12.2	2,086.6	0.9	6.30	1	1	1
11/23/2020 17:00	1.3	12.1	2,106.2	0.9	6.30	1	1	1
11/23/2020 18:00	1.4	12.1	2,112.2	0.9	6.30	1	1	1
11/23/2020 19:00	1.2	12.6	1,964.2	0.9	5.90	1	1	1
11/23/2020 20:00	0.8	13.7	1,668.7	0.7	3.30	1	1	0
11/23/2020 21:00	0.9	13.5	1,700.0	0.7	5.10	1	1	1
11/23/2020 22:00	1.3	12.4	2,048.7	0.9	6.10	1	1	1
11/23/2020 23:00	1.2	12.7	1,972.8	0.9	5.90	1	1	1
Average/Sum#:	0.9	13.3	1,736.9	0.8	104.40 #	24 #	24 #	10 #
Minimum:	0.6	12.1	1,385.9	0.5	2.80	1	1	0
Maximum:	1.4	13.8	2,112.2	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2020 00:00	1.3	12.8	1,942.9	0.9	5.80	1	1	1
11/24/2020 01:00	0.8	13.7	1,560.7	0.7	3.10	1	1	0
11/24/2020 02:00	0.8	13.7	1,566.3	0.7	3.10	1	1	0
11/24/2020 03:00	0.8	13.7	1,582.6	0.7	3.20	1	1	0
11/24/2020 04:00	1.1	13.3	1,834.3	0.9	5.50	1	1	1
11/24/2020 05:00	1.3	12.2	2,092.5	0.9	6.30	1	1	1
11/24/2020 06:00	1.3	11.7	2,222.2	0.8	6.70	1	1	1
11/24/2020 07:00	1.3	12.0	2,148.1	0.9	6.40	1	1	1
11/24/2020 08:00	1.2	13.0	1,891.4	0.9	5.70	1	1	1
11/24/2020 09:00	0.8	13.7	1,689.6	0.7	3.40	1	1	0
11/24/2020 10:00	0.8	13.8	1,672.5	0.7	3.30	1	1	1
11/24/2020 11:00	0.8	13.8	1,683.7	0.7	3.40	1	1	0
11/24/2020 12:00	0.8	13.8	1,670.4	0.7	3.30	1	1	0
11/24/2020 13:00	0.8	13.8	1,680.2	0.7	3.40	1	1	0
11/24/2020 14:00	0.8	13.8	1,599.2	0.7	3.20	1	1	0
11/24/2020 15:00	0.9	13.6	1,576.8	0.7	4.70	1	1	1
11/24/2020 16:00	1.3	12.2	2,088.0	0.9	6.30	1	1	1
11/24/2020 17:00	1.3	12.1	2,124.5	0.9	6.40	1	1	1
11/24/2020 18:00	1.3	12.0	2,143.0	0.9	6.40	1	1	1
11/24/2020 19:00	1.3	11.9	2,167.3	0.9	6.50	1	1	1
11/24/2020 20:00	1.3	11.9	2,174.8	0.9	6.50	1	1	1
11/24/2020 21:00	1.3	12.1	2,145.0	0.9	6.40	1	1	1
11/24/2020 22:00	1.3	12.2	2,125.8	0.9	6.40	1	1	1
11/24/2020 23:00	1.3	12.4	2,076.0	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.9	1,894.1	0.8	121.60 #	24 #	24 #	16 #
Minimum:	0.8	11.7	1,560.7	0.7	3.10	1	1	0
Maximum:	1.3	13.8	2,222.2	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2020 00:00	1.3	12.4	2,077.0	0.9	6.20	1	1	1
11/25/2020 01:00	1.2	13.0	1,930.7	0.9	5.80	1	1	1
11/25/2020 02:00	0.8	13.7	1,572.2	0.7	3.10	1	1	0
11/25/2020 03:00	0.7	13.7	1,378.7	0.6	2.80	1	1	0
11/25/2020 04:00	0.8	13.7	1,566.3	0.7	3.10	1	1	1
11/25/2020 05:00	1.2	12.5	2,021.7	0.8	6.10	1	1	1
11/25/2020 06:00	1.2	12.7	2,015.8	0.9	6.00	1	1	1
11/25/2020 07:00	1.5	12.6	2,013.3	1.1	8.10	1	1	1
11/25/2020 08:00	0.9	13.7	1,677.1	0.7	5.00	1	1	0
11/25/2020 09:00	0.9	13.7	1,640.7	0.7	4.90	1	1	0
11/25/2020 10:00	0.8	13.7	1,702.9	0.7	3.40	1	1	0
11/25/2020 11:00	0.8	13.7	1,702.6	0.7	3.40	1	1	0
11/25/2020 12:00	0.8	13.8	1,699.7	0.7	3.40	1	1	0
11/25/2020 13:00	0.8	13.8	1,688.1	0.7	3.40	1	1	0
11/25/2020 14:00	0.8	13.8	1,661.8	0.7	3.30	1	1	0
11/25/2020 15:00	0.6	13.8	1,357.2	0.5	2.70	1	1	0
11/25/2020 16:00	0.8	13.8	1,639.3	0.7	3.30	1	1	0
11/25/2020 17:00	0.8	13.7	1,615.1	0.7	3.20	1	1	0
11/25/2020 18:00	0.8	13.7	1,701.9	0.7	3.40	1	1	0
11/25/2020 19:00	1.3	13.1	1,863.3	1.0	7.50	1	1	1
11/25/2020 20:00	2.0	12.6	1,937.7	1.4	9.70	1	1	1
11/25/2020 21:00	1.1	13.5	1,795.2	0.9	5.40	1	1	1
11/25/2020 22:00	2.2	12.5	2,038.1	1.5	12.20	1	1	1
11/25/2020 23:00	4.3	14.1	1,276.9	3.7	8.59	1	0	1
Average/Sum#:	1.2	13.4	1,732.2	0.9	123.99 #	24 #	23 #	11 #
Minimum:	0.6	12.4	1,276.9	0.5	2.70	1	0	0
Maximum:	4.3	14.1	2,077.0	3.7	12.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 23:00	36.3	17.5	466.7	63.0	73.64	1	0	0
Average/Sum#:	36.3	17.5	466.7	63.0	73.64 #	1 #	0 #	0 #
Minimum:	36.3	17.5	466.7	63.0	73.64	0	0	0
Maximum:	36.3	17.5	466.7	63.0	73.64	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2020 00:00	13.7	16.6	585.0	18.8	40.40	1	0	0
11/27/2020 01:00	14.2	14.9	977.7	14.0	49.90	1	0	0
11/27/2020 02:00	0.7	13.8	1,452.8	0.6	2.90	1	1	0
11/27/2020 03:00	0.7	13.8	1,409.6	0.6	2.80	1	1	0
11/27/2020 04:00	1.0	13.7	1,659.8	0.8	5.00	1	1	0
11/27/2020 05:00	0.6	13.8	1,458.1	0.5	2.90	1	1	0
11/27/2020 06:00	0.9	13.7	1,707.4	0.7	5.10	1	1	0
11/27/2020 07:00	0.8	13.8	1,613.2	0.7	3.20	1	1	0
11/27/2020 08:00	0.9	13.7	1,622.4	0.7	4.90	1	1	0
11/27/2020 09:00	0.9	13.7	1,709.8	0.7	5.10	1	1	0
11/27/2020 10:00	0.9	13.8	1,694.5	0.7	5.10	1	1	0
11/27/2020 11:00	0.9	13.8	1,708.8	0.7	5.10	1	1	0
11/27/2020 12:00	0.9	13.8	1,698.0	0.7	5.10	1	1	0
11/27/2020 13:00	0.9	13.8	1,627.0	0.7	4.90	1	1	0
11/27/2020 14:00	0.9	13.8	1,666.4	0.7	5.00	1	1	0
11/27/2020 15:00	0.9	13.8	1,586.1	0.7	4.80	1	1	1
11/27/2020 16:00	1.2	12.7	1,998.3	0.9	6.00	1	1	1
11/27/2020 17:00	1.3	12.1	2,109.7	0.9	6.30	1	1	1
11/27/2020 18:00	1.3	12.3	2,073.4	0.9	6.20	1	1	1
11/27/2020 19:00	1.3	12.3	2,069.1	0.9	6.20	1	1	1
11/27/2020 20:00	1.2	12.6	1,992.5	0.9	6.00	1	1	1
11/27/2020 21:00	0.9	13.7	1,714.3	0.7	5.10	1	1	0
11/27/2020 22:00	1.1	13.3	1,854.4	0.9	5.60	1	1	1
11/27/2020 23:00	1.3	12.6	2,052.6	0.9	6.20	1	1	1
Average/Sum#:	2.1	13.6	1,668.4	2.1	199.80 #	24 #	22 #	8 #
Minimum:	0.6	12.1	585.0	0.5	2.80	1	0	0
Maximum:	14.2	16.6	2,109.7	18.8	49.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	1.3	12.5	2,061.2	0.9	6.20	1	1	1
11/28/2020 01:00	1.1	13.0	1,949.1	0.8	5.80	1	1	1
11/28/2020 02:00	0.8	13.7	1,595.5	0.7	3.20	1	1	0
11/28/2020 03:00	1.0	13.3	1,833.1	0.8	5.50	1	1	1
11/28/2020 04:00	1.2	13.0	1,951.0	0.9	5.90	1	1	1
11/28/2020 05:00	1.2	12.9	1,971.0	0.9	5.90	1	1	1
11/28/2020 06:00	0.9	13.7	1,704.0	0.7	5.10	1	1	0
11/28/2020 07:00	0.8	13.7	1,647.9	0.7	3.30	1	1	0
11/28/2020 08:00	0.9	13.7	1,691.6	0.7	5.10	1	1	0
11/28/2020 09:00	0.8	13.7	1,565.8	0.7	3.10	1	1	0
11/28/2020 10:00	0.9	13.7	1,637.2	0.7	4.90	1	1	0
11/28/2020 11:00	0.9	13.8	1,701.0	0.7	5.10	1	1	0
11/28/2020 12:00	0.9	13.8	1,706.6	0.7	5.10	1	1	0
11/28/2020 13:00	0.9	13.8	1,559.0	0.7	4.70	1	1	0
11/28/2020 14:00	0.9	13.8	1,639.1	0.7	4.90	1	1	0
11/28/2020 15:00	1.0	13.5	1,710.6	0.8	5.10	1	1	1
11/28/2020 16:00	1.3	12.4	2,050.1	0.9	6.20	1	1	1
11/28/2020 17:00	1.3	12.0	2,113.6	0.9	6.30	1	1	1
11/28/2020 18:00	1.3	11.9	2,153.6	0.9	6.50	1	1	1
11/28/2020 19:00	1.4	11.9	2,150.3	0.9	6.50	1	1	1
11/28/2020 20:00	1.4	11.6	2,213.0	0.9	6.60	1	1	1
11/28/2020 21:00	1.0	13.1	1,824.4	0.8	5.50	1	1	1
11/28/2020 22:00	1.0	13.3	1,848.3	0.8	5.50	1	1	1
11/28/2020 23:00	1.3	12.5	2,068.5	0.9	6.20	1	1	1
Average/Sum#:	1.1	13.1	1,847.7	0.8	128.20 #	24 #	24 #	14 #
Minimum:	0.8	11.6	1,559.0	0.7	3.10	1	1	0
Maximum:	1.4	13.8	2,213.0	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2020 00:00	1.2	13.0	1,933.3	0.9	5.80	1	1	1
11/29/2020 01:00	0.8	13.7	1,578.7	0.7	3.20	1	1	0
11/29/2020 02:00	1.1	13.2	1,866.9	0.8	5.60	1	1	1
11/29/2020 03:00	1.2	12.5	2,063.5	0.8	6.20	1	1	1
11/29/2020 04:00	1.3	12.4	2,048.2	0.9	6.10	1	1	1
11/29/2020 05:00	0.7	13.7	1,712.2	0.6	3.40	1	1	0
11/29/2020 06:00	0.8	13.7	1,684.9	0.7	3.40	1	1	0
11/29/2020 07:00	0.8	13.7	1,609.4	0.7	3.20	1	1	0
11/29/2020 08:00	0.9	13.7	1,651.6	0.7	5.00	1	1	0
11/29/2020 09:00	0.9	13.7	1,599.7	0.7	4.80	1	1	0
11/29/2020 10:00	0.9	13.7	1,702.1	0.7	5.10	1	1	0
11/29/2020 11:00	0.9	13.7	1,677.9	0.7	5.00	1	1	0
11/29/2020 12:00	0.9	13.7	1,692.3	0.7	5.10	1	1	0
11/29/2020 13:00	0.9	13.7	1,689.0	0.7	5.10	1	1	0
11/29/2020 14:00	0.9	13.8	1,669.0	0.7	5.00	1	1	0
11/29/2020 15:00	0.9	13.8	1,687.4	0.7	5.10	1	1	0
11/29/2020 16:00	1.1	13.1	1,850.5	0.8	5.60	1	1	1
11/29/2020 17:00	1.3	12.0	2,138.8	0.9	6.40	1	1	1
11/29/2020 18:00	1.4	11.6	2,218.5	0.9	6.70	1	1	1
11/29/2020 19:00	1.3	11.9	2,120.9	0.9	6.40	1	1	1
11/29/2020 20:00	0.9	13.7	1,701.6	0.7	5.10	1	1	0
11/29/2020 21:00	1.1	13.2	1,853.3	0.8	5.60	1	1	1
11/29/2020 22:00	1.4	12.0	2,148.8	0.9	6.40	1	1	1
11/29/2020 23:00	1.3	12.4	2,080.6	0.9	6.20	1	1	1
Average/Sum#:	1.0	13.2	1,832.5	0.8	125.50 #	24 #	24 #	11 #
Minimum:	0.7	11.6	1,578.7	0.6	3.20	1	1	0
Maximum:	1.4	13.8	2,218.5	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2020 00:00	1.3	12.4	2,096.4	0.9	6.30	1	1	1
11/30/2020 01:00	1.2	12.4	2,059.8	0.8	6.20	1	1	1
11/30/2020 02:00	0.8	13.7	1,582.3	0.7	3.20	1	1	0
11/30/2020 03:00	0.8	13.7	1,555.1	0.7	3.10	1	1	0
11/30/2020 04:00	1.0	13.3	1,784.1	0.8	5.40	1	1	1
11/30/2020 05:00	1.3	12.2	2,132.5	0.9	6.40	1	1	1
11/30/2020 06:00	1.3	12.1	2,143.8	0.9	6.40	1	1	1
11/30/2020 07:00	1.3	12.1	2,129.8	0.9	6.40	1	1	1
11/30/2020 08:00	1.2	12.7	1,987.0	0.9	6.00	1	1	1
11/30/2020 09:00	0.7	13.7	1,682.6	0.6	3.40	1	1	0
11/30/2020 10:00	0.8	13.7	1,576.8	0.7	3.20	1	1	0
11/30/2020 11:00	0.9	13.7	1,646.4	0.7	4.90	1	1	0
11/30/2020 12:00	0.9	13.8	1,631.4	0.7	4.90	1	1	0
11/30/2020 13:00	0.8	13.8	1,432.0	0.7	2.90	1	1	0
11/30/2020 14:00	0.9	13.8	1,680.7	0.7	5.00	1	1	0
11/30/2020 15:00	1.0	13.5	1,708.9	0.8	5.10	1	1	1
11/30/2020 16:00	1.3	12.3	2,073.0	0.9	6.20	1	1	1
11/30/2020 17:00	1.4	11.8	2,157.9	0.9	6.50	1	1	1
11/30/2020 18:00	1.3	11.8	2,171.2	0.8	6.50	1	1	1
11/30/2020 19:00	1.4	11.5	2,231.9	0.9	6.70	1	1	1
11/30/2020 20:00	1.4	11.9	2,164.9	0.9	6.50	1	1	1
11/30/2020 21:00	1.3	11.9	2,158.9	0.9	6.50	1	1	1
11/30/2020 22:00	1.3	12.1	2,124.4	0.9	6.40	1	1	1
11/30/2020 23:00	1.3	12.4	2,050.8	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.8	1,915.1	0.8	130.30 #	24 #	24 #	16 #
Minimum:	0.7	11.5	1,432.0	0.6	2.90	1	1	0
Maximum:	1.4	13.8	2,231.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2020 00:00	1.3	12.3	2,077.2	0.9	6.20	1	1	1
12/01/2020 01:00	1.3	12.2	2,064.5	0.9	6.20	1	1	1
12/01/2020 02:00	0.7	13.7	1,571.7	0.6	3.10	1	1	0
12/01/2020 03:00	1.1	13.2	1,850.1	0.8	5.60	1	1	1
12/01/2020 04:00	1.3	12.0	2,133.5	0.9	6.40	1	1	1
12/01/2020 05:00	1.6	11.4	2,218.4	1.0	8.90	1	1	1
12/01/2020 06:00	1.4	11.3	2,265.3	0.9	6.80	1	1	1
12/01/2020 07:00	1.3	11.8	2,183.5	0.8	6.60	1	1	1
12/01/2020 08:00	1.3	12.0	2,126.0	0.9	6.40	1	1	1
12/01/2020 09:00	0.9	13.6	1,717.6	0.7	5.20	1	1	1
12/01/2020 10:00	0.9	13.8	1,702.3	0.7	5.10	1	1	0
12/01/2020 11:00	0.9	13.8	1,675.6	0.7	5.00	1	1	0
12/01/2020 12:00	0.9	13.8	1,687.4	0.7	5.10	1	1	0
12/01/2020 13:00	0.7	13.9	1,408.9	0.6	2.80	1	1	0
12/01/2020 14:00	0.9	13.8	1,613.8	0.7	4.80	1	1	0
12/01/2020 15:00	0.8	13.8	1,551.8	0.7	3.10	1	1	1
12/01/2020 16:00	1.3	12.4	2,028.0	0.9	6.10	1	1	1
12/01/2020 17:00	1.4	11.6	2,186.7	0.9	6.60	1	1	1
12/01/2020 18:00	1.4	11.4	2,236.7	0.9	6.70	1	1	1
12/01/2020 19:00	1.4	11.4	2,236.8	0.9	6.70	1	1	1
12/01/2020 20:00	1.4	11.4	2,246.8	0.9	6.70	1	1	1
12/01/2020 21:00	1.4	11.4	2,247.8	0.9	6.70	1	1	1
12/01/2020 22:00	1.4	11.5	2,235.6	0.9	6.70	1	1	1
12/01/2020 23:00	1.4	11.9	2,175.3	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.5	1,976.7	0.8	140.00 #	24 #	24 #	18 #
Minimum:	0.7	11.3	1,408.9	0.6	2.80	1	1	0
Maximum:	1.6	13.9	2,265.3	1.0	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2020 00:00	1.3	12.1	2,148.2	0.9	6.40	1	1	1
12/02/2020 01:00	1.2	12.6	2,007.3	0.9	6.00	1	1	1
12/02/2020 02:00	0.8	13.7	1,579.9	0.7	3.20	1	1	0
12/02/2020 03:00	1.1	13.1	1,857.9	0.8	5.60	1	1	1
12/02/2020 04:00	1.3	12.3	2,091.8	0.9	6.30	1	1	1
12/02/2020 05:00	1.2	12.1	2,123.3	0.8	6.40	1	1	1
12/02/2020 06:00	1.4	12.0	2,158.0	0.9	6.50	1	1	1
12/02/2020 07:00	1.3	12.1	2,142.3	0.9	6.40	1	1	1
12/02/2020 08:00	1.3	12.4	2,079.9	0.9	6.20	1	1	1
12/02/2020 09:00	0.7	13.7	1,598.4	0.6	3.20	1	1	1
12/02/2020 10:00	0.9	13.8	1,676.4	0.7	5.00	1	1	0
12/02/2020 11:00	0.9	13.8	1,712.8	0.7	5.10	1	1	0
12/02/2020 12:00	0.9	13.8	1,667.4	0.7	5.00	1	1	0
12/02/2020 13:00	0.8	13.8	1,557.6	0.7	3.10	1	1	0
12/02/2020 14:00	0.9	13.8	1,591.0	0.7	4.80	1	1	0
12/02/2020 15:00	1.1	13.1	1,856.7	0.8	5.60	1	1	1
12/02/2020 16:00	1.4	12.0	2,132.0	0.9	6.40	1	1	1
12/02/2020 17:00	1.4	11.7	2,199.7	0.9	6.60	1	1	1
12/02/2020 18:00	1.4	11.5	2,243.2	0.9	6.70	1	1	1
12/02/2020 19:00	1.4	11.5	2,230.9	0.9	6.70	1	1	1
12/02/2020 20:00	1.4	11.7	2,188.7	0.9	6.60	1	1	1
12/02/2020 21:00	1.4	11.8	2,168.4	0.9	6.50	1	1	1
12/02/2020 22:00	1.3	12.0	2,148.4	0.9	6.40	1	1	1
12/02/2020 23:00	1.3	12.0	2,144.9	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.6	1,971.0	0.8	137.10 #	24 #	24 #	18 #
Minimum:	0.7	11.5	1,557.6	0.6	3.10	1	1	0
Maximum:	1.4	13.8	2,243.2	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2020 00:00	1.3	12.1	2,129.4	0.9	6.40	1	1	1
12/03/2020 01:00	1.3	12.2	2,129.1	0.9	6.40	1	1	1
12/03/2020 02:00	1.3	12.3	2,055.8	0.9	6.20	1	1	1
12/03/2020 03:00	0.8	13.7	1,610.8	0.7	3.20	1	1	0
12/03/2020 04:00	1.1	13.2	1,856.8	0.8	5.60	1	1	1
12/03/2020 05:00	1.5	12.0	2,150.4	1.0	8.60	1	1	1
12/03/2020 06:00	1.4	11.5	2,264.7	0.9	6.80	1	1	1
12/03/2020 07:00	1.3	12.1	2,138.4	0.9	6.40	1	1	1
12/03/2020 08:00	1.3	12.3	2,102.3	0.9	6.30	1	1	1
12/03/2020 09:00	1.2	12.8	1,978.6	0.9	5.90	1	1	1
12/03/2020 10:00	0.9	13.7	1,705.2	0.7	5.10	1	1	0
12/03/2020 11:00	0.8	13.7	1,655.5	0.7	3.30	1	1	0
12/03/2020 12:00	0.9	13.8	1,690.9	0.7	5.10	1	1	0
12/03/2020 13:00	0.9	13.8	1,691.6	0.7	5.10	1	1	0
12/03/2020 14:00	1.1	13.3	1,845.9	0.9	5.50	1	1	1
12/03/2020 15:00	1.3	12.3	2,092.7	0.9	6.30	1	1	1
12/03/2020 16:00	1.4	11.9	2,177.5	0.9	6.50	1	1	1
12/03/2020 17:00	1.4	11.6	2,223.1	0.9	6.70	1	1	1
12/03/2020 18:00	1.4	11.4	2,255.1	0.9	6.80	1	1	1
12/03/2020 19:00	1.4	11.4	2,257.9	0.9	6.80	1	1	1
12/03/2020 20:00	1.3	11.7	2,184.0	0.8	6.60	1	1	1
12/03/2020 21:00	1.4	11.6	2,218.2	0.9	6.70	1	1	1
12/03/2020 22:00	1.4	11.7	2,196.3	0.9	6.60	1	1	1
12/03/2020 23:00	1.3	12.0	2,154.2	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.4	2,031.9	0.9	145.40 #	24 #	24 #	19 #
Minimum:	0.8	11.4	1,610.8	0.7	3.20	1	1	0
Maximum:	1.5	13.8	2,264.7	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2020 00:00	1.3	12.2	2,147.2	0.9	6.40	1	1	1
12/04/2020 01:00	1.3	12.3	2,071.6	0.9	6.20	1	1	1
12/04/2020 02:00	0.8	13.7	1,698.9	0.7	3.40	1	1	0
12/04/2020 03:00	1.0	13.2	1,864.1	0.8	5.60	1	1	1
12/04/2020 04:00	1.3	12.1	2,142.8	0.9	6.40	1	1	1
12/04/2020 05:00	1.5	11.4	2,242.0	0.9	6.70	1	1	1
12/04/2020 06:00	1.4	11.4	2,281.3	0.9	6.80	1	1	1
12/04/2020 07:00	1.3	11.7	2,225.3	0.8	6.70	1	1	1
12/04/2020 08:00	1.3	12.4	2,105.3	0.9	6.30	1	1	1
12/04/2020 09:00	1.2	12.7	1,988.5	0.9	6.00	1	1	1
12/04/2020 10:00	0.8	13.8	1,630.4	0.7	3.30	1	1	0
12/04/2020 11:00	0.9	13.8	1,613.2	0.7	4.80	1	1	0
12/04/2020 12:00	1.2	13.0	1,935.7	0.9	5.80	1	1	1
12/04/2020 13:00	1.3	13.0	1,919.5	1.0	7.70	1	1	1
12/04/2020 14:00	1.0	13.7	1,675.5	0.8	5.00	1	1	0
12/04/2020 15:00	1.1	13.2	1,819.5	0.8	5.50	1	1	1
12/04/2020 16:00	1.4	12.1	2,130.5	0.9	6.40	1	1	1
12/04/2020 17:00	1.4	11.6	2,216.2	0.9	6.60	1	1	1
12/04/2020 18:00	1.4	11.6	2,210.7	0.9	6.60	1	1	1
12/04/2020 19:00	1.4	11.5	2,219.1	0.9	6.70	1	1	1
12/04/2020 20:00	1.4	11.6	2,216.2	0.9	6.60	1	1	1
12/04/2020 21:00	1.4	11.5	2,232.9	0.9	6.70	1	1	1
12/04/2020 22:00	1.4	11.8	2,186.1	0.9	6.60	1	1	1
12/04/2020 23:00	1.3	12.0	2,153.3	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.4	2,038.6	0.9	145.30 #	24 #	24 #	20 #
Minimum:	0.8	11.4	1,613.2	0.7	3.30	1	1	0
Maximum:	1.5	13.8	2,281.3	1.0	7.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2020 00:00	1.3	12.0	2,163.2	0.9	6.50	1	1	1
12/05/2020 01:00	1.3	12.1	2,126.2	0.9	6.40	1	1	1
12/05/2020 02:00	1.3	12.1	2,143.6	0.9	6.40	1	1	1
12/05/2020 03:00	1.3	12.1	2,147.9	0.9	6.40	1	1	1
12/05/2020 04:00	1.3	12.1	2,143.4	0.9	6.40	1	1	1
12/05/2020 05:00	1.4	12.1	2,149.4	0.9	6.40	1	1	1
12/05/2020 06:00	1.2	12.3	2,085.0	0.8	6.30	1	1	1
12/05/2020 07:00	0.8	13.7	1,676.5	0.7	3.40	1	1	0
12/05/2020 08:00	0.8	13.7	1,630.4	0.7	3.30	1	1	0
12/05/2020 09:00	0.9	13.7	1,687.8	0.7	5.10	1	1	0
12/05/2020 10:00	0.9	13.7	1,684.3	0.7	5.10	1	1	0
12/05/2020 11:00	0.9	13.7	1,712.3	0.7	5.10	1	1	0
12/05/2020 12:00	0.9	13.7	1,702.9	0.7	5.10	1	1	0
12/05/2020 13:00	0.9	13.7	1,666.0	0.7	5.00	1	1	0
12/05/2020 14:00	0.9	13.7	1,650.1	0.7	5.00	1	1	0
12/05/2020 15:00	1.1	13.2	1,839.7	0.8	5.50	1	1	1
12/05/2020 16:00	1.3	12.3	2,081.9	0.9	6.20	1	1	1
12/05/2020 17:00	1.4	11.8	2,186.2	0.9	6.60	1	1	1
12/05/2020 18:00	1.4	11.5	2,235.4	0.9	6.70	1	1	1
12/05/2020 19:00	1.4	11.4	2,255.9	0.9	6.80	1	1	1
12/05/2020 20:00	1.4	11.5	2,254.2	0.9	6.80	1	1	1
12/05/2020 21:00	1.4	11.6	2,241.3	0.9	6.70	1	1	1
12/05/2020 22:00	1.3	12.0	2,147.7	0.9	6.40	1	1	1
12/05/2020 23:00	1.3	12.1	2,139.8	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.6	1,989.6	0.8	140.00 #	24 #	24 #	16 #
Minimum:	0.8	11.4	1,630.4	0.7	3.30	1	1	0
Maximum:	1.4	13.7	2,255.9	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	1.3	12.2	2,135.5	0.9	6.40	1	1	1
12/06/2020 01:00	1.3	12.4	2,094.2	0.9	6.30	1	1	1
12/06/2020 02:00	1.3	12.4	2,085.7	0.9	6.30	1	1	1
12/06/2020 03:00	1.1	13.1	1,892.5	0.8	5.70	1	1	1
12/06/2020 04:00	1.0	13.5	1,807.3	0.8	5.40	1	1	1
12/06/2020 05:00	1.4	12.4	2,045.1	1.0	8.20	1	1	1
12/06/2020 06:00	1.1	12.7	1,965.7	0.8	5.90	1	1	1
12/06/2020 07:00	0.8	13.7	1,569.9	0.7	3.10	1	1	0
12/06/2020 08:00	0.8	13.7	1,571.6	0.7	3.10	1	1	0
12/06/2020 09:00	0.8	13.7	1,705.2	0.7	3.40	1	1	0
12/06/2020 10:00	0.8	13.7	1,702.2	0.7	3.40	1	1	0
12/06/2020 11:00	0.8	13.8	1,705.2	0.7	3.40	1	1	0
12/06/2020 12:00	0.8	13.8	1,630.6	0.7	3.30	1	1	0
12/06/2020 13:00	0.8	13.8	1,693.3	0.7	3.40	1	1	0
12/06/2020 14:00	0.8	13.8	1,666.3	0.7	3.30	1	1	0
12/06/2020 15:00	1.1	13.3	1,846.5	0.9	5.50	1	1	1
12/06/2020 16:00	1.3	12.3	2,104.0	0.9	6.30	1	1	1
12/06/2020 17:00	1.4	11.7	2,215.0	0.9	6.60	1	1	1
12/06/2020 18:00	1.4	11.5	2,252.2	0.9	6.80	1	1	1
12/06/2020 19:00	1.4	11.5	2,256.7	0.9	6.80	1	1	1
12/06/2020 20:00	1.4	11.5	2,254.9	0.9	6.80	1	1	1
12/06/2020 21:00	1.4	11.7	2,208.8	0.9	6.60	1	1	1
12/06/2020 22:00	1.4	12.0	2,142.4	0.9	6.40	1	1	1
12/06/2020 23:00	1.3	12.4	2,057.6	0.9	6.20	1	1	1
Average/Sum#:	1.1	12.8	1,942.0	0.8	128.60 #	24 #	24 #	16 #
Minimum:	0.8	11.5	1,569.9	0.7	3.10	1	1	0
Maximum:	1.4	13.8	2,256.7	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2020 00:00	1.3	12.2	2,100.1	0.9	6.30	1	1	1
12/07/2020 01:00	1.2	12.6	1,990.2	0.9	6.00	1	1	1
12/07/2020 02:00	0.8	13.7	1,622.7	0.7	3.20	1	1	0
12/07/2020 03:00	1.1	13.2	1,835.0	0.8	5.50	1	1	1
12/07/2020 04:00	1.3	12.3	2,073.9	0.9	6.20	1	1	1
12/07/2020 05:00	1.3	12.2	2,099.5	0.9	6.30	1	1	1
12/07/2020 06:00	1.3	11.7	2,199.7	0.8	6.60	1	1	1
12/07/2020 07:00	1.3	11.7	2,193.3	0.8	6.60	1	1	1
12/07/2020 08:00	1.3	11.8	2,174.1	0.8	6.50	1	1	1
12/07/2020 09:00	1.3	11.8	2,157.8	0.8	6.50	1	1	1
12/07/2020 10:00	0.9	13.5	1,704.8	0.7	5.10	1	1	1
12/07/2020 11:00	0.9	13.8	1,604.4	0.7	4.80	1	1	0
12/07/2020 12:00	0.9	13.8	1,602.4	0.7	4.80	1	1	0
12/07/2020 13:00	0.9	13.8	1,680.5	0.7	5.00	1	1	0
12/07/2020 14:00	1.1	13.4	1,685.4	0.9	5.10	1	1	1
12/07/2020 15:00	1.3	12.1	2,075.2	0.9	6.20	1	1	1
12/07/2020 16:00	1.3	11.9	2,121.3	0.9	6.40	1	1	1
12/07/2020 17:00	1.3	11.5	2,197.4	0.8	6.60	1	1	1
12/07/2020 18:00	1.3	11.8	2,177.1	0.8	6.50	1	1	1
12/07/2020 19:00	1.4	11.8	2,184.5	0.9	6.60	1	1	1
12/07/2020 20:00	1.4	11.7	2,207.5	0.9	6.60	1	1	1
12/07/2020 21:00	1.4	11.6	2,233.7	0.9	6.70	1	1	1
12/07/2020 22:00	1.4	11.8	2,193.8	0.9	6.60	1	1	1
12/07/2020 23:00	1.3	12.2	2,104.2	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.4	2,009.1	0.8	143.00 #	24 #	24 #	20 #
Minimum:	0.8	11.5	1,602.4	0.7	3.20	1	1	0
Maximum:	1.4	13.8	2,233.7	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2020 00:00	1.3	12.3	2,079.0	0.9	6.20	1	1	1
12/08/2020 01:00	1.2	12.9	1,951.8	0.9	5.90	1	1	1
12/08/2020 02:00	0.9	13.7	1,668.2	0.7	5.00	1	1	0
12/08/2020 03:00	1.1	13.3	1,813.6	0.9	5.40	1	1	1
12/08/2020 04:00	1.3	12.5	2,048.6	0.9	6.10	1	1	1
12/08/2020 05:00	1.2	12.9	1,984.4	0.9	6.00	1	1	1
12/08/2020 06:00	1.2	12.3	2,094.8	0.8	6.30	1	1	1
12/08/2020 07:00	1.3	11.9	2,138.8	0.9	6.40	1	1	1
12/08/2020 08:00	1.3	12.2	2,084.8	0.9	6.30	1	1	1
12/08/2020 09:00	1.2	12.8	1,961.6	0.9	5.90	1	1	1
12/08/2020 10:00	0.8	13.8	1,661.7	0.7	3.30	1	1	0
12/08/2020 11:00	0.9	13.8	1,592.7	0.7	4.80	1	1	0
12/08/2020 12:00	0.9	13.8	1,613.6	0.7	4.80	1	1	0
12/08/2020 13:00	0.9	13.8	1,579.2	0.7	4.70	1	1	0
12/08/2020 14:00	0.8	13.8	1,556.5	0.7	3.10	1	1	0
12/08/2020 15:00	1.0	13.4	1,717.2	0.8	5.20	1	1	1
12/08/2020 16:00	1.3	12.3	2,045.4	0.9	6.10	1	1	1
12/08/2020 17:00	1.4	11.6	2,198.7	0.9	6.60	1	1	1
12/08/2020 18:00	1.4	11.5	2,220.4	0.9	6.70	1	1	1
12/08/2020 19:00	1.4	11.3	2,252.9	0.9	6.80	1	1	1
12/08/2020 20:00	1.4	11.6	2,207.5	0.9	6.60	1	1	1
12/08/2020 21:00	1.4	11.9	2,171.5	0.9	6.50	1	1	1
12/08/2020 22:00	1.3	12.2	2,128.8	0.9	6.40	1	1	1
12/08/2020 23:00	1.3	12.4	2,084.1	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.7	1,952.3	0.8	137.40 #	24 #	24 #	18 #
Minimum:	0.8	11.3	1,556.5	0.7	3.10	1	1	0
Maximum:	1.4	13.8	2,252.9	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2020 00:00	1.3	12.3	2,084.1	0.9	6.30	1	1	1
12/09/2020 01:00	1.3	12.4	2,068.8	0.9	6.20	1	1	1
12/09/2020 02:00	1.2	12.9	1,941.6	0.9	5.80	1	1	1
12/09/2020 03:00	1.0	13.7	1,757.3	0.8	5.30	1	1	0
12/09/2020 04:00	1.1	13.2	1,852.2	0.8	5.60	1	1	1
12/09/2020 05:00	1.3	12.5	2,055.9	0.9	6.20	1	1	1
12/09/2020 06:00	1.3	12.1	2,127.6	0.9	6.40	1	1	1
12/09/2020 07:00	1.3	12.2	2,132.4	0.9	6.40	1	1	1
12/09/2020 08:00	1.3	12.3	2,095.0	0.9	6.30	1	1	1
12/09/2020 09:00	1.2	12.9	1,941.7	0.9	5.80	1	1	1
12/09/2020 10:00	1.0	13.7	1,762.4	0.8	5.30	1	1	0
12/09/2020 11:00	1.1	13.7	1,765.5	0.9	5.30	1	1	0
12/09/2020 12:00	1.2	13.7	1,762.2	1.0	7.00	1	1	0
12/09/2020 13:00	1.2	13.7	1,758.7	1.0	7.00	1	1	0
12/09/2020 14:00	1.2	13.6	1,759.5	1.0	7.00	1	1	0
12/09/2020 15:00	1.2	13.1	1,836.5	0.9	5.50	1	1	1
12/09/2020 16:00	1.4	11.8	2,127.8	0.9	6.40	1	1	1
12/09/2020 17:00	1.4	11.6	2,184.3	0.9	6.60	1	1	1
12/09/2020 18:00	1.4	11.6	2,181.1	0.9	6.50	1	1	1
12/09/2020 19:00	1.4	11.5	2,231.5	0.9	6.70	1	1	1
12/09/2020 20:00	1.4	11.7	2,197.2	0.9	6.60	1	1	1
12/09/2020 21:00	1.4	11.4	2,265.4	0.9	6.80	1	1	1
12/09/2020 22:00	1.4	11.5	2,241.5	0.9	6.70	1	1	1
12/09/2020 23:00	1.3	12.0	2,139.7	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.5	2,011.2	0.9	150.10 #	24 #	24 #	18 #
Minimum:	1.0	11.4	1,757.3	0.8	5.30	1	1	0
Maximum:	1.4	13.7	2,265.4	1.0	7.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2020 00:00	1.4	12.0	2,131.0	0.9	6.40	1	1	1
12/10/2020 01:00	1.3	12.3	2,062.3	0.9	6.20	1	1	1
12/10/2020 02:00	1.3	12.1	2,068.2	0.9	6.20	1	1	1
12/10/2020 03:00	0.8	13.8	1,709.6	0.7	3.40	1	1	0
12/10/2020 04:00	1.1	13.2	1,842.5	0.8	5.50	1	1	1
12/10/2020 05:00	1.6	11.5	2,203.7	1.0	8.80	1	1	1
12/10/2020 06:00	1.3	11.7	2,181.0	0.8	6.50	1	1	1
12/10/2020 07:00	1.3	11.8	2,161.5	0.8	6.50	1	1	1
12/10/2020 08:00	1.3	11.8	2,174.4	0.8	6.50	1	1	1
12/10/2020 09:00	1.4	11.7	2,183.1	0.9	6.50	1	1	1
12/10/2020 10:00	0.8	13.5	1,712.9	0.6	3.40	1	1	1
12/10/2020 11:00	0.8	13.8	1,641.3	0.7	3.30	1	1	0
12/10/2020 12:00	0.8	13.8	1,544.9	0.7	3.10	1	1	0
12/10/2020 13:00	0.8	13.8	1,583.7	0.7	3.20	1	1	0
12/10/2020 14:00	0.8	13.8	1,547.8	0.7	3.10	1	1	0
12/10/2020 15:00	1.1	13.2	1,849.8	0.8	5.50	1	1	1
12/10/2020 16:00	1.3	12.3	2,088.4	0.9	6.30	1	1	1
12/10/2020 17:00	1.4	11.8	2,186.1	0.9	6.60	1	1	1
12/10/2020 18:00	1.4	11.4	2,251.7	0.9	6.80	1	1	1
12/10/2020 19:00	1.4	11.5	2,219.2	0.9	6.70	1	1	1
12/10/2020 20:00	1.3	11.9	2,154.1	0.9	6.50	1	1	1
12/10/2020 21:00	1.4	11.8	2,174.0	0.9	6.50	1	1	1
12/10/2020 22:00	1.4	11.8	2,168.1	0.9	6.50	1	1	1
12/10/2020 23:00	1.3	12.1	2,107.6	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.4	1,997.8	0.8	136.30 #	24 #	24 #	19 #
Minimum:	0.8	11.4	1,544.9	0.6	3.10	1	1	0
Maximum:	1.6	13.8	2,251.7	1.0	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2020 00:00	1.2	12.9	1,944.7	0.9	5.80	1	1	1
12/11/2020 01:00	0.8	13.7	1,710.0	0.7	3.40	1	1	0
12/11/2020 02:00	0.8	13.7	1,613.0	0.7	3.20	1	1	0
12/11/2020 03:00	0.8	13.7	1,606.6	0.7	3.20	1	1	0
12/11/2020 04:00	1.0	13.3	1,782.6	0.8	5.30	1	1	1
12/11/2020 05:00	1.3	12.4	2,081.7	0.9	6.20	1	1	1
12/11/2020 06:00	1.3	12.0	2,176.7	0.9	6.50	1	1	1
12/11/2020 07:00	1.3	12.1	2,140.4	0.9	6.40	1	1	1
12/11/2020 08:00	1.3	12.1	2,101.0	0.9	6.30	1	1	1
12/11/2020 09:00	0.8	13.7	1,680.2	0.7	3.40	1	1	0
12/11/2020 10:00	0.8	13.7	1,677.3	0.7	3.40	1	1	0
12/11/2020 11:00	0.8	13.7	1,660.2	0.7	3.30	1	1	0
12/11/2020 12:00	0.8	13.7	1,637.1	0.7	3.30	1	1	0
12/11/2020 13:00	0.9	13.7	1,677.3	0.7	5.00	1	1	0
12/11/2020 14:00	0.9	13.7	1,683.3	0.7	5.00	1	1	0
12/11/2020 15:00	1.1	13.3	1,840.1	0.9	5.50	1	1	1
12/11/2020 16:00	1.4	12.0	2,138.3	0.9	6.40	1	1	1
12/11/2020 17:00	1.4	11.8	2,182.0	0.9	6.50	1	1	1
12/11/2020 18:00	1.4	11.4	2,284.7	0.9	6.90	1	1	1
12/11/2020 19:00	1.4	11.3	2,294.0	0.9	6.90	1	1	1
12/11/2020 20:00	1.4	11.3	2,292.7	0.9	6.90	1	1	1
12/11/2020 21:00	1.4	11.3	2,291.1	0.9	6.90	1	1	1
12/11/2020 22:00	1.4	11.9	2,178.2	0.9	6.50	1	1	1
12/11/2020 23:00	1.4	12.1	2,138.1	0.9	6.40	1	1	1
Average/Sum#:	1.1	12.7	1,950.5	0.8	128.60 #	24 #	24 #	15 #
Minimum:	0.8	11.3	1,606.6	0.7	3.20	1	1	0
Maximum:	1.4	13.7	2,294.0	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2020 00:00	1.4	12.0	2,159.3	0.9	6.50	1	1	1
12/12/2020 01:00	1.3	12.2	2,109.2	0.9	6.30	1	1	1
12/12/2020 02:00	1.2	12.8	1,958.8	0.9	5.90	1	1	1
12/12/2020 03:00	0.9	13.6	1,633.7	0.7	4.90	1	1	0
12/12/2020 04:00	1.1	13.3	1,829.9	0.9	5.50	1	1	1
12/12/2020 05:00	1.2	13.0	1,961.2	0.9	5.90	1	1	1
12/12/2020 06:00	1.3	13.0	1,948.7	1.0	7.80	1	1	1
12/12/2020 07:00	0.9	13.6	1,702.2	0.7	5.10	1	1	1
12/12/2020 08:00	0.9	13.7	1,680.5	0.7	5.00	1	1	0
12/12/2020 09:00	0.9	13.7	1,693.1	0.7	5.10	1	1	0
12/12/2020 10:00	0.9	13.7	1,677.5	0.7	5.00	1	1	0
12/12/2020 11:00	0.9	13.7	1,593.5	0.7	4.80	1	1	0
12/12/2020 12:00	0.9	13.7	1,654.8	0.7	5.00	1	1	0
12/12/2020 13:00	0.9	13.7	1,712.2	0.7	5.10	1	1	0
12/12/2020 14:00	0.9	13.7	1,684.6	0.7	5.10	1	1	0
12/12/2020 15:00	1.1	13.2	1,845.1	0.8	5.50	1	1	1
12/12/2020 16:00	1.3	12.1	2,108.9	0.9	6.30	1	1	1
12/12/2020 17:00	1.4	11.7	2,194.3	0.9	6.60	1	1	1
12/12/2020 18:00	1.4	11.4	2,264.0	0.9	6.80	1	1	1
12/12/2020 19:00	1.4	11.3	2,270.1	0.9	6.80	1	1	1
12/12/2020 20:00	1.4	11.3	2,267.3	0.9	6.80	1	1	1
12/12/2020 21:00	1.4	11.4	2,264.8	0.9	6.80	1	1	1
12/12/2020 22:00	1.4	11.4	2,256.3	0.9	6.80	1	1	1
12/12/2020 23:00	1.3	11.9	2,156.9	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.7	1,942.8	0.8	141.90 #	24 #	24 #	16 #
Minimum:	0.9	11.3	1,593.5	0.7	4.80	1	1	0
Maximum:	1.4	13.7	2,270.1	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2020 00:00	1.4	11.9	2,163.4	0.9	6.50	1	1	1
12/13/2020 01:00	1.3	12.2	2,094.8	0.9	6.30	1	1	1
12/13/2020 02:00	1.2	12.9	1,954.5	0.9	5.90	1	1	1
12/13/2020 03:00	1.3	12.9	1,952.7	1.0	7.80	1	1	1
12/13/2020 04:00	1.3	12.9	1,962.7	1.0	7.90	1	1	1
12/13/2020 05:00	1.3	12.4	2,061.3	0.9	6.20	1	1	1
12/13/2020 06:00	1.3	12.3	2,065.4	0.9	6.20	1	1	1
12/13/2020 07:00	0.8	13.6	1,614.1	0.6	3.20	1	1	0
12/13/2020 08:00	0.7	13.7	1,306.7	0.6	2.60	1	1	0
12/13/2020 09:00	0.7	13.7	1,307.5	0.6	2.60	1	1	0
12/13/2020 10:00	0.7	13.7	1,321.0	0.6	2.60	1	1	0
12/13/2020 11:00	0.9	13.7	1,510.4	0.7	4.50	1	1	0
12/13/2020 12:00	1.0	13.6	1,681.5	0.8	5.00	1	1	0
12/13/2020 13:00	1.0	13.6	1,695.4	0.8	5.10	1	1	0
12/13/2020 14:00	1.0	13.6	1,706.0	0.8	5.10	1	1	0
12/13/2020 15:00	1.1	13.2	1,825.9	0.8	5.50	1	1	1
12/13/2020 16:00	1.3	12.2	2,079.4	0.9	6.20	1	1	1
12/13/2020 17:00	1.4	11.5	2,234.2	0.9	6.70	1	1	1
12/13/2020 18:00	1.4	11.5	2,220.8	0.9	6.70	1	1	1
12/13/2020 19:00	1.4	11.9	2,159.6	0.9	6.50	1	1	1
12/13/2020 20:00	1.4	11.8	2,177.1	0.9	6.50	1	1	1
12/13/2020 21:00	1.4	12.1	2,121.9	0.9	6.40	1	1	1
12/13/2020 22:00	1.3	12.4	2,061.9	0.9	6.20	1	1	1
12/13/2020 23:00	1.3	12.5	2,041.7	0.9	6.10	1	1	1
Average/Sum#:	1.2	12.7	1,888.3	0.8	134.30 #	24 #	24 #	16 #
Minimum:	0.7	11.5	1,306.7	0.6	2.60	1	1	0
Maximum:	1.4	13.7	2,234.2	1.0	7.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	3.2	15.4	722.1	3.4	2.54	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.2	15.4	722.1	3.4	2.54 #	1 #	0 #	0 #
Minimum:	3.2	15.4	722.1	3.4	2.54	0	0	0
Maximum:	3.2	15.4	722.1	3.4	2.54	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/15/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/16/2020 15:00	30.4	17.6	453.9	54.4	56.30	1	0	0
12/16/2020 16:00	25.0	15.6	820.6	27.8	84.50	1	0	0
12/16/2020 17:00	0.9	13.5	1,784.6	0.7	5.40	1	1	0
12/16/2020 18:00	1.2	13.0	1,925.8	0.9	5.80	1	1	1
12/16/2020 19:00	1.4	11.9	2,196.3	0.9	6.60	1	1	1
12/16/2020 20:00	1.3	11.6	2,241.9	0.8	6.70	1	1	1
12/16/2020 21:00	1.4	11.6	2,239.8	0.9	6.70	1	1	1
12/16/2020 22:00	1.4	11.7	2,232.4	0.9	6.70	1	1	1
12/16/2020 23:00	1.3	11.7	2,210.6	0.8	6.60	1	1	1
Average/Sum#:	7.1	13.1	1,789.5	9.8	185.30 #	9 #	7 #	6 #
Minimum:	0.9	11.6	453.9	0.7	5.40	0	0	0
Maximum:	30.4	17.6	2,241.9	54.4	84.50	1	1	1
%SI	62.50	62.50	62.50	62.50	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2020 00:00	1.3	12.2	2,075.5	0.9	6.20	1	1	1
12/17/2020 01:00	1.2	12.7	1,911.4	0.9	5.70	1	1	1
12/17/2020 02:00	1.0	13.4	1,797.3	0.8	5.40	1	1	1
12/17/2020 03:00	1.3	12.4	2,057.6	0.9	6.20	1	1	1
12/17/2020 04:00	1.3	12.2	2,083.9	0.9	6.30	1	1	1
12/17/2020 05:00	1.1	12.2	2,105.8	0.7	6.30	1	1	1
12/17/2020 06:00	1.3	12.5	2,033.1	0.9	6.10	1	1	1
12/17/2020 07:00	1.4	11.9	2,157.4	0.9	6.50	1	1	1
12/17/2020 08:00	1.3	12.2	2,088.9	0.9	6.30	1	1	1
12/17/2020 09:00	1.2	12.6	1,988.7	0.9	6.00	1	1	1
12/17/2020 10:00	1.0	13.7	1,650.9	0.8	5.00	1	1	0
12/17/2020 11:00	1.1	13.7	1,694.7	0.9	5.10	1	1	0
12/17/2020 12:00	1.1	13.7	1,680.3	0.9	5.00	1	1	0
12/17/2020 13:00	1.1	13.7	1,691.8	0.9	5.10	1	1	0
12/17/2020 14:00	1.1	13.7	1,670.5	0.9	5.00	1	1	0
12/17/2020 15:00	1.1	13.7	1,660.3	0.9	5.00	1	1	0
12/17/2020 16:00	1.2	13.2	1,829.8	0.9	5.50	1	1	1
12/17/2020 17:00	1.3	12.1	2,139.4	0.9	6.40	1	1	1
12/17/2020 18:00	1.3	12.0	2,142.1	0.9	6.40	1	1	1
12/17/2020 19:00	1.3	12.2	2,096.3	0.9	6.30	1	1	1
12/17/2020 20:00	1.3	12.3	2,079.4	0.9	6.20	1	1	1
12/17/2020 21:00	1.3	12.0	2,155.6	0.9	6.50	1	1	1
12/17/2020 22:00	1.3	12.2	2,106.2	0.9	6.30	1	1	1
12/17/2020 23:00	1.3	12.4	2,075.4	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.7	1,957.2	0.9	141.00 #	24 #	24 #	18 #
Minimum:	1.0	11.9	1,650.9	0.7	5.00	1	1	0
Maximum:	1.4	13.7	2,157.4	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2020 00:00	1.3	12.4	2,085.7	0.9	6.30	1	1	1
12/18/2020 01:00	1.1	12.9	1,951.1	0.8	5.90	1	1	1
12/18/2020 02:00	0.9	13.7	1,712.9	0.7	5.10	1	1	0
12/18/2020 03:00	0.9	13.7	1,480.2	0.7	4.40	1	1	0
12/18/2020 04:00	1.0	13.5	1,713.6	0.8	5.10	1	1	1
12/18/2020 05:00	1.4	12.7	1,990.1	1.0	8.00	1	1	1
12/18/2020 06:00	1.3	12.0	2,176.1	0.9	6.50	1	1	1
12/18/2020 07:00	1.3	12.1	2,148.5	0.9	6.40	1	1	1
12/18/2020 08:00	1.2	13.0	1,944.7	0.9	5.80	1	1	1
12/18/2020 09:00	1.0	13.7	1,714.4	0.8	5.10	1	1	0
12/18/2020 10:00	1.0	13.7	1,570.1	0.8	4.70	1	1	0
12/18/2020 11:00	0.9	13.8	1,409.7	0.7	4.20	1	1	0
12/18/2020 12:00	1.1	13.8	1,507.3	0.9	4.50	1	1	0
12/18/2020 13:00	1.1	13.8	1,609.5	0.9	4.80	1	1	0
12/18/2020 14:00	1.0	13.8	1,420.8	0.8	4.30	1	1	0
12/18/2020 15:00	0.9	13.8	1,440.2	0.7	4.30	1	1	0
12/18/2020 16:00	1.2	13.1	1,892.3	0.9	5.70	1	1	1
12/18/2020 17:00	1.4	11.6	2,215.1	0.9	6.60	1	1	1
12/18/2020 18:00	1.4	11.3	2,291.3	0.9	6.90	1	1	1
12/18/2020 19:00	1.4	11.3	2,295.0	0.9	6.90	1	1	1
12/18/2020 20:00	1.4	11.4	2,270.3	0.9	6.80	1	1	1
12/18/2020 21:00	1.4	11.7	2,228.0	0.9	6.70	1	1	1
12/18/2020 22:00	1.3	12.1	2,150.4	0.9	6.50	1	1	1
12/18/2020 23:00	1.3	12.5	2,072.7	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.8	1,887.1	0.9	137.70 #	24 #	24 #	15 #
Minimum:	0.9	11.3	1,409.7	0.7	4.20	1	1	0
Maximum:	1.4	13.8	2,295.0	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2020 00:00	1.3	12.5	2,061.6	0.9	6.20	1	1	1
12/19/2020 01:00	1.2	12.7	2,001.3	0.9	6.00	1	1	1
12/19/2020 02:00	1.0	13.7	1,666.1	0.8	5.00	1	1	0
12/19/2020 03:00	1.0	13.7	1,561.0	0.8	4.70	1	1	0
12/19/2020 04:00	1.1	13.3	1,875.9	0.9	5.60	1	1	1
12/19/2020 05:00	1.4	12.4	2,101.1	1.0	8.40	1	1	1
12/19/2020 06:00	1.2	12.7	2,023.7	0.9	6.10	1	1	1
12/19/2020 07:00	1.0	13.7	1,683.4	0.8	5.10	1	1	0
12/19/2020 08:00	1.0	13.7	1,598.8	0.8	4.80	1	1	0
12/19/2020 09:00	1.1	13.7	1,643.4	0.9	4.90	1	1	0
12/19/2020 10:00	1.1	13.7	1,706.6	0.9	5.10	1	1	0
12/19/2020 11:00	1.1	13.7	1,713.1	0.9	5.10	1	1	0
12/19/2020 12:00	1.1	13.7	1,713.8	0.9	5.10	1	1	0
12/19/2020 13:00	1.1	13.7	1,699.9	0.9	5.10	1	1	0
12/19/2020 14:00	1.1	13.7	1,713.0	0.9	5.10	1	1	0
12/19/2020 15:00	1.1	13.5	1,771.7	0.9	5.30	1	1	1
12/19/2020 16:00	1.3	12.4	2,093.0	0.9	6.30	1	1	1
12/19/2020 17:00	1.3	12.0	2,174.5	0.9	6.50	1	1	1
12/19/2020 18:00	1.4	11.5	2,271.5	0.9	6.80	1	1	1
12/19/2020 19:00	1.4	11.4	2,301.8	0.9	6.90	1	1	1
12/19/2020 20:00	1.4	11.7	2,231.9	0.9	6.70	1	1	1
12/19/2020 21:00	1.3	11.9	2,171.0	0.9	6.50	1	1	1
12/19/2020 22:00	1.3	12.3	2,096.5	0.9	6.30	1	1	1
12/19/2020 23:00	1.2	12.7	2,012.1	0.9	6.00	1	1	1
Average/Sum#:	1.2	12.9	1,911.9	0.9	139.60 #	24 #	24 #	14 #
Minimum:	1.0	11.4	1,561.0	0.8	4.70	1	1	0
Maximum:	1.4	13.7	2,301.8	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2020 00:00	1.2	12.9	1,968.1	0.9	5.90	1	1	1
12/20/2020 01:00	1.0	13.7	1,666.2	0.8	5.00	1	1	0
12/20/2020 02:00	1.0	13.7	1,550.0	0.8	4.70	1	1	0
12/20/2020 03:00	0.8	13.7	1,378.9	0.7	2.80	1	1	0
12/20/2020 04:00	1.0	13.7	1,583.3	0.8	4.70	1	1	0
12/20/2020 05:00	1.1	13.1	1,850.7	0.8	5.60	1	1	1
12/20/2020 06:00	1.1	13.1	1,895.0	0.8	5.70	1	1	1
12/20/2020 07:00	1.0	13.7	1,715.7	0.8	5.10	1	1	0
12/20/2020 08:00	1.0	13.7	1,692.8	0.8	5.10	1	1	0
12/20/2020 09:00	1.1	13.7	1,710.3	0.9	5.10	1	1	0
12/20/2020 10:00	1.1	13.7	1,710.6	0.9	5.10	1	1	0
12/20/2020 11:00	1.1	13.7	1,709.4	0.9	5.10	1	1	0
12/20/2020 12:00	1.1	13.7	1,714.9	0.9	5.10	1	1	0
12/20/2020 13:00	1.1	13.7	1,700.9	0.9	5.10	1	1	0
12/20/2020 14:00	1.1	13.7	1,638.4	0.9	4.90	1	1	0
12/20/2020 15:00	1.1	13.5	1,711.7	0.9	5.10	1	1	1
12/20/2020 16:00	1.3	12.4	2,050.7	0.9	6.20	1	1	1
12/20/2020 17:00	1.3	11.9	2,158.3	0.9	6.50	1	1	1
12/20/2020 18:00	1.4	11.8	2,183.9	0.9	6.60	1	1	1
12/20/2020 19:00	1.4	11.8	2,185.2	0.9	6.60	1	1	1
12/20/2020 20:00	1.4	11.5	2,243.7	0.9	6.70	1	1	1
12/20/2020 21:00	1.4	11.8	2,160.3	0.9	6.50	1	1	1
12/20/2020 22:00	1.3	12.0	2,147.4	0.9	6.40	1	1	1
12/20/2020 23:00	1.3	12.5	2,074.2	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.0	1,850.0	0.9	131.80 #	24 #	24 #	12 #
Minimum:	0.8	11.5	1,378.9	0.7	2.80	1	1	0
Maximum:	1.4	13.7	2,243.7	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2020 00:00	1.2	13.0	1,932.4	0.9	5.80	1	1	1
12/21/2020 01:00	1.0	13.6	1,682.7	0.8	5.00	1	1	0
12/21/2020 02:00	1.0	13.6	1,616.3	0.8	4.80	1	1	0
12/21/2020 03:00	1.0	13.7	1,561.7	0.8	4.70	1	1	0
12/21/2020 04:00	1.1	13.2	1,866.5	0.8	5.60	1	1	1
12/21/2020 05:00	1.4	12.3	2,101.9	1.0	8.40	1	1	1
12/21/2020 06:00	1.3	12.3	2,125.2	0.9	6.40	1	1	1
12/21/2020 07:00	1.3	12.3	2,116.8	0.9	6.40	1	1	1
12/21/2020 08:00	1.2	12.7	2,012.6	0.9	6.00	1	1	1
12/21/2020 09:00	1.0	13.6	1,696.4	0.8	5.10	1	1	0
12/21/2020 10:00	1.1	13.6	1,707.6	0.9	5.10	1	1	0
12/21/2020 11:00	1.1	13.6	1,710.5	0.9	5.10	1	1	0
12/21/2020 12:00	1.1	13.6	1,700.4	0.9	5.10	1	1	0
12/21/2020 13:00	1.1	13.6	1,707.3	0.9	5.10	1	1	0
12/21/2020 14:00	1.1	13.6	1,695.2	0.9	5.10	1	1	0
12/21/2020 15:00	1.2	13.2	1,846.3	0.9	5.50	1	1	1
12/21/2020 16:00	1.3	12.1	2,120.5	0.9	6.40	1	1	1
12/21/2020 17:00	1.3	12.1	2,136.7	0.9	6.40	1	1	1
12/21/2020 18:00	1.4	11.8	2,203.6	0.9	6.60	1	1	1
12/21/2020 19:00	1.4	11.9	2,179.3	0.9	6.50	1	1	1
12/21/2020 20:00	1.3	12.1	2,143.0	0.9	6.40	1	1	1
12/21/2020 21:00	1.3	12.3	2,105.7	0.9	6.30	1	1	1
12/21/2020 22:00	1.3	12.2	2,115.1	0.9	6.30	1	1	1
12/21/2020 23:00	1.3	12.5	2,060.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.9	1,922.7	0.9	140.30 #	24 #	24 #	15 #
Minimum:	1.0	11.8	1,561.7	0.8	4.70	1	1	0
Maximum:	1.4	13.7	2,203.6	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2020 00:00	1.2	12.9	1,952.8	0.9	5.90	1	1	1
12/22/2020 01:00	1.0	13.6	1,672.4	0.8	5.00	1	1	0
12/22/2020 02:00	1.0	13.6	1,552.5	0.8	4.70	1	1	0
12/22/2020 03:00	1.0	13.6	1,531.0	0.8	4.60	1	1	0
12/22/2020 04:00	1.0	13.4	1,728.7	0.8	5.20	1	1	1
12/22/2020 05:00	1.4	12.5	2,066.2	1.0	8.30	1	1	1
12/22/2020 06:00	1.3	12.4	2,103.3	0.9	6.30	1	1	1
12/22/2020 07:00	1.3	12.1	2,173.9	0.9	6.50	1	1	1
12/22/2020 08:00	1.1	13.5	1,737.4	0.9	5.20	1	1	1
12/22/2020 09:00	1.0	13.6	1,627.0	0.8	4.90	1	1	0
12/22/2020 10:00	1.1	13.7	1,708.3	0.9	5.10	1	1	0
12/22/2020 11:00	1.1	13.7	1,646.9	0.9	4.90	1	1	0
12/22/2020 12:00	1.1	13.7	1,595.4	0.9	4.80	1	1	0
12/22/2020 13:00	1.1	13.7	1,661.6	0.9	5.00	1	1	0
12/22/2020 14:00	1.1	13.7	1,694.4	0.9	5.10	1	1	0
12/22/2020 15:00	1.0	13.5	1,717.8	0.8	5.20	1	1	1
12/22/2020 16:00	1.3	12.6	2,045.2	0.9	6.10	1	1	1
12/22/2020 17:00	1.4	11.9	2,173.7	0.9	6.50	1	1	1
12/22/2020 18:00	1.3	11.8	2,204.5	0.8	6.60	1	1	1
12/22/2020 19:00	1.3	11.8	2,211.9	0.8	6.60	1	1	1
12/22/2020 20:00	1.3	11.7	2,229.0	0.8	6.70	1	1	1
12/22/2020 21:00	1.3	12.0	2,177.0	0.9	6.50	1	1	1
12/22/2020 22:00	1.3	12.1	2,142.1	0.9	6.40	1	1	1
12/22/2020 23:00	1.3	12.3	2,105.9	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.9	1,894.1	0.9	138.40 #	24 #	24 #	15 #
Minimum:	1.0	11.7	1,531.0	0.8	4.60	1	1	0
Maximum:	1.4	13.7	2,229.0	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2020 00:00	1.2	12.6	2,020.5	0.9	6.10	1	1	1
12/23/2020 01:00	0.9	13.7	1,716.9	0.7	5.20	1	1	0
12/23/2020 02:00	1.1	13.4	1,841.5	0.9	5.50	1	1	1
12/23/2020 03:00	1.2	13.0	1,956.4	0.9	5.90	1	1	1
12/23/2020 04:00	1.2	12.6	2,023.8	0.9	6.10	1	1	1
12/23/2020 05:00	0.8	13.7	1,709.6	0.7	3.40	1	1	0
12/23/2020 06:00	1.1	13.3	1,855.4	0.9	5.60	1	1	1
12/23/2020 07:00	1.3	12.1	2,169.0	0.9	6.50	1	1	1
12/23/2020 08:00	1.3	12.1	2,149.0	0.9	6.40	1	1	1
12/23/2020 09:00	1.2	12.6	2,019.1	0.9	6.10	1	1	1
12/23/2020 10:00	1.0	13.7	1,690.9	0.8	5.10	1	1	0
12/23/2020 11:00	1.1	13.8	1,626.3	0.9	4.90	1	1	0
12/23/2020 12:00	1.1	13.8	1,661.5	0.9	5.00	1	1	0
12/23/2020 13:00	1.1	13.8	1,692.3	0.9	5.10	1	1	0
12/23/2020 14:00	1.1	13.8	1,697.7	0.9	5.10	1	1	0
12/23/2020 15:00	1.0	13.5	1,695.4	0.8	5.10	1	1	1
12/23/2020 16:00	1.3	12.2	2,105.1	0.9	6.30	1	1	1
12/23/2020 17:00	1.4	11.5	2,259.4	0.9	6.80	1	1	1
12/23/2020 18:00	1.4	11.4	2,296.2	0.9	6.90	1	1	1
12/23/2020 19:00	1.3	11.4	2,306.9	0.8	6.90	1	1	1
12/23/2020 20:00	1.3	11.4	2,301.7	0.8	6.90	1	1	1
12/23/2020 21:00	1.3	12.0	2,178.2	0.9	6.50	1	1	1
12/23/2020 22:00	1.3	12.1	2,155.9	0.9	6.50	1	1	1
12/23/2020 23:00	1.3	12.3	2,140.3	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.7	1,969.5	0.9	140.30 #	24 #	24 #	17 #
Minimum:	0.8	11.4	1,626.3	0.7	3.40	1	1	0
Maximum:	1.4	13.8	2,306.9	0.9	6.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2020 00:00	1.2	12.7	2,080.1	0.9	6.20	1	1	1
12/24/2020 01:00	1.2	12.9	1,987.5	0.9	6.00	1	1	1
12/24/2020 02:00	1.0	13.6	1,758.3	0.8	5.30	1	1	0
12/24/2020 03:00	1.1	13.3	1,847.2	0.9	5.50	1	1	1
12/24/2020 04:00	1.2	13.1	1,947.0	0.9	5.80	1	1	1
12/24/2020 05:00	1.0	13.0	1,962.1	0.7	5.90	1	1	1
12/24/2020 06:00	1.0	13.7	1,720.7	0.8	5.20	1	1	0
12/24/2020 07:00	1.1	13.7	1,710.5	0.9	5.10	1	1	0
12/24/2020 08:00	1.1	13.6	1,706.9	0.9	5.10	1	1	0
12/24/2020 09:00	0.9	13.0	1,967.8	0.7	3.90	1	1	1
12/24/2020 10:00	1.3	12.5	2,068.8	0.9	6.20	1	1	1
12/24/2020 11:00	0.9	13.7	1,656.9	0.7	5.00	1	1	0
12/24/2020 12:00	1.1	13.7	1,650.5	0.9	5.00	1	1	0
12/24/2020 13:00	1.1	13.7	1,674.5	0.9	5.00	1	1	0
12/24/2020 14:00	1.2	13.7	1,697.5	1.0	6.80	1	1	0
12/24/2020 15:00	1.2	13.2	1,823.1	0.9	5.50	1	1	1
12/24/2020 16:00	1.3	12.3	2,081.4	0.9	6.20	1	1	1
12/24/2020 17:00	1.3	11.9	2,166.7	0.9	6.50	1	1	1
12/24/2020 18:00	1.3	11.7	2,209.1	0.8	6.60	1	1	1
12/24/2020 19:00	1.3	11.8	2,202.6	0.8	6.60	1	1	1
12/24/2020 20:00	1.4	11.6	2,232.8	0.9	6.70	1	1	1
12/24/2020 21:00	1.3	12.0	2,162.0	0.9	6.50	1	1	1
12/24/2020 22:00	1.3	11.8	2,196.3	0.8	6.60	1	1	1
12/24/2020 23:00	1.3	12.2	2,120.7	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.9	1,943.0	0.9	139.60 #	24 #	24 #	16 #
Minimum:	0.9	11.6	1,650.5	0.7	3.90	1	1	0
Maximum:	1.4	13.7	2,232.8	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2020 00:00	1.3	12.2	2,103.3	0.9	6.30	1	1	1
12/25/2020 01:00	1.3	12.2	2,095.3	0.9	6.30	1	1	1
12/25/2020 02:00	1.3	12.4	2,037.2	0.9	6.10	1	1	1
12/25/2020 03:00	1.1	13.7	1,716.1	0.9	5.10	1	1	0
12/25/2020 04:00	1.1	13.2	1,853.4	0.8	5.60	1	1	1
12/25/2020 05:00	1.5	12.2	2,085.6	1.0	8.30	1	1	1
12/25/2020 06:00	1.2	12.4	2,052.0	0.8	6.20	1	1	1
12/25/2020 07:00	1.1	13.6	1,674.1	0.9	5.00	1	1	0
12/25/2020 08:00	1.1	13.6	1,637.7	0.9	4.90	1	1	0
12/25/2020 09:00	1.1	13.6	1,635.5	0.9	4.90	1	1	0
12/25/2020 10:00	1.2	13.6	1,611.6	1.0	6.40	1	1	0
12/25/2020 11:00	1.2	13.6	1,692.9	1.0	6.80	1	1	0
12/25/2020 12:00	1.2	13.6	1,698.4	1.0	6.80	1	1	0
12/25/2020 13:00	1.2	13.6	1,699.7	1.0	6.80	1	1	0
12/25/2020 14:00	1.2	13.6	1,653.5	1.0	6.60	1	1	0
12/25/2020 15:00	1.2	13.4	1,754.2	0.9	5.30	1	1	1
12/25/2020 16:00	1.3	12.3	2,060.1	0.9	6.20	1	1	1
12/25/2020 17:00	1.4	12.0	2,120.1	0.9	6.40	1	1	1
12/25/2020 18:00	1.3	12.2	2,084.3	0.9	6.30	1	1	1
12/25/2020 19:00	1.4	11.9	2,139.0	0.9	6.40	1	1	1
12/25/2020 20:00	1.2	12.7	1,944.5	0.9	5.80	1	1	1
12/25/2020 21:00	1.0	13.6	1,713.2	0.8	5.10	1	1	0
12/25/2020 22:00	1.1	13.2	1,833.8	0.8	5.50	1	1	1
12/25/2020 23:00	1.3	12.8	1,965.9	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.0	1,869.2	0.9	145.00 #	24 #	24 #	14 #
Minimum:	1.0	11.9	1,611.6	0.8	4.90	1	1	0
Maximum:	1.5	13.7	2,139.0	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2020 00:00	1.3	12.3	2,052.3	0.9	6.20	1	1	1
12/26/2020 01:00	1.2	12.8	1,917.7	0.9	5.80	1	1	1
12/26/2020 02:00	1.1	13.6	1,703.0	0.9	5.10	1	1	0
12/26/2020 03:00	1.2	13.4	1,788.8	0.9	5.40	1	1	1
12/26/2020 04:00	1.3	12.3	2,051.2	0.9	6.20	1	1	1
12/26/2020 05:00	1.3	12.9	1,949.9	1.0	7.80	1	1	1
12/26/2020 06:00	0.9	13.7	1,712.1	0.7	5.10	1	1	0
12/26/2020 07:00	1.1	13.7	1,676.7	0.9	5.00	1	1	0
12/26/2020 08:00	1.2	13.7	1,621.9	1.0	6.50	1	1	0
12/26/2020 09:00	1.2	13.7	1,677.0	1.0	6.70	1	1	0
12/26/2020 10:00	1.2	13.7	1,577.0	1.0	6.30	1	1	0
12/26/2020 11:00	1.1	13.7	1,467.6	0.9	4.40	1	1	0
12/26/2020 12:00	1.2	13.7	1,594.3	1.0	6.40	1	1	0
12/26/2020 13:00	1.2	13.7	1,702.3	1.0	6.80	1	1	0
12/26/2020 14:00	1.2	13.7	1,676.4	1.0	6.70	1	1	0
12/26/2020 15:00	1.1	13.7	1,595.0	0.9	4.80	1	1	0
12/26/2020 16:00	1.0	13.5	1,699.8	0.8	5.10	1	1	1
12/26/2020 17:00	1.3	12.4	2,073.9	0.9	6.20	1	1	1
12/26/2020 18:00	1.2	12.7	2,006.4	0.9	6.00	1	1	1
12/26/2020 19:00	1.3	12.3	2,085.2	0.9	6.30	1	1	1
12/26/2020 20:00	1.3	12.4	2,087.7	0.9	6.30	1	1	1
12/26/2020 21:00	1.3	12.4	2,072.5	0.9	6.20	1	1	1
12/26/2020 22:00	1.3	12.3	2,100.8	0.9	6.30	1	1	1
12/26/2020 23:00	1.3	12.4	2,073.9	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.1	1,831.8	0.9	143.80 #	24 #	24 #	13 #
Minimum:	0.9	12.3	1,467.6	0.7	4.40	1	1	0
Maximum:	1.3	13.7	2,100.8	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2020 00:00	1.3	12.4	2,072.8	0.9	6.20	1	1	1
12/27/2020 01:00	1.3	12.4	2,065.2	0.9	6.20	1	1	1
12/27/2020 02:00	1.2	13.0	1,924.8	0.9	5.80	1	1	1
12/27/2020 03:00	1.0	13.7	1,718.1	0.8	5.20	1	1	0
12/27/2020 04:00	1.1	13.4	1,738.2	0.9	5.20	1	1	1
12/27/2020 05:00	1.5	12.2	2,075.3	1.0	8.30	1	1	1
12/27/2020 06:00	1.2	12.3	2,072.3	0.8	6.20	1	1	1
12/27/2020 07:00	1.1	13.6	1,709.0	0.9	5.10	1	1	1
12/27/2020 08:00	1.1	13.7	1,705.6	0.9	5.10	1	1	0
12/27/2020 09:00	1.1	13.6	1,676.0	0.9	5.00	1	1	0
12/27/2020 10:00	1.1	13.7	1,620.6	0.9	4.90	1	1	0
12/27/2020 11:00	1.2	13.7	1,653.1	1.0	6.60	1	1	0
12/27/2020 12:00	1.1	13.7	1,698.9	0.9	5.10	1	1	0
12/27/2020 13:00	1.1	13.7	1,622.9	0.9	4.90	1	1	0
12/27/2020 14:00	1.2	13.7	1,695.8	1.0	6.80	1	1	0
12/27/2020 15:00	1.1	13.5	1,735.3	0.9	5.20	1	1	1
12/27/2020 16:00	1.3	12.3	2,081.3	0.9	6.20	1	1	1
12/27/2020 17:00	1.3	11.9	2,164.3	0.9	6.50	1	1	1
12/27/2020 18:00	1.4	11.8	2,180.7	0.9	6.50	1	1	1
12/27/2020 19:00	1.4	11.4	2,257.6	0.9	6.80	1	1	1
12/27/2020 20:00	1.3	11.8	2,132.8	0.8	6.40	1	1	1
12/27/2020 21:00	1.0	13.7	1,718.6	0.8	5.20	1	1	0
12/27/2020 22:00	1.1	13.1	1,863.6	0.8	5.60	1	1	1
12/27/2020 23:00	1.3	12.0	2,130.0	0.9	6.40	1	1	1
Average/Sum#:	1.2	12.9	1,888.0	0.9	141.40 #	24 #	24 #	15 #
Minimum:	1.0	11.4	1,620.6	0.8	4.90	1	1	0
Maximum:	1.5	13.7	2,257.6	1.0	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2020 00:00	1.3	12.5	1,992.2	0.9	6.00	1	1	1
12/28/2020 01:00	1.0	13.7	1,667.1	0.8	5.00	1	1	0
12/28/2020 02:00	1.1	13.2	1,853.2	0.8	5.60	1	1	1
12/28/2020 03:00	1.3	12.3	2,077.2	0.9	6.20	1	1	1
12/28/2020 04:00	1.2	12.7	1,943.2	0.9	5.80	1	1	1
12/28/2020 05:00	1.0	13.7	1,722.4	0.8	5.20	1	1	0
12/28/2020 06:00	1.1	13.2	1,844.7	0.8	5.50	1	1	1
12/28/2020 07:00	1.4	11.6	2,208.7	0.9	6.60	1	1	1
12/28/2020 08:00	1.3	11.8	2,170.8	0.8	6.50	1	1	1
12/28/2020 09:00	1.2	12.4	2,020.5	0.8	6.10	1	1	1
12/28/2020 10:00	1.0	13.7	1,677.1	0.8	5.00	1	1	0
12/28/2020 11:00	1.1	13.7	1,685.5	0.9	5.10	1	1	0
12/28/2020 12:00	1.2	13.7	1,707.0	1.0	6.80	1	1	0
12/28/2020 13:00	1.2	13.7	1,685.5	1.0	6.70	1	1	0
12/28/2020 14:00	1.2	13.7	1,704.9	1.0	6.80	1	1	0
12/28/2020 15:00	1.2	13.3	1,792.3	0.9	5.40	1	1	1
12/28/2020 16:00	1.3	12.3	2,081.9	0.9	6.20	1	1	1
12/28/2020 17:00	1.4	11.3	2,274.7	0.9	6.80	1	1	1
12/28/2020 18:00	1.3	11.3	2,278.9	0.8	6.80	1	1	1
12/28/2020 19:00	1.3	11.3	2,282.4	0.8	6.80	1	1	1
12/28/2020 20:00	1.4	11.3	2,272.8	0.9	6.80	1	1	1
12/28/2020 21:00	1.3	11.4	2,250.2	0.8	6.80	1	1	1
12/28/2020 22:00	1.4	11.6	2,216.6	0.9	6.60	1	1	1
12/28/2020 23:00	1.3	11.9	2,157.0	0.9	6.50	1	1	1
Average/Sum#:	1.2	12.6	1,982.0	0.9	147.60 #	24 #	24 #	17 #
Minimum:	1.0	11.3	1,667.1	0.8	5.00	1	1	0
Maximum:	1.4	13.7	2,282.4	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2020 00:00	1.3	11.9	2,152.9	0.9	6.50	1	1	1
12/29/2020 01:00	1.3	12.2	2,071.7	0.9	6.20	1	1	1
12/29/2020 02:00	1.1	13.7	1,725.2	0.9	5.20	1	1	0
12/29/2020 03:00	1.1	13.3	1,860.4	0.9	5.60	1	1	1
12/29/2020 04:00	1.3	12.1	2,131.0	0.9	6.40	1	1	1
12/29/2020 05:00	1.1	12.1	2,154.0	0.7	6.50	1	1	1
12/29/2020 06:00	1.4	11.5	2,278.5	0.9	6.80	1	1	1
12/29/2020 07:00	1.3	11.7	2,235.2	0.8	6.70	1	1	1
12/29/2020 08:00	1.3	11.8	2,209.9	0.8	6.60	1	1	1
12/29/2020 09:00	1.0	13.2	1,807.9	0.8	5.40	1	1	1
12/29/2020 10:00	1.0	13.7	1,702.2	0.8	5.10	1	1	0
12/29/2020 11:00	1.0	13.7	1,684.2	0.8	5.10	1	1	0
12/29/2020 12:00	1.1	13.8	1,706.6	0.9	5.10	1	1	0
12/29/2020 13:00	1.1	13.8	1,658.9	0.9	5.00	1	1	0
12/29/2020 14:00	1.1	13.8	1,695.0	0.9	5.10	1	1	0
12/29/2020 15:00	1.1	13.8	1,688.9	0.9	5.10	1	1	0
12/29/2020 16:00	1.1	13.5	1,711.9	0.9	5.10	1	1	1
12/29/2020 17:00	1.3	11.9	2,171.7	0.9	6.50	1	1	1
12/29/2020 18:00	1.3	11.4	2,267.8	0.8	6.80	1	1	1
12/29/2020 19:00	1.3	11.4	2,270.1	0.8	6.80	1	1	1
12/29/2020 20:00	1.3	11.9	2,173.5	0.9	6.50	1	1	1
12/29/2020 21:00	1.3	12.2	2,106.8	0.9	6.30	1	1	1
12/29/2020 22:00	1.3	12.2	2,108.8	0.9	6.30	1	1	1
12/29/2020 23:00	1.3	12.5	2,073.1	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.6	1,985.3	0.9	142.90 #	24 #	24 #	17 #
Minimum:	1.0	11.4	1,658.9	0.7	5.00	1	1	0
Maximum:	1.4	13.8	2,278.5	0.9	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2020 00:00	1.3	12.6	2,062.9	0.9	6.20	1	1	1
12/30/2020 01:00	1.1	13.1	1,930.0	0.8	5.80	1	1	1
12/30/2020 02:00	1.0	13.7	1,711.6	0.8	5.10	1	1	0
12/30/2020 03:00	1.1	13.5	1,732.5	0.9	5.20	1	1	1
12/30/2020 04:00	1.2	12.8	2,041.6	0.9	6.10	1	1	1
12/30/2020 05:00	1.3	12.5	2,068.3	0.9	6.20	1	1	1
12/30/2020 06:00	1.3	12.0	2,204.9	0.9	6.60	1	1	1
12/30/2020 07:00	1.2	12.4	2,112.0	0.8	6.30	1	1	1
12/30/2020 08:00	1.2	12.7	2,041.4	0.9	6.10	1	1	1
12/30/2020 09:00	1.2	13.0	1,952.5	0.9	5.90	1	1	1
12/30/2020 10:00	1.1	13.7	1,721.6	0.9	5.20	1	1	0
12/30/2020 11:00	1.2	13.7	1,703.1	1.0	6.80	1	1	0
12/30/2020 12:00	1.2	13.7	1,700.5	1.0	6.80	1	1	0
12/30/2020 13:00	1.2	13.7	1,660.7	1.0	6.60	1	1	0
12/30/2020 14:00	1.2	13.7	1,660.4	1.0	6.60	1	1	0
12/30/2020 15:00	1.1	13.5	1,735.1	0.9	5.20	1	1	1
12/30/2020 16:00	1.3	12.5	2,046.4	0.9	6.10	1	1	1
12/30/2020 17:00	1.4	11.9	2,165.5	0.9	6.50	1	1	1
12/30/2020 18:00	1.3	11.9	2,154.1	0.9	6.50	1	1	1
12/30/2020 19:00	1.3	12.3	2,077.2	0.9	6.20	1	1	1
12/30/2020 20:00	1.3	12.2	2,100.2	0.9	6.30	1	1	1
12/30/2020 21:00	1.3	12.2	2,092.7	0.9	6.30	1	1	1
12/30/2020 22:00	1.3	12.3	2,065.3	0.9	6.20	1	1	1
12/30/2020 23:00	1.3	12.5	2,055.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	12.8	1,949.8	0.9	147.00 #	24 #	24 #	18 #
Minimum:	1.0	11.9	1,660.4	0.8	5.10	1	1	0
Maximum:	1.4	13.7	2,204.9	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2020 00:00	1.2	13.0	1,924.4	0.9	5.80	1	1	1
12/31/2020 01:00	1.0	13.6	1,644.1	0.8	4.90	1	1	0
12/31/2020 02:00	1.1	13.3	1,843.4	0.9	5.50	1	1	1
12/31/2020 03:00	1.2	13.0	1,948.6	0.9	5.80	1	1	1
12/31/2020 04:00	1.2	13.0	1,928.5	0.9	5.80	1	1	1
12/31/2020 05:00	1.0	13.6	1,712.4	0.8	5.10	1	1	0
12/31/2020 06:00	1.2	13.6	1,702.8	1.0	6.80	1	1	0
12/31/2020 07:00	1.1	13.6	1,661.0	0.9	5.00	1	1	0
12/31/2020 08:00	1.1	13.7	1,616.7	0.9	4.90	1	1	0
12/31/2020 09:00	1.2	13.7	1,683.3	1.0	6.70	1	1	0
12/31/2020 10:00	1.2	13.7	1,705.5	1.0	6.80	1	1	0
12/31/2020 11:00	1.2	13.7	1,700.2	1.0	6.80	1	1	0
12/31/2020 12:00	1.2	13.7	1,664.4	1.0	6.70	1	1	0
12/31/2020 13:00	1.2	13.7	1,650.5	1.0	6.60	1	1	0
12/31/2020 14:00	1.2	13.7	1,663.6	1.0	6.70	1	1	0
12/31/2020 15:00	1.2	13.7	1,708.6	1.0	6.80	1	1	0
12/31/2020 16:00	1.2	13.2	1,845.1	0.9	5.50	1	1	1
12/31/2020 17:00	1.3	12.1	2,115.1	0.9	6.30	1	1	1
12/31/2020 18:00	1.3	11.9	2,170.2	0.9	6.50	1	1	1
12/31/2020 19:00	1.3	11.9	2,169.0	0.9	6.50	1	1	1
12/31/2020 20:00	1.3	11.9	2,170.8	0.9	6.50	1	1	1
12/31/2020 21:00	1.3	11.9	2,167.5	0.9	6.50	1	1	1
12/31/2020 22:00	1.3	12.1	2,135.4	0.9	6.40	1	1	1
12/31/2020 23:00	1.3	12.2	2,096.1	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.1	1,859.5	0.9	147.20 #	24 #	24 #	12 #
Minimum:	1.0	11.9	1,616.7	0.8	4.90	1	1	0
Maximum:	1.3	13.7	2,170.8	1.0	6.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2020 00:00	1.0	13.9	1,618.5	0.8	4.90	1	1	0
10/01/2020 01:00	1.4	13.3	1,765.8	1.1	7.10	1	1	1
10/01/2020 02:00	1.5	12.6	1,963.0	1.1	7.90	1	1	1
10/01/2020 03:00	1.5	12.4	1,975.4	1.0	7.90	1	1	1
10/01/2020 04:00	1.0	13.9	1,648.7	0.8	4.90	1	1	0
10/01/2020 05:00	1.2	13.4	1,805.5	0.9	5.40	1	1	1
10/01/2020 06:00	1.2	12.5	2,048.9	0.8	6.10	1	1	1
10/01/2020 07:00	1.4	13.0	1,834.6	1.0	7.30	1	1	1
10/01/2020 08:00	1.0	13.9	1,538.0	0.8	4.60	1	1	0
10/01/2020 09:00	0.7	14.0	1,318.5	0.6	2.60	1	1	0
10/01/2020 10:00	0.9	13.9	1,496.3	0.8	4.50	1	1	1
10/01/2020 11:00	1.5	12.5	2,026.6	1.1	8.10	1	1	1
10/01/2020 12:00	1.6	12.1	2,106.3	1.1	8.40	1	1	1
10/01/2020 13:00	1.6	11.9	2,141.9	1.0	8.60	1	1	1
10/01/2020 14:00	1.6	11.8	2,147.8	1.0	8.60	1	1	1
10/01/2020 15:00	1.6	11.9	2,120.4	1.0	8.50	1	1	1
10/01/2020 16:00	1.6	12.0	2,103.1	1.1	8.40	1	1	1
10/01/2020 17:00	1.6	12.0	2,097.1	1.1	8.40	1	1	1
10/01/2020 18:00	1.6	12.2	2,071.7	1.1	8.30	1	1	1
10/01/2020 19:00	1.6	12.1	2,076.0	1.1	8.30	1	1	1
10/01/2020 20:00	1.6	12.1	2,087.3	1.1	8.30	1	1	1
10/01/2020 21:00	1.6	12.2	2,088.7	1.1	8.40	1	1	1
10/01/2020 22:00	1.6	12.3	2,065.0	1.1	8.30	1	1	1
10/01/2020 23:00	1.5	12.6	1,987.4	1.1	7.90	1	1	1
Average/Sum#:	1.4	12.7	1,922.2	1.0	171.70 #	24 #	24 #	20 #
Minimum:	0.7	11.8	1,318.5	0.6	2.60	1	1	0
Maximum:	1.6	14.0	2,147.8	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2020 00:00	0.9	13.8	1,574.6	0.7	4.70	1	1	0
10/02/2020 01:00	1.0	13.8	1,698.7	0.8	5.10	1	1	0
10/02/2020 02:00	0.8	13.9	1,537.3	0.7	3.10	1	1	0
10/02/2020 03:00	0.9	13.9	1,579.8	0.8	4.70	1	1	0
10/02/2020 04:00	1.0	13.6	1,665.0	0.8	5.00	1	1	1
10/02/2020 05:00	1.5	12.6	2,033.1	1.1	8.10	1	1	1
10/02/2020 06:00	1.5	12.7	1,991.3	1.1	8.00	1	1	1
10/02/2020 07:00	1.1	13.8	1,751.4	0.9	5.30	1	1	0
10/02/2020 08:00	0.8	13.9	1,464.0	0.7	2.90	1	1	0
10/02/2020 09:00	0.9	14.0	1,584.4	0.8	4.80	1	1	0
10/02/2020 10:00	0.9	14.0	1,617.5	0.8	4.90	1	1	0
10/02/2020 11:00	1.1	13.6	1,668.7	0.9	5.00	1	1	1
10/02/2020 12:00	1.6	12.2	2,072.1	1.1	8.30	1	1	1
10/02/2020 13:00	1.6	11.8	2,164.4	1.0	8.70	1	1	1
10/02/2020 14:00	1.7	11.7	2,157.9	1.1	8.60	1	1	1
10/02/2020 15:00	1.6	11.8	2,137.7	1.0	8.60	1	1	1
10/02/2020 16:00	1.6	11.8	2,139.0	1.0	8.60	1	1	1
10/02/2020 17:00	1.6	11.8	2,142.9	1.0	8.60	1	1	1
10/02/2020 18:00	1.6	12.0	2,110.0	1.1	8.40	1	1	1
10/02/2020 19:00	1.6	12.1	2,085.0	1.1	8.30	1	1	1
10/02/2020 20:00	1.6	12.1	2,090.1	1.1	8.40	1	1	1
10/02/2020 21:00	1.6	12.4	2,028.9	1.1	8.10	1	1	1
10/02/2020 22:00	1.6	12.4	2,047.1	1.1	8.20	1	1	1
10/02/2020 23:00	1.6	12.3	2,056.7	1.1	8.20	1	1	1
Average/Sum#:	1.3	12.8	1,891.6	1.0	162.60 #	24 #	24 #	16 #
Minimum:	0.8	11.7	1,464.0	0.7	2.90	1	1	0
Maximum:	1.7	14.0	2,164.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	3.0	14.1	1,257.5	2.6	6.30	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/03/2020 12:00	27.0	17.7	455.8	49.8	48.37	1	0	0
10/03/2020 13:00	10.4	14.6	1,149.2	9.7	41.40	1	0	0
10/03/2020 14:00	1.1	13.9	1,610.8	0.9	4.80	1	1	0
10/03/2020 15:00	1.1	13.6	1,631.8	0.9	4.90	1	1	1
10/03/2020 16:00	1.6	12.1	2,072.1	1.1	8.30	1	1	1
10/03/2020 17:00	1.6	11.8	2,152.4	1.0	8.60	1	1	1
10/03/2020 18:00	1.6	11.9	2,135.4	1.0	8.50	1	1	1
10/03/2020 19:00	1.6	11.9	2,138.9	1.0	8.60	1	1	1
10/03/2020 20:00	1.6	12.2	2,076.3	1.1	8.30	1	1	1
10/03/2020 21:00	1.5	12.5	2,009.6	1.1	8.00	1	1	1
10/03/2020 22:00	2.6	13.8	1,437.2	2.2	8.63	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.6	13.3	1,677.3	6.0	164.70 #	12 #	8 #	9 #
Minimum:	1.1	11.8	455.8	0.9	4.80	0	0	0
Maximum:	27.0	17.7	2,152.4	49.8	48.37	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/04/2020 13:00	29.5	17.0	534.1	44.6	76.21	1	0	0
10/04/2020 14:00	4.3	14.1	1,394.0	3.7	19.50	1	0	0
10/04/2020 15:00	1.1	13.8	1,700.8	0.9	5.10	1	1	0
10/04/2020 16:00	1.3	13.1	1,814.1	1.0	7.30	1	1	1
10/04/2020 17:00	1.6	12.1	2,087.0	1.1	8.30	1	1	1
10/04/2020 18:00	1.5	12.4	2,024.0	1.0	8.10	1	1	1
10/04/2020 19:00	1.5	12.5	2,017.4	1.1	8.10	1	1	1
10/04/2020 20:00	1.6	12.4	2,020.3	1.1	8.10	1	1	1
10/04/2020 21:00	1.6	12.3	2,047.7	1.1	8.20	1	1	1
10/04/2020 22:00	1.5	12.9	1,926.2	1.1	7.70	1	1	1
10/04/2020 23:00	1.5	13.0	1,899.0	1.1	7.60	1	1	1
Average/Sum#:	4.3	13.2	1,769.5	5.3	164.21 #	11 #	9 #	8 #
Minimum:	1.1	12.1	534.1	0.9	5.10	0	0	0
Maximum:	29.5	17.0	2,087.0	44.6	76.21	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2020 00:00	1.0	13.9	1,649.9	0.8	4.90	1	1	0
10/05/2020 01:00	1.0	13.9	1,639.6	0.8	4.90	1	1	0
10/05/2020 02:00	0.9	13.9	1,590.4	0.8	4.80	1	1	0
10/05/2020 03:00	0.8	14.0	1,566.2	0.7	4.70	1	1	0
10/05/2020 04:00	1.0	13.7	1,664.3	0.8	5.00	1	1	1
10/05/2020 05:00	1.5	12.6	2,041.3	1.1	8.20	1	1	1
10/05/2020 06:00	1.3	12.5	2,025.0	0.9	6.10	1	1	1
10/05/2020 07:00	0.9	13.9	1,538.7	0.8	4.60	1	1	0
10/05/2020 08:00	0.8	13.9	1,529.4	0.7	3.10	1	1	0
10/05/2020 09:00	0.8	13.9	1,587.6	0.7	3.20	1	1	0
10/05/2020 10:00	0.8	14.0	1,577.6	0.7	4.70	1	1	0
10/05/2020 11:00	1.1	13.9	1,623.9	0.9	4.90	1	1	0
10/05/2020 12:00	1.1	13.9	1,653.1	0.9	5.00	1	1	0
10/05/2020 13:00	1.3	13.2	1,791.3	1.0	7.20	1	1	1
10/05/2020 14:00	1.6	11.9	2,153.9	1.0	8.60	1	1	1
10/05/2020 15:00	1.6	11.8	2,164.4	1.0	8.70	1	1	1
10/05/2020 16:00	1.6	11.8	2,160.9	1.0	8.60	1	1	1
10/05/2020 17:00	1.6	11.9	2,137.8	1.0	8.60	1	1	1
10/05/2020 18:00	1.6	11.8	2,151.7	1.0	8.60	1	1	1
10/05/2020 19:00	1.5	12.4	2,040.2	1.0	8.20	1	1	1
10/05/2020 20:00	1.5	12.4	2,038.1	1.0	8.20	1	1	1
10/05/2020 21:00	1.5	12.5	2,042.9	1.1	8.20	1	1	1
10/05/2020 22:00	3.6	14.1	1,243.9	3.1	7.45	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.3	13.1	1,809.2	1.0	146.45 #	23 #	22 #	13 #
Minimum:	0.8	11.8	1,243.9	0.7	3.10	0	0	0
Maximum:	3.6	14.1	2,164.4	3.1	8.70	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/06/2020 11:00	29.2	17.2	504.7	46.6	63.36	1	0	0
10/06/2020 12:00	8.3	14.3	1,333.6	7.4	36.00	1	0	0
10/06/2020 13:00	1.0	13.9	1,639.2	0.8	4.90	1	1	0
10/06/2020 14:00	1.2	13.6	1,732.8	1.0	6.90	1	1	1
10/06/2020 15:00	1.6	12.2	2,090.8	1.1	8.40	1	1	1
10/06/2020 16:00	1.6	11.9	2,135.4	1.0	8.50	1	1	1
10/06/2020 17:00	1.6	11.8	2,151.9	1.0	8.60	1	1	1
10/06/2020 18:00	1.6	11.8	2,152.4	1.0	8.60	1	1	1
10/06/2020 19:00	1.6	11.9	2,125.6	1.0	8.50	1	1	1
10/06/2020 20:00	1.1	13.6	1,657.4	0.9	5.00	1	1	1
10/06/2020 21:00	1.3	13.3	1,800.0	1.0	7.20	1	1	1
10/06/2020 22:00	1.6	12.4	2,057.1	1.1	8.20	1	1	1
10/06/2020 23:00	1.5	12.8	1,972.4	1.1	7.90	1	1	1
Average/Sum#:	4.1	13.1	1,796.4	5.0	182.06 #	13 #	11 #	10 #
Minimum:	1.0	11.8	504.7	0.8	4.90	0	0	0
Maximum:	29.2	17.2	2,152.4	46.6	63.36	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2020 00:00	1.5	12.6	2,020.8	1.1	8.10	1	1	1
10/07/2020 01:00	1.5	12.8	1,953.3	1.1	7.80	1	1	1
10/07/2020 02:00	0.9	13.9	1,524.9	0.8	4.60	1	1	0
10/07/2020 03:00	0.9	14.0	1,592.4	0.8	4.80	1	1	0
10/07/2020 04:00	1.2	13.3	1,815.9	0.9	5.40	1	1	1
10/07/2020 05:00	1.6	12.3	2,095.6	1.1	8.40	1	1	1
10/07/2020 06:00	1.4	12.7	2,017.7	1.0	8.10	1	1	1
10/07/2020 07:00	0.9	13.9	1,587.0	0.8	4.80	1	1	0
10/07/2020 08:00	0.7	14.0	1,356.8	0.6	2.70	1	1	0
10/07/2020 09:00	0.6	14.0	1,292.7	0.5	2.60	1	1	0
10/07/2020 10:00	0.6	14.0	1,349.1	0.5	2.70	1	1	0
10/07/2020 11:00	1.3	13.4	1,759.4	1.0	7.00	1	1	1
10/07/2020 12:00	1.6	12.0	2,126.6	1.1	8.50	1	1	1
10/07/2020 13:00	1.6	11.9	2,135.4	1.0	8.50	1	1	1
10/07/2020 14:00	1.2	13.5	1,690.8	1.0	6.80	1	1	1
10/07/2020 15:00	1.3	13.2	1,774.8	1.0	7.10	1	1	1
10/07/2020 16:00	1.6	12.2	2,058.2	1.1	8.20	1	1	1
10/07/2020 17:00	1.6	11.9	2,125.6	1.0	8.50	1	1	1
10/07/2020 18:00	1.6	12.1	2,083.9	1.1	8.30	1	1	1
10/07/2020 19:00	1.6	12.3	2,015.1	1.1	8.10	1	1	1
10/07/2020 20:00	1.1	13.9	1,669.8	0.9	5.00	1	1	0
10/07/2020 21:00	1.3	13.3	1,804.7	1.0	7.20	1	1	1
10/07/2020 22:00	1.6	12.3	2,073.8	1.1	8.30	1	1	1
10/07/2020 23:00	3.2	14.2	1,205.7	2.8	6.05	1	0	1
Average/Sum#:	1.4	13.1	1,797.1	1.0	157.55 #	24 #	23 #	17 #
Minimum:	0.6	11.9	1,205.7	0.5	2.60	1	0	0
Maximum:	3.2	14.2	2,135.4	2.8	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2020 01:00	28.7	17.6	450.9	51.3	59.64	1	0	0
10/11/2020 02:00	21.4	16.3	628.2	27.4	63.40	1	0	0
10/11/2020 03:00	20.7	15.7	709.1	23.5	61.70	1	0	0
10/11/2020 04:00	16.1	15.4	869.3	17.3	55.60	1	0	0
10/11/2020 05:00	0.5	14.0	1,351.9	0.4	2.70	1	1	0
10/11/2020 06:00	0.6	14.0	1,340.8	0.5	2.70	1	1	0
10/11/2020 07:00	0.6	14.0	1,337.8	0.5	2.70	1	1	0
10/11/2020 08:00	0.6	14.0	1,338.1	0.5	2.70	1	1	0
10/11/2020 09:00	0.6	14.0	1,340.5	0.5	2.70	1	1	0
10/11/2020 10:00	0.6	14.0	1,343.3	0.5	2.70	1	1	0
10/11/2020 11:00	0.7	14.0	1,346.4	0.6	2.70	1	1	0
10/11/2020 12:00	0.7	14.0	1,348.2	0.6	2.70	1	1	0
10/11/2020 13:00	0.7	14.1	1,349.6	0.6	2.70	1	1	0
10/11/2020 14:00	0.7	14.1	1,351.7	0.6	2.70	1	1	0
10/11/2020 15:00	0.7	14.1	1,366.6	0.6	2.70	1	1	0
10/11/2020 16:00	1.4	13.0	1,928.8	1.0	7.70	1	1	1
10/11/2020 17:00	1.5	13.0	1,938.8	1.1	7.80	1	1	1
10/11/2020 18:00	1.5	13.0	1,926.5	1.1	7.70	1	1	1
10/11/2020 19:00	1.5	13.0	1,907.7	1.1	7.60	1	1	1
10/11/2020 20:00	0.7	14.0	1,352.7	0.6	2.70	1	1	0
10/11/2020 21:00	0.7	14.0	1,335.6	0.6	2.70	1	1	0
10/11/2020 22:00	0.6	14.0	1,335.7	0.5	2.70	1	1	0
10/11/2020 23:00	0.6	14.0	1,335.0	0.5	2.70	1	1	0
Average/Sum#:	4.5	14.2	1,327.5	5.7	311.64 #	23 #	19 #	4 #
Minimum:	0.5	13.0	450.9	0.4	2.70	0	0	0
Maximum:	28.7	17.6	1,938.8	51.3	63.40	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0.6	14.0	1,335.1	0.5	2.70	1	1	0
10/12/2020 01:00	0.6	14.0	1,335.8	0.5	2.70	1	1	0
10/12/2020 02:00	0.6	14.0	1,335.6	0.5	2.70	1	1	0
10/12/2020 03:00	0.6	14.0	1,334.0	0.5	2.70	1	1	0
10/12/2020 04:00	0.6	14.0	1,334.5	0.5	2.70	1	1	0
10/12/2020 05:00	0.6	14.0	1,333.0	0.5	2.70	1	1	0
10/12/2020 06:00	0.6	14.0	1,332.0	0.5	2.70	1	1	0
10/12/2020 07:00	0.6	14.0	1,337.7	0.5	2.70	1	1	0
10/12/2020 08:00	0.6	14.0	1,337.5	0.5	2.70	1	1	0
10/12/2020 09:00	0.6	14.0	1,342.6	0.5	2.70	1	1	0
10/12/2020 10:00	0.6	14.0	1,346.6	0.5	2.70	1	1	0
10/12/2020 11:00	0.6	14.0	1,347.3	0.5	2.70	1	1	0
10/12/2020 12:00	0.9	14.0	1,604.1	0.8	4.80	1	1	0
10/12/2020 13:00	0.9	14.0	1,533.8	0.8	4.60	1	1	0
10/12/2020 14:00	0.9	14.0	1,563.5	0.8	4.70	1	1	0
10/12/2020 15:00	1.1	13.6	1,651.4	0.9	5.00	1	1	1
10/12/2020 16:00	1.5	12.6	2,006.2	1.1	8.00	1	1	1
10/12/2020 17:00	1.5	12.6	1,992.1	1.1	8.00	1	1	1
10/12/2020 18:00	1.5	12.7	1,979.4	1.1	7.90	1	1	1
10/12/2020 19:00	1.5	12.9	1,914.1	1.1	7.70	1	1	1
10/12/2020 20:00	1.2	13.8	1,742.0	1.0	7.00	1	1	0
10/12/2020 21:00	1.3	13.4	1,787.9	1.0	7.20	1	1	1
10/12/2020 22:00	1.5	12.7	1,987.3	1.1	7.90	1	1	1
10/12/2020 23:00	1.5	12.9	1,949.8	1.1	7.80	1	1	1
Average/Sum#:	0.9	13.6	1,573.5	0.7	113.00 #	24 #	24 #	8 #
Minimum:	0.6	12.6	1,332.0	0.5	2.70	1	1	0
Maximum:	1.5	14.0	2,006.2	1.1	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	1.0	13.9	1,656.6	0.8	5.00	1	1	0
10/13/2020 01:00	0.9	13.9	1,609.3	0.8	4.80	1	1	0
10/13/2020 02:00	0.7	13.9	1,386.6	0.6	2.80	1	1	0
10/13/2020 03:00	0.8	13.9	1,592.3	0.7	3.20	1	1	0
10/13/2020 04:00	1.3	13.4	1,797.1	1.0	7.20	1	1	1
10/13/2020 05:00	1.5	12.8	1,978.1	1.1	7.90	1	1	1
10/13/2020 06:00	1.2	13.0	1,931.3	0.9	5.80	1	1	1
10/13/2020 07:00	0.9	13.9	1,637.2	0.8	4.90	1	1	0
10/13/2020 08:00	0.7	13.9	1,474.1	0.6	2.90	1	1	0
10/13/2020 09:00	0.7	14.0	1,343.1	0.6	2.70	1	1	0
10/13/2020 10:00	0.9	13.9	1,610.2	0.8	4.80	1	1	0
10/13/2020 11:00	0.8	13.9	1,489.4	0.7	3.00	1	1	0
10/13/2020 12:00	0.8	13.9	1,490.4	0.7	3.00	1	1	0
10/13/2020 13:00	0.8	14.0	1,397.9	0.7	4.20	1	1	0
10/13/2020 14:00	0.9	13.9	1,602.2	0.8	4.80	1	1	0
10/13/2020 15:00	1.1	13.6	1,639.2	0.9	4.90	1	1	1
10/13/2020 16:00	1.6	12.5	2,022.3	1.1	8.10	1	1	1
10/13/2020 17:00	1.6	12.4	2,035.1	1.1	8.10	1	1	1
10/13/2020 18:00	1.5	12.5	2,007.6	1.1	8.00	1	1	1
10/13/2020 19:00	1.5	12.8	1,940.0	1.1	7.80	1	1	1
10/13/2020 20:00	1.0	13.9	1,690.7	0.8	5.10	1	1	0
10/13/2020 21:00	1.2	13.4	1,800.7	0.9	5.40	1	1	1
10/13/2020 22:00	1.6	12.2	2,106.2	1.1	8.40	1	1	1
10/13/2020 23:00	1.5	12.8	1,938.0	1.1	7.80	1	1	1
Average/Sum#:	1.1	13.4	1,715.7	0.9	130.60 #	24 #	24 #	11 #
Minimum:	0.7	12.2	1,343.1	0.6	2.70	1	1	0
Maximum:	1.6	14.0	2,106.2	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	1.0	13.9	1,664.7	0.8	5.00	1	1	0
10/14/2020 01:00	1.1	13.7	1,657.8	0.9	5.00	1	1	1
10/14/2020 02:00	1.5	12.5	2,046.2	1.1	8.20	1	1	1
10/14/2020 03:00	1.5	12.9	1,927.8	1.1	7.70	1	1	1
10/14/2020 04:00	0.9	13.9	1,595.8	0.8	4.80	1	1	0
10/14/2020 05:00	1.1	13.5	1,801.3	0.9	5.40	1	1	1
10/14/2020 06:00	1.4	12.7	2,001.0	1.0	8.00	1	1	1
10/14/2020 07:00	1.5	12.9	1,913.1	1.1	7.70	1	1	1
10/14/2020 08:00	0.8	13.9	1,409.5	0.7	2.80	1	1	0
10/14/2020 09:00	0.6	14.0	1,303.6	0.5	2.60	1	1	0
10/14/2020 10:00	0.8	14.0	1,531.6	0.7	4.60	1	1	0
10/14/2020 11:00	1.1	13.5	1,754.8	0.9	5.30	1	1	1
10/14/2020 12:00	1.6	12.1	2,097.1	1.1	8.40	1	1	1
10/14/2020 13:00	1.6	11.9	2,129.3	1.0	8.50	1	1	1
10/14/2020 14:00	1.0	13.8	1,741.2	0.8	5.20	1	1	1
10/14/2020 15:00	1.1	13.7	1,813.9	0.9	5.40	1	1	1
10/14/2020 16:00	1.4	12.1	2,106.5	0.9	6.30	1	1	1
10/14/2020 17:00	1.6	11.8	2,177.4	1.0	8.70	1	1	1
10/14/2020 18:00	1.6	12.1	2,100.8	1.1	8.40	1	1	1
10/14/2020 19:00	1.5	12.2	2,044.5	1.0	8.20	1	1	1
10/14/2020 20:00	1.0	13.9	1,680.5	0.8	5.00	1	1	0
10/14/2020 21:00	1.3	13.2	1,832.9	1.0	7.30	1	1	1
10/14/2020 22:00	1.6	12.0	2,151.6	1.1	8.60	1	1	1
10/14/2020 23:00	1.5	12.6	1,989.7	1.1	8.00	1	1	1
Average/Sum#:	1.3	13.0	1,853.0	0.9	155.10 #	24 #	24 #	18 #
Minimum:	0.6	11.8	1,303.6	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,177.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	1.0	13.9	1,670.7	0.8	5.00	1	1	0
10/15/2020 01:00	1.2	13.4	1,802.1	0.9	5.40	1	1	1
10/15/2020 02:00	1.6	12.2	2,121.8	1.1	8.50	1	1	1
10/15/2020 03:00	1.6	12.3	2,071.3	1.1	8.30	1	1	1
10/15/2020 04:00	1.0	13.9	1,688.0	0.8	5.10	1	1	0
10/15/2020 05:00	1.2	13.5	1,822.9	1.0	7.30	1	1	1
10/15/2020 06:00	1.4	12.5	2,056.6	1.0	8.20	1	1	1
10/15/2020 07:00	1.4	12.9	1,849.1	1.0	7.40	1	1	1
10/15/2020 08:00	0.6	14.0	1,300.9	0.5	2.60	1	1	0
10/15/2020 09:00	0.6	14.0	1,297.9	0.5	2.60	1	1	0
10/15/2020 10:00	0.6	14.0	1,316.1	0.5	2.60	1	1	0
10/15/2020 11:00	0.8	13.9	1,561.7	0.7	3.10	1	1	0
10/15/2020 12:00	0.9	13.9	1,635.0	0.8	4.90	1	1	0
10/15/2020 13:00	1.3	13.3	1,804.6	1.0	7.20	1	1	1
10/15/2020 14:00	1.6	11.9	2,164.7	1.0	8.70	1	1	1
10/15/2020 15:00	1.6	11.8	2,175.2	1.0	8.70	1	1	1
10/15/2020 16:00	1.6	11.8	2,168.1	1.0	8.70	1	1	1
10/15/2020 17:00	1.6	11.9	2,145.0	1.0	8.60	1	1	1
10/15/2020 18:00	1.6	11.9	2,155.3	1.0	8.60	1	1	1
10/15/2020 19:00	1.6	12.0	2,132.4	1.1	8.50	1	1	1
10/15/2020 20:00	1.6	11.9	2,155.8	1.0	8.60	1	1	1
10/15/2020 21:00	1.6	11.8	2,175.1	1.0	8.70	1	1	1
10/15/2020 22:00	1.6	12.0	2,136.9	1.1	8.50	1	1	1
10/15/2020 23:00	1.5	12.4	2,014.9	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.8	1,892.6	0.9	163.90 #	24 #	24 #	17 #
Minimum:	0.6	11.8	1,297.9	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,175.2	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2020 00:00	1.0	13.8	1,702.4	0.8	5.10	1	1	0
10/16/2020 01:00	0.7	14.0	1,312.2	0.6	2.60	1	1	0
10/16/2020 02:00	1.0	13.8	1,680.6	0.8	5.00	1	1	0
10/16/2020 03:00	1.3	13.4	1,804.3	1.0	7.20	1	1	1
10/16/2020 04:00	1.4	12.9	1,883.6	1.0	7.50	1	1	1
10/16/2020 05:00	1.1	13.8	1,690.3	0.9	5.10	1	1	1
10/16/2020 06:00	1.3	12.4	2,029.9	0.9	6.10	1	1	1
10/16/2020 07:00	1.5	12.8	1,944.4	1.1	7.80	1	1	1
10/16/2020 08:00	0.9	13.9	1,592.7	0.8	4.80	1	1	0
10/16/2020 09:00	0.7	14.0	1,393.6	0.6	2.80	1	1	0
10/16/2020 10:00	0.8	14.0	1,504.5	0.7	4.50	1	1	0
10/16/2020 11:00	1.0	13.7	1,579.5	0.8	4.70	1	1	1
10/16/2020 12:00	1.6	12.1	2,104.8	1.1	8.40	1	1	1
10/16/2020 13:00	1.6	12.2	2,071.4	1.1	8.30	1	1	1
10/16/2020 14:00	1.6	11.9	2,126.5	1.0	8.50	1	1	1
10/16/2020 15:00	1.6	11.9	2,131.6	1.0	8.50	1	1	1
10/16/2020 16:00	1.6	12.3	2,044.6	1.1	8.20	1	1	1
10/16/2020 17:00	1.6	12.1	2,090.7	1.1	8.40	1	1	1
10/16/2020 18:00	1.6	12.2	2,079.8	1.1	8.30	1	1	1
10/16/2020 19:00	1.6	11.9	2,146.3	1.0	8.60	1	1	1
10/16/2020 20:00	1.6	12.0	2,121.0	1.1	8.50	1	1	1
10/16/2020 21:00	1.6	12.1	2,093.4	1.1	8.40	1	1	1
10/16/2020 22:00	1.6	12.3	2,048.1	1.1	8.20	1	1	1
10/16/2020 23:00	1.5	12.5	2,007.9	1.1	8.00	1	1	1
Average/Sum#:	1.3	12.8	1,882.7	1.0	163.50 #	24 #	24 #	18 #
Minimum:	0.7	11.9	1,312.2	0.6	2.60	1	1	0
Maximum:	1.6	14.0	2,146.3	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	1.5	12.8	1,927.3	1.1	7.70	1	1	1
10/17/2020 01:00	0.9	13.9	1,546.0	0.8	4.60	1	1	0
10/17/2020 02:00	0.6	14.0	1,312.2	0.5	2.60	1	1	0
10/17/2020 03:00	0.8	14.0	1,607.7	0.7	4.80	1	1	0
10/17/2020 04:00	0.8	14.0	1,602.7	0.7	4.80	1	1	0
10/17/2020 05:00	0.8	13.9	1,656.1	0.7	3.30	1	1	0
10/17/2020 06:00	1.3	13.3	1,795.5	1.0	7.20	1	1	1
10/17/2020 07:00	1.4	13.0	1,842.5	1.0	7.40	1	1	1
10/17/2020 08:00	0.9	13.8	1,669.7	0.7	5.00	1	1	0
10/17/2020 09:00	1.0	13.8	1,675.8	0.8	5.00	1	1	0
10/17/2020 10:00	0.9	13.9	1,625.3	0.8	4.90	1	1	0
10/17/2020 11:00	0.8	13.9	1,479.6	0.7	3.00	1	1	0
10/17/2020 12:00	0.8	14.0	1,463.6	0.7	4.40	1	1	0
10/17/2020 13:00	0.8	14.0	1,453.4	0.7	4.40	1	1	0
10/17/2020 14:00	1.0	13.6	1,642.4	0.8	4.90	1	1	1
10/17/2020 15:00	1.6	12.1	2,088.5	1.1	8.40	1	1	1
10/17/2020 16:00	1.6	11.8	2,155.1	1.0	8.60	1	1	1
10/17/2020 17:00	1.6	11.8	2,156.5	1.0	8.60	1	1	1
10/17/2020 18:00	1.6	12.3	2,031.7	1.1	8.10	1	1	1
10/17/2020 19:00	1.6	12.3	2,048.0	1.1	8.20	1	1	1
10/17/2020 20:00	1.6	12.3	2,062.9	1.1	8.30	1	1	1
10/17/2020 21:00	1.5	12.7	1,983.4	1.1	7.90	1	1	1
10/17/2020 22:00	1.5	12.3	2,060.7	1.0	8.20	1	1	1
10/17/2020 23:00	1.6	12.3	2,058.5	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.2	1,789.4	0.9	148.50 #	24 #	24 #	13 #
Minimum:	0.6	11.8	1,312.2	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,156.5	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2020 00:00	1.1	13.6	1,686.2	0.9	5.10	1	1	1
10/18/2020 01:00	1.2	13.3	1,799.9	0.9	5.40	1	1	1
10/18/2020 02:00	1.6	12.0	2,148.4	1.1	8.60	1	1	1
10/18/2020 03:00	1.6	12.1	2,081.3	1.1	8.30	1	1	1
10/18/2020 04:00	0.9	13.8	1,659.3	0.7	5.00	1	1	0
10/18/2020 05:00	0.8	13.8	1,595.8	0.7	3.20	1	1	0
10/18/2020 06:00	0.8	13.8	1,553.3	0.7	3.10	1	1	0
10/18/2020 07:00	0.7	13.9	1,499.9	0.6	3.00	1	1	0
10/18/2020 08:00	0.8	13.9	1,599.2	0.7	3.20	1	1	0
10/18/2020 09:00	0.8	13.9	1,607.8	0.7	3.20	1	1	0
10/18/2020 10:00	0.8	14.0	1,573.1	0.7	4.70	1	1	0
10/18/2020 11:00	0.8	14.0	1,606.9	0.7	4.80	1	1	0
10/18/2020 12:00	0.8	13.9	1,618.8	0.7	3.20	1	1	0
10/18/2020 13:00	0.8	13.8	1,596.6	0.7	3.20	1	1	0
10/18/2020 14:00	0.9	13.8	1,629.2	0.7	4.90	1	1	0
10/18/2020 15:00	1.2	13.5	1,737.8	1.0	7.00	1	1	1
10/18/2020 16:00	1.6	12.1	2,057.6	1.1	8.20	1	1	1
10/18/2020 17:00	1.3	13.1	1,757.7	1.0	7.00	1	1	1
10/18/2020 18:00	0.5	14.0	1,284.1	0.4	2.60	1	1	0
10/18/2020 19:00	0.6	14.0	1,377.8	0.5	2.80	1	1	0
10/18/2020 20:00	1.1	13.8	1,688.6	0.9	5.10	1	1	0
10/18/2020 21:00	0.9	13.9	1,681.8	0.8	5.00	1	1	0
10/18/2020 22:00	0.7	13.9	1,485.3	0.6	3.00	1	1	0
10/18/2020 23:00	1.1	13.4	1,795.7	0.9	5.40	1	1	1
Average/Sum#:	1.0	13.6	1,671.8	0.8	115.00 #	24 #	24 #	8 #
Minimum:	0.5	12.0	1,284.1	0.4	2.60	1	1	0
Maximum:	1.6	14.0	2,148.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	1.3	13.1	1,830.2	1.0	7.30	1	1	1
10/19/2020 01:00	0.8	13.8	1,621.3	0.7	3.20	1	1	0
10/19/2020 02:00	0.8	13.8	1,573.3	0.7	3.10	1	1	0
10/19/2020 03:00	0.9	13.8	1,673.4	0.7	5.00	1	1	0
10/19/2020 04:00	1.1	13.4	1,804.0	0.9	5.40	1	1	1
10/19/2020 05:00	1.5	12.3	2,087.1	1.0	8.30	1	1	1
10/19/2020 06:00	1.4	12.4	2,052.5	1.0	8.20	1	1	1
10/19/2020 07:00	0.9	13.8	1,681.4	0.7	5.00	1	1	0
10/19/2020 08:00	0.7	13.9	1,550.3	0.6	3.10	1	1	0
10/19/2020 09:00	0.8	13.9	1,623.3	0.7	3.20	1	1	0
10/19/2020 10:00	0.8	14.0	1,615.3	0.7	4.80	1	1	0
10/19/2020 11:00	0.8	14.0	1,580.4	0.7	4.70	1	1	0
10/19/2020 12:00	0.7	14.0	1,447.0	0.6	2.90	1	1	0
10/19/2020 13:00	0.7	14.0	1,423.2	0.6	2.80	1	1	0
10/19/2020 14:00	1.0	13.7	1,636.8	0.8	4.90	1	1	1
10/19/2020 15:00	1.5	12.4	2,010.8	1.0	8.00	1	1	1
10/19/2020 16:00	1.6	12.0	2,094.6	1.1	8.40	1	1	1
10/19/2020 17:00	1.6	11.9	2,125.5	1.0	8.50	1	1	1
10/19/2020 18:00	1.6	12.1	2,073.5	1.1	8.30	1	1	1
10/19/2020 19:00	1.6	12.0	2,115.6	1.1	8.50	1	1	1
10/19/2020 20:00	1.3	13.1	1,758.0	1.0	7.00	1	1	1
10/19/2020 21:00	1.2	13.3	1,790.8	0.9	5.40	1	1	1
10/19/2020 22:00	1.6	12.4	2,039.5	1.1	8.20	1	1	1
10/19/2020 23:00	1.5	12.9	1,927.1	1.1	7.70	1	1	1
Average/Sum#:	1.2	13.2	1,797.3	0.9	141.90 #	24 #	24 #	14 #
Minimum:	0.7	11.9	1,423.2	0.6	2.80	1	1	0
Maximum:	1.6	14.0	2,125.5	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2020 00:00	0.8	13.9	1,523.8	0.7	3.00	1	1	0
10/20/2020 01:00	0.6	14.0	1,294.6	0.5	2.60	1	1	0
10/20/2020 02:00	0.6	14.0	1,380.4	0.5	2.80	1	1	0
10/20/2020 03:00	1.2	13.4	1,788.3	0.9	5.40	1	1	1
10/20/2020 04:00	1.5	12.5	2,030.2	1.1	8.10	1	1	1
10/20/2020 05:00	1.6	12.5	2,055.4	1.1	8.20	1	1	1
10/20/2020 06:00	1.3	12.5	2,013.7	0.9	6.00	1	1	1
10/20/2020 07:00	0.9	13.8	1,651.6	0.7	5.00	1	1	0
10/20/2020 08:00	0.6	14.0	1,324.7	0.5	2.60	1	1	0
10/20/2020 09:00	0.7	14.0	1,451.2	0.6	2.90	1	1	0
10/20/2020 10:00	0.9	14.0	1,626.8	0.8	4.90	1	1	0
10/20/2020 11:00	1.0	13.6	1,699.7	0.8	5.10	1	1	1
10/20/2020 12:00	1.5	12.3	2,032.9	1.0	8.10	1	1	1
10/20/2020 13:00	1.6	12.2	2,029.9	1.1	8.10	1	1	1
10/20/2020 14:00	1.0	13.8	1,685.2	0.8	5.10	1	1	0
10/20/2020 15:00	1.2	13.0	1,812.9	0.9	5.40	1	1	1
10/20/2020 16:00	1.6	11.9	2,116.0	1.0	8.50	1	1	1
10/20/2020 17:00	1.6	12.0	2,087.3	1.1	8.30	1	1	1
10/20/2020 18:00	1.6	12.2	2,044.2	1.1	8.20	1	1	1
10/20/2020 19:00	1.5	12.5	1,989.8	1.1	8.00	1	1	1
10/20/2020 20:00	1.4	12.7	1,890.3	1.0	7.60	1	1	1
10/20/2020 21:00	1.2	13.5	1,722.0	1.0	6.90	1	1	1
10/20/2020 22:00	1.6	12.4	2,030.2	1.1	8.10	1	1	1
10/20/2020 23:00	1.6	12.1	2,092.8	1.1	8.40	1	1	1
Average/Sum#:	1.2	13.0	1,807.2	0.9	147.30 #	24 #	24 #	16 #
Minimum:	0.6	11.9	1,294.6	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,116.0	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2020 00:00	1.6	12.3	2,038.9	1.1	8.20	1	1	1
10/21/2020 01:00	1.1	13.8	1,682.8	0.9	5.00	1	1	0
10/21/2020 02:00	1.3	13.3	1,737.4	1.0	6.90	1	1	1
10/21/2020 03:00	1.6	12.1	2,083.5	1.1	8.30	1	1	1
10/21/2020 04:00	1.5	12.3	2,052.9	1.0	8.20	1	1	1
10/21/2020 05:00	1.5	12.5	2,021.8	1.1	8.10	1	1	1
10/21/2020 06:00	1.4	12.2	2,090.9	0.9	6.30	1	1	1
10/21/2020 07:00	0.8	13.8	1,542.0	0.7	3.10	1	1	1
10/21/2020 08:00	0.7	13.9	1,520.2	0.6	3.00	1	1	0
10/21/2020 09:00	0.6	14.0	1,352.9	0.5	2.70	1	1	0
10/21/2020 10:00	0.8	14.0	1,566.2	0.7	4.70	1	1	0
10/21/2020 11:00	0.7	14.0	1,517.4	0.6	3.00	1	1	0
10/21/2020 12:00	0.8	14.0	1,592.8	0.7	4.80	1	1	0
10/21/2020 13:00	0.9	13.6	1,665.5	0.7	5.00	1	1	1
10/21/2020 14:00	1.5	12.1	2,071.4	1.0	8.30	1	1	1
10/21/2020 15:00	1.5	12.3	2,024.0	1.0	8.10	1	1	1
10/21/2020 16:00	1.6	12.0	2,088.4	1.1	8.40	1	1	1
10/21/2020 17:00	1.7	11.9	2,112.4	1.1	8.40	1	1	1
10/21/2020 18:00	1.6	11.9	2,111.3	1.0	8.40	1	1	1
10/21/2020 19:00	1.6	12.1	2,065.4	1.1	8.30	1	1	1
10/21/2020 20:00	1.5	12.1	2,095.6	1.0	8.40	1	1	1
10/21/2020 21:00	1.5	12.2	2,074.2	1.0	8.30	1	1	1
10/21/2020 22:00	1.5	12.2	2,059.2	1.0	8.20	1	1	1
10/21/2020 23:00	1.5	12.5	1,960.9	1.1	7.80	1	1	1
Average/Sum#:	1.3	12.8	1,880.3	0.9	159.90 #	24 #	24 #	18 #
Minimum:	0.6	11.9	1,352.9	0.5	2.70	1	1	0
Maximum:	1.7	14.0	2,112.4	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2020 00:00	1.0	13.9	1,678.3	0.8	5.00	1	1	0
10/22/2020 01:00	1.2	13.3	1,800.3	0.9	5.40	1	1	1
10/22/2020 02:00	1.4	12.5	2,019.5	1.0	8.10	1	1	1
10/22/2020 03:00	1.5	12.6	1,998.4	1.1	8.00	1	1	1
10/22/2020 04:00	0.9	13.8	1,666.8	0.7	5.00	1	1	0
10/22/2020 05:00	0.9	13.6	1,742.4	0.7	5.20	1	1	1
10/22/2020 06:00	1.5	12.1	2,131.3	1.0	8.50	1	1	1
10/22/2020 07:00	1.5	12.3	2,062.2	1.0	8.20	1	1	1
10/22/2020 08:00	0.7	13.9	1,475.7	0.6	3.00	1	1	0
10/22/2020 09:00	0.7	14.0	1,574.9	0.6	3.10	1	1	0
10/22/2020 10:00	0.7	14.0	1,604.9	0.6	3.20	1	1	0
10/22/2020 11:00	1.2	13.4	1,793.6	0.9	5.40	1	1	1
10/22/2020 12:00	1.6	12.3	2,091.0	1.1	8.40	1	1	1
10/22/2020 13:00	1.5	12.7	1,960.2	1.1	7.80	1	1	1
10/22/2020 14:00	0.9	13.9	1,574.3	0.8	4.70	1	1	0
10/22/2020 15:00	1.0	13.7	1,669.7	0.8	5.00	1	1	1
10/22/2020 16:00	1.6	12.3	2,105.5	1.1	8.40	1	1	1
10/22/2020 17:00	1.6	12.2	2,122.1	1.1	8.50	1	1	1
10/22/2020 18:00	1.5	12.7	2,001.5	1.1	8.00	1	1	1
10/22/2020 19:00	1.5	12.5	2,066.1	1.1	8.30	1	1	1
10/22/2020 20:00	1.5	12.6	2,038.0	1.1	8.20	1	1	1
10/22/2020 21:00	1.5	12.6	2,037.7	1.1	8.20	1	1	1
10/22/2020 22:00	1.5	12.7	1,994.8	1.1	8.00	1	1	1
10/22/2020 23:00	1.4	12.8	1,943.8	1.0	7.80	1	1	1
Average/Sum#:	1.3	13.0	1,881.4	0.9	159.40 #	24 #	24 #	18 #
Minimum:	0.7	12.1	1,475.7	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,131.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	0.8	14.0	1,624.7	0.7	4.90	1	1	0
10/23/2020 01:00	1.2	13.4	1,797.4	0.9	5.40	1	1	1
10/23/2020 02:00	1.5	12.4	2,077.8	1.0	8.30	1	1	1
10/23/2020 03:00	1.5	12.8	1,985.3	1.1	7.90	1	1	1
10/23/2020 04:00	0.8	13.9	1,678.3	0.7	3.40	1	1	0
10/23/2020 05:00	1.1	13.6	1,810.3	0.9	5.40	1	1	1
10/23/2020 06:00	1.5	12.2	2,138.1	1.0	8.60	1	1	1
10/23/2020 07:00	1.6	12.4	2,097.4	1.1	8.40	1	1	1
10/23/2020 08:00	1.5	12.9	1,986.3	1.1	7.90	1	1	1
10/23/2020 09:00	1.0	13.7	1,706.5	0.8	5.10	1	1	1
10/23/2020 10:00	0.9	13.9	1,677.0	0.8	5.00	1	1	0
10/23/2020 11:00	1.0	13.8	1,724.7	0.8	5.20	1	1	1
10/23/2020 12:00	1.4	12.5	2,053.7	1.0	8.20	1	1	1
10/23/2020 13:00	1.5	12.9	1,946.0	1.1	7.80	1	1	1
10/23/2020 14:00	0.8	13.9	1,595.6	0.7	3.20	1	1	0
10/23/2020 15:00	1.0	13.7	1,733.3	0.8	5.20	1	1	1
10/23/2020 16:00	1.5	12.6	2,035.0	1.1	8.10	1	1	1
10/23/2020 17:00	1.6	12.3	2,089.8	1.1	8.40	1	1	1
10/23/2020 18:00	1.4	13.0	1,914.2	1.0	7.70	1	1	1
10/23/2020 19:00	0.9	13.8	1,687.1	0.7	5.10	1	1	0
10/23/2020 20:00	1.2	13.3	1,824.8	0.9	5.50	1	1	1
10/23/2020 21:00	1.5	12.6	2,047.0	1.1	8.20	1	1	1
10/23/2020 22:00	1.5	12.7	2,011.5	1.1	8.00	1	1	1
10/23/2020 23:00	1.6	12.4	2,110.8	1.1	8.40	1	1	1
Average/Sum#:	1.3	13.1	1,889.7	0.9	159.30 #	24 #	24 #	19 #
Minimum:	0.8	12.2	1,595.6	0.7	3.20	1	1	0
Maximum:	1.6	14.0	2,138.1	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	1.0	13.6	1,710.2	0.8	5.10	1	1	1
10/24/2020 01:00	0.8	13.9	1,685.2	0.7	3.40	1	1	0
10/24/2020 02:00	1.1	13.4	1,815.9	0.9	5.40	1	1	1
10/24/2020 03:00	1.5	12.4	2,084.9	1.0	8.30	1	1	1
10/24/2020 04:00	1.5	12.9	1,943.6	1.1	7.80	1	1	1
10/24/2020 05:00	0.9	13.8	1,670.4	0.7	5.00	1	1	0
10/24/2020 06:00	0.8	13.8	1,665.7	0.7	3.30	1	1	0
10/24/2020 07:00	0.7	13.8	1,620.3	0.6	3.20	1	1	0
10/24/2020 08:00	0.7	13.9	1,565.9	0.6	3.10	1	1	0
10/24/2020 09:00	0.8	13.9	1,611.1	0.7	3.20	1	1	0
10/24/2020 10:00	0.9	13.9	1,669.5	0.8	5.00	1	1	0
10/24/2020 11:00	0.8	13.9	1,627.8	0.7	3.30	1	1	0
10/24/2020 12:00	0.7	13.9	1,425.2	0.6	2.90	1	1	0
10/24/2020 13:00	0.7	13.9	1,420.6	0.6	2.80	1	1	0
10/24/2020 14:00	0.9	13.9	1,620.5	0.8	4.90	1	1	0
10/24/2020 15:00	1.0	13.9	1,685.3	0.8	5.10	1	1	0
10/24/2020 16:00	1.3	13.3	1,794.7	1.0	7.20	1	1	1
10/24/2020 17:00	1.6	12.1	2,114.9	1.1	8.50	1	1	1
10/24/2020 18:00	1.4	12.9	1,929.2	1.0	7.70	1	1	1
10/24/2020 19:00	0.9	13.8	1,685.4	0.7	5.10	1	1	0
10/24/2020 20:00	0.9	13.8	1,677.3	0.7	5.00	1	1	0
10/24/2020 21:00	1.0	13.3	1,805.0	0.8	5.40	1	1	1
10/24/2020 22:00	1.4	12.7	1,999.8	1.0	8.00	1	1	1
10/24/2020 23:00	1.4	12.7	1,962.0	1.0	7.80	1	1	1
Average/Sum#:	1.0	13.5	1,741.3	0.8	126.50 #	24 #	24 #	10 #
Minimum:	0.7	12.1	1,420.6	0.6	2.80	1	1	0
Maximum:	1.6	13.9	2,114.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	0.9	13.8	1,672.5	0.7	5.00	1	1	0
10/25/2020 01:00	0.8	13.8	1,663.7	0.7	3.30	1	1	0
10/25/2020 02:00	0.8	13.8	1,648.1	0.7	3.30	1	1	0
10/25/2020 03:00	0.8	13.8	1,646.2	0.7	3.30	1	1	0
10/25/2020 04:00	0.7	13.8	1,641.5	0.6	3.30	1	1	0
10/25/2020 05:00	0.7	13.8	1,616.9	0.6	3.20	1	1	0
10/25/2020 06:00	0.7	13.8	1,583.6	0.6	3.20	1	1	0
10/25/2020 07:00	0.7	13.8	1,607.5	0.6	3.20	1	1	0
10/25/2020 08:00	0.7	13.9	1,608.1	0.6	3.20	1	1	0
10/25/2020 09:00	0.7	13.9	1,557.1	0.6	3.10	1	1	0
10/25/2020 10:00	0.6	14.0	1,413.8	0.5	2.80	1	1	0
10/25/2020 11:00	0.6	14.0	1,343.0	0.5	2.70	1	1	0
10/25/2020 12:00	0.7	14.0	1,543.4	0.6	3.10	1	1	0
10/25/2020 13:00	0.7	14.0	1,591.8	0.6	3.20	1	1	0
10/25/2020 14:00	0.8	14.0	1,650.7	0.7	5.00	1	1	0
10/25/2020 15:00	0.7	14.0	1,602.2	0.6	3.20	1	1	0
10/25/2020 16:00	1.2	13.5	1,826.6	1.0	7.30	1	1	1
10/25/2020 17:00	1.5	12.7	2,055.4	1.1	8.20	1	1	1
10/25/2020 18:00	1.4	12.7	2,013.8	1.0	8.10	1	1	1
10/25/2020 19:00	0.9	13.8	1,658.3	0.7	5.00	1	1	0
10/25/2020 20:00	1.1	13.3	1,821.1	0.9	5.50	1	1	1
10/25/2020 21:00	1.5	12.3	2,128.5	1.0	8.50	1	1	1
10/25/2020 22:00	1.5	12.2	2,142.1	1.0	8.60	1	1	1
10/25/2020 23:00	1.6	12.1	2,172.4	1.1	8.70	1	1	1
Average/Sum#:	0.9	13.5	1,717.0	0.7	114.00 #	24 #	24 #	7 #
Minimum:	0.6	12.1	1,343.0	0.5	2.70	1	1	0
Maximum:	1.6	14.0	2,172.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	1.4	12.7	2,037.0	1.0	8.10	1	1	1
10/26/2020 01:00	1.4	13.0	1,982.5	1.0	7.90	1	1	1
10/26/2020 02:00	1.4	12.7	2,032.7	1.0	8.10	1	1	1
10/26/2020 03:00	0.7	13.8	1,674.1	0.6	3.30	1	1	1
10/26/2020 04:00	1.2	13.4	1,856.6	0.9	5.60	1	1	1
10/26/2020 05:00	1.5	12.4	2,131.3	1.0	8.50	1	1	1
10/26/2020 06:00	1.5	12.4	2,092.6	1.0	8.40	1	1	1
10/26/2020 07:00	1.1	13.8	1,783.5	0.9	5.40	1	1	0
10/26/2020 08:00	0.8	13.9	1,744.2	0.7	3.50	1	1	0
10/26/2020 09:00	0.8	13.9	1,734.3	0.7	3.50	1	1	0
10/26/2020 10:00	0.7	14.0	1,679.3	0.6	3.40	1	1	0
10/26/2020 11:00	0.6	14.0	1,378.8	0.5	2.80	1	1	0
10/26/2020 12:00	0.7	14.0	1,524.0	0.6	3.00	1	1	0
10/26/2020 13:00	0.7	14.0	1,503.0	0.6	3.00	1	1	0
10/26/2020 14:00	0.8	14.0	1,692.4	0.7	5.10	1	1	0
10/26/2020 15:00	0.8	14.0	1,640.3	0.7	4.90	1	1	0
10/26/2020 16:00	1.3	13.4	1,844.9	1.0	7.40	1	1	1
10/26/2020 17:00	1.6	12.3	2,141.4	1.1	8.60	1	1	1
10/26/2020 18:00	1.6	12.1	2,179.9	1.1	8.70	1	1	1
10/26/2020 19:00	1.5	12.5	2,078.5	1.1	8.30	1	1	1
10/26/2020 20:00	1.6	12.4	2,117.6	1.1	8.50	1	1	1
10/26/2020 21:00	1.5	12.5	2,088.1	1.1	8.40	1	1	1
10/26/2020 22:00	1.5	12.6	2,075.4	1.1	8.30	1	1	1
10/26/2020 23:00	1.5	12.6	2,058.1	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.2	1,877.9	0.9	150.90 #	24 #	24 #	15 #
Minimum:	0.6	12.1	1,378.8	0.5	2.80	1	1	0
Maximum:	1.6	14.0	2,179.9	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	0.8	13.9	1,687.6	0.7	3.40	1	1	1
10/27/2020 01:00	1.1	13.5	1,783.3	0.9	5.30	1	1	1
10/27/2020 02:00	1.5	12.5	2,051.2	1.1	8.20	1	1	1
10/27/2020 03:00	1.4	12.7	1,991.3	1.0	8.00	1	1	1
10/27/2020 04:00	0.7	14.0	1,645.6	0.6	3.30	1	1	0
10/27/2020 05:00	1.0	13.6	1,729.5	0.8	5.20	1	1	1
10/27/2020 06:00	1.5	12.1	2,142.6	1.0	8.60	1	1	1
10/27/2020 07:00	1.6	12.2	2,157.2	1.1	8.60	1	1	1
10/27/2020 08:00	1.6	12.4	2,106.7	1.1	8.40	1	1	1
10/27/2020 09:00	1.6	12.3	2,114.6	1.1	8.50	1	1	1
10/27/2020 10:00	1.6	12.2	2,115.2	1.1	8.50	1	1	1
10/27/2020 11:00	1.6	12.1	2,141.2	1.1	8.60	1	1	1
10/27/2020 12:00	1.6	12.0	2,148.5	1.1	8.60	1	1	1
10/27/2020 13:00	1.6	12.0	2,145.5	1.1	8.60	1	1	1
10/27/2020 14:00	1.6	12.0	2,130.9	1.1	8.50	1	1	1
10/27/2020 15:00	1.5	12.7	1,980.7	1.1	7.90	1	1	1
10/27/2020 16:00	1.6	12.2	2,116.3	1.1	8.50	1	1	1
10/27/2020 17:00	1.6	12.0	2,149.3	1.1	8.60	1	1	1
10/27/2020 18:00	1.6	12.0	2,149.9	1.1	8.60	1	1	1
10/27/2020 19:00	1.6	12.0	2,147.3	1.1	8.60	1	1	1
10/27/2020 20:00	1.6	12.1	2,133.3	1.1	8.50	1	1	1
10/27/2020 21:00	1.5	12.5	2,045.5	1.1	8.20	1	1	1
10/27/2020 22:00	1.5	12.6	2,044.8	1.1	8.20	1	1	1
10/27/2020 23:00	1.5	12.5	2,053.8	1.1	8.20	1	1	1
Average/Sum#:	1.5	12.5	2,038.0	1.0	185.60 #	24 #	24 #	23 #
Minimum:	0.7	12.0	1,645.6	0.6	3.30	1	1	0
Maximum:	1.6	14.0	2,157.2	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2020 00:00	0.8	13.8	1,674.9	0.7	3.30	1	1	0
10/28/2020 01:00	0.8	13.8	1,660.6	0.7	3.30	1	1	0
10/28/2020 02:00	0.7	13.8	1,645.3	0.6	3.30	1	1	0
10/28/2020 03:00	0.7	13.9	1,640.5	0.6	3.30	1	1	0
10/28/2020 04:00	1.0	13.5	1,818.3	0.8	5.50	1	1	1
10/28/2020 05:00	1.5	12.4	2,111.2	1.0	8.40	1	1	1
10/28/2020 06:00	1.5	12.1	2,135.4	1.0	8.50	1	1	1
10/28/2020 07:00	0.5	13.9	1,275.4	0.4	2.60	1	1	0
10/28/2020 08:00	0.5	13.9	1,280.4	0.4	2.60	1	1	0
10/28/2020 09:00	0.6	13.9	1,482.6	0.5	3.00	1	1	0
10/28/2020 10:00	0.7	13.9	1,525.4	0.6	3.10	1	1	0
10/28/2020 11:00	1.3	13.7	1,799.3	1.1	7.20	1	1	0
10/28/2020 12:00	1.3	13.7	1,786.0	1.1	7.10	1	1	0
10/28/2020 13:00	1.3	13.7	1,782.2	1.1	7.10	1	1	0
10/28/2020 14:00	1.3	13.7	1,776.7	1.1	7.10	1	1	0
10/28/2020 15:00	1.3	13.7	1,773.9	1.1	7.10	1	1	0
10/28/2020 16:00	0.9	13.8	1,649.9	0.7	4.90	1	1	0
10/28/2020 17:00	0.9	13.8	1,697.8	0.7	5.10	1	1	1
10/28/2020 18:00	1.3	12.8	1,990.9	0.9	6.00	1	1	1
10/28/2020 19:00	1.5	12.6	2,043.2	1.1	8.20	1	1	1
10/28/2020 20:00	1.5	12.5	2,062.9	1.1	8.30	1	1	1
10/28/2020 21:00	1.5	12.5	2,062.0	1.1	8.20	1	1	1
10/28/2020 22:00	1.5	12.7	2,033.3	1.1	8.10	1	1	1
10/28/2020 23:00	1.4	13.1	1,902.2	1.1	7.60	1	1	1
Average/Sum#:	1.1	13.4	1,775.4	0.9	138.90 #	24 #	24 #	10 #
Minimum:	0.5	12.1	1,275.4	0.4	2.60	1	1	0
Maximum:	1.5	13.9	2,135.4	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	0.8	13.9	1,682.1	0.7	3.40	1	1	0
10/29/2020 01:00	0.8	13.9	1,673.3	0.7	3.30	1	1	0
10/29/2020 02:00	0.7	13.9	1,531.6	0.6	3.10	1	1	0
10/29/2020 03:00	0.8	13.9	1,680.0	0.7	3.40	1	1	0
10/29/2020 04:00	1.0	13.5	1,783.7	0.8	5.40	1	1	1
10/29/2020 05:00	1.5	12.7	2,042.9	1.1	8.20	1	1	1
10/29/2020 06:00	1.3	12.6	2,055.2	0.9	6.20	1	1	1
10/29/2020 07:00	1.0	13.8	1,783.4	0.8	5.40	1	1	0
10/29/2020 08:00	0.6	13.9	1,311.0	0.5	2.60	1	1	0
10/29/2020 09:00	0.6	14.0	1,264.1	0.5	2.50	1	1	0
10/29/2020 10:00	0.6	14.0	1,277.7	0.5	2.60	1	1	0
10/29/2020 11:00	0.6	14.0	1,262.8	0.5	2.50	1	1	0
10/29/2020 12:00	0.6	14.0	1,262.5	0.5	2.50	1	1	0
10/29/2020 13:00	0.6	14.0	1,263.0	0.5	2.50	1	1	0
10/29/2020 14:00	0.6	14.0	1,263.0	0.5	2.50	1	1	0
10/29/2020 15:00	0.7	14.0	1,359.5	0.6	2.70	1	1	0
10/29/2020 16:00	0.8	13.9	1,535.9	0.7	3.10	1	1	0
10/29/2020 17:00	0.9	13.8	1,745.1	0.7	5.20	1	1	1
10/29/2020 18:00	1.4	12.8	2,007.3	1.0	8.00	1	1	1
10/29/2020 19:00	1.6	12.5	2,051.0	1.1	8.20	1	1	1
10/29/2020 20:00	1.6	12.5	2,072.3	1.1	8.30	1	1	1
10/29/2020 21:00	1.5	12.5	2,064.0	1.1	8.30	1	1	1
10/29/2020 22:00	1.5	12.5	2,059.1	1.1	8.20	1	1	1
10/29/2020 23:00	1.4	13.1	1,920.3	1.1	7.70	1	1	1
Average/Sum#:	1.0	13.5	1,664.6	0.8	115.80 #	24 #	24 #	10 #
Minimum:	0.6	12.5	1,262.5	0.5	2.50	1	1	0
Maximum:	1.6	14.0	2,072.3	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	0.8	13.9	1,604.9	0.7	3.20	1	1	0
10/30/2020 01:00	0.9	13.7	1,678.5	0.7	5.00	1	1	1
10/30/2020 02:00	1.4	13.0	1,928.0	1.0	7.70	1	1	1
10/30/2020 03:00	1.4	13.0	1,923.5	1.0	7.70	1	1	1
10/30/2020 04:00	0.8	13.9	1,687.9	0.7	3.40	1	1	0
10/30/2020 05:00	1.0	13.6	1,799.8	0.8	5.40	1	1	1
10/30/2020 06:00	1.4	12.5	2,061.7	1.0	8.20	1	1	1
10/30/2020 07:00	1.5	12.8	2,012.0	1.1	8.00	1	1	1
10/30/2020 08:00	1.5	12.8	2,003.0	1.1	8.00	1	1	1
10/30/2020 09:00	1.4	12.8	1,967.1	1.0	7.90	1	1	1
10/30/2020 10:00	1.4	12.7	2,000.2	1.0	8.00	1	1	1
10/30/2020 11:00	1.5	12.7	1,944.2	1.1	7.80	1	1	1
10/30/2020 12:00	0.8	14.0	1,642.2	0.7	4.90	1	1	0
10/30/2020 13:00	1.1	13.4	1,784.4	0.9	5.40	1	1	1
10/30/2020 14:00	1.5	12.6	2,013.1	1.1	8.10	1	1	1
10/30/2020 15:00	1.6	12.3	2,065.6	1.1	8.30	1	1	1
10/30/2020 16:00	1.6	12.5	2,037.7	1.1	8.20	1	1	1
10/30/2020 17:00	1.6	12.2	2,105.4	1.1	8.40	1	1	1
10/30/2020 18:00	1.6	12.2	2,106.9	1.1	8.40	1	1	1
10/30/2020 19:00	1.6	12.1	2,134.3	1.1	8.50	1	1	1
10/30/2020 20:00	1.2	13.2	1,798.7	0.9	5.40	1	1	1
10/30/2020 21:00	1.1	13.4	1,821.4	0.9	5.50	1	1	1
10/30/2020 22:00	1.6	12.4	2,080.7	1.1	8.30	1	1	1
10/30/2020 23:00	1.4	13.0	1,929.7	1.0	7.70	1	1	1
Average/Sum#:	1.3	12.9	1,922.1	1.0	167.40 #	24 #	24 #	21 #
Minimum:	0.8	12.1	1,604.9	0.7	3.20	1	1	0
Maximum:	1.6	14.0	2,134.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2020 00:00	0.8	13.9	1,556.8	0.7	3.10	1	1	0
10/31/2020 01:00	0.8	13.9	1,655.0	0.7	3.30	1	1	0
10/31/2020 02:00	0.9	13.7	1,646.8	0.7	4.90	1	1	1
10/31/2020 03:00	1.5	12.6	2,025.8	1.1	8.10	1	1	1
10/31/2020 04:00	1.4	13.0	1,908.0	1.0	7.60	1	1	1
10/31/2020 05:00	0.8	13.9	1,688.3	0.7	3.40	1	1	0
10/31/2020 06:00	0.8	13.9	1,686.5	0.7	3.40	1	1	0
10/31/2020 07:00	0.7	13.9	1,641.9	0.6	3.30	1	1	0
10/31/2020 08:00	0.7	13.9	1,519.8	0.6	3.00	1	1	0
10/31/2020 09:00	0.7	13.9	1,494.6	0.6	3.00	1	1	0
10/31/2020 10:00	0.8	13.9	1,630.8	0.7	3.30	1	1	0
10/31/2020 11:00	0.7	14.0	1,545.5	0.6	3.10	1	1	0
10/31/2020 12:00	0.7	14.0	1,544.3	0.6	3.10	1	1	0
10/31/2020 13:00	0.8	14.0	1,555.3	0.7	4.70	1	1	0
10/31/2020 14:00	0.9	13.9	1,588.7	0.8	4.80	1	1	0
10/31/2020 15:00	1.2	13.9	1,667.8	1.0	6.70	1	1	0
10/31/2020 16:00	1.2	13.4	1,784.8	0.9	5.40	1	1	1
10/31/2020 17:00	1.4	12.8	1,979.8	1.0	7.90	1	1	1
10/31/2020 18:00	1.5	12.7	2,004.7	1.1	8.00	1	1	1
10/31/2020 19:00	0.9	13.8	1,684.5	0.7	5.10	1	1	0
10/31/2020 20:00	1.1	13.4	1,810.6	0.9	5.40	1	1	1
10/31/2020 21:00	1.5	12.6	2,037.6	1.1	8.20	1	1	1
10/31/2020 22:00	1.5	12.7	2,037.5	1.1	8.20	1	1	1
10/31/2020 23:00	1.5	12.6	2,045.7	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.5	1,739.2	0.8	125.20 #	24 #	24 #	10 #
Minimum:	0.7	12.6	1,494.6	0.6	3.00	1	1	0
Maximum:	1.5	14.0	2,045.7	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	1.5	12.8	2,015.2	1.1	8.10	1	1	1
11/01/2020 01:00	1.5	12.8	1,982.7	1.1	7.90	1	1	1
11/01/2020 02:00	0.8	13.8	1,668.6	0.7	3.30	1	1	1
11/01/2020 03:00	0.8	13.9	1,679.1	0.7	3.40	1	1	0
11/01/2020 04:00	1.1	13.4	1,812.7	0.9	5.40	1	1	1
11/01/2020 05:00	1.5	12.7	2,032.9	1.1	8.10	1	1	1
11/01/2020 06:00	1.5	12.7	2,001.6	1.1	8.00	1	1	1
11/01/2020 07:00	0.7	13.9	1,536.2	0.6	3.10	1	1	0
11/01/2020 08:00	0.8	13.9	1,682.4	0.7	3.40	1	1	0
11/01/2020 09:00	0.7	13.9	1,491.5	0.6	3.00	1	1	0
11/01/2020 10:00	0.7	13.9	1,564.2	0.6	3.10	1	1	0
11/01/2020 11:00	0.7	14.0	1,482.3	0.6	3.00	1	1	0
11/01/2020 12:00	0.7	14.0	1,567.9	0.6	3.10	1	1	0
11/01/2020 13:00	1.0	13.9	1,656.6	0.8	5.00	1	1	0
11/01/2020 14:00	1.0	13.9	1,663.1	0.8	5.00	1	1	0
11/01/2020 15:00	1.1	13.7	1,647.6	0.9	4.90	1	1	1
11/01/2020 16:00	1.5	12.6	2,012.8	1.1	8.10	1	1	1
11/01/2020 17:00	1.6	12.3	2,100.1	1.1	8.40	1	1	1
11/01/2020 18:00	1.6	12.1	2,131.1	1.1	8.50	1	1	1
11/01/2020 19:00	1.6	12.3	2,105.1	1.1	8.40	1	1	1
11/01/2020 20:00	1.6	12.3	2,094.8	1.1	8.40	1	1	1
11/01/2020 21:00	1.6	12.1	2,142.5	1.1	8.60	1	1	1
11/01/2020 22:00	1.5	12.5	2,064.2	1.1	8.30	1	1	1
11/01/2020 23:00	1.5	12.5	2,077.2	1.1	8.30	1	1	1
Average/Sum#:	1.2	13.2	1,842.2	0.9	144.80 #	24 #	24 #	15 #
Minimum:	0.7	12.1	1,482.3	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,142.5	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	1.5	12.4	2,089.6	1.0	8.40	1	1	1
11/02/2020 01:00	1.5	12.6	2,002.9	1.1	8.00	1	1	1
11/02/2020 02:00	0.8	13.9	1,640.6	0.7	3.30	1	1	0
11/02/2020 03:00	1.1	13.4	1,793.3	0.9	5.40	1	1	1
11/02/2020 04:00	1.5	12.4	2,080.6	1.0	8.30	1	1	1
11/02/2020 05:00	1.5	12.3	2,102.4	1.0	8.40	1	1	1
11/02/2020 06:00	1.4	12.5	2,050.3	1.0	8.20	1	1	1
11/02/2020 07:00	0.7	13.9	1,621.3	0.6	3.20	1	1	0
11/02/2020 08:00	0.7	13.9	1,656.5	0.6	3.30	1	1	0
11/02/2020 09:00	0.8	13.9	1,676.9	0.7	3.40	1	1	0
11/02/2020 10:00	0.8	14.0	1,643.3	0.7	4.90	1	1	0
11/02/2020 11:00	0.8	14.0	1,652.0	0.7	5.00	1	1	0
11/02/2020 12:00	1.1	13.8	1,676.1	0.9	5.00	1	1	0
11/02/2020 13:00	1.3	13.9	1,668.5	1.1	6.70	1	1	0
11/02/2020 14:00	1.2	13.7	1,696.9	1.0	6.80	1	1	1
11/02/2020 15:00	1.5	12.5	2,019.1	1.1	8.10	1	1	1
11/02/2020 16:00	1.7	12.0	2,133.1	1.1	8.50	1	1	1
11/02/2020 17:00	1.6	12.1	2,113.6	1.1	8.50	1	1	1
11/02/2020 18:00	1.7	12.0	2,128.6	1.1	8.50	1	1	1
11/02/2020 19:00	1.6	12.0	2,139.0	1.1	8.60	1	1	1
11/02/2020 20:00	1.6	12.1	2,134.9	1.1	8.50	1	1	1
11/02/2020 21:00	1.6	12.3	2,094.7	1.1	8.40	1	1	1
11/02/2020 22:00	1.6	12.3	2,084.1	1.1	8.30	1	1	1
11/02/2020 23:00	1.5	12.6	2,035.5	1.1	8.10	1	1	1
Average/Sum#:	1.3	12.9	1,913.9	1.0	163.80 #	24 #	24 #	16 #
Minimum:	0.7	12.0	1,621.3	0.6	3.20	1	1	0
Maximum:	1.7	14.0	2,139.0	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	1.5	12.4	2,054.7	1.0	8.20	1	1	1
11/03/2020 01:00	1.5	12.8	1,945.1	1.1	7.80	1	1	1
11/03/2020 02:00	0.8	13.9	1,677.9	0.7	3.40	1	1	0
11/03/2020 03:00	1.0	13.4	1,817.0	0.8	5.50	1	1	1
11/03/2020 04:00	1.6	12.3	2,088.1	1.1	8.40	1	1	1
11/03/2020 05:00	1.6	12.2	2,098.9	1.1	8.40	1	1	1
11/03/2020 06:00	1.5	12.2	2,114.3	1.0	8.50	1	1	1
11/03/2020 07:00	1.4	12.6	2,008.8	1.0	8.00	1	1	1
11/03/2020 08:00	0.8	13.9	1,651.3	0.7	3.30	1	1	0
11/03/2020 09:00	0.8	13.9	1,665.8	0.7	3.30	1	1	0
11/03/2020 10:00	0.8	13.9	1,671.5	0.7	3.30	1	1	0
11/03/2020 11:00	0.7	14.0	1,522.5	0.6	3.00	1	1	0
11/03/2020 12:00	0.7	14.0	1,522.1	0.6	3.00	1	1	0
11/03/2020 13:00	0.8	13.9	1,591.7	0.7	3.20	1	1	0
11/03/2020 14:00	0.9	13.9	1,660.3	0.8	5.00	1	1	0
11/03/2020 15:00	1.2	13.4	1,785.8	0.9	5.40	1	1	1
11/03/2020 16:00	1.6	12.2	2,103.2	1.1	8.40	1	1	1
11/03/2020 17:00	1.6	12.1	2,129.4	1.1	8.50	1	1	1
11/03/2020 18:00	1.6	12.1	2,138.7	1.1	8.60	1	1	1
11/03/2020 19:00	1.6	12.1	2,142.9	1.1	8.60	1	1	1
11/03/2020 20:00	1.6	12.2	2,117.8	1.1	8.50	1	1	1
11/03/2020 21:00	1.6	12.2	2,107.4	1.1	8.40	1	1	1
11/03/2020 22:00	1.5	12.4	2,081.9	1.0	8.30	1	1	1
11/03/2020 23:00	1.5	12.7	2,038.5	1.1	8.20	1	1	1
Average/Sum#:	1.3	12.9	1,905.7	0.9	155.20 #	24 #	24 #	16 #
Minimum:	0.7	12.1	1,522.1	0.6	3.00	1	1	0
Maximum:	1.6	14.0	2,142.9	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	1.5	12.6	2,048.8	1.1	8.20	1	1	1
11/04/2020 01:00	1.4	13.0	1,921.7	1.0	7.70	1	1	1
11/04/2020 02:00	0.8	13.9	1,688.1	0.7	3.40	1	1	0
11/04/2020 03:00	1.0	13.4	1,807.4	0.8	5.40	1	1	1
11/04/2020 04:00	1.5	12.4	2,061.2	1.0	8.20	1	1	1
11/04/2020 05:00	1.5	12.3	2,101.7	1.0	8.40	1	1	1
11/04/2020 06:00	1.3	12.3	2,121.7	0.9	6.40	1	1	1
11/04/2020 07:00	1.4	12.7	2,006.0	1.0	8.00	1	1	1
11/04/2020 08:00	0.8	13.9	1,684.5	0.7	3.40	1	1	0
11/04/2020 09:00	0.8	13.9	1,630.7	0.7	3.30	1	1	0
11/04/2020 10:00	0.7	13.9	1,532.9	0.6	3.10	1	1	0
11/04/2020 11:00	0.8	13.9	1,658.9	0.7	3.30	1	1	0
11/04/2020 12:00	0.8	14.0	1,679.9	0.7	5.00	1	1	0
11/04/2020 13:00	0.9	13.9	1,683.8	0.8	5.10	1	1	0
11/04/2020 14:00	1.0	13.8	1,715.7	0.8	5.10	1	1	1
11/04/2020 15:00	1.4	12.7	2,012.6	1.0	8.10	1	1	1
11/04/2020 16:00	1.6	12.2	2,099.1	1.1	8.40	1	1	1
11/04/2020 17:00	1.6	12.2	2,120.2	1.1	8.50	1	1	1
11/04/2020 18:00	1.6	12.0	2,155.9	1.1	8.60	1	1	1
11/04/2020 19:00	1.6	12.1	2,144.6	1.1	8.60	1	1	1
11/04/2020 20:00	1.6	12.2	2,122.0	1.1	8.50	1	1	1
11/04/2020 21:00	1.6	12.2	2,113.1	1.1	8.50	1	1	1
11/04/2020 22:00	1.6	12.2	2,112.8	1.1	8.50	1	1	1
11/04/2020 23:00	1.5	12.4	2,101.4	1.0	8.40	1	1	1
Average/Sum#:	1.3	12.9	1,930.2	0.9	160.10 #	24 #	24 #	17 #
Minimum:	0.7	12.0	1,532.9	0.6	3.10	1	1	0
Maximum:	1.6	14.0	2,155.9	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2020 00:00	1.6	12.3	2,122.4	1.1	8.50	1	1	1
11/05/2020 01:00	1.5	12.4	2,068.5	1.0	8.30	1	1	1
11/05/2020 02:00	0.8	13.8	1,628.2	0.7	3.30	1	1	0
11/05/2020 03:00	1.1	13.3	1,806.8	0.9	5.40	1	1	1
11/05/2020 04:00	1.5	12.4	2,067.5	1.0	8.30	1	1	1
11/05/2020 05:00	1.5	12.3	2,092.5	1.0	8.40	1	1	1
11/05/2020 06:00	1.5	12.4	2,075.9	1.0	8.30	1	1	1
11/05/2020 07:00	1.5	12.8	1,975.2	1.1	7.90	1	1	1
11/05/2020 08:00	0.7	13.9	1,586.0	0.6	3.20	1	1	0
11/05/2020 09:00	0.8	13.9	1,668.6	0.7	3.30	1	1	0
11/05/2020 10:00	0.7	13.9	1,581.1	0.6	3.20	1	1	0
11/05/2020 11:00	0.7	13.9	1,576.7	0.6	3.20	1	1	0
11/05/2020 12:00	0.9	13.9	1,670.6	0.8	5.00	1	1	0
11/05/2020 13:00	1.0	13.9	1,561.0	0.8	4.70	1	1	0
11/05/2020 14:00	1.2	13.5	1,724.1	1.0	6.90	1	1	1
11/05/2020 15:00	1.6	12.1	2,103.5	1.1	8.40	1	1	1
11/05/2020 16:00	1.6	12.4	2,030.5	1.1	8.10	1	1	1
11/05/2020 17:00	1.6	12.2	2,092.4	1.1	8.40	1	1	1
11/05/2020 18:00	1.6	12.1	2,095.7	1.1	8.40	1	1	1
11/05/2020 19:00	1.6	12.4	2,040.9	1.1	8.20	1	1	1
11/05/2020 20:00	1.6	12.1	2,119.5	1.1	8.50	1	1	1
11/05/2020 21:00	1.7	12.0	2,144.8	1.1	8.60	1	1	1
11/05/2020 22:00	1.6	12.4	2,065.0	1.1	8.30	1	1	1
11/05/2020 23:00	1.6	12.3	2,071.0	1.1	8.30	1	1	1
Average/Sum#:	1.3	12.9	1,915.4	1.0	163.10 #	24 #	24 #	17 #
Minimum:	0.7	12.0	1,561.0	0.6	3.20	1	1	0
Maximum:	1.7	13.9	2,144.8	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2020 00:00	1.6	12.3	2,061.7	1.1	8.20	1	1	1
11/06/2020 01:00	1.5	13.0	1,911.5	1.1	7.60	1	1	1
11/06/2020 02:00	0.9	13.8	1,636.5	0.7	4.90	1	1	0
11/06/2020 03:00	0.8	13.8	1,596.7	0.7	3.20	1	1	0
11/06/2020 04:00	1.1	13.3	1,808.1	0.9	5.40	1	1	1
11/06/2020 05:00	1.5	12.3	2,093.5	1.0	8.40	1	1	1
11/06/2020 06:00	1.5	12.5	2,018.3	1.1	8.10	1	1	1
11/06/2020 07:00	1.5	12.4	2,057.0	1.0	8.20	1	1	1
11/06/2020 08:00	0.6	13.9	1,417.9	0.5	2.80	1	1	0
11/06/2020 09:00	0.6	14.0	1,335.8	0.5	2.70	1	1	0
11/06/2020 10:00	0.5	14.0	1,307.2	0.4	2.60	1	1	0
11/06/2020 11:00	0.6	14.0	1,287.5	0.5	2.60	1	1	0
11/06/2020 12:00	0.6	14.0	1,418.6	0.5	2.80	1	1	0
11/06/2020 13:00	0.6	14.0	1,398.7	0.5	2.80	1	1	0
11/06/2020 14:00	0.6	14.0	1,321.3	0.5	2.60	1	1	0
11/06/2020 15:00	1.2	13.3	1,808.3	0.9	5.40	1	1	1
11/06/2020 16:00	1.6	12.3	2,095.9	1.1	8.40	1	1	1
11/06/2020 17:00	1.6	12.2	2,116.1	1.1	8.50	1	1	1
11/06/2020 18:00	1.6	12.2	2,109.7	1.1	8.40	1	1	1
11/06/2020 19:00	1.5	12.8	1,974.3	1.1	7.90	1	1	1
11/06/2020 20:00	1.4	13.0	1,912.8	1.0	7.70	1	1	1
11/06/2020 21:00	0.7	13.9	1,522.7	0.6	3.00	1	1	0
11/06/2020 22:00	0.9	13.6	1,740.0	0.7	5.20	1	1	1
11/06/2020 23:00	1.5	12.8	1,985.9	1.1	7.90	1	1	1
Average/Sum#:	1.1	13.2	1,747.3	0.8	135.30 #	24 #	24 #	14 #
Minimum:	0.5	12.2	1,287.5	0.4	2.60	1	1	0
Maximum:	1.6	14.0	2,116.1	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	1.4	13.1	1,901.1	1.1	7.60	1	1	1
11/07/2020 01:00	0.9	13.9	1,681.4	0.8	5.00	1	1	0
11/07/2020 02:00	0.9	13.6	1,714.0	0.7	5.10	1	1	1
11/07/2020 03:00	1.4	13.1	1,911.8	1.1	7.60	1	1	1
11/07/2020 04:00	1.4	13.1	1,909.2	1.1	7.60	1	1	1
11/07/2020 05:00	0.8	13.9	1,636.6	0.7	3.30	1	1	0
11/07/2020 06:00	0.7	13.9	1,606.2	0.6	3.20	1	1	0
11/07/2020 07:00	0.7	13.9	1,586.3	0.6	3.20	1	1	0
11/07/2020 08:00	0.8	13.9	1,650.0	0.7	3.30	1	1	0
11/07/2020 09:00	0.7	13.9	1,549.3	0.6	3.10	1	1	0
11/07/2020 10:00	0.6	13.9	1,404.5	0.5	2.80	1	1	0
11/07/2020 11:00	0.6	13.9	1,389.9	0.5	2.80	1	1	0
11/07/2020 12:00	0.8	13.9	1,572.5	0.7	3.10	1	1	0
11/07/2020 13:00	0.7	13.9	1,476.7	0.6	3.00	1	1	0
11/07/2020 14:00	0.7	13.9	1,468.0	0.6	2.90	1	1	0
11/07/2020 15:00	0.9	13.9	1,544.4	0.8	4.60	1	1	1
11/07/2020 16:00	1.4	12.6	2,031.9	1.0	8.10	1	1	1
11/07/2020 17:00	1.6	12.2	2,097.9	1.1	8.40	1	1	1
11/07/2020 18:00	1.5	12.5	2,037.4	1.1	8.10	1	1	1
11/07/2020 19:00	1.5	12.6	2,023.6	1.1	8.10	1	1	1
11/07/2020 20:00	1.5	12.9	1,939.2	1.1	7.80	1	1	1
11/07/2020 21:00	0.7	13.9	1,570.7	0.6	3.10	1	1	0
11/07/2020 22:00	1.1	13.4	1,804.7	0.9	5.40	1	1	1
11/07/2020 23:00	1.6	12.3	2,089.2	1.1	8.40	1	1	1
Average/Sum#:	1.0	13.4	1,733.2	0.8	125.60 #	24 #	24 #	12 #
Minimum:	0.6	12.2	1,389.9	0.5	2.80	1	1	0
Maximum:	1.6	13.9	2,097.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2020 00:00	1.5	12.8	1,961.7	1.1	7.80	1	1	1
11/08/2020 01:00	0.8	13.8	1,570.0	0.7	3.10	1	1	1
11/08/2020 02:00	0.8	13.9	1,552.0	0.7	3.10	1	1	0
11/08/2020 03:00	1.4	13.1	1,899.9	1.1	7.60	1	1	1
11/08/2020 04:00	1.4	13.1	1,901.0	1.1	7.60	1	1	1
11/08/2020 05:00	0.8	13.9	1,689.8	0.7	3.40	1	1	0
11/08/2020 06:00	0.8	13.9	1,653.1	0.7	3.30	1	1	0
11/08/2020 07:00	0.7	13.9	1,571.5	0.6	3.10	1	1	0
11/08/2020 08:00	0.8	13.9	1,656.7	0.7	3.30	1	1	0
11/08/2020 09:00	0.8	13.9	1,646.8	0.7	3.30	1	1	0
11/08/2020 10:00	0.8	13.9	1,680.9	0.7	3.40	1	1	0
11/08/2020 11:00	0.7	13.9	1,539.8	0.6	3.10	1	1	0
11/08/2020 12:00	0.6	14.0	1,436.2	0.5	2.90	1	1	0
11/08/2020 13:00	0.8	13.9	1,649.9	0.7	3.30	1	1	0
11/08/2020 14:00	0.8	13.9	1,657.3	0.7	3.30	1	1	0
11/08/2020 15:00	0.8	13.9	1,675.3	0.7	3.40	1	1	0
11/08/2020 16:00	1.1	13.3	1,832.0	0.9	5.50	1	1	1
11/08/2020 17:00	1.5	12.2	2,143.9	1.0	8.60	1	1	1
11/08/2020 18:00	1.5	12.5	2,066.7	1.1	8.30	1	1	1
11/08/2020 19:00	1.5	12.6	2,027.3	1.1	8.10	1	1	1
11/08/2020 20:00	0.7	13.9	1,657.9	0.6	3.30	1	1	0
11/08/2020 21:00	0.6	13.9	1,582.5	0.5	3.20	1	1	0
11/08/2020 22:00	1.0	13.5	1,811.5	0.8	5.40	1	1	1
11/08/2020 23:00	1.5	12.5	2,073.3	1.1	8.30	1	1	1
Average/Sum#:	1.0	13.5	1,747.4	0.8	115.70 #	24 #	24 #	10 #
Minimum:	0.6	12.2	1,436.2	0.5	2.90	1	1	0
Maximum:	1.5	14.0	2,143.9	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2020 00:00	1.3	13.1	1,932.3	1.0	7.70	1	1	1
11/09/2020 01:00	0.7	13.9	1,525.4	0.6	3.10	1	1	0
11/09/2020 02:00	0.5	13.9	1,297.3	0.4	2.60	1	1	0
11/09/2020 03:00	0.5	13.9	1,313.9	0.4	2.60	1	1	0
11/09/2020 04:00	0.9	13.5	1,738.1	0.7	5.20	1	1	1
11/09/2020 05:00	1.6	12.4	2,132.5	1.1	8.50	1	1	1
11/09/2020 06:00	1.5	12.2	2,175.7	1.0	8.70	1	1	1
11/09/2020 07:00	1.5	12.7	2,060.5	1.1	8.20	1	1	1
11/09/2020 08:00	1.4	13.1	1,941.7	1.1	7.80	1	1	1
11/09/2020 09:00	0.7	13.9	1,515.7	0.6	3.00	1	1	0
11/09/2020 10:00	0.7	13.9	1,539.1	0.6	3.10	1	1	0
11/09/2020 11:00	0.6	14.0	1,438.3	0.5	2.90	1	1	0
11/09/2020 12:00	0.6	14.0	1,470.3	0.5	2.90	1	1	0
11/09/2020 13:00	0.6	14.0	1,410.8	0.5	2.80	1	1	0
11/09/2020 14:00	0.7	13.9	1,617.6	0.6	3.20	1	1	0
11/09/2020 15:00	1.1	13.5	1,800.1	0.9	5.40	1	1	1
11/09/2020 16:00	1.5	12.8	2,030.3	1.1	8.10	1	1	1
11/09/2020 17:00	1.5	12.6	2,058.2	1.1	8.20	1	1	1
11/09/2020 18:00	1.5	12.5	2,104.8	1.1	8.40	1	1	1
11/09/2020 19:00	1.5	12.4	2,106.2	1.0	8.40	1	1	1
11/09/2020 20:00	1.5	12.1	2,177.3	1.0	8.70	1	1	1
11/09/2020 21:00	1.5	12.3	2,145.5	1.0	8.60	1	1	1
11/09/2020 22:00	1.5	12.7	2,046.2	1.1	8.20	1	1	1
11/09/2020 23:00	1.4	12.9	2,014.7	1.0	8.10	1	1	1
Average/Sum#:	1.1	13.2	1,816.4	0.8	144.40 #	24 #	24 #	15 #
Minimum:	0.5	12.1	1,297.3	0.4	2.60	1	1	0
Maximum:	1.6	14.0	2,177.3	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	1.5	12.9	2,022.1	1.1	8.10	1	1	1
11/10/2020 01:00	1.3	13.2	1,940.3	1.0	7.80	1	1	1
11/10/2020 02:00	0.8	13.9	1,678.0	0.7	3.40	1	1	0
11/10/2020 03:00	1.0	13.5	1,816.8	0.8	5.50	1	1	1
11/10/2020 04:00	1.5	12.9	2,013.2	1.1	8.10	1	1	1
11/10/2020 05:00	1.4	12.9	2,022.8	1.0	8.10	1	1	1
11/10/2020 06:00	1.4	13.0	2,028.1	1.0	8.10	1	1	1
11/10/2020 07:00	1.4	13.0	2,001.0	1.0	8.00	1	1	1
11/10/2020 08:00	1.2	13.2	1,943.9	0.9	5.80	1	1	1
11/10/2020 09:00	0.7	13.9	1,646.9	0.6	3.30	1	1	0
11/10/2020 10:00	0.7	13.9	1,652.5	0.6	3.30	1	1	0
11/10/2020 11:00	0.6	14.0	1,385.2	0.5	2.80	1	1	0
11/10/2020 12:00	0.7	13.9	1,501.7	0.6	3.00	1	1	0
11/10/2020 13:00	0.7	13.9	1,522.1	0.6	3.00	1	1	0
11/10/2020 14:00	0.6	14.0	1,403.1	0.5	2.80	1	1	0
11/10/2020 15:00	0.9	13.7	1,654.1	0.7	5.00	1	1	1
11/10/2020 16:00	1.5	12.9	1,991.0	1.1	8.00	1	1	1
11/10/2020 17:00	1.5	12.5	2,075.5	1.1	8.30	1	1	1
11/10/2020 18:00	1.6	12.1	2,167.5	1.1	8.70	1	1	1
11/10/2020 19:00	1.6	12.1	2,159.2	1.1	8.60	1	1	1
11/10/2020 20:00	1.5	12.4	2,108.7	1.0	8.40	1	1	1
11/10/2020 21:00	1.5	12.5	2,093.4	1.1	8.40	1	1	1
11/10/2020 22:00	1.5	12.7	2,049.9	1.1	8.20	1	1	1
11/10/2020 23:00	1.5	12.8	2,030.0	1.1	8.10	1	1	1
Average/Sum#:	1.2	13.2	1,871.1	0.9	152.80 #	24 #	24 #	17 #
Minimum:	0.6	12.1	1,385.2	0.5	2.80	1	1	0
Maximum:	1.6	14.0	2,167.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	1.5	12.8	2,024.7	1.1	8.10	1	1	1
11/11/2020 01:00	1.3	13.2	1,926.3	1.0	7.70	1	1	1
11/11/2020 02:00	0.7	13.9	1,580.3	0.6	3.20	1	1	0
11/11/2020 03:00	1.0	13.5	1,837.5	0.8	5.50	1	1	1
11/11/2020 04:00	1.4	13.0	1,988.7	1.0	8.00	1	1	1
11/11/2020 05:00	1.5	12.7	2,059.4	1.1	8.20	1	1	1
11/11/2020 06:00	1.4	12.3	2,138.4	1.0	8.60	1	1	1
11/11/2020 07:00	1.4	13.0	1,979.2	1.0	7.90	1	1	1
11/11/2020 08:00	0.8	13.9	1,678.2	0.7	3.40	1	1	0
11/11/2020 09:00	0.7	13.9	1,670.5	0.6	3.30	1	1	0
11/11/2020 10:00	0.7	13.9	1,645.0	0.6	3.30	1	1	0
11/11/2020 11:00	0.7	13.9	1,560.7	0.6	3.10	1	1	0
11/11/2020 12:00	0.8	13.9	1,648.1	0.7	3.30	1	1	0
11/11/2020 13:00	0.7	13.9	1,516.6	0.6	3.00	1	1	0
11/11/2020 14:00	0.8	13.9	1,676.6	0.7	3.40	1	1	0
11/11/2020 15:00	0.6	14.0	1,375.8	0.5	2.80	1	1	0
11/11/2020 16:00	1.3	13.3	1,854.1	1.0	7.40	1	1	1
11/11/2020 17:00	1.5	12.8	2,008.2	1.1	8.00	1	1	1
11/11/2020 18:00	1.5	12.5	2,059.7	1.1	8.20	1	1	1
11/11/2020 19:00	1.5	12.7	2,035.9	1.1	8.10	1	1	1
11/11/2020 20:00	1.4	12.8	1,999.1	1.0	8.00	1	1	1
11/11/2020 21:00	0.8	13.9	1,652.6	0.7	3.30	1	1	0
11/11/2020 22:00	1.1	13.5	1,822.8	0.9	5.50	1	1	1
11/11/2020 23:00	1.5	12.9	2,016.4	1.1	8.10	1	1	1
Average/Sum#:	1.1	13.3	1,823.1	0.9	139.40 #	24 #	24 #	14 #
Minimum:	0.6	12.3	1,375.8	0.5	2.80	1	1	0
Maximum:	1.5	14.0	2,138.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2020 00:00	1.5	12.8	2,023.8	1.1	8.10	1	1	1
11/12/2020 01:00	1.2	13.2	1,918.6	0.9	5.80	1	1	1
11/12/2020 02:00	0.7	13.9	1,563.0	0.6	3.10	1	1	0
11/12/2020 03:00	0.8	13.7	1,680.8	0.7	3.40	1	1	1
11/12/2020 04:00	1.5	12.9	2,021.0	1.1	8.10	1	1	1
11/12/2020 05:00	1.5	12.8	2,057.4	1.1	8.20	1	1	1
11/12/2020 06:00	1.6	12.2	2,188.7	1.1	8.80	1	1	1
11/12/2020 07:00	1.4	12.6	2,053.0	1.0	8.20	1	1	1
11/12/2020 08:00	0.7	13.9	1,623.9	0.6	3.20	1	1	0
11/12/2020 09:00	0.7	13.9	1,634.5	0.6	3.30	1	1	0
11/12/2020 10:00	0.8	13.9	1,662.5	0.7	3.30	1	1	0
11/12/2020 11:00	0.7	13.9	1,597.3	0.6	3.20	1	1	0
11/12/2020 12:00	0.8	13.9	1,693.2	0.7	3.40	1	1	0
11/12/2020 13:00	0.7	13.9	1,565.8	0.6	3.10	1	1	0
11/12/2020 14:00	0.7	13.9	1,554.9	0.6	3.10	1	1	0
11/12/2020 15:00	0.9	13.7	1,679.4	0.7	5.00	1	1	1
11/12/2020 16:00	1.5	12.6	2,033.0	1.1	8.10	1	1	1
11/12/2020 17:00	1.5	12.5	2,057.5	1.1	8.20	1	1	1
11/12/2020 18:00	1.5	12.4	2,074.2	1.0	8.30	1	1	1
11/12/2020 19:00	1.5	12.4	2,092.1	1.0	8.40	1	1	1
11/12/2020 20:00	1.5	12.7	1,998.0	1.1	8.00	1	1	1
11/12/2020 21:00	0.8	13.9	1,657.0	0.7	3.30	1	1	0
11/12/2020 22:00	1.1	13.5	1,816.0	0.9	5.40	1	1	1
11/12/2020 23:00	1.5	12.8	2,013.1	1.1	8.10	1	1	1
Average/Sum#:	1.1	13.2	1,844.1	0.9	139.10 #	24 #	24 #	15 #
Minimum:	0.7	12.2	1,554.9	0.6	3.10	1	1	0
Maximum:	1.6	13.9	2,188.7	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	1.4	13.2	1,922.4	1.1	7.70	1	1	1
11/13/2020 01:00	1.0	13.7	1,494.9	0.8	4.50	1	1	1
11/13/2020 02:00	0.6	13.9	1,288.7	0.5	2.60	1	1	0
11/13/2020 03:00	0.6	13.9	1,357.3	0.5	2.70	1	1	0
11/13/2020 04:00	0.6	13.9	1,319.5	0.5	2.60	1	1	0
11/13/2020 05:00	0.8	13.9	1,583.7	0.7	3.20	1	1	0
11/13/2020 06:00	0.9	13.8	1,707.1	0.7	5.10	1	1	0
11/13/2020 07:00	1.1	13.5	1,809.2	0.9	5.40	1	1	1
11/13/2020 08:00	1.3	13.2	1,853.5	1.0	7.40	1	1	1
11/13/2020 09:00	0.9	13.9	1,668.6	0.8	5.00	1	1	0
11/13/2020 10:00	0.9	13.9	1,671.9	0.8	5.00	1	1	0
11/13/2020 11:00	0.8	13.9	1,646.2	0.7	3.30	1	1	0
11/13/2020 12:00	0.7	13.9	1,529.3	0.6	3.10	1	1	0
11/13/2020 13:00	0.9	13.8	1,642.5	0.7	4.90	1	1	0
11/13/2020 14:00	0.9	13.9	1,653.5	0.8	5.00	1	1	0
11/13/2020 15:00	1.0	13.4	1,756.1	0.8	5.30	1	1	1
11/13/2020 16:00	1.5	12.4	2,064.8	1.0	8.30	1	1	1
11/13/2020 17:00	1.5	12.5	2,045.5	1.1	8.20	1	1	1
11/13/2020 18:00	1.5	12.6	2,023.3	1.1	8.10	1	1	1
11/13/2020 19:00	1.4	13.1	1,869.8	1.1	7.50	1	1	1
11/13/2020 20:00	0.9	13.8	1,671.2	0.7	5.00	1	1	0
11/13/2020 21:00	0.9	13.6	1,683.9	0.7	5.10	1	1	1
11/13/2020 22:00	1.5	12.8	2,015.5	1.1	8.10	1	1	1
11/13/2020 23:00	1.1	13.5	1,637.6	0.9	4.90	1	1	1
Average/Sum#:	1.0	13.5	1,704.8	0.8	128.00 #	24 #	24 #	12 #
Minimum:	0.6	12.4	1,288.7	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,064.8	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	2.5	14.9	901.9	2.5	3.40	1	0	0
11/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2020 05:00	9.8	17.7	441.4	18.1	15.39	1	0	0
11/14/2020 06:00	10.4	15.3	946.5	11.0	37.90	1	0	0
11/14/2020 07:00	0.6	13.8	1,597.2	0.5	3.20	1	1	0
11/14/2020 08:00	0.8	13.8	1,693.4	0.7	3.40	1	1	0
11/14/2020 09:00	0.8	13.8	1,684.3	0.7	3.40	1	1	0
11/14/2020 10:00	0.8	13.8	1,693.4	0.7	3.40	1	1	0
11/14/2020 11:00	0.8	13.9	1,688.5	0.7	3.40	1	1	0
11/14/2020 12:00	0.8	13.9	1,678.3	0.7	3.40	1	1	0
11/14/2020 13:00	0.8	13.9	1,678.0	0.7	3.40	1	1	0
11/14/2020 14:00	0.8	13.9	1,646.3	0.7	3.30	1	1	0
11/14/2020 15:00	0.9	13.7	1,694.6	0.7	5.10	1	1	1
11/14/2020 16:00	1.5	12.8	2,007.9	1.1	8.00	1	1	1
11/14/2020 17:00	1.5	12.7	2,025.6	1.1	8.10	1	1	1
11/14/2020 18:00	1.5	12.7	2,023.9	1.1	8.10	1	1	1
11/14/2020 19:00	1.4	12.8	1,984.5	1.0	7.90	1	1	1
11/14/2020 20:00	0.8	13.9	1,657.1	0.7	3.30	1	1	0
11/14/2020 21:00	1.1	13.5	1,820.9	0.9	5.50	1	1	1
11/14/2020 22:00	1.5	12.8	2,022.5	1.1	8.10	1	1	1
11/14/2020 23:00	1.3	13.2	1,950.0	1.0	7.80	1	1	1
Average/Sum#:	2.0	13.8	1,641.8	2.3	145.49 #	20 #	17 #	8 #
Minimum:	0.6	12.7	441.4	0.5	3.20	0	0	0
Maximum:	10.4	17.7	2,025.6	18.1	37.90	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2020 00:00	1.5	12.8	2,016.2	1.1	8.10	1	1	1
11/15/2020 01:00	1.3	13.1	1,926.3	1.0	7.70	1	1	1
11/15/2020 02:00	0.8	13.9	1,614.7	0.7	3.20	1	1	0
11/15/2020 03:00	0.9	13.7	1,695.4	0.7	5.10	1	1	1
11/15/2020 04:00	1.4	12.9	2,004.0	1.0	8.00	1	1	1
11/15/2020 05:00	1.2	13.3	1,881.6	0.9	5.60	1	1	1
11/15/2020 06:00	0.8	13.8	1,652.9	0.7	3.30	1	1	0
11/15/2020 07:00	0.6	13.9	1,477.7	0.5	3.00	1	1	0
11/15/2020 08:00	0.7	13.8	1,664.6	0.6	3.30	1	1	0
11/15/2020 09:00	0.8	13.8	1,682.3	0.7	3.40	1	1	0
11/15/2020 10:00	0.8	13.9	1,687.8	0.7	3.40	1	1	0
11/15/2020 11:00	0.8	13.9	1,683.7	0.7	3.40	1	1	0
11/15/2020 12:00	0.8	13.9	1,685.5	0.7	3.40	1	1	0
11/15/2020 13:00	0.8	13.9	1,686.7	0.7	3.40	1	1	0
11/15/2020 14:00	0.8	13.9	1,678.4	0.7	3.40	1	1	0
11/15/2020 15:00	0.7	13.9	1,449.6	0.6	2.90	1	1	0
11/15/2020 16:00	0.7	13.9	1,558.6	0.6	3.10	1	1	0
11/15/2020 17:00	0.7	13.9	1,563.5	0.6	3.10	1	1	0
11/15/2020 18:00	0.7	13.9	1,594.2	0.6	3.20	1	1	0
11/15/2020 19:00	0.7	13.9	1,626.8	0.6	3.30	1	1	0
11/15/2020 20:00	1.1	13.5	1,815.0	0.9	5.40	1	1	1
11/15/2020 21:00	1.4	13.1	1,884.5	1.1	7.50	1	1	1
11/15/2020 22:00	0.9	13.8	1,730.5	0.7	5.20	1	1	1
11/15/2020 23:00	1.4	12.8	2,009.3	1.0	8.00	1	1	1
Average/Sum#:	0.9	13.6	1,719.6	0.8	109.40 #	24 #	24 #	9 #
Minimum:	0.6	12.8	1,449.6	0.5	2.90	1	1	0
Maximum:	1.5	13.9	2,016.2	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	1.3	13.3	1,819.9	1.0	7.30	1	1	1
11/16/2020 01:00	0.6	13.9	1,293.1	0.5	2.60	1	1	0
11/16/2020 02:00	0.6	13.9	1,286.9	0.5	2.60	1	1	0
11/16/2020 03:00	0.6	13.9	1,285.8	0.5	2.60	1	1	0
11/16/2020 04:00	0.9	13.7	1,682.9	0.7	5.00	1	1	1
11/16/2020 05:00	1.5	12.8	2,008.4	1.1	8.00	1	1	1
11/16/2020 06:00	1.4	12.6	2,052.6	1.0	8.20	1	1	1
11/16/2020 07:00	1.5	12.8	1,962.8	1.1	7.90	1	1	1
11/16/2020 08:00	0.8	13.9	1,685.3	0.7	3.40	1	1	0
11/16/2020 09:00	0.7	13.9	1,628.3	0.6	3.30	1	1	0
11/16/2020 10:00	0.8	13.9	1,668.4	0.7	3.30	1	1	0
11/16/2020 11:00	0.8	13.9	1,678.4	0.7	3.40	1	1	0
11/16/2020 12:00	0.8	13.9	1,669.6	0.7	3.30	1	1	0
11/16/2020 13:00	0.8	13.9	1,672.8	0.7	3.30	1	1	0
11/16/2020 14:00	0.8	13.9	1,618.7	0.7	3.20	1	1	0
11/16/2020 15:00	1.0	13.6	1,703.6	0.8	5.10	1	1	1
11/16/2020 16:00	1.4	12.6	2,017.0	1.0	8.10	1	1	1
11/16/2020 17:00	1.6	12.3	2,080.5	1.1	8.30	1	1	1
11/16/2020 18:00	1.6	12.2	2,107.1	1.1	8.40	1	1	1
11/16/2020 19:00	1.6	12.2	2,094.7	1.1	8.40	1	1	1
11/16/2020 20:00	1.5	12.3	2,090.3	1.0	8.40	1	1	1
11/16/2020 21:00	1.5	12.5	2,040.9	1.1	8.20	1	1	1
11/16/2020 22:00	1.5	12.5	2,050.2	1.1	8.20	1	1	1
11/16/2020 23:00	1.4	12.7	2,025.2	1.0	8.10	1	1	1
Average/Sum#:	1.1	13.2	1,801.0	0.9	138.60 #	24 #	24 #	14 #
Minimum:	0.6	12.2	1,285.8	0.5	2.60	1	1	0
Maximum:	1.6	13.9	2,107.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2020 00:00	1.5	12.6	2,024.3	1.1	8.10	1	1	1
11/17/2020 01:00	1.5	12.8	1,966.1	1.1	7.90	1	1	1
11/17/2020 02:00	0.8	13.9	1,533.2	0.7	3.10	1	1	0
11/17/2020 03:00	0.7	13.9	1,519.1	0.6	3.00	1	1	0
11/17/2020 04:00	0.9	13.6	1,719.2	0.7	5.20	1	1	1
11/17/2020 05:00	1.5	12.7	2,021.4	1.1	8.10	1	1	1
11/17/2020 06:00	1.5	12.4	2,091.2	1.0	8.40	1	1	1
11/17/2020 07:00	1.4	12.8	1,975.1	1.0	7.90	1	1	1
11/17/2020 08:00	0.9	13.9	1,663.4	0.8	5.00	1	1	0
11/17/2020 09:00	0.8	13.9	1,561.7	0.7	3.10	1	1	0
11/17/2020 10:00	0.7	13.9	1,548.7	0.6	3.10	1	1	0
11/17/2020 11:00	0.9	13.8	1,693.8	0.7	5.10	1	1	0
11/17/2020 12:00	0.7	13.9	1,462.7	0.6	2.90	1	1	0
11/17/2020 13:00	0.7	13.8	1,567.6	0.6	3.10	1	1	0
11/17/2020 14:00	0.8	13.8	1,598.9	0.7	3.20	1	1	0
11/17/2020 15:00	1.1	13.3	1,814.4	0.9	5.40	1	1	1
11/17/2020 16:00	1.5	12.3	2,073.4	1.0	8.30	1	1	1
11/17/2020 17:00	1.5	12.2	2,092.3	1.0	8.40	1	1	1
11/17/2020 18:00	1.5	12.2	2,088.3	1.0	8.40	1	1	1
11/17/2020 19:00	1.5	12.3	2,063.5	1.0	8.30	1	1	1
11/17/2020 20:00	1.5	12.5	2,023.7	1.1	8.10	1	1	1
11/17/2020 21:00	1.5	12.5	2,021.6	1.1	8.10	1	1	1
11/17/2020 22:00	1.4	12.5	2,024.6	1.0	8.10	1	1	1
11/17/2020 23:00	1.4	12.9	1,954.2	1.0	7.80	1	1	1
Average/Sum#:	1.2	13.1	1,837.6	0.9	148.10 #	24 #	24 #	15 #
Minimum:	0.7	12.2	1,462.7	0.6	2.90	1	1	0
Maximum:	1.5	13.9	2,092.3	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	1.4	12.5	2,020.2	1.0	8.10	1	1	1
11/18/2020 01:00	1.3	13.2	1,803.7	1.0	7.20	1	1	1
11/18/2020 02:00	0.7	13.9	1,394.9	0.6	2.80	1	1	0
11/18/2020 03:00	0.6	13.9	1,296.0	0.5	2.60	1	1	0
11/18/2020 04:00	0.9	13.6	1,688.1	0.7	5.10	1	1	1
11/18/2020 05:00	1.5	12.5	2,037.2	1.1	8.10	1	1	1
11/18/2020 06:00	1.5	12.2	2,088.9	1.0	8.40	1	1	1
11/18/2020 07:00	1.4	12.7	1,957.5	1.0	7.80	1	1	1
11/18/2020 08:00	0.7	13.9	1,507.4	0.6	3.00	1	1	0
11/18/2020 09:00	0.7	13.9	1,510.1	0.6	3.00	1	1	0
11/18/2020 10:00	0.7	13.9	1,572.7	0.6	3.10	1	1	0
11/18/2020 11:00	0.9	13.9	1,690.4	0.8	5.10	1	1	0
11/18/2020 12:00	0.8	13.9	1,668.3	0.7	3.30	1	1	0
11/18/2020 13:00	0.7	13.9	1,579.8	0.6	3.20	1	1	0
11/18/2020 14:00	0.7	13.9	1,509.1	0.6	3.00	1	1	0
11/18/2020 15:00	0.9	13.9	1,689.9	0.8	5.10	1	1	1
11/18/2020 16:00	1.3	12.9	1,981.5	1.0	7.90	1	1	1
11/18/2020 17:00	1.5	12.7	2,029.0	1.1	8.10	1	1	1
11/18/2020 18:00	1.5	12.5	2,079.2	1.1	8.30	1	1	1
11/18/2020 19:00	1.4	12.9	1,959.9	1.0	7.80	1	1	1
11/18/2020 20:00	1.4	13.1	1,924.1	1.1	7.70	1	1	1
11/18/2020 21:00	1.4	13.2	1,919.2	1.1	7.70	1	1	1
11/18/2020 22:00	1.4	13.2	1,928.2	1.1	7.70	1	1	1
11/18/2020 23:00	1.4	13.2	1,927.7	1.1	7.70	1	1	1
Average/Sum#:	1.1	13.3	1,781.8	0.9	141.80 #	24 #	24 #	15 #
Minimum:	0.6	12.2	1,296.0	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,088.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	1.2	13.2	1,909.1	0.9	5.70	1	1	1
11/19/2020 01:00	0.7	13.9	1,522.8	0.6	3.00	1	1	0
11/19/2020 02:00	0.6	13.9	1,370.4	0.5	2.70	1	1	0
11/19/2020 03:00	0.6	13.9	1,297.7	0.5	2.60	1	1	0
11/19/2020 04:00	0.6	13.9	1,294.9	0.5	2.60	1	1	0
11/19/2020 05:00	0.7	13.8	1,549.3	0.6	3.10	1	1	1
11/19/2020 06:00	1.2	13.0	1,996.8	0.9	6.00	1	1	1
11/19/2020 07:00	1.3	13.1	1,957.6	1.0	7.80	1	1	1
11/19/2020 08:00	0.8	13.9	1,601.7	0.7	3.20	1	1	0
11/19/2020 09:00	0.7	13.9	1,662.9	0.6	3.30	1	1	0
11/19/2020 10:00	0.8	13.9	1,691.0	0.7	3.40	1	1	0
11/19/2020 11:00	0.7	13.9	1,588.4	0.6	3.20	1	1	0
11/19/2020 12:00	0.8	13.9	1,695.3	0.7	3.40	1	1	0
11/19/2020 13:00	0.8	13.9	1,640.1	0.7	3.30	1	1	0
11/19/2020 14:00	0.8	13.9	1,673.6	0.7	3.30	1	1	0
11/19/2020 15:00	0.6	14.0	1,313.2	0.5	2.60	1	1	0
11/19/2020 16:00	0.7	13.9	1,590.2	0.6	3.20	1	1	0
11/19/2020 17:00	0.8	13.9	1,712.7	0.7	3.40	1	1	1
11/19/2020 18:00	1.4	12.7	2,037.8	1.0	8.20	1	1	1
11/19/2020 19:00	1.5	12.4	2,101.9	1.0	8.40	1	1	1
11/19/2020 20:00	1.5	12.6	2,066.5	1.1	8.30	1	1	1
11/19/2020 21:00	1.4	12.9	1,991.8	1.0	8.00	1	1	1
11/19/2020 22:00	1.5	12.7	2,034.0	1.1	8.10	1	1	1
11/19/2020 23:00	1.4	13.1	1,948.5	1.1	7.80	1	1	1
Average/Sum#:	1.0	13.5	1,718.7	0.8	114.60 #	24 #	24 #	11 #
Minimum:	0.6	12.4	1,294.9	0.5	2.60	1	1	0
Maximum:	1.5	14.0	2,101.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2020 00:00	1.5	12.8	2,030.6	1.1	8.10	1	1	1
11/20/2020 01:00	1.3	13.2	1,916.7	1.0	7.70	1	1	1
11/20/2020 02:00	0.7	13.9	1,585.2	0.6	3.20	1	1	0
11/20/2020 03:00	0.7	13.9	1,583.8	0.6	3.20	1	1	0
11/20/2020 04:00	0.8	13.8	1,723.5	0.7	3.40	1	1	1
11/20/2020 05:00	1.5	12.7	2,056.5	1.1	8.20	1	1	1
11/20/2020 06:00	1.4	12.5	2,101.2	1.0	8.40	1	1	1
11/20/2020 07:00	1.5	12.6	2,069.7	1.1	8.30	1	1	1
11/20/2020 08:00	1.5	12.8	2,011.3	1.1	8.00	1	1	1
11/20/2020 09:00	1.4	12.9	1,963.5	1.0	7.90	1	1	1
11/20/2020 10:00	0.8	13.9	1,655.8	0.7	3.30	1	1	0
11/20/2020 11:00	0.7	14.0	1,581.6	0.6	3.20	1	1	0
11/20/2020 12:00	0.8	14.0	1,641.3	0.7	4.90	1	1	0
11/20/2020 13:00	0.6	14.0	1,501.7	0.5	3.00	1	1	0
11/20/2020 14:00	0.7	14.0	1,539.4	0.6	3.10	1	1	0
11/20/2020 15:00	1.2	13.5	1,816.6	1.0	7.30	1	1	1
11/20/2020 16:00	1.5	12.7	2,060.0	1.1	8.20	1	1	1
11/20/2020 17:00	1.6	12.5	2,106.5	1.1	8.40	1	1	1
11/20/2020 18:00	1.6	12.4	2,121.9	1.1	8.50	1	1	1
11/20/2020 19:00	1.6	12.4	2,117.1	1.1	8.50	1	1	1
11/20/2020 20:00	1.6	12.4	2,121.2	1.1	8.50	1	1	1
11/20/2020 21:00	1.6	12.5	2,110.7	1.1	8.40	1	1	1
11/20/2020 22:00	1.5	12.5	2,082.2	1.1	8.30	1	1	1
11/20/2020 23:00	1.5	12.7	2,038.2	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.1	1,897.3	0.9	158.20 #	24 #	24 #	17 #
Minimum:	0.6	12.4	1,501.7	0.5	3.00	1	1	0
Maximum:	1.6	14.0	2,121.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	1.5	12.7	2,026.7	1.1	8.10	1	1	1
11/21/2020 01:00	1.4	13.1	1,932.7	1.1	7.70	1	1	1
11/21/2020 02:00	1.4	13.2	1,901.5	1.1	7.60	1	1	1
11/21/2020 03:00	0.8	13.9	1,748.4	0.7	3.50	1	1	0
11/21/2020 04:00	1.0	13.4	1,830.9	0.8	5.50	1	1	1
11/21/2020 05:00	1.5	12.6	2,062.3	1.1	8.20	1	1	1
11/21/2020 06:00	1.5	12.5	2,088.0	1.1	8.40	1	1	1
11/21/2020 07:00	0.7	13.7	1,613.1	0.6	3.20	1	1	1
11/21/2020 08:00	0.6	13.9	1,604.7	0.5	3.20	1	1	0
11/21/2020 09:00	0.6	13.9	1,611.1	0.5	3.20	1	1	0
11/21/2020 10:00	0.6	14.0	1,469.0	0.5	2.90	1	1	0
11/21/2020 11:00	0.7	14.0	1,666.3	0.6	3.30	1	1	0
11/21/2020 12:00	0.7	14.0	1,665.7	0.6	3.30	1	1	0
11/21/2020 13:00	0.7	14.0	1,685.5	0.6	3.40	1	1	0
11/21/2020 14:00	0.7	14.0	1,592.8	0.6	3.20	1	1	0
11/21/2020 15:00	1.0	13.4	1,835.2	0.8	5.50	1	1	1
11/21/2020 16:00	1.5	12.6	2,056.8	1.1	8.20	1	1	1
11/21/2020 17:00	1.5	12.5	2,084.1	1.1	8.30	1	1	1
11/21/2020 18:00	1.6	12.4	2,111.1	1.1	8.40	1	1	1
11/21/2020 19:00	1.6	12.4	2,099.8	1.1	8.40	1	1	1
11/21/2020 20:00	1.5	12.5	2,051.4	1.1	8.20	1	1	1
11/21/2020 21:00	0.8	13.9	1,676.8	0.7	3.40	1	1	0
11/21/2020 22:00	1.0	13.4	1,816.6	0.8	5.40	1	1	1
11/21/2020 23:00	1.5	12.6	2,055.2	1.1	8.20	1	1	1
Average/Sum#:	1.1	13.3	1,845.2	0.9	138.70 #	24 #	24 #	15 #
Minimum:	0.6	12.4	1,469.0	0.5	2.90	1	1	0
Maximum:	1.6	14.0	2,111.1	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	1.5	12.7	2,032.8	1.1	8.10	1	1	1
11/22/2020 01:00	1.1	13.3	1,798.1	0.9	5.40	1	1	1
11/22/2020 02:00	0.6	13.9	1,297.5	0.5	2.60	1	1	0
11/22/2020 03:00	0.6	13.9	1,354.4	0.5	2.70	1	1	0
11/22/2020 04:00	0.7	13.9	1,614.4	0.6	3.20	1	1	0
11/22/2020 05:00	1.0	13.5	1,830.8	0.8	5.50	1	1	1
11/22/2020 06:00	1.1	13.5	1,864.6	0.9	5.60	1	1	1
11/22/2020 07:00	0.6	13.9	1,510.8	0.5	3.00	1	1	0
11/22/2020 08:00	0.7	13.9	1,669.7	0.6	3.30	1	1	0
11/22/2020 09:00	0.8	13.9	1,685.7	0.7	3.40	1	1	0
11/22/2020 10:00	0.7	13.9	1,614.2	0.6	3.20	1	1	0
11/22/2020 11:00	0.8	13.9	1,667.8	0.7	3.30	1	1	0
11/22/2020 12:00	0.8	13.9	1,635.6	0.7	3.30	1	1	0
11/22/2020 13:00	0.8	13.9	1,629.1	0.7	3.30	1	1	0
11/22/2020 14:00	0.8	13.9	1,687.0	0.7	3.40	1	1	0
11/22/2020 15:00	1.1	13.4	1,819.1	0.9	5.50	1	1	1
11/22/2020 16:00	1.5	12.5	2,061.9	1.1	8.20	1	1	1
11/22/2020 17:00	1.5	12.4	2,076.2	1.0	8.30	1	1	1
11/22/2020 18:00	1.5	12.5	2,061.0	1.1	8.20	1	1	1
11/22/2020 19:00	1.5	12.6	2,014.1	1.1	8.10	1	1	1
11/22/2020 20:00	0.8	13.9	1,680.5	0.7	3.40	1	1	0
11/22/2020 21:00	1.1	13.3	1,838.9	0.9	5.50	1	1	1
11/22/2020 22:00	1.5	12.5	2,064.1	1.1	8.30	1	1	1
11/22/2020 23:00	1.2	13.3	1,854.9	0.9	5.60	1	1	1
Average/Sum#:	1.0	13.4	1,765.1	0.8	120.40 #	24 #	24 #	12 #
Minimum:	0.6	12.4	1,297.5	0.5	2.60	1	1	0
Maximum:	1.5	13.9	2,076.2	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	0.9	13.7	1,696.5	0.7	5.10	1	1	1
11/23/2020 01:00	1.2	13.0	1,944.8	0.9	5.80	1	1	1
11/23/2020 02:00	1.7	14.4	1,218.8	1.5	6.72	1	0	0
11/23/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/23/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/23/2020 05:00	4.8	17.3	501.4	7.9	10.15	1	0	0
11/23/2020 06:00	8.7	14.5	1,170.2	8.0	35.10	1	0	0
11/23/2020 07:00	0.8	13.9	1,695.1	0.7	3.40	1	1	0
11/23/2020 08:00	0.7	13.9	1,621.8	0.6	3.20	1	1	0
11/23/2020 09:00	0.8	13.9	1,651.7	0.7	3.30	1	1	0
11/23/2020 10:00	0.7	13.9	1,579.2	0.6	3.20	1	1	0
11/23/2020 11:00	0.8	13.9	1,660.8	0.7	3.30	1	1	0
11/23/2020 12:00	0.8	13.9	1,681.9	0.7	3.40	1	1	0
11/23/2020 13:00	0.8	13.9	1,634.1	0.7	3.30	1	1	0
11/23/2020 14:00	0.8	13.9	1,680.8	0.7	3.40	1	1	0
11/23/2020 15:00	1.1	13.7	1,749.2	0.9	5.20	1	1	1
11/23/2020 16:00	1.5	12.6	2,052.0	1.1	8.20	1	1	1
11/23/2020 17:00	1.5	12.5	2,072.1	1.1	8.30	1	1	1
11/23/2020 18:00	1.5	12.5	2,079.3	1.1	8.30	1	1	1
11/23/2020 19:00	1.4	12.9	1,943.9	1.0	7.80	1	1	1
11/23/2020 20:00	0.8	13.9	1,658.4	0.7	3.30	1	1	0
11/23/2020 21:00	0.9	13.7	1,686.5	0.7	5.10	1	1	1
11/23/2020 22:00	1.5	12.7	2,009.5	1.1	8.00	1	1	1
11/23/2020 23:00	1.3	13.0	1,952.4	1.0	7.80	1	1	1
Average/Sum#:	1.6	13.7	1,679.1	1.5	151.37 #	22 #	19 #	10 #
Minimum:	0.7	12.5	501.4	0.6	3.20	0	0	0
Maximum:	8.7	17.3	2,079.3	8.0	35.10	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	1.2	13.0	1,925.1	0.9	5.80	1	1	1
11/24/2020 01:00	0.7	13.9	1,553.3	0.6	3.10	1	1	0
11/24/2020 02:00	0.7	13.9	1,558.0	0.6	3.10	1	1	0
11/24/2020 03:00	0.7	13.9	1,575.0	0.6	3.20	1	1	0
11/24/2020 04:00	1.1	13.4	1,813.2	0.9	5.40	1	1	1
11/24/2020 05:00	1.5	12.6	2,059.5	1.1	8.20	1	1	1
11/24/2020 06:00	1.5	12.1	2,176.5	1.0	8.70	1	1	1
11/24/2020 07:00	1.5	12.4	2,109.4	1.0	8.40	1	1	1
11/24/2020 08:00	1.4	13.2	1,862.2	1.1	7.40	1	1	1
11/24/2020 09:00	0.8	13.9	1,683.0	0.7	3.40	1	1	0
11/24/2020 10:00	0.8	13.9	1,662.4	0.7	3.30	1	1	0
11/24/2020 11:00	0.8	13.9	1,669.3	0.7	3.30	1	1	0
11/24/2020 12:00	0.8	14.0	1,656.6	0.7	5.00	1	1	0
11/24/2020 13:00	0.8	14.0	1,667.5	0.7	5.00	1	1	0
11/24/2020 14:00	0.7	14.0	1,586.2	0.6	3.20	1	1	0
11/24/2020 15:00	0.8	13.8	1,565.7	0.7	3.10	1	1	1
11/24/2020 16:00	1.5	12.5	2,073.0	1.1	8.30	1	1	1
11/24/2020 17:00	1.6	12.3	2,121.3	1.1	8.50	1	1	1
11/24/2020 18:00	1.6	12.2	2,143.7	1.1	8.60	1	1	1
11/24/2020 19:00	1.5	12.2	2,138.2	1.0	8.60	1	1	1
11/24/2020 20:00	1.6	12.2	2,146.4	1.1	8.60	1	1	1
11/24/2020 21:00	1.5	12.4	2,122.4	1.0	8.50	1	1	1
11/24/2020 22:00	1.5	12.4	2,109.5	1.0	8.40	1	1	1
11/24/2020 23:00	1.5	12.7	2,067.2	1.1	8.30	1	1	1
Average/Sum#:	1.2	13.1	1,876.9	0.9	147.40 #	24 #	24 #	15 #
Minimum:	0.7	12.1	1,553.3	0.6	3.10	1	1	0
Maximum:	1.6	14.0	2,176.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2020 00:00	1.5	12.6	2,070.0	1.1	8.30	1	1	1
11/25/2020 01:00	1.2	13.1	1,935.8	0.9	5.80	1	1	1
11/25/2020 02:00	0.7	13.9	1,561.3	0.6	3.10	1	1	0
11/25/2020 03:00	0.6	13.9	1,373.5	0.5	2.70	1	1	0
11/25/2020 04:00	0.7	13.9	1,558.2	0.6	3.10	1	1	1
11/25/2020 05:00	1.4	12.9	2,008.5	1.0	8.00	1	1	1
11/25/2020 06:00	1.3	13.0	1,995.7	1.0	8.00	1	1	1
11/25/2020 07:00	1.3	12.9	1,987.1	1.0	7.90	1	1	1
11/25/2020 08:00	0.8	13.8	1,671.0	0.7	3.30	1	1	0
11/25/2020 09:00	0.7	13.9	1,632.6	0.6	3.30	1	1	0
11/25/2020 10:00	0.8	13.9	1,693.6	0.7	3.40	1	1	0
11/25/2020 11:00	0.8	13.9	1,694.8	0.7	3.40	1	1	0
11/25/2020 12:00	0.8	13.9	1,694.5	0.7	3.40	1	1	0
11/25/2020 13:00	0.8	13.9	1,678.8	0.7	3.40	1	1	0
11/25/2020 14:00	0.8	14.0	1,646.8	0.7	4.90	1	1	0
11/25/2020 15:00	0.6	14.0	1,347.0	0.5	2.70	1	1	0
11/25/2020 16:00	0.8	13.9	1,629.8	0.7	3.30	1	1	0
11/25/2020 17:00	0.7	13.9	1,603.7	0.6	3.20	1	1	0
11/25/2020 18:00	0.8	13.9	1,687.1	0.7	3.40	1	1	0
11/25/2020 19:00	1.1	13.4	1,848.1	0.9	5.50	1	1	1
11/25/2020 20:00	1.4	13.0	1,914.7	1.0	7.70	1	1	1
11/25/2020 21:00	1.0	13.7	1,788.8	0.8	5.40	1	1	1
11/25/2020 22:00	1.5	12.8	2,025.6	1.1	8.10	1	1	1
11/25/2020 23:00	4.0	14.4	1,234.1	3.6	8.00	1	0	1
Average/Sum#:	1.1	13.6	1,720.0	0.9	119.30 #	24 #	23 #	11 #
Minimum:	0.6	12.6	1,234.1	0.5	2.70	1	0	0
Maximum:	4.0	14.4	2,070.0	3.6	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2020 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2020 04:00	29.9	17.5	477.8	51.9	84.00	1	0	0
11/27/2020 05:00	12.1	14.9	1,074.5	11.9	47.30	1	0	0
11/27/2020 06:00	0.8	13.9	1,704.6	0.7	3.40	1	1	0
11/27/2020 07:00	0.7	13.9	1,609.8	0.6	3.20	1	1	0
11/27/2020 08:00	0.6	13.9	1,616.5	0.5	3.20	1	1	0
11/27/2020 09:00	0.8	13.9	1,694.9	0.7	3.40	1	1	0
11/27/2020 10:00	0.8	13.9	1,687.0	0.7	3.40	1	1	0
11/27/2020 11:00	0.8	13.9	1,703.0	0.7	3.40	1	1	0
11/27/2020 12:00	0.8	14.0	1,687.2	0.7	5.10	1	1	0
11/27/2020 13:00	0.7	14.0	1,613.9	0.6	3.20	1	1	0
11/27/2020 14:00	0.8	14.0	1,656.4	0.7	5.00	1	1	0
11/27/2020 15:00	0.7	13.9	1,578.9	0.6	3.20	1	1	1
11/27/2020 16:00	1.5	12.9	1,999.5	1.1	8.00	1	1	1
11/27/2020 17:00	1.5	12.6	2,084.2	1.1	8.30	1	1	1
11/27/2020 18:00	1.5	12.7	2,048.0	1.1	8.20	1	1	1
11/27/2020 19:00	1.5	12.7	2,042.4	1.1	8.20	1	1	1
11/27/2020 20:00	1.3	12.9	1,981.1	1.0	7.90	1	1	1
11/27/2020 21:00	0.8	13.9	1,706.5	0.7	3.40	1	1	0
11/27/2020 22:00	1.0	13.5	1,842.8	0.8	5.50	1	1	1
11/27/2020 23:00	1.5	12.9	2,030.6	1.1	8.10	1	1	1
Average/Sum#:	3.0	13.8	1,692.0	3.9	225.40 #	20 #	18 #	8 #
Minimum:	0.6	12.6	477.8	0.5	3.20	0	0	0
Maximum:	29.9	17.5	2,084.2	51.9	84.00	1	1	1
%SI	16.67	16.67	16.67	16.67	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	1.5	12.9	2,038.3	1.1	8.20	1	1	1
11/28/2020 01:00	1.2	13.2	1,942.0	0.9	5.80	1	1	1
11/28/2020 02:00	0.7	13.9	1,586.4	0.6	3.20	1	1	0
11/28/2020 03:00	1.0	13.5	1,827.2	0.8	5.50	1	1	1
11/28/2020 04:00	1.1	13.2	1,946.1	0.8	5.80	1	1	1
11/28/2020 05:00	1.3	13.1	1,966.3	1.0	7.90	1	1	1
11/28/2020 06:00	0.8	13.9	1,693.9	0.7	3.40	1	1	0
11/28/2020 07:00	0.7	13.9	1,643.2	0.6	3.30	1	1	0
11/28/2020 08:00	0.7	13.9	1,688.2	0.6	3.40	1	1	0
11/28/2020 09:00	0.6	13.9	1,556.0	0.5	3.10	1	1	0
11/28/2020 10:00	0.7	13.9	1,628.1	0.6	3.30	1	1	0
11/28/2020 11:00	0.8	13.9	1,694.4	0.7	3.40	1	1	0
11/28/2020 12:00	0.8	13.9	1,696.2	0.7	3.40	1	1	0
11/28/2020 13:00	0.6	14.0	1,546.7	0.5	3.10	1	1	0
11/28/2020 14:00	0.7	14.0	1,626.7	0.6	3.30	1	1	0
11/28/2020 15:00	1.0	13.7	1,698.4	0.8	5.10	1	1	1
11/28/2020 16:00	1.5	12.7	2,020.4	1.1	8.10	1	1	1
11/28/2020 17:00	1.5	12.5	2,073.3	1.1	8.30	1	1	1
11/28/2020 18:00	1.5	12.4	2,105.4	1.0	8.40	1	1	1
11/28/2020 19:00	1.5	12.4	2,104.7	1.0	8.40	1	1	1
11/28/2020 20:00	1.5	12.2	2,151.8	1.0	8.60	1	1	1
11/28/2020 21:00	1.1	13.3	1,806.0	0.9	5.40	1	1	1
11/28/2020 22:00	1.0	13.5	1,840.5	0.8	5.50	1	1	1
11/28/2020 23:00	1.5	12.8	2,047.9	1.1	8.20	1	1	1
Average/Sum#:	1.1	13.4	1,830.3	0.8	132.10 #	24 #	24 #	14 #
Minimum:	0.6	12.2	1,546.7	0.5	3.10	1	1	0
Maximum:	1.5	14.0	2,151.8	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2020 00:00	1.2	13.2	1,934.1	0.9	5.80	1	1	1
11/29/2020 01:00	0.7	13.9	1,569.8	0.6	3.10	1	1	0
11/29/2020 02:00	1.0	13.4	1,855.0	0.8	5.60	1	1	1
11/29/2020 03:00	1.4	12.8	2,040.9	1.0	8.20	1	1	1
11/29/2020 04:00	1.4	12.8	2,024.9	1.0	8.10	1	1	1
11/29/2020 05:00	0.8	13.9	1,706.1	0.7	3.40	1	1	0
11/29/2020 06:00	0.7	13.9	1,685.2	0.6	3.40	1	1	0
11/29/2020 07:00	0.6	13.9	1,609.4	0.5	3.20	1	1	0
11/29/2020 08:00	0.7	13.9	1,640.1	0.6	3.30	1	1	0
11/29/2020 09:00	0.6	13.9	1,587.6	0.5	3.20	1	1	0
11/29/2020 10:00	0.7	13.9	1,690.8	0.6	3.40	1	1	0
11/29/2020 11:00	0.8	13.9	1,669.9	0.7	3.30	1	1	0
11/29/2020 12:00	0.8	13.9	1,682.5	0.7	3.40	1	1	0
11/29/2020 13:00	0.8	13.9	1,679.0	0.7	3.40	1	1	0
11/29/2020 14:00	0.7	13.9	1,660.0	0.6	3.30	1	1	0
11/29/2020 15:00	0.8	13.9	1,677.7	0.7	3.40	1	1	0
11/29/2020 16:00	1.1	13.4	1,830.4	0.9	5.50	1	1	1
11/29/2020 17:00	1.5	12.5	2,093.2	1.1	8.40	1	1	1
11/29/2020 18:00	1.6	12.2	2,154.9	1.1	8.60	1	1	1
11/29/2020 19:00	1.5	12.4	2,074.8	1.0	8.30	1	1	1
11/29/2020 20:00	0.8	13.9	1,694.2	0.7	3.40	1	1	0
11/29/2020 21:00	1.0	13.4	1,834.9	0.8	5.50	1	1	1
11/29/2020 22:00	1.5	12.5	2,104.8	1.1	8.40	1	1	1
11/29/2020 23:00	1.5	12.8	2,042.9	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.4	1,814.3	0.8	123.80 #	24 #	24 #	11 #
Minimum:	0.6	12.2	1,569.8	0.5	3.10	1	1	0
Maximum:	1.6	13.9	2,154.9	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2020 00:00	1.5	12.8	2,059.1	1.1	8.20	1	1	1
11/30/2020 01:00	1.4	12.8	2,025.3	1.0	8.10	1	1	1
11/30/2020 02:00	0.7	13.9	1,572.7	0.6	3.10	1	1	0
11/30/2020 03:00	0.6	13.9	1,545.8	0.5	3.10	1	1	0
11/30/2020 04:00	0.9	13.6	1,775.2	0.7	5.30	1	1	1
11/30/2020 05:00	1.5	12.7	2,103.2	1.1	8.40	1	1	1
11/30/2020 06:00	1.5	12.6	2,111.9	1.1	8.40	1	1	1
11/30/2020 07:00	1.5	12.6	2,098.6	1.1	8.40	1	1	1
11/30/2020 08:00	1.3	13.1	1,933.6	1.0	7.70	1	1	1
11/30/2020 09:00	0.8	13.9	1,668.1	0.7	3.30	1	1	0
11/30/2020 10:00	0.7	13.9	1,567.9	0.6	3.10	1	1	0
11/30/2020 11:00	0.7	13.9	1,637.5	0.6	3.30	1	1	0
11/30/2020 12:00	0.7	13.9	1,618.2	0.6	3.20	1	1	0
11/30/2020 13:00	0.6	14.0	1,420.3	0.5	2.80	1	1	0
11/30/2020 14:00	0.8	13.9	1,672.3	0.7	3.30	1	1	0
11/30/2020 15:00	0.9	13.7	1,696.2	0.7	5.10	1	1	1
11/30/2020 16:00	1.5	12.7	2,036.7	1.1	8.10	1	1	1
11/30/2020 17:00	1.6	12.3	2,111.4	1.1	8.40	1	1	1
11/30/2020 18:00	1.5	12.3	2,120.4	1.0	8.50	1	1	1
11/30/2020 19:00	1.6	12.1	2,164.1	1.1	8.70	1	1	1
11/30/2020 20:00	1.5	12.4	2,113.2	1.0	8.50	1	1	1
11/30/2020 21:00	1.5	12.4	2,105.8	1.0	8.40	1	1	1
11/30/2020 22:00	1.5	12.5	2,077.7	1.1	8.30	1	1	1
11/30/2020 23:00	1.4	12.8	2,017.1	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.1	1,885.5	0.9	151.80 #	24 #	24 #	16 #
Minimum:	0.6	12.1	1,420.3	0.5	2.80	1	1	0
Maximum:	1.6	14.0	2,164.1	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2020 00:00	1.5	12.7	2,041.9	1.1	8.20	1	1	1
12/01/2020 01:00	1.5	12.6	2,026.4	1.1	8.10	1	1	1
12/01/2020 02:00	0.7	13.9	1,562.1	0.6	3.10	1	1	0
12/01/2020 03:00	1.0	13.4	1,839.5	0.8	5.50	1	1	1
12/01/2020 04:00	1.5	12.5	2,097.3	1.1	8.40	1	1	1
12/01/2020 05:00	1.5	12.2	2,163.8	1.0	8.70	1	1	1
12/01/2020 06:00	1.5	12.0	2,197.6	1.0	8.80	1	1	1
12/01/2020 07:00	1.6	12.3	2,138.7	1.1	8.60	1	1	1
12/01/2020 08:00	1.5	12.5	2,086.5	1.1	8.30	1	1	1
12/01/2020 09:00	0.9	13.7	1,711.6	0.7	5.10	1	1	1
12/01/2020 10:00	0.7	14.0	1,698.2	0.6	3.40	1	1	0
12/01/2020 11:00	0.7	14.0	1,665.3	0.6	3.30	1	1	0
12/01/2020 12:00	0.8	14.0	1,675.5	0.7	5.00	1	1	0
12/01/2020 13:00	0.6	14.0	1,398.6	0.5	2.80	1	1	0
12/01/2020 14:00	0.7	14.0	1,603.5	0.6	3.20	1	1	0
12/01/2020 15:00	0.8	13.9	1,547.3	0.7	3.10	1	1	1
12/01/2020 16:00	1.4	12.8	1,999.4	1.0	8.00	1	1	1
12/01/2020 17:00	1.5	12.2	2,120.3	1.0	8.50	1	1	1
12/01/2020 18:00	1.6	12.1	2,156.5	1.1	8.60	1	1	1
12/01/2020 19:00	1.5	12.1	2,152.9	1.0	8.60	1	1	1
12/01/2020 20:00	1.6	12.1	2,164.3	1.1	8.70	1	1	1
12/01/2020 21:00	1.6	12.1	2,165.7	1.1	8.70	1	1	1
12/01/2020 22:00	1.5	12.2	2,162.6	1.0	8.70	1	1	1
12/01/2020 23:00	1.5	12.4	2,122.6	1.0	8.50	1	1	1
Average/Sum#:	1.2	12.9	1,937.4	0.9	161.90 #	24 #	24 #	18 #
Minimum:	0.6	12.0	1,398.6	0.5	2.80	1	1	0
Maximum:	1.6	14.0	2,197.6	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2020 00:00	1.5	12.6	2,101.6	1.1	8.40	1	1	1
12/02/2020 01:00	1.4	12.9	1,984.0	1.0	7.90	1	1	1
12/02/2020 02:00	0.7	13.9	1,571.3	0.6	3.10	1	1	0
12/02/2020 03:00	1.1	13.4	1,847.6	0.9	5.50	1	1	1
12/02/2020 04:00	1.5	12.6	2,072.8	1.1	8.30	1	1	1
12/02/2020 05:00	1.5	12.6	2,090.4	1.1	8.40	1	1	1
12/02/2020 06:00	1.4	12.4	2,117.4	1.0	8.50	1	1	1
12/02/2020 07:00	1.5	12.5	2,102.8	1.1	8.40	1	1	1
12/02/2020 08:00	1.5	12.7	2,045.9	1.1	8.20	1	1	1
12/02/2020 09:00	0.7	13.9	1,585.8	0.6	3.20	1	1	1
12/02/2020 10:00	0.7	13.9	1,666.8	0.6	3.30	1	1	0
12/02/2020 11:00	0.8	14.0	1,699.9	0.7	5.10	1	1	0
12/02/2020 12:00	0.8	14.0	1,652.9	0.7	5.00	1	1	0
12/02/2020 13:00	0.7	14.0	1,548.5	0.6	3.10	1	1	0
12/02/2020 14:00	0.8	14.0	1,583.5	0.7	4.80	1	1	0
12/02/2020 15:00	1.2	13.4	1,840.6	0.9	5.50	1	1	1
12/02/2020 16:00	1.5	12.5	2,105.6	1.1	8.40	1	1	1
12/02/2020 17:00	1.6	12.2	2,157.6	1.1	8.60	1	1	1
12/02/2020 18:00	1.6	12.1	2,186.9	1.1	8.70	1	1	1
12/02/2020 19:00	1.6	12.1	2,185.4	1.1	8.70	1	1	1
12/02/2020 20:00	1.5	12.3	2,124.3	1.0	8.50	1	1	1
12/02/2020 21:00	1.5	12.4	2,109.7	1.0	8.40	1	1	1
12/02/2020 22:00	1.5	12.5	2,100.4	1.1	8.40	1	1	1
12/02/2020 23:00	1.5	12.5	2,097.3	1.1	8.40	1	1	1
Average/Sum#:	1.3	13.0	1,940.8	0.9	164.80 #	24 #	24 #	18 #
Minimum:	0.7	12.1	1,548.5	0.6	3.10	1	1	0
Maximum:	1.6	14.0	2,186.9	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2020 00:00	1.5	12.6	2,084.1	1.1	8.30	1	1	1
12/03/2020 01:00	1.5	12.6	2,085.5	1.1	8.30	1	1	1
12/03/2020 02:00	1.5	12.7	2,021.0	1.1	8.10	1	1	1
12/03/2020 03:00	0.7	13.9	1,600.8	0.6	3.20	1	1	0
12/03/2020 04:00	1.0	13.5	1,848.2	0.8	5.50	1	1	1
12/03/2020 05:00	1.5	12.5	2,126.8	1.1	8.50	1	1	1
12/03/2020 06:00	1.6	12.1	2,214.2	1.1	8.90	1	1	1
12/03/2020 07:00	1.5	12.5	2,105.4	1.1	8.40	1	1	1
12/03/2020 08:00	1.5	12.7	2,073.3	1.1	8.30	1	1	1
12/03/2020 09:00	1.3	13.0	1,968.2	1.0	7.90	1	1	1
12/03/2020 10:00	0.8	13.9	1,696.7	0.7	3.40	1	1	0
12/03/2020 11:00	0.7	13.9	1,645.0	0.6	3.30	1	1	0
12/03/2020 12:00	0.8	13.9	1,678.3	0.7	3.40	1	1	0
12/03/2020 13:00	0.8	13.9	1,677.0	0.7	3.40	1	1	0
12/03/2020 14:00	1.0	13.5	1,833.6	0.8	5.50	1	1	1
12/03/2020 15:00	1.4	12.6	2,063.9	1.0	8.30	1	1	1
12/03/2020 16:00	1.6	12.3	2,133.9	1.1	8.50	1	1	1
12/03/2020 17:00	1.6	12.1	2,168.2	1.1	8.70	1	1	1
12/03/2020 18:00	1.6	12.0	2,181.3	1.1	8.70	1	1	1
12/03/2020 19:00	1.6	12.0	2,181.6	1.1	8.70	1	1	1
12/03/2020 20:00	1.5	12.3	2,127.5	1.0	8.50	1	1	1
12/03/2020 21:00	1.5	12.2	2,151.6	1.0	8.60	1	1	1
12/03/2020 22:00	1.5	12.3	2,133.1	1.0	8.50	1	1	1
12/03/2020 23:00	1.5	12.5	2,105.8	1.1	8.40	1	1	1
Average/Sum#:	1.3	12.8	1,996.0	1.0	171.30 #	24 #	24 #	19 #
Minimum:	0.7	12.0	1,600.8	0.6	3.20	1	1	0
Maximum:	1.6	13.9	2,214.2	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2020 00:00	1.5	12.6	2,104.5	1.1	8.40	1	1	1
12/04/2020 01:00	1.5	12.7	2,035.8	1.1	8.10	1	1	1
12/04/2020 02:00	0.8	13.9	1,687.4	0.7	3.40	1	1	0
12/04/2020 03:00	1.0	13.4	1,852.5	0.8	5.60	1	1	1
12/04/2020 04:00	1.5	12.5	2,109.8	1.1	8.40	1	1	1
12/04/2020 05:00	1.6	12.2	2,180.7	1.1	8.70	1	1	1
12/04/2020 06:00	1.5	12.0	2,204.9	1.0	8.80	1	1	1
12/04/2020 07:00	1.5	12.2	2,165.4	1.0	8.70	1	1	1
12/04/2020 08:00	1.5	12.7	2,066.6	1.1	8.30	1	1	1
12/04/2020 09:00	1.4	13.0	1,969.7	1.0	7.90	1	1	1
12/04/2020 10:00	0.7	13.9	1,620.2	0.6	3.20	1	1	0
12/04/2020 11:00	0.8	13.9	1,600.7	0.7	3.20	1	1	0
12/04/2020 12:00	1.2	13.2	1,929.1	0.9	5.80	1	1	1
12/04/2020 13:00	1.3	13.1	1,938.7	1.0	7.80	1	1	1
12/04/2020 14:00	0.8	13.9	1,663.3	0.7	3.30	1	1	0
12/04/2020 15:00	1.0	13.5	1,801.7	0.8	5.40	1	1	1
12/04/2020 16:00	1.6	12.5	2,098.6	1.1	8.40	1	1	1
12/04/2020 17:00	1.6	12.2	2,165.5	1.1	8.70	1	1	1
12/04/2020 18:00	1.6	12.2	2,173.7	1.1	8.70	1	1	1
12/04/2020 19:00	1.6	12.1	2,191.2	1.1	8.80	1	1	1
12/04/2020 20:00	1.6	12.2	2,155.8	1.1	8.60	1	1	1
12/04/2020 21:00	1.6	12.1	2,166.0	1.1	8.70	1	1	1
12/04/2020 22:00	1.5	12.3	2,133.9	1.0	8.50	1	1	1
12/04/2020 23:00	1.5	12.5	2,105.5	1.1	8.40	1	1	1
Average/Sum#:	1.3	12.8	2,005.1	1.0	173.80 #	24 #	24 #	20 #
Minimum:	0.7	12.0	1,600.7	0.6	3.20	1	1	0
Maximum:	1.6	13.9	2,204.9	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2020 00:00	1.5	12.5	2,111.5	1.1	8.40	1	1	1
12/05/2020 01:00	1.5	12.6	2,085.4	1.1	8.30	1	1	1
12/05/2020 02:00	1.5	12.6	2,101.7	1.1	8.40	1	1	1
12/05/2020 03:00	1.5	12.6	2,104.1	1.1	8.40	1	1	1
12/05/2020 04:00	1.5	12.6	2,102.4	1.1	8.40	1	1	1
12/05/2020 05:00	1.5	12.5	2,107.1	1.1	8.40	1	1	1
12/05/2020 06:00	1.3	12.8	2,051.3	0.9	6.20	1	1	1
12/05/2020 07:00	0.7	13.9	1,670.3	0.6	3.30	1	1	0
12/05/2020 08:00	0.7	13.9	1,629.1	0.6	3.30	1	1	0
12/05/2020 09:00	0.7	13.9	1,682.4	0.6	3.40	1	1	0
12/05/2020 10:00	0.8	13.9	1,674.4	0.7	3.30	1	1	0
12/05/2020 11:00	0.8	13.9	1,706.1	0.7	3.40	1	1	0
12/05/2020 12:00	0.8	13.9	1,697.3	0.7	3.40	1	1	0
12/05/2020 13:00	0.8	13.9	1,656.1	0.7	3.30	1	1	0
12/05/2020 14:00	0.8	13.9	1,640.7	0.7	3.30	1	1	0
12/05/2020 15:00	1.1	13.4	1,842.4	0.9	5.50	1	1	1
12/05/2020 16:00	1.5	12.6	2,088.0	1.1	8.40	1	1	1
12/05/2020 17:00	1.5	12.3	2,150.7	1.0	8.60	1	1	1
12/05/2020 18:00	1.6	12.1	2,184.2	1.1	8.70	1	1	1
12/05/2020 19:00	1.6	12.0	2,207.9	1.1	8.80	1	1	1
12/05/2020 20:00	1.6	12.1	2,192.9	1.1	8.80	1	1	1
12/05/2020 21:00	1.6	12.2	2,186.7	1.1	8.70	1	1	1
12/05/2020 22:00	1.5	12.5	2,116.2	1.1	8.50	1	1	1
12/05/2020 23:00	1.5	12.6	2,111.9	1.1	8.40	1	1	1
Average/Sum#:	1.2	13.0	1,962.5	0.9	157.60 #	24 #	24 #	16 #
Minimum:	0.7	12.0	1,629.1	0.6	3.30	1	1	0
Maximum:	1.6	13.9	2,207.9	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	1.5	12.6	2,109.1	1.1	8.40	1	1	1
12/06/2020 01:00	1.5	12.8	2,071.0	1.1	8.30	1	1	1
12/06/2020 02:00	1.5	12.8	2,070.6	1.1	8.30	1	1	1
12/06/2020 03:00	1.3	13.3	1,891.3	1.0	7.60	1	1	1
12/06/2020 04:00	1.0	13.7	1,800.5	0.8	5.40	1	1	1
12/06/2020 05:00	1.4	12.8	2,031.3	1.0	8.10	1	1	1
12/06/2020 06:00	1.2	13.0	1,955.2	0.9	5.90	1	1	1
12/06/2020 07:00	0.6	13.9	1,559.6	0.5	3.10	1	1	0
12/06/2020 08:00	0.6	13.9	1,564.2	0.5	3.10	1	1	0
12/06/2020 09:00	0.8	13.9	1,689.1	0.7	3.40	1	1	0
12/06/2020 10:00	0.8	13.9	1,688.9	0.7	3.40	1	1	0
12/06/2020 11:00	0.8	13.9	1,698.4	0.7	3.40	1	1	0
12/06/2020 12:00	0.7	14.0	1,617.5	0.6	3.20	1	1	0
12/06/2020 13:00	0.8	14.0	1,684.3	0.7	5.10	1	1	0
12/06/2020 14:00	0.7	14.0	1,654.6	0.6	3.30	1	1	0
12/06/2020 15:00	1.0	13.5	1,839.1	0.8	5.50	1	1	1
12/06/2020 16:00	1.5	12.6	2,077.2	1.1	8.30	1	1	1
12/06/2020 17:00	1.6	12.2	2,168.7	1.1	8.70	1	1	1
12/06/2020 18:00	1.6	12.1	2,193.8	1.1	8.80	1	1	1
12/06/2020 19:00	1.6	12.1	2,194.5	1.1	8.80	1	1	1
12/06/2020 20:00	1.6	12.1	2,191.8	1.1	8.80	1	1	1
12/06/2020 21:00	1.6	12.3	2,154.9	1.1	8.60	1	1	1
12/06/2020 22:00	1.5	12.5	2,100.7	1.1	8.40	1	1	1
12/06/2020 23:00	1.5	12.7	2,044.3	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.1	1,918.8	0.9	154.10 #	24 #	24 #	16 #
Minimum:	0.6	12.1	1,559.6	0.5	3.10	1	1	0
Maximum:	1.6	14.0	2,194.5	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2020 00:00	1.5	12.6	2,064.1	1.1	8.30	1	1	1
12/07/2020 01:00	1.4	12.9	1,966.0	1.0	7.90	1	1	1
12/07/2020 02:00	0.7	13.9	1,609.0	0.6	3.20	1	1	0
12/07/2020 03:00	1.1	13.5	1,819.8	0.9	5.50	1	1	1
12/07/2020 04:00	1.5	12.7	2,051.9	1.1	8.20	1	1	1
12/07/2020 05:00	1.5	12.6	2,073.5	1.1	8.30	1	1	1
12/07/2020 06:00	1.4	12.2	2,152.0	0.9	6.50	1	1	1
12/07/2020 07:00	1.5	12.2	2,146.6	1.0	8.60	1	1	1
12/07/2020 08:00	1.5	12.3	2,126.8	1.0	8.50	1	1	1
12/07/2020 09:00	1.5	12.3	2,108.4	1.0	8.40	1	1	1
12/07/2020 10:00	0.9	13.7	1,691.7	0.7	5.10	1	1	1
12/07/2020 11:00	0.7	14.0	1,595.5	0.6	3.20	1	1	0
12/07/2020 12:00	0.7	14.0	1,589.1	0.6	3.20	1	1	0
12/07/2020 13:00	0.8	14.0	1,668.9	0.7	5.00	1	1	0
12/07/2020 14:00	1.1	13.6	1,659.9	0.9	5.00	1	1	1
12/07/2020 15:00	1.5	12.5	2,029.3	1.1	8.10	1	1	1
12/07/2020 16:00	1.5	12.4	2,070.9	1.0	8.30	1	1	1
12/07/2020 17:00	1.5	12.2	2,130.0	1.0	8.50	1	1	1
12/07/2020 18:00	1.6	12.3	2,129.7	1.1	8.50	1	1	1
12/07/2020 19:00	1.6	12.3	2,133.4	1.1	8.50	1	1	1
12/07/2020 20:00	1.6	12.3	2,149.2	1.1	8.60	1	1	1
12/07/2020 21:00	1.6	12.2	2,169.2	1.1	8.70	1	1	1
12/07/2020 22:00	1.6	12.3	2,138.0	1.1	8.60	1	1	1
12/07/2020 23:00	1.5	12.7	2,064.9	1.1	8.30	1	1	1
Average/Sum#:	1.3	12.8	1,972.4	1.0	171.00 #	24 #	24 #	20 #
Minimum:	0.7	12.2	1,589.1	0.6	3.20	1	1	0
Maximum:	1.6	14.0	2,169.2	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2020 00:00	1.5	12.8	2,041.9	1.1	8.20	1	1	1
12/08/2020 01:00	1.4	13.1	1,938.2	1.1	7.80	1	1	1
12/08/2020 02:00	0.8	13.9	1,660.2	0.7	3.30	1	1	0
12/08/2020 03:00	1.0	13.5	1,793.9	0.8	5.40	1	1	1
12/08/2020 04:00	1.4	12.8	2,025.4	1.0	8.10	1	1	1
12/08/2020 05:00	1.4	13.1	1,972.8	1.1	7.90	1	1	1
12/08/2020 06:00	1.5	12.6	2,072.0	1.1	8.30	1	1	1
12/08/2020 07:00	1.5	12.3	2,149.5	1.0	8.60	1	1	1
12/08/2020 08:00	1.5	12.5	2,097.7	1.1	8.40	1	1	1
12/08/2020 09:00	1.4	13.0	1,961.8	1.0	7.80	1	1	1
12/08/2020 10:00	0.8	13.9	1,653.3	0.7	3.30	1	1	0
12/08/2020 11:00	0.7	14.0	1,579.3	0.6	3.20	1	1	0
12/08/2020 12:00	0.8	14.0	1,601.5	0.7	4.80	1	1	0
12/08/2020 13:00	0.7	14.0	1,566.8	0.6	3.10	1	1	0
12/08/2020 14:00	0.7	14.0	1,544.9	0.6	3.10	1	1	0
12/08/2020 15:00	1.1	13.7	1,708.2	0.9	5.10	1	1	1
12/08/2020 16:00	1.5	12.7	2,020.8	1.1	8.10	1	1	1
12/08/2020 17:00	1.6	12.2	2,141.1	1.1	8.60	1	1	1
12/08/2020 18:00	1.6	12.1	2,153.4	1.1	8.60	1	1	1
12/08/2020 19:00	1.6	12.0	2,180.5	1.1	8.70	1	1	1
12/08/2020 20:00	1.6	12.2	2,155.9	1.1	8.60	1	1	1
12/08/2020 21:00	1.5	12.4	2,117.1	1.0	8.50	1	1	1
12/08/2020 22:00	1.5	12.6	2,084.9	1.1	8.30	1	1	1
12/08/2020 23:00	1.5	12.8	2,050.4	1.1	8.20	1	1	1
Average/Sum#:	1.3	13.0	1,928.0	1.0	164.00 #	24 #	24 #	18 #
Minimum:	0.7	12.0	1,544.9	0.6	3.10	1	1	0
Maximum:	1.6	14.0	2,180.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2020 00:00	1.5	12.7	2,055.3	1.1	8.20	1	1	1
12/09/2020 01:00	1.5	12.8	2,036.2	1.1	8.10	1	1	1
12/09/2020 02:00	1.2	13.2	1,932.9	0.9	5.80	1	1	1
12/09/2020 03:00	0.9	13.9	1,752.2	0.8	5.30	1	1	0
12/09/2020 04:00	1.1	13.5	1,824.7	0.9	5.50	1	1	1
12/09/2020 05:00	1.5	12.8	2,037.2	1.1	8.10	1	1	1
12/09/2020 06:00	1.3	12.5	2,090.5	0.9	6.30	1	1	1
12/09/2020 07:00	1.5	12.6	2,087.7	1.1	8.40	1	1	1
12/09/2020 08:00	1.5	12.7	2,072.4	1.1	8.30	1	1	1
12/09/2020 09:00	1.4	13.2	1,904.2	1.1	7.60	1	1	1
12/09/2020 10:00	0.9	13.9	1,753.3	0.8	5.30	1	1	0
12/09/2020 11:00	0.9	13.9	1,754.1	0.8	5.30	1	1	0
12/09/2020 12:00	1.1	13.8	1,751.3	0.9	5.30	1	1	0
12/09/2020 13:00	1.3	13.8	1,754.8	1.1	7.00	1	1	0
12/09/2020 14:00	1.3	13.8	1,751.7	1.1	7.00	1	1	0
12/09/2020 15:00	1.4	13.3	1,816.3	1.1	7.30	1	1	1
12/09/2020 16:00	1.5	12.4	2,054.6	1.0	8.20	1	1	1
12/09/2020 17:00	1.5	12.3	2,088.2	1.0	8.40	1	1	1
12/09/2020 18:00	1.5	12.3	2,087.2	1.0	8.30	1	1	1
12/09/2020 19:00	1.6	12.3	2,132.6	1.1	8.50	1	1	1
12/09/2020 20:00	1.5	12.4	2,111.0	1.0	8.40	1	1	1
12/09/2020 21:00	1.6	12.2	2,149.4	1.1	8.60	1	1	1
12/09/2020 22:00	1.5	12.2	2,141.9	1.0	8.60	1	1	1
12/09/2020 23:00	1.5	12.5	2,081.5	1.1	8.30	1	1	1
Average/Sum#:	1.4	13.0	1,967.6	1.0	176.10 #	24 #	24 #	18 #
Minimum:	0.9	12.2	1,751.3	0.8	5.30	1	1	0
Maximum:	1.6	13.9	2,149.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	1.5	12.6	2,074.4	1.1	8.30	1	1	1
12/10/2020 01:00	1.5	12.7	2,045.2	1.1	8.20	1	1	1
12/10/2020 02:00	1.5	12.6	2,058.3	1.1	8.20	1	1	1
12/10/2020 03:00	0.8	13.9	1,695.1	0.7	3.40	1	1	0
12/10/2020 04:00	1.1	13.4	1,830.0	0.9	5.50	1	1	1
12/10/2020 05:00	1.5	12.3	2,122.5	1.0	8.50	1	1	1
12/10/2020 06:00	1.5	12.4	2,109.0	1.0	8.40	1	1	1
12/10/2020 07:00	1.5	12.4	2,096.7	1.0	8.40	1	1	1
12/10/2020 08:00	1.5	12.4	2,101.1	1.0	8.40	1	1	1
12/10/2020 09:00	1.5	12.4	2,100.4	1.0	8.40	1	1	1
12/10/2020 10:00	0.9	13.7	1,696.2	0.7	5.10	1	1	1
12/10/2020 11:00	0.7	14.0	1,626.8	0.6	3.30	1	1	0
12/10/2020 12:00	0.6	14.0	1,532.4	0.5	3.10	1	1	0
12/10/2020 13:00	0.7	14.0	1,574.9	0.6	3.10	1	1	0
12/10/2020 14:00	0.7	14.0	1,536.7	0.6	3.10	1	1	0
12/10/2020 15:00	1.1	13.5	1,819.1	0.9	5.50	1	1	1
12/10/2020 16:00	1.5	12.7	2,059.5	1.1	8.20	1	1	1
12/10/2020 17:00	1.6	12.4	2,132.7	1.1	8.50	1	1	1
12/10/2020 18:00	1.6	12.2	2,150.8	1.1	8.60	1	1	1
12/10/2020 19:00	1.6	12.3	2,125.9	1.1	8.50	1	1	1
12/10/2020 20:00	1.6	12.5	2,096.4	1.1	8.40	1	1	1
12/10/2020 21:00	1.5	12.4	2,113.2	1.0	8.50	1	1	1
12/10/2020 22:00	1.6	12.4	2,107.0	1.1	8.40	1	1	1
12/10/2020 23:00	1.5	12.7	2,070.0	1.1	8.30	1	1	1
Average/Sum#:	1.3	12.9	1,953.1	0.9	166.30 #	24 #	24 #	19 #
Minimum:	0.6	12.2	1,532.4	0.5	3.10	1	1	0
Maximum:	1.6	14.0	2,150.8	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2020 00:00	1.4	13.1	1,943.2	1.1	7.80	1	1	1
12/11/2020 01:00	0.8	13.9	1,702.9	0.7	3.40	1	1	0
12/11/2020 02:00	0.7	13.9	1,603.5	0.6	3.20	1	1	0
12/11/2020 03:00	0.7	13.9	1,594.9	0.6	3.20	1	1	0
12/11/2020 04:00	1.0	13.5	1,774.4	0.8	5.30	1	1	1
12/11/2020 05:00	1.5	12.8	2,063.6	1.1	8.30	1	1	1
12/11/2020 06:00	1.5	12.5	2,134.0	1.1	8.50	1	1	1
12/11/2020 07:00	1.5	12.5	2,112.2	1.1	8.40	1	1	1
12/11/2020 08:00	1.5	12.6	2,075.6	1.1	8.30	1	1	1
12/11/2020 09:00	0.8	13.9	1,668.3	0.7	3.30	1	1	0
12/11/2020 10:00	0.7	13.9	1,667.1	0.6	3.30	1	1	0
12/11/2020 11:00	0.7	13.9	1,650.1	0.6	3.30	1	1	0
12/11/2020 12:00	0.7	13.9	1,627.3	0.6	3.30	1	1	0
12/11/2020 13:00	0.8	13.9	1,670.4	0.7	3.30	1	1	0
12/11/2020 14:00	0.8	13.9	1,675.3	0.7	3.40	1	1	0
12/11/2020 15:00	1.1	13.5	1,823.4	0.9	5.50	1	1	1
12/11/2020 16:00	1.5	12.5	2,092.7	1.1	8.40	1	1	1
12/11/2020 17:00	1.5	12.4	2,120.0	1.0	8.50	1	1	1
12/11/2020 18:00	1.6	12.1	2,177.2	1.1	8.70	1	1	1
12/11/2020 19:00	1.6	12.1	2,182.0	1.1	8.70	1	1	1
12/11/2020 20:00	1.6	12.1	2,181.6	1.1	8.70	1	1	1
12/11/2020 21:00	1.6	12.1	2,179.2	1.1	8.70	1	1	1
12/11/2020 22:00	1.6	12.4	2,113.9	1.1	8.50	1	1	1
12/11/2020 23:00	1.5	12.6	2,084.2	1.1	8.30	1	1	1
Average/Sum#:	1.2	13.1	1,913.2	0.9	150.30 #	24 #	24 #	15 #
Minimum:	0.7	12.1	1,594.9	0.6	3.20	1	1	0
Maximum:	1.6	13.9	2,182.0	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	1.5	12.5	2,098.2	1.1	8.40	1	1	1
12/12/2020 01:00	1.5	12.6	2,064.1	1.1	8.30	1	1	1
12/12/2020 02:00	1.3	13.1	1,946.1	1.0	7.80	1	1	1
12/12/2020 03:00	0.8	13.8	1,622.9	0.7	3.20	1	1	0
12/12/2020 04:00	1.0	13.5	1,817.4	0.8	5.50	1	1	1
12/12/2020 05:00	1.2	13.2	1,947.0	0.9	5.80	1	1	1
12/12/2020 06:00	1.2	13.2	1,936.7	0.9	5.80	1	1	1
12/12/2020 07:00	0.8	13.8	1,690.5	0.7	3.40	1	1	1
12/12/2020 08:00	0.7	13.8	1,675.2	0.6	3.40	1	1	0
12/12/2020 09:00	0.8	13.8	1,687.3	0.7	3.40	1	1	0
12/12/2020 10:00	0.7	13.9	1,672.3	0.6	3.30	1	1	0
12/12/2020 11:00	0.7	13.9	1,582.7	0.6	3.20	1	1	0
12/12/2020 12:00	0.7	13.9	1,644.0	0.6	3.30	1	1	0
12/12/2020 13:00	0.8	13.9	1,701.2	0.7	3.40	1	1	0
12/12/2020 14:00	0.7	13.9	1,672.1	0.6	3.30	1	1	0
12/12/2020 15:00	1.1	13.4	1,825.5	0.9	5.50	1	1	1
12/12/2020 16:00	1.5	12.6	2,069.8	1.1	8.30	1	1	1
12/12/2020 17:00	1.5	12.3	2,128.6	1.0	8.50	1	1	1
12/12/2020 18:00	1.6	12.2	2,163.9	1.1	8.70	1	1	1
12/12/2020 19:00	1.6	12.2	2,164.6	1.1	8.70	1	1	1
12/12/2020 20:00	1.6	12.2	2,162.7	1.1	8.70	1	1	1
12/12/2020 21:00	1.6	12.2	2,159.5	1.1	8.60	1	1	1
12/12/2020 22:00	1.5	12.2	2,145.1	1.0	8.60	1	1	1
12/12/2020 23:00	1.6	12.5	2,089.3	1.1	8.40	1	1	1
Average/Sum#:	1.2	13.1	1,902.8	0.9	145.50 #	24 #	24 #	16 #
Minimum:	0.7	12.2	1,582.7	0.6	3.20	1	1	0
Maximum:	1.6	13.9	2,164.6	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	1.5	12.5	2,094.3	1.1	8.40	1	1	1
12/13/2020 01:00	1.5	12.7	2,049.3	1.1	8.20	1	1	1
12/13/2020 02:00	1.2	13.2	1,945.5	0.9	5.80	1	1	1
12/13/2020 03:00	1.2	13.2	1,945.8	0.9	5.80	1	1	1
12/13/2020 04:00	1.2	13.2	1,957.7	0.9	5.90	1	1	1
12/13/2020 05:00	1.5	12.8	2,035.9	1.1	8.10	1	1	1
12/13/2020 06:00	1.4	12.8	2,026.4	1.0	8.10	1	1	1
12/13/2020 07:00	0.8	13.8	1,606.2	0.7	3.20	1	1	0
12/13/2020 08:00	0.6	13.9	1,299.5	0.5	2.60	1	1	0
12/13/2020 09:00	0.6	13.9	1,300.2	0.5	2.60	1	1	0
12/13/2020 10:00	0.6	13.9	1,314.2	0.5	2.60	1	1	0
12/13/2020 11:00	0.7	13.9	1,500.8	0.6	3.00	1	1	0
12/13/2020 12:00	0.8	13.8	1,668.3	0.7	3.30	1	1	0
12/13/2020 13:00	0.8	13.8	1,683.1	0.7	3.40	1	1	0
12/13/2020 14:00	0.8	13.8	1,693.8	0.7	3.40	1	1	0
12/13/2020 15:00	1.1	13.4	1,806.9	0.9	5.40	1	1	1
12/13/2020 16:00	1.5	12.6	2,042.3	1.1	8.20	1	1	1
12/13/2020 17:00	1.6	12.2	2,140.8	1.1	8.60	1	1	1
12/13/2020 18:00	1.6	12.2	2,137.1	1.1	8.50	1	1	1
12/13/2020 19:00	1.6	12.4	2,108.1	1.1	8.40	1	1	1
12/13/2020 20:00	1.6	12.4	2,120.4	1.1	8.50	1	1	1
12/13/2020 21:00	1.5	12.6	2,081.7	1.1	8.30	1	1	1
12/13/2020 22:00	1.5	12.8	2,038.0	1.1	8.20	1	1	1
12/13/2020 23:00	1.5	12.8	2,012.3	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.1	1,858.7	0.9	146.50 #	24 #	24 #	16 #
Minimum:	0.6	12.2	1,299.5	0.5	2.60	1	1	0
Maximum:	1.6	13.9	2,140.8	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	6.2	15.5	715.7	6.8	4.83	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/14/2020 05:00	14.1	17.5	497.1	24.5	29.06	1	0	0
12/14/2020 06:00	7.0	13.9	1,539.7	5.9	33.90	1	0	1
12/14/2020 07:00	1.4	12.8	2,066.9	1.0	8.30	1	1	1
12/14/2020 08:00	1.4	12.9	2,053.3	1.0	8.20	1	1	1
12/14/2020 09:00	1.4	13.0	2,019.6	1.0	8.10	1	1	1
12/14/2020 10:00	0.6	13.9	1,526.8	0.5	3.10	1	1	0
12/14/2020 11:00	0.7	13.9	1,544.1	0.6	3.10	1	1	0
12/14/2020 12:00	0.7	13.9	1,421.5	0.6	2.80	1	1	0
12/14/2020 13:00	0.6	14.0	1,375.4	0.5	2.80	1	1	0
12/14/2020 14:00	0.0	0.0	1,426.7	0.0	0.00	1	1	0
12/14/2020 15:00	0.0	0.0	1,852.2	0.0	0.00	1	1	1
12/14/2020 16:00	1.0	12.6	1,988.4	0.7	6.00	1	1	1
12/14/2020 17:00	1.5	12.2	2,161.3	1.0	8.60	1	1	1
12/14/2020 18:00	1.6	12.2	2,174.8	1.1	8.70	1	1	1
12/14/2020 19:00	1.6	12.2	2,172.2	1.1	8.70	1	1	1
12/14/2020 20:00	1.6	12.2	2,172.7	1.1	8.70	1	1	1
12/14/2020 21:00	1.6	12.2	2,171.4	1.1	8.70	1	1	1
12/14/2020 22:00	1.5	12.4	2,108.0	1.0	8.40	1	1	1
12/14/2020 23:00	1.2	13.2	1,938.6	0.9	5.80	1	1	1
Average/Sum#:	2.5	13.4	1,746.3	2.8	167.79 #	20 #	17 #	13 #
Minimum:	0.6	12.2	497.1	0.5	2.80	0	0	0
Maximum:	14.1	17.5	2,174.8	24.5	33.90	1	1	1
%SI	25.00	25.00	16.67	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2020 00:00	1.4	12.9	2,009.6	1.0	8.00	1	1	1
12/15/2020 01:00	1.2	13.2	1,940.9	0.9	5.80	1	1	1
12/15/2020 02:00	1.3	13.2	1,940.2	1.0	7.80	1	1	1
12/15/2020 03:00	1.2	13.3	1,935.0	0.9	5.80	1	1	1
12/15/2020 04:00	1.4	12.9	2,029.4	1.0	8.10	1	1	1
12/15/2020 05:00	1.6	12.3	2,158.1	1.1	8.60	1	1	1
12/15/2020 06:00	1.6	12.3	2,168.5	1.1	8.70	1	1	1
12/15/2020 07:00	1.6	12.4	2,134.9	1.1	8.50	1	1	1
12/15/2020 08:00	1.5	12.9	2,019.0	1.1	8.10	1	1	1
12/15/2020 09:00	1.3	13.2	1,957.2	1.0	7.80	1	1	1
12/15/2020 10:00	1.1	13.3	1,930.5	0.9	5.80	1	1	1
12/15/2020 11:00	1.1	13.3	1,941.1	0.9	5.80	1	1	1
12/15/2020 12:00	1.1	13.2	1,943.1	0.8	5.80	1	1	1
12/15/2020 13:00	1.2	13.2	1,941.8	0.9	5.80	1	1	1
12/15/2020 14:00	1.4	13.2	1,945.4	1.1	7.80	1	1	1
12/15/2020 15:00	1.4	13.2	1,946.1	1.1	7.80	1	1	1
12/15/2020 16:00	1.4	12.9	2,017.1	1.0	8.10	1	1	1
12/15/2020 17:00	1.6	12.3	2,159.2	1.1	8.60	1	1	1
12/15/2020 18:00	1.6	12.2	2,174.2	1.1	8.70	1	1	1
12/15/2020 19:00	1.6	12.3	2,168.9	1.1	8.70	1	1	1
12/15/2020 20:00	1.6	12.3	2,160.0	1.1	8.60	1	1	1
12/15/2020 21:00	1.6	12.4	2,150.1	1.1	8.60	1	1	1
12/15/2020 22:00	1.5	12.4	2,139.6	1.0	8.60	1	1	1
12/15/2020 23:00	1.5	12.7	2,065.7	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.8	2,040.7	1.0	184.20 #	24 #	24 #	24 #
Minimum:	1.1	12.2	1,930.5	0.8	5.80	1	1	1
Maximum:	1.6	13.3	2,174.2	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2020 00:00	1.5	12.8	2,038.4	1.1	8.20	1	1	1
12/16/2020 01:00	1.4	13.0	1,993.0	1.0	8.00	1	1	1
12/16/2020 02:00	1.1	13.3	1,941.5	0.9	5.80	1	1	1
12/16/2020 03:00	1.1	13.3	1,944.0	0.9	5.80	1	1	1
12/16/2020 04:00	1.3	13.1	1,981.3	1.0	7.90	1	1	1
12/16/2020 05:00	1.5	12.6	2,094.3	1.1	8.40	1	1	1
12/16/2020 06:00	1.5	12.4	2,126.3	1.0	8.50	1	1	1
12/16/2020 07:00	1.6	12.4	2,154.6	1.1	8.60	1	1	1
12/16/2020 08:00	1.5	12.7	2,092.8	1.1	8.40	1	1	1
12/16/2020 09:00	1.0	13.3	1,938.6	0.8	5.80	1	1	1
12/16/2020 10:00	1.1	13.3	1,934.1	0.9	5.80	1	1	1
12/16/2020 11:00	1.3	13.2	1,940.5	1.0	7.80	1	1	1
12/16/2020 12:00	1.4	13.2	1,937.4	1.1	7.70	1	1	1
12/16/2020 13:00	1.5	13.1	1,940.0	1.1	7.80	1	1	1
12/16/2020 14:00	1.4	13.1	1,933.2	1.1	7.70	1	1	1
12/16/2020 15:00	0.7	13.9	1,688.3	0.6	3.40	1	1	0
12/16/2020 16:00	0.5	13.9	1,508.1	0.4	3.00	1	1	0
12/16/2020 17:00	0.7	13.7	1,774.6	0.6	3.50	1	1	0
12/16/2020 18:00	1.1	13.2	1,909.3	0.8	5.70	1	1	1
12/16/2020 19:00	1.5	12.3	2,134.9	1.0	8.50	1	1	1
12/16/2020 20:00	1.6	12.1	2,167.0	1.1	8.70	1	1	1
12/16/2020 21:00	1.6	12.1	2,164.6	1.1	8.70	1	1	1
12/16/2020 22:00	1.6	12.1	2,161.2	1.1	8.60	1	1	1
12/16/2020 23:00	1.5	12.2	2,147.4	1.0	8.60	1	1	1
Average/Sum#:	1.3	12.9	1,985.2	1.0	170.90 #	24 #	24 #	21 #
Minimum:	0.5	12.1	1,508.1	0.4	3.00	1	1	0
Maximum:	1.6	13.9	2,167.0	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2020 00:00	1.4	12.5	2,073.1	1.0	8.30	1	1	1
12/17/2020 01:00	1.2	13.0	1,893.2	0.9	5.70	1	1	1
12/17/2020 02:00	0.8	13.6	1,784.7	0.6	3.60	1	1	1
12/17/2020 03:00	1.3	12.7	2,035.1	0.9	6.10	1	1	1
12/17/2020 04:00	1.4	12.6	2,056.8	1.0	8.20	1	1	1
12/17/2020 05:00	1.4	12.5	2,074.1	1.0	8.30	1	1	1
12/17/2020 06:00	1.4	12.7	2,013.4	1.0	8.10	1	1	1
12/17/2020 07:00	1.5	12.4	2,113.9	1.0	8.50	1	1	1
12/17/2020 08:00	1.4	12.6	2,061.6	1.0	8.20	1	1	1
12/17/2020 09:00	1.3	12.9	1,976.5	1.0	7.90	1	1	1
12/17/2020 10:00	0.6	13.9	1,637.6	0.5	3.30	1	1	0
12/17/2020 11:00	0.6	13.9	1,686.0	0.5	3.40	1	1	0
12/17/2020 12:00	0.6	13.9	1,671.8	0.5	3.30	1	1	0
12/17/2020 13:00	0.6	13.9	1,685.6	0.5	3.40	1	1	0
12/17/2020 14:00	0.6	13.9	1,660.7	0.5	3.30	1	1	0
12/17/2020 15:00	0.5	13.9	1,654.1	0.4	3.30	1	1	0
12/17/2020 16:00	0.9	13.5	1,810.0	0.7	5.40	1	1	1
12/17/2020 17:00	1.5	12.6	2,085.0	1.1	8.30	1	1	1
12/17/2020 18:00	1.5	12.5	2,093.9	1.1	8.40	1	1	1
12/17/2020 19:00	1.5	12.6	2,068.2	1.1	8.30	1	1	1
12/17/2020 20:00	1.5	12.7	2,058.0	1.1	8.20	1	1	1
12/17/2020 21:00	1.5	12.5	2,112.6	1.1	8.50	1	1	1
12/17/2020 22:00	1.5	12.7	2,078.4	1.1	8.30	1	1	1
12/17/2020 23:00	1.5	12.8	2,052.8	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.0	1,934.9	0.9	156.50 #	24 #	24 #	18 #
Minimum:	0.5	12.4	1,637.6	0.4	3.30	1	1	0
Maximum:	1.5	13.9	2,113.9	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	1.5	12.8	2,060.5	1.1	8.20	1	1	1
12/18/2020 01:00	1.2	13.2	1,956.3	0.9	5.90	1	1	1
12/18/2020 02:00	0.7	13.9	1,694.8	0.6	3.40	1	1	0
12/18/2020 03:00	0.4	13.9	1,467.8	0.3	1.50	1	1	0
12/18/2020 04:00	0.7	13.8	1,689.6	0.6	3.40	1	1	1
12/18/2020 05:00	1.1	13.1	1,977.9	0.8	5.90	1	1	1
12/18/2020 06:00	1.4	12.5	2,121.0	1.0	8.50	1	1	1
12/18/2020 07:00	1.5	12.6	2,109.8	1.1	8.40	1	1	1
12/18/2020 08:00	1.1	13.2	1,944.1	0.8	5.80	1	1	1
12/18/2020 09:00	0.6	13.9	1,698.5	0.5	3.40	1	1	0
12/18/2020 10:00	0.5	13.9	1,560.0	0.4	3.10	1	1	0
12/18/2020 11:00	0.4	14.0	1,405.1	0.3	1.40	1	1	0
12/18/2020 12:00	0.5	13.9	1,499.7	0.4	3.00	1	1	0
12/18/2020 13:00	0.5	13.9	1,596.7	0.4	3.20	1	1	0
12/18/2020 14:00	0.4	14.0	1,410.7	0.3	1.40	1	1	0
12/18/2020 15:00	0.5	14.0	1,430.1	0.4	2.90	1	1	0
12/18/2020 16:00	1.1	13.4	1,859.6	0.9	5.60	1	1	1
12/18/2020 17:00	1.6	12.3	2,145.7	1.1	8.60	1	1	1
12/18/2020 18:00	1.6	12.1	2,195.2	1.1	8.80	1	1	1
12/18/2020 19:00	1.6	12.1	2,202.0	1.1	8.80	1	1	1
12/18/2020 20:00	1.6	12.2	2,186.5	1.1	8.70	1	1	1
12/18/2020 21:00	1.6	12.3	2,161.8	1.1	8.60	1	1	1
12/18/2020 22:00	1.5	12.6	2,114.9	1.1	8.50	1	1	1
12/18/2020 23:00	1.5	12.8	2,056.8	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.2	1,856.0	0.8	135.20 #	24 #	24 #	15 #
Minimum:	0.4	12.1	1,405.1	0.3	1.40	1	1	0
Maximum:	1.6	14.0	2,202.0	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	1.5	12.9	2,046.4	1.1	8.20	1	1	1
12/19/2020 01:00	1.3	13.0	1,996.8	1.0	8.00	1	1	1
12/19/2020 02:00	0.6	13.8	1,649.9	0.5	3.30	1	1	0
12/19/2020 03:00	0.5	13.9	1,546.5	0.4	3.10	1	1	0
12/19/2020 04:00	0.8	13.5	1,863.9	0.6	3.70	1	1	1
12/19/2020 05:00	1.4	12.8	2,071.0	1.0	8.30	1	1	1
12/19/2020 06:00	1.2	13.0	2,006.2	0.9	6.00	1	1	1
12/19/2020 07:00	0.6	13.8	1,669.1	0.5	3.30	1	1	0
12/19/2020 08:00	0.5	13.8	1,584.7	0.4	3.20	1	1	0
12/19/2020 09:00	0.5	13.8	1,629.3	0.4	3.30	1	1	0
12/19/2020 10:00	0.5	13.8	1,694.1	0.4	3.40	1	1	0
12/19/2020 11:00	0.6	13.9	1,703.6	0.5	3.40	1	1	0
12/19/2020 12:00	0.6	13.9	1,705.0	0.5	3.40	1	1	0
12/19/2020 13:00	0.6	13.9	1,694.8	0.5	3.40	1	1	0
12/19/2020 14:00	0.7	13.9	1,703.9	0.6	3.40	1	1	0
12/19/2020 15:00	0.8	13.7	1,760.6	0.7	3.50	1	1	1
12/19/2020 16:00	1.4	12.7	2,047.2	1.0	8.20	1	1	1
12/19/2020 17:00	1.5	12.5	2,112.1	1.1	8.40	1	1	1
12/19/2020 18:00	1.6	12.2	2,168.6	1.1	8.70	1	1	1
12/19/2020 19:00	1.6	12.2	2,183.5	1.1	8.70	1	1	1
12/19/2020 20:00	1.6	12.3	2,153.8	1.1	8.60	1	1	1
12/19/2020 21:00	1.5	12.5	2,119.8	1.1	8.50	1	1	1
12/19/2020 22:00	1.5	12.7	2,068.5	1.1	8.30	1	1	1
12/19/2020 23:00	1.5	13.0	2,001.6	1.1	8.00	1	1	1
Average/Sum#:	1.0	13.2	1,882.5	0.8	138.30 #	24 #	24 #	14 #
Minimum:	0.5	12.2	1,546.5	0.4	3.10	1	1	0
Maximum:	1.6	13.9	2,183.5	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	1.2	13.1	1,967.3	0.9	5.90	1	1	1
12/20/2020 01:00	0.6	13.9	1,654.5	0.5	3.30	1	1	0
12/20/2020 02:00	0.5	13.9	1,544.0	0.4	3.10	1	1	0
12/20/2020 03:00	0.4	13.9	1,373.6	0.3	1.40	1	1	0
12/20/2020 04:00	0.5	13.8	1,570.8	0.4	3.10	1	1	0
12/20/2020 05:00	0.8	13.5	1,848.0	0.6	3.70	1	1	1
12/20/2020 06:00	0.9	13.4	1,881.2	0.7	5.60	1	1	1
12/20/2020 07:00	0.5	13.8	1,695.8	0.4	3.40	1	1	0
12/20/2020 08:00	0.5	13.8	1,672.4	0.4	3.30	1	1	0
12/20/2020 09:00	0.5	13.8	1,690.2	0.4	3.40	1	1	0
12/20/2020 10:00	0.6	13.8	1,690.4	0.5	3.40	1	1	0
12/20/2020 11:00	0.6	13.9	1,689.4	0.5	3.40	1	1	0
12/20/2020 12:00	0.6	13.9	1,698.6	0.5	3.40	1	1	0
12/20/2020 13:00	0.6	13.9	1,680.8	0.5	3.40	1	1	0
12/20/2020 14:00	0.5	13.9	1,620.0	0.4	3.20	1	1	0
12/20/2020 15:00	0.7	13.7	1,701.9	0.6	3.40	1	1	1
12/20/2020 16:00	1.4	12.8	2,019.1	1.0	8.10	1	1	1
12/20/2020 17:00	1.6	12.4	2,102.7	1.1	8.40	1	1	1
12/20/2020 18:00	1.6	12.4	2,118.0	1.1	8.50	1	1	1
12/20/2020 19:00	1.6	12.4	2,120.9	1.1	8.50	1	1	1
12/20/2020 20:00	1.6	12.2	2,153.0	1.1	8.60	1	1	1
12/20/2020 21:00	1.5	12.4	2,103.0	1.0	8.40	1	1	1
12/20/2020 22:00	1.5	12.5	2,092.3	1.1	8.40	1	1	1
12/20/2020 23:00	1.4	12.8	2,037.5	1.0	8.20	1	1	1
Average/Sum#:	0.9	13.3	1,821.9	0.7	123.50 #	24 #	24 #	12 #
Minimum:	0.4	12.2	1,373.6	0.3	1.40	1	1	0
Maximum:	1.6	13.9	2,153.0	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	1.1	13.2	1,928.9	0.8	5.80	1	1	1
12/21/2020 01:00	0.6	13.8	1,665.1	0.5	3.30	1	1	0
12/21/2020 02:00	0.5	13.8	1,601.8	0.4	3.20	1	1	0
12/21/2020 03:00	0.5	13.8	1,550.2	0.4	3.10	1	1	0
12/21/2020 04:00	0.9	13.5	1,855.9	0.7	5.60	1	1	1
12/21/2020 05:00	1.4	12.8	2,073.0	1.0	8.30	1	1	1
12/21/2020 06:00	1.5	12.7	2,088.8	1.1	8.40	1	1	1
12/21/2020 07:00	1.4	12.7	2,092.5	1.0	8.40	1	1	1
12/21/2020 08:00	1.3	13.0	2,002.1	1.0	8.00	1	1	1
12/21/2020 09:00	0.6	13.8	1,681.8	0.5	3.40	1	1	0
12/21/2020 10:00	0.5	13.8	1,690.7	0.4	3.40	1	1	0
12/21/2020 11:00	0.6	13.8	1,690.4	0.5	3.40	1	1	0
12/21/2020 12:00	0.6	13.8	1,680.4	0.5	3.40	1	1	0
12/21/2020 13:00	0.6	13.8	1,689.3	0.5	3.40	1	1	0
12/21/2020 14:00	0.6	13.9	1,682.8	0.5	3.40	1	1	0
12/21/2020 15:00	0.9	13.5	1,810.1	0.7	5.40	1	1	1
12/21/2020 16:00	1.4	12.6	2,076.7	1.0	8.30	1	1	1
12/21/2020 17:00	1.5	12.5	2,092.6	1.1	8.40	1	1	1
12/21/2020 18:00	1.5	12.4	2,141.3	1.0	8.60	1	1	1
12/21/2020 19:00	1.5	12.5	2,119.8	1.1	8.50	1	1	1
12/21/2020 20:00	1.4	12.6	2,090.8	1.0	8.40	1	1	1
12/21/2020 21:00	1.4	12.7	2,067.4	1.0	8.30	1	1	1
12/21/2020 22:00	1.4	12.7	2,065.7	1.0	8.30	1	1	1
12/21/2020 23:00	1.4	12.9	2,022.9	1.0	8.10	1	1	1
Average/Sum#:	1.0	13.2	1,894.2	0.8	146.80 #	24 #	24 #	15 #
Minimum:	0.5	12.4	1,550.2	0.4	3.10	1	1	0
Maximum:	1.5	13.9	2,141.3	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2020 00:00	1.2	13.2	1,944.2	0.9	5.80	1	1	1
12/22/2020 01:00	0.6	13.8	1,654.9	0.5	3.30	1	1	0
12/22/2020 02:00	0.5	13.8	1,539.7	0.4	3.10	1	1	0
12/22/2020 03:00	0.5	13.8	1,519.5	0.4	3.00	1	1	0
12/22/2020 04:00	0.7	13.7	1,715.0	0.6	3.40	1	1	1
12/22/2020 05:00	1.3	12.9	2,044.5	1.0	8.20	1	1	1
12/22/2020 06:00	1.3	12.7	2,071.3	0.9	6.20	1	1	1
12/22/2020 07:00	1.4	12.5	2,123.3	1.0	8.50	1	1	1
12/22/2020 08:00	0.7	13.6	1,722.7	0.6	3.40	1	1	1
12/22/2020 09:00	0.5	13.8	1,611.8	0.4	3.20	1	1	0
12/22/2020 10:00	0.6	13.9	1,691.1	0.5	3.40	1	1	0
12/22/2020 11:00	0.6	13.9	1,630.8	0.5	3.30	1	1	0
12/22/2020 12:00	0.5	13.9	1,585.7	0.4	3.20	1	1	0
12/22/2020 13:00	0.6	13.9	1,651.0	0.5	3.30	1	1	0
12/22/2020 14:00	0.6	13.9	1,685.0	0.5	3.40	1	1	0
12/22/2020 15:00	0.7	13.8	1,697.0	0.6	3.40	1	1	1
12/22/2020 16:00	1.4	12.9	2,003.8	1.0	8.00	1	1	1
12/22/2020 17:00	1.5	12.5	2,104.5	1.1	8.40	1	1	1
12/22/2020 18:00	1.5	12.4	2,122.2	1.0	8.50	1	1	1
12/22/2020 19:00	1.5	12.4	2,125.2	1.0	8.50	1	1	1
12/22/2020 20:00	1.5	12.4	2,135.4	1.0	8.50	1	1	1
12/22/2020 21:00	1.5	12.5	2,104.4	1.1	8.40	1	1	1
12/22/2020 22:00	1.5	12.6	2,087.9	1.1	8.40	1	1	1
12/22/2020 23:00	1.5	12.8	2,061.4	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.2	1,859.7	0.8	135.00 #	24 #	24 #	15 #
Minimum:	0.5	12.4	1,519.5	0.4	3.00	1	1	0
Maximum:	1.5	13.9	2,135.4	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2020 00:00	1.3	12.9	1,993.7	1.0	8.00	1	1	1
12/23/2020 01:00	0.7	13.9	1,699.9	0.6	3.40	1	1	0
12/23/2020 02:00	0.9	13.5	1,835.5	0.7	5.50	1	1	1
12/23/2020 03:00	1.1	13.2	1,955.2	0.8	5.90	1	1	1
12/23/2020 04:00	1.4	12.9	1,998.6	1.0	8.00	1	1	1
12/23/2020 05:00	0.7	13.9	1,692.0	0.6	3.40	1	1	0
12/23/2020 06:00	1.1	13.3	1,833.8	0.9	5.50	1	1	1
12/23/2020 07:00	1.4	12.6	2,092.0	1.0	8.40	1	1	1
12/23/2020 08:00	1.5	12.6	2,079.8	1.1	8.30	1	1	1
12/23/2020 09:00	1.4	12.9	1,990.0	1.0	8.00	1	1	1
12/23/2020 10:00	0.6	13.9	1,674.9	0.5	3.30	1	1	0
12/23/2020 11:00	0.5	14.0	1,617.6	0.4	3.20	1	1	0
12/23/2020 12:00	0.6	14.0	1,657.1	0.5	3.30	1	1	0
12/23/2020 13:00	0.6	14.0	1,685.4	0.5	3.40	1	1	0
12/23/2020 14:00	0.6	14.0	1,687.4	0.5	3.40	1	1	0
12/23/2020 15:00	0.7	13.8	1,671.8	0.6	3.30	1	1	1
12/23/2020 16:00	1.5	12.6	2,069.0	1.1	8.30	1	1	1
12/23/2020 17:00	1.5	12.1	2,196.0	1.0	8.80	1	1	1
12/23/2020 18:00	1.6	12.0	2,217.8	1.1	8.90	1	1	1
12/23/2020 19:00	1.6	12.0	2,222.9	1.1	8.90	1	1	1
12/23/2020 20:00	1.6	12.1	2,223.4	1.1	8.90	1	1	1
12/23/2020 21:00	1.5	12.5	2,102.1	1.1	8.40	1	1	1
12/23/2020 22:00	1.5	12.6	2,111.4	1.1	8.40	1	1	1
12/23/2020 23:00	1.5	12.7	2,096.5	1.1	8.40	1	1	1
Average/Sum#:	1.1	13.1	1,933.5	0.9	153.30 #	24 #	24 #	17 #
Minimum:	0.5	12.0	1,617.6	0.4	3.20	1	1	0
Maximum:	1.6	14.0	2,223.4	1.1	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2020 00:00	1.5	12.9	2,051.2	1.1	8.20	1	1	1
12/24/2020 01:00	1.3	13.2	1,978.3	1.0	7.90	1	1	1
12/24/2020 02:00	0.8	13.8	1,747.0	0.7	3.50	1	1	0
12/24/2020 03:00	0.9	13.5	1,844.1	0.7	5.50	1	1	1
12/24/2020 04:00	1.0	13.3	1,949.1	0.8	5.80	1	1	1
12/24/2020 05:00	1.3	13.2	1,954.0	1.0	7.80	1	1	1
12/24/2020 06:00	0.6	13.8	1,703.4	0.5	3.40	1	1	0
12/24/2020 07:00	0.5	13.8	1,693.7	0.4	3.40	1	1	0
12/24/2020 08:00	0.5	13.8	1,689.7	0.4	3.40	1	1	0
12/24/2020 09:00	1.1	13.3	1,937.8	0.9	5.80	1	1	1
12/24/2020 10:00	1.4	12.9	2,006.5	1.0	8.00	1	1	1
12/24/2020 11:00	0.6	13.9	1,642.4	0.5	3.30	1	1	0
12/24/2020 12:00	0.6	13.9	1,641.4	0.5	3.30	1	1	0
12/24/2020 13:00	0.6	13.9	1,670.1	0.5	3.30	1	1	0
12/24/2020 14:00	0.7	13.9	1,692.8	0.6	3.40	1	1	0
12/24/2020 15:00	1.0	13.5	1,806.6	0.8	5.40	1	1	1
12/24/2020 16:00	1.5	12.7	2,053.1	1.1	8.20	1	1	1
12/24/2020 17:00	1.5	12.5	2,116.6	1.1	8.50	1	1	1
12/24/2020 18:00	1.5	12.4	2,142.9	1.0	8.60	1	1	1
12/24/2020 19:00	1.5	12.4	2,139.8	1.0	8.60	1	1	1
12/24/2020 20:00	1.6	12.3	2,157.7	1.1	8.60	1	1	1
12/24/2020 21:00	1.5	12.5	2,113.2	1.1	8.50	1	1	1
12/24/2020 22:00	1.5	12.5	2,133.4	1.1	8.50	1	1	1
12/24/2020 23:00	1.5	12.7	2,082.7	1.1	8.30	1	1	1
Average/Sum#:	1.1	13.2	1,914.5	0.8	149.20 #	24 #	24 #	16 #
Minimum:	0.5	12.3	1,641.4	0.4	3.30	1	1	0
Maximum:	1.6	13.9	2,157.7	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	1.5	12.7	2,065.4	1.1	8.30	1	1	1
12/25/2020 01:00	1.5	12.7	2,060.2	1.1	8.20	1	1	1
12/25/2020 02:00	1.4	12.8	2,005.4	1.0	8.00	1	1	1
12/25/2020 03:00	0.7	13.8	1,696.4	0.6	3.40	1	1	0
12/25/2020 04:00	0.9	13.5	1,836.1	0.7	5.50	1	1	1
12/25/2020 05:00	1.5	12.8	2,046.1	1.1	8.20	1	1	1
12/25/2020 06:00	1.3	12.9	2,020.5	1.0	8.10	1	1	1
12/25/2020 07:00	0.6	13.8	1,657.6	0.5	3.30	1	1	0
12/25/2020 08:00	0.5	13.8	1,622.8	0.4	3.20	1	1	0
12/25/2020 09:00	0.6	13.8	1,620.7	0.5	3.20	1	1	0
12/25/2020 10:00	0.6	13.8	1,597.4	0.5	3.20	1	1	0
12/25/2020 11:00	0.6	13.8	1,680.1	0.5	3.40	1	1	0
12/25/2020 12:00	0.6	13.8	1,684.2	0.5	3.40	1	1	0
12/25/2020 13:00	0.6	13.8	1,681.5	0.5	3.40	1	1	0
12/25/2020 14:00	0.6	13.8	1,636.4	0.5	3.30	1	1	0
12/25/2020 15:00	0.7	13.8	1,728.5	0.6	3.50	1	1	1
12/25/2020 16:00	1.3	12.8	2,021.9	0.9	6.10	1	1	1
12/25/2020 17:00	1.6	12.5	2,071.8	1.1	8.30	1	1	1
12/25/2020 18:00	1.5	12.6	2,042.2	1.1	8.20	1	1	1
12/25/2020 19:00	1.5	12.4	2,080.7	1.0	8.30	1	1	1
12/25/2020 20:00	1.4	13.0	1,938.1	1.0	7.80	1	1	1
12/25/2020 21:00	0.7	13.8	1,700.8	0.6	3.40	1	1	0
12/25/2020 22:00	1.0	13.5	1,818.3	0.8	5.50	1	1	1
12/25/2020 23:00	1.4	13.1	1,942.2	1.1	7.80	1	1	1
Average/Sum#:	1.0	13.3	1,844.0	0.8	135.00 #	24 #	24 #	14 #
Minimum:	0.5	12.4	1,597.4	0.4	3.20	1	1	0
Maximum:	1.6	13.8	2,080.7	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2020 00:00	1.5	12.7	2,023.3	1.1	8.10	1	1	1
12/26/2020 01:00	1.3	13.1	1,915.7	1.0	7.70	1	1	1
12/26/2020 02:00	0.7	13.8	1,691.0	0.6	3.40	1	1	0
12/26/2020 03:00	0.8	13.7	1,766.8	0.7	3.50	1	1	1
12/26/2020 04:00	1.4	12.7	2,028.1	1.0	8.10	1	1	1
12/26/2020 05:00	1.4	13.0	1,943.7	1.0	7.80	1	1	1
12/26/2020 06:00	0.7	13.9	1,697.0	0.6	3.40	1	1	0
12/26/2020 07:00	0.6	13.9	1,660.9	0.5	3.30	1	1	0
12/26/2020 08:00	0.5	13.9	1,609.1	0.4	3.20	1	1	0
12/26/2020 09:00	0.6	13.9	1,665.9	0.5	3.30	1	1	0
12/26/2020 10:00	0.5	13.9	1,566.2	0.4	3.10	1	1	0
12/26/2020 11:00	0.5	13.9	1,456.1	0.4	2.90	1	1	0
12/26/2020 12:00	0.6	13.9	1,580.6	0.5	3.20	1	1	0
12/26/2020 13:00	0.7	13.9	1,694.4	0.6	3.40	1	1	0
12/26/2020 14:00	0.6	13.9	1,668.8	0.5	3.30	1	1	0
12/26/2020 15:00	0.6	13.9	1,580.4	0.5	3.20	1	1	0
12/26/2020 16:00	0.8	13.7	1,686.2	0.7	3.40	1	1	1
12/26/2020 17:00	1.5	12.7	2,041.2	1.1	8.20	1	1	1
12/26/2020 18:00	1.4	13.0	1,980.8	1.0	7.90	1	1	1
12/26/2020 19:00	1.5	12.7	2,049.7	1.1	8.20	1	1	1
12/26/2020 20:00	1.5	12.7	2,061.0	1.1	8.20	1	1	1
12/26/2020 21:00	1.5	12.7	2,046.7	1.1	8.20	1	1	1
12/26/2020 22:00	1.5	12.6	2,070.7	1.1	8.30	1	1	1
12/26/2020 23:00	1.5	12.8	2,044.8	1.1	8.20	1	1	1
Average/Sum#:	1.0	13.4	1,813.7	0.8	131.50 #	24 #	24 #	13 #
Minimum:	0.5	12.6	1,456.1	0.4	2.90	1	1	0
Maximum:	1.5	13.9	2,070.7	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	1.5	12.8	2,042.5	1.1	8.20	1	1	1
12/27/2020 01:00	1.5	12.8	2,034.8	1.1	8.10	1	1	1
12/27/2020 02:00	1.2	13.2	1,922.2	0.9	5.80	1	1	1
12/27/2020 03:00	0.7	13.9	1,699.5	0.6	3.40	1	1	0
12/27/2020 04:00	0.8	13.7	1,724.1	0.7	3.40	1	1	1
12/27/2020 05:00	1.4	12.7	2,045.8	1.0	8.20	1	1	1
12/27/2020 06:00	1.4	12.8	2,041.2	1.0	8.20	1	1	1
12/27/2020 07:00	0.6	13.8	1,687.8	0.5	3.40	1	1	1
12/27/2020 08:00	0.6	13.9	1,686.7	0.5	3.40	1	1	0
12/27/2020 09:00	0.5	13.8	1,657.2	0.4	3.30	1	1	0
12/27/2020 10:00	0.5	13.9	1,607.2	0.4	3.20	1	1	0
12/27/2020 11:00	0.6	13.9	1,640.6	0.5	3.30	1	1	0
12/27/2020 12:00	0.7	13.9	1,688.8	0.6	3.40	1	1	0
12/27/2020 13:00	0.5	13.9	1,610.7	0.4	3.20	1	1	0
12/27/2020 14:00	0.6	13.9	1,689.7	0.5	3.40	1	1	0
12/27/2020 15:00	0.7	13.7	1,725.7	0.6	3.50	1	1	1
12/27/2020 16:00	1.4	12.7	2,059.0	1.0	8.20	1	1	1
12/27/2020 17:00	1.6	12.4	2,129.0	1.1	8.50	1	1	1
12/27/2020 18:00	1.6	12.3	2,142.0	1.1	8.60	1	1	1
12/27/2020 19:00	1.6	12.0	2,193.5	1.1	8.80	1	1	1
12/27/2020 20:00	1.5	12.3	2,090.1	1.0	8.40	1	1	1
12/27/2020 21:00	0.7	13.9	1,701.7	0.6	3.40	1	1	0
12/27/2020 22:00	1.0	13.4	1,846.1	0.8	5.50	1	1	1
12/27/2020 23:00	1.5	12.5	2,082.5	1.1	8.30	1	1	1
Average/Sum#:	1.0	13.3	1,864.5	0.8	135.10 #	24 #	24 #	15 #
Minimum:	0.5	12.0	1,607.2	0.4	3.20	1	1	0
Maximum:	1.6	13.9	2,193.5	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	1.4	12.9	1,972.7	1.0	7.90	1	1	1
12/28/2020 01:00	0.6	13.9	1,650.3	0.5	3.30	1	1	0
12/28/2020 02:00	1.0	13.4	1,841.9	0.8	5.50	1	1	1
12/28/2020 03:00	1.5	12.6	2,036.9	1.1	8.10	1	1	1
12/28/2020 04:00	1.4	13.0	1,928.0	1.0	7.70	1	1	1
12/28/2020 05:00	0.7	13.9	1,703.3	0.6	3.40	1	1	0
12/28/2020 06:00	1.2	13.2	1,835.1	0.9	5.50	1	1	1
12/28/2020 07:00	1.5	12.2	2,161.4	1.0	8.60	1	1	1
12/28/2020 08:00	1.6	12.3	2,134.6	1.1	8.50	1	1	1
12/28/2020 09:00	1.4	12.8	2,000.0	1.0	8.00	1	1	1
12/28/2020 10:00	0.7	13.9	1,662.9	0.6	3.30	1	1	0
12/28/2020 11:00	0.6	13.9	1,676.9	0.5	3.40	1	1	0
12/28/2020 12:00	0.6	13.9	1,694.7	0.5	3.40	1	1	0
12/28/2020 13:00	0.6	13.9	1,673.6	0.5	3.30	1	1	0
12/28/2020 14:00	0.6	13.9	1,694.0	0.5	3.40	1	1	0
12/28/2020 15:00	0.9	13.5	1,773.6	0.7	5.30	1	1	1
12/28/2020 16:00	1.4	12.7	2,020.7	1.0	8.10	1	1	1
12/28/2020 17:00	1.6	12.0	2,195.4	1.1	8.80	1	1	1
12/28/2020 18:00	1.6	12.0	2,197.0	1.1	8.80	1	1	1
12/28/2020 19:00	1.6	12.0	2,202.8	1.1	8.80	1	1	1
12/28/2020 20:00	1.6	12.0	2,200.8	1.1	8.80	1	1	1
12/28/2020 21:00	1.6	12.1	2,184.9	1.1	8.70	1	1	1
12/28/2020 22:00	1.6	12.2	2,159.8	1.1	8.60	1	1	1
12/28/2020 23:00	1.5	12.4	2,112.0	1.0	8.40	1	1	1
Average/Sum#:	1.2	12.9	1,946.4	0.9	157.60 #	24 #	24 #	17 #
Minimum:	0.6	12.0	1,650.3	0.5	3.30	1	1	0
Maximum:	1.6	13.9	2,202.8	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	NOx, Ppmvdc	NOx, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	1.5	12.5	2,106.8	1.1	8.40	1	1	1
12/29/2020 01:00	1.5	12.6	2,041.2	1.1	8.20	1	1	1
12/29/2020 02:00	0.7	13.9	1,706.4	0.6	3.40	1	1	0
12/29/2020 03:00	0.9	13.5	1,837.2	0.7	5.50	1	1	1
12/29/2020 04:00	1.5	12.6	2,096.6	1.1	8.40	1	1	1
12/29/2020 05:00	1.5	12.5	2,115.5	1.1	8.50	1	1	1
12/29/2020 06:00	1.5	12.1	2,212.1	1.0	8.80	1	1	1
12/29/2020 07:00	1.6	12.2	2,182.9	1.1	8.70	1	1	1
12/29/2020 08:00	1.5	12.3	2,161.5	1.0	8.60	1	1	1
12/29/2020 09:00	1.0	13.4	1,790.9	0.8	5.40	1	1	1
12/29/2020 10:00	0.6	13.9	1,683.9	0.5	3.40	1	1	0
12/29/2020 11:00	0.6	13.9	1,669.1	0.5	3.30	1	1	0
12/29/2020 12:00	0.6	13.9	1,694.9	0.5	3.40	1	1	0
12/29/2020 13:00	0.6	14.0	1,649.5	0.5	3.30	1	1	0
12/29/2020 14:00	0.6	14.0	1,679.9	0.5	3.40	1	1	0
12/29/2020 15:00	0.6	14.0	1,673.6	0.5	3.30	1	1	0
12/29/2020 16:00	0.7	13.8	1,698.0	0.6	3.40	1	1	1
12/29/2020 17:00	1.5	12.4	2,122.8	1.0	8.50	1	1	1
12/29/2020 18:00	1.5	12.0	2,201.4	1.0	8.80	1	1	1
12/29/2020 19:00	1.5	12.0	2,200.4	1.0	8.80	1	1	1
12/29/2020 20:00	1.5	12.4	2,128.6	1.0	8.50	1	1	1
12/29/2020 21:00	1.4	12.6	2,073.1	1.0	8.30	1	1	1
12/29/2020 22:00	1.5	12.6	2,078.1	1.1	8.30	1	1	1
12/29/2020 23:00	1.4	12.8	2,038.4	1.0	8.20	1	1	1
Average/Sum#:	1.2	13.0	1,951.8	0.8	156.80 #	24 #	24 #	17 #
Minimum:	0.6	12.0	1,649.5	0.5	3.30	1	1	0
Maximum:	1.6	14.0	2,212.1	1.1	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2020 00:00	1.5	12.9	2,032.1	1.1	8.10	1	1	1
12/30/2020 01:00	1.1	13.3	1,929.1	0.9	5.80	1	1	1
12/30/2020 02:00	0.6	13.9	1,692.9	0.5	3.40	1	1	0
12/30/2020 03:00	0.7	13.7	1,722.2	0.6	3.40	1	1	1
12/30/2020 04:00	1.4	13.1	2,016.7	1.1	8.10	1	1	1
12/30/2020 05:00	1.4	12.9	2,046.3	1.0	8.20	1	1	1
12/30/2020 06:00	1.4	12.4	2,160.1	1.0	8.60	1	1	1
12/30/2020 07:00	1.4	12.8	2,068.2	1.0	8.30	1	1	1
12/30/2020 08:00	1.5	13.0	2,029.7	1.1	8.10	1	1	1
12/30/2020 09:00	1.2	13.2	1,945.2	0.9	5.80	1	1	1
12/30/2020 10:00	0.7	13.8	1,705.8	0.6	3.40	1	1	0
12/30/2020 11:00	0.6	13.9	1,693.0	0.5	3.40	1	1	0
12/30/2020 12:00	0.6	13.9	1,689.5	0.5	3.40	1	1	0
12/30/2020 13:00	0.6	13.9	1,647.2	0.5	3.30	1	1	0
12/30/2020 14:00	0.6	13.9	1,645.9	0.5	3.30	1	1	0
12/30/2020 15:00	0.7	13.7	1,721.3	0.6	3.40	1	1	1
12/30/2020 16:00	1.4	12.9	2,020.7	1.0	8.10	1	1	1
12/30/2020 17:00	1.5	12.4	2,112.9	1.0	8.50	1	1	1
12/30/2020 18:00	1.5	12.4	2,102.7	1.0	8.40	1	1	1
12/30/2020 19:00	1.5	12.7	2,045.4	1.1	8.20	1	1	1
12/30/2020 20:00	1.5	12.6	2,063.7	1.1	8.30	1	1	1
12/30/2020 21:00	1.5	12.6	2,055.0	1.1	8.20	1	1	1
12/30/2020 22:00	1.5	12.7	2,032.2	1.1	8.10	1	1	1
12/30/2020 23:00	1.5	12.8	2,021.0	1.1	8.10	1	1	1
Average/Sum#:	1.2	13.1	1,925.0	0.9	153.90 #	24 #	24 #	18 #
Minimum:	0.6	12.4	1,645.9	0.5	3.30	1	1	0
Maximum:	1.5	13.9	2,160.1	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:54 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2020 00:00	1.1	13.2	1,919.8	0.8	5.80	1	1	1
12/31/2020 01:00	0.6	13.8	1,625.6	0.5	3.30	1	1	0
12/31/2020 02:00	0.9	13.5	1,823.7	0.7	5.50	1	1	1
12/31/2020 03:00	1.1	13.2	1,946.0	0.8	5.80	1	1	1
12/31/2020 04:00	1.1	13.2	1,929.3	0.8	5.80	1	1	1
12/31/2020 05:00	0.7	13.8	1,696.0	0.6	3.40	1	1	0
12/31/2020 06:00	0.6	13.8	1,691.7	0.5	3.40	1	1	0
12/31/2020 07:00	0.6	13.8	1,646.2	0.5	3.30	1	1	0
12/31/2020 08:00	0.5	13.8	1,598.0	0.4	3.20	1	1	0
12/31/2020 09:00	0.6	13.8	1,664.9	0.5	3.30	1	1	0
12/31/2020 10:00	0.6	13.9	1,689.3	0.5	3.40	1	1	0
12/31/2020 11:00	0.7	13.9	1,686.4	0.6	3.40	1	1	0
12/31/2020 12:00	0.6	13.9	1,652.5	0.5	3.30	1	1	0
12/31/2020 13:00	0.6	13.9	1,645.1	0.5	3.30	1	1	0
12/31/2020 14:00	0.6	13.9	1,652.9	0.5	3.30	1	1	0
12/31/2020 15:00	0.6	13.9	1,701.0	0.5	3.40	1	1	0
12/31/2020 16:00	0.9	13.4	1,822.2	0.7	5.50	1	1	1
12/31/2020 17:00	1.5	12.6	2,061.0	1.1	8.20	1	1	1
12/31/2020 18:00	1.6	12.4	2,100.4	1.1	8.40	1	1	1
12/31/2020 19:00	1.6	12.5	2,100.9	1.1	8.40	1	1	1
12/31/2020 20:00	1.5	12.5	2,100.4	1.1	8.40	1	1	1
12/31/2020 21:00	1.5	12.5	2,098.9	1.1	8.40	1	1	1
12/31/2020 22:00	1.5	12.6	2,097.5	1.1	8.40	1	1	1
12/31/2020 23:00	1.5	12.7	2,066.9	1.1	8.30	1	1	1
Average/Sum#:	1.0	13.4	1,834.0	0.7	126.90 #	24 #	24 #	12 #
Minimum:	0.5	12.4	1,598.0	0.4	3.20	1	1	0
Maximum:	1.6	13.9	2,100.9	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	0.0	13.9	1,632.6	0.4	0.0	1	1	0
10/01/2020 01:00	0.3	13.3	1,798.6	0.3	0.9	1	1	1
10/01/2020 02:00	0.5	12.5	1,987.6	0.2	1.6	1	1	1
10/01/2020 03:00	0.4	12.3	1,996.0	0.3	1.2	1	1	1
10/01/2020 04:00	0.0	13.9	1,666.5	0.2	0.0	1	1	0
10/01/2020 05:00	0.9	13.0	1,822.9	0.3	2.7	1	1	1
10/01/2020 06:00	1.0	12.3	2,073.1	0.5	3.2	1	1	1
10/01/2020 07:00	0.8	13.1	1,809.7	0.7	2.5	1	1	1
10/01/2020 08:00	0.0	13.9	1,560.8	0.4	0.0	1	1	0
10/01/2020 09:00	0.0	14.1	1,327.1	0.2	0.0	1	1	0
10/01/2020 10:00	0.0	14.0	1,516.1	0.0	0.0	1	1	1
10/01/2020 11:00	0.9	12.3	2,062.7	0.2	2.9	1	1	1
10/01/2020 12:00	0.8	11.8	2,142.6	0.4	2.5	1	1	1
10/01/2020 13:00	0.7	11.6	2,180.8	0.5	2.2	1	1	1
10/01/2020 14:00	0.7	11.5	2,191.1	0.4	2.2	1	1	1
10/01/2020 15:00	0.7	11.6	2,163.3	0.4	2.2	1	1	1
10/01/2020 16:00	0.8	11.7	2,144.3	0.4	2.5	1	1	1
10/01/2020 17:00	0.8	11.7	2,138.3	0.5	2.5	1	1	1
10/01/2020 18:00	0.9	11.9	2,110.4	0.5	2.8	1	1	1
10/01/2020 19:00	0.8	11.9	2,114.7	0.5	2.5	1	1	1
10/01/2020 20:00	0.8	11.9	2,113.2	0.5	2.5	1	1	1
10/01/2020 21:00	0.8	11.9	2,119.0	0.5	2.5	1	1	1
10/01/2020 22:00	0.9	12.1	2,094.3	0.5	2.8	1	1	1
10/01/2020 23:00	0.9	12.4	2,011.9	0.6	2.8	1	1	1
Average/Sum#:	0.6	12.5	1,949.1	0.4	45.0 #	24 #	24 #	20 #
Minimum:	0.0	11.5	1,327.1	0.0	0.0	1	1	0
Maximum:	1.0	14.1	2,191.1	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	0.0	13.9	1,589.6	0.4	0.0	1	1	0
10/02/2020 01:00	0.0	13.9	1,707.3	0.2	0.0	1	1	0
10/02/2020 02:00	0.1	13.9	1,553.1	0.0	0.3	1	1	0
10/02/2020 03:00	0.1	13.9	1,596.2	0.1	0.3	1	1	0
10/02/2020 04:00	0.5	13.6	1,682.9	0.2	1.5	1	1	1
10/02/2020 05:00	1.0	12.3	2,058.4	0.4	3.2	1	1	1
10/02/2020 06:00	1.0	12.5	2,014.7	0.6	3.2	1	1	1
10/02/2020 07:00	0.0	13.8	1,771.1	0.5	0.0	1	1	0
10/02/2020 08:00	0.1	13.9	1,477.5	0.3	0.3	1	1	0
10/02/2020 09:00	0.0	14.0	1,595.2	0.0	0.0	1	1	0
10/02/2020 10:00	0.0	14.0	1,627.9	0.0	0.0	1	1	0
10/02/2020 11:00	0.2	13.6	1,694.5	0.1	0.6	1	1	1
10/02/2020 12:00	0.9	11.9	2,126.7	0.3	2.8	1	1	1
10/02/2020 13:00	0.7	11.5	2,205.8	0.4	2.2	1	1	1
10/02/2020 14:00	0.7	11.4	2,203.7	0.5	2.1	1	1	1
10/02/2020 15:00	0.7	11.5	2,182.9	0.4	2.1	1	1	1
10/02/2020 16:00	0.7	11.5	2,184.2	0.4	2.1	1	1	1
10/02/2020 17:00	0.7	11.4	2,193.0	0.4	2.1	1	1	1
10/02/2020 18:00	0.7	11.7	2,153.3	0.4	2.2	1	1	1
10/02/2020 19:00	0.8	11.8	2,130.0	0.4	2.5	1	1	1
10/02/2020 20:00	0.8	11.7	2,159.8	0.5	2.5	1	1	1
10/02/2020 21:00	0.9	12.2	2,074.6	0.5	2.8	1	1	1
10/02/2020 22:00	0.9	12.1	2,092.5	0.6	2.8	1	1	1
10/02/2020 23:00	0.9	12.0	2,105.5	0.6	2.8	1	1	1
Average/Sum#:	0.5	12.7	1,924.2	0.3	38.4 #	24 #	24 #	16 #
Minimum:	0.0	11.4	1,477.5	0.0	0.0	1	1	0
Maximum:	1.0	14.0	2,205.8	0.6	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	7.7	14.0	1,271.8	0.0	9.4	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 08:00	17.7	18.1	388.1	0.0	12.0	1	0	0
10/03/2020 09:00	30.7	15.0	979.6	0.0	67.3	1	0	0
10/03/2020 10:00	0.0	14.0	1,391.9	0.0	0.0	1	0	0
10/03/2020 11:00	0.0	14.0	1,363.8	0.0	0.0	1	0	0
10/03/2020 12:00	0.0	13.9	1,608.4	0.0	0.0	1	0	0
10/03/2020 13:00	0.0	14.0	1,481.9	0.0	0.0	1	0	0
10/03/2020 14:00	0.0	13.9	1,640.7	0.0	0.0	1	1	0
10/03/2020 15:00	0.3	13.5	1,661.9	0.1	0.9	1	1	1
10/03/2020 16:00	0.9	11.8	2,108.5	0.3	2.8	1	1	1
10/03/2020 17:00	0.7	11.4	2,193.9	0.4	2.1	1	1	1
10/03/2020 18:00	0.7	11.5	2,181.0	0.5	2.1	1	1	1
10/03/2020 19:00	0.7	11.6	2,184.6	0.4	2.2	1	1	1
10/03/2020 20:00	0.8	11.9	2,117.9	0.4	2.5	1	1	1
10/03/2020 21:00	0.9	12.3	2,045.4	0.5	2.8	1	1	1
10/03/2020 22:00	5.6	13.8	1,460.5	0.0	11.4	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	4.2	13.4	1,630.0	0.3	115.5 #	16 #	8 #	9 #
Minimum:	0.0	11.4	388.1	0.0	0.0	0	0	0
Maximum:	30.7	18.1	2,193.9	0.5	67.3	1	1	1
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 09:00	32.1	16.9	544.9	0.0	54.9	1	0	0
10/04/2020 10:00	14.8	14.5	1,153.0	0.0	35.2	1	0	0
10/04/2020 11:00	0.0	14.0	1,372.4	0.0	0.0	1	0	0
10/04/2020 12:00	0.0	14.0	1,376.6	0.0	0.0	1	0	0
10/04/2020 13:00	0.0	13.9	1,610.8	0.0	0.0	1	0	0
10/04/2020 14:00	0.0	14.0	1,482.3	0.0	0.0	1	0	0
10/04/2020 15:00	0.0	13.8	1,712.8	0.0	0.0	1	1	0
10/04/2020 16:00	0.8	13.0	1,842.2	0.2	2.5	1	1	1
10/04/2020 17:00	0.9	11.8	2,123.7	0.4	2.8	1	1	1
10/04/2020 18:00	1.0	12.1	2,061.3	0.6	3.1	1	1	1
10/04/2020 19:00	1.0	12.2	2,055.2	0.7	3.1	1	1	1
10/04/2020 20:00	1.0	12.2	2,059.3	0.7	3.1	1	1	1
10/04/2020 21:00	0.9	12.1	2,086.7	0.7	2.8	1	1	1
10/04/2020 22:00	0.9	12.8	1,954.6	0.7	2.9	1	1	1
10/04/2020 23:00	1.0	12.9	1,923.1	0.7	3.2	1	1	1
Average/Sum#:	3.6	13.3	1,690.6	0.4	113.6 #	15 #	9 #	8 #
Minimum:	0.0	11.8	544.9	0.0	0.0	0	0	0
Maximum:	32.1	16.9	2,123.7	0.7	54.9	1	1	1
%SI	37.50	37.50	37.50	54.17	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	0.0	13.9	1,660.5	0.5	0.0	1	1	0
10/05/2020 01:00	0.1	13.9	1,650.0	0.3	0.3	1	1	0
10/05/2020 02:00	0.1	13.9	1,603.8	0.1	0.3	1	1	0
10/05/2020 03:00	0.0	14.0	1,580.0	0.1	0.0	1	1	0
10/05/2020 04:00	0.4	13.7	1,683.2	0.1	1.2	1	1	1
10/05/2020 05:00	1.1	12.3	2,061.7	0.4	3.5	1	1	1
10/05/2020 06:00	1.0	12.3	2,046.4	0.6	3.1	1	1	1
10/05/2020 07:00	0.0	13.9	1,551.7	0.5	0.0	1	1	0
10/05/2020 08:00	0.0	13.9	1,541.3	0.2	0.0	1	1	0
10/05/2020 09:00	0.0	14.0	1,597.6	0.0	0.0	1	1	0
10/05/2020 10:00	0.0	14.0	1,587.0	0.0	0.0	1	1	0
10/05/2020 11:00	0.0	13.9	1,651.5	0.0	0.0	1	1	0
10/05/2020 12:00	0.0	13.9	1,668.5	0.0	0.0	1	1	0
10/05/2020 13:00	0.5	13.2	1,816.3	0.1	1.6	1	1	1
10/05/2020 14:00	0.7	11.6	2,193.4	0.3	2.2	1	1	1
10/05/2020 15:00	0.7	11.4	2,208.7	0.4	2.1	1	1	1
10/05/2020 16:00	0.7	11.4	2,208.0	0.4	2.1	1	1	1
10/05/2020 17:00	0.7	11.6	2,183.1	0.4	2.2	1	1	1
10/05/2020 18:00	0.7	11.5	2,199.9	0.4	2.2	1	1	1
10/05/2020 19:00	0.8	12.1	2,079.1	0.4	2.5	1	1	1
10/05/2020 20:00	0.8	12.2	2,070.9	0.5	2.5	1	1	1
10/05/2020 21:00	0.9	12.2	2,075.3	0.5	2.8	1	1	1
10/05/2020 22:00	7.6	14.1	1,244.7	0.0	9.2	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.7	13.0	1,833.2	0.3	37.8 #	23 #	22 #	13 #
Minimum:	0.0	11.4	1,244.7	0.0	0.0	0	0	0
Maximum:	7.6	14.1	2,208.7	0.6	9.2	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 06:00	15.3	18.1	390.7	0.0	10.4	1	0	0
10/06/2020 07:00	17.9	15.8	831.8	0.0	38.6	1	0	0
10/06/2020 08:00	0.0	14.0	1,408.7	0.0	0.0	1	0	0
10/06/2020 09:00	0.0	14.0	1,385.6	0.0	0.0	1	0	0
10/06/2020 10:00	0.0	14.0	1,399.3	0.0	0.0	1	0	0
10/06/2020 11:00	0.0	14.0	1,640.7	0.0	0.0	1	0	0
10/06/2020 12:00	0.0	14.0	1,491.8	0.0	0.0	1	0	0
10/06/2020 13:00	0.0	13.9	1,653.6	0.0	0.0	1	1	0
10/06/2020 14:00	0.3	13.6	1,752.2	0.1	1.0	1	1	1
10/06/2020 15:00	0.9	11.8	2,133.8	0.3	2.8	1	1	1
10/06/2020 16:00	0.8	11.5	2,183.3	0.4	2.5	1	1	1
10/06/2020 17:00	0.7	11.4	2,200.7	0.5	2.1	1	1	1
10/06/2020 18:00	0.7	11.4	2,205.4	0.4	2.1	1	1	1
10/06/2020 19:00	0.7	11.6	2,175.9	0.4	2.2	1	1	1
10/06/2020 20:00	0.2	13.5	1,676.1	0.3	0.6	1	1	1
10/06/2020 21:00	0.6	13.2	1,824.6	0.4	1.9	1	1	1
10/06/2020 22:00	1.0	12.2	2,086.4	0.5	3.2	1	1	1
10/06/2020 23:00	1.0	12.6	1,996.7	0.6	3.2	1	1	1
Average/Sum#:	2.2	13.4	1,691.0	0.3	70.6 #	18 #	11 #	10 #
Minimum:	0.0	11.4	390.7	0.0	0.0	0	0	0
Maximum:	17.9	18.1	2,205.4	0.6	38.6	1	1	1
%SI	25.00	25.00	25.00	41.67	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	1.0	12.3	2,050.3	0.7	3.1	1	1	1
10/07/2020 01:00	1.0	12.6	1,980.4	0.7	3.2	1	1	1
10/07/2020 02:00	0.0	13.9	1,541.2	0.5	0.0	1	1	0
10/07/2020 03:00	0.0	14.0	1,606.7	0.2	0.0	1	1	0
10/07/2020 04:00	0.7	13.3	1,834.3	0.2	2.2	1	1	1
10/07/2020 05:00	1.1	12.0	2,118.8	0.4	3.5	1	1	1
10/07/2020 06:00	1.0	12.4	2,038.2	0.6	3.2	1	1	1
10/07/2020 07:00	0.1	13.9	1,602.9	0.5	0.3	1	1	0
10/07/2020 08:00	0.0	14.0	1,366.6	0.3	0.0	1	1	0
10/07/2020 09:00	0.0	14.0	1,301.4	0.0	0.0	1	1	0
10/07/2020 10:00	0.0	14.0	1,357.7	0.0	0.0	1	1	0
10/07/2020 11:00	0.5	13.3	1,796.0	0.1	1.6	1	1	1
10/07/2020 12:00	0.9	11.7	2,171.8	0.3	2.8	1	1	1
10/07/2020 13:00	0.8	11.5	2,183.5	0.5	2.5	1	1	1
10/07/2020 14:00	0.2	13.5	1,711.1	0.4	0.6	1	1	1
10/07/2020 15:00	0.6	13.1	1,798.7	0.4	1.8	1	1	1
10/07/2020 16:00	1.0	12.0	2,093.1	0.5	3.1	1	1	1
10/07/2020 17:00	0.9	11.6	2,163.2	0.6	2.8	1	1	1
10/07/2020 18:00	0.9	11.8	2,123.7	0.6	2.8	1	1	1
10/07/2020 19:00	0.9	12.1	2,052.4	0.6	2.8	1	1	1
10/07/2020 20:00	0.0	13.9	1,686.3	0.4	0.0	1	1	0
10/07/2020 21:00	0.6	13.2	1,827.0	0.4	1.9	1	1	1
10/07/2020 22:00	1.0	12.1	2,099.0	0.4	3.2	1	1	1
10/07/2020 23:00	7.7	14.0	1,254.1	0.0	8.9	1	0	1
Average/Sum#:	0.9	12.9	1,823.3	0.4	50.3 #	24 #	23 #	17 #
Minimum:	0.0	11.5	1,254.1	0.0	0.0	1	0	0
Maximum:	7.7	14.0	2,183.5	0.7	8.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	19 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/12/2020 12:00	58.6	17.7	447.5	0.0	75.7	1	1	0
10/12/2020 13:00	20.2	15.7	746.4	0.0	38.3	1	1	0
10/12/2020 14:00	0.0	14.0	1,575.2	0.0	0.0	1	1	0
10/12/2020 15:00	0.0	13.7	1,668.7	0.0	0.0	1	1	1
10/12/2020 16:00	0.9	12.3	2,046.9	0.0	2.8	1	1	1
10/12/2020 17:00	1.0	12.4	2,032.4	0.4	3.2	1	1	1
10/12/2020 18:00	1.0	12.5	2,017.0	0.7	3.2	1	1	1
10/12/2020 19:00	0.9	12.7	1,949.5	0.7	2.8	1	1	1
10/12/2020 20:00	0.0	13.8	1,762.1	0.4	0.0	1	1	0
10/12/2020 21:00	0.5	13.3	1,825.5	0.3	1.6	1	1	1
10/12/2020 22:00	0.9	12.5	2,015.6	0.3	2.9	1	1	1
10/12/2020 23:00	0.9	12.7	1,971.8	0.5	2.9	1	1	1
Average/Sum#:	7.1	13.6	1,671.6	0.5	133.4 #	12 #	24 #	8 #
Minimum:	0.0	12.3	447.5	0.3	0.0	0	1	0
Maximum:	58.6	17.7	2,046.9	0.7	75.7	1	1	1
%SI	50.00	50.00	50.00	70.83	50.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	0.0	13.9	1,671.5	0.4	0.0	1	1	0
10/13/2020 01:00	0.0	13.9	1,624.8	0.2	0.0	1	1	0
10/13/2020 02:00	0.0	14.0	1,396.7	0.0	0.0	1	1	0
10/13/2020 03:00	0.0	14.0	1,603.9	0.0	0.0	1	1	0
10/13/2020 04:00	0.4	13.4	1,820.6	0.1	1.3	1	1	1
10/13/2020 05:00	0.9	12.7	2,000.2	0.3	2.9	1	1	1
10/13/2020 06:00	0.9	12.9	1,944.4	0.5	2.9	1	1	1
10/13/2020 07:00	0.0	13.9	1,653.3	0.4	0.0	1	1	0
10/13/2020 08:00	0.0	13.9	1,487.9	0.2	0.0	1	1	0
10/13/2020 09:00	0.0	14.0	1,351.7	0.0	0.0	1	1	0
10/13/2020 10:00	0.0	13.9	1,622.3	0.0	0.0	1	1	0
10/13/2020 11:00	0.0	13.9	1,501.7	0.0	0.0	1	1	0
10/13/2020 12:00	0.0	13.9	1,502.6	0.0	0.0	1	1	0
10/13/2020 13:00	0.0	14.0	1,407.8	0.0	0.0	1	1	0
10/13/2020 14:00	0.0	13.9	1,611.8	0.0	0.0	1	1	0
10/13/2020 15:00	0.2	13.6	1,663.6	0.1	0.6	1	1	1
10/13/2020 16:00	0.9	12.3	2,056.4	0.3	2.8	1	1	1
10/13/2020 17:00	0.8	12.2	2,073.0	0.4	2.5	1	1	1
10/13/2020 18:00	0.8	12.3	2,045.1	0.5	2.5	1	1	1
10/13/2020 19:00	0.8	12.6	1,974.4	0.5	2.5	1	1	1
10/13/2020 20:00	0.0	13.9	1,708.1	0.4	0.0	1	1	0
10/13/2020 21:00	0.4	13.4	1,822.4	0.3	1.3	1	1	1
10/13/2020 22:00	0.7	12.0	2,134.7	0.3	2.2	1	1	1
10/13/2020 23:00	0.7	12.7	1,961.5	0.4	2.2	1	1	1
Average/Sum#:	0.3	13.4	1,735.0	0.2	23.7 #	24 #	24 #	11 #
Minimum:	0.0	12.0	1,351.7	0.0	0.0	1	1	0
Maximum:	0.9	14.0	2,134.7	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	0.0	13.9	1,679.7	0.3	0.0	1	1	0
10/14/2020 01:00	0.1	13.7	1,681.9	0.2	0.3	1	1	1
10/14/2020 02:00	0.7	12.2	2,076.5	0.2	2.2	1	1	1
10/14/2020 03:00	0.7	12.7	1,951.4	0.4	2.2	1	1	1
10/14/2020 04:00	0.0	13.9	1,607.4	0.3	0.0	1	1	0
10/14/2020 05:00	0.8	13.0	1,827.4	0.4	2.4	1	1	1
10/14/2020 06:00	0.8	12.5	2,025.0	0.4	2.5	1	1	1
10/14/2020 07:00	0.0	0.0	1,931.7	0.0	0.0	1	1	1
10/14/2020 08:00	0.3	13.9	1,419.2	0.0	0.8	1	1	0
10/14/2020 09:00	0.3	14.0	1,311.0	0.0	0.8	1	1	0
10/14/2020 10:00	0.3	13.9	1,545.8	0.3	0.9	1	1	0
10/14/2020 11:00	1.2	12.3	1,786.5	0.5	3.3	1	1	1
10/14/2020 12:00	1.2	12.1	2,162.9	0.6	3.9	1	1	1
10/14/2020 13:00	1.0	11.5	2,210.4	0.7	3.1	1	1	1
10/14/2020 14:00	1.0	12.6	1,766.5	0.7	2.8	1	1	1
10/14/2020 15:00	1.3	12.5	1,842.7	0.7	3.8	1	1	1
10/14/2020 16:00	1.2	11.8	2,147.2	0.8	3.7	1	1	1
10/14/2020 17:00	1.0	11.4	2,222.3	0.8	3.1	1	1	1
10/14/2020 18:00	1.1	11.8	2,139.1	0.7	3.4	1	1	1
10/14/2020 19:00	1.1	11.9	2,089.3	0.7	3.4	1	1	1
10/14/2020 20:00	0.4	13.8	1,694.2	0.6	1.3	1	1	0
10/14/2020 21:00	0.9	13.1	1,854.6	0.6	2.8	1	1	1
10/14/2020 22:00	1.1	11.7	2,179.8	0.6	3.4	1	1	1
10/14/2020 23:00	1.2	12.4	2,016.1	0.7	3.8	1	1	1
Average/Sum#:	0.8	12.7	1,882.0	0.5	53.9 #	24 #	24 #	18 #
Minimum:	0.0	11.4	1,311.0	0.2	0.0	1	1	0
Maximum:	1.3	14.0	2,222.3	0.8	3.9	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	0.4	13.8	1,684.8	0.6	1.3	1	1	0
10/15/2020 01:00	0.9	13.3	1,820.4	0.6	2.8	1	1	1
10/15/2020 02:00	1.3	11.9	2,148.2	0.6	4.1	1	1	1
10/15/2020 03:00	1.3	12.0	2,097.9	0.8	4.0	1	1	1
10/15/2020 04:00	0.5	13.8	1,701.3	0.7	1.6	1	1	0
10/15/2020 05:00	1.3	12.9	1,839.4	0.8	3.9	1	1	1
10/15/2020 06:00	1.4	12.2	2,079.6	0.8	4.4	1	1	1
10/15/2020 07:00	1.1	12.7	1,868.9	0.9	3.3	1	1	1
10/15/2020 08:00	0.4	14.0	1,309.4	0.7	1.0	1	1	0
10/15/2020 09:00	0.3	14.0	1,305.4	0.5	0.7	1	1	0
10/15/2020 10:00	0.3	14.0	1,323.7	0.3	0.8	1	1	0
10/15/2020 11:00	0.4	13.8	1,576.9	0.3	1.2	1	1	0
10/15/2020 12:00	0.5	13.8	1,651.4	0.3	1.5	1	1	0
10/15/2020 13:00	1.0	13.1	1,832.0	0.5	3.1	1	1	1
10/15/2020 14:00	1.2	11.5	2,209.0	0.7	3.7	1	1	1
10/15/2020 15:00	1.1	11.4	2,223.9	0.8	3.4	1	1	1
10/15/2020 16:00	1.1	11.4	2,220.5	0.7	3.4	1	1	1
10/15/2020 17:00	1.1	11.5	2,198.0	0.7	3.4	1	1	1
10/15/2020 18:00	1.1	11.5	2,210.5	0.7	3.4	1	1	1
10/15/2020 19:00	1.1	11.6	2,184.8	0.7	3.4	1	1	1
10/15/2020 20:00	1.1	11.6	2,203.5	0.7	3.4	1	1	1
10/15/2020 21:00	1.1	11.5	2,223.1	0.7	3.4	1	1	1
10/15/2020 22:00	1.1	11.7	2,179.0	0.7	3.4	1	1	1
10/15/2020 23:00	1.2	12.2	2,052.8	0.7	3.7	1	1	1
Average/Sum#:	0.9	12.6	1,922.7	0.6	68.3 #	24 #	24 #	17 #
Minimum:	0.3	11.4	1,305.4	0.3	0.7	1	1	0
Maximum:	1.4	14.0	2,223.9	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	0.4	13.8	1,715.7	0.6	1.3	1	1	0
10/16/2020 01:00	0.4	14.0	1,320.2	0.5	1.0	1	1	0
10/16/2020 02:00	0.4	13.8	1,694.2	0.3	1.3	1	1	0
10/16/2020 03:00	1.0	13.2	1,839.3	0.5	3.2	1	1	1
10/16/2020 04:00	1.1	12.7	1,907.8	0.6	3.4	1	1	1
10/16/2020 05:00	0.7	13.4	1,714.5	0.7	2.1	1	1	1
10/16/2020 06:00	1.0	12.1	2,073.6	0.7	3.1	1	1	1
10/16/2020 07:00	1.2	12.7	1,970.7	0.7	3.8	1	1	1
10/16/2020 08:00	0.4	13.8	1,609.8	0.6	1.2	1	1	0
10/16/2020 09:00	0.4	14.0	1,403.9	0.5	1.1	1	1	0
10/16/2020 10:00	0.3	14.0	1,520.0	0.3	0.9	1	1	0
10/16/2020 11:00	0.6	13.6	1,601.7	0.4	1.7	1	1	1
10/16/2020 12:00	1.2	11.8	2,142.8	0.5	3.7	1	1	1
10/16/2020 13:00	1.2	11.9	2,110.6	0.7	3.7	1	1	1
10/16/2020 14:00	1.0	11.6	2,173.1	0.7	3.1	1	1	1
10/16/2020 15:00	1.0	11.5	2,183.0	0.7	3.1	1	1	1
10/16/2020 16:00	1.1	11.9	2,090.6	0.6	3.4	1	1	1
10/16/2020 17:00	1.1	11.8	2,140.0	0.7	3.4	1	1	1
10/16/2020 18:00	1.1	11.9	2,130.2	0.7	3.4	1	1	1
10/16/2020 19:00	1.0	11.5	2,200.5	0.7	3.1	1	1	1
10/16/2020 20:00	1.0	11.6	2,168.2	0.6	3.1	1	1	1
10/16/2020 21:00	1.1	11.8	2,136.6	0.6	3.4	1	1	1
10/16/2020 22:00	1.1	12.1	2,086.7	0.7	3.4	1	1	1
10/16/2020 23:00	1.2	12.3	2,040.6	0.7	3.8	1	1	1
Average/Sum#:	0.9	12.6	1,915.6	0.6	64.7 #	24 #	24 #	18 #
Minimum:	0.3	11.5	1,320.2	0.3	0.9	1	1	0
Maximum:	1.2	14.0	2,200.5	0.7	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	1.1	12.6	1,954.1	0.8	3.4	1	1	1
10/17/2020 01:00	0.4	13.8	1,562.9	0.6	1.2	1	1	0
10/17/2020 02:00	0.3	14.0	1,321.6	0.5	0.8	1	1	0
10/17/2020 03:00	0.3	13.9	1,620.7	0.3	0.9	1	1	0
10/17/2020 04:00	0.3	13.9	1,617.4	0.3	0.9	1	1	0
10/17/2020 05:00	0.3	13.9	1,670.8	0.3	0.9	1	1	0
10/17/2020 06:00	0.8	13.3	1,820.2	0.4	2.5	1	1	1
10/17/2020 07:00	1.0	12.9	1,866.3	0.5	3.1	1	1	1
10/17/2020 08:00	0.4	13.8	1,679.6	0.5	1.2	1	1	0
10/17/2020 09:00	0.4	13.8	1,682.9	0.4	1.3	1	1	0
10/17/2020 10:00	0.4	13.8	1,636.8	0.3	1.2	1	1	0
10/17/2020 11:00	0.4	13.8	1,493.0	0.3	1.1	1	1	0
10/17/2020 12:00	0.4	13.9	1,473.3	0.3	1.1	1	1	0
10/17/2020 13:00	0.3	14.0	1,463.4	0.3	0.8	1	1	0
10/17/2020 14:00	0.6	13.5	1,664.1	0.4	1.8	1	1	1
10/17/2020 15:00	1.1	11.8	2,127.5	0.5	3.4	1	1	1
10/17/2020 16:00	0.9	11.4	2,203.3	0.6	2.8	1	1	1
10/17/2020 17:00	0.9	11.4	2,207.1	0.6	2.8	1	1	1
10/17/2020 18:00	1.1	12.0	2,077.5	0.6	3.4	1	1	1
10/17/2020 19:00	1.1	12.0	2,106.0	0.7	3.4	1	1	1
10/17/2020 20:00	1.1	11.9	2,119.4	0.7	3.4	1	1	1
10/17/2020 21:00	1.1	12.4	2,018.8	0.7	3.5	1	1	1
10/17/2020 22:00	1.1	12.0	2,111.8	0.7	3.4	1	1	1
10/17/2020 23:00	1.1	12.0	2,107.6	0.7	3.4	1	1	1
Average/Sum#:	0.7	13.0	1,816.9	0.5	51.7 #	24 #	24 #	13 #
Minimum:	0.3	11.4	1,321.6	0.3	0.8	1	1	0
Maximum:	1.1	14.0	2,207.1	0.8	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	0.6	13.5	1,703.8	0.6	1.8	1	1	1
10/18/2020 01:00	0.8	13.1	1,837.0	0.6	2.5	1	1	1
10/18/2020 02:00	1.0	11.5	2,212.7	0.6	3.1	1	1	1
10/18/2020 03:00	1.0	11.8	2,136.2	0.6	3.1	1	1	1
10/18/2020 04:00	0.4	13.8	1,674.6	0.5	1.2	1	1	0
10/18/2020 05:00	0.4	13.8	1,609.1	0.4	1.2	1	1	0
10/18/2020 06:00	0.4	13.8	1,567.6	0.3	1.2	1	1	0
10/18/2020 07:00	0.5	13.9	1,512.7	0.3	1.4	1	1	0
10/18/2020 08:00	0.3	13.9	1,610.8	0.3	0.9	1	1	0
10/18/2020 09:00	0.3	13.9	1,617.4	0.3	0.9	1	1	0
10/18/2020 10:00	0.3	13.9	1,583.4	0.3	0.9	1	1	0
10/18/2020 11:00	0.3	13.9	1,614.7	0.3	0.9	1	1	0
10/18/2020 12:00	0.4	13.8	1,628.8	0.3	1.2	1	1	0
10/18/2020 13:00	0.4	13.8	1,606.8	0.3	1.2	1	1	0
10/18/2020 14:00	0.4	13.8	1,641.9	0.3	1.2	1	1	0
10/18/2020 15:00	1.0	13.2	1,795.2	0.5	3.1	1	1	1
10/18/2020 16:00	1.4	11.7	2,152.2	0.7	4.3	1	1	1
10/18/2020 17:00	0.6	13.5	1,725.4	0.7	1.8	1	1	1
10/18/2020 18:00	7.5	15.0	886.1	0.0	6.4	1	1	0
10/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/18/2020 21:00	12.3	17.9	397.4	0.0	9.7	1	1	0
10/18/2020 22:00	10.5	14.7	1,185.4	0.0	26.5	1	1	0
10/18/2020 23:00	0.8	13.2	1,825.1	0.0	2.5	1	1	1
Average/Sum#:	1.9	13.7	1,614.7	0.4	77.0 #	22 #	24 #	8 #
Minimum:	0.3	11.5	397.4	0.3	0.9	0	1	0
Maximum:	12.3	17.9	2,212.7	0.7	26.5	1	1	1
%SI	8.33	8.33	8.33	25.00	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	1.0	13.0	1,852.4	0.0	3.1	1	1	1
10/19/2020 01:00	0.4	13.8	1,636.1	0.5	1.2	1	1	0
10/19/2020 02:00	0.4	13.8	1,589.9	0.4	1.2	1	1	0
10/19/2020 03:00	0.4	13.8	1,690.0	0.3	1.3	1	1	0
10/19/2020 04:00	1.0	13.3	1,825.8	0.5	3.2	1	1	1
10/19/2020 05:00	1.2	12.0	2,129.1	0.6	3.8	1	1	1
10/19/2020 06:00	1.0	12.1	2,093.8	0.8	3.1	1	1	1
10/19/2020 07:00	0.4	13.8	1,696.5	0.6	1.3	1	1	0
10/19/2020 08:00	0.4	13.9	1,565.1	0.4	1.2	1	1	0
10/19/2020 09:00	0.4	13.8	1,632.5	0.3	1.2	1	1	0
10/19/2020 10:00	0.4	13.8	1,620.5	0.3	1.2	1	1	0
10/19/2020 11:00	0.3	13.9	1,589.6	0.3	0.9	1	1	0
10/19/2020 12:00	0.3	13.9	1,456.3	0.3	0.8	1	1	0
10/19/2020 13:00	0.3	14.0	1,431.0	0.3	0.8	1	1	0
10/19/2020 14:00	0.5	13.5	1,670.8	0.3	1.5	1	1	1
10/19/2020 15:00	1.1	12.2	2,053.8	0.5	3.4	1	1	1
10/19/2020 16:00	1.0	11.6	2,170.1	0.6	3.1	1	1	1
10/19/2020 17:00	0.9	11.4	2,212.3	0.6	2.8	1	1	1
10/19/2020 18:00	1.0	11.7	2,141.1	0.6	3.1	1	1	1
10/19/2020 19:00	0.9	11.5	2,195.9	0.6	2.8	1	1	1
10/19/2020 20:00	0.7	12.9	1,786.1	0.6	2.1	1	1	1
10/19/2020 21:00	0.8	13.2	1,814.9	0.6	2.5	1	1	1
10/19/2020 22:00	1.1	12.2	2,070.7	0.6	3.5	1	1	1
10/19/2020 23:00	1.1	12.8	1,944.0	0.7	3.5	1	1	1
Average/Sum#:	0.7	13.0	1,827.8	0.5	52.6 #	24 #	24 #	14 #
Minimum:	0.3	11.4	1,431.0	0.3	0.8	1	1	0
Maximum:	1.2	14.0	2,212.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	0.3	13.8	1,538.9	0.6	0.9	1	1	0
10/20/2020 01:00	0.3	14.0	1,294.8	0.4	0.7	1	1	0
10/20/2020 02:00	0.3	13.9	1,392.4	0.3	0.8	1	1	0
10/20/2020 03:00	0.8	13.4	1,808.3	0.4	2.5	1	1	1
10/20/2020 04:00	1.2	12.3	2,059.3	0.6	3.8	1	1	1
10/20/2020 05:00	1.1	12.1	2,088.8	0.7	3.4	1	1	1
10/20/2020 06:00	1.1	12.2	2,048.3	0.7	3.4	1	1	1
10/20/2020 07:00	0.4	13.8	1,666.9	0.6	1.2	1	1	0
10/20/2020 08:00	0.3	14.0	1,333.0	0.4	0.8	1	1	0
10/20/2020 09:00	0.3	13.9	1,463.2	0.3	0.8	1	1	0
10/20/2020 10:00	0.3	13.9	1,637.6	0.3	0.9	1	1	0
10/20/2020 11:00	0.6	13.5	1,721.8	0.4	1.8	1	1	1
10/20/2020 12:00	1.1	12.1	2,080.0	0.5	3.4	1	1	1
10/20/2020 13:00	1.0	11.9	2,081.8	0.6	3.1	1	1	1
10/20/2020 14:00	0.4	13.8	1,698.9	0.6	1.3	1	1	0
10/20/2020 15:00	0.8	12.9	1,844.3	0.5	2.4	1	1	1
10/20/2020 16:00	0.9	11.4	2,195.8	0.5	2.7	1	1	1
10/20/2020 17:00	1.0	11.6	2,156.0	0.6	3.1	1	1	1
10/20/2020 18:00	1.0	11.9	2,102.2	0.6	3.1	1	1	1
10/20/2020 19:00	1.1	12.2	2,037.0	0.7	3.4	1	1	1
10/20/2020 20:00	0.9	12.4	1,935.2	0.7	2.7	1	1	1
10/20/2020 21:00	0.6	13.4	1,752.1	0.6	1.9	1	1	1
10/20/2020 22:00	1.1	12.1	2,088.6	0.6	3.4	1	1	1
10/20/2020 23:00	1.0	11.6	2,166.5	0.6	3.1	1	1	1
Average/Sum#:	0.7	12.8	1,841.3	0.5	54.6 #	24 #	24 #	16 #
Minimum:	0.3	11.4	1,294.8	0.3	0.7	1	1	0
Maximum:	1.2	14.0	2,195.8	0.7	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	1.0	11.9	2,087.1	0.7	3.1	1	1	1
10/21/2020 01:00	0.3	13.8	1,695.0	0.5	0.9	1	1	0
10/21/2020 02:00	0.6	13.2	1,771.2	0.5	1.8	1	1	1
10/21/2020 03:00	1.0	11.7	2,176.8	0.4	3.1	1	1	1
10/21/2020 04:00	1.0	11.9	2,121.9	0.6	3.1	1	1	1
10/21/2020 05:00	1.1	12.4	2,049.5	0.7	3.5	1	1	1
10/21/2020 06:00	1.1	11.9	2,139.5	0.7	3.5	1	1	1
10/21/2020 07:00	0.4	13.7	1,557.2	0.6	1.1	1	1	1
10/21/2020 08:00	0.3	13.9	1,533.5	0.4	0.9	1	1	0
10/21/2020 09:00	0.3	13.9	1,362.4	0.3	0.8	1	1	0
10/21/2020 10:00	0.3	13.9	1,576.2	0.3	0.9	1	1	0
10/21/2020 11:00	0.3	13.9	1,529.3	0.3	0.9	1	1	0
10/21/2020 12:00	0.3	13.9	1,602.4	0.3	0.9	1	1	0
10/21/2020 13:00	0.6	13.5	1,687.3	0.4	1.8	1	1	1
10/21/2020 14:00	1.0	11.8	2,130.1	0.5	3.1	1	1	1
10/21/2020 15:00	1.1	12.0	2,073.2	0.6	3.4	1	1	1
10/21/2020 16:00	1.0	11.6	2,162.6	0.6	3.1	1	1	1
10/21/2020 17:00	0.9	11.4	2,197.7	0.6	2.7	1	1	1
10/21/2020 18:00	0.9	11.4	2,198.2	0.6	2.8	1	1	1
10/21/2020 19:00	1.0	11.7	2,153.5	0.6	3.1	1	1	1
10/21/2020 20:00	0.9	11.6	2,170.0	0.6	2.8	1	1	1
10/21/2020 21:00	0.8	11.8	2,108.9	0.6	2.4	1	1	1
10/21/2020 22:00	0.8	11.8	2,130.5	0.5	2.5	1	1	1
10/21/2020 23:00	0.9	12.2	2,030.6	0.5	2.8	1	1	1
Average/Sum#:	0.7	12.5	1,926.9	0.5	55.0 #	24 #	24 #	18 #
Minimum:	0.3	11.4	1,362.4	0.3	0.8	1	1	0
Maximum:	1.1	13.9	2,198.2	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	0.3	13.9	1,693.3	0.5	1.0	1	1	0
10/22/2020 01:00	0.7	13.2	1,828.3	0.5	2.2	1	1	1
10/22/2020 02:00	0.9	12.4	1,996.5	0.5	2.8	1	1	1
10/22/2020 03:00	0.9	12.5	1,968.2	0.6	2.8	1	1	1
10/22/2020 04:00	0.3	13.9	1,689.9	0.5	1.0	1	1	0
10/22/2020 05:00	1.0	13.0	1,767.7	0.5	3.0	1	1	1
10/22/2020 06:00	1.1	11.9	2,176.0	0.6	3.5	1	1	1
10/22/2020 07:00	1.0	12.0	2,099.5	0.7	3.1	1	1	1
10/22/2020 08:00	0.3	13.9	1,489.7	0.6	0.8	1	1	0
10/22/2020 09:00	0.3	13.9	1,589.5	0.4	0.9	1	1	0
10/22/2020 10:00	0.3	13.9	1,618.1	0.3	0.9	1	1	0
10/22/2020 11:00	0.9	13.3	1,829.4	0.4	2.9	1	1	1
10/22/2020 12:00	1.3	12.0	2,132.3	0.6	4.1	1	1	1
10/22/2020 13:00	1.3	12.5	1,999.9	0.8	4.1	1	1	1
10/22/2020 14:00	0.4	13.8	1,589.1	0.7	1.2	1	1	0
10/22/2020 15:00	0.8	13.6	1,685.4	0.6	2.4	1	1	1
10/22/2020 16:00	1.3	12.0	2,131.8	0.6	4.1	1	1	1
10/22/2020 17:00	1.2	11.9	2,144.5	0.8	3.8	1	1	1
10/22/2020 18:00	1.2	12.5	2,020.1	0.8	3.8	1	1	1
10/22/2020 19:00	1.3	12.2	2,090.3	0.8	4.1	1	1	1
10/22/2020 20:00	1.3	12.3	2,061.9	0.9	4.1	1	1	1
10/22/2020 21:00	1.2	12.4	2,062.5	0.9	3.8	1	1	1
10/22/2020 22:00	1.1	12.5	2,020.5	0.8	3.5	1	1	1
10/22/2020 23:00	0.9	12.6	1,969.7	0.7	2.8	1	1	1
Average/Sum#:	0.9	12.8	1,902.3	0.6	66.7 #	24 #	24 #	18 #
Minimum:	0.3	11.9	1,489.7	0.3	0.8	1	1	0
Maximum:	1.3	13.9	2,176.0	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	0.3	13.9	1,637.3	0.6	0.9	1	1	0
10/23/2020 01:00	0.7	13.3	1,817.5	0.5	2.2	1	1	1
10/23/2020 02:00	1.1	12.2	2,108.7	0.5	3.5	1	1	1
10/23/2020 03:00	1.2	12.6	2,003.8	0.7	3.8	1	1	1
10/23/2020 04:00	0.4	13.9	1,684.8	0.6	1.3	1	1	0
10/23/2020 05:00	1.0	13.1	1,826.2	0.7	3.1	1	1	1
10/23/2020 06:00	1.3	12.0	2,156.6	0.7	4.2	1	1	1
10/23/2020 07:00	1.2	12.2	2,114.2	0.8	3.9	1	1	1
10/23/2020 08:00	1.2	12.7	2,000.8	0.9	3.9	1	1	1
10/23/2020 09:00	0.5	13.6	1,717.0	0.7	1.6	1	1	1
10/23/2020 10:00	0.4	13.8	1,689.6	0.5	1.3	1	1	0
10/23/2020 11:00	0.5	13.7	1,737.8	0.4	1.6	1	1	1
10/23/2020 12:00	1.3	12.3	2,075.6	0.5	4.1	1	1	1
10/23/2020 13:00	1.1	12.7	1,962.9	0.7	3.5	1	1	1
10/23/2020 14:00	0.4	13.9	1,607.9	0.7	1.2	1	1	0
10/23/2020 15:00	0.6	13.6	1,751.8	0.5	1.9	1	1	1
10/23/2020 16:00	1.2	12.3	2,066.9	0.5	3.8	1	1	1
10/23/2020 17:00	1.1	12.0	2,119.8	0.7	3.5	1	1	1
10/23/2020 18:00	1.1	12.9	1,936.0	0.8	3.5	1	1	1
10/23/2020 19:00	0.4	13.8	1,701.4	0.6	1.3	1	1	0
10/23/2020 20:00	1.0	13.3	1,838.5	0.6	3.2	1	1	1
10/23/2020 21:00	1.3	12.3	2,067.8	0.7	4.1	1	1	1
10/23/2020 22:00	1.2	12.6	2,034.1	0.9	3.9	1	1	1
10/23/2020 23:00	1.1	12.1	2,131.9	0.8	3.5	1	1	1
Average/Sum#:	0.9	13.0	1,907.9	0.7	68.8 #	24 #	24 #	19 #
Minimum:	0.3	12.0	1,607.9	0.4	0.9	1	1	0
Maximum:	1.3	13.9	2,156.6	0.9	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:55 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	0.5	13.6	1,724.3	0.7	1.6	1	1	1
10/24/2020 01:00	0.4	13.8	1,694.2	0.5	1.3	1	1	0
10/24/2020 02:00	0.8	13.3	1,835.8	0.4	2.6	1	1	1
10/24/2020 03:00	1.1	12.2	2,111.6	0.5	3.5	1	1	1
10/24/2020 04:00	1.1	12.8	1,953.9	0.7	3.5	1	1	1
10/24/2020 05:00	0.4	13.8	1,680.8	0.6	1.3	1	1	0
10/24/2020 06:00	0.4	13.8	1,676.3	0.5	1.2	1	1	0
10/24/2020 07:00	0.4	13.8	1,631.4	0.3	1.2	1	1	0
10/24/2020 08:00	0.4	13.8	1,577.1	0.3	1.2	1	1	0
10/24/2020 09:00	0.4	13.8	1,622.2	0.3	1.2	1	1	0
10/24/2020 10:00	0.4	13.8	1,678.7	0.3	1.2	1	1	0
10/24/2020 11:00	0.4	13.8	1,637.4	0.3	1.2	1	1	0
10/24/2020 12:00	0.4	13.9	1,437.7	0.3	1.1	1	1	0
10/24/2020 13:00	0.4	13.9	1,433.0	0.3	1.1	1	1	0
10/24/2020 14:00	0.4	13.9	1,633.5	0.3	1.2	1	1	0
10/24/2020 15:00	0.4	13.9	1,698.1	0.3	1.3	1	1	0
10/24/2020 16:00	0.9	13.2	1,825.9	0.4	2.8	1	1	1
10/24/2020 17:00	1.4	11.9	2,136.8	0.6	4.4	1	1	1
10/24/2020 18:00	1.4	12.8	1,944.2	0.9	4.4	1	1	1
10/24/2020 19:00	0.5	13.8	1,700.8	0.8	1.6	1	1	0
10/24/2020 20:00	0.5	13.8	1,692.6	0.6	1.6	1	1	0
10/24/2020 21:00	1.1	13.3	1,817.8	0.6	3.5	1	1	1
10/24/2020 22:00	1.4	12.5	2,018.4	0.8	4.4	1	1	1
10/24/2020 23:00	1.1	12.6	1,968.0	0.9	3.4	1	1	1
Average/Sum#:	0.7	13.4	1,755.4	0.5	51.8 #	24 #	24 #	10 #
Minimum:	0.4	11.9	1,433.0	0.3	1.1	1	1	0
Maximum:	1.4	13.9	2,136.8	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	0.4	13.8	1,681.8	0.7	1.3	1	1	0
10/25/2020 01:00	0.4	13.8	1,669.3	0.5	1.2	1	1	0
10/25/2020 02:00	0.4	13.8	1,654.8	0.3	1.2	1	1	0
10/25/2020 03:00	0.4	13.8	1,653.7	0.3	1.2	1	1	0
10/25/2020 04:00	0.4	13.8	1,652.7	0.3	1.2	1	1	0
10/25/2020 05:00	0.4	13.8	1,628.9	0.3	1.2	1	1	0
10/25/2020 06:00	0.4	13.8	1,595.1	0.3	1.2	1	1	0
10/25/2020 07:00	0.4	13.8	1,619.8	0.3	1.2	1	1	0
10/25/2020 08:00	0.4	13.9	1,615.0	0.3	1.2	1	1	0
10/25/2020 09:00	0.4	13.9	1,564.9	0.3	1.2	1	1	0
10/25/2020 10:00	0.4	13.9	1,423.2	0.3	1.1	1	1	0
10/25/2020 11:00	0.4	14.0	1,352.0	0.3	1.0	1	1	0
10/25/2020 12:00	0.4	13.9	1,556.7	0.3	1.2	1	1	0
10/25/2020 13:00	0.4	13.9	1,606.2	0.3	1.2	1	1	0
10/25/2020 14:00	0.4	13.9	1,662.3	0.3	1.3	1	1	0
10/25/2020 15:00	0.4	14.0	1,613.3	0.3	1.2	1	1	0
10/25/2020 16:00	1.0	13.4	1,848.6	0.5	3.3	1	1	1
10/25/2020 17:00	1.5	12.5	2,084.2	0.7	4.9	1	1	1
10/25/2020 18:00	1.4	12.5	2,035.4	1.0	4.5	1	1	1
10/25/2020 19:00	0.4	13.9	1,672.5	0.8	1.3	1	1	0
10/25/2020 20:00	0.8	13.3	1,833.0	0.6	2.5	1	1	1
10/25/2020 21:00	1.0	12.0	2,171.6	0.5	3.2	1	1	1
10/25/2020 22:00	0.9	11.9	2,195.3	0.6	2.9	1	1	1
10/25/2020 23:00	0.8	11.7	2,239.9	0.6	2.6	1	1	1
Average/Sum#:	0.6	13.5	1,734.6	0.4	44.3 #	24 #	24 #	7 #
Minimum:	0.4	11.7	1,352.0	0.3	1.0	1	1	0
Maximum:	1.5	14.0	2,239.9	1.0	4.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	0.9	12.5	2,059.9	0.6	2.9	1	1	1
10/26/2020 01:00	0.9	12.9	1,990.9	0.6	3.0	1	1	1
10/26/2020 02:00	0.9	12.5	2,059.2	0.6	2.9	1	1	1
10/26/2020 03:00	0.3	13.8	1,690.7	0.5	0.9	1	1	1
10/26/2020 04:00	0.9	13.3	1,875.0	0.5	2.9	1	1	1
10/26/2020 05:00	1.0	11.9	2,169.8	0.5	3.2	1	1	1
10/26/2020 06:00	0.9	12.1	2,129.9	0.7	2.9	1	1	1
10/26/2020 07:00	0.3	13.8	1,789.8	0.5	1.0	1	1	0
10/26/2020 08:00	0.3	13.9	1,762.0	0.4	1.0	1	1	0
10/26/2020 09:00	0.3	13.9	1,750.1	0.3	1.0	1	1	0
10/26/2020 10:00	0.3	13.9	1,688.4	0.3	1.0	1	1	0
10/26/2020 11:00	0.3	14.0	1,389.8	0.3	0.8	1	1	0
10/26/2020 12:00	0.3	14.0	1,538.7	0.3	0.9	1	1	0
10/26/2020 13:00	0.3	14.0	1,515.7	0.3	0.9	1	1	0
10/26/2020 14:00	0.4	14.0	1,699.0	0.3	1.3	1	1	0
10/26/2020 15:00	0.3	14.0	1,651.4	0.3	0.9	1	1	0
10/26/2020 16:00	1.0	13.2	1,870.3	0.5	3.2	1	1	1
10/26/2020 17:00	1.4	12.0	2,186.7	0.7	4.5	1	1	1
10/26/2020 18:00	1.3	11.7	2,238.1	0.8	4.2	1	1	1
10/26/2020 19:00	1.3	12.3	2,111.9	0.9	4.2	1	1	1
10/26/2020 20:00	1.3	12.1	2,162.7	0.9	4.2	1	1	1
10/26/2020 21:00	1.3	12.2	2,127.1	0.9	4.2	1	1	1
10/26/2020 22:00	1.3	12.3	2,113.0	0.9	4.2	1	1	1
10/26/2020 23:00	1.2	12.4	2,082.3	0.9	3.9	1	1	1
Average/Sum#:	0.8	13.0	1,902.2	0.6	60.1 #	24 #	24 #	15 #
Minimum:	0.3	11.7	1,389.8	0.3	0.8	1	1	0
Maximum:	1.4	14.0	2,238.1	0.9	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	0.4	13.9	1,693.1	0.7	1.3	1	1	1
10/27/2020 01:00	0.6	13.5	1,801.7	0.5	1.9	1	1	1
10/27/2020 02:00	1.0	12.2	2,095.4	0.5	3.2	1	1	1
10/27/2020 03:00	0.9	12.5	2,025.8	0.6	2.9	1	1	1
10/27/2020 04:00	0.3	13.9	1,663.1	0.5	0.9	1	1	0
10/27/2020 05:00	0.9	13.0	1,753.9	0.5	2.6	1	1	1
10/27/2020 06:00	1.0	11.7	2,210.8	0.5	3.2	1	1	1
10/27/2020 07:00	1.2	11.8	2,211.1	0.7	3.9	1	1	1
10/27/2020 08:00	1.2	12.1	2,148.0	0.7	3.9	1	1	1
10/27/2020 09:00	1.2	11.9	2,160.6	0.8	3.8	1	1	1
10/27/2020 10:00	1.2	11.9	2,167.7	0.8	3.8	1	1	1
10/27/2020 11:00	1.3	11.8	2,166.0	0.8	4.1	1	1	1
10/27/2020 12:00	1.3	11.9	2,155.6	0.8	4.1	1	1	1
10/27/2020 13:00	1.2	11.7	2,171.9	0.8	3.7	1	1	1
10/27/2020 14:00	1.2	11.7	2,176.5	0.8	3.7	1	1	1
10/27/2020 15:00	1.2	12.5	2,002.6	0.8	3.8	1	1	1
10/27/2020 16:00	1.2	11.7	2,174.1	0.8	3.7	1	1	1
10/27/2020 17:00	1.1	11.5	2,219.9	0.8	3.4	1	1	1
10/27/2020 18:00	1.1	11.5	2,221.6	0.7	3.4	1	1	1
10/27/2020 19:00	1.1	11.6	2,220.9	0.7	3.5	1	1	1
10/27/2020 20:00	1.1	11.7	2,202.1	0.7	3.5	1	1	1
10/27/2020 21:00	1.3	12.3	2,078.8	0.8	4.2	1	1	1
10/27/2020 22:00	1.3	12.4	2,075.6	0.8	4.2	1	1	1
10/27/2020 23:00	1.1	12.3	2,060.5	0.9	3.5	1	1	1
Average/Sum#:	1.1	12.2	2,077.4	0.7	80.2 #	24 #	24 #	23 #
Minimum:	0.3	11.5	1,663.1	0.5	0.9	1	1	0
Maximum:	1.3	13.9	2,221.6	0.9	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	0.4	13.9	1,682.5	0.7	1.3	1	1	0
10/28/2020 01:00	0.4	13.9	1,670.4	0.5	1.3	1	1	0
10/28/2020 02:00	0.4	13.9	1,659.0	0.3	1.3	1	1	0
10/28/2020 03:00	0.4	13.9	1,656.1	0.3	1.2	1	1	0
10/28/2020 04:00	0.8	13.4	1,835.8	0.4	2.6	1	1	1
10/28/2020 05:00	1.1	12.0	2,143.8	0.5	3.5	1	1	1
10/28/2020 06:00	0.9	11.8	2,179.4	0.6	2.8	1	1	1
10/28/2020 07:00	0.4	13.7	1,809.3	0.5	1.3	1	1	0
10/28/2020 08:00	0.4	13.7	1,738.9	0.4	1.3	1	1	0
10/28/2020 09:00	0.5	13.8	1,635.2	0.3	1.5	1	1	0
10/28/2020 10:00	0.6	13.8	1,662.0	0.4	1.9	1	1	0
10/28/2020 11:00	0.6	13.9	1,305.9	0.5	1.5	1	1	0
10/28/2020 12:00	0.5	14.0	1,268.9	0.5	1.2	1	1	0
10/28/2020 13:00	0.5	13.9	1,476.7	0.4	1.4	1	1	0
10/28/2020 14:00	0.5	13.9	1,554.7	0.4	1.5	1	1	0
10/28/2020 15:00	0.5	14.0	1,295.6	0.4	1.2	1	1	0
10/28/2020 16:00	0.6	13.8	1,640.7	0.4	1.8	1	1	0
10/28/2020 17:00	0.7	13.8	1,712.0	0.5	2.2	1	1	1
10/28/2020 18:00	1.5	12.6	2,009.7	0.7	4.8	1	1	1
10/28/2020 19:00	1.4	12.3	2,064.4	0.9	4.4	1	1	1
10/28/2020 20:00	1.4	12.2	2,089.0	1.0	4.4	1	1	1
10/28/2020 21:00	1.4	12.3	2,088.6	1.0	4.5	1	1	1
10/28/2020 22:00	1.3	12.4	2,062.8	0.9	4.2	1	1	1
10/28/2020 23:00	1.2	12.9	1,921.3	0.9	3.8	1	1	1
Average/Sum#:	0.8	13.3	1,756.8	0.6	56.9 #	24 #	24 #	10 #
Minimum:	0.4	11.8	1,268.9	0.3	1.2	1	1	0
Maximum:	1.5	14.0	2,179.4	1.0	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	0.5	13.9	1,698.1	0.7	1.6	1	1	0
10/29/2020 01:00	0.5	13.9	1,687.8	0.6	1.6	1	1	0
10/29/2020 02:00	0.5	13.9	1,545.9	0.4	1.5	1	1	0
10/29/2020 03:00	0.5	13.9	1,691.2	0.4	1.6	1	1	0
10/29/2020 04:00	0.9	13.4	1,803.4	0.5	2.9	1	1	1
10/29/2020 05:00	1.2	12.5	2,057.9	0.6	3.9	1	1	1
10/29/2020 06:00	1.2	12.4	2,065.5	0.8	3.9	1	1	1
10/29/2020 07:00	0.5	13.9	1,278.4	0.7	1.2	1	1	0
10/29/2020 08:00	0.5	13.9	1,295.7	0.5	1.2	1	1	0
10/29/2020 09:00	0.5	13.9	1,500.4	0.4	1.4	1	1	0
10/29/2020 10:00	0.5	13.9	1,501.2	0.4	1.4	1	1	0
10/29/2020 11:00	0.6	13.6	1,788.3	0.4	1.9	1	1	0
10/29/2020 12:00	0.6	13.6	1,807.6	0.5	2.0	1	1	0
10/29/2020 13:00	0.6	13.6	1,801.4	0.5	2.0	1	1	0
10/29/2020 14:00	0.6	13.6	1,801.6	0.5	2.0	1	1	0
10/29/2020 15:00	0.6	13.6	1,799.9	0.5	2.0	1	1	0
10/29/2020 16:00	0.6	13.7	1,762.9	0.5	1.9	1	1	0
10/29/2020 17:00	0.7	13.8	1,759.5	0.5	2.3	1	1	1
10/29/2020 18:00	1.6	12.5	2,029.9	0.7	5.1	1	1	1
10/29/2020 19:00	1.5	12.3	2,074.9	0.9	4.8	1	1	1
10/29/2020 20:00	1.5	12.2	2,097.7	1.0	4.8	1	1	1
10/29/2020 21:00	1.5	12.2	2,091.7	1.0	4.8	1	1	1
10/29/2020 22:00	1.5	12.3	2,088.8	1.0	4.8	1	1	1
10/29/2020 23:00	1.5	12.9	1,941.2	1.0	4.8	1	1	1
Average/Sum#:	0.9	13.3	1,790.5	0.6	65.4 #	24 #	24 #	10 #
Minimum:	0.5	12.2	1,278.4	0.4	1.2	1	1	0
Maximum:	1.6	13.9	2,097.7	1.0	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	0.5	13.9	1,620.6	0.8	1.5	1	1	0
10/30/2020 01:00	0.8	13.6	1,696.1	0.7	2.5	1	1	1
10/30/2020 02:00	1.2	12.9	1,948.5	0.6	3.9	1	1	1
10/30/2020 03:00	1.1	12.8	1,949.6	0.8	3.5	1	1	1
10/30/2020 04:00	0.5	13.9	1,698.2	0.7	1.6	1	1	0
10/30/2020 05:00	1.2	12.9	1,829.6	0.7	3.6	1	1	1
10/30/2020 06:00	1.2	12.3	2,100.8	0.7	3.9	1	1	1
10/30/2020 07:00	1.1	11.7	2,241.2	0.8	3.5	1	1	1
10/30/2020 08:00	1.0	11.6	2,249.3	0.7	3.2	1	1	1
10/30/2020 09:00	1.0	11.6	2,210.3	0.6	3.1	1	1	1
10/30/2020 10:00	0.9	11.6	2,193.4	0.6	2.8	1	1	1
10/30/2020 11:00	1.0	12.5	1,992.9	0.6	3.1	1	1	1
10/30/2020 12:00	0.4	13.9	1,653.3	0.5	1.2	1	1	0
10/30/2020 13:00	1.0	13.3	1,813.2	0.6	3.2	1	1	1
10/30/2020 14:00	1.4	12.4	2,050.0	0.7	4.5	1	1	1
10/30/2020 15:00	1.4	12.0	2,117.3	0.9	4.4	1	1	1
10/30/2020 16:00	1.4	12.2	2,083.7	0.9	4.4	1	1	1
10/30/2020 17:00	1.4	11.8	2,169.3	0.9	4.4	1	1	1
10/30/2020 18:00	1.3	11.8	2,171.2	0.9	4.1	1	1	1
10/30/2020 19:00	1.3	11.7	2,205.8	0.8	4.1	1	1	1
10/30/2020 20:00	1.0	13.1	1,823.3	0.8	3.1	1	1	1
10/30/2020 21:00	1.1	13.3	1,838.3	0.8	3.5	1	1	1
10/30/2020 22:00	1.4	12.1	2,115.0	0.9	4.4	1	1	1
10/30/2020 23:00	1.4	12.9	1,934.7	0.9	4.5	1	1	1
Average/Sum#:	1.1	12.6	1,987.7	0.7	82.0 #	24 #	24 #	21 #
Minimum:	0.4	11.6	1,620.6	0.5	1.2	1	1	0
Maximum:	1.4	13.9	2,249.3	0.9	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	0.5	13.9	1,569.3	0.8	1.5	1	1	0
10/31/2020 01:00	0.5	13.8	1,663.9	0.6	1.5	1	1	0
10/31/2020 02:00	0.8	13.6	1,660.3	0.5	2.4	1	1	1
10/31/2020 03:00	1.2	12.4	2,054.8	0.6	3.8	1	1	1
10/31/2020 04:00	1.2	12.9	1,928.1	0.8	3.8	1	1	1
10/31/2020 05:00	0.5	13.8	1,693.1	0.7	1.6	1	1	0
10/31/2020 06:00	0.5	13.8	1,693.8	0.6	1.6	1	1	0
10/31/2020 07:00	0.5	13.8	1,651.9	0.4	1.5	1	1	0
10/31/2020 08:00	0.6	13.8	1,532.2	0.4	1.7	1	1	0
10/31/2020 09:00	0.5	13.9	1,509.1	0.4	1.4	1	1	0
10/31/2020 10:00	0.5	13.9	1,639.5	0.4	1.5	1	1	0
10/31/2020 11:00	0.5	13.9	1,558.5	0.4	1.5	1	1	0
10/31/2020 12:00	0.5	13.9	1,556.5	0.4	1.5	1	1	0
10/31/2020 13:00	0.5	13.9	1,568.8	0.4	1.5	1	1	0
10/31/2020 14:00	0.5	13.9	1,604.4	0.4	1.5	1	1	0
10/31/2020 15:00	0.5	13.8	1,684.3	0.4	1.6	1	1	0
10/31/2020 16:00	0.9	13.3	1,819.6	0.5	2.8	1	1	1
10/31/2020 17:00	1.4	12.5	2,010.0	0.7	4.4	1	1	1
10/31/2020 18:00	1.4	12.4	2,035.1	0.9	4.4	1	1	1
10/31/2020 19:00	0.6	13.8	1,698.6	0.8	1.9	1	1	0
10/31/2020 20:00	1.1	13.3	1,825.0	0.8	3.5	1	1	1
10/31/2020 21:00	1.4	12.4	2,067.2	0.8	4.5	1	1	1
10/31/2020 22:00	1.3	12.5	2,044.4	0.9	4.2	1	1	1
10/31/2020 23:00	1.1	12.5	2,032.4	0.9	3.5	1	1	1
Average/Sum#:	0.8	13.4	1,754.2	0.6	59.1 #	24 #	24 #	10 #
Minimum:	0.5	12.4	1,509.1	0.4	1.4	1	1	0
Maximum:	1.4	13.9	2,067.2	0.9	4.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	1.1	12.5	2,030.9	0.8	3.5	1	1	1
11/01/2020 01:00	1.1	12.5	2,012.0	0.8	3.5	1	1	1
11/01/2020 02:00	0.5	13.8	1,681.1	0.7	1.6	1	1	1
11/01/2020 03:00	0.5	13.9	1,693.1	0.5	1.6	1	1	0
11/01/2020 04:00	0.9	13.3	1,832.1	0.5	2.9	1	1	1
11/01/2020 05:00	1.2	12.3	2,066.3	0.6	3.8	1	1	1
11/01/2020 06:00	1.1	12.5	2,033.0	0.8	3.5	1	1	1
11/01/2020 07:00	0.4	13.9	1,548.4	0.6	1.2	1	1	0
11/01/2020 08:00	0.5	13.9	1,695.4	0.5	1.6	1	1	0
11/01/2020 09:00	0.5	13.9	1,505.4	0.4	1.4	1	1	0
11/01/2020 10:00	0.5	13.9	1,576.7	0.4	1.5	1	1	0
11/01/2020 11:00	0.5	13.9	1,494.0	0.4	1.4	1	1	0
11/01/2020 12:00	0.5	13.9	1,578.6	0.4	1.5	1	1	0
11/01/2020 13:00	0.5	13.9	1,665.9	0.4	1.6	1	1	0
11/01/2020 14:00	0.5	13.8	1,681.2	0.4	1.6	1	1	0
11/01/2020 15:00	0.7	13.6	1,678.2	0.5	2.1	1	1	1
11/01/2020 16:00	1.4	12.4	2,040.1	0.7	4.4	1	1	1
11/01/2020 17:00	1.3	11.9	2,154.4	0.8	4.1	1	1	1
11/01/2020 18:00	1.2	11.7	2,195.5	0.9	3.8	1	1	1
11/01/2020 19:00	1.2	11.9	2,157.7	0.8	3.8	1	1	1
11/01/2020 20:00	1.3	11.9	2,142.2	0.8	4.1	1	1	1
11/01/2020 21:00	1.2	11.6	2,208.0	0.8	3.8	1	1	1
11/01/2020 22:00	1.3	12.2	2,103.5	0.9	4.2	1	1	1
11/01/2020 23:00	1.2	12.3	2,105.5	0.8	3.9	1	1	1
Average/Sum#:	0.9	13.0	1,870.0	0.6	66.4 #	24 #	24 #	15 #
Minimum:	0.4	11.6	1,494.0	0.4	1.2	1	1	0
Maximum:	1.4	13.9	2,208.0	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	1.1	12.1	2,123.3	0.8	3.5	1	1	1
11/02/2020 01:00	1.1	12.3	2,036.6	0.8	3.4	1	1	1
11/02/2020 02:00	0.5	13.9	1,654.9	0.6	1.6	1	1	0
11/02/2020 03:00	0.8	13.3	1,813.6	0.6	2.5	1	1	1
11/02/2020 04:00	1.2	12.1	2,120.5	0.6	3.8	1	1	1
11/02/2020 05:00	1.1	12.0	2,148.3	0.7	3.5	1	1	1
11/02/2020 06:00	1.1	12.1	2,093.4	0.7	3.5	1	1	1
11/02/2020 07:00	0.4	13.9	1,636.3	0.6	1.2	1	1	0
11/02/2020 08:00	0.5	13.9	1,668.5	0.5	1.6	1	1	0
11/02/2020 09:00	0.5	13.9	1,692.6	0.4	1.6	1	1	0
11/02/2020 10:00	0.5	13.9	1,657.3	0.4	1.6	1	1	0
11/02/2020 11:00	0.5	13.9	1,665.0	0.4	1.6	1	1	0
11/02/2020 12:00	0.5	13.8	1,692.2	0.4	1.6	1	1	0
11/02/2020 13:00	0.5	13.7	1,699.1	0.4	1.6	1	1	0
11/02/2020 14:00	0.8	13.6	1,727.4	0.5	2.5	1	1	1
11/02/2020 15:00	1.3	12.3	2,060.5	0.6	4.1	1	1	1
11/02/2020 16:00	1.1	11.5	2,202.3	0.7	3.4	1	1	1
11/02/2020 17:00	1.2	11.7	2,176.1	0.8	3.7	1	1	1
11/02/2020 18:00	1.1	11.6	2,201.8	0.7	3.4	1	1	1
11/02/2020 19:00	1.1	11.5	2,217.8	0.7	3.4	1	1	1
11/02/2020 20:00	1.1	11.6	2,206.5	0.7	3.4	1	1	1
11/02/2020 21:00	1.2	11.9	2,145.1	0.7	3.8	1	1	1
11/02/2020 22:00	1.2	12.0	2,125.3	0.8	3.8	1	1	1
11/02/2020 23:00	1.2	12.4	2,056.0	0.8	3.8	1	1	1
Average/Sum#:	0.9	12.7	1,950.9	0.6	67.9 #	24 #	24 #	16 #
Minimum:	0.4	11.5	1,636.3	0.4	1.2	1	1	0
Maximum:	1.3	13.9	2,217.8	0.8	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	1.1	12.1	2,097.3	0.8	3.5	1	1	1
11/03/2020 01:00	1.1	12.5	1,974.6	0.8	3.4	1	1	1
11/03/2020 02:00	0.5	13.8	1,695.2	0.6	1.6	1	1	0
11/03/2020 03:00	0.9	13.3	1,829.4	0.6	2.9	1	1	1
11/03/2020 04:00	1.2	12.0	2,129.9	0.6	3.8	1	1	1
11/03/2020 05:00	1.1	11.9	2,151.7	0.7	3.5	1	1	1
11/03/2020 06:00	1.1	11.7	2,172.7	0.7	3.4	1	1	1
11/03/2020 07:00	1.0	12.3	2,045.9	0.7	3.1	1	1	1
11/03/2020 08:00	0.5	13.8	1,664.5	0.6	1.5	1	1	0
11/03/2020 09:00	0.5	13.9	1,683.0	0.5	1.6	1	1	0
11/03/2020 10:00	0.5	13.9	1,686.4	0.4	1.6	1	1	0
11/03/2020 11:00	0.5	13.9	1,536.2	0.4	1.4	1	1	0
11/03/2020 12:00	0.5	13.9	1,535.5	0.4	1.4	1	1	0
11/03/2020 13:00	0.5	13.9	1,605.1	0.4	1.5	1	1	0
11/03/2020 14:00	0.5	13.9	1,676.2	0.4	1.6	1	1	0
11/03/2020 15:00	1.0	13.3	1,812.8	0.5	3.2	1	1	1
11/03/2020 16:00	1.3	11.9	2,151.6	0.7	4.1	1	1	1
11/03/2020 17:00	1.2	11.7	2,189.1	0.8	3.8	1	1	1
11/03/2020 18:00	1.2	11.6	2,201.6	0.8	3.8	1	1	1
11/03/2020 19:00	1.1	11.6	2,210.4	0.8	3.5	1	1	1
11/03/2020 20:00	1.2	11.8	2,172.2	0.8	3.8	1	1	1
11/03/2020 21:00	1.2	11.9	2,155.4	0.8	3.8	1	1	1
11/03/2020 22:00	1.2	12.1	2,124.8	0.8	3.8	1	1	1
11/03/2020 23:00	1.3	12.5	2,058.4	0.8	4.2	1	1	1
Average/Sum#:	0.9	12.7	1,940.0	0.6	69.8 #	24 #	24 #	16 #
Minimum:	0.5	11.6	1,535.5	0.4	1.4	1	1	0
Maximum:	1.3	13.9	2,210.4	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	1.2	12.4	2,066.9	0.8	3.9	1	1	1
11/04/2020 01:00	1.1	12.8	1,935.3	0.8	3.5	1	1	1
11/04/2020 02:00	0.5	13.8	1,695.0	0.7	1.6	1	1	0
11/04/2020 03:00	0.9	13.3	1,825.3	0.6	2.9	1	1	1
11/04/2020 04:00	1.2	12.2	2,106.2	0.6	3.8	1	1	1
11/04/2020 05:00	1.2	12.0	2,155.7	0.8	3.8	1	1	1
11/04/2020 06:00	1.2	12.0	2,175.0	0.8	3.9	1	1	1
11/04/2020 07:00	1.1	12.4	2,041.5	0.8	3.5	1	1	1
11/04/2020 08:00	0.5	13.8	1,696.7	0.7	1.6	1	1	0
11/04/2020 09:00	0.5	13.9	1,645.6	0.5	1.6	1	1	0
11/04/2020 10:00	0.5	13.9	1,545.1	0.4	1.5	1	1	0
11/04/2020 11:00	0.5	13.9	1,672.3	0.4	1.6	1	1	0
11/04/2020 12:00	0.5	13.9	1,694.7	0.4	1.6	1	1	0
11/04/2020 13:00	0.5	13.9	1,699.3	0.4	1.6	1	1	0
11/04/2020 14:00	0.7	13.7	1,737.7	0.5	2.2	1	1	1
11/04/2020 15:00	1.3	12.4	2,047.7	0.6	4.1	1	1	1
11/04/2020 16:00	1.2	11.9	2,147.3	0.8	3.8	1	1	1
11/04/2020 17:00	1.2	11.7	2,182.3	0.8	3.8	1	1	1
11/04/2020 18:00	1.1	11.5	2,235.9	0.8	3.5	1	1	1
11/04/2020 19:00	1.1	11.6	2,220.7	0.7	3.5	1	1	1
11/04/2020 20:00	1.2	11.7	2,183.1	0.7	3.8	1	1	1
11/04/2020 21:00	1.2	11.8	2,172.0	0.8	3.8	1	1	1
11/04/2020 22:00	1.2	11.8	2,169.8	0.8	3.8	1	1	1
11/04/2020 23:00	1.2	12.1	2,133.6	0.8	3.8	1	1	1
Average/Sum#:	1.0	12.7	1,966.0	0.7	72.5 #	24 #	24 #	17 #
Minimum:	0.5	11.5	1,545.1	0.4	1.5	1	1	0
Maximum:	1.3	13.9	2,235.9	0.8	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	1.1	12.0	2,118.5	0.8	3.5	1	1	1
11/05/2020 01:00	1.0	12.2	2,047.8	0.7	3.1	1	1	1
11/05/2020 02:00	0.5	13.9	1,647.4	0.6	1.6	1	1	0
11/05/2020 03:00	0.9	13.2	1,826.4	0.6	2.8	1	1	1
11/05/2020 04:00	1.2	12.2	2,099.1	0.6	3.8	1	1	1
11/05/2020 05:00	1.1	11.9	2,139.3	0.7	3.5	1	1	1
11/05/2020 06:00	1.1	12.1	2,120.0	0.7	3.5	1	1	1
11/05/2020 07:00	1.1	12.6	2,002.8	0.7	3.5	1	1	1
11/05/2020 08:00	0.5	13.8	1,601.2	0.6	1.5	1	1	0
11/05/2020 09:00	0.5	13.8	1,683.6	0.5	1.6	1	1	0
11/05/2020 10:00	0.5	13.9	1,592.1	0.4	1.5	1	1	0
11/05/2020 11:00	0.5	13.9	1,585.9	0.4	1.5	1	1	0
11/05/2020 12:00	0.5	13.8	1,680.8	0.4	1.6	1	1	0
11/05/2020 13:00	0.5	13.8	1,574.8	0.4	1.5	1	1	0
11/05/2020 14:00	0.8	13.4	1,760.5	0.5	2.5	1	1	1
11/05/2020 15:00	1.2	11.7	2,158.2	0.6	3.7	1	1	1
11/05/2020 16:00	1.3	12.1	2,067.2	0.8	4.0	1	1	1
11/05/2020 17:00	1.2	11.8	2,150.2	0.8	3.7	1	1	1
11/05/2020 18:00	1.2	11.7	2,156.6	0.8	3.7	1	1	1
11/05/2020 19:00	1.3	12.1	2,083.2	0.8	4.1	1	1	1
11/05/2020 20:00	1.2	11.6	2,191.1	0.8	3.7	1	1	1
11/05/2020 21:00	1.2	11.5	2,218.8	0.8	3.7	1	1	1
11/05/2020 22:00	1.3	12.0	2,109.5	0.8	4.1	1	1	1
11/05/2020 23:00	1.3	12.0	2,114.9	0.9	4.1	1	1	1
Average/Sum#:	1.0	12.6	1,947.1	0.7	71.8 #	24 #	24 #	17 #
Minimum:	0.5	11.5	1,574.8	0.4	1.5	1	1	0
Maximum:	1.3	13.9	2,218.8	0.9	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	1.3	12.0	2,101.9	0.9	4.1	1	1	1
11/06/2020 01:00	1.4	12.8	1,928.1	0.9	4.4	1	1	1
11/06/2020 02:00	0.7	13.8	1,651.1	0.8	2.1	1	1	0
11/06/2020 03:00	0.6	13.8	1,611.0	0.7	1.8	1	1	0
11/06/2020 04:00	1.1	13.2	1,828.4	0.6	3.4	1	1	1
11/06/2020 05:00	1.3	11.9	2,131.3	0.7	4.1	1	1	1
11/06/2020 06:00	1.2	12.4	2,044.5	0.8	3.8	1	1	1
11/06/2020 07:00	1.1	12.0	2,099.5	0.8	3.4	1	1	1
11/06/2020 08:00	0.5	13.9	1,428.8	0.6	1.3	1	1	0
11/06/2020 09:00	0.5	13.9	1,347.2	0.5	1.3	1	1	0
11/06/2020 10:00	0.5	13.9	1,318.4	0.4	1.2	1	1	0
11/06/2020 11:00	0.5	13.9	1,299.4	0.4	1.2	1	1	0
11/06/2020 12:00	0.5	13.9	1,433.6	0.4	1.4	1	1	0
11/06/2020 13:00	0.5	13.9	1,412.2	0.4	1.3	1	1	0
11/06/2020 14:00	0.6	13.9	1,332.7	0.4	1.5	1	1	0
11/06/2020 15:00	1.1	13.2	1,832.6	0.6	3.5	1	1	1
11/06/2020 16:00	1.4	11.9	2,142.0	0.7	4.4	1	1	1
11/06/2020 17:00	1.2	11.8	2,152.8	0.8	3.7	1	1	1
11/06/2020 18:00	1.1	11.8	2,162.2	0.8	3.5	1	1	1
11/06/2020 19:00	1.2	12.5	2,011.8	0.8	3.8	1	1	1
11/06/2020 20:00	1.2	12.8	1,937.7	0.8	3.8	1	1	1
11/06/2020 21:00	0.5	13.8	1,534.8	0.7	1.4	1	1	0
11/06/2020 22:00	0.7	13.6	1,751.2	0.6	2.2	1	1	1
11/06/2020 23:00	1.1	12.6	1,998.6	0.6	3.5	1	1	1
Average/Sum#:	0.9	13.1	1,770.5	0.7	66.1 #	24 #	24 #	14 #
Minimum:	0.5	11.8	1,299.4	0.4	1.2	1	1	0
Maximum:	1.4	13.9	2,162.2	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	1.1	13.0	1,915.2	0.7	3.5	1	1	1
11/07/2020 01:00	0.5	13.8	1,690.1	0.7	1.6	1	1	0
11/07/2020 02:00	0.8	13.6	1,724.6	0.6	2.5	1	1	1
11/07/2020 03:00	1.3	13.0	1,931.8	0.7	4.2	1	1	1
11/07/2020 04:00	1.3	13.0	1,924.6	0.9	4.2	1	1	1
11/07/2020 05:00	0.6	13.8	1,645.2	0.8	1.8	1	1	0
11/07/2020 06:00	0.6	13.8	1,613.7	0.7	1.8	1	1	0
11/07/2020 07:00	0.5	13.8	1,596.3	0.5	1.5	1	1	0
11/07/2020 08:00	0.6	13.8	1,659.6	0.5	1.9	1	1	0
11/07/2020 09:00	0.6	13.8	1,558.0	0.5	1.7	1	1	0
11/07/2020 10:00	0.6	13.9	1,414.6	0.5	1.6	1	1	0
11/07/2020 11:00	0.6	13.8	1,400.9	0.5	1.6	1	1	0
11/07/2020 12:00	0.5	13.8	1,582.3	0.5	1.5	1	1	0
11/07/2020 13:00	0.5	13.8	1,489.2	0.4	1.4	1	1	0
11/07/2020 14:00	0.6	13.8	1,480.7	0.4	1.7	1	1	0
11/07/2020 15:00	0.6	13.8	1,555.7	0.5	1.7	1	1	1
11/07/2020 16:00	1.5	12.3	2,064.3	0.7	4.8	1	1	1
11/07/2020 17:00	1.3	11.9	2,137.0	0.8	4.1	1	1	1
11/07/2020 18:00	1.2	12.1	2,069.1	0.9	3.7	1	1	1
11/07/2020 19:00	1.3	12.3	2,053.4	0.9	4.1	1	1	1
11/07/2020 20:00	1.2	12.6	1,959.0	0.9	3.7	1	1	1
11/07/2020 21:00	0.0	0.0	1,580.6	0.0	0.0	1	1	0
11/07/2020 22:00	0.7	12.8	1,827.7	0.0	2.1	1	1	1
11/07/2020 23:00	0.7	11.9	2,113.8	0.0	2.2	1	1	1
Average/Sum#:	0.8	13.2	1,749.5	0.6	58.9 #	24 #	24 #	12 #
Minimum:	0.5	11.9	1,400.9	0.4	1.4	1	1	0
Maximum:	1.5	13.9	2,137.0	0.9	4.8	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	0.7	12.5	1,977.1	0.5	2.2	1	1	1
11/08/2020 01:00	0.2	13.7	1,578.5	0.4	0.6	1	1	1
11/08/2020 02:00	0.2	13.7	1,561.9	0.3	0.6	1	1	1
11/08/2020 03:00	1.1	12.9	1,930.9	0.4	3.5	1	1	1
11/08/2020 04:00	1.0	12.9	1,917.7	0.6	3.2	1	1	1
11/08/2020 05:00	0.2	13.7	1,689.1	0.6	0.6	1	1	0
11/08/2020 06:00	0.2	13.7	1,655.8	0.4	0.6	1	1	0
11/08/2020 07:00	0.2	13.7	1,579.4	0.2	0.6	1	1	0
11/08/2020 08:00	0.2	13.7	1,663.9	0.2	0.6	1	1	0
11/08/2020 09:00	0.2	13.7	1,661.0	0.2	0.6	1	1	0
11/08/2020 10:00	0.2	13.8	1,701.4	0.2	0.6	1	1	0
11/08/2020 11:00	0.2	13.8	1,552.2	0.2	0.6	1	1	0
11/08/2020 12:00	0.2	13.8	1,444.4	0.2	0.5	1	1	0
11/08/2020 13:00	0.2	13.8	1,664.0	0.2	0.6	1	1	0
11/08/2020 14:00	0.2	13.8	1,670.4	0.2	0.6	1	1	0
11/08/2020 15:00	0.2	13.8	1,694.5	0.2	0.6	1	1	0
11/08/2020 16:00	0.6	13.1	1,853.1	0.3	1.9	1	1	1
11/08/2020 17:00	0.8	11.7	2,195.3	0.4	2.5	1	1	1
11/08/2020 18:00	0.8	12.1	2,098.5	0.5	2.5	1	1	1
11/08/2020 19:00	0.8	12.2	2,058.7	0.5	2.5	1	1	1
11/08/2020 20:00	0.1	13.7	1,667.7	0.4	0.3	1	1	0
11/08/2020 21:00	0.2	13.7	1,594.7	0.3	0.6	1	1	0
11/08/2020 22:00	0.6	13.3	1,821.2	0.3	1.9	1	1	1
11/08/2020 23:00	0.9	12.1	2,118.9	0.4	2.9	1	1	1
Average/Sum#:	0.4	13.3	1,764.6	0.3	31.7 #	24 #	24 #	11 #
Minimum:	0.1	11.7	1,444.4	0.2	0.3	1	1	0
Maximum:	1.1	13.8	2,195.3	0.6	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	0.8	12.8	1,941.3	0.6	2.5	1	1	1
11/09/2020 01:00	0.1	13.7	1,534.4	0.4	0.3	1	1	0
11/09/2020 02:00	0.2	13.8	1,305.0	0.3	0.5	1	1	0
11/09/2020 03:00	0.2	13.8	1,321.4	0.2	0.5	1	1	0
11/09/2020 04:00	0.5	13.2	1,766.4	0.3	1.5	1	1	1
11/09/2020 05:00	0.6	11.8	2,179.0	0.3	1.9	1	1	1
11/09/2020 06:00	0.7	11.5	2,274.0	0.4	2.2	1	1	1
11/09/2020 07:00	0.7	12.3	2,093.1	0.4	2.3	1	1	1
11/09/2020 08:00	0.8	12.9	1,947.9	0.5	2.6	1	1	1
11/09/2020 09:00	0.1	13.8	1,525.6	0.4	0.3	1	1	0
11/09/2020 10:00	0.2	13.8	1,551.7	0.3	0.6	1	1	0
11/09/2020 11:00	0.1	13.8	1,448.0	0.1	0.3	1	1	0
11/09/2020 12:00	0.1	13.8	1,479.3	0.1	0.3	1	1	0
11/09/2020 13:00	0.2	13.8	1,419.4	0.1	0.5	1	1	0
11/09/2020 14:00	0.2	13.8	1,625.1	0.2	0.6	1	1	0
11/09/2020 15:00	0.5	13.3	1,815.6	0.3	1.6	1	1	1
11/09/2020 16:00	0.7	12.4	2,049.4	0.4	2.2	1	1	1
11/09/2020 17:00	0.6	12.3	2,076.2	0.4	1.9	1	1	1
11/09/2020 18:00	0.6	12.1	2,123.0	0.4	1.9	1	1	1
11/09/2020 19:00	0.6	12.1	2,127.6	0.4	1.9	1	1	1
11/09/2020 20:00	0.7	11.6	2,243.7	0.4	2.2	1	1	1
11/09/2020 21:00	0.7	11.7	2,201.7	0.4	2.2	1	1	1
11/09/2020 22:00	0.7	12.3	2,080.3	0.4	2.2	1	1	1
11/09/2020 23:00	0.8	12.6	2,039.9	0.5	2.6	1	1	1
Average/Sum#:	0.5	12.9	1,840.4	0.3	35.6 #	24 #	24 #	15 #
Minimum:	0.1	11.5	1,305.0	0.1	0.3	1	1	0
Maximum:	0.8	13.8	2,274.0	0.6	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	0.8	12.6	2,047.2	0.6	2.6	1	1	1
11/10/2020 01:00	0.9	12.9	1,947.2	0.6	2.9	1	1	1
11/10/2020 02:00	0.1	13.7	1,687.3	0.5	0.3	1	1	0
11/10/2020 03:00	0.5	13.4	1,822.5	0.4	1.6	1	1	1
11/10/2020 04:00	0.7	12.7	2,019.9	0.3	2.3	1	1	1
11/10/2020 05:00	0.7	12.6	2,037.0	0.5	2.3	1	1	1
11/10/2020 06:00	0.9	12.6	2,050.0	0.5	2.9	1	1	1
11/10/2020 07:00	0.8	12.8	2,018.1	0.6	2.6	1	1	1
11/10/2020 08:00	1.0	13.0	1,953.1	0.6	3.3	1	1	1
11/10/2020 09:00	0.2	13.7	1,655.9	0.5	0.6	1	1	0
11/10/2020 10:00	0.2	13.7	1,664.5	0.4	0.6	1	1	0
11/10/2020 11:00	0.2	13.8	1,392.8	0.2	0.5	1	1	0
11/10/2020 12:00	0.2	13.8	1,511.0	0.2	0.6	1	1	0
11/10/2020 13:00	0.2	13.8	1,530.4	0.2	0.6	1	1	0
11/10/2020 14:00	0.2	13.8	1,412.2	0.2	0.5	1	1	0
11/10/2020 15:00	0.4	13.5	1,667.2	0.2	1.2	1	1	1
11/10/2020 16:00	0.9	12.5	2,014.8	0.4	2.9	1	1	1
11/10/2020 17:00	0.8	12.1	2,112.6	0.5	2.5	1	1	1
11/10/2020 18:00	0.7	11.5	2,234.0	0.5	2.2	1	1	1
11/10/2020 19:00	0.7	11.5	2,222.4	0.4	2.2	1	1	1
11/10/2020 20:00	0.8	11.9	2,150.5	0.4	2.5	1	1	1
11/10/2020 21:00	0.8	12.0	2,128.9	0.5	2.5	1	1	1
11/10/2020 22:00	0.8	12.3	2,079.9	0.5	2.6	1	1	1
11/10/2020 23:00	0.8	12.4	2,061.4	0.5	2.6	1	1	1
Average/Sum#:	0.6	12.9	1,892.5	0.4	45.4 #	24 #	24 #	17 #
Minimum:	0.1	11.5	1,392.8	0.2	0.3	1	1	0
Maximum:	1.0	13.8	2,234.0	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	0.8	12.4	2,060.5	0.6	2.6	1	1	1
11/11/2020 01:00	0.9	12.9	1,941.0	0.6	2.9	1	1	1
11/11/2020 02:00	0.2	13.7	1,590.7	0.5	0.6	1	1	0
11/11/2020 03:00	0.6	13.3	1,846.9	0.5	1.9	1	1	1
11/11/2020 04:00	0.8	12.6	2,034.3	0.4	2.6	1	1	1
11/11/2020 05:00	0.9	12.3	2,072.8	0.6	2.9	1	1	1
11/11/2020 06:00	0.9	11.9	2,171.3	0.6	2.9	1	1	1
11/11/2020 07:00	0.9	12.7	1,996.5	0.6	2.9	1	1	1
11/11/2020 08:00	0.2	13.7	1,684.4	0.5	0.6	1	1	0
11/11/2020 09:00	0.2	13.7	1,682.7	0.3	0.6	1	1	0
11/11/2020 10:00	0.2	13.7	1,653.9	0.2	0.6	1	1	0
11/11/2020 11:00	0.2	13.7	1,571.0	0.2	0.6	1	1	0
11/11/2020 12:00	0.2	13.7	1,657.8	0.2	0.6	1	1	0
11/11/2020 13:00	0.2	13.8	1,528.0	0.2	0.6	1	1	0
11/11/2020 14:00	0.2	13.7	1,688.7	0.2	0.6	1	1	0
11/11/2020 15:00	0.2	13.8	1,385.8	0.2	0.5	1	1	0
11/11/2020 16:00	0.8	13.0	1,869.7	0.3	2.5	1	1	1
11/11/2020 17:00	0.9	12.4	2,030.0	0.5	2.8	1	1	1
11/11/2020 18:00	0.9	12.1	2,091.9	0.6	2.8	1	1	1
11/11/2020 19:00	0.9	12.3	2,066.1	0.6	2.9	1	1	1
11/11/2020 20:00	0.9	12.5	2,017.6	0.6	2.9	1	1	1
11/11/2020 21:00	0.2	13.7	1,665.5	0.5	0.6	1	1	0
11/11/2020 22:00	0.6	13.3	1,829.8	0.4	1.9	1	1	1
11/11/2020 23:00	0.9	12.6	2,034.8	0.4	2.9	1	1	1
Average/Sum#:	0.6	13.1	1,840.5	0.4	43.3 #	24 #	24 #	14 #
Minimum:	0.2	11.9	1,385.8	0.2	0.5	1	1	0
Maximum:	0.9	13.8	2,171.3	0.6	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	0.9	12.5	2,045.9	0.6	2.9	1	1	1
11/12/2020 01:00	1.0	13.1	1,919.8	0.7	3.3	1	1	1
11/12/2020 02:00	0.2	13.7	1,570.9	0.5	0.6	1	1	0
11/12/2020 03:00	0.4	13.5	1,698.9	0.4	1.2	1	1	1
11/12/2020 04:00	0.9	12.6	2,044.8	0.4	2.9	1	1	1
11/12/2020 05:00	1.0	12.2	2,081.5	0.5	3.2	1	1	1
11/12/2020 06:00	0.9	11.6	2,246.7	0.6	2.9	1	1	1
11/12/2020 07:00	0.8	12.2	2,106.4	0.6	2.6	1	1	1
11/12/2020 08:00	0.2	13.7	1,630.1	0.4	0.6	1	1	0
11/12/2020 09:00	0.2	13.7	1,638.6	0.3	0.6	1	1	0
11/12/2020 10:00	0.2	13.7	1,678.2	0.2	0.6	1	1	0
11/12/2020 11:00	0.2	13.7	1,609.2	0.2	0.6	1	1	0
11/12/2020 12:00	0.2	13.7	1,697.4	0.2	0.6	1	1	0
11/12/2020 13:00	0.2	13.8	1,577.7	0.2	0.6	1	1	0
11/12/2020 14:00	0.2	13.8	1,568.2	0.2	0.6	1	1	0
11/12/2020 15:00	0.5	13.5	1,691.9	0.3	1.5	1	1	1
11/12/2020 16:00	1.0	12.2	2,070.4	0.4	3.1	1	1	1
11/12/2020 17:00	0.9	12.1	2,091.8	0.6	2.8	1	1	1
11/12/2020 18:00	0.9	12.0	2,114.3	0.6	2.8	1	1	1
11/12/2020 19:00	0.9	11.9	2,140.2	0.6	2.8	1	1	1
11/12/2020 20:00	0.9	12.3	2,030.4	0.6	2.8	1	1	1
11/12/2020 21:00	0.2	13.7	1,665.3	0.5	0.6	1	1	0
11/12/2020 22:00	0.7	13.3	1,829.8	0.4	2.2	1	1	1
11/12/2020 23:00	1.0	12.5	2,038.6	0.5	3.2	1	1	1
Average/Sum#:	0.6	13.0	1,866.1	0.4	45.6 #	24 #	24 #	15 #
Minimum:	0.2	11.6	1,568.2	0.2	0.6	1	1	0
Maximum:	1.0	13.8	2,246.7	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	1.2	13.0	1,924.6	0.7	3.9	1	1	1
11/13/2020 01:00	0.6	13.6	1,503.0	0.7	1.6	1	1	1
11/13/2020 02:00	0.3	13.8	1,295.4	0.5	0.7	1	1	0
11/13/2020 03:00	0.4	13.7	1,362.8	0.3	1.0	1	1	0
11/13/2020 04:00	0.4	13.7	1,325.7	0.3	1.0	1	1	0
11/13/2020 05:00	0.3	13.7	1,593.2	0.3	0.9	1	1	0
11/13/2020 06:00	0.3	13.7	1,726.3	0.2	0.9	1	1	0
11/13/2020 07:00	0.9	13.3	1,825.5	0.4	2.9	1	1	1
11/13/2020 08:00	0.9	12.9	1,870.3	0.5	2.8	1	1	1
11/13/2020 09:00	0.2	13.7	1,682.3	0.5	0.6	1	1	0
11/13/2020 10:00	0.2	13.7	1,682.1	0.4	0.6	1	1	0
11/13/2020 11:00	0.2	13.7	1,657.5	0.2	0.6	1	1	0
11/13/2020 12:00	0.2	13.7	1,536.3	0.2	0.6	1	1	0
11/13/2020 13:00	0.2	13.7	1,655.6	0.2	0.6	1	1	0
11/13/2020 14:00	0.2	13.7	1,664.2	0.2	0.6	1	1	0
11/13/2020 15:00	0.6	13.2	1,769.9	0.3	1.8	1	1	1
11/13/2020 16:00	1.0	11.9	2,098.0	0.5	3.1	1	1	1
11/13/2020 17:00	0.9	12.0	2,071.9	0.6	2.8	1	1	1
11/13/2020 18:00	0.9	12.2	2,054.7	0.6	2.8	1	1	1
11/13/2020 19:00	1.0	12.8	1,924.3	0.6	3.1	1	1	1
11/13/2020 20:00	0.2	13.6	1,687.3	0.5	0.6	1	1	0
11/13/2020 21:00	0.6	13.4	1,692.1	0.5	1.8	1	1	1
11/13/2020 22:00	1.0	12.4	2,032.4	0.5	3.2	1	1	1
11/13/2020 23:00	0.6	13.3	1,645.2	0.6	1.7	1	1	1
Average/Sum#:	0.6	13.3	1,720.0	0.4	40.2 #	24 #	24 #	12 #
Minimum:	0.2	11.9	1,295.4	0.2	0.6	1	1	0
Maximum:	1.2	13.8	2,098.0	0.7	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	0.3	13.7	1,360.0	0.5	0.7	1	0	0
11/14/2020 01:00	0.3	13.7	1,360.4	0.3	0.7	1	0	0
11/14/2020 02:00	0.3	13.7	1,353.7	0.2	0.7	1	0	0
11/14/2020 03:00	0.3	13.7	1,359.9	0.2	0.7	1	0	0
11/14/2020 04:00	0.3	13.8	1,349.6	0.2	0.8	1	0	0
11/14/2020 05:00	0.3	13.6	1,663.6	0.2	0.9	1	0	0
11/14/2020 06:00	0.3	13.7	1,519.5	0.2	0.8	1	0	0
11/14/2020 07:00	0.3	13.7	1,605.7	0.2	0.9	1	1	0
11/14/2020 08:00	0.2	13.6	1,690.7	0.2	0.6	1	1	0
11/14/2020 09:00	0.2	13.6	1,682.6	0.2	0.6	1	1	0
11/14/2020 10:00	0.2	13.7	1,691.2	0.2	0.6	1	1	0
11/14/2020 11:00	0.2	13.7	1,696.5	0.2	0.6	1	1	0
11/14/2020 12:00	0.2	13.7	1,687.0	0.2	0.6	1	1	0
11/14/2020 13:00	0.2	13.7	1,688.9	0.2	0.6	1	1	0
11/14/2020 14:00	0.2	13.7	1,659.1	0.2	0.6	1	1	0
11/14/2020 15:00	0.4	13.5	1,707.7	0.2	1.2	1	1	1
11/14/2020 16:00	0.9	12.4	2,043.4	0.4	2.9	1	1	1
11/14/2020 17:00	0.9	12.3	2,064.1	0.5	2.9	1	1	1
11/14/2020 18:00	0.9	12.3	2,064.6	0.6	2.9	1	1	1
11/14/2020 19:00	0.9	12.5	2,010.5	0.6	2.8	1	1	1
11/14/2020 20:00	0.2	13.7	1,668.5	0.5	0.6	1	1	0
11/14/2020 21:00	0.6	13.3	1,831.7	0.4	1.9	1	1	1
11/14/2020 22:00	0.8	12.5	2,043.4	0.4	2.6	1	1	1
11/14/2020 23:00	0.8	12.9	1,956.0	0.6	2.6	1	1	1
Average/Sum#:	0.4	13.4	1,698.3	0.3	30.8 #	24 #	17 #	8 #
Minimum:	0.2	12.3	1,349.6	0.2	0.6	1	0	0
Maximum:	0.9	13.8	2,064.6	0.6	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	0.8	12.5	2,037.6	0.6	2.6	1	1	1
11/15/2020 01:00	0.8	12.9	1,938.8	0.6	2.6	1	1	1
11/15/2020 02:00	0.2	13.7	1,624.8	0.5	0.6	1	1	0
11/15/2020 03:00	0.6	13.5	1,701.5	0.4	1.8	1	1	1
11/15/2020 04:00	1.0	12.6	2,018.8	0.5	3.2	1	1	1
11/15/2020 05:00	1.2	13.1	1,926.5	0.7	3.9	1	1	1
11/15/2020 06:00	0.2	13.7	1,656.2	0.6	0.6	1	1	0
11/15/2020 07:00	0.3	13.7	1,484.6	0.4	0.8	1	1	0
11/15/2020 08:00	0.3	13.7	1,669.9	0.2	0.9	1	1	0
11/15/2020 09:00	0.3	13.7	1,689.5	0.2	0.9	1	1	0
11/15/2020 10:00	0.3	13.7	1,708.3	0.2	0.9	1	1	0
11/15/2020 11:00	0.2	13.7	1,698.8	0.2	0.6	1	1	0
11/15/2020 12:00	0.2	13.7	1,694.5	0.2	0.6	1	1	0
11/15/2020 13:00	0.2	13.7	1,696.4	0.2	0.6	1	1	0
11/15/2020 14:00	0.2	13.7	1,690.7	0.2	0.6	1	1	0
11/15/2020 15:00	0.3	13.7	1,462.4	0.2	0.8	1	1	0
11/15/2020 16:00	0.2	13.7	1,572.8	0.2	0.6	1	1	0
11/15/2020 17:00	0.2	13.7	1,573.2	0.2	0.6	1	1	0
11/15/2020 18:00	0.2	13.7	1,605.1	0.2	0.6	1	1	0
11/15/2020 19:00	0.2	13.7	1,637.7	0.2	0.6	1	1	0
11/15/2020 20:00	0.6	13.3	1,824.8	0.3	1.9	1	1	1
11/15/2020 21:00	0.7	12.8	1,901.8	0.4	2.2	1	1	1
11/15/2020 22:00	0.5	13.5	1,746.4	0.5	1.6	1	1	1
11/15/2020 23:00	0.9	12.5	2,029.5	0.5	2.9	1	1	1
Average/Sum#:	0.4	13.4	1,732.9	0.4	33.0 #	24 #	24 #	9 #
Minimum:	0.2	12.5	1,462.4	0.2	0.6	1	1	0
Maximum:	1.2	13.7	2,037.6	0.7	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	0.8	13.1	1,826.1	0.5	2.5	1	1	1
11/16/2020 01:00	0.2	13.8	1,301.4	0.5	0.5	1	1	0
11/16/2020 02:00	0.3	13.8	1,294.8	0.3	0.7	1	1	0
11/16/2020 03:00	0.3	13.8	1,293.8	0.2	0.7	1	1	0
11/16/2020 04:00	0.4	13.6	1,687.7	0.2	1.2	1	1	1
11/16/2020 05:00	0.8	12.3	2,034.0	0.3	2.5	1	1	1
11/16/2020 06:00	0.7	12.1	2,089.2	0.4	2.2	1	1	1
11/16/2020 07:00	0.7	12.4	1,988.0	0.5	2.2	1	1	1
11/16/2020 08:00	0.2	13.7	1,695.1	0.4	0.6	1	1	0
11/16/2020 09:00	0.2	13.7	1,640.3	0.3	0.6	1	1	0
11/16/2020 10:00	0.2	13.7	1,681.2	0.2	0.6	1	1	0
11/16/2020 11:00	0.1	13.7	1,695.0	0.2	0.3	1	1	0
11/16/2020 12:00	0.1	13.7	1,683.5	0.1	0.3	1	1	0
11/16/2020 13:00	0.2	13.7	1,684.8	0.1	0.6	1	1	0
11/16/2020 14:00	0.2	13.7	1,629.0	0.2	0.6	1	1	0
11/16/2020 15:00	0.4	13.4	1,723.3	0.2	1.2	1	1	1
11/16/2020 16:00	0.9	12.2	2,040.9	0.4	2.8	1	1	1
11/16/2020 17:00	0.8	11.9	2,111.4	0.5	2.5	1	1	1
11/16/2020 18:00	0.8	11.7	2,140.3	0.5	2.5	1	1	1
11/16/2020 19:00	0.8	11.8	2,128.9	0.5	2.5	1	1	1
11/16/2020 20:00	0.8	11.8	2,122.4	0.5	2.5	1	1	1
11/16/2020 21:00	0.8	12.1	2,072.0	0.5	2.5	1	1	1
11/16/2020 22:00	0.8	12.1	2,084.2	0.5	2.5	1	1	1
11/16/2020 23:00	0.8	12.3	2,056.5	0.5	2.5	1	1	1
Average/Sum#:	0.5	12.9	1,821.0	0.4	37.6 #	24 #	24 #	14 #
Minimum:	0.1	11.7	1,293.8	0.1	0.3	1	1	0
Maximum:	0.9	13.8	2,140.3	0.5	2.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	0.8	12.2	2,059.7	0.5	2.5	1	1	1
11/17/2020 01:00	0.7	12.4	1,992.0	0.5	2.2	1	1	1
11/17/2020 02:00	0.2	13.7	1,542.4	0.4	0.6	1	1	0
11/17/2020 03:00	0.3	13.7	1,529.5	0.3	0.8	1	1	0
11/17/2020 04:00	0.5	13.5	1,732.3	0.3	1.5	1	1	1
11/17/2020 05:00	1.0	12.2	2,051.1	0.4	3.1	1	1	1
11/17/2020 06:00	1.0	11.8	2,150.8	0.6	3.1	1	1	1
11/17/2020 07:00	1.0	12.4	2,002.6	0.7	3.1	1	1	1
11/17/2020 08:00	0.3	13.7	1,671.8	0.5	0.9	1	1	0
11/17/2020 09:00	0.3	13.7	1,569.2	0.4	0.9	1	1	0
11/17/2020 10:00	0.3	13.7	1,557.1	0.2	0.9	1	1	0
11/17/2020 11:00	0.2	13.6	1,699.5	0.2	0.6	1	1	0
11/17/2020 12:00	0.3	13.7	1,469.9	0.2	0.8	1	1	0
11/17/2020 13:00	0.3	13.6	1,576.0	0.2	0.9	1	1	0
11/17/2020 14:00	0.3	13.6	1,608.8	0.2	0.9	1	1	0
11/17/2020 15:00	0.7	13.0	1,825.2	0.3	2.1	1	1	1
11/17/2020 16:00	1.0	11.7	2,130.3	0.4	3.1	1	1	1
11/17/2020 17:00	0.8	11.5	2,163.1	0.5	2.4	1	1	1
11/17/2020 18:00	0.8	11.6	2,164.5	0.5	2.5	1	1	1
11/17/2020 19:00	0.8	11.7	2,130.3	0.5	2.4	1	1	1
11/17/2020 20:00	0.9	12.0	2,072.1	0.5	2.8	1	1	1
11/17/2020 21:00	0.9	12.0	2,071.0	0.6	2.8	1	1	1
11/17/2020 22:00	0.9	12.0	2,074.9	0.6	2.8	1	1	1
11/17/2020 23:00	0.9	12.5	1,982.2	0.6	2.8	1	1	1
Average/Sum#:	0.6	12.7	1,867.8	0.4	46.5 #	24 #	24 #	15 #
Minimum:	0.2	11.5	1,469.9	0.2	0.6	1	1	0
Maximum:	1.0	13.7	2,164.5	0.7	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	0.9	12.1	2,066.0	0.6	2.8	1	1	1
11/18/2020 01:00	0.8	12.9	1,822.8	0.6	2.4	1	1	1
11/18/2020 02:00	0.3	13.7	1,405.2	0.5	0.8	1	1	0
11/18/2020 03:00	0.3	13.7	1,304.1	0.3	0.7	1	1	0
11/18/2020 04:00	0.5	13.4	1,700.6	0.3	1.5	1	1	1
11/18/2020 05:00	1.0	12.0	2,069.5	0.4	3.1	1	1	1
11/18/2020 06:00	0.9	11.7	2,134.3	0.6	2.8	1	1	1
11/18/2020 07:00	0.8	12.4	1,983.4	0.6	2.5	1	1	1
11/18/2020 08:00	0.2	13.7	1,518.7	0.5	0.6	1	1	0
11/18/2020 09:00	0.2	13.7	1,522.7	0.3	0.6	1	1	0
11/18/2020 10:00	0.2	13.7	1,584.9	0.2	0.6	1	1	0
11/18/2020 11:00	0.2	13.7	1,694.7	0.2	0.6	1	1	0
11/18/2020 12:00	0.2	13.7	1,674.7	0.2	0.6	1	1	0
11/18/2020 13:00	0.2	13.8	1,591.5	0.2	0.6	1	1	0
11/18/2020 14:00	0.2	13.8	1,522.5	0.2	0.6	1	1	0
11/18/2020 15:00	0.5	13.5	1,712.2	0.3	1.5	1	1	1
11/18/2020 16:00	1.2	12.6	2,012.3	0.5	3.8	1	1	1
11/18/2020 17:00	1.1	12.3	2,061.3	0.7	3.5	1	1	1
11/18/2020 18:00	1.0	12.1	2,112.2	0.8	3.2	1	1	1
11/18/2020 19:00	0.9	12.6	1,975.3	0.7	2.8	1	1	1
11/18/2020 20:00	1.1	12.9	1,940.7	0.7	3.5	1	1	1
11/18/2020 21:00	1.1	12.9	1,943.0	0.7	3.5	1	1	1
11/18/2020 22:00	1.1	12.9	1,949.8	0.8	3.5	1	1	1
11/18/2020 23:00	1.1	13.0	1,945.2	0.8	3.6	1	1	1
Average/Sum#:	0.7	13.0	1,802.0	0.5	49.7 #	24 #	24 #	15 #
Minimum:	0.2	11.7	1,304.1	0.2	0.6	1	1	0
Maximum:	1.2	13.8	2,134.3	0.8	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	1.1	13.0	1,922.1	0.8	3.5	1	1	1
11/19/2020 01:00	0.2	13.7	1,533.2	0.6	0.6	1	1	0
11/19/2020 02:00	0.3	13.8	1,377.0	0.4	0.8	1	1	0
11/19/2020 03:00	0.3	13.8	1,306.5	0.2	0.7	1	1	0
11/19/2020 04:00	0.3	13.8	1,302.7	0.2	0.7	1	1	0
11/19/2020 05:00	0.3	13.7	1,557.0	0.2	0.9	1	1	1
11/19/2020 06:00	1.2	12.8	2,016.0	0.4	3.9	1	1	1
11/19/2020 07:00	1.1	12.9	1,970.0	0.6	3.6	1	1	1
11/19/2020 08:00	0.2	13.7	1,608.5	0.6	0.6	1	1	0
11/19/2020 09:00	0.2	13.7	1,671.0	0.4	0.6	1	1	0
11/19/2020 10:00	0.2	13.7	1,699.0	0.2	0.6	1	1	0
11/19/2020 11:00	0.2	13.7	1,599.0	0.2	0.6	1	1	0
11/19/2020 12:00	0.2	13.7	1,703.4	0.2	0.6	1	1	0
11/19/2020 13:00	0.1	13.8	1,652.7	0.2	0.3	1	1	0
11/19/2020 14:00	0.1	13.8	1,687.2	0.1	0.3	1	1	0
11/19/2020 15:00	0.2	13.9	1,322.7	0.1	0.5	1	1	0
11/19/2020 16:00	0.2	13.8	1,601.2	0.2	0.6	1	1	0
11/19/2020 17:00	0.2	13.7	1,720.9	0.2	0.6	1	1	1
11/19/2020 18:00	1.0	12.4	2,068.3	0.4	3.2	1	1	1
11/19/2020 19:00	0.9	12.0	2,141.6	0.5	2.9	1	1	1
11/19/2020 20:00	0.9	12.2	2,102.1	0.6	2.9	1	1	1
11/19/2020 21:00	0.9	12.6	2,011.4	0.6	2.9	1	1	1
11/19/2020 22:00	0.9	12.4	2,064.2	0.6	2.9	1	1	1
11/19/2020 23:00	0.9	12.9	1,956.2	0.6	2.9	1	1	1
Average/Sum#:	0.5	13.3	1,733.1	0.4	37.7 #	24 #	24 #	11 #
Minimum:	0.1	12.0	1,302.7	0.1	0.3	1	1	0
Maximum:	1.2	13.9	2,141.6	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	0.9	12.4	2,054.1	0.6	2.9	1	1	1
11/20/2020 01:00	0.9	13.0	1,923.3	0.7	2.9	1	1	1
11/20/2020 02:00	0.1	13.8	1,595.7	0.5	0.3	1	1	0
11/20/2020 03:00	0.2	13.7	1,595.1	0.3	0.6	1	1	0
11/20/2020 04:00	0.4	13.5	1,740.2	0.2	1.2	1	1	1
11/20/2020 05:00	0.9	12.2	2,079.1	0.4	2.8	1	1	1
11/20/2020 06:00	0.9	12.1	2,132.9	0.5	2.9	1	1	1
11/20/2020 07:00	0.8	12.2	2,097.1	0.6	2.5	1	1	1
11/20/2020 08:00	0.8	12.5	2,033.6	0.6	2.6	1	1	1
11/20/2020 09:00	0.8	12.6	1,986.1	0.6	2.5	1	1	1
11/20/2020 10:00	0.1	13.8	1,667.7	0.4	0.3	1	1	0
11/20/2020 11:00	0.1	13.8	1,590.4	0.3	0.3	1	1	0
11/20/2020 12:00	0.1	13.8	1,650.0	0.1	0.3	1	1	0
11/20/2020 13:00	0.1	13.8	1,515.2	0.1	0.3	1	1	0
11/20/2020 14:00	0.1	13.8	1,550.5	0.1	0.3	1	1	0
11/20/2020 15:00	0.6	13.2	1,838.1	0.2	1.9	1	1	1
11/20/2020 16:00	1.1	12.3	2,090.9	0.5	3.5	1	1	1
11/20/2020 17:00	0.9	12.1	2,129.0	0.6	2.9	1	1	1
11/20/2020 18:00	0.8	12.0	2,123.5	0.6	2.5	1	1	1
11/20/2020 19:00	0.8	12.0	2,124.6	0.5	2.5	1	1	1
11/20/2020 20:00	0.8	12.0	2,132.9	0.5	2.5	1	1	1
11/20/2020 21:00	0.8	12.0	2,122.3	0.5	2.5	1	1	1
11/20/2020 22:00	0.8	12.0	2,133.8	0.5	2.5	1	1	1
11/20/2020 23:00	0.8	12.3	2,078.8	0.5	2.6	1	1	1
Average/Sum#:	0.6	12.8	1,916.0	0.4	46.1 #	24 #	24 #	17 #
Minimum:	0.1	12.0	1,515.2	0.1	0.3	1	1	0
Maximum:	1.1	13.8	2,133.8	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	0.8	12.4	2,063.4	0.5	2.6	1	1	1
11/21/2020 01:00	0.9	12.9	1,949.7	0.6	2.9	1	1	1
11/21/2020 02:00	0.9	13.0	1,919.4	0.7	2.9	1	1	1
11/21/2020 03:00	0.2	13.8	1,752.8	0.5	0.7	1	1	0
11/21/2020 04:00	0.6	13.2	1,840.5	0.5	1.9	1	1	1
11/21/2020 05:00	0.9	12.1	2,102.9	0.4	2.8	1	1	1
11/21/2020 06:00	0.8	12.0	2,143.1	0.5	2.5	1	1	1
11/21/2020 07:00	0.3	13.5	1,622.5	0.4	0.9	1	1	1
11/21/2020 08:00	0.1	13.8	1,615.9	0.3	0.3	1	1	0
11/21/2020 09:00	0.2	13.8	1,622.1	0.2	0.6	1	1	0
11/21/2020 10:00	0.2	13.8	1,476.6	0.2	0.5	1	1	0
11/21/2020 11:00	0.1	13.8	1,672.2	0.2	0.3	1	1	0
11/21/2020 12:00	0.1	13.8	1,675.6	0.1	0.3	1	1	0
11/21/2020 13:00	0.1	13.8	1,697.4	0.1	0.3	1	1	0
11/21/2020 14:00	0.1	13.8	1,604.9	0.1	0.3	1	1	0
11/21/2020 15:00	0.7	13.2	1,850.8	0.2	2.2	1	1	1
11/21/2020 16:00	1.0	12.2	2,085.5	0.4	3.2	1	1	1
11/21/2020 17:00	1.0	12.1	2,116.5	0.6	3.2	1	1	1
11/21/2020 18:00	1.0	11.9	2,153.8	0.7	3.2	1	1	1
11/21/2020 19:00	1.0	12.0	2,144.2	0.7	3.2	1	1	1
11/21/2020 20:00	1.0	12.1	2,090.3	0.7	3.1	1	1	1
11/21/2020 21:00	0.2	13.7	1,686.8	0.5	0.6	1	1	0
11/21/2020 22:00	0.6	13.2	1,838.2	0.5	1.9	1	1	1
11/21/2020 23:00	0.9	12.3	2,079.8	0.4	2.9	1	1	1
Average/Sum#:	0.6	13.0	1,866.9	0.4	43.3 #	24 #	24 #	15 #
Minimum:	0.1	11.9	1,476.6	0.1	0.3	1	1	0
Maximum:	1.0	13.8	2,153.8	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	0.9	12.4	2,056.5	0.6	2.9	1	1	1
11/22/2020 01:00	0.6	13.0	1,806.1	0.5	1.8	1	1	1
11/22/2020 02:00	0.2	13.8	1,305.9	0.4	0.5	1	1	0
11/22/2020 03:00	0.3	13.8	1,363.8	0.3	0.8	1	1	0
11/22/2020 04:00	0.2	13.7	1,623.9	0.2	0.6	1	1	0
11/22/2020 05:00	1.0	13.1	1,844.5	0.4	3.1	1	1	1
11/22/2020 06:00	0.9	13.1	1,879.0	0.6	2.9	1	1	1
11/22/2020 07:00	0.2	13.7	1,518.2	0.6	0.6	1	1	0
11/22/2020 08:00	0.2	13.7	1,678.7	0.4	0.6	1	1	0
11/22/2020 09:00	0.2	13.7	1,691.0	0.2	0.6	1	1	0
11/22/2020 10:00	0.2	13.7	1,623.1	0.2	0.6	1	1	0
11/22/2020 11:00	0.2	13.7	1,674.4	0.2	0.6	1	1	0
11/22/2020 12:00	0.2	13.7	1,649.7	0.2	0.6	1	1	0
11/22/2020 13:00	0.2	13.7	1,644.2	0.2	0.6	1	1	0
11/22/2020 14:00	0.2	13.7	1,698.4	0.2	0.6	1	1	0
11/22/2020 15:00	0.6	13.2	1,838.0	0.3	1.9	1	1	1
11/22/2020 16:00	1.0	12.1	2,097.6	0.5	3.1	1	1	1
11/22/2020 17:00	0.9	12.0	2,112.3	0.6	2.8	1	1	1
11/22/2020 18:00	0.9	12.1	2,099.2	0.6	2.8	1	1	1
11/22/2020 19:00	0.9	12.2	2,044.1	0.6	2.8	1	1	1
11/22/2020 20:00	0.2	13.7	1,690.1	0.5	0.6	1	1	0
11/22/2020 21:00	0.6	13.1	1,856.5	0.4	1.9	1	1	1
11/22/2020 22:00	1.0	12.1	2,091.4	0.5	3.1	1	1	1
11/22/2020 23:00	0.7	13.0	1,856.3	0.6	2.2	1	1	1
Average/Sum#:	0.5	13.2	1,781.0	0.4	38.6 #	24 #	24 #	12 #
Minimum:	0.2	12.0	1,305.9	0.2	0.5	1	1	0
Maximum:	1.0	13.8	2,112.3	0.6	3.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	0.4	13.4	1,712.3	0.5	1.2	1	1	1
11/23/2020 01:00	0.9	12.9	1,912.4	0.5	2.8	1	1	1
11/23/2020 02:00	0.2	13.7	1,475.3	0.4	0.5	1	0	0
11/23/2020 03:00	0.3	13.7	1,385.9	0.4	0.8	1	0	0
11/23/2020 04:00	0.3	13.8	1,395.9	0.2	0.8	1	0	0
11/23/2020 05:00	0.2	13.7	1,708.4	0.2	0.6	1	0	0
11/23/2020 06:00	0.3	13.8	1,398.5	0.2	0.8	1	0	0
11/23/2020 07:00	0.2	13.7	1,696.7	0.2	0.6	1	1	0
11/23/2020 08:00	0.2	13.7	1,629.3	0.2	0.6	1	1	0
11/23/2020 09:00	0.2	13.7	1,660.5	0.2	0.6	1	1	0
11/23/2020 10:00	0.2	13.7	1,586.9	0.2	0.6	1	1	0
11/23/2020 11:00	0.2	13.7	1,669.8	0.2	0.6	1	1	0
11/23/2020 12:00	0.2	13.8	1,692.9	0.2	0.6	1	1	0
11/23/2020 13:00	0.2	13.8	1,646.7	0.2	0.6	1	1	0
11/23/2020 14:00	0.2	13.8	1,691.1	0.2	0.6	1	1	0
11/23/2020 15:00	0.4	13.5	1,764.4	0.2	1.3	1	1	1
11/23/2020 16:00	1.0	12.2	2,086.6	0.4	3.2	1	1	1
11/23/2020 17:00	1.0	12.1	2,106.2	0.6	3.2	1	1	1
11/23/2020 18:00	1.0	12.1	2,112.2	0.7	3.2	1	1	1
11/23/2020 19:00	0.9	12.6	1,964.2	0.7	2.8	1	1	1
11/23/2020 20:00	0.2	13.7	1,668.7	0.5	0.6	1	1	0
11/23/2020 21:00	0.4	13.5	1,700.0	0.4	1.2	1	1	1
11/23/2020 22:00	0.9	12.4	2,048.7	0.4	2.9	1	1	1
11/23/2020 23:00	0.9	12.7	1,972.8	0.5	2.9	1	1	1
Average/Sum#:	0.5	13.3	1,736.9	0.4	33.6 #	24 #	19 #	10 #
Minimum:	0.2	12.1	1,385.9	0.2	0.5	1	0	0
Maximum:	1.0	13.8	2,112.2	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	0.9	12.8	1,942.9	0.6	2.9	1	1	1
11/24/2020 01:00	0.2	13.7	1,560.7	0.5	0.6	1	1	0
11/24/2020 02:00	0.2	13.7	1,566.3	0.4	0.6	1	1	0
11/24/2020 03:00	0.2	13.7	1,582.6	0.2	0.6	1	1	0
11/24/2020 04:00	0.6	13.3	1,834.3	0.3	1.9	1	1	1
11/24/2020 05:00	0.9	12.2	2,092.5	0.4	2.9	1	1	1
11/24/2020 06:00	0.9	11.7	2,222.2	0.6	2.9	1	1	1
11/24/2020 07:00	0.8	12.0	2,148.1	0.6	2.6	1	1	1
11/24/2020 08:00	0.6	13.0	1,891.4	0.5	1.9	1	1	1
11/24/2020 09:00	0.2	13.7	1,689.6	0.4	0.6	1	1	0
11/24/2020 10:00	0.2	13.8	1,672.5	0.3	0.6	1	1	1
11/24/2020 11:00	0.2	13.8	1,683.7	0.2	0.6	1	1	0
11/24/2020 12:00	0.1	13.8	1,670.4	0.2	0.3	1	1	0
11/24/2020 13:00	0.2	13.8	1,680.2	0.2	0.6	1	1	0
11/24/2020 14:00	0.2	13.8	1,599.2	0.2	0.6	1	1	0
11/24/2020 15:00	0.5	13.6	1,576.8	0.3	1.4	1	1	1
11/24/2020 16:00	1.6	12.2	2,088.0	0.6	5.1	1	1	1
11/24/2020 17:00	1.2	12.1	2,124.5	0.8	3.8	1	1	1
11/24/2020 18:00	1.2	12.0	2,143.0	0.9	3.8	1	1	1
11/24/2020 19:00	1.2	11.9	2,167.3	0.8	3.8	1	1	1
11/24/2020 20:00	1.0	11.9	2,174.8	0.8	3.2	1	1	1
11/24/2020 21:00	0.8	12.1	2,145.0	0.7	2.6	1	1	1
11/24/2020 22:00	0.8	12.2	2,125.8	0.6	2.6	1	1	1
11/24/2020 23:00	0.8	12.4	2,076.0	0.5	2.6	1	1	1
Average/Sum#:	0.6	12.9	1,894.1	0.5	49.1 #	24 #	24 #	16 #
Minimum:	0.1	11.7	1,560.7	0.2	0.3	1	1	0
Maximum:	1.6	13.8	2,222.2	0.9	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	0.8	12.4	2,077.0	0.6	2.6	1	1	1
11/25/2020 01:00	0.8	13.0	1,930.7	0.6	2.6	1	1	1
11/25/2020 02:00	0.2	13.7	1,572.2	0.5	0.6	1	1	0
11/25/2020 03:00	0.4	13.7	1,378.7	0.4	1.0	1	1	0
11/25/2020 04:00	0.4	13.7	1,566.3	0.3	1.1	1	1	1
11/25/2020 05:00	1.0	12.5	2,021.7	0.4	3.2	1	1	1
11/25/2020 06:00	1.1	12.7	2,015.8	0.6	3.6	1	1	1
11/25/2020 07:00	1.1	12.6	2,013.3	0.8	3.5	1	1	1
11/25/2020 08:00	0.2	13.7	1,677.1	0.6	0.6	1	1	0
11/25/2020 09:00	0.2	13.7	1,640.7	0.4	0.6	1	1	0
11/25/2020 10:00	0.2	13.7	1,702.9	0.2	0.6	1	1	0
11/25/2020 11:00	0.2	13.7	1,702.6	0.2	0.6	1	1	0
11/25/2020 12:00	0.2	13.8	1,699.7	0.2	0.6	1	1	0
11/25/2020 13:00	0.2	13.8	1,688.1	0.2	0.6	1	1	0
11/25/2020 14:00	0.2	13.8	1,661.8	0.2	0.6	1	1	0
11/25/2020 15:00	0.2	13.8	1,357.2	0.2	0.5	1	1	0
11/25/2020 16:00	0.2	13.8	1,639.3	0.2	0.6	1	1	0
11/25/2020 17:00	0.2	13.7	1,615.1	0.2	0.6	1	1	0
11/25/2020 18:00	0.2	13.7	1,701.9	0.2	0.6	1	1	0
11/25/2020 19:00	0.7	13.1	1,863.3	0.3	2.2	1	1	1
11/25/2020 20:00	0.8	12.6	1,937.7	0.4	2.5	1	1	1
11/25/2020 21:00	0.5	13.5	1,795.2	0.5	1.6	1	1	1
11/25/2020 22:00	1.0	12.5	2,038.1	0.6	3.2	1	1	1
11/25/2020 23:00	7.0	14.1	1,276.9	0.0	8.4	1	0	1
Average/Sum#:	0.8	13.4	1,732.2	0.4	42.6 #	24 #	23 #	11 #
Minimum:	0.2	12.4	1,276.9	0.2	0.5	1	0	0
Maximum:	7.0	14.1	2,077.0	0.8	8.4	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 23:00	50.8	17.5	466.7	0.0	62.6	1	0	0
Average/Sum#:	50.8	17.5	466.7	0.0	62.6 #	1 #	0 #	0 #
Minimum:	50.8	17.5	466.7	0.0	62.6	0	0	0
Maximum:	50.8	17.5	466.7	0.0	62.6	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	19.5	16.6	585.0	0.0	35.0	1	0	0
11/27/2020 01:00	26.2	14.9	977.7	0.0	56.4	1	0	0
11/27/2020 02:00	0.2	13.8	1,452.8	0.0	0.5	1	0	0
11/27/2020 03:00	0.3	13.8	1,409.6	0.0	0.8	1	0	0
11/27/2020 04:00	0.2	13.7	1,659.8	0.2	0.6	1	0	0
11/27/2020 05:00	0.3	13.8	1,458.1	0.2	0.8	1	0	0
11/27/2020 06:00	0.2	13.7	1,707.4	0.2	0.6	1	1	0
11/27/2020 07:00	0.2	13.8	1,613.2	0.2	0.6	1	1	0
11/27/2020 08:00	0.3	13.7	1,622.4	0.2	0.9	1	1	0
11/27/2020 09:00	0.2	13.7	1,709.8	0.2	0.6	1	1	0
11/27/2020 10:00	0.2	13.8	1,694.5	0.2	0.6	1	1	0
11/27/2020 11:00	0.2	13.8	1,708.8	0.2	0.6	1	1	0
11/27/2020 12:00	0.2	13.8	1,698.0	0.2	0.6	1	1	0
11/27/2020 13:00	0.2	13.8	1,627.0	0.2	0.6	1	1	0
11/27/2020 14:00	0.2	13.8	1,666.4	0.2	0.6	1	1	0
11/27/2020 15:00	0.3	13.8	1,586.1	0.2	0.9	1	1	1
11/27/2020 16:00	1.0	12.7	1,998.3	0.4	3.2	1	1	1
11/27/2020 17:00	1.0	12.1	2,109.7	0.5	3.2	1	1	1
11/27/2020 18:00	0.9	12.3	2,073.4	0.7	2.9	1	1	1
11/27/2020 19:00	1.0	12.3	2,069.1	0.7	3.2	1	1	1
11/27/2020 20:00	1.0	12.6	1,992.5	0.7	3.2	1	1	1
11/27/2020 21:00	0.2	13.7	1,714.3	0.5	0.6	1	1	0
11/27/2020 22:00	0.7	13.3	1,854.4	0.5	2.3	1	1	1
11/27/2020 23:00	1.0	12.6	2,052.6	0.5	3.3	1	1	1
Average/Sum#:	2.3	13.6	1,668.4	0.3	122.6 #	24 #	18 #	8 #
Minimum:	0.2	12.1	585.0	0.2	0.5	1	0	0
Maximum:	26.2	16.6	2,109.7	0.7	56.4	1	1	1
%SI	0.00	0.00	0.00	16.67	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	1.0	12.5	2,061.2	0.6	3.2	1	1	1
11/28/2020 01:00	1.0	13.0	1,949.1	0.7	3.3	1	1	1
11/28/2020 02:00	0.2	13.7	1,595.5	0.5	0.6	1	1	0
11/28/2020 03:00	0.7	13.3	1,833.1	0.5	2.2	1	1	1
11/28/2020 04:00	1.1	13.0	1,951.0	0.5	3.6	1	1	1
11/28/2020 05:00	1.0	12.9	1,971.0	0.7	3.3	1	1	1
11/28/2020 06:00	0.2	13.7	1,704.0	0.6	0.6	1	1	0
11/28/2020 07:00	0.3	13.7	1,647.9	0.4	0.9	1	1	0
11/28/2020 08:00	0.3	13.7	1,691.6	0.2	0.9	1	1	0
11/28/2020 09:00	0.2	13.7	1,565.8	0.2	0.6	1	1	0
11/28/2020 10:00	0.2	13.7	1,637.2	0.2	0.6	1	1	0
11/28/2020 11:00	0.2	13.8	1,701.0	0.2	0.6	1	1	0
11/28/2020 12:00	0.2	13.8	1,706.6	0.2	0.6	1	1	0
11/28/2020 13:00	0.2	13.8	1,559.0	0.2	0.6	1	1	0
11/28/2020 14:00	0.2	13.8	1,639.1	0.2	0.6	1	1	0
11/28/2020 15:00	0.4	13.5	1,710.6	0.2	1.2	1	1	1
11/28/2020 16:00	0.9	12.4	2,050.1	0.4	2.9	1	1	1
11/28/2020 17:00	0.9	12.0	2,113.6	0.5	2.8	1	1	1
11/28/2020 18:00	0.9	11.9	2,153.6	0.6	2.8	1	1	1
11/28/2020 19:00	0.9	11.9	2,150.3	0.6	2.8	1	1	1
11/28/2020 20:00	0.8	11.6	2,213.0	0.6	2.5	1	1	1
11/28/2020 21:00	0.5	13.1	1,824.4	0.5	1.5	1	1	1
11/28/2020 22:00	0.6	13.3	1,848.3	0.5	1.9	1	1	1
11/28/2020 23:00	0.9	12.5	2,068.5	0.5	2.9	1	1	1
Average/Sum#:	0.6	13.1	1,847.7	0.4	43.5 #	24 #	24 #	14 #
Minimum:	0.2	11.6	1,559.0	0.2	0.6	1	1	0
Maximum:	1.1	13.8	2,213.0	0.7	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	1.0	13.0	1,933.3	0.6	3.2	1	1	1
11/29/2020 01:00	0.2	13.7	1,578.7	0.5	0.6	1	1	0
11/29/2020 02:00	0.6	13.2	1,866.9	0.5	1.9	1	1	1
11/29/2020 03:00	1.0	12.5	2,063.5	0.5	3.2	1	1	1
11/29/2020 04:00	0.9	12.4	2,048.2	0.6	2.9	1	1	1
11/29/2020 05:00	0.2	13.7	1,712.2	0.5	0.6	1	1	0
11/29/2020 06:00	0.2	13.7	1,684.9	0.3	0.6	1	1	0
11/29/2020 07:00	0.2	13.7	1,609.4	0.2	0.6	1	1	0
11/29/2020 08:00	0.2	13.7	1,651.6	0.2	0.6	1	1	0
11/29/2020 09:00	0.2	13.7	1,599.7	0.2	0.6	1	1	0
11/29/2020 10:00	0.2	13.7	1,702.1	0.2	0.6	1	1	0
11/29/2020 11:00	0.2	13.7	1,677.9	0.2	0.6	1	1	0
11/29/2020 12:00	0.2	13.7	1,692.3	0.2	0.6	1	1	0
11/29/2020 13:00	0.2	13.7	1,689.0	0.2	0.6	1	1	0
11/29/2020 14:00	0.2	13.8	1,669.0	0.2	0.6	1	1	0
11/29/2020 15:00	0.2	13.8	1,687.4	0.2	0.6	1	1	0
11/29/2020 16:00	0.6	13.1	1,850.5	0.3	1.9	1	1	1
11/29/2020 17:00	1.0	12.0	2,138.8	0.5	3.2	1	1	1
11/29/2020 18:00	0.9	11.6	2,218.5	0.6	2.8	1	1	1
11/29/2020 19:00	0.8	11.9	2,120.9	0.6	2.5	1	1	1
11/29/2020 20:00	0.2	13.7	1,701.6	0.4	0.6	1	1	0
11/29/2020 21:00	0.7	13.2	1,853.3	0.4	2.2	1	1	1
11/29/2020 22:00	0.9	12.0	2,148.8	0.4	2.9	1	1	1
11/29/2020 23:00	0.9	12.4	2,080.6	0.6	2.9	1	1	1
Average/Sum#:	0.5	13.2	1,832.5	0.4	37.4 #	24 #	24 #	11 #
Minimum:	0.2	11.6	1,578.7	0.2	0.6	1	1	0
Maximum:	1.0	13.8	2,218.5	0.6	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0.9	12.4	2,096.4	0.6	2.9	1	1	1
11/30/2020 01:00	0.9	12.4	2,059.8	0.6	2.9	1	1	1
11/30/2020 02:00	0.2	13.7	1,582.3	0.5	0.6	1	1	0
11/30/2020 03:00	0.2	13.7	1,555.1	0.3	0.6	1	1	0
11/30/2020 04:00	0.6	13.3	1,784.1	0.3	1.9	1	1	1
11/30/2020 05:00	1.0	12.2	2,132.5	0.5	3.2	1	1	1
11/30/2020 06:00	1.0	12.1	2,143.8	0.6	3.2	1	1	1
11/30/2020 07:00	0.9	12.1	2,129.8	0.7	2.9	1	1	1
11/30/2020 08:00	1.0	12.7	1,987.0	0.7	3.2	1	1	1
11/30/2020 09:00	0.2	13.7	1,682.6	0.5	0.6	1	1	0
11/30/2020 10:00	0.2	13.7	1,576.8	0.4	0.6	1	1	0
11/30/2020 11:00	0.2	13.7	1,646.4	0.2	0.6	1	1	0
11/30/2020 12:00	0.2	13.8	1,631.4	0.2	0.6	1	1	0
11/30/2020 13:00	0.2	13.8	1,432.0	0.2	0.5	1	1	0
11/30/2020 14:00	0.2	13.8	1,680.7	0.2	0.6	1	1	0
11/30/2020 15:00	0.4	13.5	1,708.9	0.2	1.2	1	1	1
11/30/2020 16:00	1.0	12.3	2,073.0	0.4	3.2	1	1	1
11/30/2020 17:00	0.9	11.8	2,157.9	0.5	2.8	1	1	1
11/30/2020 18:00	0.9	11.8	2,171.2	0.6	2.8	1	1	1
11/30/2020 19:00	0.8	11.5	2,231.9	0.6	2.5	1	1	1
11/30/2020 20:00	0.8	11.9	2,164.9	0.5	2.5	1	1	1
11/30/2020 21:00	0.8	11.9	2,158.9	0.5	2.5	1	1	1
11/30/2020 22:00	0.8	12.1	2,124.4	0.5	2.6	1	1	1
11/30/2020 23:00	0.8	12.4	2,050.8	0.5	2.5	1	1	1
Average/Sum#:	0.6	12.8	1,915.1	0.5	47.5 #	24 #	24 #	16 #
Minimum:	0.2	11.5	1,432.0	0.2	0.5	1	1	0
Maximum:	1.0	13.8	2,231.9	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0.9	12.3	2,077.2	0.6	2.9	1	1	1
12/01/2020 01:00	0.9	12.2	2,064.5	0.6	2.8	1	1	1
12/01/2020 02:00	0.2	13.7	1,571.7	0.5	0.6	1	1	0
12/01/2020 03:00	0.6	13.2	1,850.1	0.4	1.9	1	1	1
12/01/2020 04:00	0.9	12.0	2,133.5	0.4	2.8	1	1	1
12/01/2020 05:00	0.8	11.4	2,218.4	0.5	2.5	1	1	1
12/01/2020 06:00	0.8	11.3	2,265.3	0.5	2.5	1	1	1
12/01/2020 07:00	0.8	11.8	2,183.5	0.5	2.5	1	1	1
12/01/2020 08:00	0.8	12.0	2,126.0	0.5	2.5	1	1	1
12/01/2020 09:00	0.3	13.6	1,717.6	0.4	0.9	1	1	1
12/01/2020 10:00	0.2	13.8	1,702.3	0.3	0.6	1	1	0
12/01/2020 11:00	0.2	13.8	1,675.6	0.2	0.6	1	1	0
12/01/2020 12:00	0.1	13.8	1,687.4	0.2	0.3	1	1	0
12/01/2020 13:00	0.1	13.9	1,408.9	0.1	0.3	1	1	0
12/01/2020 14:00	0.2	13.8	1,613.8	0.1	0.6	1	1	0
12/01/2020 15:00	0.2	13.8	1,551.8	0.2	0.6	1	1	1
12/01/2020 16:00	0.9	12.4	2,028.0	0.3	2.8	1	1	1
12/01/2020 17:00	0.8	11.6	2,186.7	0.4	2.5	1	1	1
12/01/2020 18:00	0.7	11.4	2,236.7	0.5	2.2	1	1	1
12/01/2020 19:00	0.7	11.4	2,236.8	0.4	2.2	1	1	1
12/01/2020 20:00	0.7	11.4	2,246.8	0.4	2.2	1	1	1
12/01/2020 21:00	0.8	11.4	2,247.8	0.4	2.5	1	1	1
12/01/2020 22:00	0.8	11.5	2,235.6	0.5	2.5	1	1	1
12/01/2020 23:00	0.9	11.9	2,175.3	0.5	2.9	1	1	1
Average/Sum#:	0.6	12.5	1,976.7	0.4	44.7 #	24 #	24 #	18 #
Minimum:	0.1	11.3	1,408.9	0.1	0.3	1	1	0
Maximum:	0.9	13.9	2,265.3	0.6	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0.9	12.1	2,148.2	0.6	2.9	1	1	1
12/02/2020 01:00	0.9	12.6	2,007.3	0.6	2.9	1	1	1
12/02/2020 02:00	0.2	13.7	1,579.9	0.5	0.6	1	1	0
12/02/2020 03:00	0.6	13.1	1,857.9	0.4	1.9	1	1	1
12/02/2020 04:00	0.9	12.3	2,091.8	0.4	2.9	1	1	1
12/02/2020 05:00	0.9	12.1	2,123.3	0.6	2.9	1	1	1
12/02/2020 06:00	0.9	12.0	2,158.0	0.6	2.9	1	1	1
12/02/2020 07:00	0.9	12.1	2,142.3	0.6	2.9	1	1	1
12/02/2020 08:00	0.9	12.4	2,079.9	0.6	2.9	1	1	1
12/02/2020 09:00	0.2	13.7	1,598.4	0.5	0.6	1	1	1
12/02/2020 10:00	0.2	13.8	1,676.4	0.3	0.6	1	1	0
12/02/2020 11:00	0.2	13.8	1,712.8	0.2	0.6	1	1	0
12/02/2020 12:00	0.2	13.8	1,667.4	0.2	0.6	1	1	0
12/02/2020 13:00	0.2	13.8	1,557.6	0.2	0.6	1	1	0
12/02/2020 14:00	0.3	13.8	1,591.0	0.2	0.9	1	1	0
12/02/2020 15:00	0.8	13.1	1,856.7	0.3	2.5	1	1	1
12/02/2020 16:00	1.2	12.0	2,132.0	0.5	3.8	1	1	1
12/02/2020 17:00	1.1	11.7	2,199.7	0.7	3.5	1	1	1
12/02/2020 18:00	1.0	11.5	2,243.2	0.7	3.2	1	1	1
12/02/2020 19:00	0.9	11.5	2,230.9	0.6	2.8	1	1	1
12/02/2020 20:00	0.9	11.7	2,188.7	0.6	2.8	1	1	1
12/02/2020 21:00	0.9	11.8	2,168.4	0.6	2.8	1	1	1
12/02/2020 22:00	0.9	12.0	2,148.4	0.6	2.9	1	1	1
12/02/2020 23:00	0.9	12.0	2,144.9	0.6	2.9	1	1	1
Average/Sum#:	0.7	12.6	1,971.0	0.5	53.9 #	24 #	24 #	18 #
Minimum:	0.2	11.5	1,557.6	0.2	0.6	1	1	0
Maximum:	1.2	13.8	2,243.2	0.7	3.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0.9	12.1	2,129.4	0.6	2.9	1	1	1
12/03/2020 01:00	0.9	12.2	2,129.1	0.6	2.9	1	1	1
12/03/2020 02:00	0.9	12.3	2,055.8	0.6	2.8	1	1	1
12/03/2020 03:00	0.2	13.7	1,610.8	0.5	0.6	1	1	0
12/03/2020 04:00	0.6	13.2	1,856.8	0.4	1.9	1	1	1
12/03/2020 05:00	1.0	12.0	2,150.4	0.5	3.2	1	1	1
12/03/2020 06:00	0.9	11.5	2,264.7	0.6	2.9	1	1	1
12/03/2020 07:00	0.9	12.1	2,138.4	0.6	2.9	1	1	1
12/03/2020 08:00	0.9	12.3	2,102.3	0.6	2.9	1	1	1
12/03/2020 09:00	0.9	12.8	1,978.6	0.6	2.9	1	1	1
12/03/2020 10:00	0.2	13.7	1,705.2	0.5	0.6	1	1	0
12/03/2020 11:00	0.2	13.7	1,655.5	0.4	0.6	1	1	0
12/03/2020 12:00	0.2	13.8	1,690.9	0.2	0.6	1	1	0
12/03/2020 13:00	0.2	13.8	1,691.6	0.2	0.6	1	1	0
12/03/2020 14:00	0.7	13.3	1,845.9	0.3	2.2	1	1	1
12/03/2020 15:00	1.0	12.3	2,092.7	0.5	3.2	1	1	1
12/03/2020 16:00	1.0	11.9	2,177.5	0.6	3.2	1	1	1
12/03/2020 17:00	0.9	11.6	2,223.1	0.7	2.8	1	1	1
12/03/2020 18:00	0.7	11.4	2,255.1	0.6	2.2	1	1	1
12/03/2020 19:00	0.7	11.4	2,257.9	0.5	2.2	1	1	1
12/03/2020 20:00	0.8	11.7	2,184.0	0.4	2.5	1	1	1
12/03/2020 21:00	0.8	11.6	2,218.2	0.5	2.5	1	1	1
12/03/2020 22:00	0.8	11.7	2,196.3	0.5	2.5	1	1	1
12/03/2020 23:00	0.9	12.0	2,154.2	0.5	2.9	1	1	1
Average/Sum#:	0.7	12.4	2,031.9	0.5	54.5 #	24 #	24 #	19 #
Minimum:	0.2	11.4	1,610.8	0.2	0.6	1	1	0
Maximum:	1.0	13.8	2,264.7	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0.9	12.2	2,147.2	0.6	2.9	1	1	1
12/04/2020 01:00	0.9	12.3	2,071.6	0.6	2.9	1	1	1
12/04/2020 02:00	0.2	13.7	1,698.9	0.5	0.6	1	1	0
12/04/2020 03:00	0.6	13.2	1,864.1	0.4	1.9	1	1	1
12/04/2020 04:00	1.0	12.1	2,142.8	0.5	3.2	1	1	1
12/04/2020 05:00	0.8	11.4	2,242.0	0.6	2.5	1	1	1
12/04/2020 06:00	0.8	11.4	2,281.3	0.6	2.5	1	1	1
12/04/2020 07:00	0.9	11.7	2,225.3	0.5	2.9	1	1	1
12/04/2020 08:00	0.9	12.4	2,105.3	0.6	2.9	1	1	1
12/04/2020 09:00	1.0	12.7	1,988.5	0.6	3.2	1	1	1
12/04/2020 10:00	0.2	13.8	1,630.4	0.5	0.6	1	1	0
12/04/2020 11:00	0.2	13.8	1,613.2	0.4	0.6	1	1	0
12/04/2020 12:00	1.2	13.0	1,935.7	0.4	3.9	1	1	1
12/04/2020 13:00	1.3	13.0	1,919.5	0.7	4.2	1	1	1
12/04/2020 14:00	0.2	13.7	1,675.5	0.7	0.6	1	1	0
12/04/2020 15:00	0.7	13.2	1,819.5	0.6	2.2	1	1	1
12/04/2020 16:00	1.1	12.1	2,130.5	0.5	3.5	1	1	1
12/04/2020 17:00	1.0	11.6	2,216.2	0.6	3.1	1	1	1
12/04/2020 18:00	0.9	11.6	2,210.7	0.6	2.8	1	1	1
12/04/2020 19:00	0.8	11.5	2,219.1	0.6	2.5	1	1	1
12/04/2020 20:00	0.8	11.6	2,216.2	0.5	2.5	1	1	1
12/04/2020 21:00	0.8	11.5	2,232.9	0.5	2.5	1	1	1
12/04/2020 22:00	0.9	11.8	2,186.1	0.5	2.9	1	1	1
12/04/2020 23:00	0.9	12.0	2,153.3	0.6	2.9	1	1	1
Average/Sum#:	0.8	12.4	2,038.6	0.6	60.3 #	24 #	24 #	20 #
Minimum:	0.2	11.4	1,613.2	0.4	0.6	1	1	0
Maximum:	1.3	13.8	2,281.3	0.7	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	1.0	12.0	2,163.2	0.6	3.2	1	1	1
12/05/2020 01:00	0.9	12.1	2,126.2	0.6	2.9	1	1	1
12/05/2020 02:00	1.0	12.1	2,143.6	0.7	3.2	1	1	1
12/05/2020 03:00	1.0	12.1	2,147.9	0.7	3.2	1	1	1
12/05/2020 04:00	1.0	12.1	2,143.4	0.7	3.2	1	1	1
12/05/2020 05:00	1.0	12.1	2,149.4	0.7	3.2	1	1	1
12/05/2020 06:00	1.0	12.3	2,085.0	0.7	3.2	1	1	1
12/05/2020 07:00	0.2	13.7	1,676.5	0.5	0.6	1	1	0
12/05/2020 08:00	0.3	13.7	1,630.4	0.4	0.9	1	1	0
12/05/2020 09:00	0.3	13.7	1,687.8	0.2	0.9	1	1	0
12/05/2020 10:00	0.2	13.7	1,684.3	0.2	0.6	1	1	0
12/05/2020 11:00	0.2	13.7	1,712.3	0.2	0.6	1	1	0
12/05/2020 12:00	0.3	13.7	1,702.9	0.2	0.9	1	1	0
12/05/2020 13:00	0.3	13.7	1,666.0	0.2	0.9	1	1	0
12/05/2020 14:00	0.3	13.7	1,650.1	0.2	0.9	1	1	0
12/05/2020 15:00	0.8	13.2	1,839.7	0.3	2.5	1	1	1
12/05/2020 16:00	1.0	12.3	2,081.9	0.5	3.2	1	1	1
12/05/2020 17:00	1.0	11.8	2,186.2	0.6	3.2	1	1	1
12/05/2020 18:00	0.9	11.5	2,235.4	0.6	2.8	1	1	1
12/05/2020 19:00	0.9	11.4	2,255.9	0.6	2.8	1	1	1
12/05/2020 20:00	0.9	11.5	2,254.2	0.6	2.9	1	1	1
12/05/2020 21:00	0.9	11.6	2,241.3	0.6	2.9	1	1	1
12/05/2020 22:00	1.0	12.0	2,147.7	0.6	3.2	1	1	1
12/05/2020 23:00	1.0	12.1	2,139.8	0.7	3.2	1	1	1
Average/Sum#:	0.7	12.6	1,989.6	0.5	55.1 #	24 #	24 #	16 #
Minimum:	0.2	11.4	1,630.4	0.2	0.6	1	1	0
Maximum:	1.0	13.7	2,255.9	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	1.0	12.2	2,135.5	0.7	3.2	1	1	1
12/06/2020 01:00	1.0	12.4	2,094.2	0.7	3.3	1	1	1
12/06/2020 02:00	1.0	12.4	2,085.7	0.7	3.2	1	1	1
12/06/2020 03:00	1.0	13.1	1,892.5	0.7	3.2	1	1	1
12/06/2020 04:00	0.5	13.5	1,807.3	0.6	1.6	1	1	1
12/06/2020 05:00	1.0	12.4	2,045.1	0.6	3.2	1	1	1
12/06/2020 06:00	0.9	12.7	1,965.7	0.6	2.8	1	1	1
12/06/2020 07:00	0.2	13.7	1,569.9	0.5	0.6	1	1	0
12/06/2020 08:00	0.2	13.7	1,571.6	0.3	0.6	1	1	0
12/06/2020 09:00	0.2	13.7	1,705.2	0.2	0.6	1	1	0
12/06/2020 10:00	0.2	13.7	1,702.2	0.2	0.6	1	1	0
12/06/2020 11:00	0.2	13.8	1,705.2	0.2	0.6	1	1	0
12/06/2020 12:00	0.2	13.8	1,630.6	0.2	0.6	1	1	0
12/06/2020 13:00	0.2	13.8	1,693.3	0.2	0.6	1	1	0
12/06/2020 14:00	0.2	13.8	1,666.3	0.2	0.6	1	1	0
12/06/2020 15:00	0.8	13.3	1,846.5	0.3	2.6	1	1	1
12/06/2020 16:00	1.1	12.3	2,104.0	0.5	3.6	1	1	1
12/06/2020 17:00	1.0	11.7	2,215.0	0.7	3.2	1	1	1
12/06/2020 18:00	1.0	11.5	2,252.2	0.7	3.2	1	1	1
12/06/2020 19:00	1.0	11.5	2,256.7	0.6	3.2	1	1	1
12/06/2020 20:00	0.9	11.5	2,254.9	0.6	2.9	1	1	1
12/06/2020 21:00	1.0	11.7	2,208.8	0.6	3.2	1	1	1
12/06/2020 22:00	1.0	12.0	2,142.4	0.6	3.2	1	1	1
12/06/2020 23:00	0.9	12.4	2,057.6	0.6	2.9	1	1	1
Average/Sum#:	0.7	12.8	1,942.0	0.5	53.3 #	24 #	24 #	16 #
Minimum:	0.2	11.5	1,569.9	0.2	0.6	1	1	0
Maximum:	1.1	13.8	2,256.7	0.7	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0.9	12.2	2,100.1	0.6	2.9	1	1	1
12/07/2020 01:00	0.9	12.6	1,990.2	0.6	2.9	1	1	1
12/07/2020 02:00	0.2	13.7	1,622.7	0.5	0.6	1	1	0
12/07/2020 03:00	0.6	13.2	1,835.0	0.4	1.9	1	1	1
12/07/2020 04:00	1.0	12.3	2,073.9	0.5	3.2	1	1	1
12/07/2020 05:00	1.0	12.2	2,099.5	0.6	3.2	1	1	1
12/07/2020 06:00	0.9	11.7	2,199.7	0.7	2.8	1	1	1
12/07/2020 07:00	0.9	11.7	2,193.3	0.6	2.8	1	1	1
12/07/2020 08:00	0.9	11.8	2,174.1	0.6	2.8	1	1	1
12/07/2020 09:00	0.8	11.8	2,157.8	0.6	2.5	1	1	1
12/07/2020 10:00	0.3	13.5	1,704.8	0.4	0.9	1	1	1
12/07/2020 11:00	0.2	13.8	1,604.4	0.3	0.6	1	1	0
12/07/2020 12:00	0.2	13.8	1,602.4	0.2	0.6	1	1	0
12/07/2020 13:00	0.2	13.8	1,680.5	0.2	0.6	1	1	0
12/07/2020 14:00	0.4	13.4	1,685.4	0.2	1.2	1	1	1
12/07/2020 15:00	0.9	12.1	2,075.2	0.4	2.8	1	1	1
12/07/2020 16:00	0.8	11.9	2,121.3	0.5	2.5	1	1	1
12/07/2020 17:00	0.8	11.5	2,197.4	0.5	2.5	1	1	1
12/07/2020 18:00	0.9	11.8	2,177.1	0.5	2.8	1	1	1
12/07/2020 19:00	1.0	11.8	2,184.5	0.6	3.2	1	1	1
12/07/2020 20:00	1.0	11.7	2,207.5	0.6	3.2	1	1	1
12/07/2020 21:00	0.9	11.6	2,233.7	0.6	2.9	1	1	1
12/07/2020 22:00	0.9	11.8	2,193.8	0.6	2.9	1	1	1
12/07/2020 23:00	1.0	12.2	2,104.2	0.6	3.2	1	1	1
Average/Sum#:	0.7	12.4	2,009.1	0.5	55.5 #	24 #	24 #	20 #
Minimum:	0.2	11.5	1,602.4	0.2	0.6	1	1	0
Maximum:	1.0	13.8	2,233.7	0.7	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	1.0	12.3	2,079.0	0.7	3.2	1	1	1
12/08/2020 01:00	1.2	12.9	1,951.8	0.8	3.9	1	1	1
12/08/2020 02:00	0.2	13.7	1,668.2	0.6	0.6	1	1	0
12/08/2020 03:00	0.6	13.3	1,813.6	0.5	1.9	1	1	1
12/08/2020 04:00	1.0	12.5	2,048.6	0.5	3.2	1	1	1
12/08/2020 05:00	1.2	12.9	1,984.4	0.7	3.9	1	1	1
12/08/2020 06:00	1.0	12.3	2,094.8	0.8	3.2	1	1	1
12/08/2020 07:00	0.9	11.9	2,138.8	0.7	2.8	1	1	1
12/08/2020 08:00	0.9	12.2	2,084.8	0.6	2.8	1	1	1
12/08/2020 09:00	0.9	12.8	1,961.6	0.6	2.9	1	1	1
12/08/2020 10:00	0.2	13.8	1,661.7	0.5	0.6	1	1	0
12/08/2020 11:00	0.2	13.8	1,592.7	0.4	0.6	1	1	0
12/08/2020 12:00	0.2	13.8	1,613.6	0.2	0.6	1	1	0
12/08/2020 13:00	0.2	13.8	1,579.2	0.2	0.6	1	1	0
12/08/2020 14:00	0.2	13.8	1,556.5	0.2	0.6	1	1	0
12/08/2020 15:00	0.4	13.4	1,717.2	0.2	1.2	1	1	1
12/08/2020 16:00	1.0	12.3	2,045.4	0.4	3.1	1	1	1
12/08/2020 17:00	0.9	11.6	2,198.7	0.5	2.8	1	1	1
12/08/2020 18:00	0.9	11.5	2,220.4	0.6	2.8	1	1	1
12/08/2020 19:00	0.8	11.3	2,252.9	0.6	2.5	1	1	1
12/08/2020 20:00	0.9	11.6	2,207.5	0.6	2.8	1	1	1
12/08/2020 21:00	0.9	11.9	2,171.5	0.6	2.9	1	1	1
12/08/2020 22:00	1.0	12.2	2,128.8	0.6	3.2	1	1	1
12/08/2020 23:00	1.0	12.4	2,084.1	0.7	3.2	1	1	1
Average/Sum#:	0.7	12.7	1,952.3	0.5	55.9 #	24 #	24 #	18 #
Minimum:	0.2	11.3	1,556.5	0.2	0.6	1	1	0
Maximum:	1.2	13.8	2,252.9	0.8	3.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	1.0	12.3	2,084.1	0.7	3.2	1	1	1
12/09/2020 01:00	1.0	12.4	2,068.8	0.7	3.2	1	1	1
12/09/2020 02:00	1.0	12.9	1,941.6	0.7	3.2	1	1	1
12/09/2020 03:00	0.3	13.7	1,757.3	0.5	1.0	1	1	0
12/09/2020 04:00	0.7	13.2	1,852.2	0.5	2.2	1	1	1
12/09/2020 05:00	1.0	12.5	2,055.9	0.5	3.2	1	1	1
12/09/2020 06:00	1.0	12.1	2,127.6	0.6	3.2	1	1	1
12/09/2020 07:00	1.0	12.2	2,132.4	0.7	3.2	1	1	1
12/09/2020 08:00	1.0	12.3	2,095.0	0.7	3.2	1	1	1
12/09/2020 09:00	1.1	12.9	1,941.7	0.7	3.5	1	1	1
12/09/2020 10:00	0.2	13.7	1,762.4	0.6	0.6	1	1	0
12/09/2020 11:00	0.2	13.7	1,765.5	0.4	0.6	1	1	0
12/09/2020 12:00	0.2	13.7	1,762.2	0.2	0.6	1	1	0
12/09/2020 13:00	0.2	13.7	1,758.7	0.2	0.6	1	1	0
12/09/2020 14:00	0.2	13.6	1,759.5	0.2	0.6	1	1	0
12/09/2020 15:00	0.6	13.1	1,836.5	0.3	1.9	1	1	1
12/09/2020 16:00	0.9	11.8	2,127.8	0.4	2.8	1	1	1
12/09/2020 17:00	0.8	11.6	2,184.3	0.5	2.5	1	1	1
12/09/2020 18:00	0.8	11.6	2,181.1	0.5	2.5	1	1	1
12/09/2020 19:00	0.9	11.5	2,231.5	0.5	2.8	1	1	1
12/09/2020 20:00	1.0	11.7	2,197.2	0.6	3.2	1	1	1
12/09/2020 21:00	0.9	11.4	2,265.4	0.6	2.8	1	1	1
12/09/2020 22:00	0.9	11.5	2,241.5	0.6	2.8	1	1	1
12/09/2020 23:00	1.0	12.0	2,139.7	0.6	3.2	1	1	1
Average/Sum#:	0.7	12.5	2,011.2	0.5	56.6 #	24 #	24 #	18 #
Minimum:	0.2	11.4	1,757.3	0.2	0.6	1	1	0
Maximum:	1.1	13.7	2,265.4	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	1.0	12.0	2,131.0	0.7	3.2	1	1	1
12/10/2020 01:00	0.9	12.3	2,062.3	0.7	2.9	1	1	1
12/10/2020 02:00	0.9	12.1	2,068.2	0.6	2.8	1	1	1
12/10/2020 03:00	0.2	13.8	1,709.6	0.5	0.6	1	1	0
12/10/2020 04:00	0.6	13.2	1,842.5	0.4	1.9	1	1	1
12/10/2020 05:00	0.9	11.5	2,203.7	0.4	2.8	1	1	1
12/10/2020 06:00	0.9	11.7	2,181.0	0.6	2.8	1	1	1
12/10/2020 07:00	0.9	11.8	2,161.5	0.6	2.8	1	1	1
12/10/2020 08:00	0.9	11.8	2,174.4	0.6	2.8	1	1	1
12/10/2020 09:00	0.8	11.7	2,183.1	0.6	2.5	1	1	1
12/10/2020 10:00	0.3	13.5	1,712.9	0.4	0.9	1	1	1
12/10/2020 11:00	0.2	13.8	1,641.3	0.3	0.6	1	1	0
12/10/2020 12:00	0.2	13.8	1,544.9	0.2	0.6	1	1	0
12/10/2020 13:00	0.2	13.8	1,583.7	0.2	0.6	1	1	0
12/10/2020 14:00	0.2	13.8	1,547.8	0.2	0.6	1	1	0
12/10/2020 15:00	0.7	13.2	1,849.8	0.3	2.2	1	1	1
12/10/2020 16:00	1.1	12.3	2,088.4	0.5	3.5	1	1	1
12/10/2020 17:00	1.0	11.8	2,186.1	0.6	3.2	1	1	1
12/10/2020 18:00	0.8	11.4	2,251.7	0.6	2.5	1	1	1
12/10/2020 19:00	0.9	11.5	2,219.2	0.6	2.8	1	1	1
12/10/2020 20:00	0.9	11.9	2,154.1	0.6	2.8	1	1	1
12/10/2020 21:00	0.9	11.8	2,174.0	0.6	2.8	1	1	1
12/10/2020 22:00	0.9	11.8	2,168.1	0.6	2.8	1	1	1
12/10/2020 23:00	1.0	12.1	2,107.6	0.6	3.2	1	1	1
Average/Sum#:	0.7	12.4	1,997.8	0.5	54.2 #	24 #	24 #	19 #
Minimum:	0.2	11.4	1,544.9	0.2	0.6	1	1	0
Maximum:	1.1	13.8	2,251.7	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	1.0	12.9	1,944.7	0.7	3.2	1	1	1
12/11/2020 01:00	0.2	13.7	1,710.0	0.5	0.6	1	1	0
12/11/2020 02:00	0.2	13.7	1,613.0	0.4	0.6	1	1	0
12/11/2020 03:00	0.3	13.7	1,606.6	0.2	0.9	1	1	0
12/11/2020 04:00	0.7	13.3	1,782.6	0.3	2.2	1	1	1
12/11/2020 05:00	1.0	12.4	2,081.7	0.5	3.2	1	1	1
12/11/2020 06:00	1.0	12.0	2,176.7	0.6	3.2	1	1	1
12/11/2020 07:00	1.0	12.1	2,140.4	0.7	3.2	1	1	1
12/11/2020 08:00	1.0	12.1	2,101.0	0.7	3.2	1	1	1
12/11/2020 09:00	0.2	13.7	1,680.2	0.5	0.6	1	1	0
12/11/2020 10:00	0.2	13.7	1,677.3	0.4	0.6	1	1	0
12/11/2020 11:00	0.2	13.7	1,660.2	0.2	0.6	1	1	0
12/11/2020 12:00	0.3	13.7	1,637.1	0.2	0.9	1	1	0
12/11/2020 13:00	0.3	13.7	1,677.3	0.2	0.9	1	1	0
12/11/2020 14:00	0.3	13.7	1,683.3	0.2	0.9	1	1	0
12/11/2020 15:00	0.7	13.3	1,840.1	0.3	2.2	1	1	1
12/11/2020 16:00	1.1	12.0	2,138.3	0.5	3.5	1	1	1
12/11/2020 17:00	1.1	11.8	2,182.0	0.6	3.5	1	1	1
12/11/2020 18:00	1.0	11.4	2,284.7	0.7	3.2	1	1	1
12/11/2020 19:00	0.9	11.3	2,294.0	0.6	2.8	1	1	1
12/11/2020 20:00	0.9	11.3	2,292.7	0.6	2.8	1	1	1
12/11/2020 21:00	0.9	11.3	2,291.1	0.6	2.8	1	1	1
12/11/2020 22:00	1.0	11.9	2,178.2	0.6	3.2	1	1	1
12/11/2020 23:00	1.0	12.1	2,138.1	0.7	3.2	1	1	1
Average/Sum#:	0.7	12.7	1,950.5	0.5	52.0 #	24 #	24 #	15 #
Minimum:	0.2	11.3	1,606.6	0.2	0.6	1	1	0
Maximum:	1.1	13.7	2,294.0	0.7	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	1.0	12.0	2,159.3	0.7	3.2	1	1	1
12/12/2020 01:00	1.0	12.2	2,109.2	0.7	3.2	1	1	1
12/12/2020 02:00	1.1	12.8	1,958.8	0.7	3.5	1	1	1
12/12/2020 03:00	0.2	13.6	1,633.7	0.6	0.6	1	1	0
12/12/2020 04:00	0.8	13.3	1,829.9	0.5	2.5	1	1	1
12/12/2020 05:00	1.3	13.0	1,961.2	0.6	4.3	1	1	1
12/12/2020 06:00	1.3	13.0	1,948.7	0.9	4.2	1	1	1
12/12/2020 07:00	0.3	13.6	1,702.2	0.7	0.9	1	1	1
12/12/2020 08:00	0.3	13.7	1,680.5	0.5	0.9	1	1	0
12/12/2020 09:00	0.3	13.7	1,693.1	0.2	0.9	1	1	0
12/12/2020 10:00	0.3	13.7	1,677.5	0.2	0.9	1	1	0
12/12/2020 11:00	0.3	13.7	1,593.5	0.2	0.9	1	1	0
12/12/2020 12:00	0.3	13.7	1,654.8	0.2	0.9	1	1	0
12/12/2020 13:00	0.3	13.7	1,712.2	0.2	0.9	1	1	0
12/12/2020 14:00	0.3	13.7	1,684.6	0.2	0.9	1	1	0
12/12/2020 15:00	0.7	13.2	1,845.1	0.3	2.2	1	1	1
12/12/2020 16:00	1.1	12.1	2,108.9	0.5	3.5	1	1	1
12/12/2020 17:00	1.0	11.7	2,194.3	0.6	3.1	1	1	1
12/12/2020 18:00	0.9	11.4	2,264.0	0.6	2.8	1	1	1
12/12/2020 19:00	0.9	11.3	2,270.1	0.6	2.8	1	1	1
12/12/2020 20:00	0.8	11.3	2,267.3	0.6	2.5	1	1	1
12/12/2020 21:00	0.8	11.4	2,264.8	0.5	2.5	1	1	1
12/12/2020 22:00	0.8	11.4	2,256.3	0.5	2.5	1	1	1
12/12/2020 23:00	0.9	11.9	2,156.9	0.5	2.8	1	1	1
Average/Sum#:	0.7	12.7	1,942.8	0.5	53.4 #	24 #	24 #	16 #
Minimum:	0.2	11.3	1,593.5	0.2	0.6	1	1	0
Maximum:	1.3	13.7	2,270.1	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	1.0	11.9	2,163.4	0.6	3.2	1	1	1
12/13/2020 01:00	1.0	12.2	2,094.8	0.7	3.2	1	1	1
12/13/2020 02:00	1.0	12.9	1,954.5	0.7	3.2	1	1	1
12/13/2020 03:00	1.0	12.9	1,952.7	0.7	3.2	1	1	1
12/13/2020 04:00	1.1	12.9	1,962.7	0.7	3.6	1	1	1
12/13/2020 05:00	1.0	12.4	2,061.3	0.7	3.2	1	1	1
12/13/2020 06:00	1.0	12.3	2,065.4	0.7	3.2	1	1	1
12/13/2020 07:00	0.3	13.6	1,614.1	0.5	0.9	1	1	0
12/13/2020 08:00	0.5	13.7	1,306.7	0.4	1.2	1	1	0
12/13/2020 09:00	0.5	13.7	1,307.5	0.3	1.2	1	1	0
12/13/2020 10:00	0.5	13.7	1,321.0	0.4	1.2	1	1	0
12/13/2020 11:00	0.3	13.7	1,510.4	0.3	0.8	1	1	0
12/13/2020 12:00	0.3	13.6	1,681.5	0.3	0.9	1	1	0
12/13/2020 13:00	0.3	13.6	1,695.4	0.2	0.9	1	1	0
12/13/2020 14:00	0.3	13.6	1,706.0	0.2	0.9	1	1	0
12/13/2020 15:00	0.8	13.2	1,825.9	0.3	2.5	1	1	1
12/13/2020 16:00	1.1	12.2	2,079.4	0.5	3.5	1	1	1
12/13/2020 17:00	1.0	11.5	2,234.2	0.6	3.1	1	1	1
12/13/2020 18:00	0.9	11.5	2,220.8	0.6	2.8	1	1	1
12/13/2020 19:00	1.0	11.9	2,159.6	0.6	3.2	1	1	1
12/13/2020 20:00	1.0	11.8	2,177.1	0.6	3.2	1	1	1
12/13/2020 21:00	1.0	12.1	2,121.9	0.7	3.2	1	1	1
12/13/2020 22:00	1.0	12.4	2,061.9	0.7	3.2	1	1	1
12/13/2020 23:00	1.0	12.5	2,041.7	0.7	3.2	1	1	1
Average/Sum#:	0.8	12.7	1,888.3	0.5	58.7 #	24 #	24 #	16 #
Minimum:	0.3	11.5	1,306.7	0.2	0.8	1	1	0
Maximum:	1.1	13.7	2,234.2	0.7	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	13.1	15.4	722.1	0.0	6.1	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	13.1	15.4	722.1	0.0	6.1 #	1 #	17 #	0 #
Minimum:	13.1	15.4	722.1	0.0	6.1	0	0	0
Maximum:	13.1	15.4	722.1	0.0	6.1	1	1	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	1	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	24 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	1	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/16/2020 15:00	93.3	17.6	453.9	0.0	105.1	1	1	0
12/16/2020 16:00	18.1	15.6	820.6	0.0	37.0	1	1	0
12/16/2020 17:00	0.0	13.5	1,784.6	0.0	0.0	1	1	0
12/16/2020 18:00	0.2	13.0	1,925.8	0.0	0.6	1	1	1
12/16/2020 19:00	0.3	11.9	2,196.3	0.1	1.0	1	1	1
12/16/2020 20:00	0.2	11.6	2,241.9	0.1	0.6	1	1	1
12/16/2020 21:00	0.2	11.6	2,239.8	0.1	0.6	1	1	1
12/16/2020 22:00	0.2	11.7	2,232.4	0.1	0.6	1	1	1
12/16/2020 23:00	0.2	11.7	2,210.6	0.1	0.6	1	1	1
Average/Sum#:	12.5	13.1	1,789.5	0.1	146.1 #	9 #	24 #	6 #
Minimum:	0.0	11.6	453.9	0.1	0.0	0	1	0
Maximum:	93.3	17.6	2,241.9	0.1	105.1	1	1	1
%SI	62.50	62.50	62.50	79.17	62.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0.3	12.2	2,075.5	0.1	0.9	1	1	1
12/17/2020 01:00	0.1	12.7	1,911.4	0.1	0.3	1	1	1
12/17/2020 02:00	0.0	13.4	1,797.3	0.1	0.0	1	1	1
12/17/2020 03:00	0.3	12.4	2,057.6	0.1	1.0	1	1	1
12/17/2020 04:00	0.3	12.2	2,083.9	0.1	0.9	1	1	1
12/17/2020 05:00	0.3	12.2	2,105.8	0.2	1.0	1	1	1
12/17/2020 06:00	0.3	12.5	2,033.1	0.2	1.0	1	1	1
12/17/2020 07:00	0.2	11.9	2,157.4	0.2	0.6	1	1	1
12/17/2020 08:00	0.2	12.2	2,088.9	0.1	0.6	1	1	1
12/17/2020 09:00	0.3	12.6	1,988.7	0.1	0.9	1	1	1
12/17/2020 10:00	0.0	13.7	1,650.9	0.1	0.0	1	1	0
12/17/2020 11:00	0.0	13.7	1,694.7	0.1	0.0	1	1	0
12/17/2020 12:00	0.0	13.7	1,680.3	0.0	0.0	1	1	0
12/17/2020 13:00	0.0	13.7	1,691.8	0.0	0.0	1	1	0
12/17/2020 14:00	0.0	13.7	1,670.5	0.0	0.0	1	1	0
12/17/2020 15:00	0.0	13.7	1,660.3	0.0	0.0	1	1	0
12/17/2020 16:00	0.1	13.2	1,829.8	0.0	0.3	1	1	1
12/17/2020 17:00	0.5	12.1	2,139.4	0.1	1.6	1	1	1
12/17/2020 18:00	0.4	12.0	2,142.1	0.2	1.3	1	1	1
12/17/2020 19:00	0.4	12.2	2,096.3	0.3	1.3	1	1	1
12/17/2020 20:00	0.4	12.3	2,079.4	0.3	1.3	1	1	1
12/17/2020 21:00	0.4	12.0	2,155.6	0.3	1.3	1	1	1
12/17/2020 22:00	0.4	12.2	2,106.2	0.3	1.3	1	1	1
12/17/2020 23:00	0.4	12.4	2,075.4	0.3	1.3	1	1	1
Average/Sum#:	0.2	12.7	1,957.2	0.1	16.9 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,650.9	0.0	0.0	1	1	0
Maximum:	0.5	13.7	2,157.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0.4	12.4	2,085.7	0.3	1.3	1	1	1
12/18/2020 01:00	0.6	12.9	1,951.1	0.3	1.9	1	1	1
12/18/2020 02:00	0.0	13.7	1,712.9	0.2	0.0	1	1	0
12/18/2020 03:00	0.0	13.7	1,480.2	0.1	0.0	1	1	0
12/18/2020 04:00	0.1	13.5	1,713.6	0.0	0.3	1	1	1
12/18/2020 05:00	0.6	12.7	1,990.1	0.2	1.9	1	1	1
12/18/2020 06:00	0.5	12.0	2,176.1	0.3	1.6	1	1	1
12/18/2020 07:00	0.5	12.1	2,148.5	0.3	1.6	1	1	1
12/18/2020 08:00	0.6	13.0	1,944.7	0.3	2.0	1	1	1
12/18/2020 09:00	0.0	13.7	1,714.4	0.2	0.0	1	1	0
12/18/2020 10:00	0.0	13.7	1,570.1	0.1	0.0	1	1	0
12/18/2020 11:00	0.0	13.8	1,409.7	0.0	0.0	1	1	0
12/18/2020 12:00	0.0	13.8	1,507.3	0.0	0.0	1	1	0
12/18/2020 13:00	0.0	13.8	1,609.5	0.0	0.0	1	1	0
12/18/2020 14:00	0.0	13.8	1,420.8	0.0	0.0	1	1	0
12/18/2020 15:00	0.0	13.8	1,440.2	0.0	0.0	1	1	0
12/18/2020 16:00	0.4	13.1	1,892.3	0.1	1.3	1	1	1
12/18/2020 17:00	0.4	11.6	2,215.1	0.2	1.3	1	1	1
12/18/2020 18:00	0.3	11.3	2,291.3	0.3	0.9	1	1	1
12/18/2020 19:00	0.3	11.3	2,295.0	0.2	0.9	1	1	1
12/18/2020 20:00	0.3	11.4	2,270.3	0.2	0.9	1	1	1
12/18/2020 21:00	0.4	11.7	2,228.0	0.2	1.3	1	1	1
12/18/2020 22:00	0.4	12.1	2,150.4	0.3	1.3	1	1	1
12/18/2020 23:00	0.4	12.5	2,072.7	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.8	1,887.1	0.2	19.8 #	24 #	24 #	15 #
Minimum:	0.0	11.3	1,409.7	0.0	0.0	1	1	0
Maximum:	0.6	13.8	2,295.0	0.3	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0.4	12.5	2,061.6	0.3	1.3	1	1	1
12/19/2020 01:00	0.5	12.7	2,001.3	0.3	1.6	1	1	1
12/19/2020 02:00	0.0	13.7	1,666.1	0.2	0.0	1	1	0
12/19/2020 03:00	0.0	13.7	1,561.0	0.1	0.0	1	1	0
12/19/2020 04:00	0.1	13.3	1,875.9	0.0	0.3	1	1	1
12/19/2020 05:00	0.5	12.4	2,101.1	0.1	1.6	1	1	1
12/19/2020 06:00	0.6	12.7	2,023.7	0.3	2.0	1	1	1
12/19/2020 07:00	0.0	13.7	1,683.4	0.2	0.0	1	1	0
12/19/2020 08:00	0.0	13.7	1,598.8	0.1	0.0	1	1	0
12/19/2020 09:00	0.0	13.7	1,643.4	0.0	0.0	1	1	0
12/19/2020 10:00	0.0	13.7	1,706.6	0.0	0.0	1	1	0
12/19/2020 11:00	0.0	13.7	1,713.1	0.0	0.0	1	1	0
12/19/2020 12:00	0.0	13.7	1,713.8	0.0	0.0	1	1	0
12/19/2020 13:00	0.0	13.7	1,699.9	0.0	0.0	1	1	0
12/19/2020 14:00	0.0	13.7	1,713.0	0.0	0.0	1	1	0
12/19/2020 15:00	0.0	13.5	1,771.7	0.0	0.0	1	1	1
12/19/2020 16:00	0.5	12.4	2,093.0	0.1	1.6	1	1	1
12/19/2020 17:00	0.5	12.0	2,174.5	0.2	1.6	1	1	1
12/19/2020 18:00	0.4	11.5	2,271.5	0.3	1.3	1	1	1
12/19/2020 19:00	0.3	11.4	2,301.8	0.3	1.0	1	1	1
12/19/2020 20:00	0.4	11.7	2,231.9	0.3	1.3	1	1	1
12/19/2020 21:00	0.4	11.9	2,171.0	0.3	1.3	1	1	1
12/19/2020 22:00	0.4	12.3	2,096.5	0.3	1.3	1	1	1
12/19/2020 23:00	0.4	12.7	2,012.1	0.3	1.3	1	1	1
Average/Sum#:	0.2	12.9	1,911.9	0.2	17.5 #	24 #	24 #	14 #
Minimum:	0.0	11.4	1,561.0	0.0	0.0	1	1	0
Maximum:	0.6	13.7	2,301.8	0.3	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0.5	12.9	1,968.1	0.3	1.6	1	1	1
12/20/2020 01:00	0.0	13.7	1,666.2	0.2	0.0	1	1	0
12/20/2020 02:00	0.0	13.7	1,550.0	0.1	0.0	1	1	0
12/20/2020 03:00	0.2	13.7	1,378.9	0.1	0.5	1	1	0
12/20/2020 04:00	0.0	13.7	1,583.3	0.1	0.0	1	1	0
12/20/2020 05:00	0.5	13.1	1,850.7	0.2	1.6	1	1	1
12/20/2020 06:00	0.3	13.1	1,895.0	0.2	1.0	1	1	1
12/20/2020 07:00	0.0	13.7	1,715.7	0.2	0.0	1	1	0
12/20/2020 08:00	0.0	13.7	1,692.8	0.1	0.0	1	1	0
12/20/2020 09:00	0.0	13.7	1,710.3	0.0	0.0	1	1	0
12/20/2020 10:00	0.0	13.7	1,710.6	0.0	0.0	1	1	0
12/20/2020 11:00	0.0	13.7	1,709.4	0.0	0.0	1	1	0
12/20/2020 12:00	0.0	13.7	1,714.9	0.0	0.0	1	1	0
12/20/2020 13:00	0.0	13.7	1,700.9	0.0	0.0	1	1	0
12/20/2020 14:00	0.0	13.7	1,638.4	0.0	0.0	1	1	0
12/20/2020 15:00	0.0	13.5	1,711.7	0.0	0.0	1	1	1
12/20/2020 16:00	0.5	12.4	2,050.7	0.1	1.6	1	1	1
12/20/2020 17:00	0.5	11.9	2,158.3	0.2	1.6	1	1	1
12/20/2020 18:00	0.4	11.8	2,183.9	0.3	1.3	1	1	1
12/20/2020 19:00	0.4	11.8	2,185.2	0.3	1.3	1	1	1
12/20/2020 20:00	0.4	11.5	2,243.7	0.3	1.3	1	1	1
12/20/2020 21:00	0.4	11.8	2,160.3	0.3	1.3	1	1	1
12/20/2020 22:00	0.4	12.0	2,147.4	0.3	1.3	1	1	1
12/20/2020 23:00	0.4	12.5	2,074.2	0.3	1.3	1	1	1
Average/Sum#:	0.2	13.0	1,850.0	0.2	15.7 #	24 #	24 #	12 #
Minimum:	0.0	11.5	1,378.9	0.0	0.0	1	1	0
Maximum:	0.5	13.7	2,243.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0.7	13.0	1,932.4	0.4	2.3	1	1	1
12/21/2020 01:00	0.0	13.6	1,682.7	0.3	0.0	1	1	0
12/21/2020 02:00	0.0	13.6	1,616.3	0.2	0.0	1	1	0
12/21/2020 03:00	0.0	13.7	1,561.7	0.0	0.0	1	1	0
12/21/2020 04:00	0.3	13.2	1,866.5	0.1	1.0	1	1	1
12/21/2020 05:00	0.6	12.3	2,101.9	0.2	1.9	1	1	1
12/21/2020 06:00	0.5	12.3	2,125.2	0.3	1.6	1	1	1
12/21/2020 07:00	0.5	12.3	2,116.8	0.3	1.6	1	1	1
12/21/2020 08:00	0.6	12.7	2,012.6	0.3	1.9	1	1	1
12/21/2020 09:00	0.0	13.6	1,696.4	0.2	0.0	1	1	0
12/21/2020 10:00	0.0	13.6	1,707.6	0.1	0.0	1	1	0
12/21/2020 11:00	0.0	13.6	1,710.5	0.0	0.0	1	1	0
12/21/2020 12:00	0.0	13.6	1,700.4	0.0	0.0	1	1	0
12/21/2020 13:00	0.0	13.6	1,707.3	0.0	0.0	1	1	0
12/21/2020 14:00	0.0	13.6	1,695.2	0.0	0.0	1	1	0
12/21/2020 15:00	0.1	13.2	1,846.3	0.0	0.3	1	1	1
12/21/2020 16:00	0.6	12.1	2,120.5	0.2	1.9	1	1	1
12/21/2020 17:00	0.6	12.1	2,136.7	0.3	1.9	1	1	1
12/21/2020 18:00	0.6	11.8	2,203.6	0.4	1.9	1	1	1
12/21/2020 19:00	0.6	11.9	2,179.3	0.4	1.9	1	1	1
12/21/2020 20:00	0.5	12.1	2,143.0	0.4	1.6	1	1	1
12/21/2020 21:00	0.5	12.3	2,105.7	0.3	1.6	1	1	1
12/21/2020 22:00	0.5	12.2	2,115.1	0.3	1.6	1	1	1
12/21/2020 23:00	0.5	12.5	2,060.5	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,922.7	0.2	24.6 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,561.7	0.0	0.0	1	1	0
Maximum:	0.7	13.7	2,203.6	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0.8	12.9	1,952.8	0.4	2.6	1	1	1
12/22/2020 01:00	0.1	13.6	1,672.4	0.4	0.3	1	1	0
12/22/2020 02:00	0.2	13.6	1,552.5	0.3	0.6	1	1	0
12/22/2020 03:00	0.3	13.6	1,531.0	0.2	0.8	1	1	0
12/22/2020 04:00	0.4	13.4	1,728.7	0.2	1.2	1	1	1
12/22/2020 05:00	0.6	12.5	2,066.2	0.3	1.9	1	1	1
12/22/2020 06:00	0.6	12.4	2,103.3	0.4	2.0	1	1	1
12/22/2020 07:00	0.6	12.1	2,173.9	0.4	2.0	1	1	1
12/22/2020 08:00	0.1	13.5	1,737.4	0.3	0.3	1	1	1
12/22/2020 09:00	0.1	13.6	1,627.0	0.2	0.3	1	1	0
12/22/2020 10:00	0.0	13.7	1,708.3	0.1	0.0	1	1	0
12/22/2020 11:00	0.0	13.7	1,646.9	0.0	0.0	1	1	0
12/22/2020 12:00	0.0	13.7	1,595.4	0.0	0.0	1	1	0
12/22/2020 13:00	0.0	13.7	1,661.6	0.0	0.0	1	1	0
12/22/2020 14:00	0.0	13.7	1,694.4	0.0	0.0	1	1	0
12/22/2020 15:00	0.0	13.5	1,717.8	0.0	0.0	1	1	1
12/22/2020 16:00	0.5	12.6	2,045.2	0.1	1.6	1	1	1
12/22/2020 17:00	0.5	11.9	2,173.7	0.2	1.6	1	1	1
12/22/2020 18:00	0.5	11.8	2,204.5	0.3	1.6	1	1	1
12/22/2020 19:00	0.4	11.8	2,211.9	0.3	1.3	1	1	1
12/22/2020 20:00	0.4	11.7	2,229.0	0.3	1.3	1	1	1
12/22/2020 21:00	0.4	12.0	2,177.0	0.3	1.3	1	1	1
12/22/2020 22:00	0.4	12.1	2,142.1	0.3	1.3	1	1	1
12/22/2020 23:00	0.4	12.3	2,105.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,894.1	0.2	23.3 #	24 #	24 #	15 #
Minimum:	0.0	11.7	1,531.0	0.0	0.0	1	1	0
Maximum:	0.8	13.7	2,229.0	0.4	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0.4	12.6	2,020.5	0.3	1.3	1	1	1
12/23/2020 01:00	0.0	13.7	1,716.9	0.2	0.0	1	1	0
12/23/2020 02:00	0.1	13.4	1,841.5	0.1	0.3	1	1	1
12/23/2020 03:00	0.4	13.0	1,956.4	0.1	1.3	1	1	1
12/23/2020 04:00	0.5	12.6	2,023.8	0.3	1.6	1	1	1
12/23/2020 05:00	0.0	13.7	1,709.6	0.2	0.0	1	1	0
12/23/2020 06:00	0.1	13.3	1,855.4	0.2	0.3	1	1	1
12/23/2020 07:00	0.5	12.1	2,169.0	0.1	1.6	1	1	1
12/23/2020 08:00	0.5	12.1	2,149.0	0.2	1.6	1	1	1
12/23/2020 09:00	0.4	12.6	2,019.1	0.3	1.3	1	1	1
12/23/2020 10:00	0.0	13.7	1,690.9	0.2	0.0	1	1	0
12/23/2020 11:00	0.0	13.8	1,626.3	0.1	0.0	1	1	0
12/23/2020 12:00	0.0	13.8	1,661.5	0.0	0.0	1	1	0
12/23/2020 13:00	0.0	13.8	1,692.3	0.0	0.0	1	1	0
12/23/2020 14:00	0.0	13.8	1,697.7	0.0	0.0	1	1	0
12/23/2020 15:00	0.0	13.5	1,695.4	0.0	0.0	1	1	1
12/23/2020 16:00	0.5	12.2	2,105.1	0.1	1.6	1	1	1
12/23/2020 17:00	0.5	11.5	2,259.4	0.2	1.6	1	1	1
12/23/2020 18:00	0.4	11.4	2,296.2	0.3	1.3	1	1	1
12/23/2020 19:00	0.4	11.4	2,306.9	0.2	1.3	1	1	1
12/23/2020 20:00	0.4	11.4	2,301.7	0.2	1.3	1	1	1
12/23/2020 21:00	0.5	12.0	2,178.2	0.2	1.6	1	1	1
12/23/2020 22:00	0.5	12.1	2,155.9	0.3	1.6	1	1	1
12/23/2020 23:00	0.5	12.3	2,140.3	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.7	1,969.5	0.2	21.2 #	24 #	24 #	17 #
Minimum:	0.0	11.4	1,626.3	0.0	0.0	1	1	0
Maximum:	0.5	13.8	2,306.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0.5	12.7	2,080.1	0.3	1.7	1	1	1
12/24/2020 01:00	0.7	12.9	1,987.5	0.4	2.3	1	1	1
12/24/2020 02:00	0.0	13.6	1,758.3	0.3	0.0	1	1	0
12/24/2020 03:00	0.4	13.3	1,847.2	0.3	1.3	1	1	1
12/24/2020 04:00	0.7	13.1	1,947.0	0.3	2.3	1	1	1
12/24/2020 05:00	0.6	13.0	1,962.1	0.4	2.0	1	1	1
12/24/2020 06:00	0.0	13.7	1,720.7	0.3	0.0	1	1	0
12/24/2020 07:00	0.2	13.7	1,710.5	0.2	0.6	1	1	0
12/24/2020 08:00	0.2	13.6	1,706.9	0.1	0.6	1	1	0
12/24/2020 09:00	0.6	13.0	1,967.8	0.3	2.0	1	1	1
12/24/2020 10:00	0.6	12.5	2,068.8	0.3	2.0	1	1	1
12/24/2020 11:00	0.0	13.7	1,656.9	0.3	0.0	1	1	0
12/24/2020 12:00	0.0	13.7	1,650.5	0.1	0.0	1	1	0
12/24/2020 13:00	0.0	13.7	1,674.5	0.0	0.0	1	1	0
12/24/2020 14:00	0.0	13.7	1,697.5	0.0	0.0	1	1	0
12/24/2020 15:00	0.2	13.2	1,823.1	0.1	0.6	1	1	1
12/24/2020 16:00	0.5	12.3	2,081.4	0.2	1.6	1	1	1
12/24/2020 17:00	0.5	11.9	2,166.7	0.3	1.6	1	1	1
12/24/2020 18:00	0.5	11.7	2,209.1	0.3	1.6	1	1	1
12/24/2020 19:00	0.5	11.8	2,202.6	0.3	1.6	1	1	1
12/24/2020 20:00	0.5	11.6	2,232.8	0.3	1.6	1	1	1
12/24/2020 21:00	0.5	12.0	2,162.0	0.3	1.6	1	1	1
12/24/2020 22:00	0.5	11.8	2,196.3	0.3	1.6	1	1	1
12/24/2020 23:00	0.5	12.2	2,120.7	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.9	1,943.0	0.3	28.2 #	24 #	24 #	16 #
Minimum:	0.0	11.6	1,650.5	0.0	0.0	1	1	0
Maximum:	0.7	13.7	2,232.8	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0.5	12.2	2,103.3	0.3	1.6	1	1	1
12/25/2020 01:00	0.5	12.2	2,095.3	0.3	1.6	1	1	1
12/25/2020 02:00	0.5	12.4	2,037.2	0.3	1.6	1	1	1
12/25/2020 03:00	0.0	13.7	1,716.1	0.2	0.0	1	1	0
12/25/2020 04:00	0.3	13.2	1,853.4	0.2	1.0	1	1	1
12/25/2020 05:00	0.6	12.2	2,085.6	0.2	1.9	1	1	1
12/25/2020 06:00	0.6	12.4	2,052.0	0.3	1.9	1	1	1
12/25/2020 07:00	0.0	13.6	1,674.1	0.3	0.0	1	1	0
12/25/2020 08:00	0.1	13.6	1,637.7	0.2	0.3	1	1	0
12/25/2020 09:00	0.1	13.6	1,635.5	0.1	0.3	1	1	0
12/25/2020 10:00	0.2	13.6	1,611.6	0.1	0.6	1	1	0
12/25/2020 11:00	0.1	13.6	1,692.9	0.1	0.3	1	1	0
12/25/2020 12:00	0.1	13.6	1,698.4	0.1	0.3	1	1	0
12/25/2020 13:00	0.1	13.6	1,699.7	0.1	0.3	1	1	0
12/25/2020 14:00	0.1	13.6	1,653.5	0.1	0.3	1	1	0
12/25/2020 15:00	0.2	13.4	1,754.2	0.1	0.6	1	1	1
12/25/2020 16:00	0.7	12.3	2,060.1	0.3	2.2	1	1	1
12/25/2020 17:00	0.6	12.0	2,120.1	0.4	1.9	1	1	1
12/25/2020 18:00	0.6	12.2	2,084.3	0.4	1.9	1	1	1
12/25/2020 19:00	0.5	11.9	2,139.0	0.4	1.6	1	1	1
12/25/2020 20:00	0.6	12.7	1,944.5	0.4	1.9	1	1	1
12/25/2020 21:00	0.0	13.6	1,713.2	0.2	0.0	1	1	0
12/25/2020 22:00	0.3	13.2	1,833.8	0.2	0.9	1	1	1
12/25/2020 23:00	0.6	12.8	1,965.9	0.2	1.9	1	1	1
Average/Sum#:	0.3	13.0	1,869.2	0.2	24.9 #	24 #	24 #	14 #
Minimum:	0.0	11.9	1,611.6	0.1	0.0	1	1	0
Maximum:	0.7	13.7	2,139.0	0.4	2.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0.5	12.3	2,052.3	0.3	1.6	1	1	1
12/26/2020 01:00	0.6	12.8	1,917.7	0.4	1.9	1	1	1
12/26/2020 02:00	0.0	13.6	1,703.0	0.2	0.0	1	1	0
12/26/2020 03:00	0.1	13.4	1,788.8	0.2	0.3	1	1	1
12/26/2020 04:00	0.6	12.3	2,051.2	0.2	1.9	1	1	1
12/26/2020 05:00	0.6	12.9	1,949.9	0.3	1.9	1	1	1
12/26/2020 06:00	0.0	13.7	1,712.1	0.3	0.0	1	1	0
12/26/2020 07:00	0.0	13.7	1,676.7	0.1	0.0	1	1	0
12/26/2020 08:00	0.0	13.7	1,621.9	0.0	0.0	1	1	0
12/26/2020 09:00	0.0	13.7	1,677.0	0.0	0.0	1	1	0
12/26/2020 10:00	0.0	13.7	1,577.0	0.0	0.0	1	1	0
12/26/2020 11:00	0.0	13.7	1,467.6	0.0	0.0	1	1	0
12/26/2020 12:00	0.0	13.7	1,594.3	0.0	0.0	1	1	0
12/26/2020 13:00	0.0	13.7	1,702.3	0.0	0.0	1	1	0
12/26/2020 14:00	0.0	13.7	1,676.4	0.0	0.0	1	1	0
12/26/2020 15:00	0.0	13.7	1,595.0	0.0	0.0	1	1	0
12/26/2020 16:00	0.1	13.5	1,699.8	0.0	0.3	1	1	1
12/26/2020 17:00	0.6	12.4	2,073.9	0.2	1.9	1	1	1
12/26/2020 18:00	0.5	12.7	2,006.4	0.3	1.6	1	1	1
12/26/2020 19:00	0.5	12.3	2,085.2	0.4	1.6	1	1	1
12/26/2020 20:00	0.5	12.4	2,087.7	0.3	1.6	1	1	1
12/26/2020 21:00	0.5	12.4	2,072.5	0.3	1.6	1	1	1
12/26/2020 22:00	0.5	12.3	2,100.8	0.3	1.6	1	1	1
12/26/2020 23:00	0.5	12.4	2,073.9	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.1	1,831.8	0.2	19.4 #	24 #	24 #	13 #
Minimum:	0.0	12.3	1,467.6	0.0	0.0	1	1	0
Maximum:	0.6	13.7	2,100.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0.5	12.4	2,072.8	0.3	1.6	1	1	1
12/27/2020 01:00	0.5	12.4	2,065.2	0.3	1.6	1	1	1
12/27/2020 02:00	0.5	13.0	1,924.8	0.3	1.6	1	1	1
12/27/2020 03:00	0.0	13.7	1,718.1	0.2	0.0	1	1	0
12/27/2020 04:00	0.2	13.4	1,738.2	0.2	0.6	1	1	1
12/27/2020 05:00	0.6	12.2	2,075.3	0.2	1.9	1	1	1
12/27/2020 06:00	0.5	12.3	2,072.3	0.3	1.6	1	1	1
12/27/2020 07:00	0.0	13.6	1,709.0	0.2	0.0	1	1	1
12/27/2020 08:00	0.0	13.7	1,705.6	0.1	0.0	1	1	0
12/27/2020 09:00	0.0	13.6	1,676.0	0.0	0.0	1	1	0
12/27/2020 10:00	0.0	13.7	1,620.6	0.0	0.0	1	1	0
12/27/2020 11:00	0.0	13.7	1,653.1	0.0	0.0	1	1	0
12/27/2020 12:00	0.0	13.7	1,698.9	0.0	0.0	1	1	0
12/27/2020 13:00	0.0	13.7	1,622.9	0.0	0.0	1	1	0
12/27/2020 14:00	0.0	13.7	1,695.8	0.0	0.0	1	1	0
12/27/2020 15:00	0.2	13.5	1,735.3	0.1	0.6	1	1	1
12/27/2020 16:00	0.6	12.3	2,081.3	0.2	1.9	1	1	1
12/27/2020 17:00	0.6	11.9	2,164.3	0.3	1.9	1	1	1
12/27/2020 18:00	0.5	11.8	2,180.7	0.4	1.6	1	1	1
12/27/2020 19:00	0.4	11.4	2,257.6	0.3	1.3	1	1	1
12/27/2020 20:00	0.4	11.8	2,132.8	0.3	1.2	1	1	1
12/27/2020 21:00	0.0	13.7	1,718.6	0.2	0.0	1	1	0
12/27/2020 22:00	0.2	13.1	1,863.6	0.2	0.6	1	1	1
12/27/2020 23:00	0.5	12.0	2,130.0	0.2	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,888.0	0.2	19.6 #	24 #	24 #	15 #
Minimum:	0.0	11.4	1,620.6	0.0	0.0	1	1	0
Maximum:	0.6	13.7	2,257.6	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0.5	12.5	1,992.2	0.3	1.6	1	1	1
12/28/2020 01:00	0.0	13.7	1,667.1	0.2	0.0	1	1	0
12/28/2020 02:00	0.1	13.2	1,853.2	0.2	0.3	1	1	1
12/28/2020 03:00	0.5	12.3	2,077.2	0.1	1.6	1	1	1
12/28/2020 04:00	0.5	12.7	1,943.2	0.3	1.6	1	1	1
12/28/2020 05:00	0.0	13.7	1,722.4	0.2	0.0	1	1	0
12/28/2020 06:00	0.2	13.2	1,844.7	0.2	0.6	1	1	1
12/28/2020 07:00	0.5	11.6	2,208.7	0.2	1.6	1	1	1
12/28/2020 08:00	0.4	11.8	2,170.8	0.3	1.3	1	1	1
12/28/2020 09:00	0.4	12.4	2,020.5	0.3	1.3	1	1	1
12/28/2020 10:00	0.0	13.7	1,677.1	0.2	0.0	1	1	0
12/28/2020 11:00	0.0	13.7	1,685.5	0.1	0.0	1	1	0
12/28/2020 12:00	0.0	13.7	1,707.0	0.0	0.0	1	1	0
12/28/2020 13:00	0.0	13.7	1,685.5	0.0	0.0	1	1	0
12/28/2020 14:00	0.0	13.7	1,704.9	0.0	0.0	1	1	0
12/28/2020 15:00	0.1	13.3	1,792.3	0.0	0.3	1	1	1
12/28/2020 16:00	0.5	12.3	2,081.9	0.1	1.6	1	1	1
12/28/2020 17:00	0.4	11.3	2,274.7	0.2	1.3	1	1	1
12/28/2020 18:00	0.3	11.3	2,278.9	0.2	0.9	1	1	1
12/28/2020 19:00	0.3	11.3	2,282.4	0.2	0.9	1	1	1
12/28/2020 20:00	0.3	11.3	2,272.8	0.2	0.9	1	1	1
12/28/2020 21:00	0.3	11.4	2,250.2	0.2	0.9	1	1	1
12/28/2020 22:00	0.4	11.6	2,216.6	0.2	1.3	1	1	1
12/28/2020 23:00	0.4	11.9	2,157.0	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.6	1,982.0	0.2	19.3 #	24 #	24 #	17 #
Minimum:	0.0	11.3	1,667.1	0.0	0.0	1	1	0
Maximum:	0.5	13.7	2,282.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0.4	11.9	2,152.9	0.3	1.3	1	1	1
12/29/2020 01:00	0.4	12.2	2,071.7	0.3	1.3	1	1	1
12/29/2020 02:00	0.0	13.7	1,725.2	0.2	0.0	1	1	0
12/29/2020 03:00	0.2	13.3	1,860.4	0.2	0.6	1	1	1
12/29/2020 04:00	0.5	12.1	2,131.0	0.2	1.6	1	1	1
12/29/2020 05:00	0.5	12.1	2,154.0	0.3	1.6	1	1	1
12/29/2020 06:00	0.4	11.5	2,278.5	0.3	1.3	1	1	1
12/29/2020 07:00	0.4	11.7	2,235.2	0.3	1.3	1	1	1
12/29/2020 08:00	0.4	11.8	2,209.9	0.3	1.3	1	1	1
12/29/2020 09:00	0.1	13.2	1,807.9	0.2	0.3	1	1	1
12/29/2020 10:00	0.0	13.7	1,702.2	0.1	0.0	1	1	0
12/29/2020 11:00	0.0	13.7	1,684.2	0.0	0.0	1	1	0
12/29/2020 12:00	0.0	13.8	1,706.6	0.0	0.0	1	1	0
12/29/2020 13:00	0.0	13.8	1,658.9	0.0	0.0	1	1	0
12/29/2020 14:00	0.0	13.8	1,695.0	0.0	0.0	1	1	0
12/29/2020 15:00	0.0	13.8	1,688.9	0.0	0.0	1	1	0
12/29/2020 16:00	0.0	13.5	1,711.9	0.0	0.0	1	1	1
12/29/2020 17:00	0.5	11.9	2,171.7	0.1	1.6	1	1	1
12/29/2020 18:00	0.3	11.4	2,267.8	0.2	0.9	1	1	1
12/29/2020 19:00	0.3	11.4	2,270.1	0.2	0.9	1	1	1
12/29/2020 20:00	0.4	11.9	2,173.5	0.2	1.3	1	1	1
12/29/2020 21:00	0.4	12.2	2,106.8	0.3	1.3	1	1	1
12/29/2020 22:00	0.4	12.2	2,108.8	0.3	1.3	1	1	1
12/29/2020 23:00	0.4	12.5	2,073.1	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.6	1,985.3	0.2	19.2 #	24 #	24 #	17 #
Minimum:	0.0	11.4	1,658.9	0.0	0.0	1	1	0
Maximum:	0.5	13.8	2,278.5	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0.4	12.6	2,062.9	0.3	1.3	1	1	1
12/30/2020 01:00	0.6	13.1	1,930.0	0.4	2.0	1	1	1
12/30/2020 02:00	0.0	13.7	1,711.6	0.3	0.0	1	1	0
12/30/2020 03:00	0.3	13.5	1,732.5	0.2	0.9	1	1	1
12/30/2020 04:00	0.6	12.8	2,041.6	0.2	2.0	1	1	1
12/30/2020 05:00	0.5	12.5	2,068.3	0.3	1.6	1	1	1
12/30/2020 06:00	0.6	12.0	2,204.9	0.4	2.0	1	1	1
12/30/2020 07:00	0.6	12.4	2,112.0	0.4	2.0	1	1	1
12/30/2020 08:00	0.6	12.7	2,041.4	0.4	2.0	1	1	1
12/30/2020 09:00	0.9	13.0	1,952.5	0.5	2.9	1	1	1
12/30/2020 10:00	0.0	13.7	1,721.6	0.4	0.0	1	1	0
12/30/2020 11:00	0.0	13.7	1,703.1	0.2	0.0	1	1	0
12/30/2020 12:00	0.0	13.7	1,700.5	0.0	0.0	1	1	0
12/30/2020 13:00	0.0	13.7	1,660.7	0.0	0.0	1	1	0
12/30/2020 14:00	0.0	13.7	1,660.4	0.0	0.0	1	1	0
12/30/2020 15:00	0.2	13.5	1,735.1	0.1	0.6	1	1	1
12/30/2020 16:00	0.6	12.5	2,046.4	0.2	1.9	1	1	1
12/30/2020 17:00	0.6	11.9	2,165.5	0.3	1.9	1	1	1
12/30/2020 18:00	0.5	11.9	2,154.1	0.4	1.6	1	1	1
12/30/2020 19:00	0.5	12.3	2,077.2	0.3	1.6	1	1	1
12/30/2020 20:00	0.5	12.2	2,100.2	0.3	1.6	1	1	1
12/30/2020 21:00	0.5	12.2	2,092.7	0.3	1.6	1	1	1
12/30/2020 22:00	0.5	12.3	2,065.3	0.3	1.6	1	1	1
12/30/2020 23:00	0.5	12.5	2,055.5	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,949.8	0.3	30.7 #	24 #	24 #	18 #
Minimum:	0.0	11.9	1,660.4	0.0	0.0	1	1	0
Maximum:	0.9	13.7	2,204.9	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0.7	13.0	1,924.4	0.4	2.3	1	1	1
12/31/2020 01:00	0.0	13.6	1,644.1	0.3	0.0	1	1	0
12/31/2020 02:00	0.4	13.3	1,843.4	0.3	1.3	1	1	1
12/31/2020 03:00	0.8	13.0	1,948.6	0.3	2.6	1	1	1
12/31/2020 04:00	0.8	13.0	1,928.5	0.5	2.6	1	1	1
12/31/2020 05:00	0.0	13.6	1,712.4	0.4	0.0	1	1	0
12/31/2020 06:00	0.1	13.6	1,702.8	0.2	0.3	1	1	0
12/31/2020 07:00	0.1	13.6	1,661.0	0.1	0.3	1	1	0
12/31/2020 08:00	0.1	13.7	1,616.7	0.1	0.3	1	1	0
12/31/2020 09:00	0.0	13.7	1,683.3	0.1	0.0	1	1	0
12/31/2020 10:00	0.0	13.7	1,705.5	0.0	0.0	1	1	0
12/31/2020 11:00	0.0	13.7	1,700.2	0.0	0.0	1	1	0
12/31/2020 12:00	0.0	13.7	1,664.4	0.0	0.0	1	1	0
12/31/2020 13:00	0.0	13.7	1,650.5	0.0	0.0	1	1	0
12/31/2020 14:00	0.0	13.7	1,663.6	0.0	0.0	1	1	0
12/31/2020 15:00	0.0	13.7	1,708.6	0.0	0.0	1	1	0
12/31/2020 16:00	0.2	13.2	1,845.1	0.1	0.6	1	1	1
12/31/2020 17:00	0.6	12.1	2,115.1	0.2	1.9	1	1	1
12/31/2020 18:00	0.5	11.9	2,170.2	0.3	1.6	1	1	1
12/31/2020 19:00	0.5	11.9	2,169.0	0.3	1.6	1	1	1
12/31/2020 20:00	0.5	11.9	2,170.8	0.3	1.6	1	1	1
12/31/2020 21:00	0.5	11.9	2,167.5	0.3	1.6	1	1	1
12/31/2020 22:00	0.5	12.1	2,135.4	0.3	1.6	1	1	1
12/31/2020 23:00	0.5	12.2	2,096.1	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.1	1,859.5	0.2	21.8 #	24 #	24 #	12 #
Minimum:	0.0	11.9	1,616.7	0.0	0.0	1	1	0
Maximum:	0.8	13.7	2,170.8	0.5	2.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	0.3	13.9	1,618.5	0.3	0.9	1	1	0
10/01/2020 01:00	0.4	13.3	1,765.8	0.3	1.2	1	1	1
10/01/2020 02:00	0.3	12.6	1,963.0	0.3	0.9	1	1	1
10/01/2020 03:00	0.2	12.4	1,975.4	0.2	0.6	1	1	1
10/01/2020 04:00	0.2	13.9	1,648.7	0.2	0.6	1	1	0
10/01/2020 05:00	0.5	13.4	1,805.5	0.2	1.6	1	1	1
10/01/2020 06:00	0.5	12.5	2,048.9	0.3	1.6	1	1	1
10/01/2020 07:00	0.5	13.0	1,834.6	0.4	1.5	1	1	1
10/01/2020 08:00	0.3	13.9	1,538.0	0.4	0.9	1	1	0
10/01/2020 09:00	0.2	14.0	1,318.5	0.3	0.5	1	1	0
10/01/2020 10:00	0.2	13.9	1,496.3	0.2	0.6	1	1	1
10/01/2020 11:00	0.5	12.5	2,026.6	0.3	1.6	1	1	1
10/01/2020 12:00	0.4	12.1	2,106.3	0.3	1.3	1	1	1
10/01/2020 13:00	0.4	11.9	2,141.9	0.3	1.3	1	1	1
10/01/2020 14:00	0.4	11.8	2,147.8	0.3	1.2	1	1	1
10/01/2020 15:00	0.4	11.9	2,120.4	0.3	1.2	1	1	1
10/01/2020 16:00	0.4	12.0	2,103.1	0.3	1.2	1	1	1
10/01/2020 17:00	0.4	12.0	2,097.1	0.3	1.2	1	1	1
10/01/2020 18:00	0.4	12.2	2,071.7	0.3	1.3	1	1	1
10/01/2020 19:00	0.4	12.1	2,076.0	0.3	1.2	1	1	1
10/01/2020 20:00	0.4	12.1	2,087.3	0.3	1.3	1	1	1
10/01/2020 21:00	0.4	12.2	2,088.7	0.3	1.3	1	1	1
10/01/2020 22:00	0.5	12.3	2,065.0	0.3	1.6	1	1	1
10/01/2020 23:00	0.5	12.6	1,987.4	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.7	1,922.2	0.3	28.2 #	24 #	24 #	20 #
Minimum:	0.2	11.8	1,318.5	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,147.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	0.3	13.8	1,574.6	0.3	0.9	1	1	0
10/02/2020 01:00	0.3	13.8	1,698.7	0.3	0.9	1	1	0
10/02/2020 02:00	0.3	13.9	1,537.3	0.2	0.9	1	1	0
10/02/2020 03:00	0.3	13.9	1,579.8	0.3	0.9	1	1	0
10/02/2020 04:00	0.4	13.6	1,665.0	0.3	1.2	1	1	1
10/02/2020 05:00	0.6	12.6	2,033.1	0.3	1.9	1	1	1
10/02/2020 06:00	0.6	12.7	1,991.3	0.4	1.9	1	1	1
10/02/2020 07:00	0.3	13.8	1,751.4	0.3	1.0	1	1	0
10/02/2020 08:00	0.3	13.9	1,464.0	0.3	0.8	1	1	0
10/02/2020 09:00	0.2	14.0	1,584.4	0.2	0.6	1	1	0
10/02/2020 10:00	0.2	14.0	1,617.5	0.2	0.6	1	1	0
10/02/2020 11:00	0.3	13.6	1,668.7	0.2	0.9	1	1	1
10/02/2020 12:00	0.5	12.2	2,072.1	0.2	1.6	1	1	1
10/02/2020 13:00	0.4	11.8	2,164.4	0.3	1.3	1	1	1
10/02/2020 14:00	0.4	11.7	2,157.9	0.3	1.2	1	1	1
10/02/2020 15:00	0.4	11.8	2,137.7	0.3	1.2	1	1	1
10/02/2020 16:00	0.4	11.8	2,139.0	0.3	1.2	1	1	1
10/02/2020 17:00	0.3	11.8	2,142.9	0.3	0.9	1	1	1
10/02/2020 18:00	0.4	12.0	2,110.0	0.3	1.3	1	1	1
10/02/2020 19:00	0.4	12.1	2,085.0	0.3	1.3	1	1	1
10/02/2020 20:00	0.4	12.1	2,090.1	0.3	1.3	1	1	1
10/02/2020 21:00	0.5	12.4	2,028.9	0.3	1.6	1	1	1
10/02/2020 22:00	0.5	12.4	2,047.1	0.3	1.6	1	1	1
10/02/2020 23:00	0.5	12.3	2,056.7	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,891.6	0.3	28.6 #	24 #	24 #	16 #
Minimum:	0.2	11.7	1,464.0	0.2	0.6	1	1	0
Maximum:	0.6	14.0	2,164.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	5.4	14.1	1,257.5	0.0	6.6	1	0	1
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/03/2020 12:00	13.8	17.7	455.8	0.0	15.1	1	0	0
10/03/2020 13:00	9.7	14.6	1,149.2	0.0	23.4	1	0	0
10/03/2020 14:00	0.2	13.9	1,610.8	0.0	0.6	1	1	0
10/03/2020 15:00	0.3	13.6	1,631.8	0.0	0.9	1	1	1
10/03/2020 16:00	0.4	12.1	2,072.1	0.2	1.2	1	1	1
10/03/2020 17:00	0.3	11.8	2,152.4	0.2	0.9	1	1	1
10/03/2020 18:00	0.3	11.9	2,135.4	0.2	0.9	1	1	1
10/03/2020 19:00	0.4	11.9	2,138.9	0.2	1.3	1	1	1
10/03/2020 20:00	0.4	12.2	2,076.3	0.3	1.3	1	1	1
10/03/2020 21:00	0.5	12.5	2,009.6	0.3	1.6	1	1	1
10/03/2020 22:00	4.2	13.8	1,437.2	0.0	8.4	1	0	1
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	3.0	13.3	1,677.3	0.2	62.2 #	12 #	8 #	9 #
Minimum:	0.2	11.8	455.8	0.2	0.6	0	0	0
Maximum:	13.8	17.7	2,152.4	0.3	23.4	1	1	1
%SI	50.00	50.00	50.00	75.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/04/2020 13:00	24.7	17.0	534.1	0.0	38.9	1	0	0
10/04/2020 14:00	2.8	14.1	1,394.0	0.0	7.6	1	0	0
10/04/2020 15:00	0.3	13.8	1,700.8	0.0	0.9	1	1	0
10/04/2020 16:00	0.5	13.1	1,814.1	0.0	1.5	1	1	1
10/04/2020 17:00	0.5	12.1	2,087.0	0.3	1.6	1	1	1
10/04/2020 18:00	0.5	12.4	2,024.0	0.3	1.6	1	1	1
10/04/2020 19:00	0.5	12.5	2,017.4	0.3	1.6	1	1	1
10/04/2020 20:00	0.5	12.4	2,020.3	0.3	1.6	1	1	1
10/04/2020 21:00	0.5	12.3	2,047.7	0.3	1.6	1	1	1
10/04/2020 22:00	0.6	12.9	1,926.2	0.3	1.9	1	1	1
10/04/2020 23:00	0.6	13.0	1,899.0	0.4	1.9	1	1	1
Average/Sum#:	2.9	13.2	1,769.5	0.3	60.7 #	11 #	9 #	8 #
Minimum:	0.3	12.1	534.1	0.3	0.9	0	0	0
Maximum:	24.7	17.0	2,087.0	0.4	38.9	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	0.3	13.9	1,649.9	0.4	0.9	1	1	0
10/05/2020 01:00	0.3	13.9	1,639.6	0.3	0.9	1	1	0
10/05/2020 02:00	0.3	13.9	1,590.4	0.3	0.9	1	1	0
10/05/2020 03:00	0.3	14.0	1,566.2	0.3	0.9	1	1	0
10/05/2020 04:00	0.4	13.7	1,664.3	0.3	1.2	1	1	1
10/05/2020 05:00	0.6	12.6	2,041.3	0.3	1.9	1	1	1
10/05/2020 06:00	0.5	12.5	2,025.0	0.4	1.6	1	1	1
10/05/2020 07:00	0.3	13.9	1,538.7	0.4	0.9	1	1	0
10/05/2020 08:00	0.2	13.9	1,529.4	0.3	0.6	1	1	0
10/05/2020 09:00	0.2	13.9	1,587.6	0.2	0.6	1	1	0
10/05/2020 10:00	0.2	14.0	1,577.6	0.2	0.6	1	1	0
10/05/2020 11:00	0.2	13.9	1,623.9	0.2	0.6	1	1	0
10/05/2020 12:00	0.3	13.9	1,653.1	0.2	0.9	1	1	0
10/05/2020 13:00	0.5	13.2	1,791.3	0.3	1.5	1	1	1
10/05/2020 14:00	0.4	11.9	2,153.9	0.3	1.3	1	1	1
10/05/2020 15:00	0.3	11.8	2,164.4	0.3	0.9	1	1	1
10/05/2020 16:00	0.3	11.8	2,160.9	0.2	0.9	1	1	1
10/05/2020 17:00	0.3	11.9	2,137.8	0.2	0.9	1	1	1
10/05/2020 18:00	0.3	11.8	2,151.7	0.2	0.9	1	1	1
10/05/2020 19:00	0.4	12.4	2,040.2	0.2	1.3	1	1	1
10/05/2020 20:00	0.4	12.4	2,038.1	0.3	1.3	1	1	1
10/05/2020 21:00	0.5	12.5	2,042.9	0.3	1.6	1	1	1
10/05/2020 22:00	5.2	14.1	1,243.9	0.0	6.3	1	0	1
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.1	1,809.2	0.3	29.4 #	23 #	22 #	13 #
Minimum:	0.2	11.8	1,243.9	0.2	0.6	0	0	0
Maximum:	5.2	14.1	2,164.4	0.4	6.3	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/06/2020 11:00	13.2	17.2	504.7	0.0	17.4	1	0	0
10/06/2020 12:00	4.7	14.3	1,333.6	0.0	12.5	1	0	0
10/06/2020 13:00	0.2	13.9	1,639.2	0.0	0.6	1	1	0
10/06/2020 14:00	0.4	13.6	1,732.8	0.0	1.3	1	1	1
10/06/2020 15:00	0.5	12.2	2,090.8	0.3	1.6	1	1	1
10/06/2020 16:00	0.3	11.9	2,135.4	0.3	0.9	1	1	1
10/06/2020 17:00	0.3	11.8	2,151.9	0.2	0.9	1	1	1
10/06/2020 18:00	0.3	11.8	2,152.4	0.2	0.9	1	1	1
10/06/2020 19:00	0.4	11.9	2,125.6	0.2	1.2	1	1	1
10/06/2020 20:00	0.3	13.6	1,657.4	0.2	0.9	1	1	1
10/06/2020 21:00	0.5	13.3	1,800.0	0.3	1.6	1	1	1
10/06/2020 22:00	0.5	12.4	2,057.1	0.3	1.6	1	1	1
10/06/2020 23:00	0.6	12.8	1,972.4	0.4	1.9	1	1	1
Average/Sum#:	1.7	13.1	1,796.4	0.3	43.3 #	13 #	11 #	10 #
Minimum:	0.2	11.8	504.7	0.2	0.6	0	0	0
Maximum:	13.2	17.2	2,152.4	0.4	17.4	1	1	1
%SI	45.83	45.83	45.83	62.50	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	0.5	12.6	2,020.8	0.4	1.6	1	1	1
10/07/2020 01:00	0.5	12.8	1,953.3	0.4	1.6	1	1	1
10/07/2020 02:00	0.3	13.9	1,524.9	0.4	0.9	1	1	0
10/07/2020 03:00	0.2	14.0	1,592.4	0.3	0.6	1	1	0
10/07/2020 04:00	0.5	13.3	1,815.9	0.3	1.6	1	1	1
10/07/2020 05:00	0.5	12.3	2,095.6	0.3	1.6	1	1	1
10/07/2020 06:00	0.5	12.7	2,017.7	0.4	1.6	1	1	1
10/07/2020 07:00	0.3	13.9	1,587.0	0.3	0.9	1	1	0
10/07/2020 08:00	0.2	14.0	1,356.8	0.3	0.5	1	1	0
10/07/2020 09:00	0.2	14.0	1,292.7	0.2	0.5	1	1	0
10/07/2020 10:00	0.1	14.0	1,349.1	0.2	0.3	1	1	0
10/07/2020 11:00	0.4	13.4	1,759.4	0.2	1.2	1	1	1
10/07/2020 12:00	0.4	12.0	2,126.6	0.2	1.3	1	1	1
10/07/2020 13:00	0.4	11.9	2,135.4	0.3	1.3	1	1	1
10/07/2020 14:00	0.3	13.5	1,690.8	0.3	0.9	1	1	1
10/07/2020 15:00	0.5	13.2	1,774.8	0.3	1.5	1	1	1
10/07/2020 16:00	0.5	12.2	2,058.2	0.3	1.6	1	1	1
10/07/2020 17:00	0.4	11.9	2,125.6	0.3	1.2	1	1	1
10/07/2020 18:00	0.4	12.1	2,083.9	0.3	1.3	1	1	1
10/07/2020 19:00	0.5	12.3	2,015.1	0.3	1.5	1	1	1
10/07/2020 20:00	0.3	13.9	1,669.8	0.3	0.9	1	1	0
10/07/2020 21:00	0.5	13.3	1,804.7	0.3	1.6	1	1	1
10/07/2020 22:00	0.5	12.3	2,073.8	0.3	1.6	1	1	1
10/07/2020 23:00	5.1	14.2	1,205.7	0.0	6.1	1	0	1
Average/Sum#:	0.6	13.1	1,797.1	0.3	33.7 #	24 #	23 #	17 #
Minimum:	0.1	11.9	1,205.7	0.2	0.3	1	0	0
Maximum:	5.1	14.2	2,135.4	0.4	6.1	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2020 01:00	69.6	17.6	450.9	0.0	87.9	1	0	0
10/11/2020 02:00	20.4	16.3	628.2	0.0	36.8	1	0	0
10/11/2020 03:00	36.9	15.7	709.1	0.0	66.5	1	0	0
10/11/2020 04:00	31.1	15.4	869.3	0.0	64.9	1	0	0
10/11/2020 05:00	0.2	14.0	1,351.9	0.0	0.5	1	1	0
10/11/2020 06:00	0.2	14.0	1,340.8	0.0	0.5	1	1	0
10/11/2020 07:00	0.2	14.0	1,337.8	0.2	0.5	1	1	0
10/11/2020 08:00	0.2	14.0	1,338.1	0.2	0.5	1	1	0
10/11/2020 09:00	0.1	14.0	1,340.5	0.2	0.3	1	1	0
10/11/2020 10:00	0.1	14.0	1,343.3	0.1	0.3	1	1	0
10/11/2020 11:00	0.1	14.0	1,346.4	0.1	0.3	1	1	0
10/11/2020 12:00	0.1	14.0	1,348.2	0.1	0.3	1	1	0
10/11/2020 13:00	0.1	14.1	1,349.6	0.1	0.3	1	1	0
10/11/2020 14:00	0.1	14.1	1,351.7	0.1	0.3	1	1	0
10/11/2020 15:00	0.1	14.1	1,366.6	0.1	0.3	1	1	0
10/11/2020 16:00	0.8	13.0	1,928.8	0.3	2.6	1	1	1
10/11/2020 17:00	0.8	13.0	1,938.8	0.4	2.6	1	1	1
10/11/2020 18:00	0.8	13.0	1,926.5	0.6	2.6	1	1	1
10/11/2020 19:00	0.8	13.0	1,907.7	0.6	2.6	1	1	1
10/11/2020 20:00	0.3	14.0	1,352.7	0.5	0.8	1	1	0
10/11/2020 21:00	0.2	14.0	1,335.6	0.4	0.5	1	1	0
10/11/2020 22:00	0.2	14.0	1,335.7	0.2	0.5	1	1	0
10/11/2020 23:00	0.2	14.0	1,335.0	0.2	0.5	1	1	0
Average/Sum#:	7.1	14.2	1,327.5	0.3	272.9 #	23 #	19 #	4 #
Minimum:	0.1	13.0	450.9	0.1	0.3	0	0	0
Maximum:	69.6	17.6	1,938.8	0.6	87.9	1	1	1
%SI	4.17	4.17	4.17	29.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0.2	14.0	1,335.1	0.2	0.5	1	1	0
10/12/2020 01:00	0.2	14.0	1,335.8	0.2	0.5	1	1	0
10/12/2020 02:00	0.2	14.0	1,335.6	0.2	0.5	1	1	0
10/12/2020 03:00	0.2	14.0	1,334.0	0.2	0.5	1	1	0
10/12/2020 04:00	0.2	14.0	1,334.5	0.2	0.5	1	1	0
10/12/2020 05:00	0.2	14.0	1,333.0	0.2	0.5	1	1	0
10/12/2020 06:00	0.2	14.0	1,332.0	0.2	0.5	1	1	0
10/12/2020 07:00	0.2	14.0	1,337.7	0.2	0.5	1	1	0
10/12/2020 08:00	0.2	14.0	1,337.5	0.2	0.5	1	1	0
10/12/2020 09:00	0.2	14.0	1,342.6	0.2	0.5	1	1	0
10/12/2020 10:00	0.2	14.0	1,346.6	0.2	0.5	1	1	0
10/12/2020 11:00	0.1	14.0	1,347.3	0.2	0.3	1	1	0
10/12/2020 12:00	0.2	14.0	1,604.1	0.2	0.6	1	1	0
10/12/2020 13:00	0.2	14.0	1,533.8	0.2	0.6	1	1	0
10/12/2020 14:00	0.2	14.0	1,563.5	0.2	0.6	1	1	0
10/12/2020 15:00	0.4	13.6	1,651.4	0.2	1.2	1	1	1
10/12/2020 16:00	0.6	12.6	2,006.2	0.3	1.9	1	1	1
10/12/2020 17:00	0.6	12.6	1,992.1	0.4	1.9	1	1	1
10/12/2020 18:00	0.6	12.7	1,979.4	0.4	1.9	1	1	1
10/12/2020 19:00	0.6	12.9	1,914.1	0.4	1.9	1	1	1
10/12/2020 20:00	0.3	13.8	1,742.0	0.3	1.0	1	1	0
10/12/2020 21:00	0.5	13.4	1,787.9	0.3	1.6	1	1	1
10/12/2020 22:00	0.6	12.7	1,987.3	0.3	1.9	1	1	1
10/12/2020 23:00	0.6	12.9	1,949.8	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.6	1,573.5	0.3	22.8 #	24 #	24 #	8 #
Minimum:	0.1	12.6	1,332.0	0.2	0.3	1	1	0
Maximum:	0.6	14.0	2,006.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	0.3	13.9	1,656.6	0.4	0.9	1	1	0
10/13/2020 01:00	0.3	13.9	1,609.3	0.3	0.9	1	1	0
10/13/2020 02:00	0.2	13.9	1,386.6	0.3	0.5	1	1	0
10/13/2020 03:00	0.2	13.9	1,592.3	0.2	0.6	1	1	0
10/13/2020 04:00	0.5	13.4	1,797.1	0.3	1.6	1	1	1
10/13/2020 05:00	0.6	12.8	1,978.1	0.3	1.9	1	1	1
10/13/2020 06:00	0.6	13.0	1,931.3	0.4	1.9	1	1	1
10/13/2020 07:00	0.3	13.9	1,637.2	0.4	0.9	1	1	0
10/13/2020 08:00	0.3	13.9	1,474.1	0.3	0.8	1	1	0
10/13/2020 09:00	0.2	14.0	1,343.1	0.3	0.5	1	1	0
10/13/2020 10:00	0.3	13.9	1,610.2	0.3	0.9	1	1	0
10/13/2020 11:00	0.3	13.9	1,489.4	0.3	0.8	1	1	0
10/13/2020 12:00	0.3	13.9	1,490.4	0.3	0.8	1	1	0
10/13/2020 13:00	0.2	14.0	1,397.9	0.3	0.5	1	1	0
10/13/2020 14:00	0.3	13.9	1,602.2	0.3	0.9	1	1	0
10/13/2020 15:00	0.4	13.6	1,639.2	0.3	1.2	1	1	1
10/13/2020 16:00	0.6	12.5	2,022.3	0.3	1.9	1	1	1
10/13/2020 17:00	0.5	12.4	2,035.1	0.3	1.6	1	1	1
10/13/2020 18:00	0.5	12.5	2,007.6	0.4	1.6	1	1	1
10/13/2020 19:00	0.5	12.8	1,940.0	0.4	1.6	1	1	1
10/13/2020 20:00	0.2	13.9	1,690.7	0.3	0.6	1	1	0
10/13/2020 21:00	0.4	13.4	1,800.7	0.3	1.3	1	1	1
10/13/2020 22:00	0.4	12.2	2,106.2	0.3	1.3	1	1	1
10/13/2020 23:00	0.5	12.8	1,938.0	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.4	1,715.7	0.3	27.1 #	24 #	24 #	11 #
Minimum:	0.2	12.2	1,343.1	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,106.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	0.2	13.9	1,664.7	0.3	0.6	1	1	0
10/14/2020 01:00	0.3	13.7	1,657.8	0.3	0.9	1	1	1
10/14/2020 02:00	0.5	12.5	2,046.2	0.3	1.6	1	1	1
10/14/2020 03:00	0.5	12.9	1,927.8	0.3	1.6	1	1	1
10/14/2020 04:00	0.2	13.9	1,595.8	0.3	0.6	1	1	0
10/14/2020 05:00	0.4	13.5	1,801.3	0.3	1.3	1	1	1
10/14/2020 06:00	0.5	12.7	2,001.0	0.3	1.6	1	1	1
10/14/2020 07:00	0.5	12.9	1,913.1	0.4	1.6	1	1	1
10/14/2020 08:00	0.1	13.9	1,409.5	0.3	0.3	1	1	0
10/14/2020 09:00	0.1	14.0	1,303.6	0.2	0.2	1	1	0
10/14/2020 10:00	0.1	14.0	1,531.6	0.1	0.3	1	1	0
10/14/2020 11:00	0.3	13.5	1,754.8	0.1	0.9	1	1	1
10/14/2020 12:00	0.4	12.1	2,097.1	0.2	1.3	1	1	1
10/14/2020 13:00	0.3	11.9	2,129.3	0.2	0.9	1	1	1
10/14/2020 14:00	0.2	13.8	1,741.2	0.2	0.6	1	1	1
10/14/2020 15:00	0.2	13.7	1,813.9	0.2	0.7	1	1	1
10/14/2020 16:00	0.5	12.1	2,106.5	0.2	1.6	1	1	1
10/14/2020 17:00	0.3	11.8	2,177.4	0.2	0.9	1	1	1
10/14/2020 18:00	0.4	12.1	2,100.8	0.3	1.3	1	1	1
10/14/2020 19:00	0.4	12.2	2,044.5	0.3	1.2	1	1	1
10/14/2020 20:00	0.2	13.9	1,680.5	0.3	0.6	1	1	0
10/14/2020 21:00	0.4	13.2	1,832.9	0.3	1.3	1	1	1
10/14/2020 22:00	0.4	12.0	2,151.6	0.3	1.3	1	1	1
10/14/2020 23:00	0.5	12.6	1,989.7	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.0	1,853.0	0.3	24.8 #	24 #	24 #	18 #
Minimum:	0.1	11.8	1,303.6	0.1	0.2	1	1	0
Maximum:	0.5	14.0	2,177.4	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	0.2	13.9	1,670.7	0.3	0.6	1	1	0
10/15/2020 01:00	0.4	13.4	1,802.1	0.3	1.3	1	1	1
10/15/2020 02:00	0.5	12.2	2,121.8	0.3	1.6	1	1	1
10/15/2020 03:00	0.5	12.3	2,071.3	0.3	1.6	1	1	1
10/15/2020 04:00	0.3	13.9	1,688.0	0.3	1.0	1	1	0
10/15/2020 05:00	0.5	13.5	1,822.9	0.3	1.6	1	1	1
10/15/2020 06:00	0.6	12.5	2,056.6	0.4	1.9	1	1	1
10/15/2020 07:00	0.5	12.9	1,849.1	0.4	1.5	1	1	1
10/15/2020 08:00	0.2	14.0	1,300.9	0.3	0.5	1	1	0
10/15/2020 09:00	0.1	14.0	1,297.9	0.2	0.2	1	1	0
10/15/2020 10:00	0.1	14.0	1,316.1	0.1	0.3	1	1	0
10/15/2020 11:00	0.2	13.9	1,561.7	0.1	0.6	1	1	0
10/15/2020 12:00	0.3	13.9	1,635.0	0.2	0.9	1	1	0
10/15/2020 13:00	0.5	13.3	1,804.6	0.3	1.6	1	1	1
10/15/2020 14:00	0.4	11.9	2,164.7	0.3	1.3	1	1	1
10/15/2020 15:00	0.4	11.8	2,175.2	0.3	1.3	1	1	1
10/15/2020 16:00	0.3	11.8	2,168.1	0.3	0.9	1	1	1
10/15/2020 17:00	0.4	11.9	2,145.0	0.3	1.3	1	1	1
10/15/2020 18:00	0.4	11.9	2,155.3	0.3	1.3	1	1	1
10/15/2020 19:00	0.4	12.0	2,132.4	0.3	1.3	1	1	1
10/15/2020 20:00	0.4	11.9	2,155.8	0.3	1.3	1	1	1
10/15/2020 21:00	0.3	11.8	2,175.1	0.3	0.9	1	1	1
10/15/2020 22:00	0.4	12.0	2,136.9	0.3	1.3	1	1	1
10/15/2020 23:00	0.4	12.4	2,014.9	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.8	1,892.6	0.3	27.4 #	24 #	24 #	17 #
Minimum:	0.1	11.8	1,297.9	0.1	0.2	1	1	0
Maximum:	0.6	14.0	2,175.2	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	0.2	13.8	1,702.4	0.3	0.6	1	1	0
10/16/2020 01:00	0.2	14.0	1,312.2	0.2	0.5	1	1	0
10/16/2020 02:00	0.2	13.8	1,680.6	0.2	0.6	1	1	0
10/16/2020 03:00	0.5	13.4	1,804.3	0.3	1.6	1	1	1
10/16/2020 04:00	0.5	12.9	1,883.6	0.3	1.6	1	1	1
10/16/2020 05:00	0.2	13.8	1,690.3	0.3	0.6	1	1	1
10/16/2020 06:00	0.4	12.4	2,029.9	0.3	1.3	1	1	1
10/16/2020 07:00	0.5	12.8	1,944.4	0.3	1.6	1	1	1
10/16/2020 08:00	0.2	13.9	1,592.7	0.3	0.6	1	1	0
10/16/2020 09:00	0.2	14.0	1,393.6	0.3	0.5	1	1	0
10/16/2020 10:00	0.1	14.0	1,504.5	0.2	0.3	1	1	0
10/16/2020 11:00	0.3	13.7	1,579.5	0.2	0.9	1	1	1
10/16/2020 12:00	0.4	12.1	2,104.8	0.2	1.3	1	1	1
10/16/2020 13:00	0.4	12.2	2,071.4	0.3	1.3	1	1	1
10/16/2020 14:00	0.3	11.9	2,126.5	0.3	0.9	1	1	1
10/16/2020 15:00	0.3	11.9	2,131.6	0.2	0.9	1	1	1
10/16/2020 16:00	0.4	12.3	2,044.6	0.2	1.3	1	1	1
10/16/2020 17:00	0.4	12.1	2,090.7	0.3	1.3	1	1	1
10/16/2020 18:00	0.4	12.2	2,079.8	0.3	1.3	1	1	1
10/16/2020 19:00	0.3	11.9	2,146.3	0.3	0.9	1	1	1
10/16/2020 20:00	0.3	12.0	2,121.0	0.2	0.9	1	1	1
10/16/2020 21:00	0.4	12.1	2,093.4	0.2	1.3	1	1	1
10/16/2020 22:00	0.4	12.3	2,048.1	0.3	1.3	1	1	1
10/16/2020 23:00	0.4	12.5	2,007.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.8	1,882.7	0.3	24.7 #	24 #	24 #	18 #
Minimum:	0.1	11.9	1,312.2	0.2	0.3	1	1	0
Maximum:	0.5	14.0	2,146.3	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	0.5	12.8	1,927.3	0.3	1.6	1	1	1
10/17/2020 01:00	0.2	13.9	1,546.0	0.3	0.6	1	1	0
10/17/2020 02:00	0.2	14.0	1,312.2	0.3	0.5	1	1	0
10/17/2020 03:00	0.2	14.0	1,607.7	0.2	0.6	1	1	0
10/17/2020 04:00	0.2	14.0	1,602.7	0.2	0.6	1	1	0
10/17/2020 05:00	0.2	13.9	1,656.1	0.2	0.6	1	1	0
10/17/2020 06:00	0.5	13.3	1,795.5	0.3	1.6	1	1	1
10/17/2020 07:00	0.4	13.0	1,842.5	0.3	1.2	1	1	1
10/17/2020 08:00	0.2	13.8	1,669.7	0.3	0.6	1	1	0
10/17/2020 09:00	0.2	13.8	1,675.8	0.2	0.6	1	1	0
10/17/2020 10:00	0.2	13.9	1,625.3	0.2	0.6	1	1	0
10/17/2020 11:00	0.2	13.9	1,479.6	0.2	0.6	1	1	0
10/17/2020 12:00	0.2	14.0	1,463.6	0.2	0.6	1	1	0
10/17/2020 13:00	0.1	14.0	1,453.4	0.2	0.3	1	1	0
10/17/2020 14:00	0.3	13.6	1,642.4	0.2	0.9	1	1	1
10/17/2020 15:00	0.4	12.1	2,088.5	0.2	1.3	1	1	1
10/17/2020 16:00	0.3	11.8	2,155.1	0.2	0.9	1	1	1
10/17/2020 17:00	0.3	11.8	2,156.5	0.2	0.9	1	1	1
10/17/2020 18:00	0.4	12.3	2,031.7	0.2	1.2	1	1	1
10/17/2020 19:00	0.4	12.3	2,048.0	0.3	1.3	1	1	1
10/17/2020 20:00	0.4	12.3	2,062.9	0.3	1.3	1	1	1
10/17/2020 21:00	0.4	12.7	1,983.4	0.3	1.3	1	1	1
10/17/2020 22:00	0.4	12.3	2,060.7	0.3	1.3	1	1	1
10/17/2020 23:00	0.4	12.3	2,058.5	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.2	1,789.4	0.2	22.3 #	24 #	24 #	13 #
Minimum:	0.1	11.8	1,312.2	0.2	0.3	1	1	0
Maximum:	0.5	14.0	2,156.5	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	0.3	13.6	1,686.2	0.3	0.9	1	1	1
10/18/2020 01:00	0.4	13.3	1,799.9	0.3	1.3	1	1	1
10/18/2020 02:00	0.3	12.0	2,148.4	0.2	1.0	1	1	1
10/18/2020 03:00	0.3	12.1	2,081.3	0.2	0.9	1	1	1
10/18/2020 04:00	0.2	13.8	1,659.3	0.2	0.6	1	1	0
10/18/2020 05:00	0.2	13.8	1,595.8	0.2	0.6	1	1	0
10/18/2020 06:00	0.2	13.8	1,553.3	0.2	0.6	1	1	0
10/18/2020 07:00	0.2	13.9	1,499.9	0.2	0.6	1	1	0
10/18/2020 08:00	0.2	13.9	1,599.2	0.2	0.6	1	1	0
10/18/2020 09:00	0.1	13.9	1,607.8	0.2	0.3	1	1	0
10/18/2020 10:00	0.1	14.0	1,573.1	0.1	0.3	1	1	0
10/18/2020 11:00	0.1	14.0	1,606.9	0.1	0.3	1	1	0
10/18/2020 12:00	0.2	13.9	1,618.8	0.1	0.6	1	1	0
10/18/2020 13:00	0.2	13.8	1,596.6	0.2	0.6	1	1	0
10/18/2020 14:00	0.2	13.8	1,629.2	0.2	0.6	1	1	0
10/18/2020 15:00	0.4	13.5	1,737.8	0.2	1.2	1	1	1
10/18/2020 16:00	0.4	12.1	2,057.6	0.3	1.2	1	1	1
10/18/2020 17:00	0.4	13.1	1,757.7	0.3	1.2	1	1	1
10/18/2020 18:00	0.1	14.0	1,284.1	0.2	0.2	1	1	0
10/18/2020 19:00	0.1	14.0	1,377.8	0.2	0.3	1	1	0
10/18/2020 20:00	0.2	13.8	1,688.6	0.1	0.6	1	1	0
10/18/2020 21:00	0.2	13.9	1,681.8	0.2	0.6	1	1	0
10/18/2020 22:00	0.1	13.9	1,485.3	0.2	0.3	1	1	0
10/18/2020 23:00	0.4	13.4	1,795.7	0.2	1.3	1	1	1
Average/Sum#:	0.2	13.6	1,671.8	0.2	16.7 #	24 #	24 #	8 #
Minimum:	0.1	12.0	1,284.1	0.1	0.2	1	1	0
Maximum:	0.4	14.0	2,148.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	0.4	13.1	1,830.2	0.2	1.2	1	1	1
10/19/2020 01:00	0.2	13.8	1,621.3	0.3	0.6	1	1	0
10/19/2020 02:00	0.2	13.8	1,573.3	0.2	0.6	1	1	0
10/19/2020 03:00	0.2	13.8	1,673.4	0.2	0.6	1	1	0
10/19/2020 04:00	0.4	13.4	1,804.0	0.2	1.3	1	1	1
10/19/2020 05:00	0.4	12.3	2,087.1	0.3	1.3	1	1	1
10/19/2020 06:00	0.4	12.4	2,052.5	0.3	1.3	1	1	1
10/19/2020 07:00	0.2	13.8	1,681.4	0.3	0.6	1	1	0
10/19/2020 08:00	0.2	13.9	1,550.3	0.2	0.6	1	1	0
10/19/2020 09:00	0.2	13.9	1,623.3	0.2	0.6	1	1	0
10/19/2020 10:00	0.1	14.0	1,615.3	0.2	0.3	1	1	0
10/19/2020 11:00	0.1	14.0	1,580.4	0.1	0.3	1	1	0
10/19/2020 12:00	0.1	14.0	1,447.0	0.1	0.3	1	1	0
10/19/2020 13:00	0.1	14.0	1,423.2	0.1	0.3	1	1	0
10/19/2020 14:00	0.3	13.7	1,636.8	0.1	0.9	1	1	1
10/19/2020 15:00	0.4	12.4	2,010.8	0.2	1.2	1	1	1
10/19/2020 16:00	0.3	12.0	2,094.6	0.2	0.9	1	1	1
10/19/2020 17:00	0.3	11.9	2,125.5	0.2	0.9	1	1	1
10/19/2020 18:00	0.3	12.1	2,073.5	0.2	0.9	1	1	1
10/19/2020 19:00	0.3	12.0	2,115.6	0.2	0.9	1	1	1
10/19/2020 20:00	0.3	13.1	1,758.0	0.2	0.9	1	1	1
10/19/2020 21:00	0.3	13.3	1,790.8	0.2	0.9	1	1	1
10/19/2020 22:00	0.4	12.4	2,039.5	0.2	1.3	1	1	1
10/19/2020 23:00	0.4	12.9	1,927.1	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.2	1,797.3	0.2	20.0 #	24 #	24 #	14 #
Minimum:	0.1	11.9	1,423.2	0.1	0.3	1	1	0
Maximum:	0.4	14.0	2,125.5	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	0.2	13.9	1,523.8	0.3	0.6	1	1	0
10/20/2020 01:00	0.1	14.0	1,294.6	0.2	0.2	1	1	0
10/20/2020 02:00	0.1	14.0	1,380.4	0.1	0.3	1	1	0
10/20/2020 03:00	0.4	13.4	1,788.3	0.2	1.3	1	1	1
10/20/2020 04:00	0.5	12.5	2,030.2	0.3	1.6	1	1	1
10/20/2020 05:00	0.4	12.5	2,055.4	0.3	1.3	1	1	1
10/20/2020 06:00	0.4	12.5	2,013.7	0.3	1.3	1	1	1
10/20/2020 07:00	0.2	13.8	1,651.6	0.3	0.6	1	1	0
10/20/2020 08:00	0.1	14.0	1,324.7	0.2	0.3	1	1	0
10/20/2020 09:00	0.1	14.0	1,451.2	0.1	0.3	1	1	0
10/20/2020 10:00	0.2	14.0	1,626.8	0.1	0.6	1	1	0
10/20/2020 11:00	0.3	13.6	1,699.7	0.2	0.9	1	1	1
10/20/2020 12:00	0.4	12.3	2,032.9	0.2	1.2	1	1	1
10/20/2020 13:00	0.4	12.2	2,029.9	0.3	1.2	1	1	1
10/20/2020 14:00	0.2	13.8	1,685.2	0.3	0.6	1	1	0
10/20/2020 15:00	0.3	13.0	1,812.9	0.2	0.9	1	1	1
10/20/2020 16:00	0.3	11.9	2,116.0	0.2	0.9	1	1	1
10/20/2020 17:00	0.3	12.0	2,087.3	0.2	0.9	1	1	1
10/20/2020 18:00	0.3	12.2	2,044.2	0.2	0.9	1	1	1
10/20/2020 19:00	0.4	12.5	1,989.8	0.2	1.3	1	1	1
10/20/2020 20:00	0.3	12.7	1,890.3	0.2	0.9	1	1	1
10/20/2020 21:00	0.2	13.5	1,722.0	0.2	0.6	1	1	1
10/20/2020 22:00	0.4	12.4	2,030.2	0.2	1.3	1	1	1
10/20/2020 23:00	0.3	12.1	2,092.8	0.2	0.9	1	1	1
Average/Sum#:	0.3	13.0	1,807.2	0.2	20.9 #	24 #	24 #	16 #
Minimum:	0.1	11.9	1,294.6	0.1	0.2	1	1	0
Maximum:	0.5	14.0	2,116.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	0.3	12.3	2,038.9	0.2	0.9	1	1	1
10/21/2020 01:00	0.1	13.8	1,682.8	0.2	0.3	1	1	0
10/21/2020 02:00	0.2	13.3	1,737.4	0.2	0.6	1	1	1
10/21/2020 03:00	0.3	12.1	2,083.5	0.2	0.9	1	1	1
10/21/2020 04:00	0.3	12.3	2,052.9	0.2	0.9	1	1	1
10/21/2020 05:00	0.4	12.5	2,021.8	0.2	1.3	1	1	1
10/21/2020 06:00	0.4	12.2	2,090.9	0.3	1.3	1	1	1
10/21/2020 07:00	0.2	13.8	1,542.0	0.3	0.6	1	1	1
10/21/2020 08:00	0.2	13.9	1,520.2	0.2	0.6	1	1	0
10/21/2020 09:00	0.1	14.0	1,352.9	0.2	0.3	1	1	0
10/21/2020 10:00	0.1	14.0	1,566.2	0.1	0.3	1	1	0
10/21/2020 11:00	0.1	14.0	1,517.4	0.1	0.3	1	1	0
10/21/2020 12:00	0.1	14.0	1,592.8	0.1	0.3	1	1	0
10/21/2020 13:00	0.3	13.6	1,665.5	0.1	0.9	1	1	1
10/21/2020 14:00	0.4	12.1	2,071.4	0.2	1.2	1	1	1
10/21/2020 15:00	0.4	12.3	2,024.0	0.3	1.2	1	1	1
10/21/2020 16:00	0.3	12.0	2,088.4	0.3	0.9	1	1	1
10/21/2020 17:00	0.3	11.9	2,112.4	0.2	0.9	1	1	1
10/21/2020 18:00	0.3	11.9	2,111.3	0.2	0.9	1	1	1
10/21/2020 19:00	0.3	12.1	2,065.4	0.2	0.9	1	1	1
10/21/2020 20:00	0.3	12.1	2,095.6	0.2	0.9	1	1	1
10/21/2020 21:00	0.3	12.2	2,074.2	0.2	0.9	1	1	1
10/21/2020 22:00	0.3	12.2	2,059.2	0.2	0.9	1	1	1
10/21/2020 23:00	0.2	12.5	1,960.9	0.2	0.6	1	1	1
Average/Sum#:	0.3	12.8	1,880.3	0.2	18.8 #	24 #	24 #	18 #
Minimum:	0.1	11.9	1,352.9	0.1	0.3	1	1	0
Maximum:	0.4	14.0	2,112.4	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	0.1	13.9	1,678.3	0.1	0.3	1	1	0
10/22/2020 01:00	0.3	13.3	1,800.3	0.1	0.9	1	1	1
10/22/2020 02:00	0.4	12.5	2,019.5	0.2	1.3	1	1	1
10/22/2020 03:00	0.4	12.6	1,998.4	0.3	1.3	1	1	1
10/22/2020 04:00	0.2	13.8	1,666.8	0.3	0.6	1	1	0
10/22/2020 05:00	0.3	13.6	1,742.4	0.2	0.9	1	1	1
10/22/2020 06:00	0.4	12.1	2,131.3	0.2	1.3	1	1	1
10/22/2020 07:00	0.4	12.3	2,062.2	0.3	1.3	1	1	1
10/22/2020 08:00	0.1	13.9	1,475.7	0.2	0.3	1	1	0
10/22/2020 09:00	0.1	14.0	1,574.9	0.2	0.3	1	1	0
10/22/2020 10:00	0.2	14.0	1,604.9	0.1	0.6	1	1	0
10/22/2020 11:00	0.4	13.4	1,793.6	0.2	1.3	1	1	1
10/22/2020 12:00	0.5	12.3	2,091.0	0.3	1.6	1	1	1
10/22/2020 13:00	0.5	12.7	1,960.2	0.3	1.6	1	1	1
10/22/2020 14:00	0.2	13.9	1,574.3	0.3	0.6	1	1	0
10/22/2020 15:00	0.3	13.7	1,669.7	0.3	0.9	1	1	1
10/22/2020 16:00	0.5	12.3	2,105.5	0.2	1.6	1	1	1
10/22/2020 17:00	0.4	12.2	2,122.1	0.3	1.3	1	1	1
10/22/2020 18:00	0.5	12.7	2,001.5	0.3	1.6	1	1	1
10/22/2020 19:00	0.5	12.5	2,066.1	0.4	1.6	1	1	1
10/22/2020 20:00	0.5	12.6	2,038.0	0.4	1.6	1	1	1
10/22/2020 21:00	0.5	12.6	2,037.7	0.4	1.6	1	1	1
10/22/2020 22:00	0.4	12.7	1,994.8	0.4	1.3	1	1	1
10/22/2020 23:00	0.3	12.8	1,943.8	0.3	1.0	1	1	1
Average/Sum#:	0.4	13.0	1,881.4	0.3	26.7 #	24 #	24 #	18 #
Minimum:	0.1	12.1	1,475.7	0.1	0.3	1	1	0
Maximum:	0.5	14.0	2,131.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	0.1	14.0	1,624.7	0.2	0.3	1	1	0
10/23/2020 01:00	0.3	13.4	1,797.4	0.2	0.9	1	1	1
10/23/2020 02:00	0.4	12.4	2,077.8	0.2	1.3	1	1	1
10/23/2020 03:00	0.5	12.8	1,985.3	0.3	1.6	1	1	1
10/23/2020 04:00	0.2	13.9	1,678.3	0.3	0.6	1	1	0
10/23/2020 05:00	0.3	13.6	1,810.3	0.3	1.0	1	1	1
10/23/2020 06:00	0.5	12.2	2,138.1	0.2	1.6	1	1	1
10/23/2020 07:00	0.5	12.4	2,097.4	0.3	1.6	1	1	1
10/23/2020 08:00	0.5	12.9	1,986.3	0.3	1.6	1	1	1
10/23/2020 09:00	0.2	13.7	1,706.5	0.3	0.6	1	1	1
10/23/2020 10:00	0.2	13.9	1,677.0	0.3	0.6	1	1	0
10/23/2020 11:00	0.2	13.8	1,724.7	0.2	0.6	1	1	1
10/23/2020 12:00	0.5	12.5	2,053.7	0.3	1.6	1	1	1
10/23/2020 13:00	0.5	12.9	1,946.0	0.3	1.6	1	1	1
10/23/2020 14:00	0.2	13.9	1,595.6	0.3	0.6	1	1	0
10/23/2020 15:00	0.3	13.7	1,733.3	0.3	1.0	1	1	1
10/23/2020 16:00	0.5	12.6	2,035.0	0.3	1.6	1	1	1
10/23/2020 17:00	0.4	12.3	2,089.8	0.3	1.3	1	1	1
10/23/2020 18:00	0.4	13.0	1,914.2	0.3	1.3	1	1	1
10/23/2020 19:00	0.2	13.8	1,687.1	0.3	0.6	1	1	0
10/23/2020 20:00	0.4	13.3	1,824.8	0.3	1.3	1	1	1
10/23/2020 21:00	0.5	12.6	2,047.0	0.3	1.6	1	1	1
10/23/2020 22:00	0.5	12.7	2,011.5	0.4	1.6	1	1	1
10/23/2020 23:00	0.4	12.4	2,110.8	0.4	1.3	1	1	1
Average/Sum#:	0.4	13.1	1,889.7	0.3	27.7 #	24 #	24 #	19 #
Minimum:	0.1	12.2	1,595.6	0.2	0.3	1	1	0
Maximum:	0.5	14.0	2,138.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	0.2	13.6	1,710.2	0.3	0.6	1	1	1
10/24/2020 01:00	0.2	13.9	1,685.2	0.2	0.6	1	1	0
10/24/2020 02:00	0.4	13.4	1,815.9	0.2	1.3	1	1	1
10/24/2020 03:00	0.4	12.4	2,084.9	0.3	1.3	1	1	1
10/24/2020 04:00	0.4	12.9	1,943.6	0.3	1.3	1	1	1
10/24/2020 05:00	0.2	13.8	1,670.4	0.3	0.6	1	1	0
10/24/2020 06:00	0.2	13.8	1,665.7	0.2	0.6	1	1	0
10/24/2020 07:00	0.2	13.8	1,620.3	0.2	0.6	1	1	0
10/24/2020 08:00	0.2	13.9	1,565.9	0.2	0.6	1	1	0
10/24/2020 09:00	0.2	13.9	1,611.1	0.2	0.6	1	1	0
10/24/2020 10:00	0.2	13.9	1,669.5	0.2	0.6	1	1	0
10/24/2020 11:00	0.2	13.9	1,627.8	0.2	0.6	1	1	0
10/24/2020 12:00	0.2	13.9	1,425.2	0.2	0.5	1	1	0
10/24/2020 13:00	0.2	13.9	1,420.6	0.2	0.5	1	1	0
10/24/2020 14:00	0.2	13.9	1,620.5	0.2	0.6	1	1	0
10/24/2020 15:00	0.2	13.9	1,685.3	0.2	0.6	1	1	0
10/24/2020 16:00	0.5	13.3	1,794.7	0.3	1.6	1	1	1
10/24/2020 17:00	0.5	12.1	2,114.9	0.3	1.6	1	1	1
10/24/2020 18:00	0.5	12.9	1,929.2	0.4	1.6	1	1	1
10/24/2020 19:00	0.3	13.8	1,685.4	0.3	0.9	1	1	0
10/24/2020 20:00	0.3	13.8	1,677.3	0.3	0.9	1	1	0
10/24/2020 21:00	0.5	13.3	1,805.0	0.3	1.6	1	1	1
10/24/2020 22:00	0.6	12.7	1,999.8	0.3	1.9	1	1	1
10/24/2020 23:00	0.5	12.7	1,962.0	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.5	1,741.3	0.3	23.2 #	24 #	24 #	10 #
Minimum:	0.2	12.1	1,420.6	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,114.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	0.2	13.8	1,672.5	0.3	0.6	1	1	0
10/25/2020 01:00	0.2	13.8	1,663.7	0.3	0.6	1	1	0
10/25/2020 02:00	0.2	13.8	1,648.1	0.2	0.6	1	1	0
10/25/2020 03:00	0.2	13.8	1,646.2	0.2	0.6	1	1	0
10/25/2020 04:00	0.2	13.8	1,641.5	0.2	0.6	1	1	0
10/25/2020 05:00	0.3	13.8	1,616.9	0.2	0.9	1	1	0
10/25/2020 06:00	0.3	13.8	1,583.6	0.2	0.9	1	1	0
10/25/2020 07:00	0.2	13.8	1,607.5	0.2	0.6	1	1	0
10/25/2020 08:00	0.2	13.9	1,608.1	0.2	0.6	1	1	0
10/25/2020 09:00	0.2	13.9	1,557.1	0.2	0.6	1	1	0
10/25/2020 10:00	0.2	14.0	1,413.8	0.2	0.5	1	1	0
10/25/2020 11:00	0.2	14.0	1,343.0	0.2	0.5	1	1	0
10/25/2020 12:00	0.2	14.0	1,543.4	0.2	0.6	1	1	0
10/25/2020 13:00	0.2	14.0	1,591.8	0.2	0.6	1	1	0
10/25/2020 14:00	0.2	14.0	1,650.7	0.2	0.6	1	1	0
10/25/2020 15:00	0.2	14.0	1,602.2	0.2	0.6	1	1	0
10/25/2020 16:00	0.5	13.5	1,826.6	0.3	1.6	1	1	1
10/25/2020 17:00	0.6	12.7	2,055.4	0.3	2.0	1	1	1
10/25/2020 18:00	0.6	12.7	2,013.8	0.4	1.9	1	1	1
10/25/2020 19:00	0.3	13.8	1,658.3	0.3	0.9	1	1	0
10/25/2020 20:00	0.4	13.3	1,821.1	0.3	1.3	1	1	1
10/25/2020 21:00	0.4	12.3	2,128.5	0.3	1.3	1	1	1
10/25/2020 22:00	0.3	12.2	2,142.1	0.3	1.0	1	1	1
10/25/2020 23:00	0.3	12.1	2,172.4	0.2	1.0	1	1	1
Average/Sum#:	0.3	13.5	1,717.0	0.2	21.0 #	24 #	24 #	7 #
Minimum:	0.2	12.1	1,343.0	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,172.4	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	0.3	12.7	2,037.0	0.2	1.0	1	1	1
10/26/2020 01:00	0.4	13.0	1,982.5	0.2	1.3	1	1	1
10/26/2020 02:00	0.4	12.7	2,032.7	0.3	1.3	1	1	1
10/26/2020 03:00	0.2	13.8	1,674.1	0.3	0.6	1	1	1
10/26/2020 04:00	0.3	13.4	1,856.6	0.2	1.0	1	1	1
10/26/2020 05:00	0.4	12.4	2,131.3	0.2	1.3	1	1	1
10/26/2020 06:00	0.3	12.4	2,092.6	0.2	1.0	1	1	1
10/26/2020 07:00	0.2	13.8	1,783.5	0.2	0.7	1	1	0
10/26/2020 08:00	0.2	13.9	1,744.2	0.2	0.7	1	1	0
10/26/2020 09:00	0.2	13.9	1,734.3	0.2	0.7	1	1	0
10/26/2020 10:00	0.2	14.0	1,679.3	0.2	0.6	1	1	0
10/26/2020 11:00	0.1	14.0	1,378.8	0.2	0.3	1	1	0
10/26/2020 12:00	0.2	14.0	1,524.0	0.2	0.6	1	1	0
10/26/2020 13:00	0.2	14.0	1,503.0	0.2	0.6	1	1	0
10/26/2020 14:00	0.2	14.0	1,692.4	0.2	0.6	1	1	0
10/26/2020 15:00	0.2	14.0	1,640.3	0.2	0.6	1	1	0
10/26/2020 16:00	0.5	13.4	1,844.9	0.3	1.6	1	1	1
10/26/2020 17:00	0.5	12.3	2,141.4	0.3	1.6	1	1	1
10/26/2020 18:00	0.5	12.1	2,179.9	0.3	1.6	1	1	1
10/26/2020 19:00	0.5	12.5	2,078.5	0.3	1.6	1	1	1
10/26/2020 20:00	0.5	12.4	2,117.6	0.3	1.6	1	1	1
10/26/2020 21:00	0.5	12.5	2,088.1	0.4	1.6	1	1	1
10/26/2020 22:00	0.6	12.6	2,075.4	0.4	2.0	1	1	1
10/26/2020 23:00	0.5	12.6	2,058.1	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.2	1,877.9	0.3	26.1 #	24 #	24 #	15 #
Minimum:	0.1	12.1	1,378.8	0.2	0.3	1	1	0
Maximum:	0.6	14.0	2,179.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	0.2	13.9	1,687.6	0.3	0.6	1	1	1
10/27/2020 01:00	0.3	13.5	1,783.3	0.3	1.0	1	1	1
10/27/2020 02:00	0.4	12.5	2,051.2	0.2	1.3	1	1	1
10/27/2020 03:00	0.3	12.7	1,991.3	0.2	1.0	1	1	1
10/27/2020 04:00	0.2	14.0	1,645.6	0.2	0.6	1	1	0
10/27/2020 05:00	0.3	13.6	1,729.5	0.2	0.9	1	1	1
10/27/2020 06:00	0.3	12.1	2,142.6	0.2	1.0	1	1	1
10/27/2020 07:00	0.4	12.2	2,157.2	0.2	1.3	1	1	1
10/27/2020 08:00	0.5	12.4	2,106.7	0.3	1.6	1	1	1
10/27/2020 09:00	0.4	12.3	2,114.6	0.3	1.3	1	1	1
10/27/2020 10:00	0.4	12.2	2,115.2	0.3	1.3	1	1	1
10/27/2020 11:00	0.4	12.1	2,141.2	0.3	1.3	1	1	1
10/27/2020 12:00	0.4	12.0	2,148.5	0.3	1.3	1	1	1
10/27/2020 13:00	0.4	12.0	2,145.5	0.3	1.3	1	1	1
10/27/2020 14:00	0.4	12.0	2,130.9	0.3	1.3	1	1	1
10/27/2020 15:00	0.5	12.7	1,980.7	0.3	1.6	1	1	1
10/27/2020 16:00	0.4	12.2	2,116.3	0.3	1.3	1	1	1
10/27/2020 17:00	0.4	12.0	2,149.3	0.3	1.3	1	1	1
10/27/2020 18:00	0.4	12.0	2,149.9	0.3	1.3	1	1	1
10/27/2020 19:00	0.4	12.0	2,147.3	0.3	1.3	1	1	1
10/27/2020 20:00	0.4	12.1	2,133.3	0.3	1.3	1	1	1
10/27/2020 21:00	0.5	12.5	2,045.5	0.3	1.6	1	1	1
10/27/2020 22:00	0.5	12.6	2,044.8	0.4	1.6	1	1	1
10/27/2020 23:00	0.5	12.5	2,053.8	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.5	2,038.0	0.3	30.0 #	24 #	24 #	23 #
Minimum:	0.2	12.0	1,645.6	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,157.2	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	0.2	13.8	1,674.9	0.3	0.6	1	1	0
10/28/2020 01:00	0.3	13.8	1,660.6	0.3	0.9	1	1	0
10/28/2020 02:00	0.3	13.8	1,645.3	0.2	0.9	1	1	0
10/28/2020 03:00	0.3	13.9	1,640.5	0.2	0.9	1	1	0
10/28/2020 04:00	0.4	13.5	1,818.3	0.3	1.3	1	1	1
10/28/2020 05:00	0.4	12.4	2,111.2	0.3	1.3	1	1	1
10/28/2020 06:00	0.3	12.1	2,135.4	0.3	1.0	1	1	1
10/28/2020 07:00	0.1	13.9	1,275.4	0.2	0.2	1	1	0
10/28/2020 08:00	0.1	13.9	1,280.4	0.1	0.2	1	1	0
10/28/2020 09:00	0.2	13.9	1,482.6	0.1	0.6	1	1	0
10/28/2020 10:00	0.2	13.9	1,525.4	0.2	0.6	1	1	0
10/28/2020 11:00	0.3	13.7	1,799.3	0.2	1.0	1	1	0
10/28/2020 12:00	0.3	13.7	1,786.0	0.2	1.0	1	1	0
10/28/2020 13:00	0.3	13.7	1,782.2	0.2	1.0	1	1	0
10/28/2020 14:00	0.3	13.7	1,776.7	0.2	1.0	1	1	0
10/28/2020 15:00	0.3	13.7	1,773.9	0.2	1.0	1	1	0
10/28/2020 16:00	0.3	13.8	1,649.9	0.2	0.9	1	1	0
10/28/2020 17:00	0.3	13.8	1,697.8	0.2	0.9	1	1	1
10/28/2020 18:00	0.6	12.8	1,990.9	0.3	1.9	1	1	1
10/28/2020 19:00	0.5	12.6	2,043.2	0.3	1.6	1	1	1
10/28/2020 20:00	0.5	12.5	2,062.9	0.4	1.6	1	1	1
10/28/2020 21:00	0.5	12.5	2,062.0	0.4	1.6	1	1	1
10/28/2020 22:00	0.5	12.7	2,033.3	0.4	1.6	1	1	1
10/28/2020 23:00	0.4	13.1	1,902.2	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,775.4	0.3	24.9 #	24 #	24 #	10 #
Minimum:	0.1	12.1	1,275.4	0.1	0.2	1	1	0
Maximum:	0.6	13.9	2,135.4	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	0.2	13.9	1,682.1	0.3	0.6	1	1	0
10/29/2020 01:00	0.2	13.9	1,673.3	0.2	0.6	1	1	0
10/29/2020 02:00	0.2	13.9	1,531.6	0.2	0.6	1	1	0
10/29/2020 03:00	0.2	13.9	1,680.0	0.2	0.6	1	1	0
10/29/2020 04:00	0.4	13.5	1,783.7	0.2	1.3	1	1	1
10/29/2020 05:00	0.5	12.7	2,042.9	0.3	1.6	1	1	1
10/29/2020 06:00	0.4	12.6	2,055.2	0.3	1.3	1	1	1
10/29/2020 07:00	0.2	13.8	1,783.4	0.3	0.7	1	1	0
10/29/2020 08:00	0.2	13.9	1,311.0	0.2	0.5	1	1	0
10/29/2020 09:00	0.1	14.0	1,264.1	0.2	0.2	1	1	0
10/29/2020 10:00	0.2	14.0	1,277.7	0.2	0.5	1	1	0
10/29/2020 11:00	0.1	14.0	1,262.8	0.1	0.2	1	1	0
10/29/2020 12:00	0.1	14.0	1,262.5	0.1	0.2	1	1	0
10/29/2020 13:00	0.1	14.0	1,263.0	0.1	0.2	1	1	0
10/29/2020 14:00	0.1	14.0	1,263.0	0.1	0.2	1	1	0
10/29/2020 15:00	0.1	14.0	1,359.5	0.1	0.3	1	1	0
10/29/2020 16:00	0.2	13.9	1,535.9	0.1	0.6	1	1	0
10/29/2020 17:00	0.3	13.8	1,745.1	0.2	1.0	1	1	1
10/29/2020 18:00	0.6	12.8	2,007.3	0.3	2.0	1	1	1
10/29/2020 19:00	0.6	12.5	2,051.0	0.3	1.9	1	1	1
10/29/2020 20:00	0.6	12.5	2,072.3	0.4	2.0	1	1	1
10/29/2020 21:00	0.5	12.5	2,064.0	0.4	1.6	1	1	1
10/29/2020 22:00	0.5	12.5	2,059.1	0.4	1.6	1	1	1
10/29/2020 23:00	0.7	13.1	1,920.3	0.4	2.3	1	1	1
Average/Sum#:	0.3	13.5	1,664.6	0.2	22.6 #	24 #	24 #	10 #
Minimum:	0.1	12.5	1,262.5	0.1	0.2	1	1	0
Maximum:	0.7	14.0	2,072.3	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	0.2	13.9	1,604.9	0.4	0.6	1	1	0
10/30/2020 01:00	0.3	13.7	1,678.5	0.3	0.9	1	1	1
10/30/2020 02:00	0.4	13.0	1,928.0	0.2	1.3	1	1	1
10/30/2020 03:00	0.4	13.0	1,923.5	0.3	1.3	1	1	1
10/30/2020 04:00	0.2	13.9	1,687.9	0.3	0.6	1	1	0
10/30/2020 05:00	0.3	13.6	1,799.8	0.2	1.0	1	1	1
10/30/2020 06:00	0.4	12.5	2,061.7	0.2	1.3	1	1	1
10/30/2020 07:00	0.4	12.8	2,012.0	0.3	1.3	1	1	1
10/30/2020 08:00	0.4	12.8	2,003.0	0.3	1.3	1	1	1
10/30/2020 09:00	0.4	12.8	1,967.1	0.3	1.3	1	1	1
10/30/2020 10:00	0.3	12.7	2,000.2	0.3	1.0	1	1	1
10/30/2020 11:00	0.3	12.7	1,944.2	0.2	0.9	1	1	1
10/30/2020 12:00	0.1	14.0	1,642.2	0.2	0.3	1	1	0
10/30/2020 13:00	0.4	13.4	1,784.4	0.2	1.3	1	1	1
10/30/2020 14:00	0.5	12.6	2,013.1	0.3	1.6	1	1	1
10/30/2020 15:00	0.5	12.3	2,065.6	0.3	1.6	1	1	1
10/30/2020 16:00	0.5	12.5	2,037.7	0.4	1.6	1	1	1
10/30/2020 17:00	0.4	12.2	2,105.4	0.3	1.3	1	1	1
10/30/2020 18:00	0.4	12.2	2,106.9	0.3	1.3	1	1	1
10/30/2020 19:00	0.4	12.1	2,134.3	0.3	1.3	1	1	1
10/30/2020 20:00	0.3	13.2	1,798.7	0.3	0.9	1	1	1
10/30/2020 21:00	0.4	13.4	1,821.4	0.3	1.3	1	1	1
10/30/2020 22:00	0.5	12.4	2,080.7	0.3	1.6	1	1	1
10/30/2020 23:00	0.5	13.0	1,929.7	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.9	1,922.1	0.3	28.5 #	24 #	24 #	21 #
Minimum:	0.1	12.1	1,604.9	0.2	0.3	1	1	0
Maximum:	0.5	14.0	2,134.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	0.2	13.9	1,556.8	0.3	0.6	1	1	0
10/31/2020 01:00	0.2	13.9	1,655.0	0.3	0.6	1	1	0
10/31/2020 02:00	0.3	13.7	1,646.8	0.2	0.9	1	1	1
10/31/2020 03:00	0.4	12.6	2,025.8	0.2	1.3	1	1	1
10/31/2020 04:00	0.4	13.0	1,908.0	0.3	1.3	1	1	1
10/31/2020 05:00	0.2	13.9	1,688.3	0.3	0.6	1	1	0
10/31/2020 06:00	0.2	13.9	1,686.5	0.2	0.6	1	1	0
10/31/2020 07:00	0.2	13.9	1,641.9	0.2	0.6	1	1	0
10/31/2020 08:00	0.2	13.9	1,519.8	0.2	0.6	1	1	0
10/31/2020 09:00	0.2	13.9	1,494.6	0.2	0.6	1	1	0
10/31/2020 10:00	0.2	13.9	1,630.8	0.2	0.6	1	1	0
10/31/2020 11:00	0.2	14.0	1,545.5	0.2	0.6	1	1	0
10/31/2020 12:00	0.2	14.0	1,544.3	0.2	0.6	1	1	0
10/31/2020 13:00	0.2	14.0	1,555.3	0.2	0.6	1	1	0
10/31/2020 14:00	0.2	13.9	1,588.7	0.2	0.6	1	1	0
10/31/2020 15:00	0.2	13.9	1,667.8	0.2	0.6	1	1	0
10/31/2020 16:00	0.4	13.4	1,784.8	0.2	1.3	1	1	1
10/31/2020 17:00	0.5	12.8	1,979.8	0.3	1.6	1	1	1
10/31/2020 18:00	0.5	12.7	2,004.7	0.4	1.6	1	1	1
10/31/2020 19:00	0.2	13.8	1,684.5	0.3	0.6	1	1	0
10/31/2020 20:00	0.4	13.4	1,810.6	0.3	1.3	1	1	1
10/31/2020 21:00	0.5	12.6	2,037.6	0.3	1.6	1	1	1
10/31/2020 22:00	0.5	12.7	2,037.5	0.4	1.6	1	1	1
10/31/2020 23:00	0.5	12.6	2,045.7	0.4	1.6	1	1	1
Average/Sum#:	0.3	13.5	1,739.2	0.3	22.5 #	24 #	24 #	10 #
Minimum:	0.2	12.6	1,494.6	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,045.7	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	0.4	12.8	2,015.2	0.4	1.3	1	1	1
11/01/2020 01:00	0.4	12.8	1,982.7	0.3	1.3	1	1	1
11/01/2020 02:00	0.2	13.8	1,668.6	0.3	0.6	1	1	1
11/01/2020 03:00	0.2	13.9	1,679.1	0.2	0.6	1	1	0
11/01/2020 04:00	0.3	13.4	1,812.7	0.2	1.0	1	1	1
11/01/2020 05:00	0.4	12.7	2,032.9	0.2	1.3	1	1	1
11/01/2020 06:00	0.4	12.7	2,001.6	0.3	1.3	1	1	1
11/01/2020 07:00	0.1	13.9	1,536.2	0.2	0.3	1	1	0
11/01/2020 08:00	0.2	13.9	1,682.4	0.2	0.6	1	1	0
11/01/2020 09:00	0.2	13.9	1,491.5	0.2	0.6	1	1	0
11/01/2020 10:00	0.2	13.9	1,564.2	0.2	0.6	1	1	0
11/01/2020 11:00	0.2	14.0	1,482.3	0.2	0.6	1	1	0
11/01/2020 12:00	0.2	14.0	1,567.9	0.2	0.6	1	1	0
11/01/2020 13:00	0.2	13.9	1,656.6	0.2	0.6	1	1	0
11/01/2020 14:00	0.2	13.9	1,663.1	0.2	0.6	1	1	0
11/01/2020 15:00	0.3	13.7	1,647.6	0.2	0.9	1	1	1
11/01/2020 16:00	0.5	12.6	2,012.8	0.3	1.6	1	1	1
11/01/2020 17:00	0.4	12.3	2,100.1	0.3	1.3	1	1	1
11/01/2020 18:00	0.4	12.1	2,131.1	0.3	1.3	1	1	1
11/01/2020 19:00	0.4	12.3	2,105.1	0.3	1.3	1	1	1
11/01/2020 20:00	0.4	12.3	2,094.8	0.3	1.3	1	1	1
11/01/2020 21:00	0.4	12.1	2,142.5	0.3	1.3	1	1	1
11/01/2020 22:00	0.4	12.5	2,064.2	0.3	1.3	1	1	1
11/01/2020 23:00	0.5	12.5	2,077.2	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.2	1,842.2	0.3	23.8 #	24 #	24 #	15 #
Minimum:	0.1	12.1	1,482.3	0.2	0.3	1	1	0
Maximum:	0.5	14.0	2,142.5	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	0.4	12.4	2,089.6	0.3	1.3	1	1	1
11/02/2020 01:00	0.3	12.6	2,002.9	0.3	1.0	1	1	1
11/02/2020 02:00	0.2	13.9	1,640.6	0.2	0.6	1	1	0
11/02/2020 03:00	0.3	13.4	1,793.3	0.2	0.9	1	1	1
11/02/2020 04:00	0.4	12.4	2,080.6	0.2	1.3	1	1	1
11/02/2020 05:00	0.3	12.3	2,102.4	0.2	1.0	1	1	1
11/02/2020 06:00	0.4	12.5	2,050.3	0.3	1.3	1	1	1
11/02/2020 07:00	0.2	13.9	1,621.3	0.2	0.6	1	1	0
11/02/2020 08:00	0.2	13.9	1,656.5	0.2	0.6	1	1	0
11/02/2020 09:00	0.2	13.9	1,676.9	0.2	0.6	1	1	0
11/02/2020 10:00	0.2	14.0	1,643.3	0.2	0.6	1	1	0
11/02/2020 11:00	0.2	14.0	1,652.0	0.2	0.6	1	1	0
11/02/2020 12:00	0.2	13.8	1,676.1	0.2	0.6	1	1	0
11/02/2020 13:00	0.2	13.9	1,668.5	0.2	0.6	1	1	0
11/02/2020 14:00	0.3	13.7	1,696.9	0.2	0.9	1	1	1
11/02/2020 15:00	0.5	12.5	2,019.1	0.3	1.6	1	1	1
11/02/2020 16:00	0.3	12.0	2,133.1	0.3	0.9	1	1	1
11/02/2020 17:00	0.4	12.1	2,113.6	0.3	1.3	1	1	1
11/02/2020 18:00	0.4	12.0	2,128.6	0.3	1.3	1	1	1
11/02/2020 19:00	0.3	12.0	2,139.0	0.3	1.0	1	1	1
11/02/2020 20:00	0.4	12.1	2,134.9	0.3	1.3	1	1	1
11/02/2020 21:00	0.4	12.3	2,094.7	0.3	1.3	1	1	1
11/02/2020 22:00	0.4	12.3	2,084.1	0.3	1.3	1	1	1
11/02/2020 23:00	0.4	12.6	2,035.5	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,913.9	0.3	23.8 #	24 #	24 #	16 #
Minimum:	0.2	12.0	1,621.3	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,139.0	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	0.4	12.4	2,054.7	0.3	1.3	1	1	1
11/03/2020 01:00	0.4	12.8	1,945.1	0.3	1.3	1	1	1
11/03/2020 02:00	0.2	13.9	1,677.9	0.3	0.6	1	1	0
11/03/2020 03:00	0.4	13.4	1,817.0	0.3	1.3	1	1	1
11/03/2020 04:00	0.4	12.3	2,088.1	0.3	1.3	1	1	1
11/03/2020 05:00	0.3	12.2	2,098.9	0.3	1.0	1	1	1
11/03/2020 06:00	0.3	12.2	2,114.3	0.2	1.0	1	1	1
11/03/2020 07:00	0.3	12.6	2,008.8	0.2	1.0	1	1	1
11/03/2020 08:00	0.2	13.9	1,651.3	0.2	0.6	1	1	0
11/03/2020 09:00	0.2	13.9	1,665.8	0.2	0.6	1	1	0
11/03/2020 10:00	0.2	13.9	1,671.5	0.2	0.6	1	1	0
11/03/2020 11:00	0.2	14.0	1,522.5	0.2	0.6	1	1	0
11/03/2020 12:00	0.2	14.0	1,522.1	0.2	0.6	1	1	0
11/03/2020 13:00	0.2	13.9	1,591.7	0.2	0.6	1	1	0
11/03/2020 14:00	0.2	13.9	1,660.3	0.2	0.6	1	1	0
11/03/2020 15:00	0.3	13.4	1,785.8	0.2	0.9	1	1	1
11/03/2020 16:00	0.4	12.2	2,103.2	0.2	1.3	1	1	1
11/03/2020 17:00	0.4	12.1	2,129.4	0.3	1.3	1	1	1
11/03/2020 18:00	0.4	12.1	2,138.7	0.3	1.3	1	1	1
11/03/2020 19:00	0.4	12.1	2,142.9	0.3	1.3	1	1	1
11/03/2020 20:00	0.4	12.2	2,117.8	0.3	1.3	1	1	1
11/03/2020 21:00	0.4	12.2	2,107.4	0.3	1.3	1	1	1
11/03/2020 22:00	0.4	12.4	2,081.9	0.3	1.3	1	1	1
11/03/2020 23:00	0.5	12.7	2,038.5	0.3	1.6	1	1	1
Average/Sum#:	0.3	12.9	1,905.7	0.3	24.6 #	24 #	24 #	16 #
Minimum:	0.2	12.1	1,522.1	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,142.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	0.4	12.6	2,048.8	0.3	1.3	1	1	1
11/04/2020 01:00	0.4	13.0	1,921.7	0.3	1.3	1	1	1
11/04/2020 02:00	0.2	13.9	1,688.1	0.3	0.6	1	1	0
11/04/2020 03:00	0.4	13.4	1,807.4	0.3	1.3	1	1	1
11/04/2020 04:00	0.4	12.4	2,061.2	0.3	1.3	1	1	1
11/04/2020 05:00	0.4	12.3	2,101.7	0.3	1.3	1	1	1
11/04/2020 06:00	0.4	12.3	2,121.7	0.3	1.3	1	1	1
11/04/2020 07:00	0.4	12.7	2,006.0	0.3	1.3	1	1	1
11/04/2020 08:00	0.2	13.9	1,684.5	0.3	0.6	1	1	0
11/04/2020 09:00	0.2	13.9	1,630.7	0.2	0.6	1	1	0
11/04/2020 10:00	0.2	13.9	1,532.9	0.2	0.6	1	1	0
11/04/2020 11:00	0.2	13.9	1,658.9	0.2	0.6	1	1	0
11/04/2020 12:00	0.2	14.0	1,679.9	0.2	0.6	1	1	0
11/04/2020 13:00	0.2	13.9	1,683.8	0.2	0.6	1	1	0
11/04/2020 14:00	0.3	13.8	1,715.7	0.2	1.0	1	1	1
11/04/2020 15:00	0.5	12.7	2,012.6	0.3	1.6	1	1	1
11/04/2020 16:00	0.4	12.2	2,099.1	0.3	1.3	1	1	1
11/04/2020 17:00	0.4	12.2	2,120.2	0.3	1.3	1	1	1
11/04/2020 18:00	0.4	12.0	2,155.9	0.3	1.3	1	1	1
11/04/2020 19:00	0.3	12.1	2,144.6	0.3	1.0	1	1	1
11/04/2020 20:00	0.4	12.2	2,122.0	0.3	1.3	1	1	1
11/04/2020 21:00	0.4	12.2	2,113.1	0.3	1.3	1	1	1
11/04/2020 22:00	0.4	12.2	2,112.8	0.3	1.3	1	1	1
11/04/2020 23:00	0.4	12.4	2,101.4	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,930.2	0.3	26.0 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,532.9	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,155.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	0.4	12.3	2,122.4	0.3	1.3	1	1	1
11/05/2020 01:00	0.4	12.4	2,068.5	0.3	1.3	1	1	1
11/05/2020 02:00	0.2	13.8	1,628.2	0.3	0.6	1	1	0
11/05/2020 03:00	0.3	13.3	1,806.8	0.2	0.9	1	1	1
11/05/2020 04:00	0.4	12.4	2,067.5	0.2	1.3	1	1	1
11/05/2020 05:00	0.4	12.3	2,092.5	0.3	1.3	1	1	1
11/05/2020 06:00	0.4	12.4	2,075.9	0.3	1.3	1	1	1
11/05/2020 07:00	0.4	12.8	1,975.2	0.3	1.3	1	1	1
11/05/2020 08:00	0.2	13.9	1,586.0	0.3	0.6	1	1	0
11/05/2020 09:00	0.2	13.9	1,668.6	0.2	0.6	1	1	0
11/05/2020 10:00	0.2	13.9	1,581.1	0.2	0.6	1	1	0
11/05/2020 11:00	0.2	13.9	1,576.7	0.2	0.6	1	1	0
11/05/2020 12:00	0.2	13.9	1,670.6	0.2	0.6	1	1	0
11/05/2020 13:00	0.2	13.9	1,561.0	0.2	0.6	1	1	0
11/05/2020 14:00	0.3	13.5	1,724.1	0.2	0.9	1	1	1
11/05/2020 15:00	0.4	12.1	2,103.5	0.2	1.3	1	1	1
11/05/2020 16:00	0.4	12.4	2,030.5	0.3	1.3	1	1	1
11/05/2020 17:00	0.4	12.2	2,092.4	0.3	1.3	1	1	1
11/05/2020 18:00	0.4	12.1	2,095.7	0.3	1.3	1	1	1
11/05/2020 19:00	0.4	12.4	2,040.9	0.3	1.3	1	1	1
11/05/2020 20:00	0.4	12.1	2,119.5	0.3	1.3	1	1	1
11/05/2020 21:00	0.4	12.0	2,144.8	0.3	1.3	1	1	1
11/05/2020 22:00	0.4	12.4	2,065.0	0.3	1.3	1	1	1
11/05/2020 23:00	0.4	12.3	2,071.0	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,915.4	0.3	25.5 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,561.0	0.2	0.6	1	1	0
Maximum:	0.4	13.9	2,144.8	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	0.4	12.3	2,061.7	0.3	1.3	1	1	1
11/06/2020 01:00	0.5	13.0	1,911.5	0.3	1.6	1	1	1
11/06/2020 02:00	0.2	13.8	1,636.5	0.3	0.6	1	1	0
11/06/2020 03:00	0.2	13.8	1,596.7	0.3	0.6	1	1	0
11/06/2020 04:00	0.4	13.3	1,808.1	0.2	1.3	1	1	1
11/06/2020 05:00	0.5	12.3	2,093.5	0.3	1.6	1	1	1
11/06/2020 06:00	0.4	12.5	2,018.3	0.3	1.3	1	1	1
11/06/2020 07:00	0.4	12.4	2,057.0	0.3	1.3	1	1	1
11/06/2020 08:00	0.1	13.9	1,417.9	0.2	0.3	1	1	0
11/06/2020 09:00	0.2	14.0	1,335.8	0.2	0.5	1	1	0
11/06/2020 10:00	0.2	14.0	1,307.2	0.2	0.5	1	1	0
11/06/2020 11:00	0.1	14.0	1,287.5	0.2	0.2	1	1	0
11/06/2020 12:00	0.2	14.0	1,418.6	0.2	0.5	1	1	0
11/06/2020 13:00	0.2	14.0	1,398.7	0.2	0.5	1	1	0
11/06/2020 14:00	0.2	14.0	1,321.3	0.2	0.5	1	1	0
11/06/2020 15:00	0.4	13.3	1,808.3	0.2	1.3	1	1	1
11/06/2020 16:00	0.5	12.3	2,095.9	0.3	1.6	1	1	1
11/06/2020 17:00	0.4	12.2	2,116.1	0.3	1.3	1	1	1
11/06/2020 18:00	0.4	12.2	2,109.7	0.3	1.3	1	1	1
11/06/2020 19:00	0.4	12.8	1,974.3	0.3	1.3	1	1	1
11/06/2020 20:00	0.4	13.0	1,912.8	0.3	1.3	1	1	1
11/06/2020 21:00	0.2	13.9	1,522.7	0.3	0.6	1	1	0
11/06/2020 22:00	0.3	13.6	1,740.0	0.2	0.9	1	1	1
11/06/2020 23:00	0.5	12.8	1,985.9	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.2	1,747.3	0.3	23.8 #	24 #	24 #	14 #
Minimum:	0.1	12.2	1,287.5	0.2	0.2	1	1	0
Maximum:	0.5	14.0	2,116.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	0.5	13.1	1,901.1	0.3	1.6	1	1	1
11/07/2020 01:00	0.2	13.9	1,681.4	0.3	0.6	1	1	0
11/07/2020 02:00	0.3	13.6	1,714.0	0.3	0.9	1	1	1
11/07/2020 03:00	0.5	13.1	1,911.8	0.3	1.6	1	1	1
11/07/2020 04:00	0.5	13.1	1,909.2	0.3	1.6	1	1	1
11/07/2020 05:00	0.2	13.9	1,636.6	0.3	0.6	1	1	0
11/07/2020 06:00	0.2	13.9	1,606.2	0.3	0.6	1	1	0
11/07/2020 07:00	0.2	13.9	1,586.3	0.2	0.6	1	1	0
11/07/2020 08:00	0.2	13.9	1,650.0	0.2	0.6	1	1	0
11/07/2020 09:00	0.2	13.9	1,549.3	0.2	0.6	1	1	0
11/07/2020 10:00	0.2	13.9	1,404.5	0.2	0.5	1	1	0
11/07/2020 11:00	0.2	13.9	1,389.9	0.2	0.5	1	1	0
11/07/2020 12:00	0.2	13.9	1,572.5	0.2	0.6	1	1	0
11/07/2020 13:00	0.2	13.9	1,476.7	0.2	0.6	1	1	0
11/07/2020 14:00	0.2	13.9	1,468.0	0.2	0.6	1	1	0
11/07/2020 15:00	0.2	13.9	1,544.4	0.2	0.6	1	1	1
11/07/2020 16:00	0.6	12.6	2,031.9	0.3	1.9	1	1	1
11/07/2020 17:00	0.4	12.2	2,097.9	0.3	1.3	1	1	1
11/07/2020 18:00	0.4	12.5	2,037.4	0.3	1.3	1	1	1
11/07/2020 19:00	0.5	12.6	2,023.6	0.3	1.6	1	1	1
11/07/2020 20:00	0.5	12.9	1,939.2	0.4	1.6	1	1	1
11/07/2020 21:00	0.2	13.9	1,570.7	0.3	0.6	1	1	0
11/07/2020 22:00	0.4	13.4	1,804.7	0.3	1.3	1	1	1
11/07/2020 23:00	0.4	12.3	2,089.2	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,733.2	0.3	23.6 #	24 #	24 #	12 #
Minimum:	0.2	12.2	1,389.9	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,097.9	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	0.4	12.8	1,961.7	0.3	1.3	1	1	1
11/08/2020 01:00	0.3	13.8	1,570.0	0.3	0.9	1	1	1
11/08/2020 02:00	0.2	13.9	1,552.0	0.2	0.6	1	1	0
11/08/2020 03:00	0.5	13.1	1,899.9	0.3	1.6	1	1	1
11/08/2020 04:00	0.5	13.1	1,901.0	0.3	1.6	1	1	1
11/08/2020 05:00	0.2	13.9	1,689.8	0.3	0.6	1	1	0
11/08/2020 06:00	0.2	13.9	1,653.1	0.3	0.6	1	1	0
11/08/2020 07:00	0.2	13.9	1,571.5	0.2	0.6	1	1	0
11/08/2020 08:00	0.2	13.9	1,656.7	0.2	0.6	1	1	0
11/08/2020 09:00	0.2	13.9	1,646.8	0.2	0.6	1	1	0
11/08/2020 10:00	0.2	13.9	1,680.9	0.2	0.6	1	1	0
11/08/2020 11:00	0.2	13.9	1,539.8	0.2	0.6	1	1	0
11/08/2020 12:00	0.2	14.0	1,436.2	0.2	0.5	1	1	0
11/08/2020 13:00	0.2	13.9	1,649.9	0.2	0.6	1	1	0
11/08/2020 14:00	0.2	13.9	1,657.3	0.2	0.6	1	1	0
11/08/2020 15:00	0.2	13.9	1,675.3	0.2	0.6	1	1	0
11/08/2020 16:00	0.4	13.3	1,832.0	0.2	1.3	1	1	1
11/08/2020 17:00	0.4	12.2	2,143.9	0.3	1.3	1	1	1
11/08/2020 18:00	0.4	12.5	2,066.7	0.3	1.3	1	1	1
11/08/2020 19:00	0.4	12.6	2,027.3	0.3	1.3	1	1	1
11/08/2020 20:00	0.2	13.9	1,657.9	0.3	0.6	1	1	0
11/08/2020 21:00	0.2	13.9	1,582.5	0.2	0.6	1	1	0
11/08/2020 22:00	0.4	13.5	1,811.5	0.2	1.3	1	1	1
11/08/2020 23:00	0.4	12.5	2,073.3	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.5	1,747.4	0.2	21.5 #	24 #	24 #	10 #
Minimum:	0.2	12.2	1,436.2	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,143.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	0.4	13.1	1,932.3	0.3	1.3	1	1	1
11/09/2020 01:00	0.2	13.9	1,525.4	0.3	0.6	1	1	0
11/09/2020 02:00	0.1	13.9	1,297.3	0.2	0.2	1	1	0
11/09/2020 03:00	0.2	13.9	1,313.9	0.2	0.5	1	1	0
11/09/2020 04:00	0.3	13.5	1,738.1	0.2	0.9	1	1	1
11/09/2020 05:00	0.5	12.4	2,132.5	0.2	1.7	1	1	1
11/09/2020 06:00	0.4	12.2	2,175.7	0.3	1.3	1	1	1
11/09/2020 07:00	0.4	12.7	2,060.5	0.3	1.3	1	1	1
11/09/2020 08:00	0.4	13.1	1,941.7	0.3	1.3	1	1	1
11/09/2020 09:00	0.2	13.9	1,515.7	0.3	0.6	1	1	0
11/09/2020 10:00	0.2	13.9	1,539.1	0.2	0.6	1	1	0
11/09/2020 11:00	0.2	14.0	1,438.3	0.2	0.6	1	1	0
11/09/2020 12:00	0.2	14.0	1,470.3	0.2	0.6	1	1	0
11/09/2020 13:00	0.2	14.0	1,410.8	0.2	0.5	1	1	0
11/09/2020 14:00	0.2	13.9	1,617.6	0.2	0.6	1	1	0
11/09/2020 15:00	0.4	13.5	1,800.1	0.2	1.3	1	1	1
11/09/2020 16:00	0.4	12.8	2,030.3	0.3	1.3	1	1	1
11/09/2020 17:00	0.4	12.6	2,058.2	0.3	1.3	1	1	1
11/09/2020 18:00	0.4	12.5	2,104.8	0.3	1.3	1	1	1
11/09/2020 19:00	0.4	12.4	2,106.2	0.3	1.3	1	1	1
11/09/2020 20:00	0.3	12.1	2,177.3	0.3	1.0	1	1	1
11/09/2020 21:00	0.4	12.3	2,145.5	0.3	1.3	1	1	1
11/09/2020 22:00	0.4	12.7	2,046.2	0.3	1.3	1	1	1
11/09/2020 23:00	0.4	12.9	2,014.7	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.2	1,816.4	0.3	24.0 #	24 #	24 #	15 #
Minimum:	0.1	12.1	1,297.3	0.2	0.2	1	1	0
Maximum:	0.5	14.0	2,177.3	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	0.4	12.9	2,022.1	0.3	1.3	1	1	1
11/10/2020 01:00	0.5	13.2	1,940.3	0.3	1.7	1	1	1
11/10/2020 02:00	0.2	13.9	1,678.0	0.3	0.6	1	1	0
11/10/2020 03:00	0.3	13.5	1,816.8	0.3	1.0	1	1	1
11/10/2020 04:00	0.5	12.9	2,013.2	0.3	1.7	1	1	1
11/10/2020 05:00	0.5	12.9	2,022.8	0.3	1.7	1	1	1
11/10/2020 06:00	0.5	13.0	2,028.1	0.4	1.7	1	1	1
11/10/2020 07:00	0.5	13.0	2,001.0	0.4	1.7	1	1	1
11/10/2020 08:00	0.5	13.2	1,943.9	0.4	1.7	1	1	1
11/10/2020 09:00	0.2	13.9	1,646.9	0.3	0.6	1	1	0
11/10/2020 10:00	0.2	13.9	1,652.5	0.3	0.6	1	1	0
11/10/2020 11:00	0.2	14.0	1,385.2	0.2	0.5	1	1	0
11/10/2020 12:00	0.2	13.9	1,501.7	0.2	0.6	1	1	0
11/10/2020 13:00	0.2	13.9	1,522.1	0.2	0.6	1	1	0
11/10/2020 14:00	0.2	14.0	1,403.1	0.2	0.5	1	1	0
11/10/2020 15:00	0.3	13.7	1,654.1	0.2	0.9	1	1	1
11/10/2020 16:00	0.5	12.9	1,991.0	0.3	1.6	1	1	1
11/10/2020 17:00	0.4	12.5	2,075.5	0.3	1.3	1	1	1
11/10/2020 18:00	0.4	12.1	2,167.5	0.3	1.3	1	1	1
11/10/2020 19:00	0.3	12.1	2,159.2	0.3	1.0	1	1	1
11/10/2020 20:00	0.4	12.4	2,108.7	0.3	1.3	1	1	1
11/10/2020 21:00	0.4	12.5	2,093.4	0.3	1.3	1	1	1
11/10/2020 22:00	0.4	12.7	2,049.9	0.3	1.3	1	1	1
11/10/2020 23:00	0.4	12.8	2,030.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.2	1,871.1	0.3	27.8 #	24 #	24 #	17 #
Minimum:	0.2	12.1	1,385.2	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,167.5	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	0.5	12.8	2,024.7	0.3	1.7	1	1	1
11/11/2020 01:00	0.5	13.2	1,926.3	0.4	1.7	1	1	1
11/11/2020 02:00	0.2	13.9	1,580.3	0.3	0.6	1	1	0
11/11/2020 03:00	0.4	13.5	1,837.5	0.3	1.3	1	1	1
11/11/2020 04:00	0.5	13.0	1,988.7	0.3	1.7	1	1	1
11/11/2020 05:00	0.5	12.7	2,059.4	0.4	1.7	1	1	1
11/11/2020 06:00	0.4	12.3	2,138.4	0.4	1.3	1	1	1
11/11/2020 07:00	0.5	13.0	1,979.2	0.4	1.7	1	1	1
11/11/2020 08:00	0.2	13.9	1,678.2	0.3	0.6	1	1	0
11/11/2020 09:00	0.2	13.9	1,670.5	0.3	0.6	1	1	0
11/11/2020 10:00	0.2	13.9	1,645.0	0.2	0.6	1	1	0
11/11/2020 11:00	0.2	13.9	1,560.7	0.2	0.6	1	1	0
11/11/2020 12:00	0.2	13.9	1,648.1	0.2	0.6	1	1	0
11/11/2020 13:00	0.2	13.9	1,516.6	0.2	0.6	1	1	0
11/11/2020 14:00	0.2	13.9	1,676.6	0.2	0.6	1	1	0
11/11/2020 15:00	0.2	14.0	1,375.8	0.2	0.5	1	1	0
11/11/2020 16:00	0.4	13.3	1,854.1	0.2	1.3	1	1	1
11/11/2020 17:00	0.5	12.8	2,008.2	0.3	1.6	1	1	1
11/11/2020 18:00	0.4	12.5	2,059.7	0.3	1.3	1	1	1
11/11/2020 19:00	0.5	12.7	2,035.9	0.4	1.6	1	1	1
11/11/2020 20:00	0.4	12.8	1,999.1	0.3	1.3	1	1	1
11/11/2020 21:00	0.2	13.9	1,652.6	0.3	0.6	1	1	0
11/11/2020 22:00	0.4	13.5	1,822.8	0.3	1.3	1	1	1
11/11/2020 23:00	0.5	12.9	2,016.4	0.3	1.7	1	1	1
Average/Sum#:	0.4	13.3	1,823.1	0.3	27.1 #	24 #	24 #	14 #
Minimum:	0.2	12.3	1,375.8	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,138.4	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	0.5	12.8	2,023.8	0.4	1.6	1	1	1
11/12/2020 01:00	0.5	13.2	1,918.6	0.4	1.6	1	1	1
11/12/2020 02:00	0.2	13.9	1,563.0	0.3	0.6	1	1	0
11/12/2020 03:00	0.3	13.7	1,680.8	0.3	0.9	1	1	1
11/12/2020 04:00	0.5	12.9	2,021.0	0.3	1.7	1	1	1
11/12/2020 05:00	0.5	12.8	2,057.4	0.3	1.7	1	1	1
11/12/2020 06:00	0.4	12.2	2,188.7	0.4	1.3	1	1	1
11/12/2020 07:00	0.4	12.6	2,053.0	0.3	1.3	1	1	1
11/12/2020 08:00	0.2	13.9	1,623.9	0.3	0.6	1	1	0
11/12/2020 09:00	0.2	13.9	1,634.5	0.2	0.6	1	1	0
11/12/2020 10:00	0.2	13.9	1,662.5	0.2	0.6	1	1	0
11/12/2020 11:00	0.2	13.9	1,597.3	0.2	0.6	1	1	0
11/12/2020 12:00	0.2	13.9	1,693.2	0.2	0.6	1	1	0
11/12/2020 13:00	0.2	13.9	1,565.8	0.2	0.6	1	1	0
11/12/2020 14:00	0.2	13.9	1,554.9	0.2	0.6	1	1	0
11/12/2020 15:00	0.3	13.7	1,679.4	0.2	0.9	1	1	1
11/12/2020 16:00	0.5	12.6	2,033.0	0.3	1.6	1	1	1
11/12/2020 17:00	0.5	12.5	2,057.5	0.3	1.6	1	1	1
11/12/2020 18:00	0.5	12.4	2,074.2	0.4	1.6	1	1	1
11/12/2020 19:00	0.4	12.4	2,092.1	0.3	1.3	1	1	1
11/12/2020 20:00	0.4	12.7	1,998.0	0.3	1.3	1	1	1
11/12/2020 21:00	0.2	13.9	1,657.0	0.3	0.6	1	1	0
11/12/2020 22:00	0.4	13.5	1,816.0	0.3	1.3	1	1	1
11/12/2020 23:00	0.5	12.8	2,013.1	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.2	1,844.1	0.3	26.7 #	24 #	24 #	15 #
Minimum:	0.2	12.2	1,554.9	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,188.7	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	0.5	13.2	1,922.4	0.4	1.6	1	1	1
11/13/2020 01:00	0.3	13.7	1,494.9	0.3	0.8	1	1	1
11/13/2020 02:00	0.2	13.9	1,288.7	0.3	0.5	1	1	0
11/13/2020 03:00	0.2	13.9	1,357.3	0.2	0.5	1	1	0
11/13/2020 04:00	0.3	13.9	1,319.5	0.2	0.7	1	1	0
11/13/2020 05:00	0.3	13.9	1,583.7	0.3	0.9	1	1	0
11/13/2020 06:00	0.3	13.8	1,707.1	0.3	1.0	1	1	0
11/13/2020 07:00	0.4	13.5	1,809.2	0.3	1.3	1	1	1
11/13/2020 08:00	0.5	13.2	1,853.5	0.3	1.6	1	1	1
11/13/2020 09:00	0.2	13.9	1,668.6	0.3	0.6	1	1	0
11/13/2020 10:00	0.2	13.9	1,671.9	0.3	0.6	1	1	0
11/13/2020 11:00	0.2	13.9	1,646.2	0.2	0.6	1	1	0
11/13/2020 12:00	0.2	13.9	1,529.3	0.2	0.6	1	1	0
11/13/2020 13:00	0.3	13.8	1,642.5	0.2	0.9	1	1	0
11/13/2020 14:00	0.2	13.9	1,653.5	0.2	0.6	1	1	0
11/13/2020 15:00	0.4	13.4	1,756.1	0.2	1.2	1	1	1
11/13/2020 16:00	0.5	12.4	2,064.8	0.3	1.6	1	1	1
11/13/2020 17:00	0.5	12.5	2,045.5	0.3	1.6	1	1	1
11/13/2020 18:00	0.5	12.6	2,023.3	0.4	1.6	1	1	1
11/13/2020 19:00	0.5	13.1	1,869.8	0.4	1.6	1	1	1
11/13/2020 20:00	0.2	13.8	1,671.2	0.3	0.6	1	1	0
11/13/2020 21:00	0.3	13.6	1,683.9	0.3	0.9	1	1	1
11/13/2020 22:00	0.5	12.8	2,015.5	0.3	1.6	1	1	1
11/13/2020 23:00	0.3	13.5	1,637.6	0.3	0.9	1	1	1
Average/Sum#:	0.3	13.5	1,704.8	0.3	24.4 #	24 #	24 #	12 #
Minimum:	0.2	12.4	1,288.7	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,064.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	7.6	14.9	901.9	0.0	6.3	1	0	0
11/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2020 05:00	12.3	17.7	441.4	0.0	11.6	1	0	0
11/14/2020 06:00	17.7	15.3	946.5	0.0	39.5	1	0	0
11/14/2020 07:00	0.2	13.8	1,597.2	0.0	0.6	1	1	0
11/14/2020 08:00	0.3	13.8	1,693.4	0.0	0.9	1	1	0
11/14/2020 09:00	0.2	13.8	1,684.3	0.2	0.6	1	1	0
11/14/2020 10:00	0.3	13.8	1,693.4	0.2	0.9	1	1	0
11/14/2020 11:00	0.2	13.9	1,688.5	0.2	0.6	1	1	0
11/14/2020 12:00	0.2	13.9	1,678.3	0.2	0.6	1	1	0
11/14/2020 13:00	0.2	13.9	1,678.0	0.2	0.6	1	1	0
11/14/2020 14:00	0.2	13.9	1,646.3	0.2	0.6	1	1	0
11/14/2020 15:00	0.3	13.7	1,694.6	0.2	0.9	1	1	1
11/14/2020 16:00	0.5	12.8	2,007.9	0.3	1.6	1	1	1
11/14/2020 17:00	0.5	12.7	2,025.6	0.3	1.6	1	1	1
11/14/2020 18:00	0.4	12.7	2,023.9	0.4	1.3	1	1	1
11/14/2020 19:00	0.4	12.8	1,984.5	0.3	1.3	1	1	1
11/14/2020 20:00	0.2	13.9	1,657.1	0.3	0.6	1	1	0
11/14/2020 21:00	0.4	13.5	1,820.9	0.3	1.3	1	1	1
11/14/2020 22:00	0.5	12.8	2,022.5	0.3	1.6	1	1	1
11/14/2020 23:00	0.5	13.2	1,950.0	0.4	1.7	1	1	1
Average/Sum#:	2.2	13.8	1,641.8	0.3	74.7 #	20 #	17 #	8 #
Minimum:	0.2	12.7	441.4	0.2	0.6	0	0	0
Maximum:	17.7	17.7	2,025.6	0.4	39.5	1	1	1
%SI	16.67	16.67	16.67	37.50	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	0.5	12.8	2,016.2	0.4	1.6	1	1	1
11/15/2020 01:00	0.5	13.1	1,926.3	0.4	1.6	1	1	1
11/15/2020 02:00	0.2	13.9	1,614.7	0.3	0.6	1	1	0
11/15/2020 03:00	0.3	13.7	1,695.4	0.3	0.9	1	1	1
11/15/2020 04:00	0.5	12.9	2,004.0	0.3	1.7	1	1	1
11/15/2020 05:00	0.5	13.3	1,881.6	0.3	1.6	1	1	1
11/15/2020 06:00	0.2	13.8	1,652.9	0.3	0.6	1	1	0
11/15/2020 07:00	0.3	13.9	1,477.7	0.3	0.8	1	1	0
11/15/2020 08:00	0.3	13.8	1,664.6	0.2	0.9	1	1	0
11/15/2020 09:00	0.3	13.8	1,682.3	0.2	0.9	1	1	0
11/15/2020 10:00	0.3	13.9	1,687.8	0.2	1.0	1	1	0
11/15/2020 11:00	0.2	13.9	1,683.7	0.2	0.6	1	1	0
11/15/2020 12:00	0.2	13.9	1,685.5	0.2	0.6	1	1	0
11/15/2020 13:00	0.2	13.9	1,686.7	0.2	0.6	1	1	0
11/15/2020 14:00	0.2	13.9	1,678.4	0.2	0.6	1	1	0
11/15/2020 15:00	0.2	13.9	1,449.6	0.2	0.5	1	1	0
11/15/2020 16:00	0.2	13.9	1,558.6	0.2	0.6	1	1	0
11/15/2020 17:00	0.2	13.9	1,563.5	0.2	0.6	1	1	0
11/15/2020 18:00	0.2	13.9	1,594.2	0.2	0.6	1	1	0
11/15/2020 19:00	0.2	13.9	1,626.8	0.2	0.6	1	1	0
11/15/2020 20:00	0.4	13.5	1,815.0	0.2	1.3	1	1	1
11/15/2020 21:00	0.5	13.1	1,884.5	0.3	1.6	1	1	1
11/15/2020 22:00	0.3	13.8	1,730.5	0.3	1.0	1	1	1
11/15/2020 23:00	0.5	12.8	2,009.3	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.6	1,719.6	0.3	23.0 #	24 #	24 #	9 #
Minimum:	0.2	12.8	1,449.6	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,016.2	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	0.4	13.3	1,819.9	0.3	1.3	1	1	1
11/16/2020 01:00	0.2	13.9	1,293.1	0.3	0.5	1	1	0
11/16/2020 02:00	0.2	13.9	1,286.9	0.2	0.5	1	1	0
11/16/2020 03:00	0.2	13.9	1,285.8	0.2	0.5	1	1	0
11/16/2020 04:00	0.3	13.7	1,682.9	0.2	0.9	1	1	1
11/16/2020 05:00	0.5	12.8	2,008.4	0.3	1.6	1	1	1
11/16/2020 06:00	0.4	12.6	2,052.6	0.3	1.3	1	1	1
11/16/2020 07:00	0.4	12.8	1,962.8	0.3	1.3	1	1	1
11/16/2020 08:00	0.2	13.9	1,685.3	0.3	0.6	1	1	0
11/16/2020 09:00	0.2	13.9	1,628.3	0.2	0.6	1	1	0
11/16/2020 10:00	0.2	13.9	1,668.4	0.2	0.6	1	1	0
11/16/2020 11:00	0.2	13.9	1,678.4	0.2	0.6	1	1	0
11/16/2020 12:00	0.2	13.9	1,669.6	0.2	0.6	1	1	0
11/16/2020 13:00	0.2	13.9	1,672.8	0.2	0.6	1	1	0
11/16/2020 14:00	0.2	13.9	1,618.7	0.2	0.6	1	1	0
11/16/2020 15:00	0.3	13.6	1,703.6	0.2	0.9	1	1	1
11/16/2020 16:00	0.5	12.6	2,017.0	0.3	1.6	1	1	1
11/16/2020 17:00	0.4	12.3	2,080.5	0.3	1.3	1	1	1
11/16/2020 18:00	0.4	12.2	2,107.1	0.3	1.3	1	1	1
11/16/2020 19:00	0.4	12.2	2,094.7	0.3	1.3	1	1	1
11/16/2020 20:00	0.4	12.3	2,090.3	0.3	1.3	1	1	1
11/16/2020 21:00	0.4	12.5	2,040.9	0.3	1.3	1	1	1
11/16/2020 22:00	0.4	12.5	2,050.2	0.3	1.3	1	1	1
11/16/2020 23:00	0.5	12.7	2,025.2	0.3	1.6	1	1	1
Average/Sum#:	0.3	13.2	1,801.0	0.3	24.0 #	24 #	24 #	14 #
Minimum:	0.2	12.2	1,285.8	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,107.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	0.5	12.6	2,024.3	0.4	1.6	1	1	1
11/17/2020 01:00	0.5	12.8	1,966.1	0.4	1.6	1	1	1
11/17/2020 02:00	0.2	13.9	1,533.2	0.3	0.6	1	1	0
11/17/2020 03:00	0.2	13.9	1,519.1	0.3	0.6	1	1	0
11/17/2020 04:00	0.4	13.6	1,719.2	0.2	1.2	1	1	1
11/17/2020 05:00	0.5	12.7	2,021.4	0.3	1.6	1	1	1
11/17/2020 06:00	0.5	12.4	2,091.2	0.3	1.6	1	1	1
11/17/2020 07:00	0.5	12.8	1,975.1	0.4	1.6	1	1	1
11/17/2020 08:00	0.3	13.9	1,663.4	0.3	0.9	1	1	0
11/17/2020 09:00	0.3	13.9	1,561.7	0.3	0.9	1	1	0
11/17/2020 10:00	0.2	13.9	1,548.7	0.3	0.6	1	1	0
11/17/2020 11:00	0.2	13.8	1,693.8	0.2	0.6	1	1	0
11/17/2020 12:00	0.2	13.9	1,462.7	0.2	0.6	1	1	0
11/17/2020 13:00	0.2	13.8	1,567.6	0.2	0.6	1	1	0
11/17/2020 14:00	0.2	13.8	1,598.9	0.2	0.6	1	1	0
11/17/2020 15:00	0.5	13.3	1,814.4	0.3	1.6	1	1	1
11/17/2020 16:00	0.4	12.3	2,073.4	0.3	1.3	1	1	1
11/17/2020 17:00	0.4	12.2	2,092.3	0.3	1.3	1	1	1
11/17/2020 18:00	0.4	12.2	2,088.3	0.3	1.3	1	1	1
11/17/2020 19:00	0.4	12.3	2,063.5	0.3	1.3	1	1	1
11/17/2020 20:00	0.4	12.5	2,023.7	0.3	1.3	1	1	1
11/17/2020 21:00	0.4	12.5	2,021.6	0.3	1.3	1	1	1
11/17/2020 22:00	0.4	12.5	2,024.6	0.3	1.3	1	1	1
11/17/2020 23:00	0.5	12.9	1,954.2	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,837.6	0.3	27.5 #	24 #	24 #	15 #
Minimum:	0.2	12.2	1,462.7	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,092.3	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	0.5	12.5	2,020.2	0.4	1.6	1	1	1
11/18/2020 01:00	0.4	13.2	1,803.7	0.4	1.2	1	1	1
11/18/2020 02:00	0.2	13.9	1,394.9	0.3	0.5	1	1	0
11/18/2020 03:00	0.2	13.9	1,296.0	0.2	0.5	1	1	0
11/18/2020 04:00	0.3	13.6	1,688.1	0.2	0.9	1	1	1
11/18/2020 05:00	0.5	12.5	2,037.2	0.3	1.6	1	1	1
11/18/2020 06:00	0.4	12.2	2,088.9	0.3	1.3	1	1	1
11/18/2020 07:00	0.4	12.7	1,957.5	0.3	1.3	1	1	1
11/18/2020 08:00	0.2	13.9	1,507.4	0.3	0.6	1	1	0
11/18/2020 09:00	0.2	13.9	1,510.1	0.2	0.6	1	1	0
11/18/2020 10:00	0.2	13.9	1,572.7	0.2	0.6	1	1	0
11/18/2020 11:00	0.2	13.9	1,690.4	0.2	0.6	1	1	0
11/18/2020 12:00	0.2	13.9	1,668.3	0.2	0.6	1	1	0
11/18/2020 13:00	0.2	13.9	1,579.8	0.2	0.6	1	1	0
11/18/2020 14:00	0.2	13.9	1,509.1	0.2	0.6	1	1	0
11/18/2020 15:00	0.3	13.9	1,689.9	0.2	1.0	1	1	1
11/18/2020 16:00	0.6	12.9	1,981.5	0.3	2.0	1	1	1
11/18/2020 17:00	0.5	12.7	2,029.0	0.4	1.6	1	1	1
11/18/2020 18:00	0.5	12.5	2,079.2	0.4	1.6	1	1	1
11/18/2020 19:00	0.4	12.9	1,959.9	0.4	1.3	1	1	1
11/18/2020 20:00	0.5	13.1	1,924.1	0.4	1.6	1	1	1
11/18/2020 21:00	0.5	13.2	1,919.2	0.4	1.6	1	1	1
11/18/2020 22:00	0.5	13.2	1,928.2	0.4	1.7	1	1	1
11/18/2020 23:00	0.5	13.2	1,927.7	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.3	1,781.8	0.3	27.2 #	24 #	24 #	15 #
Minimum:	0.2	12.2	1,296.0	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,088.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	0.5	13.2	1,909.1	0.4	1.6	1	1	1
11/19/2020 01:00	0.2	13.9	1,522.8	0.3	0.6	1	1	0
11/19/2020 02:00	0.2	13.9	1,370.4	0.3	0.5	1	1	0
11/19/2020 03:00	0.2	13.9	1,297.7	0.2	0.5	1	1	0
11/19/2020 04:00	0.2	13.9	1,294.9	0.2	0.5	1	1	0
11/19/2020 05:00	0.3	13.8	1,549.3	0.2	0.9	1	1	1
11/19/2020 06:00	0.6	13.0	1,996.8	0.3	2.0	1	1	1
11/19/2020 07:00	0.5	13.1	1,957.6	0.3	1.7	1	1	1
11/19/2020 08:00	0.2	13.9	1,601.7	0.3	0.6	1	1	0
11/19/2020 09:00	0.2	13.9	1,662.9	0.3	0.6	1	1	0
11/19/2020 10:00	0.2	13.9	1,691.0	0.2	0.6	1	1	0
11/19/2020 11:00	0.2	13.9	1,588.4	0.2	0.6	1	1	0
11/19/2020 12:00	0.2	13.9	1,695.3	0.2	0.6	1	1	0
11/19/2020 13:00	0.2	13.9	1,640.1	0.2	0.6	1	1	0
11/19/2020 14:00	0.2	13.9	1,673.6	0.2	0.6	1	1	0
11/19/2020 15:00	0.2	14.0	1,313.2	0.2	0.5	1	1	0
11/19/2020 16:00	0.2	13.9	1,590.2	0.2	0.6	1	1	0
11/19/2020 17:00	0.2	13.9	1,712.7	0.2	0.6	1	1	1
11/19/2020 18:00	0.5	12.7	2,037.8	0.3	1.6	1	1	1
11/19/2020 19:00	0.4	12.4	2,101.9	0.3	1.3	1	1	1
11/19/2020 20:00	0.4	12.6	2,066.5	0.3	1.3	1	1	1
11/19/2020 21:00	0.4	12.9	1,991.8	0.3	1.3	1	1	1
11/19/2020 22:00	0.4	12.7	2,034.0	0.3	1.3	1	1	1
11/19/2020 23:00	0.4	13.1	1,948.5	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.5	1,718.7	0.3	22.3 #	24 #	24 #	11 #
Minimum:	0.2	12.4	1,294.9	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,101.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	0.5	12.8	2,030.6	0.3	1.7	1	1	1
11/20/2020 01:00	0.5	13.2	1,916.7	0.4	1.6	1	1	1
11/20/2020 02:00	0.2	13.9	1,585.2	0.3	0.6	1	1	0
11/20/2020 03:00	0.2	13.9	1,583.8	0.3	0.6	1	1	0
11/20/2020 04:00	0.3	13.8	1,723.5	0.2	1.0	1	1	1
11/20/2020 05:00	0.5	12.7	2,056.5	0.3	1.7	1	1	1
11/20/2020 06:00	0.4	12.5	2,101.2	0.3	1.3	1	1	1
11/20/2020 07:00	0.4	12.6	2,069.7	0.3	1.3	1	1	1
11/20/2020 08:00	0.4	12.8	2,011.3	0.3	1.3	1	1	1
11/20/2020 09:00	0.4	12.9	1,963.5	0.3	1.3	1	1	1
11/20/2020 10:00	0.2	13.9	1,655.8	0.3	0.6	1	1	0
11/20/2020 11:00	0.2	14.0	1,581.6	0.2	0.6	1	1	0
11/20/2020 12:00	0.2	14.0	1,641.3	0.2	0.6	1	1	0
11/20/2020 13:00	0.2	14.0	1,501.7	0.2	0.6	1	1	0
11/20/2020 14:00	0.2	14.0	1,539.4	0.2	0.6	1	1	0
11/20/2020 15:00	0.4	13.5	1,816.6	0.2	1.3	1	1	1
11/20/2020 16:00	0.5	12.7	2,060.0	0.3	1.7	1	1	1
11/20/2020 17:00	0.5	12.5	2,106.5	0.4	1.7	1	1	1
11/20/2020 18:00	0.4	12.4	2,121.9	0.4	1.3	1	1	1
11/20/2020 19:00	0.4	12.4	2,117.1	0.3	1.3	1	1	1
11/20/2020 20:00	0.4	12.4	2,121.2	0.3	1.3	1	1	1
11/20/2020 21:00	0.4	12.5	2,110.7	0.3	1.3	1	1	1
11/20/2020 22:00	0.4	12.5	2,082.2	0.3	1.3	1	1	1
11/20/2020 23:00	0.4	12.7	2,038.2	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.1	1,897.3	0.3	27.9 #	24 #	24 #	17 #
Minimum:	0.2	12.4	1,501.7	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,121.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	0.4	12.7	2,026.7	0.3	1.3	1	1	1
11/21/2020 01:00	0.4	13.1	1,932.7	0.3	1.3	1	1	1
11/21/2020 02:00	0.5	13.2	1,901.5	0.3	1.6	1	1	1
11/21/2020 03:00	0.2	13.9	1,748.4	0.3	0.7	1	1	0
11/21/2020 04:00	0.3	13.4	1,830.9	0.3	1.0	1	1	1
11/21/2020 05:00	0.4	12.6	2,062.3	0.2	1.3	1	1	1
11/21/2020 06:00	0.4	12.5	2,088.0	0.3	1.3	1	1	1
11/21/2020 07:00	0.2	13.7	1,613.1	0.3	0.6	1	1	1
11/21/2020 08:00	0.2	13.9	1,604.7	0.2	0.6	1	1	0
11/21/2020 09:00	0.2	13.9	1,611.1	0.2	0.6	1	1	0
11/21/2020 10:00	0.2	14.0	1,469.0	0.2	0.6	1	1	0
11/21/2020 11:00	0.2	14.0	1,666.3	0.2	0.6	1	1	0
11/21/2020 12:00	0.2	14.0	1,665.7	0.2	0.6	1	1	0
11/21/2020 13:00	0.2	14.0	1,685.5	0.2	0.6	1	1	0
11/21/2020 14:00	0.2	14.0	1,592.8	0.2	0.6	1	1	0
11/21/2020 15:00	0.4	13.4	1,835.2	0.2	1.3	1	1	1
11/21/2020 16:00	0.5	12.6	2,056.8	0.3	1.6	1	1	1
11/21/2020 17:00	0.5	12.5	2,084.1	0.4	1.6	1	1	1
11/21/2020 18:00	0.5	12.4	2,111.1	0.4	1.6	1	1	1
11/21/2020 19:00	0.5	12.4	2,099.8	0.3	1.6	1	1	1
11/21/2020 20:00	0.5	12.5	2,051.4	0.3	1.6	1	1	1
11/21/2020 21:00	0.2	13.9	1,676.8	0.3	0.6	1	1	0
11/21/2020 22:00	0.4	13.4	1,816.6	0.3	1.3	1	1	1
11/21/2020 23:00	0.4	12.6	2,055.2	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.3	1,845.2	0.3	25.8 #	24 #	24 #	15 #
Minimum:	0.2	12.4	1,469.0	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,111.1	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	0.4	12.7	2,032.8	0.3	1.3	1	1	1
11/22/2020 01:00	0.3	13.3	1,798.1	0.3	0.9	1	1	1
11/22/2020 02:00	0.1	13.9	1,297.5	0.2	0.2	1	1	0
11/22/2020 03:00	0.2	13.9	1,354.4	0.2	0.5	1	1	0
11/22/2020 04:00	0.2	13.9	1,614.4	0.2	0.6	1	1	0
11/22/2020 05:00	0.4	13.5	1,830.8	0.2	1.3	1	1	1
11/22/2020 06:00	0.4	13.5	1,864.6	0.3	1.3	1	1	1
11/22/2020 07:00	0.2	13.9	1,510.8	0.3	0.6	1	1	0
11/22/2020 08:00	0.2	13.9	1,669.7	0.2	0.6	1	1	0
11/22/2020 09:00	0.2	13.9	1,685.7	0.2	0.6	1	1	0
11/22/2020 10:00	0.2	13.9	1,614.2	0.2	0.6	1	1	0
11/22/2020 11:00	0.2	13.9	1,667.8	0.2	0.6	1	1	0
11/22/2020 12:00	0.2	13.9	1,635.6	0.2	0.6	1	1	0
11/22/2020 13:00	0.2	13.9	1,629.1	0.2	0.6	1	1	0
11/22/2020 14:00	0.2	13.9	1,687.0	0.2	0.6	1	1	0
11/22/2020 15:00	0.4	13.4	1,819.1	0.2	1.3	1	1	1
11/22/2020 16:00	0.5	12.5	2,061.9	0.3	1.6	1	1	1
11/22/2020 17:00	0.4	12.4	2,076.2	0.3	1.3	1	1	1
11/22/2020 18:00	0.4	12.5	2,061.0	0.3	1.3	1	1	1
11/22/2020 19:00	0.4	12.6	2,014.1	0.3	1.3	1	1	1
11/22/2020 20:00	0.2	13.9	1,680.5	0.3	0.6	1	1	0
11/22/2020 21:00	0.4	13.3	1,838.9	0.3	1.3	1	1	1
11/22/2020 22:00	0.5	12.5	2,064.1	0.3	1.6	1	1	1
11/22/2020 23:00	0.4	13.3	1,854.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.4	1,765.1	0.3	22.5 #	24 #	24 #	12 #
Minimum:	0.1	12.4	1,297.5	0.2	0.2	1	1	0
Maximum:	0.5	13.9	2,076.2	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	0.3	13.7	1,696.5	0.3	0.9	1	1	1
11/23/2020 01:00	0.5	13.0	1,944.8	0.3	1.6	1	1	1
11/23/2020 02:00	3.3	14.4	1,218.8	0.0	7.5	1	0	0
11/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/23/2020 05:00	14.6	17.3	501.4	0.0	18.8	1	0	0
11/23/2020 06:00	11.8	14.5	1,170.2	0.0	28.5	1	0	0
11/23/2020 07:00	0.2	13.9	1,695.1	0.0	0.6	1	1	0
11/23/2020 08:00	0.2	13.9	1,621.8	0.0	0.6	1	1	0
11/23/2020 09:00	0.2	13.9	1,651.7	0.2	0.6	1	1	0
11/23/2020 10:00	0.2	13.9	1,579.2	0.2	0.6	1	1	0
11/23/2020 11:00	0.2	13.9	1,660.8	0.2	0.6	1	1	0
11/23/2020 12:00	0.2	13.9	1,681.9	0.2	0.6	1	1	0
11/23/2020 13:00	0.2	13.9	1,634.1	0.2	0.6	1	1	0
11/23/2020 14:00	0.2	13.9	1,680.8	0.2	0.6	1	1	0
11/23/2020 15:00	0.3	13.7	1,749.2	0.2	1.0	1	1	1
11/23/2020 16:00	0.5	12.6	2,052.0	0.3	1.6	1	1	1
11/23/2020 17:00	0.5	12.5	2,072.1	0.3	1.6	1	1	1
11/23/2020 18:00	0.4	12.5	2,079.3	0.4	1.3	1	1	1
11/23/2020 19:00	0.4	12.9	1,943.9	0.3	1.3	1	1	1
11/23/2020 20:00	0.2	13.9	1,658.4	0.3	0.6	1	1	0
11/23/2020 21:00	0.3	13.7	1,686.5	0.2	0.9	1	1	1
11/23/2020 22:00	0.4	12.7	2,009.5	0.2	1.3	1	1	1
11/23/2020 23:00	0.4	13.0	1,952.4	0.3	1.3	1	1	1
Average/Sum#:	1.6	13.7	1,679.1	0.3	73.0 #	22 #	19 #	10 #
Minimum:	0.2	12.5	501.4	0.2	0.6	0	0	0
Maximum:	14.6	17.3	2,079.3	0.4	28.5	1	1	1
%SI	8.33	8.33	8.33	29.17	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	0.4	13.0	1,925.1	0.3	1.3	1	1	1
11/24/2020 01:00	0.2	13.9	1,553.3	0.3	0.6	1	1	0
11/24/2020 02:00	0.2	13.9	1,558.0	0.2	0.6	1	1	0
11/24/2020 03:00	0.2	13.9	1,575.0	0.2	0.6	1	1	0
11/24/2020 04:00	0.4	13.4	1,813.2	0.2	1.3	1	1	1
11/24/2020 05:00	0.5	12.6	2,059.5	0.3	1.6	1	1	1
11/24/2020 06:00	0.4	12.1	2,176.5	0.3	1.3	1	1	1
11/24/2020 07:00	0.4	12.4	2,109.4	0.3	1.3	1	1	1
11/24/2020 08:00	0.3	13.2	1,862.2	0.3	1.0	1	1	1
11/24/2020 09:00	0.2	13.9	1,683.0	0.2	0.6	1	1	0
11/24/2020 10:00	0.2	13.9	1,662.4	0.2	0.6	1	1	0
11/24/2020 11:00	0.2	13.9	1,669.3	0.2	0.6	1	1	0
11/24/2020 12:00	0.2	14.0	1,656.6	0.2	0.6	1	1	0
11/24/2020 13:00	0.2	14.0	1,667.5	0.2	0.6	1	1	0
11/24/2020 14:00	0.2	14.0	1,586.2	0.2	0.6	1	1	0
11/24/2020 15:00	0.3	13.8	1,565.7	0.2	0.9	1	1	1
11/24/2020 16:00	0.4	12.5	2,073.0	0.2	1.3	1	1	1
11/24/2020 17:00	0.5	12.3	2,121.3	0.3	1.6	1	1	1
11/24/2020 18:00	0.4	12.2	2,143.7	0.3	1.3	1	1	1
11/24/2020 19:00	0.4	12.2	2,138.2	0.3	1.3	1	1	1
11/24/2020 20:00	0.4	12.2	2,146.4	0.3	1.3	1	1	1
11/24/2020 21:00	0.4	12.4	2,122.4	0.3	1.3	1	1	1
11/24/2020 22:00	0.4	12.4	2,109.5	0.3	1.3	1	1	1
11/24/2020 23:00	0.5	12.7	2,067.2	0.3	1.7	1	1	1
Average/Sum#:	0.3	13.1	1,876.9	0.3	25.2 #	24 #	24 #	15 #
Minimum:	0.2	12.1	1,553.3	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,176.5	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	0.5	12.6	2,070.0	0.4	1.6	1	1	1
11/25/2020 01:00	0.5	13.1	1,935.8	0.4	1.6	1	1	1
11/25/2020 02:00	0.2	13.9	1,561.3	0.3	0.6	1	1	0
11/25/2020 03:00	0.2	13.9	1,373.5	0.3	0.5	1	1	0
11/25/2020 04:00	0.3	13.9	1,558.2	0.2	0.9	1	1	1
11/25/2020 05:00	0.6	12.9	2,008.5	0.3	2.0	1	1	1
11/25/2020 06:00	0.6	13.0	1,995.7	0.4	2.0	1	1	1
11/25/2020 07:00	0.5	12.9	1,987.1	0.4	1.6	1	1	1
11/25/2020 08:00	0.2	13.8	1,671.0	0.3	0.6	1	1	0
11/25/2020 09:00	0.2	13.9	1,632.6	0.3	0.6	1	1	0
11/25/2020 10:00	0.2	13.9	1,693.6	0.2	0.6	1	1	0
11/25/2020 11:00	0.2	13.9	1,694.8	0.2	0.6	1	1	0
11/25/2020 12:00	0.2	13.9	1,694.5	0.2	0.6	1	1	0
11/25/2020 13:00	0.2	13.9	1,678.8	0.2	0.6	1	1	0
11/25/2020 14:00	0.2	14.0	1,646.8	0.2	0.6	1	1	0
11/25/2020 15:00	0.2	14.0	1,347.0	0.2	0.5	1	1	0
11/25/2020 16:00	0.2	13.9	1,629.8	0.2	0.6	1	1	0
11/25/2020 17:00	0.2	13.9	1,603.7	0.2	0.6	1	1	0
11/25/2020 18:00	0.2	13.9	1,687.1	0.2	0.6	1	1	0
11/25/2020 19:00	0.4	13.4	1,848.1	0.2	1.3	1	1	1
11/25/2020 20:00	0.4	13.0	1,914.7	0.3	1.3	1	1	1
11/25/2020 21:00	0.3	13.7	1,788.8	0.3	1.0	1	1	1
11/25/2020 22:00	0.5	12.8	2,025.6	0.3	1.7	1	1	1
11/25/2020 23:00	5.5	14.4	1,234.1	0.0	6.9	1	0	1
Average/Sum#:	0.5	13.6	1,720.0	0.3	29.5 #	24 #	23 #	11 #
Minimum:	0.2	12.6	1,234.1	0.2	0.5	1	0	0
Maximum:	5.5	14.4	2,070.0	0.4	6.9	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2020 04:00	41.2	17.5	477.8	0.0	70.4	1	0	0
11/27/2020 05:00	12.8	14.9	1,074.5	0.0	30.3	1	0	0
11/27/2020 06:00	0.2	13.9	1,704.6	0.0	0.6	1	1	0
11/27/2020 07:00	0.2	13.9	1,609.8	0.0	0.6	1	1	0
11/27/2020 08:00	0.2	13.9	1,616.5	0.2	0.6	1	1	0
11/27/2020 09:00	0.2	13.9	1,694.9	0.2	0.6	1	1	0
11/27/2020 10:00	0.2	13.9	1,687.0	0.2	0.6	1	1	0
11/27/2020 11:00	0.2	13.9	1,703.0	0.2	0.6	1	1	0
11/27/2020 12:00	0.2	14.0	1,687.2	0.2	0.6	1	1	0
11/27/2020 13:00	0.2	14.0	1,613.9	0.2	0.6	1	1	0
11/27/2020 14:00	0.2	14.0	1,656.4	0.2	0.6	1	1	0
11/27/2020 15:00	0.2	13.9	1,578.9	0.2	0.6	1	1	1
11/27/2020 16:00	0.5	12.9	1,999.5	0.3	1.7	1	1	1
11/27/2020 17:00	0.4	12.6	2,084.2	0.3	1.3	1	1	1
11/27/2020 18:00	0.4	12.7	2,048.0	0.3	1.3	1	1	1
11/27/2020 19:00	0.5	12.7	2,042.4	0.3	1.6	1	1	1
11/27/2020 20:00	0.5	12.9	1,981.1	0.4	1.6	1	1	1
11/27/2020 21:00	0.2	13.9	1,706.5	0.3	0.6	1	1	0
11/27/2020 22:00	0.4	13.5	1,842.8	0.3	1.3	1	1	1
11/27/2020 23:00	0.5	12.9	2,030.6	0.3	1.7	1	1	1
Average/Sum#:	3.0	13.8	1,692.0	0.3	117.8 #	20 #	18 #	8 #
Minimum:	0.2	12.6	477.8	0.2	0.6	0	0	0
Maximum:	41.2	17.5	2,084.2	0.4	70.4	1	1	1
%SI	16.67	16.67	16.67	33.33	16.67	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	0.5	12.9	2,038.3	0.4	1.7	1	1	1
11/28/2020 01:00	0.5	13.2	1,942.0	0.4	1.7	1	1	1
11/28/2020 02:00	0.2	13.9	1,586.4	0.3	0.6	1	1	0
11/28/2020 03:00	0.4	13.5	1,827.2	0.3	1.3	1	1	1
11/28/2020 04:00	0.5	13.2	1,946.1	0.3	1.7	1	1	1
11/28/2020 05:00	0.5	13.1	1,966.3	0.4	1.7	1	1	1
11/28/2020 06:00	0.2	13.9	1,693.9	0.3	0.6	1	1	0
11/28/2020 07:00	0.2	13.9	1,643.2	0.3	0.6	1	1	0
11/28/2020 08:00	0.3	13.9	1,688.2	0.2	1.0	1	1	0
11/28/2020 09:00	0.2	13.9	1,556.0	0.2	0.6	1	1	0
11/28/2020 10:00	0.2	13.9	1,628.1	0.2	0.6	1	1	0
11/28/2020 11:00	0.2	13.9	1,694.4	0.2	0.6	1	1	0
11/28/2020 12:00	0.2	13.9	1,696.2	0.2	0.6	1	1	0
11/28/2020 13:00	0.2	14.0	1,546.7	0.2	0.6	1	1	0
11/28/2020 14:00	0.2	14.0	1,626.7	0.2	0.6	1	1	0
11/28/2020 15:00	0.3	13.7	1,698.4	0.2	0.9	1	1	1
11/28/2020 16:00	0.4	12.7	2,020.4	0.2	1.3	1	1	1
11/28/2020 17:00	0.4	12.5	2,073.3	0.3	1.3	1	1	1
11/28/2020 18:00	0.4	12.4	2,105.4	0.3	1.3	1	1	1
11/28/2020 19:00	0.4	12.4	2,104.7	0.3	1.3	1	1	1
11/28/2020 20:00	0.4	12.2	2,151.8	0.3	1.3	1	1	1
11/28/2020 21:00	0.3	13.3	1,806.0	0.3	0.9	1	1	1
11/28/2020 22:00	0.4	13.5	1,840.5	0.3	1.3	1	1	1
11/28/2020 23:00	0.5	12.8	2,047.9	0.3	1.7	1	1	1
Average/Sum#:	0.3	13.4	1,830.3	0.3	25.8 #	24 #	24 #	14 #
Minimum:	0.2	12.2	1,546.7	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,151.8	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	0.5	13.2	1,934.1	0.4	1.7	1	1	1
11/29/2020 01:00	0.2	13.9	1,569.8	0.3	0.6	1	1	0
11/29/2020 02:00	0.4	13.4	1,855.0	0.3	1.3	1	1	1
11/29/2020 03:00	0.5	12.8	2,040.9	0.3	1.7	1	1	1
11/29/2020 04:00	0.5	12.8	2,024.9	0.4	1.7	1	1	1
11/29/2020 05:00	0.2	13.9	1,706.1	0.3	0.6	1	1	0
11/29/2020 06:00	0.2	13.9	1,685.2	0.3	0.6	1	1	0
11/29/2020 07:00	0.2	13.9	1,609.4	0.2	0.6	1	1	0
11/29/2020 08:00	0.2	13.9	1,640.1	0.2	0.6	1	1	0
11/29/2020 09:00	0.2	13.9	1,587.6	0.2	0.6	1	1	0
11/29/2020 10:00	0.2	13.9	1,690.8	0.2	0.6	1	1	0
11/29/2020 11:00	0.2	13.9	1,669.9	0.2	0.6	1	1	0
11/29/2020 12:00	0.2	13.9	1,682.5	0.2	0.6	1	1	0
11/29/2020 13:00	0.2	13.9	1,679.0	0.2	0.6	1	1	0
11/29/2020 14:00	0.2	13.9	1,660.0	0.2	0.6	1	1	0
11/29/2020 15:00	0.2	13.9	1,677.7	0.2	0.6	1	1	0
11/29/2020 16:00	0.4	13.4	1,830.4	0.2	1.3	1	1	1
11/29/2020 17:00	0.4	12.5	2,093.2	0.3	1.3	1	1	1
11/29/2020 18:00	0.4	12.2	2,154.9	0.3	1.3	1	1	1
11/29/2020 19:00	0.4	12.4	2,074.8	0.3	1.3	1	1	1
11/29/2020 20:00	0.2	13.9	1,694.2	0.3	0.6	1	1	0
11/29/2020 21:00	0.4	13.4	1,834.9	0.3	1.3	1	1	1
11/29/2020 22:00	0.5	12.5	2,104.8	0.3	1.7	1	1	1
11/29/2020 23:00	0.5	12.8	2,042.9	0.4	1.7	1	1	1
Average/Sum#:	0.3	13.4	1,814.3	0.3	24.1 #	24 #	24 #	11 #
Minimum:	0.2	12.2	1,569.8	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,154.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0.5	12.8	2,059.1	0.4	1.7	1	1	1
11/30/2020 01:00	0.5	12.8	2,025.3	0.4	1.7	1	1	1
11/30/2020 02:00	0.2	13.9	1,572.7	0.3	0.6	1	1	0
11/30/2020 03:00	0.2	13.9	1,545.8	0.3	0.6	1	1	0
11/30/2020 04:00	0.4	13.6	1,775.2	0.2	1.3	1	1	1
11/30/2020 05:00	0.5	12.7	2,103.2	0.3	1.7	1	1	1
11/30/2020 06:00	0.5	12.6	2,111.9	0.4	1.7	1	1	1
11/30/2020 07:00	0.5	12.6	2,098.6	0.4	1.7	1	1	1
11/30/2020 08:00	0.4	13.1	1,933.6	0.4	1.3	1	1	1
11/30/2020 09:00	0.2	13.9	1,668.1	0.3	0.6	1	1	0
11/30/2020 10:00	0.2	13.9	1,567.9	0.2	0.6	1	1	0
11/30/2020 11:00	0.2	13.9	1,637.5	0.2	0.6	1	1	0
11/30/2020 12:00	0.2	13.9	1,618.2	0.2	0.6	1	1	0
11/30/2020 13:00	0.2	14.0	1,420.3	0.2	0.5	1	1	0
11/30/2020 14:00	0.2	13.9	1,672.3	0.2	0.6	1	1	0
11/30/2020 15:00	0.3	13.7	1,696.2	0.2	0.9	1	1	1
11/30/2020 16:00	0.5	12.7	2,036.7	0.3	1.6	1	1	1
11/30/2020 17:00	0.4	12.3	2,111.4	0.3	1.3	1	1	1
11/30/2020 18:00	0.4	12.3	2,120.4	0.3	1.3	1	1	1
11/30/2020 19:00	0.4	12.1	2,164.1	0.3	1.3	1	1	1
11/30/2020 20:00	0.4	12.4	2,113.2	0.3	1.3	1	1	1
11/30/2020 21:00	0.4	12.4	2,105.8	0.3	1.3	1	1	1
11/30/2020 22:00	0.4	12.5	2,077.7	0.3	1.3	1	1	1
11/30/2020 23:00	0.4	12.8	2,017.1	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.1	1,885.5	0.3	27.4 #	24 #	24 #	16 #
Minimum:	0.2	12.1	1,420.3	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,164.1	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0.4	12.7	2,041.9	0.3	1.3	1	1	1
12/01/2020 01:00	0.4	12.6	2,026.4	0.3	1.3	1	1	1
12/01/2020 02:00	0.2	13.9	1,562.1	0.3	0.6	1	1	0
12/01/2020 03:00	0.4	13.4	1,839.5	0.3	1.3	1	1	1
12/01/2020 04:00	0.4	12.5	2,097.3	0.3	1.3	1	1	1
12/01/2020 05:00	0.4	12.2	2,163.8	0.3	1.3	1	1	1
12/01/2020 06:00	0.3	12.0	2,197.6	0.3	1.0	1	1	1
12/01/2020 07:00	0.4	12.3	2,138.7	0.3	1.3	1	1	1
12/01/2020 08:00	0.4	12.5	2,086.5	0.3	1.3	1	1	1
12/01/2020 09:00	0.2	13.7	1,711.6	0.3	0.6	1	1	1
12/01/2020 10:00	0.2	14.0	1,698.2	0.2	0.7	1	1	0
12/01/2020 11:00	0.2	14.0	1,665.3	0.2	0.6	1	1	0
12/01/2020 12:00	0.2	14.0	1,675.5	0.2	0.6	1	1	0
12/01/2020 13:00	0.1	14.0	1,398.6	0.2	0.3	1	1	0
12/01/2020 14:00	0.2	14.0	1,603.5	0.2	0.6	1	1	0
12/01/2020 15:00	0.2	13.9	1,547.3	0.2	0.6	1	1	1
12/01/2020 16:00	0.4	12.8	1,999.4	0.2	1.3	1	1	1
12/01/2020 17:00	0.3	12.2	2,120.3	0.2	1.0	1	1	1
12/01/2020 18:00	0.3	12.1	2,156.5	0.2	1.0	1	1	1
12/01/2020 19:00	0.3	12.1	2,152.9	0.2	1.0	1	1	1
12/01/2020 20:00	0.3	12.1	2,164.3	0.2	1.0	1	1	1
12/01/2020 21:00	0.3	12.1	2,165.7	0.2	1.0	1	1	1
12/01/2020 22:00	0.3	12.2	2,162.6	0.2	1.0	1	1	1
12/01/2020 23:00	0.4	12.4	2,122.6	0.2	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,937.4	0.2	23.3 #	24 #	24 #	18 #
Minimum:	0.1	12.0	1,398.6	0.2	0.3	1	1	0
Maximum:	0.4	14.0	2,197.6	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0.4	12.6	2,101.6	0.3	1.3	1	1	1
12/02/2020 01:00	0.5	12.9	1,984.0	0.3	1.6	1	1	1
12/02/2020 02:00	0.2	13.9	1,571.3	0.3	0.6	1	1	0
12/02/2020 03:00	0.4	13.4	1,847.6	0.3	1.3	1	1	1
12/02/2020 04:00	0.5	12.6	2,072.8	0.3	1.6	1	1	1
12/02/2020 05:00	0.5	12.6	2,090.4	0.4	1.7	1	1	1
12/02/2020 06:00	0.4	12.4	2,117.4	0.4	1.3	1	1	1
12/02/2020 07:00	0.4	12.5	2,102.8	0.3	1.3	1	1	1
12/02/2020 08:00	0.4	12.7	2,045.9	0.3	1.3	1	1	1
12/02/2020 09:00	0.2	13.9	1,585.8	0.3	0.6	1	1	1
12/02/2020 10:00	0.2	13.9	1,666.8	0.2	0.6	1	1	0
12/02/2020 11:00	0.2	14.0	1,699.9	0.2	0.7	1	1	0
12/02/2020 12:00	0.2	14.0	1,652.9	0.2	0.6	1	1	0
12/02/2020 13:00	0.2	14.0	1,548.5	0.2	0.6	1	1	0
12/02/2020 14:00	0.2	14.0	1,583.5	0.2	0.6	1	1	0
12/02/2020 15:00	0.5	13.4	1,840.6	0.3	1.6	1	1	1
12/02/2020 16:00	0.5	12.5	2,105.6	0.3	1.7	1	1	1
12/02/2020 17:00	0.5	12.2	2,157.6	0.4	1.6	1	1	1
12/02/2020 18:00	0.4	12.1	2,186.9	0.3	1.3	1	1	1
12/02/2020 19:00	0.4	12.1	2,185.4	0.3	1.3	1	1	1
12/02/2020 20:00	0.4	12.3	2,124.3	0.3	1.3	1	1	1
12/02/2020 21:00	0.4	12.4	2,109.7	0.3	1.3	1	1	1
12/02/2020 22:00	0.4	12.5	2,100.4	0.3	1.3	1	1	1
12/02/2020 23:00	0.4	12.5	2,097.3	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.0	1,940.8	0.3	28.4 #	24 #	24 #	18 #
Minimum:	0.2	12.1	1,548.5	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,186.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0.4	12.6	2,084.1	0.3	1.3	1	1	1
12/03/2020 01:00	0.5	12.6	2,085.5	0.3	1.7	1	1	1
12/03/2020 02:00	0.5	12.7	2,021.0	0.4	1.6	1	1	1
12/03/2020 03:00	0.2	13.9	1,600.8	0.3	0.6	1	1	0
12/03/2020 04:00	0.4	13.5	1,848.2	0.3	1.3	1	1	1
12/03/2020 05:00	0.5	12.5	2,126.8	0.3	1.7	1	1	1
12/03/2020 06:00	0.4	12.1	2,214.2	0.3	1.3	1	1	1
12/03/2020 07:00	0.5	12.5	2,105.4	0.4	1.7	1	1	1
12/03/2020 08:00	0.5	12.7	2,073.3	0.4	1.7	1	1	1
12/03/2020 09:00	0.5	13.0	1,968.2	0.4	1.6	1	1	1
12/03/2020 10:00	0.2	13.9	1,696.7	0.3	0.6	1	1	0
12/03/2020 11:00	0.2	13.9	1,645.0	0.3	0.6	1	1	0
12/03/2020 12:00	0.2	13.9	1,678.3	0.2	0.6	1	1	0
12/03/2020 13:00	0.2	13.9	1,677.0	0.2	0.6	1	1	0
12/03/2020 14:00	0.4	13.5	1,833.6	0.2	1.3	1	1	1
12/03/2020 15:00	0.5	12.6	2,063.9	0.3	1.6	1	1	1
12/03/2020 16:00	0.5	12.3	2,133.9	0.3	1.6	1	1	1
12/03/2020 17:00	0.4	12.1	2,168.2	0.3	1.3	1	1	1
12/03/2020 18:00	0.3	12.0	2,181.3	0.3	1.0	1	1	1
12/03/2020 19:00	0.3	12.0	2,181.6	0.2	1.0	1	1	1
12/03/2020 20:00	0.4	12.3	2,127.5	0.2	1.3	1	1	1
12/03/2020 21:00	0.4	12.2	2,151.6	0.3	1.3	1	1	1
12/03/2020 22:00	0.4	12.3	2,133.1	0.3	1.3	1	1	1
12/03/2020 23:00	0.4	12.5	2,105.8	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.8	1,996.0	0.3	29.9 #	24 #	24 #	19 #
Minimum:	0.2	12.0	1,600.8	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,214.2	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0.4	12.6	2,104.5	0.3	1.3	1	1	1
12/04/2020 01:00	0.4	12.7	2,035.8	0.3	1.3	1	1	1
12/04/2020 02:00	0.2	13.9	1,687.4	0.3	0.6	1	1	0
12/04/2020 03:00	0.4	13.4	1,852.5	0.3	1.3	1	1	1
12/04/2020 04:00	0.5	12.5	2,109.8	0.3	1.7	1	1	1
12/04/2020 05:00	0.4	12.2	2,180.7	0.3	1.3	1	1	1
12/04/2020 06:00	0.4	12.0	2,204.9	0.3	1.3	1	1	1
12/04/2020 07:00	0.4	12.2	2,165.4	0.3	1.3	1	1	1
12/04/2020 08:00	0.5	12.7	2,066.6	0.3	1.7	1	1	1
12/04/2020 09:00	0.5	13.0	1,969.7	0.4	1.6	1	1	1
12/04/2020 10:00	0.2	13.9	1,620.2	0.3	0.6	1	1	0
12/04/2020 11:00	0.2	13.9	1,600.7	0.3	0.6	1	1	0
12/04/2020 12:00	0.5	13.2	1,929.1	0.3	1.7	1	1	1
12/04/2020 13:00	0.5	13.1	1,938.7	0.3	1.6	1	1	1
12/04/2020 14:00	0.2	13.9	1,663.3	0.3	0.6	1	1	0
12/04/2020 15:00	0.4	13.5	1,801.7	0.3	1.3	1	1	1
12/04/2020 16:00	0.5	12.5	2,098.6	0.3	1.6	1	1	1
12/04/2020 17:00	0.4	12.2	2,165.5	0.3	1.3	1	1	1
12/04/2020 18:00	0.4	12.2	2,173.7	0.3	1.3	1	1	1
12/04/2020 19:00	0.4	12.1	2,191.2	0.3	1.3	1	1	1
12/04/2020 20:00	0.4	12.2	2,155.8	0.3	1.3	1	1	1
12/04/2020 21:00	0.4	12.1	2,166.0	0.3	1.3	1	1	1
12/04/2020 22:00	0.4	12.3	2,133.9	0.3	1.3	1	1	1
12/04/2020 23:00	0.4	12.5	2,105.5	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.8	2,005.1	0.3	30.5 #	24 #	24 #	20 #
Minimum:	0.2	12.0	1,600.7	0.3	0.6	1	1	0
Maximum:	0.5	13.9	2,204.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	0.4	12.5	2,111.5	0.3	1.3	1	1	1
12/05/2020 01:00	0.5	12.6	2,085.4	0.3	1.7	1	1	1
12/05/2020 02:00	0.5	12.6	2,101.7	0.4	1.7	1	1	1
12/05/2020 03:00	0.5	12.6	2,104.1	0.4	1.7	1	1	1
12/05/2020 04:00	0.5	12.6	2,102.4	0.4	1.7	1	1	1
12/05/2020 05:00	0.5	12.5	2,107.1	0.4	1.7	1	1	1
12/05/2020 06:00	0.5	12.8	2,051.3	0.4	1.7	1	1	1
12/05/2020 07:00	0.2	13.9	1,670.3	0.3	0.6	1	1	0
12/05/2020 08:00	0.2	13.9	1,629.1	0.3	0.6	1	1	0
12/05/2020 09:00	0.2	13.9	1,682.4	0.2	0.6	1	1	0
12/05/2020 10:00	0.2	13.9	1,674.4	0.2	0.6	1	1	0
12/05/2020 11:00	0.2	13.9	1,706.1	0.2	0.6	1	1	0
12/05/2020 12:00	0.2	13.9	1,697.3	0.2	0.6	1	1	0
12/05/2020 13:00	0.2	13.9	1,656.1	0.2	0.6	1	1	0
12/05/2020 14:00	0.3	13.9	1,640.7	0.2	0.9	1	1	0
12/05/2020 15:00	0.5	13.4	1,842.4	0.3	1.6	1	1	1
12/05/2020 16:00	0.5	12.6	2,088.0	0.4	1.7	1	1	1
12/05/2020 17:00	0.5	12.3	2,150.7	0.4	1.7	1	1	1
12/05/2020 18:00	0.4	12.1	2,184.2	0.3	1.3	1	1	1
12/05/2020 19:00	0.4	12.0	2,207.9	0.3	1.3	1	1	1
12/05/2020 20:00	0.4	12.1	2,192.9	0.3	1.3	1	1	1
12/05/2020 21:00	0.4	12.2	2,186.7	0.3	1.3	1	1	1
12/05/2020 22:00	0.5	12.5	2,116.2	0.3	1.7	1	1	1
12/05/2020 23:00	0.5	12.6	2,111.9	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.0	1,962.5	0.3	30.2 #	24 #	24 #	16 #
Minimum:	0.2	12.0	1,629.1	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,207.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	0.5	12.6	2,109.1	0.4	1.7	1	1	1
12/06/2020 01:00	0.5	12.8	2,071.0	0.4	1.7	1	1	1
12/06/2020 02:00	0.5	12.8	2,070.6	0.4	1.7	1	1	1
12/06/2020 03:00	0.5	13.3	1,891.3	0.4	1.6	1	1	1
12/06/2020 04:00	0.3	13.7	1,800.5	0.3	1.0	1	1	1
12/06/2020 05:00	0.5	12.8	2,031.3	0.3	1.7	1	1	1
12/06/2020 06:00	0.5	13.0	1,955.2	0.3	1.6	1	1	1
12/06/2020 07:00	0.2	13.9	1,559.6	0.3	0.6	1	1	0
12/06/2020 08:00	0.2	13.9	1,564.2	0.3	0.6	1	1	0
12/06/2020 09:00	0.2	13.9	1,689.1	0.2	0.6	1	1	0
12/06/2020 10:00	0.2	13.9	1,688.9	0.2	0.6	1	1	0
12/06/2020 11:00	0.2	13.9	1,698.4	0.2	0.6	1	1	0
12/06/2020 12:00	0.2	14.0	1,617.5	0.2	0.6	1	1	0
12/06/2020 13:00	0.2	14.0	1,684.3	0.2	0.6	1	1	0
12/06/2020 14:00	0.2	14.0	1,654.6	0.2	0.6	1	1	0
12/06/2020 15:00	0.4	13.5	1,839.1	0.2	1.3	1	1	1
12/06/2020 16:00	0.5	12.6	2,077.2	0.3	1.7	1	1	1
12/06/2020 17:00	0.4	12.2	2,168.7	0.3	1.3	1	1	1
12/06/2020 18:00	0.4	12.1	2,193.8	0.3	1.3	1	1	1
12/06/2020 19:00	0.4	12.1	2,194.5	0.3	1.3	1	1	1
12/06/2020 20:00	0.4	12.1	2,191.8	0.3	1.3	1	1	1
12/06/2020 21:00	0.4	12.3	2,154.9	0.3	1.3	1	1	1
12/06/2020 22:00	0.4	12.5	2,100.7	0.3	1.3	1	1	1
12/06/2020 23:00	0.5	12.7	2,044.3	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,918.8	0.3	28.2 #	24 #	24 #	16 #
Minimum:	0.2	12.1	1,559.6	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,194.5	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0.4	12.6	2,064.1	0.3	1.3	1	1	1
12/07/2020 01:00	0.4	12.9	1,966.0	0.3	1.3	1	1	1
12/07/2020 02:00	0.2	13.9	1,609.0	0.3	0.6	1	1	0
12/07/2020 03:00	0.4	13.5	1,819.8	0.3	1.3	1	1	1
12/07/2020 04:00	0.5	12.7	2,051.9	0.3	1.7	1	1	1
12/07/2020 05:00	0.4	12.6	2,073.5	0.3	1.3	1	1	1
12/07/2020 06:00	0.4	12.2	2,152.0	0.3	1.3	1	1	1
12/07/2020 07:00	0.4	12.2	2,146.6	0.3	1.3	1	1	1
12/07/2020 08:00	0.4	12.3	2,126.8	0.3	1.3	1	1	1
12/07/2020 09:00	0.3	12.3	2,108.4	0.3	1.0	1	1	1
12/07/2020 10:00	0.2	13.7	1,691.7	0.2	0.6	1	1	1
12/07/2020 11:00	0.2	14.0	1,595.5	0.2	0.6	1	1	0
12/07/2020 12:00	0.2	14.0	1,589.1	0.2	0.6	1	1	0
12/07/2020 13:00	0.2	14.0	1,668.9	0.2	0.6	1	1	0
12/07/2020 14:00	0.3	13.6	1,659.9	0.2	0.9	1	1	1
12/07/2020 15:00	0.4	12.5	2,029.3	0.2	1.3	1	1	1
12/07/2020 16:00	0.3	12.4	2,070.9	0.2	1.0	1	1	1
12/07/2020 17:00	0.3	12.2	2,130.0	0.2	1.0	1	1	1
12/07/2020 18:00	0.4	12.3	2,129.7	0.2	1.3	1	1	1
12/07/2020 19:00	0.4	12.3	2,133.4	0.3	1.3	1	1	1
12/07/2020 20:00	0.4	12.3	2,149.2	0.3	1.3	1	1	1
12/07/2020 21:00	0.4	12.2	2,169.2	0.3	1.3	1	1	1
12/07/2020 22:00	0.4	12.3	2,138.0	0.3	1.3	1	1	1
12/07/2020 23:00	0.4	12.7	2,064.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.8	1,972.4	0.3	26.8 #	24 #	24 #	20 #
Minimum:	0.2	12.2	1,589.1	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,169.2	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	0.4	12.8	2,041.9	0.3	1.3	1	1	1
12/08/2020 01:00	0.5	13.1	1,938.2	0.3	1.6	1	1	1
12/08/2020 02:00	0.2	13.9	1,660.2	0.3	0.6	1	1	0
12/08/2020 03:00	0.3	13.5	1,793.9	0.3	1.0	1	1	1
12/08/2020 04:00	0.5	12.8	2,025.4	0.3	1.7	1	1	1
12/08/2020 05:00	0.5	13.1	1,972.8	0.3	1.7	1	1	1
12/08/2020 06:00	0.5	12.6	2,072.0	0.4	1.6	1	1	1
12/08/2020 07:00	0.4	12.3	2,149.5	0.4	1.3	1	1	1
12/08/2020 08:00	0.4	12.5	2,097.7	0.3	1.3	1	1	1
12/08/2020 09:00	0.5	13.0	1,961.8	0.3	1.6	1	1	1
12/08/2020 10:00	0.2	13.9	1,653.3	0.3	0.6	1	1	0
12/08/2020 11:00	0.2	14.0	1,579.3	0.3	0.6	1	1	0
12/08/2020 12:00	0.2	14.0	1,601.5	0.2	0.6	1	1	0
12/08/2020 13:00	0.2	14.0	1,566.8	0.2	0.6	1	1	0
12/08/2020 14:00	0.2	14.0	1,544.9	0.2	0.6	1	1	0
12/08/2020 15:00	0.3	13.7	1,708.2	0.2	0.9	1	1	1
12/08/2020 16:00	0.5	12.7	2,020.8	0.3	1.6	1	1	1
12/08/2020 17:00	0.4	12.2	2,141.1	0.3	1.3	1	1	1
12/08/2020 18:00	0.4	12.1	2,153.4	0.3	1.3	1	1	1
12/08/2020 19:00	0.4	12.0	2,180.5	0.3	1.3	1	1	1
12/08/2020 20:00	0.4	12.2	2,155.9	0.3	1.3	1	1	1
12/08/2020 21:00	0.4	12.4	2,117.1	0.3	1.3	1	1	1
12/08/2020 22:00	0.5	12.6	2,084.9	0.3	1.7	1	1	1
12/08/2020 23:00	0.5	12.8	2,050.4	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.0	1,928.0	0.3	29.1 #	24 #	24 #	18 #
Minimum:	0.2	12.0	1,544.9	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,180.5	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	0.5	12.7	2,055.3	0.4	1.7	1	1	1
12/09/2020 01:00	0.5	12.8	2,036.2	0.4	1.7	1	1	1
12/09/2020 02:00	0.5	13.2	1,932.9	0.4	1.7	1	1	1
12/09/2020 03:00	0.3	13.9	1,752.2	0.4	1.0	1	1	0
12/09/2020 04:00	0.4	13.5	1,824.7	0.3	1.3	1	1	1
12/09/2020 05:00	0.5	12.8	2,037.2	0.3	1.7	1	1	1
12/09/2020 06:00	0.5	12.5	2,090.5	0.4	1.6	1	1	1
12/09/2020 07:00	0.5	12.6	2,087.7	0.4	1.7	1	1	1
12/09/2020 08:00	0.5	12.7	2,072.4	0.4	1.7	1	1	1
12/09/2020 09:00	0.5	13.2	1,904.2	0.4	1.6	1	1	1
12/09/2020 10:00	0.2	13.9	1,753.3	0.3	0.7	1	1	0
12/09/2020 11:00	0.2	13.9	1,754.1	0.3	0.7	1	1	0
12/09/2020 12:00	0.2	13.8	1,751.3	0.2	0.7	1	1	0
12/09/2020 13:00	0.2	13.8	1,754.8	0.2	0.7	1	1	0
12/09/2020 14:00	0.2	13.8	1,751.7	0.2	0.7	1	1	0
12/09/2020 15:00	0.4	13.3	1,816.3	0.2	1.3	1	1	1
12/09/2020 16:00	0.4	12.4	2,054.6	0.3	1.3	1	1	1
12/09/2020 17:00	0.3	12.3	2,088.2	0.3	1.0	1	1	1
12/09/2020 18:00	0.3	12.3	2,087.2	0.2	1.0	1	1	1
12/09/2020 19:00	0.4	12.3	2,132.6	0.2	1.3	1	1	1
12/09/2020 20:00	0.4	12.4	2,111.0	0.3	1.3	1	1	1
12/09/2020 21:00	0.4	12.2	2,149.4	0.3	1.3	1	1	1
12/09/2020 22:00	0.4	12.2	2,141.9	0.3	1.3	1	1	1
12/09/2020 23:00	0.4	12.5	2,081.5	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.0	1,967.6	0.3	30.3 #	24 #	24 #	18 #
Minimum:	0.2	12.2	1,751.3	0.2	0.7	1	1	0
Maximum:	0.5	13.9	2,149.4	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	0.4	12.6	2,074.4	0.3	1.3	1	1	1
12/10/2020 01:00	0.5	12.7	2,045.2	0.3	1.6	1	1	1
12/10/2020 02:00	0.5	12.6	2,058.3	0.4	1.6	1	1	1
12/10/2020 03:00	0.2	13.9	1,695.1	0.3	0.6	1	1	0
12/10/2020 04:00	0.3	13.4	1,830.0	0.3	1.0	1	1	1
12/10/2020 05:00	0.4	12.3	2,122.5	0.2	1.3	1	1	1
12/10/2020 06:00	0.4	12.4	2,109.0	0.3	1.3	1	1	1
12/10/2020 07:00	0.4	12.4	2,096.7	0.3	1.3	1	1	1
12/10/2020 08:00	0.4	12.4	2,101.1	0.3	1.3	1	1	1
12/10/2020 09:00	0.4	12.4	2,100.4	0.3	1.3	1	1	1
12/10/2020 10:00	0.2	13.7	1,696.2	0.3	0.6	1	1	1
12/10/2020 11:00	0.2	14.0	1,626.8	0.2	0.6	1	1	0
12/10/2020 12:00	0.2	14.0	1,532.4	0.2	0.6	1	1	0
12/10/2020 13:00	0.2	14.0	1,574.9	0.2	0.6	1	1	0
12/10/2020 14:00	0.2	14.0	1,536.7	0.2	0.6	1	1	0
12/10/2020 15:00	0.3	13.5	1,819.1	0.2	1.0	1	1	1
12/10/2020 16:00	0.5	12.7	2,059.5	0.3	1.7	1	1	1
12/10/2020 17:00	0.5	12.4	2,132.7	0.3	1.7	1	1	1
12/10/2020 18:00	0.4	12.2	2,150.8	0.3	1.3	1	1	1
12/10/2020 19:00	0.4	12.3	2,125.9	0.3	1.3	1	1	1
12/10/2020 20:00	0.4	12.5	2,096.4	0.3	1.3	1	1	1
12/10/2020 21:00	0.4	12.4	2,113.2	0.3	1.3	1	1	1
12/10/2020 22:00	0.4	12.4	2,107.0	0.3	1.3	1	1	1
12/10/2020 23:00	0.5	12.7	2,070.0	0.3	1.7	1	1	1
Average/Sum#:	0.4	12.9	1,953.1	0.3	28.2 #	24 #	24 #	19 #
Minimum:	0.2	12.2	1,532.4	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,150.8	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	0.5	13.1	1,943.2	0.4	1.6	1	1	1
12/11/2020 01:00	0.2	13.9	1,702.9	0.3	0.6	1	1	0
12/11/2020 02:00	0.2	13.9	1,603.5	0.3	0.6	1	1	0
12/11/2020 03:00	0.2	13.9	1,594.9	0.2	0.6	1	1	0
12/11/2020 04:00	0.4	13.5	1,774.4	0.2	1.3	1	1	1
12/11/2020 05:00	0.5	12.8	2,063.6	0.3	1.7	1	1	1
12/11/2020 06:00	0.5	12.5	2,134.0	0.4	1.7	1	1	1
12/11/2020 07:00	0.5	12.5	2,112.2	0.4	1.7	1	1	1
12/11/2020 08:00	0.5	12.6	2,075.6	0.4	1.7	1	1	1
12/11/2020 09:00	0.2	13.9	1,668.3	0.3	0.6	1	1	0
12/11/2020 10:00	0.2	13.9	1,667.1	0.3	0.6	1	1	0
12/11/2020 11:00	0.2	13.9	1,650.1	0.2	0.6	1	1	0
12/11/2020 12:00	0.2	13.9	1,627.3	0.2	0.6	1	1	0
12/11/2020 13:00	0.3	13.9	1,670.4	0.2	0.9	1	1	0
12/11/2020 14:00	0.3	13.9	1,675.3	0.3	0.9	1	1	0
12/11/2020 15:00	0.4	13.5	1,823.4	0.3	1.3	1	1	1
12/11/2020 16:00	0.6	12.5	2,092.7	0.3	2.0	1	1	1
12/11/2020 17:00	0.5	12.4	2,120.0	0.3	1.6	1	1	1
12/11/2020 18:00	0.4	12.1	2,177.2	0.3	1.3	1	1	1
12/11/2020 19:00	0.4	12.1	2,182.0	0.3	1.3	1	1	1
12/11/2020 20:00	0.4	12.1	2,181.6	0.3	1.3	1	1	1
12/11/2020 21:00	0.4	12.1	2,179.2	0.3	1.3	1	1	1
12/11/2020 22:00	0.5	12.4	2,113.9	0.3	1.6	1	1	1
12/11/2020 23:00	0.5	12.6	2,084.2	0.3	1.7	1	1	1
Average/Sum#:	0.4	13.1	1,913.2	0.3	29.1 #	24 #	24 #	15 #
Minimum:	0.2	12.1	1,594.9	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,182.0	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	0.5	12.5	2,098.2	0.4	1.6	1	1	1
12/12/2020 01:00	0.5	12.6	2,064.1	0.4	1.6	1	1	1
12/12/2020 02:00	0.5	13.1	1,946.1	0.4	1.6	1	1	1
12/12/2020 03:00	0.2	13.8	1,622.9	0.3	0.6	1	1	0
12/12/2020 04:00	0.4	13.5	1,817.4	0.3	1.3	1	1	1
12/12/2020 05:00	0.6	13.2	1,947.0	0.3	2.0	1	1	1
12/12/2020 06:00	0.6	13.2	1,936.7	0.4	2.0	1	1	1
12/12/2020 07:00	0.2	13.8	1,690.5	0.4	0.6	1	1	1
12/12/2020 08:00	0.2	13.8	1,675.2	0.3	0.6	1	1	0
12/12/2020 09:00	0.3	13.8	1,687.3	0.2	0.9	1	1	0
12/12/2020 10:00	0.2	13.9	1,672.3	0.2	0.6	1	1	0
12/12/2020 11:00	0.2	13.9	1,582.7	0.2	0.6	1	1	0
12/12/2020 12:00	0.2	13.9	1,644.0	0.2	0.6	1	1	0
12/12/2020 13:00	0.2	13.9	1,701.2	0.2	0.6	1	1	0
12/12/2020 14:00	0.2	13.9	1,672.1	0.2	0.6	1	1	0
12/12/2020 15:00	0.4	13.4	1,825.5	0.2	1.3	1	1	1
12/12/2020 16:00	0.5	12.6	2,069.8	0.3	1.6	1	1	1
12/12/2020 17:00	0.4	12.3	2,128.6	0.3	1.3	1	1	1
12/12/2020 18:00	0.4	12.2	2,163.9	0.3	1.3	1	1	1
12/12/2020 19:00	0.4	12.2	2,164.6	0.3	1.3	1	1	1
12/12/2020 20:00	0.4	12.2	2,162.7	0.3	1.3	1	1	1
12/12/2020 21:00	0.4	12.2	2,159.5	0.3	1.3	1	1	1
12/12/2020 22:00	0.4	12.2	2,145.1	0.3	1.3	1	1	1
12/12/2020 23:00	0.4	12.5	2,089.3	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.1	1,902.8	0.3	27.8 #	24 #	24 #	16 #
Minimum:	0.2	12.2	1,582.7	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,164.6	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	0.4	12.5	2,094.3	0.3	1.3	1	1	1
12/13/2020 01:00	0.5	12.7	2,049.3	0.3	1.7	1	1	1
12/13/2020 02:00	0.5	13.2	1,945.5	0.4	1.7	1	1	1
12/13/2020 03:00	0.5	13.2	1,945.8	0.4	1.7	1	1	1
12/13/2020 04:00	0.5	13.2	1,957.7	0.4	1.7	1	1	1
12/13/2020 05:00	0.5	12.8	2,035.9	0.4	1.7	1	1	1
12/13/2020 06:00	0.5	12.8	2,026.4	0.4	1.7	1	1	1
12/13/2020 07:00	0.2	13.8	1,606.2	0.3	0.6	1	1	0
12/13/2020 08:00	0.2	13.9	1,299.5	0.3	0.5	1	1	0
12/13/2020 09:00	0.2	13.9	1,300.2	0.2	0.5	1	1	0
12/13/2020 10:00	0.2	13.9	1,314.2	0.2	0.5	1	1	0
12/13/2020 11:00	0.2	13.9	1,500.8	0.2	0.6	1	1	0
12/13/2020 12:00	0.3	13.8	1,668.3	0.2	0.9	1	1	0
12/13/2020 13:00	0.3	13.8	1,683.1	0.2	0.9	1	1	0
12/13/2020 14:00	0.3	13.8	1,693.8	0.2	0.9	1	1	0
12/13/2020 15:00	0.5	13.4	1,806.9	0.3	1.6	1	1	1
12/13/2020 16:00	0.6	12.6	2,042.3	0.3	1.9	1	1	1
12/13/2020 17:00	0.4	12.2	2,140.8	0.4	1.3	1	1	1
12/13/2020 18:00	0.4	12.2	2,137.1	0.3	1.3	1	1	1
12/13/2020 19:00	0.5	12.4	2,108.1	0.3	1.6	1	1	1
12/13/2020 20:00	0.5	12.4	2,120.4	0.3	1.6	1	1	1
12/13/2020 21:00	0.5	12.6	2,081.7	0.3	1.7	1	1	1
12/13/2020 22:00	0.5	12.8	2,038.0	0.4	1.7	1	1	1
12/13/2020 23:00	0.5	12.8	2,012.3	0.4	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,858.7	0.3	31.2 #	24 #	24 #	16 #
Minimum:	0.2	12.2	1,299.5	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,140.8	0.4	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	10.8	15.5	715.7	0.0	5.1	1	0	0
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/14/2020 05:00	17.0	17.5	497.1	0.0	21.3	1	0	0
12/14/2020 06:00	9.3	13.9	1,539.7	0.0	27.0	1	0	1
12/14/2020 07:00	0.6	12.8	2,066.9	0.0	2.0	1	1	1
12/14/2020 08:00	0.6	12.9	2,053.3	0.0	2.0	1	1	1
12/14/2020 09:00	0.6	13.0	2,019.6	0.4	2.0	1	1	1
12/14/2020 10:00	0.2	13.9	1,526.8	0.3	0.6	1	1	0
12/14/2020 11:00	0.2	13.9	1,544.1	0.3	0.6	1	1	0
12/14/2020 12:00	0.2	13.9	1,421.5	0.2	0.5	1	1	0
12/14/2020 13:00	0.2	14.0	1,375.4	0.2	0.5	1	1	0
12/14/2020 14:00	0.0	0.0	1,426.7	0.0	0.0	1	1	0
12/14/2020 15:00	0.0	0.0	1,852.2	0.0	0.0	1	1	1
12/14/2020 16:00	0.6	12.6	1,988.4	0.0	1.9	1	1	1
12/14/2020 17:00	0.5	12.2	2,161.3	0.0	1.6	1	1	1
12/14/2020 18:00	0.5	12.2	2,174.8	0.3	1.7	1	1	1
12/14/2020 19:00	0.5	12.2	2,172.2	0.3	1.6	1	1	1
12/14/2020 20:00	0.5	12.2	2,172.7	0.3	1.6	1	1	1
12/14/2020 21:00	0.5	12.2	2,171.4	0.3	1.6	1	1	1
12/14/2020 22:00	0.5	12.4	2,108.0	0.3	1.6	1	1	1
12/14/2020 23:00	0.6	13.2	1,938.6	0.4	2.0	1	1	1
Average/Sum#:	2.4	13.4	1,746.3	0.3	75.2 #	20 #	17 #	13 #
Minimum:	0.2	12.2	497.1	0.2	0.5	0	0	0
Maximum:	17.0	17.5	2,174.8	0.4	27.0	1	1	1
%SI	25.00	25.00	16.67	54.17	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0.6	12.9	2,009.6	0.4	2.0	1	1	1
12/15/2020 01:00	0.6	13.2	1,940.9	0.5	2.0	1	1	1
12/15/2020 02:00	0.6	13.2	1,940.2	0.5	2.0	1	1	1
12/15/2020 03:00	0.6	13.3	1,935.0	0.5	2.0	1	1	1
12/15/2020 04:00	0.6	12.9	2,029.4	0.5	2.0	1	1	1
12/15/2020 05:00	0.6	12.3	2,158.1	0.4	2.0	1	1	1
12/15/2020 06:00	0.6	12.3	2,168.5	0.4	2.0	1	1	1
12/15/2020 07:00	0.6	12.4	2,134.9	0.4	2.0	1	1	1
12/15/2020 08:00	0.6	12.9	2,019.0	0.4	2.0	1	1	1
12/15/2020 09:00	0.6	13.2	1,957.2	0.4	2.0	1	1	1
12/15/2020 10:00	0.6	13.3	1,930.5	0.5	2.0	1	1	1
12/15/2020 11:00	0.6	13.3	1,941.1	0.5	2.0	1	1	1
12/15/2020 12:00	0.6	13.2	1,943.1	0.5	2.0	1	1	1
12/15/2020 13:00	0.6	13.2	1,941.8	0.5	2.0	1	1	1
12/15/2020 14:00	0.6	13.2	1,945.4	0.5	2.0	1	1	1
12/15/2020 15:00	0.6	13.2	1,946.1	0.5	2.0	1	1	1
12/15/2020 16:00	0.6	12.9	2,017.1	0.5	2.0	1	1	1
12/15/2020 17:00	0.6	12.3	2,159.2	0.4	2.0	1	1	1
12/15/2020 18:00	0.6	12.2	2,174.2	0.4	2.0	1	1	1
12/15/2020 19:00	0.6	12.3	2,168.9	0.4	2.0	1	1	1
12/15/2020 20:00	0.6	12.3	2,160.0	0.4	2.0	1	1	1
12/15/2020 21:00	0.6	12.4	2,150.1	0.4	2.0	1	1	1
12/15/2020 22:00	0.6	12.4	2,139.6	0.4	2.0	1	1	1
12/15/2020 23:00	0.6	12.7	2,065.7	0.4	2.0	1	1	1
Average/Sum#:	0.6	12.8	2,040.7	0.4	48.0 #	24 #	24 #	24 #
Minimum:	0.6	12.2	1,930.5	0.4	2.0	1	1	1
Maximum:	0.6	13.3	2,174.2	0.5	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0.6	12.8	2,038.4	0.4	2.0	1	1	1
12/16/2020 01:00	0.6	13.0	1,993.0	0.4	2.0	1	1	1
12/16/2020 02:00	0.6	13.3	1,941.5	0.4	2.0	1	1	1
12/16/2020 03:00	0.6	13.3	1,944.0	0.5	2.0	1	1	1
12/16/2020 04:00	0.7	13.1	1,981.3	0.5	2.3	1	1	1
12/16/2020 05:00	0.6	12.6	2,094.3	0.5	2.0	1	1	1
12/16/2020 06:00	0.6	12.4	2,126.3	0.4	2.0	1	1	1
12/16/2020 07:00	0.6	12.4	2,154.6	0.4	2.0	1	1	1
12/16/2020 08:00	0.6	12.7	2,092.8	0.4	2.0	1	1	1
12/16/2020 09:00	0.6	13.3	1,938.6	0.4	2.0	1	1	1
12/16/2020 10:00	0.7	13.3	1,934.1	0.5	2.4	1	1	1
12/16/2020 11:00	0.6	13.2	1,940.5	0.5	2.0	1	1	1
12/16/2020 12:00	0.7	13.2	1,937.4	0.5	2.3	1	1	1
12/16/2020 13:00	0.6	13.1	1,940.0	0.5	2.0	1	1	1
12/16/2020 14:00	0.6	13.1	1,933.2	0.5	2.0	1	1	1
12/16/2020 15:00	0.3	13.9	1,688.3	0.4	1.0	1	1	0
12/16/2020 16:00	0.2	13.9	1,508.1	0.3	0.6	1	1	0
12/16/2020 17:00	0.3	13.7	1,774.6	0.2	1.0	1	1	0
12/16/2020 18:00	0.5	13.2	1,909.3	0.3	1.6	1	1	1
12/16/2020 19:00	0.5	12.3	2,134.9	0.3	1.6	1	1	1
12/16/2020 20:00	0.4	12.1	2,167.0	0.3	1.3	1	1	1
12/16/2020 21:00	0.4	12.1	2,164.6	0.3	1.3	1	1	1
12/16/2020 22:00	0.4	12.1	2,161.2	0.3	1.3	1	1	1
12/16/2020 23:00	0.4	12.2	2,147.4	0.3	1.3	1	1	1
Average/Sum#:	0.5	12.9	1,985.2	0.4	42.0 #	24 #	24 #	21 #
Minimum:	0.2	12.1	1,508.1	0.2	0.6	1	1	0
Maximum:	0.7	13.9	2,167.0	0.5	2.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0.5	12.5	2,073.1	0.3	1.6	1	1	1
12/17/2020 01:00	0.4	13.0	1,893.2	0.3	1.3	1	1	1
12/17/2020 02:00	0.3	13.6	1,784.7	0.3	1.0	1	1	1
12/17/2020 03:00	0.5	12.7	2,035.1	0.3	1.6	1	1	1
12/17/2020 04:00	0.5	12.6	2,056.8	0.3	1.6	1	1	1
12/17/2020 05:00	0.5	12.5	2,074.1	0.4	1.6	1	1	1
12/17/2020 06:00	0.5	12.7	2,013.4	0.4	1.6	1	1	1
12/17/2020 07:00	0.5	12.4	2,113.9	0.4	1.6	1	1	1
12/17/2020 08:00	0.5	12.6	2,061.6	0.4	1.6	1	1	1
12/17/2020 09:00	0.5	12.9	1,976.5	0.4	1.6	1	1	1
12/17/2020 10:00	0.2	13.9	1,637.6	0.3	0.6	1	1	0
12/17/2020 11:00	0.2	13.9	1,686.0	0.3	0.6	1	1	0
12/17/2020 12:00	0.2	13.9	1,671.8	0.2	0.6	1	1	0
12/17/2020 13:00	0.2	13.9	1,685.6	0.2	0.6	1	1	0
12/17/2020 14:00	0.2	13.9	1,660.7	0.2	0.6	1	1	0
12/17/2020 15:00	0.2	13.9	1,654.1	0.2	0.6	1	1	0
12/17/2020 16:00	0.4	13.5	1,810.0	0.2	1.3	1	1	1
12/17/2020 17:00	0.5	12.6	2,085.0	0.3	1.7	1	1	1
12/17/2020 18:00	0.4	12.5	2,093.9	0.3	1.3	1	1	1
12/17/2020 19:00	0.5	12.6	2,068.2	0.4	1.6	1	1	1
12/17/2020 20:00	0.5	12.7	2,058.0	0.4	1.7	1	1	1
12/17/2020 21:00	0.5	12.5	2,112.6	0.4	1.7	1	1	1
12/17/2020 22:00	0.5	12.7	2,078.4	0.4	1.7	1	1	1
12/17/2020 23:00	0.5	12.8	2,052.8	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.0	1,934.9	0.3	31.4 #	24 #	24 #	18 #
Minimum:	0.2	12.4	1,637.6	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,113.9	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0.5	12.8	2,060.5	0.4	1.7	1	1	1
12/18/2020 01:00	0.5	13.2	1,956.3	0.4	1.7	1	1	1
12/18/2020 02:00	0.2	13.9	1,694.8	0.3	0.6	1	1	0
12/18/2020 03:00	0.2	13.9	1,467.8	0.3	0.6	1	1	0
12/18/2020 04:00	0.3	13.8	1,689.6	0.2	0.9	1	1	1
12/18/2020 05:00	0.5	13.1	1,977.9	0.3	1.7	1	1	1
12/18/2020 06:00	0.5	12.5	2,121.0	0.3	1.7	1	1	1
12/18/2020 07:00	0.5	12.6	2,109.8	0.4	1.7	1	1	1
12/18/2020 08:00	0.5	13.2	1,944.1	0.4	1.7	1	1	1
12/18/2020 09:00	0.2	13.9	1,698.5	0.3	0.6	1	1	0
12/18/2020 10:00	0.2	13.9	1,560.0	0.3	0.6	1	1	0
12/18/2020 11:00	0.2	14.0	1,405.1	0.2	0.5	1	1	0
12/18/2020 12:00	0.2	13.9	1,499.7	0.2	0.6	1	1	0
12/18/2020 13:00	0.2	13.9	1,596.7	0.2	0.6	1	1	0
12/18/2020 14:00	0.2	14.0	1,410.7	0.2	0.5	1	1	0
12/18/2020 15:00	0.2	14.0	1,430.1	0.2	0.5	1	1	0
12/18/2020 16:00	0.4	13.4	1,859.6	0.2	1.3	1	1	1
12/18/2020 17:00	0.4	12.3	2,145.7	0.3	1.3	1	1	1
12/18/2020 18:00	0.4	12.1	2,195.2	0.3	1.3	1	1	1
12/18/2020 19:00	0.4	12.1	2,202.0	0.3	1.3	1	1	1
12/18/2020 20:00	0.4	12.2	2,186.5	0.3	1.3	1	1	1
12/18/2020 21:00	0.4	12.3	2,161.8	0.3	1.3	1	1	1
12/18/2020 22:00	0.5	12.6	2,114.9	0.3	1.7	1	1	1
12/18/2020 23:00	0.5	12.8	2,056.8	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.2	1,856.0	0.3	27.4 #	24 #	24 #	15 #
Minimum:	0.2	12.1	1,405.1	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,202.0	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0.5	12.9	2,046.4	0.4	1.7	1	1	1
12/19/2020 01:00	0.5	13.0	1,996.8	0.4	1.7	1	1	1
12/19/2020 02:00	0.2	13.8	1,649.9	0.3	0.6	1	1	0
12/19/2020 03:00	0.2	13.9	1,546.5	0.3	0.6	1	1	0
12/19/2020 04:00	0.4	13.5	1,863.9	0.2	1.3	1	1	1
12/19/2020 05:00	0.5	12.8	2,071.0	0.3	1.7	1	1	1
12/19/2020 06:00	0.5	13.0	2,006.2	0.4	1.7	1	1	1
12/19/2020 07:00	0.2	13.8	1,669.1	0.3	0.6	1	1	0
12/19/2020 08:00	0.2	13.8	1,584.7	0.3	0.6	1	1	0
12/19/2020 09:00	0.2	13.8	1,629.3	0.2	0.6	1	1	0
12/19/2020 10:00	0.2	13.8	1,694.1	0.2	0.6	1	1	0
12/19/2020 11:00	0.2	13.9	1,703.6	0.2	0.6	1	1	0
12/19/2020 12:00	0.2	13.9	1,705.0	0.2	0.6	1	1	0
12/19/2020 13:00	0.2	13.9	1,694.8	0.2	0.6	1	1	0
12/19/2020 14:00	0.2	13.9	1,703.9	0.2	0.6	1	1	0
12/19/2020 15:00	0.3	13.7	1,760.6	0.2	1.0	1	1	1
12/19/2020 16:00	0.5	12.7	2,047.2	0.3	1.6	1	1	1
12/19/2020 17:00	0.5	12.5	2,112.1	0.3	1.7	1	1	1
12/19/2020 18:00	0.4	12.2	2,168.6	0.4	1.3	1	1	1
12/19/2020 19:00	0.4	12.2	2,183.5	0.3	1.3	1	1	1
12/19/2020 20:00	0.4	12.3	2,153.8	0.3	1.3	1	1	1
12/19/2020 21:00	0.4	12.5	2,119.8	0.3	1.3	1	1	1
12/19/2020 22:00	0.4	12.7	2,068.5	0.3	1.3	1	1	1
12/19/2020 23:00	0.5	13.0	2,001.6	0.3	1.7	1	1	1
Average/Sum#:	0.3	13.2	1,882.5	0.3	26.6 #	24 #	24 #	14 #
Minimum:	0.2	12.2	1,546.5	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,183.5	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0.5	13.1	1,967.3	0.4	1.7	1	1	1
12/20/2020 01:00	0.2	13.9	1,654.5	0.3	0.6	1	1	0
12/20/2020 02:00	0.2	13.9	1,544.0	0.3	0.6	1	1	0
12/20/2020 03:00	0.2	13.9	1,373.6	0.2	0.5	1	1	0
12/20/2020 04:00	0.2	13.8	1,570.8	0.2	0.6	1	1	0
12/20/2020 05:00	0.4	13.5	1,848.0	0.2	1.3	1	1	1
12/20/2020 06:00	0.4	13.4	1,881.2	0.3	1.3	1	1	1
12/20/2020 07:00	0.2	13.8	1,695.8	0.3	0.6	1	1	0
12/20/2020 08:00	0.3	13.8	1,672.4	0.2	0.9	1	1	0
12/20/2020 09:00	0.2	13.8	1,690.2	0.2	0.6	1	1	0
12/20/2020 10:00	0.2	13.8	1,690.4	0.2	0.6	1	1	0
12/20/2020 11:00	0.2	13.9	1,689.4	0.2	0.6	1	1	0
12/20/2020 12:00	0.2	13.9	1,698.6	0.2	0.6	1	1	0
12/20/2020 13:00	0.2	13.9	1,680.8	0.2	0.6	1	1	0
12/20/2020 14:00	0.2	13.9	1,620.0	0.2	0.6	1	1	0
12/20/2020 15:00	0.3	13.7	1,701.9	0.2	0.9	1	1	1
12/20/2020 16:00	0.5	12.8	2,019.1	0.3	1.6	1	1	1
12/20/2020 17:00	0.5	12.4	2,102.7	0.3	1.6	1	1	1
12/20/2020 18:00	0.4	12.4	2,118.0	0.3	1.3	1	1	1
12/20/2020 19:00	0.4	12.4	2,120.9	0.3	1.3	1	1	1
12/20/2020 20:00	0.4	12.2	2,153.0	0.3	1.3	1	1	1
12/20/2020 21:00	0.4	12.4	2,103.0	0.3	1.3	1	1	1
12/20/2020 22:00	0.5	12.5	2,092.3	0.3	1.6	1	1	1
12/20/2020 23:00	0.5	12.8	2,037.5	0.4	1.7	1	1	1
Average/Sum#:	0.3	13.3	1,821.9	0.3	24.3 #	24 #	24 #	12 #
Minimum:	0.2	12.2	1,373.6	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,153.0	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0.5	13.2	1,928.9	0.4	1.7	1	1	1
12/21/2020 01:00	0.3	13.8	1,665.1	0.3	0.9	1	1	0
12/21/2020 02:00	0.2	13.8	1,601.8	0.3	0.6	1	1	0
12/21/2020 03:00	0.2	13.8	1,550.2	0.2	0.6	1	1	0
12/21/2020 04:00	0.5	13.5	1,855.9	0.3	1.7	1	1	1
12/21/2020 05:00	0.6	12.8	2,073.0	0.3	2.0	1	1	1
12/21/2020 06:00	0.5	12.7	2,088.8	0.4	1.7	1	1	1
12/21/2020 07:00	0.5	12.7	2,092.5	0.4	1.7	1	1	1
12/21/2020 08:00	0.5	13.0	2,002.1	0.4	1.7	1	1	1
12/21/2020 09:00	0.3	13.8	1,681.8	0.3	0.9	1	1	0
12/21/2020 10:00	0.3	13.8	1,690.7	0.3	0.9	1	1	0
12/21/2020 11:00	0.3	13.8	1,690.4	0.2	0.9	1	1	0
12/21/2020 12:00	0.3	13.8	1,680.4	0.2	0.9	1	1	0
12/21/2020 13:00	0.3	13.8	1,689.3	0.2	0.9	1	1	0
12/21/2020 14:00	0.3	13.9	1,682.8	0.2	1.0	1	1	0
12/21/2020 15:00	0.4	13.5	1,810.1	0.3	1.3	1	1	1
12/21/2020 16:00	0.5	12.6	2,076.7	0.3	1.7	1	1	1
12/21/2020 17:00	0.5	12.5	2,092.6	0.4	1.6	1	1	1
12/21/2020 18:00	0.5	12.4	2,141.3	0.4	1.7	1	1	1
12/21/2020 19:00	0.5	12.5	2,119.8	0.4	1.7	1	1	1
12/21/2020 20:00	0.5	12.6	2,090.8	0.4	1.7	1	1	1
12/21/2020 21:00	0.5	12.7	2,067.4	0.4	1.7	1	1	1
12/21/2020 22:00	0.5	12.7	2,065.7	0.4	1.7	1	1	1
12/21/2020 23:00	0.5	12.9	2,022.9	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.2	1,894.2	0.3	32.9 #	24 #	24 #	15 #
Minimum:	0.2	12.4	1,550.2	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,141.3	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0.6	13.2	1,944.2	0.4	2.0	1	1	1
12/22/2020 01:00	0.3	13.8	1,654.9	0.4	0.9	1	1	0
12/22/2020 02:00	0.3	13.8	1,539.7	0.3	0.9	1	1	0
12/22/2020 03:00	0.3	13.8	1,519.5	0.2	0.8	1	1	0
12/22/2020 04:00	0.4	13.7	1,715.0	0.2	1.3	1	1	1
12/22/2020 05:00	0.6	12.9	2,044.5	0.3	2.0	1	1	1
12/22/2020 06:00	0.6	12.7	2,071.3	0.4	2.0	1	1	1
12/22/2020 07:00	0.5	12.5	2,123.3	0.4	1.7	1	1	1
12/22/2020 08:00	0.3	13.6	1,722.7	0.3	0.9	1	1	1
12/22/2020 09:00	0.2	13.8	1,611.8	0.3	0.6	1	1	0
12/22/2020 10:00	0.2	13.9	1,691.1	0.2	0.6	1	1	0
12/22/2020 11:00	0.2	13.9	1,630.8	0.2	0.6	1	1	0
12/22/2020 12:00	0.2	13.9	1,585.7	0.2	0.6	1	1	0
12/22/2020 13:00	0.2	13.9	1,651.0	0.2	0.6	1	1	0
12/22/2020 14:00	0.2	13.9	1,685.0	0.2	0.6	1	1	0
12/22/2020 15:00	0.3	13.8	1,697.0	0.2	0.9	1	1	1
12/22/2020 16:00	0.5	12.9	2,003.8	0.3	1.7	1	1	1
12/22/2020 17:00	0.4	12.5	2,104.5	0.3	1.3	1	1	1
12/22/2020 18:00	0.4	12.4	2,122.2	0.3	1.3	1	1	1
12/22/2020 19:00	0.4	12.4	2,125.2	0.3	1.3	1	1	1
12/22/2020 20:00	0.4	12.4	2,135.4	0.3	1.3	1	1	1
12/22/2020 21:00	0.4	12.5	2,104.4	0.3	1.3	1	1	1
12/22/2020 22:00	0.4	12.6	2,087.9	0.3	1.3	1	1	1
12/22/2020 23:00	0.5	12.8	2,061.4	0.3	1.7	1	1	1
Average/Sum#:	0.4	13.2	1,859.7	0.3	28.2 #	24 #	24 #	15 #
Minimum:	0.2	12.4	1,519.5	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,135.4	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0.5	12.9	1,993.7	0.4	1.6	1	1	1
12/23/2020 01:00	0.2	13.9	1,699.9	0.3	0.6	1	1	0
12/23/2020 02:00	0.4	13.5	1,835.5	0.3	1.3	1	1	1
12/23/2020 03:00	0.5	13.2	1,955.2	0.3	1.7	1	1	1
12/23/2020 04:00	0.5	12.9	1,998.6	0.4	1.6	1	1	1
12/23/2020 05:00	0.2	13.9	1,692.0	0.3	0.6	1	1	0
12/23/2020 06:00	0.4	13.3	1,833.8	0.3	1.3	1	1	1
12/23/2020 07:00	0.5	12.6	2,092.0	0.3	1.7	1	1	1
12/23/2020 08:00	0.4	12.6	2,079.8	0.3	1.3	1	1	1
12/23/2020 09:00	0.4	12.9	1,990.0	0.3	1.3	1	1	1
12/23/2020 10:00	0.2	13.9	1,674.9	0.3	0.6	1	1	0
12/23/2020 11:00	0.2	14.0	1,617.6	0.2	0.6	1	1	0
12/23/2020 12:00	0.2	14.0	1,657.1	0.2	0.6	1	1	0
12/23/2020 13:00	0.2	14.0	1,685.4	0.2	0.6	1	1	0
12/23/2020 14:00	0.2	14.0	1,687.4	0.2	0.6	1	1	0
12/23/2020 15:00	0.3	13.8	1,671.8	0.2	0.9	1	1	1
12/23/2020 16:00	0.5	12.6	2,069.0	0.3	1.6	1	1	1
12/23/2020 17:00	0.4	12.1	2,196.0	0.3	1.3	1	1	1
12/23/2020 18:00	0.4	12.0	2,217.8	0.3	1.3	1	1	1
12/23/2020 19:00	0.4	12.0	2,222.9	0.3	1.3	1	1	1
12/23/2020 20:00	0.4	12.1	2,223.4	0.3	1.3	1	1	1
12/23/2020 21:00	0.5	12.5	2,102.1	0.3	1.7	1	1	1
12/23/2020 22:00	0.5	12.6	2,111.4	0.4	1.7	1	1	1
12/23/2020 23:00	0.5	12.7	2,096.5	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.1	1,933.5	0.3	28.8 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,617.6	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,223.4	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0.5	12.9	2,051.2	0.4	1.7	1	1	1
12/24/2020 01:00	0.5	13.2	1,978.3	0.4	1.7	1	1	1
12/24/2020 02:00	0.2	13.8	1,747.0	0.3	0.6	1	1	0
12/24/2020 03:00	0.4	13.5	1,844.1	0.3	1.3	1	1	1
12/24/2020 04:00	0.5	13.3	1,949.1	0.3	1.7	1	1	1
12/24/2020 05:00	0.5	13.2	1,954.0	0.4	1.7	1	1	1
12/24/2020 06:00	0.3	13.8	1,703.4	0.3	1.0	1	1	0
12/24/2020 07:00	0.3	13.8	1,693.7	0.3	0.9	1	1	0
12/24/2020 08:00	0.3	13.8	1,689.7	0.2	0.9	1	1	0
12/24/2020 09:00	0.5	13.3	1,937.8	0.3	1.7	1	1	1
12/24/2020 10:00	0.5	12.9	2,006.5	0.3	1.7	1	1	1
12/24/2020 11:00	0.2	13.9	1,642.4	0.3	0.6	1	1	0
12/24/2020 12:00	0.2	13.9	1,641.4	0.3	0.6	1	1	0
12/24/2020 13:00	0.2	13.9	1,670.1	0.2	0.6	1	1	0
12/24/2020 14:00	0.2	13.9	1,692.8	0.2	0.6	1	1	0
12/24/2020 15:00	0.4	13.5	1,806.6	0.2	1.3	1	1	1
12/24/2020 16:00	0.5	12.7	2,053.1	0.3	1.7	1	1	1
12/24/2020 17:00	0.5	12.5	2,116.6	0.4	1.7	1	1	1
12/24/2020 18:00	0.4	12.4	2,142.9	0.4	1.3	1	1	1
12/24/2020 19:00	0.4	12.4	2,139.8	0.3	1.3	1	1	1
12/24/2020 20:00	0.4	12.3	2,157.7	0.3	1.3	1	1	1
12/24/2020 21:00	0.5	12.5	2,113.2	0.3	1.7	1	1	1
12/24/2020 22:00	0.5	12.5	2,133.4	0.4	1.7	1	1	1
12/24/2020 23:00	0.5	12.7	2,082.7	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.2	1,914.5	0.3	31.0 #	24 #	24 #	16 #
Minimum:	0.2	12.3	1,641.4	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,157.7	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0.5	12.7	2,065.4	0.4	1.7	1	1	1
12/25/2020 01:00	0.5	12.7	2,060.2	0.4	1.7	1	1	1
12/25/2020 02:00	0.5	12.8	2,005.4	0.4	1.6	1	1	1
12/25/2020 03:00	0.2	13.8	1,696.4	0.3	0.6	1	1	0
12/25/2020 04:00	0.4	13.5	1,836.1	0.3	1.3	1	1	1
12/25/2020 05:00	0.5	12.8	2,046.1	0.3	1.7	1	1	1
12/25/2020 06:00	0.5	12.9	2,020.5	0.4	1.7	1	1	1
12/25/2020 07:00	0.3	13.8	1,657.6	0.3	0.9	1	1	0
12/25/2020 08:00	0.3	13.8	1,622.8	0.3	0.9	1	1	0
12/25/2020 09:00	0.3	13.8	1,620.7	0.2	0.9	1	1	0
12/25/2020 10:00	0.3	13.8	1,597.4	0.2	0.9	1	1	0
12/25/2020 11:00	0.3	13.8	1,680.1	0.2	0.9	1	1	0
12/25/2020 12:00	0.3	13.8	1,684.2	0.2	0.9	1	1	0
12/25/2020 13:00	0.3	13.8	1,681.5	0.2	0.9	1	1	0
12/25/2020 14:00	0.3	13.8	1,636.4	0.2	0.9	1	1	0
12/25/2020 15:00	0.3	13.8	1,728.5	0.2	1.0	1	1	1
12/25/2020 16:00	0.6	12.8	2,021.9	0.3	2.0	1	1	1
12/25/2020 17:00	0.5	12.5	2,071.8	0.3	1.6	1	1	1
12/25/2020 18:00	0.5	12.6	2,042.2	0.4	1.6	1	1	1
12/25/2020 19:00	0.5	12.4	2,080.7	0.4	1.6	1	1	1
12/25/2020 20:00	0.5	13.0	1,938.1	0.4	1.6	1	1	1
12/25/2020 21:00	0.2	13.8	1,700.8	0.3	0.6	1	1	0
12/25/2020 22:00	0.4	13.5	1,818.3	0.3	1.3	1	1	1
12/25/2020 23:00	0.5	13.1	1,942.2	0.3	1.6	1	1	1
Average/Sum#:	0.4	13.3	1,844.0	0.3	30.4 #	24 #	24 #	14 #
Minimum:	0.2	12.4	1,597.4	0.2	0.6	1	1	0
Maximum:	0.6	13.8	2,080.7	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0.5	12.7	2,023.3	0.4	1.6	1	1	1
12/26/2020 01:00	0.5	13.1	1,915.7	0.4	1.6	1	1	1
12/26/2020 02:00	0.2	13.8	1,691.0	0.3	0.6	1	1	0
12/26/2020 03:00	0.3	13.7	1,766.8	0.3	1.0	1	1	1
12/26/2020 04:00	0.5	12.7	2,028.1	0.3	1.6	1	1	1
12/26/2020 05:00	0.5	13.0	1,943.7	0.3	1.6	1	1	1
12/26/2020 06:00	0.2	13.9	1,697.0	0.3	0.6	1	1	0
12/26/2020 07:00	0.2	13.9	1,660.9	0.3	0.6	1	1	0
12/26/2020 08:00	0.3	13.9	1,609.1	0.2	0.9	1	1	0
12/26/2020 09:00	0.3	13.9	1,665.9	0.3	0.9	1	1	0
12/26/2020 10:00	0.2	13.9	1,566.2	0.3	0.6	1	1	0
12/26/2020 11:00	0.2	13.9	1,456.1	0.2	0.5	1	1	0
12/26/2020 12:00	0.2	13.9	1,580.6	0.2	0.6	1	1	0
12/26/2020 13:00	0.2	13.9	1,694.4	0.2	0.6	1	1	0
12/26/2020 14:00	0.2	13.9	1,668.8	0.2	0.6	1	1	0
12/26/2020 15:00	0.2	13.9	1,580.4	0.2	0.6	1	1	0
12/26/2020 16:00	0.3	13.7	1,686.2	0.2	0.9	1	1	1
12/26/2020 17:00	0.5	12.7	2,041.2	0.3	1.6	1	1	1
12/26/2020 18:00	0.5	13.0	1,980.8	0.3	1.7	1	1	1
12/26/2020 19:00	0.5	12.7	2,049.7	0.4	1.7	1	1	1
12/26/2020 20:00	0.5	12.7	2,061.0	0.4	1.7	1	1	1
12/26/2020 21:00	0.5	12.7	2,046.7	0.4	1.6	1	1	1
12/26/2020 22:00	0.5	12.6	2,070.7	0.4	1.6	1	1	1
12/26/2020 23:00	0.5	12.8	2,044.8	0.4	1.7	1	1	1
Average/Sum#:	0.4	13.4	1,813.7	0.3	27.0 #	24 #	24 #	13 #
Minimum:	0.2	12.6	1,456.1	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,070.7	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0.5	12.8	2,042.5	0.4	1.7	1	1	1
12/27/2020 01:00	0.5	12.8	2,034.8	0.4	1.7	1	1	1
12/27/2020 02:00	0.6	13.2	1,922.2	0.4	2.0	1	1	1
12/27/2020 03:00	0.2	13.9	1,699.5	0.4	0.6	1	1	0
12/27/2020 04:00	0.3	13.7	1,724.1	0.3	0.9	1	1	1
12/27/2020 05:00	0.5	12.7	2,045.8	0.3	1.6	1	1	1
12/27/2020 06:00	0.5	12.8	2,041.2	0.3	1.7	1	1	1
12/27/2020 07:00	0.2	13.8	1,687.8	0.3	0.6	1	1	1
12/27/2020 08:00	0.2	13.9	1,686.7	0.3	0.6	1	1	0
12/27/2020 09:00	0.3	13.8	1,657.2	0.2	0.9	1	1	0
12/27/2020 10:00	0.3	13.9	1,607.2	0.2	0.9	1	1	0
12/27/2020 11:00	0.3	13.9	1,640.6	0.3	0.9	1	1	0
12/27/2020 12:00	0.3	13.9	1,688.8	0.3	1.0	1	1	0
12/27/2020 13:00	0.2	13.9	1,610.7	0.3	0.6	1	1	0
12/27/2020 14:00	0.3	13.9	1,689.7	0.3	1.0	1	1	0
12/27/2020 15:00	0.3	13.7	1,725.7	0.2	0.9	1	1	1
12/27/2020 16:00	0.6	12.7	2,059.0	0.3	2.0	1	1	1
12/27/2020 17:00	0.5	12.4	2,129.0	0.3	1.7	1	1	1
12/27/2020 18:00	0.5	12.3	2,142.0	0.3	1.6	1	1	1
12/27/2020 19:00	0.4	12.0	2,193.5	0.3	1.3	1	1	1
12/27/2020 20:00	0.4	12.3	2,090.1	0.3	1.3	1	1	1
12/27/2020 21:00	0.2	13.9	1,701.7	0.3	0.6	1	1	0
12/27/2020 22:00	0.4	13.4	1,846.1	0.3	1.3	1	1	1
12/27/2020 23:00	0.4	12.5	2,082.5	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.3	1,864.5	0.3	28.7 #	24 #	24 #	15 #
Minimum:	0.2	12.0	1,607.2	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,193.5	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0.5	12.9	1,972.7	0.3	1.6	1	1	1
12/28/2020 01:00	0.2	13.9	1,650.3	0.3	0.6	1	1	0
12/28/2020 02:00	0.4	13.4	1,841.9	0.3	1.3	1	1	1
12/28/2020 03:00	0.5	12.6	2,036.9	0.3	1.6	1	1	1
12/28/2020 04:00	0.5	13.0	1,928.0	0.4	1.6	1	1	1
12/28/2020 05:00	0.2	13.9	1,703.3	0.3	0.6	1	1	0
12/28/2020 06:00	0.5	13.2	1,835.1	0.3	1.6	1	1	1
12/28/2020 07:00	0.4	12.2	2,161.4	0.3	1.3	1	1	1
12/28/2020 08:00	0.4	12.3	2,134.6	0.3	1.3	1	1	1
12/28/2020 09:00	0.5	12.8	2,000.0	0.3	1.6	1	1	1
12/28/2020 10:00	0.2	13.9	1,662.9	0.3	0.6	1	1	0
12/28/2020 11:00	0.2	13.9	1,676.9	0.3	0.6	1	1	0
12/28/2020 12:00	0.2	13.9	1,694.7	0.2	0.6	1	1	0
12/28/2020 13:00	0.2	13.9	1,673.6	0.2	0.6	1	1	0
12/28/2020 14:00	0.2	13.9	1,694.0	0.2	0.6	1	1	0
12/28/2020 15:00	0.3	13.5	1,773.6	0.2	0.9	1	1	1
12/28/2020 16:00	0.5	12.7	2,020.7	0.3	1.6	1	1	1
12/28/2020 17:00	0.4	12.0	2,195.4	0.3	1.3	1	1	1
12/28/2020 18:00	0.4	12.0	2,197.0	0.3	1.3	1	1	1
12/28/2020 19:00	0.4	12.0	2,202.8	0.3	1.3	1	1	1
12/28/2020 20:00	0.4	12.0	2,200.8	0.3	1.3	1	1	1
12/28/2020 21:00	0.4	12.1	2,184.9	0.3	1.3	1	1	1
12/28/2020 22:00	0.4	12.2	2,159.8	0.3	1.3	1	1	1
12/28/2020 23:00	0.4	12.4	2,112.0	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.9	1,946.4	0.3	27.7 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,650.3	0.2	0.6	1	1	0
Maximum:	0.5	13.9	2,202.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0.4	12.5	2,106.8	0.3	1.3	1	1	1
12/29/2020 01:00	0.4	12.6	2,041.2	0.3	1.3	1	1	1
12/29/2020 02:00	0.2	13.9	1,706.4	0.3	0.6	1	1	0
12/29/2020 03:00	0.4	13.5	1,837.2	0.3	1.3	1	1	1
12/29/2020 04:00	0.5	12.6	2,096.6	0.3	1.7	1	1	1
12/29/2020 05:00	0.5	12.5	2,115.5	0.4	1.7	1	1	1
12/29/2020 06:00	0.4	12.1	2,212.1	0.4	1.3	1	1	1
12/29/2020 07:00	0.4	12.2	2,182.9	0.3	1.3	1	1	1
12/29/2020 08:00	0.4	12.3	2,161.5	0.3	1.3	1	1	1
12/29/2020 09:00	0.3	13.4	1,790.9	0.3	0.9	1	1	1
12/29/2020 10:00	0.2	13.9	1,683.9	0.2	0.6	1	1	0
12/29/2020 11:00	0.2	13.9	1,669.1	0.2	0.6	1	1	0
12/29/2020 12:00	0.2	13.9	1,694.9	0.2	0.6	1	1	0
12/29/2020 13:00	0.2	14.0	1,649.5	0.2	0.6	1	1	0
12/29/2020 14:00	0.2	14.0	1,679.9	0.2	0.6	1	1	0
12/29/2020 15:00	0.2	14.0	1,673.6	0.2	0.6	1	1	0
12/29/2020 16:00	0.3	13.8	1,698.0	0.2	0.9	1	1	1
12/29/2020 17:00	0.5	12.4	2,122.8	0.2	1.6	1	1	1
12/29/2020 18:00	0.4	12.0	2,201.4	0.3	1.3	1	1	1
12/29/2020 19:00	0.4	12.0	2,200.4	0.3	1.3	1	1	1
12/29/2020 20:00	0.4	12.4	2,128.6	0.3	1.3	1	1	1
12/29/2020 21:00	0.4	12.6	2,073.1	0.3	1.3	1	1	1
12/29/2020 22:00	0.4	12.6	2,078.1	0.3	1.3	1	1	1
12/29/2020 23:00	0.5	12.8	2,038.4	0.3	1.7	1	1	1
Average/Sum#:	0.4	13.0	1,951.8	0.3	27.0 #	24 #	24 #	17 #
Minimum:	0.2	12.0	1,649.5	0.2	0.6	1	1	0
Maximum:	0.5	14.0	2,212.1	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0.5	12.9	2,032.1	0.4	1.7	1	1	1
12/30/2020 01:00	0.5	13.3	1,929.1	0.4	1.7	1	1	1
12/30/2020 02:00	0.2	13.9	1,692.9	0.3	0.6	1	1	0
12/30/2020 03:00	0.3	13.7	1,722.2	0.3	0.9	1	1	1
12/30/2020 04:00	0.4	13.1	2,016.7	0.2	1.4	1	1	1
12/30/2020 05:00	0.5	12.9	2,046.3	0.3	1.7	1	1	1
12/30/2020 06:00	0.5	12.4	2,160.1	0.3	1.7	1	1	1
12/30/2020 07:00	0.5	12.8	2,068.2	0.4	1.7	1	1	1
12/30/2020 08:00	0.5	13.0	2,029.7	0.4	1.7	1	1	1
12/30/2020 09:00	0.6	13.2	1,945.2	0.4	2.0	1	1	1
12/30/2020 10:00	0.3	13.8	1,705.8	0.4	1.0	1	1	0
12/30/2020 11:00	0.3	13.9	1,693.0	0.3	1.0	1	1	0
12/30/2020 12:00	0.3	13.9	1,689.5	0.3	1.0	1	1	0
12/30/2020 13:00	0.3	13.9	1,647.2	0.3	0.9	1	1	0
12/30/2020 14:00	0.3	13.9	1,645.9	0.3	0.9	1	1	0
12/30/2020 15:00	0.4	13.7	1,721.3	0.3	1.3	1	1	1
12/30/2020 16:00	0.6	12.9	2,020.7	0.3	2.0	1	1	1
12/30/2020 17:00	0.5	12.4	2,112.9	0.3	1.6	1	1	1
12/30/2020 18:00	0.5	12.4	2,102.7	0.3	1.6	1	1	1
12/30/2020 19:00	0.5	12.7	2,045.4	0.3	1.6	1	1	1
12/30/2020 20:00	0.5	12.6	2,063.7	0.4	1.6	1	1	1
12/30/2020 21:00	0.5	12.6	2,055.0	0.4	1.6	1	1	1
12/30/2020 22:00	0.5	12.7	2,032.2	0.4	1.6	1	1	1
12/30/2020 23:00	0.5	12.8	2,021.0	0.4	1.6	1	1	1
Average/Sum#:	0.4	13.1	1,925.0	0.3	34.4 #	24 #	24 #	18 #
Minimum:	0.2	12.4	1,645.9	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,160.1	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 09:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0.6	13.2	1,919.8	0.4	2.0	1	1	1
12/31/2020 01:00	0.3	13.8	1,625.6	0.4	0.9	1	1	0
12/31/2020 02:00	0.4	13.5	1,823.7	0.3	1.3	1	1	1
12/31/2020 03:00	0.6	13.2	1,946.0	0.3	2.0	1	1	1
12/31/2020 04:00	0.6	13.2	1,929.3	0.4	2.0	1	1	1
12/31/2020 05:00	0.2	13.8	1,696.0	0.4	0.6	1	1	0
12/31/2020 06:00	0.3	13.8	1,691.7	0.3	0.9	1	1	0
12/31/2020 07:00	0.3	13.8	1,646.2	0.2	0.9	1	1	0
12/31/2020 08:00	0.3	13.8	1,598.0	0.2	0.9	1	1	0
12/31/2020 09:00	0.3	13.8	1,664.9	0.2	0.9	1	1	0
12/31/2020 10:00	0.3	13.9	1,689.3	0.2	1.0	1	1	0
12/31/2020 11:00	0.3	13.9	1,686.4	0.3	1.0	1	1	0
12/31/2020 12:00	0.2	13.9	1,652.5	0.3	0.6	1	1	0
12/31/2020 13:00	0.2	13.9	1,645.1	0.2	0.6	1	1	0
12/31/2020 14:00	0.2	13.9	1,652.9	0.2	0.6	1	1	0
12/31/2020 15:00	0.2	13.9	1,701.0	0.2	0.6	1	1	0
12/31/2020 16:00	0.4	13.4	1,822.2	0.2	1.3	1	1	1
12/31/2020 17:00	0.5	12.6	2,061.0	0.3	1.6	1	1	1
12/31/2020 18:00	0.4	12.4	2,100.4	0.3	1.3	1	1	1
12/31/2020 19:00	0.4	12.5	2,100.9	0.3	1.3	1	1	1
12/31/2020 20:00	0.4	12.5	2,100.4	0.3	1.3	1	1	1
12/31/2020 21:00	0.4	12.5	2,098.9	0.3	1.3	1	1	1
12/31/2020 22:00	0.4	12.6	2,097.5	0.3	1.3	1	1	1
12/31/2020 23:00	0.4	12.7	2,066.9	0.3	1.3	1	1	1
Average/Sum#:	0.4	13.4	1,834.0	0.3	27.5 #	24 #	24 #	12 #
Minimum:	0.2	12.4	1,598.0	0.2	0.6	1	1	0
Maximum:	0.6	13.9	2,100.9	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:57 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 09:58 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8

Hourly Emissions – NH_3

FCD: AQ-18

Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/01/2020 00:00	8.6	13.9	7.2	105.1	3,193,888.9	1,632.6	1.1	0.7
10/01/2020 01:00	10.9	13.7	8.9	149.5	3,240,850.9	1,798.6	1.6	1.1
10/01/2020 02:00	10.9	13.5	8.7	167.6	3,240,318.9	1,987.6	1.8	1.4
10/01/2020 03:00	10.7	13.5	8.5	179.4	3,178,338.5	1,996.0	1.9	1.4
10/01/2020 04:00	8.6	13.9	7.2	121.7	3,260,208.2	1,666.5	1.3	0.8
10/01/2020 05:00	9.3	13.7	7.6	142.4	3,159,903.4	1,822.9	1.5	1.1
10/01/2020 06:00	11.0	13.4	8.7	163.8	3,301,108.9	2,073.1	1.7	1.5
10/01/2020 07:00	10.4	13.6	8.4	146.3	3,177,240.1	1,809.7	1.6	1.1
10/01/2020 08:00	9.9	13.9	8.3	124.2	3,053,425.1	1,560.8	1.4	0.8
10/01/2020 09:00	9.2	14.0	7.9	87.2	2,672,592.8	1,327.1	1.1	0.5
10/01/2020 10:00	9.7	13.9	8.2	113.1	3,008,962.8	1,516.1	1.2	0.8
10/01/2020 11:00	10.9	13.4	8.6	166.2	3,284,548.5	2,062.7	1.7	1.4
10/01/2020 12:00	10.9	13.3	8.5	187.9	3,224,317.2	2,142.6	2.0	1.7
10/01/2020 13:00	11.0	13.3	8.5	199.4	3,211,226.6	2,180.8	2.2	1.7
10/01/2020 14:00	11.0	13.3	8.5	203.8	3,192,070.0	2,191.1	2.2	1.8
10/01/2020 15:00	10.9	13.3	8.5	196.9	3,185,457.8	2,163.3	2.2	1.7
10/01/2020 16:00	10.9	13.3	8.5	194.4	3,191,800.8	2,144.3	2.1	1.7
10/01/2020 17:00	10.9	13.3	8.5	195.4	3,182,869.7	2,138.3	2.1	1.7
10/01/2020 18:00	10.8	13.3	8.4	185.1	3,211,148.0	2,110.4	2.0	1.7
10/01/2020 19:00	10.8	13.3	8.4	182.0	3,217,690.8	2,114.7	2.0	1.7
10/01/2020 20:00	10.7	13.3	8.3	180.7	3,215,408.5	2,113.2	1.9	1.5
10/01/2020 21:00	10.8	13.3	8.4	182.4	3,224,233.6	2,119.0	2.0	1.7
10/01/2020 22:00	10.7	13.3	8.3	171.6	3,259,074.4	2,094.3	1.8	1.5
10/01/2020 23:00	10.6	13.4	8.3	161.1	3,241,347.0	2,011.9	1.7	1.4
Average/Sum#:	10.4	13.5	8.3	162.8	3,180,334.6	1,949.1	1.8	1.4
Minimum:	8.6	13.3	7.2	87.2	2,672,592.8	1,327.1	1.1	0.5
Maximum:	11.0	14.0	8.9	203.8	3,301,108.9	2,191.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/02/2020 00:00	8.7	13.9	7.3	101.4	3,109,767.1	1,589.6	1.1	0.6
10/02/2020 01:00	8.9	13.9	7.5	110.5	3,340,026.1	1,707.3	1.1	0.7
10/02/2020 02:00	8.9	13.9	7.5	98.1	3,038,361.4	1,553.1	1.1	0.6
10/02/2020 03:00	8.9	13.9	7.5	101.7	3,122,678.9	1,596.2	1.1	0.6
10/02/2020 04:00	9.8	13.7	8.0	120.2	3,156,992.2	1,682.9	1.3	0.8
10/02/2020 05:00	10.9	13.4	8.6	171.9	3,277,701.3	2,058.4	1.8	1.4
10/02/2020 06:00	11.0	13.4	8.7	161.5	3,284,499.2	2,014.7	1.7	1.4
10/02/2020 07:00	9.1	13.8	7.6	118.0	3,416,038.8	1,771.1	1.1	0.7
10/02/2020 08:00	8.6	13.9	7.2	92.7	2,890,463.6	1,477.5	1.1	0.6
10/02/2020 09:00	8.8	14.0	7.5	99.2	3,165,950.4	1,595.2	1.0	0.6
10/02/2020 10:00	8.6	14.0	7.4	100.8	3,230,849.2	1,627.9	1.0	0.7
10/02/2020 11:00	10.0	13.8	8.3	131.4	3,178,752.9	1,694.5	1.4	0.8
10/02/2020 12:00	11.0	13.3	8.5	181.1	3,235,949.8	2,126.7	1.9	1.5
10/02/2020 13:00	11.1	13.3	8.6	207.0	3,213,485.4	2,205.8	2.2	1.8
10/02/2020 14:00	11.0	13.3	8.5	209.0	3,176,632.1	2,203.7	2.3	2.0
10/02/2020 15:00	10.9	13.3	8.5	204.7	3,180,123.9	2,182.9	2.2	1.7
10/02/2020 16:00	11.0	13.3	8.5	202.5	3,182,017.8	2,184.2	2.2	1.7
10/02/2020 17:00	10.9	13.3	8.5	204.5	3,161,208.1	2,193.0	2.3	2.0
10/02/2020 18:00	10.9	13.3	8.5	192.4	3,205,197.3	2,153.3	2.1	1.7
10/02/2020 19:00	10.9	13.3	8.5	190.9	3,205,356.0	2,130.0	2.1	1.7
10/02/2020 20:00	11.0	13.3	8.5	198.5	3,214,872.6	2,159.8	2.2	1.7
10/02/2020 21:00	10.8	13.4	8.5	177.0	3,265,526.2	2,074.6	1.9	1.5
10/02/2020 22:00	10.6	13.4	8.3	174.5	3,256,273.3	2,092.5	1.8	1.5
10/02/2020 23:00	10.7	13.4	8.4	180.3	3,239,688.8	2,105.5	1.9	1.5
Average/Sum#:	10.1	13.6	8.1	155.4	3,197,850.5	1,924.2	1.7	1.2
Minimum:	8.6	13.3	7.2	92.7	2,890,463.6	1,477.5	1.0	0.6
Maximum:	11.1	14.0	8.7	209.0	3,416,038.8	2,205.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/03/2020 00:00	16.4	14.7	15.6	171.5	2,524,107.1	1,271.8	2.2	1.0
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 08:00	31.5	17.7	58.1	33.4	1,898,120.0	388.1	0.0	0.0
10/03/2020 09:00	42.0	15.0	42.0	249.1	2,273,708.7	979.6	3.5	1.3
10/03/2020 10:00	8.6	14.0	7.4	92.7	2,762,466.4	1,391.9	1.1	0.6
10/03/2020 11:00	8.9	14.0	7.6	86.3	2,706,697.1	1,363.8	1.0	0.5
10/03/2020 12:00	9.8	13.9	8.3	102.2	3,146,546.0	1,608.4	1.1	0.6
10/03/2020 13:00	9.3	14.0	8.0	107.3	2,941,086.9	1,481.9	1.2	0.7
10/03/2020 14:00	10.6	13.9	8.9	127.6	3,209,735.1	1,640.7	1.3	0.8
10/03/2020 15:00	9.9	13.7	8.1	126.8	3,075,468.1	1,661.9	1.4	0.8
10/03/2020 16:00	11.3	13.3	8.8	186.7	3,173,001.4	2,108.5	2.0	1.7
10/03/2020 17:00	11.2	13.3	8.7	213.7	3,162,505.4	2,193.9	2.4	2.0
10/03/2020 18:00	11.1	13.3	8.6	206.9	3,177,355.9	2,181.0	2.3	2.0
10/03/2020 19:00	10.9	13.3	8.5	200.6	3,216,822.1	2,184.6	2.2	1.7
10/03/2020 20:00	10.7	13.3	8.3	181.9	3,222,559.9	2,117.9	2.0	1.7
10/03/2020 21:00	10.7	13.4	8.4	168.6	3,257,000.7	2,045.4	1.8	1.4
10/03/2020 22:00	14.7	14.3	13.1	165.7	2,816,963.8	1,460.5	2.0	1.2
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.2	14.1	14.3	151.3	2,910,259.0	1,630.0	1.7	1.1
Minimum:	8.6	13.3	7.4	33.4	1,898,120.0	388.1	0.0	0.0
Maximum:	42.0	17.7	58.1	249.1	3,257,000.7	2,193.9	3.5	2.0
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 09:00	47.4	16.7	66.6	120.8	1,865,498.4	544.9	0.0	0.0
10/04/2020 10:00	29.1	14.5	26.8	212.4	2,467,103.6	1,153.0	2.8	1.3
10/04/2020 11:00	8.8	14.0	7.5	88.0	2,723,765.3	1,372.4	1.1	0.5
10/04/2020 12:00	9.0	14.0	7.7	87.6	2,732,100.9	1,376.6	1.1	0.6
10/04/2020 13:00	9.5	13.9	8.0	113.9	3,151,241.1	1,610.8	1.2	0.8
10/04/2020 14:00	9.3	14.0	8.0	109.4	2,941,880.8	1,482.3	1.2	0.7
10/04/2020 15:00	9.0	13.8	7.5	110.8	3,303,591.7	1,712.8	1.1	0.7
10/04/2020 16:00	10.5	13.5	8.4	144.6	3,193,359.0	1,842.2	1.5	1.1
10/04/2020 17:00	11.3	13.3	8.8	191.2	3,195,875.3	2,123.7	2.1	1.7
10/04/2020 18:00	11.2	13.4	8.8	179.8	3,207,721.0	2,061.3	1.9	1.4
10/04/2020 19:00	11.0	13.4	8.7	173.9	3,234,989.6	2,055.2	1.8	1.4
10/04/2020 20:00	10.9	13.4	8.6	174.5	3,241,443.3	2,059.3	1.9	1.4
10/04/2020 21:00	11.0	13.4	8.7	183.8	3,247,247.6	2,086.7	2.0	1.7
10/04/2020 22:00	10.7	13.5	8.5	158.0	3,304,539.4	1,954.6	1.6	1.2
10/04/2020 23:00	10.5	13.5	8.4	153.3	3,291,925.0	1,923.1	1.6	1.2
Average/Sum#:	13.9	13.9	13.4	146.8	3,006,818.8	1,690.6	1.5	1.0
Minimum:	8.8	13.3	7.5	87.6	1,865,498.4	544.9	0.0	0.0
Maximum:	47.4	16.7	66.6	212.4	3,304,539.4	2,123.7	2.8	1.7
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/05/2020 00:00	8.7	13.9	7.3	107.4	3,248,470.3	1,660.5	1.1	0.7
10/05/2020 01:00	8.9	13.9	7.5	108.0	3,227,928.9	1,650.0	1.1	0.7
10/05/2020 02:00	8.9	13.9	7.5	104.7	3,137,546.9	1,603.8	1.1	0.6
10/05/2020 03:00	8.7	14.0	7.4	99.6	3,135,783.4	1,580.0	1.0	0.6
10/05/2020 04:00	9.5	13.8	7.9	125.3	3,201,409.9	1,683.2	1.3	0.8
10/05/2020 05:00	10.9	13.4	8.6	159.7	3,282,956.1	2,061.7	1.7	1.4
10/05/2020 06:00	10.9	13.4	8.6	176.1	3,258,593.1	2,046.4	1.9	1.4
10/05/2020 07:00	8.7	13.9	7.3	99.8	3,035,622.6	1,551.7	1.1	0.6
10/05/2020 08:00	8.7	14.0	7.4	97.1	3,015,276.9	1,541.3	1.1	0.6
10/05/2020 09:00	8.7	14.0	7.4	99.9	3,170,713.6	1,597.6	1.0	0.6
10/05/2020 10:00	8.5	14.0	7.3	99.0	3,149,676.1	1,587.0	1.0	0.6
10/05/2020 11:00	10.0	13.9	8.4	129.3	3,230,863.4	1,651.5	1.3	0.8
10/05/2020 12:00	8.8	13.9	7.4	116.1	3,264,120.8	1,668.5	1.2	0.8
10/05/2020 13:00	10.0	13.6	8.1	142.8	3,230,240.9	1,816.3	1.5	1.1
10/05/2020 14:00	11.1	13.3	8.6	205.0	3,229,780.0	2,193.4	2.2	1.8
10/05/2020 15:00	11.0	13.3	8.5	210.0	3,183,839.6	2,208.7	2.3	2.0
10/05/2020 16:00	11.0	13.3	8.5	213.1	3,182,830.6	2,208.0	2.3	2.0
10/05/2020 17:00	11.0	13.3	8.5	208.3	3,214,613.3	2,183.1	2.3	2.0
10/05/2020 18:00	10.8	13.3	8.4	207.4	3,204,890.1	2,199.9	2.3	2.0
10/05/2020 19:00	10.8	13.4	8.5	182.1	3,235,420.7	2,079.1	1.9	1.5
10/05/2020 20:00	10.8	13.4	8.5	180.1	3,259,702.2	2,070.9	1.9	1.4
10/05/2020 21:00	10.8	13.4	8.5	180.3	3,266,628.1	2,075.3	1.9	1.5
10/05/2020 22:00	16.5	14.8	16.0	166.5	2,506,650.8	1,244.7	2.2	1.0
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.2	13.7	8.4	148.6	3,168,415.6	1,833.2	1.6	1.2
Minimum:	8.5	13.3	7.3	97.1	2,506,650.8	1,244.7	1.0	0.6
Maximum:	16.5	14.8	16.0	213.1	3,282,956.1	2,208.7	2.3	2.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 06:00	34.8	17.7	64.2	3.9	1,910,836.1	390.7	0.0	0.0
10/06/2020 07:00	43.3	15.7	49.1	250.6	2,233,504.3	831.8	3.5	1.1
10/06/2020 08:00	8.7	14.0	7.4	96.4	2,795,808.9	1,408.7	1.1	0.6
10/06/2020 09:00	8.8	14.0	7.5	86.9	2,749,962.9	1,385.6	1.0	0.6
10/06/2020 10:00	8.8	14.1	7.6	87.4	2,777,153.0	1,399.3	1.0	0.6
10/06/2020 11:00	9.9	13.9	8.3	123.5	3,256,253.0	1,640.7	1.3	0.8
10/06/2020 12:00	9.7	14.0	8.3	111.9	2,960,735.2	1,491.8	1.3	0.7
10/06/2020 13:00	8.8	13.9	7.4	105.0	3,234,971.7	1,653.6	1.1	0.7
10/06/2020 14:00	9.7	13.7	7.9	130.6	3,286,993.7	1,752.2	1.3	0.9
10/06/2020 15:00	11.6	13.3	9.0	193.9	3,211,074.5	2,133.8	2.1	1.7
10/06/2020 16:00	11.5	13.3	8.9	209.4	3,180,706.7	2,183.3	2.3	2.0
10/06/2020 17:00	11.5	13.3	8.9	214.8	3,172,307.6	2,200.7	2.4	2.0
10/06/2020 18:00	11.4	13.3	8.9	216.6	3,179,082.7	2,205.4	2.4	2.0
10/06/2020 19:00	11.4	13.3	8.9	212.1	3,204,011.3	2,175.9	2.3	2.0
10/06/2020 20:00	9.3	13.8	7.7	124.3	3,101,746.2	1,676.1	1.4	0.8
10/06/2020 21:00	10.2	13.6	8.2	145.1	3,245,002.2	1,824.6	1.5	1.1
10/06/2020 22:00	11.2	13.4	8.8	180.8	3,284,100.0	2,086.4	1.9	1.5
10/06/2020 23:00	11.2	13.4	8.8	170.0	3,294,373.1	1,996.7	1.8	1.4
Average/Sum#:	13.4	14.0	13.7	148.0	3,004,368.0	1,691.0	1.7	1.1
Minimum:	8.7	13.3	7.4	3.9	1,910,836.1	390.7	0.0	0.0
Maximum:	43.3	17.7	64.2	250.6	3,294,373.1	2,205.4	3.5	2.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/07/2020 00:00	11.2	13.4	8.8	174.9	3,264,803.3	2,050.3	1.8	1.4
10/07/2020 01:00	10.9	13.4	8.6	168.8	3,267,479.6	1,980.4	1.8	1.4
10/07/2020 02:00	8.8	13.9	7.4	99.9	3,015,081.2	1,541.2	1.1	0.6
10/07/2020 03:00	8.5	14.0	7.3	100.3	3,188,774.1	1,606.7	1.0	0.6
10/07/2020 04:00	10.2	13.6	8.2	147.7	3,305,177.8	1,834.3	1.5	1.1
10/07/2020 05:00	11.1	13.4	8.7	164.0	3,260,153.2	2,118.8	1.7	1.5
10/07/2020 06:00	11.1	13.4	8.7	174.6	3,283,718.6	2,038.2	1.8	1.4
10/07/2020 07:00	8.8	13.9	7.4	103.1	3,135,786.2	1,602.9	1.1	0.6
10/07/2020 08:00	9.1	14.0	7.8	87.7	2,712,254.1	1,366.6	1.1	0.5
10/07/2020 09:00	9.4	14.0	8.0	87.3	2,582,853.5	1,301.4	1.1	0.5
10/07/2020 10:00	8.9	14.1	7.7	86.3	2,694,590.6	1,357.7	1.1	0.5
10/07/2020 11:00	10.9	13.6	8.8	157.8	3,236,166.0	1,796.0	1.7	1.3
10/07/2020 12:00	11.3	13.3	8.8	201.2	3,232,734.6	2,171.8	2.2	1.7
10/07/2020 13:00	11.2	13.3	8.7	209.3	3,180,998.0	2,183.5	2.3	2.0
10/07/2020 14:00	9.2	13.8	7.6	129.1	3,166,516.3	1,711.1	1.4	0.9
10/07/2020 15:00	10.4	13.6	8.4	152.2	3,157,927.7	1,798.7	1.6	1.1
10/07/2020 16:00	11.5	13.3	8.9	193.3	3,220,609.2	2,093.1	2.1	1.7
10/07/2020 17:00	11.5	13.2	8.8	206.2	3,185,310.6	2,163.2	2.3	1.9
10/07/2020 18:00	11.2	13.3	8.7	192.7	3,195,875.3	2,123.7	2.1	1.7
10/07/2020 19:00	11.0	13.4	8.7	183.9	3,193,871.1	2,052.4	2.0	1.6
10/07/2020 20:00	8.7	13.9	7.3	107.9	3,298,943.3	1,686.3	1.1	0.7
10/07/2020 21:00	10.1	13.6	8.2	144.4	3,249,270.6	1,827.0	1.5	1.1
10/07/2020 22:00	11.1	13.3	8.6	180.1	3,266,388.4	2,099.0	1.9	1.5
10/07/2020 23:00	16.9	14.7	16.1	174.2	2,488,978.4	1,254.1	2.3	1.1
Average/Sum#:	10.5	13.6	8.6	151.1	3,116,010.9	1,823.3	1.7	1.2
Minimum:	8.5	13.2	7.3	86.3	2,488,978.4	1,254.1	1.0	0.5
Maximum:	16.9	14.7	16.1	209.3	3,305,177.8	2,183.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/12/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2020 12:00	41.4	17.4	69.8	0.0	1,915,054.4	447.5	0.0	0.0
10/12/2020 13:00	52.4	15.6	58.3	249.9	1,965,650.7	746.4	4.1	1.2
10/12/2020 14:00	8.2	14.0	7.0	123.9	3,126,256.9	1,575.2	1.3	0.8
10/12/2020 15:00	9.3	13.8	7.7	132.7	3,173,831.2	1,668.7	1.4	0.8
10/12/2020 16:00	11.0	13.4	8.7	177.2	3,259,389.3	2,046.9	1.9	1.4
10/12/2020 17:00	10.9	13.4	8.6	180.6	3,274,374.3	2,032.4	1.9	1.4
10/12/2020 18:00	10.9	13.4	8.6	168.6	3,288,248.8	2,017.0	1.8	1.4
10/12/2020 19:00	10.7	13.5	8.5	160.2	3,255,723.0	1,949.5	1.7	1.4
10/12/2020 20:00	9.2	13.8	7.6	128.9	3,398,679.9	1,762.1	1.3	0.9
10/12/2020 21:00	10.0	13.6	8.1	139.4	3,289,321.3	1,825.5	1.4	0.9
10/12/2020 22:00	10.9	13.4	8.6	164.0	3,285,966.4	2,015.6	1.7	1.4
10/12/2020 23:00	10.6	13.5	8.5	158.3	3,292,964.6	1,971.8	1.6	1.2
Average/Sum#:	16.3	14.1	17.5	148.6	3,043,788.4	1,671.6	1.7	1.1
Minimum:	8.2	13.4	7.0	0.0	1,915,054.4	447.5	0.0	0.0
Maximum:	52.4	17.4	69.8	249.9	3,398,679.9	2,046.9	4.1	1.4
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/13/2020 00:00	8.4	13.9	7.1	105.8	3,269,989.8	1,671.5	1.1	0.7
10/13/2020 01:00	8.6	13.9	7.2	101.9	3,178,629.6	1,624.8	1.1	0.6
10/13/2020 02:00	8.8	14.0	7.5	88.2	2,771,992.8	1,396.7	1.0	0.6
10/13/2020 03:00	8.4	14.0	7.2	99.4	3,183,217.1	1,603.9	1.0	0.6
10/13/2020 04:00	10.3	13.7	8.4	149.8	3,324,232.0	1,820.6	1.5	1.1
10/13/2020 05:00	11.0	13.4	8.7	167.4	3,340,393.5	2,000.2	1.7	1.4
10/13/2020 06:00	10.4	13.5	8.3	144.5	3,328,386.0	1,944.4	1.5	1.2
10/13/2020 07:00	8.6	13.9	7.2	105.0	3,234,384.8	1,653.3	1.1	0.7
10/13/2020 08:00	8.6	13.9	7.2	93.7	2,910,809.3	1,487.9	1.1	0.6
10/13/2020 09:00	8.9	14.0	7.6	87.0	2,682,682.5	1,351.7	1.1	0.5
10/13/2020 10:00	8.7	13.9	7.3	103.5	3,173,738.8	1,622.3	1.1	0.6
10/13/2020 11:00	8.9	13.9	7.5	95.1	2,937,806.6	1,501.7	1.1	0.6
10/13/2020 12:00	8.9	13.9	7.5	96.2	2,939,567.3	1,502.6	1.1	0.6
10/13/2020 13:00	8.9	14.0	7.6	90.2	2,794,022.7	1,407.8	1.1	0.6
10/13/2020 14:00	8.8	13.9	7.4	104.2	3,153,197.5	1,611.8	1.1	0.6
10/13/2020 15:00	10.5	13.7	8.6	134.6	3,120,786.9	1,663.6	1.4	0.8
10/13/2020 16:00	11.2	13.4	8.8	175.0	3,274,516.6	2,056.4	1.8	1.4
10/13/2020 17:00	10.9	13.4	8.6	176.0	3,263,007.8	2,073.0	1.9	1.5
10/13/2020 18:00	10.7	13.4	8.4	167.4	3,256,523.0	2,045.1	1.8	1.4
10/13/2020 19:00	10.5	13.4	8.3	159.7	3,257,580.1	1,974.4	1.7	1.4
10/13/2020 20:00	8.3	13.9	7.0	106.5	3,341,591.1	1,708.1	1.1	0.7
10/13/2020 21:00	9.7	13.7	7.9	136.1	3,327,518.7	1,822.4	1.4	0.9
10/13/2020 22:00	10.9	13.3	8.5	180.9	3,284,618.2	2,134.7	1.9	1.5
10/13/2020 23:00	10.5	13.5	8.4	156.9	3,275,763.3	1,961.5	1.6	1.2
Average/Sum#:	9.6	13.7	7.8	126.0	3,151,039.8	1,735.0	1.3	0.9
Minimum:	8.3	13.3	7.0	87.0	2,682,682.5	1,351.7	1.0	0.5
Maximum:	11.2	14.0	8.8	180.9	3,341,591.1	2,134.7	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/14/2020 00:00	8.3	13.9	7.0	105.2	3,286,031.6	1,679.7	1.1	0.7
10/14/2020 01:00	9.9	13.8	8.2	125.8	3,198,937.3	1,681.9	1.3	0.8
10/14/2020 02:00	10.7	13.4	8.4	167.1	3,268,516.9	2,076.5	1.8	1.5
10/14/2020 03:00	10.4	13.5	8.3	155.1	3,258,896.0	1,951.4	1.6	1.2
10/14/2020 04:00	8.4	13.9	7.1	102.2	3,144,589.6	1,607.4	1.1	0.6
10/14/2020 05:00	9.5	13.7	7.8	128.9	3,167,703.9	1,827.4	1.4	0.9
10/14/2020 06:00	10.9	13.4	8.6	161.0	3,301,290.9	2,025.0	1.7	1.4
10/14/2020 07:00	0.0	0.0	0.0	121.4	1,265,702.0	1,931.7	3.6	2.7
10/14/2020 08:00	8.8	14.0	7.5	95.3	2,776,410.1	1,419.2	1.1	0.6
10/14/2020 09:00	9.0	14.0	7.7	86.4	2,601,906.3	1,311.0	1.1	0.5
10/14/2020 10:00	8.4	14.0	7.2	97.8	3,024,080.3	1,545.8	1.1	0.6
10/14/2020 11:00	10.1	13.6	8.2	137.5	2,844,740.3	1,786.5	1.7	1.3
10/14/2020 12:00	11.0	13.3	8.5	167.5	3,365,827.3	2,162.9	1.7	1.5
10/14/2020 13:00	11.0	13.3	8.5	220.8	3,220,186.9	2,210.4	2.4	2.0
10/14/2020 14:00	9.3	13.7	7.6	129.8	2,914,564.1	1,766.5	1.5	1.1
10/14/2020 15:00	10.2	13.6	8.2	157.9	3,004,093.2	1,842.7	1.8	1.3
10/14/2020 16:00	10.9	13.3	8.5	199.8	3,231,239.6	2,147.2	2.2	1.7
10/14/2020 17:00	10.8	13.3	8.4	217.9	3,203,444.0	2,222.3	2.4	2.0
10/14/2020 18:00	10.6	13.3	8.2	194.7	3,219,050.2	2,139.1	2.1	1.7
10/14/2020 19:00	10.5	13.3	8.2	195.4	3,179,042.6	2,089.3	2.1	1.7
10/14/2020 20:00	8.3	13.9	7.0	112.4	3,267,716.6	1,694.2	1.2	0.8
10/14/2020 21:00	10.1	13.6	8.2	160.1	3,256,069.8	1,854.6	1.7	1.3
10/14/2020 22:00	10.9	13.3	8.5	204.9	3,244,642.7	2,179.8	2.2	1.7
10/14/2020 23:00	10.5	13.4	8.3	177.3	3,248,113.5	2,016.1	1.9	1.4
Average/Sum#:	9.9	13.6	8.0	150.9	3,140,308.4	1,882.0	1.7	1.2
Minimum:	8.3	13.3	7.0	86.4	2,601,906.3	1,311.0	1.1	0.5
Maximum:	11.0	14.0	8.6	220.8	3,365,827.3	2,222.3	2.4	2.0
%SI	4.17	4.17	4.17	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/15/2020 00:00	8.3	13.9	7.0	109.3	3,249,586.2	1,684.8	1.1	0.7
10/15/2020 01:00	9.9	13.6	8.0	159.5	3,280,131.8	1,820.4	1.7	1.3
10/15/2020 02:00	11.2	13.3	8.7	203.7	3,268,663.8	2,148.2	2.2	1.7
10/15/2020 03:00	10.7	13.4	8.4	192.2	3,227,994.8	2,097.9	2.1	1.7
10/15/2020 04:00	8.3	13.9	7.0	111.5	3,281,410.9	1,701.3	1.1	0.7
10/15/2020 05:00	9.5	13.7	7.8	148.5	3,148,649.0	1,839.4	1.6	1.1
10/15/2020 06:00	11.0	13.4	8.7	176.4	3,273,396.5	2,079.6	1.9	1.5
10/15/2020 07:00	10.3	13.5	8.2	162.7	3,121,118.6	1,868.9	1.8	1.3
10/15/2020 08:00	9.1	14.0	7.8	87.9	2,598,730.9	1,309.4	1.1	0.5
10/15/2020 09:00	9.0	14.1	7.8	86.2	2,590,792.2	1,305.4	1.1	0.5
10/15/2020 10:00	8.7	14.1	7.5	85.7	2,627,111.7	1,323.7	1.1	0.5
10/15/2020 11:00	8.5	13.9	7.2	107.1	3,041,472.3	1,576.9	1.2	0.8
10/15/2020 12:00	8.6	13.9	7.2	111.5	3,185,165.4	1,651.4	1.2	0.8
10/15/2020 13:00	10.3	13.6	8.3	164.7	3,216,391.6	1,832.0	1.8	1.3
10/15/2020 14:00	11.2	13.3	8.7	215.1	3,218,147.3	2,209.0	2.3	2.0
10/15/2020 15:00	11.0	13.3	8.5	219.6	3,205,750.4	2,223.9	2.4	2.0
10/15/2020 16:00	10.9	13.3	8.5	220.2	3,200,849.3	2,220.5	2.4	2.0
10/15/2020 17:00	10.8	13.3	8.4	212.6	3,202,122.1	2,198.0	2.3	2.0
10/15/2020 18:00	10.9	13.3	8.5	219.0	3,220,332.6	2,210.5	2.4	2.0
10/15/2020 19:00	10.8	13.3	8.4	215.1	3,217,116.6	2,184.8	2.3	2.0
10/15/2020 20:00	10.8	13.3	8.4	217.3	3,244,652.3	2,203.5	2.4	2.0
10/15/2020 21:00	10.7	13.3	8.3	219.3	3,238,688.7	2,223.1	2.4	2.0
10/15/2020 22:00	10.7	13.3	8.3	210.9	3,243,451.9	2,179.0	2.3	2.0
10/15/2020 23:00	10.5	13.4	8.3	187.6	3,231,211.9	2,052.8	2.0	1.6
Average/Sum#:	10.1	13.6	8.1	168.5	3,138,872.5	1,922.7	1.8	1.4
Minimum:	8.3	13.3	7.0	85.7	2,590,792.2	1,305.4	1.1	0.5
Maximum:	11.2	14.1	8.7	220.2	3,281,410.9	2,223.9	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/16/2020 00:00	8.4	13.9	7.1	113.4	3,309,185.1	1,715.7	1.1	0.7
10/16/2020 01:00	9.0	14.0	7.7	87.9	2,620,165.3	1,320.2	1.1	0.5
10/16/2020 02:00	8.7	13.9	7.3	124.7	3,267,716.6	1,694.2	1.3	0.8
10/16/2020 03:00	10.2	13.6	8.2	158.3	3,271,145.8	1,839.3	1.7	1.3
10/16/2020 04:00	10.3	13.5	8.2	160.9	3,186,082.7	1,907.8	1.7	1.3
10/16/2020 05:00	9.9	13.8	8.2	151.5	3,130,504.1	1,714.5	1.7	1.2
10/16/2020 06:00	11.4	13.4	9.0	185.1	3,226,861.8	2,073.6	2.0	1.7
10/16/2020 07:00	10.5	13.4	8.3	171.0	3,291,127.6	1,970.7	1.8	1.4
10/16/2020 08:00	8.7	13.9	7.3	114.6	3,104,928.7	1,609.8	1.2	0.8
10/16/2020 09:00	8.5	14.0	7.3	88.2	2,786,282.5	1,403.9	1.0	0.6
10/16/2020 10:00	8.4	14.0	7.2	95.3	3,016,703.0	1,520.0	1.0	0.6
10/16/2020 11:00	9.3	13.8	7.7	121.2	3,004,667.2	1,601.7	1.4	0.8
10/16/2020 12:00	11.1	13.3	8.6	199.5	3,224,618.2	2,142.8	2.2	1.7
10/16/2020 13:00	10.8	13.3	8.4	194.6	3,211,452.3	2,110.6	2.1	1.7
10/16/2020 14:00	10.9	13.3	8.5	211.7	3,199,888.3	2,173.1	2.3	2.0
10/16/2020 15:00	10.8	13.3	8.4	211.3	3,180,269.6	2,183.0	2.3	2.0
10/16/2020 16:00	10.7	13.3	8.3	190.9	3,181,020.7	2,090.6	2.1	1.7
10/16/2020 17:00	10.5	13.3	8.2	199.4	3,220,404.6	2,140.0	2.2	1.7
10/16/2020 18:00	10.5	13.3	8.2	196.8	3,241,275.4	2,130.2	2.1	1.7
10/16/2020 19:00	10.6	13.3	8.2	212.5	3,205,764.2	2,200.5	2.3	2.0
10/16/2020 20:00	10.4	13.3	8.1	204.6	3,192,673.1	2,168.2	2.2	1.7
10/16/2020 21:00	10.4	13.3	8.1	196.1	3,215,288.1	2,136.6	2.1	1.7
10/16/2020 22:00	10.4	13.3	8.1	186.5	3,247,247.6	2,086.7	2.0	1.7
10/16/2020 23:00	10.5	13.4	8.3	176.8	3,249,357.4	2,040.6	1.9	1.4
Average/Sum#:	10.0	13.5	8.0	164.7	3,157,692.9	1,915.6	1.8	1.4
Minimum:	8.4	13.3	7.1	87.9	2,620,165.3	1,320.2	1.0	0.5
Maximum:	11.4	14.0	9.0	212.5	3,309,185.1	2,200.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/17/2020 00:00	10.3	13.4	8.1	165.3	3,224,087.0	1,954.1	1.8	1.4
10/17/2020 01:00	8.5	13.9	7.2	102.2	3,014,469.5	1,562.9	1.1	0.6
10/17/2020 02:00	8.8	14.0	7.5	86.5	2,622,943.9	1,321.6	1.1	0.5
10/17/2020 03:00	8.4	14.0	7.2	103.2	3,170,608.7	1,620.7	1.1	0.6
10/17/2020 04:00	8.1	14.0	6.9	99.4	3,164,152.9	1,617.4	1.0	0.6
10/17/2020 05:00	8.4	14.0	7.2	104.2	3,268,620.4	1,670.8	1.1	0.7
10/17/2020 06:00	9.8	13.6	7.9	143.0	3,279,771.4	1,820.2	1.5	1.1
10/17/2020 07:00	10.0	13.5	8.0	152.3	3,194,695.9	1,866.3	1.6	1.1
10/17/2020 08:00	8.5	13.9	7.2	109.1	3,239,556.6	1,679.6	1.1	0.7
10/17/2020 09:00	8.6	13.9	7.2	111.7	3,245,921.5	1,682.9	1.2	0.8
10/17/2020 10:00	8.7	13.9	7.3	108.8	3,157,005.4	1,636.8	1.2	0.8
10/17/2020 11:00	8.8	13.9	7.4	99.0	2,879,648.7	1,493.0	1.1	0.6
10/17/2020 12:00	8.6	14.0	7.4	92.4	2,882,247.1	1,473.3	1.1	0.6
10/17/2020 13:00	8.4	14.0	7.2	90.6	2,904,370.5	1,463.4	1.0	0.6
10/17/2020 14:00	9.4	13.8	7.8	134.2	3,079,539.3	1,664.1	1.5	1.0
10/17/2020 15:00	10.9	13.3	8.5	186.2	3,201,593.8	2,127.5	2.0	1.7
10/17/2020 16:00	10.6	13.2	8.1	209.1	3,176,055.5	2,203.3	2.3	2.0
10/17/2020 17:00	10.6	13.3	8.2	213.7	3,181,533.2	2,207.1	2.4	2.0
10/17/2020 18:00	10.4	13.3	8.1	182.5	3,196,605.8	2,077.5	2.0	1.7
10/17/2020 19:00	10.5	13.3	8.2	186.3	3,240,458.1	2,106.0	2.0	1.7
10/17/2020 20:00	10.4	13.3	8.1	188.0	3,224,842.3	2,119.4	2.0	1.7
10/17/2020 21:00	10.4	13.4	8.2	167.7	3,252,463.5	2,018.8	1.8	1.4
10/17/2020 22:00	10.4	13.3	8.1	184.2	3,249,382.5	2,111.8	2.0	1.7
10/17/2020 23:00	10.4	13.3	8.1	185.1	3,242,920.0	2,107.6	2.0	1.7
Average/Sum#:	9.5	13.6	7.7	141.9	3,137,228.9	1,816.9	1.5	1.1
Minimum:	8.1	13.2	6.9	86.5	2,622,943.9	1,321.6	1.0	0.5
Maximum:	10.9	14.0	8.5	213.7	3,279,771.4	2,207.1	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/18/2020 00:00	8.6	13.8	7.1	119.1	3,153,007.1	1,703.8	1.3	0.9
10/18/2020 01:00	9.8	13.6	7.9	151.9	3,225,170.0	1,837.0	1.6	1.1
10/18/2020 02:00	10.7	13.3	8.3	207.9	3,223,537.6	2,212.7	2.3	2.0
10/18/2020 03:00	10.2	13.3	7.9	196.8	3,214,686.1	2,136.2	2.1	1.7
10/18/2020 04:00	8.1	13.9	6.8	107.6	3,229,912.8	1,674.6	1.1	0.7
10/18/2020 05:00	8.4	13.9	7.1	104.6	3,103,578.6	1,609.1	1.1	0.6
10/18/2020 06:00	8.8	13.9	7.4	100.7	3,023,534.7	1,567.6	1.1	0.6
10/18/2020 07:00	8.6	13.9	7.2	94.5	2,959,326.1	1,512.7	1.1	0.6
10/18/2020 08:00	8.4	14.0	7.2	100.3	3,151,241.1	1,610.8	1.1	0.6
10/18/2020 09:00	8.3	14.0	7.1	99.5	3,164,152.9	1,617.4	1.0	0.6
10/18/2020 10:00	8.3	14.0	7.1	99.0	3,097,638.0	1,583.4	1.1	0.6
10/18/2020 11:00	8.4	14.0	7.2	102.3	3,158,870.8	1,614.7	1.1	0.6
10/18/2020 12:00	8.5	13.9	7.2	108.4	3,141,575.3	1,628.8	1.2	0.8
10/18/2020 13:00	8.7	13.9	7.3	107.2	3,099,142.4	1,606.8	1.2	0.8
10/18/2020 14:00	8.8	13.8	7.3	112.6	3,166,842.1	1,641.9	1.2	0.8
10/18/2020 15:00	10.1	13.6	8.2	155.0	3,192,715.1	1,795.2	1.7	1.3
10/18/2020 16:00	11.1	13.3	8.6	193.2	3,203,560.0	2,152.2	2.1	1.7
10/18/2020 17:00	10.4	13.6	8.4	160.6	3,192,979.5	1,725.4	1.7	1.2
10/18/2020 18:00	17.3	15.2	17.9	140.9	2,056,689.7	886.1	2.2	0.7
10/18/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2020 21:00	39.3	17.5	68.2	85.6	1,814,030.8	397.4	0.0	0.0
10/18/2020 22:00	30.5	14.7	29.0	215.9	2,618,251.1	1,185.4	2.6	1.2
10/18/2020 23:00	9.8	13.6	7.9	141.9	3,245,891.5	1,825.1	1.5	1.1
Average/Sum#:	11.9	14.0	11.7	132.1	3,019,833.3	1,614.7	1.4	0.9
Minimum:	8.1	13.3	6.8	85.6	1,814,030.8	397.4	0.0	0.0
Maximum:	39.3	17.5	68.2	215.9	3,245,891.5	2,212.7	2.6	2.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/19/2020 00:00	9.9	13.6	8.0	153.2	3,211,040.2	1,852.4	1.6	1.1
10/19/2020 01:00	8.6	13.9	7.2	104.2	3,155,655.3	1,636.1	1.1	0.7
10/19/2020 02:00	8.8	13.9	7.4	105.2	3,066,546.2	1,589.9	1.1	0.6
10/19/2020 03:00	8.9	13.8	7.4	122.2	3,259,615.8	1,690.0	1.3	0.8
10/19/2020 04:00	10.0	13.6	8.1	141.9	3,289,861.9	1,825.8	1.5	1.1
10/19/2020 05:00	11.0	13.3	8.5	191.6	3,276,001.6	2,129.1	2.0	1.7
10/19/2020 06:00	10.9	13.3	8.5	175.4	3,258,296.3	2,093.8	1.9	1.5
10/19/2020 07:00	8.4	13.8	7.0	107.6	3,272,152.8	1,696.5	1.1	0.7
10/19/2020 08:00	8.6	13.9	7.2	98.8	3,061,837.3	1,565.1	1.1	0.6
10/19/2020 09:00	8.6	13.9	7.2	105.0	3,148,711.7	1,632.5	1.1	0.7
10/19/2020 10:00	8.7	13.8	7.2	105.8	3,125,566.5	1,620.5	1.1	0.6
10/19/2020 11:00	8.6	14.0	7.4	100.4	3,109,767.1	1,589.6	1.1	0.6
10/19/2020 12:00	8.5	14.0	7.3	90.7	2,848,989.6	1,456.3	1.1	0.6
10/19/2020 13:00	8.4	14.0	7.2	90.9	2,840,067.1	1,431.0	1.1	0.6
10/19/2020 14:00	9.5	13.7	7.8	135.2	3,091,938.2	1,670.8	1.5	1.0
10/19/2020 15:00	11.1	13.3	8.6	176.8	3,232,786.0	2,053.8	1.9	1.4
10/19/2020 16:00	11.0	13.2	8.4	205.2	3,195,470.8	2,170.1	2.2	1.7
10/19/2020 17:00	10.8	13.2	8.3	214.6	3,189,029.0	2,212.3	2.4	2.0
10/19/2020 18:00	10.7	13.3	8.3	196.3	3,187,037.6	2,141.1	2.1	1.7
10/19/2020 19:00	10.6	13.3	8.2	207.9	3,199,062.8	2,195.9	2.3	2.0
10/19/2020 20:00	9.5	13.6	7.7	154.4	3,057,411.1	1,786.1	1.7	1.3
10/19/2020 21:00	9.8	13.6	7.9	142.8	3,227,751.1	1,814.9	1.5	1.1
10/19/2020 22:00	10.7	13.4	8.4	176.1	3,259,387.4	2,070.7	1.9	1.4
10/19/2020 23:00	10.3	13.4	8.1	161.2	3,286,618.5	1,944.0	1.7	1.4
Average/Sum#:	9.7	13.6	7.8	144.3	3,160,441.7	1,827.8	1.6	1.1
Minimum:	8.4	13.2	7.0	90.7	2,840,067.1	1,431.0	1.1	0.6
Maximum:	11.1	14.0	8.6	214.6	3,289,861.9	2,212.3	2.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/20/2020 00:00	8.5	13.9	7.2	97.8	2,968,179.1	1,538.9	1.1	0.6
10/20/2020 01:00	9.0	14.0	7.7	86.5	2,569,754.6	1,294.8	1.1	0.5
10/20/2020 02:00	8.6	14.0	7.4	86.6	2,723,980.7	1,392.4	1.1	0.6
10/20/2020 03:00	9.9	13.7	8.1	151.4	3,301,773.5	1,808.3	1.6	1.1
10/20/2020 04:00	10.6	13.4	8.3	169.1	3,279,134.5	2,059.3	1.8	1.4
10/20/2020 05:00	10.5	13.4	8.3	182.1	3,250,515.5	2,088.8	1.9	1.5
10/20/2020 06:00	10.8	13.4	8.5	170.3	3,224,128.7	2,048.3	1.8	1.4
10/20/2020 07:00	8.5	13.9	7.2	108.2	3,215,061.3	1,666.9	1.1	0.7
10/20/2020 08:00	9.0	14.0	7.7	87.8	2,645,569.1	1,333.0	1.1	0.5
10/20/2020 09:00	8.6	14.0	7.4	92.3	2,862,488.2	1,463.2	1.1	0.6
10/20/2020 10:00	8.9	14.0	7.6	113.5	3,203,670.5	1,637.6	1.2	0.8
10/20/2020 11:00	9.5	13.7	7.8	139.0	3,186,317.4	1,721.8	1.5	1.0
10/20/2020 12:00	10.9	13.3	8.5	174.4	3,236,821.3	2,080.0	1.9	1.5
10/20/2020 13:00	10.7	13.3	8.3	183.2	3,167,630.8	2,081.8	2.0	1.7
10/20/2020 14:00	8.7	13.8	7.2	119.3	3,276,781.8	1,698.9	1.2	0.8
10/20/2020 15:00	10.2	13.5	8.1	153.3	3,157,036.7	1,844.3	1.7	1.3
10/20/2020 16:00	10.9	13.2	8.4	205.9	3,165,244.3	2,195.8	2.3	2.0
10/20/2020 17:00	10.5	13.3	8.2	194.2	3,174,708.6	2,156.0	2.1	1.7
10/20/2020 18:00	10.4	13.3	8.1	180.7	3,198,671.0	2,102.2	2.0	1.7
10/20/2020 19:00	10.4	13.3	8.1	168.2	3,206,341.9	2,037.0	1.8	1.4
10/20/2020 20:00	10.2	13.4	8.0	174.6	3,117,776.6	1,935.2	1.9	1.4
10/20/2020 21:00	10.3	13.7	8.4	137.1	3,199,158.0	1,752.1	1.4	0.9
10/20/2020 22:00	10.6	13.3	8.2	174.8	3,250,204.3	2,088.6	1.9	1.5
10/20/2020 23:00	10.5	13.3	8.2	191.8	3,190,169.8	2,166.5	2.1	1.7
Average/Sum#:	9.9	13.6	8.0	147.6	3,115,463.3	1,841.3	1.6	1.2
Minimum:	8.5	13.2	7.2	86.5	2,569,754.6	1,294.8	1.1	0.5
Maximum:	10.9	14.0	8.5	205.9	3,301,773.5	2,195.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/21/2020 00:00	10.3	13.4	8.1	177.8	3,175,695.1	2,087.1	1.9	1.5
10/21/2020 01:00	9.0	13.8	7.5	118.1	3,269,259.6	1,695.0	1.2	0.8
10/21/2020 02:00	10.4	13.7	8.5	149.3	3,150,031.8	1,771.2	1.6	1.1
10/21/2020 03:00	10.6	13.3	8.2	193.7	3,240,177.2	2,176.8	2.1	1.7
10/21/2020 04:00	10.3	13.3	8.0	185.3	3,228,646.2	2,121.9	2.0	1.7
10/21/2020 05:00	10.3	13.4	8.1	160.7	3,301,923.9	2,049.5	1.7	1.4
10/21/2020 06:00	10.8	13.3	8.4	177.8	3,255,426.1	2,139.5	1.9	1.5
10/21/2020 07:00	8.7	13.8	7.2	104.1	2,961,760.6	1,557.2	1.2	0.8
10/21/2020 08:00	8.5	13.9	7.2	96.3	3,000,017.6	1,533.5	1.1	0.6
10/21/2020 09:00	8.8	14.0	7.5	87.5	2,665,291.1	1,362.4	1.1	0.5
10/21/2020 10:00	8.4	14.0	7.2	98.9	3,083,552.4	1,576.2	1.1	0.6
10/21/2020 11:00	8.4	14.0	7.2	95.1	2,991,801.0	1,529.3	1.1	0.6
10/21/2020 12:00	8.6	14.0	7.4	102.4	3,134,808.0	1,602.4	1.1	0.6
10/21/2020 13:00	9.3	13.7	7.6	128.3	3,122,472.7	1,687.3	1.4	0.8
10/21/2020 14:00	11.0	13.3	8.5	186.0	3,205,506.5	2,130.1	2.0	1.7
10/21/2020 15:00	10.8	13.3	8.4	178.6	3,189,989.5	2,073.2	1.9	1.5
10/21/2020 16:00	10.6	13.3	8.2	195.5	3,184,427.1	2,162.6	2.1	1.7
10/21/2020 17:00	10.5	13.2	8.0	205.5	3,167,983.1	2,197.7	2.3	2.0
10/21/2020 18:00	10.4	13.3	8.1	204.8	3,168,703.9	2,198.2	2.3	2.0
10/21/2020 19:00	10.3	13.3	8.0	189.3	3,205,495.0	2,153.5	2.1	1.7
10/21/2020 20:00	10.4	13.3	8.1	201.4	3,195,323.6	2,170.0	2.2	1.7
10/21/2020 21:00	10.3	13.4	8.1	188.9	3,173,603.4	2,108.9	2.1	1.7
10/21/2020 22:00	10.4	13.4	8.2	197.6	3,206,108.4	2,130.5	2.2	1.7
10/21/2020 23:00	10.2	13.4	8.0	176.0	3,196,268.0	2,030.6	1.9	1.4
Average/Sum#:	9.9	13.5	7.9	158.3	3,144,761.3	1,926.9	1.7	1.3
Minimum:	8.4	13.2	7.2	87.5	2,665,291.1	1,362.4	1.1	0.5
Maximum:	11.0	14.0	8.5	205.5	3,301,923.9	2,198.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/22/2020 00:00	8.7	13.9	7.3	116.6	3,312,637.6	1,693.3	1.2	0.8
10/22/2020 01:00	9.8	13.6	7.9	148.3	3,251,582.6	1,828.3	1.6	1.1
10/22/2020 02:00	10.7	13.5	8.5	175.1	3,216,536.2	1,996.5	1.9	1.4
10/22/2020 03:00	10.4	13.5	8.3	171.0	3,208,691.8	1,968.2	1.8	1.4
10/22/2020 04:00	8.1	14.0	6.9	107.9	3,305,986.1	1,689.9	1.1	0.7
10/22/2020 05:00	8.8	13.8	7.3	135.9	3,064,217.1	1,767.7	1.5	1.1
10/22/2020 06:00	10.9	13.3	8.5	186.0	3,310,963.8	2,176.0	1.9	1.5
10/22/2020 07:00	10.4	13.4	8.2	186.6	3,230,456.7	2,099.5	2.0	1.7
10/22/2020 08:00	8.3	13.9	7.0	96.2	2,914,330.7	1,489.7	1.1	0.6
10/22/2020 09:00	8.2	14.0	7.0	97.9	3,109,571.5	1,589.5	1.0	0.6
10/22/2020 10:00	8.2	14.0	7.0	99.6	3,165,522.3	1,618.1	1.0	0.6
10/22/2020 11:00	10.1	13.6	8.2	157.3	3,296,348.6	1,829.4	1.6	1.1
10/22/2020 12:00	10.9	13.3	8.5	190.4	3,280,925.4	2,132.3	2.0	1.7
10/22/2020 13:00	10.6	13.4	8.3	171.8	3,260,371.2	1,999.9	1.8	1.4
10/22/2020 14:00	8.6	13.9	7.2	106.9	3,065,003.2	1,589.1	1.2	0.8
10/22/2020 15:00	9.3	13.8	7.7	128.2	3,161,682.0	1,685.4	1.4	0.8
10/22/2020 16:00	11.0	13.3	8.5	187.2	3,280,156.1	2,131.8	2.0	1.7
10/22/2020 17:00	10.8	13.3	8.4	193.2	3,263,034.0	2,144.5	2.1	1.7
10/22/2020 18:00	10.5	13.4	8.3	169.6	3,293,302.6	2,020.1	1.8	1.4
10/22/2020 19:00	10.7	13.4	8.4	179.6	3,290,238.8	2,090.3	1.9	1.5
10/22/2020 20:00	10.5	13.4	8.3	173.3	3,283,274.6	2,061.9	1.8	1.4
10/22/2020 21:00	10.5	13.4	8.3	171.2	3,322,868.0	2,062.5	1.8	1.4
10/22/2020 22:00	10.8	13.5	8.6	172.2	3,293,954.7	2,020.5	1.8	1.4
10/22/2020 23:00	10.7	13.5	8.5	174.0	3,249,825.6	1,969.7	1.8	1.4
Average/Sum#:	9.9	13.6	8.0	154.0	3,226,311.7	1,902.3	1.6	1.2
Minimum:	8.1	13.3	6.9	96.2	2,914,330.7	1,489.7	1.0	0.6
Maximum:	11.0	14.0	8.6	193.2	3,322,868.0	2,176.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/23/2020 00:00	7.8	14.0	6.7	102.6	3,203,083.6	1,637.3	1.1	0.7
10/23/2020 01:00	10.0	13.7	8.2	144.4	3,274,906.3	1,817.5	1.5	1.1
10/23/2020 02:00	10.6	13.4	8.3	182.8	3,319,201.4	2,108.7	1.9	1.5
10/23/2020 03:00	10.1	13.4	7.9	163.6	3,306,087.4	2,003.8	1.7	1.4
10/23/2020 04:00	8.1	13.9	6.8	105.2	3,296,008.9	1,684.8	1.1	0.7
10/23/2020 05:00	9.7	13.8	8.1	131.9	3,206,208.7	1,826.2	1.4	0.9
10/23/2020 06:00	10.8	13.3	8.4	180.8	3,318,315.3	2,156.6	1.9	1.5
10/23/2020 07:00	10.5	13.4	8.3	176.4	3,327,858.7	2,114.2	1.8	1.5
10/23/2020 08:00	10.3	13.4	8.1	156.8	3,341,395.5	2,000.8	1.6	1.2
10/23/2020 09:00	8.4	13.8	7.0	112.6	3,220,961.2	1,717.0	1.2	0.9
10/23/2020 10:00	8.4	13.9	7.1	105.8	3,258,844.3	1,689.6	1.1	0.7
10/23/2020 11:00	9.2	13.8	7.6	138.4	3,305,257.9	1,737.8	1.4	0.9
10/23/2020 12:00	10.8	13.4	8.5	164.4	3,305,089.8	2,075.6	1.7	1.5
10/23/2020 13:00	10.4	13.4	8.2	158.8	3,278,101.4	1,962.9	1.7	1.4
10/23/2020 14:00	8.4	13.9	7.1	103.8	3,145,567.8	1,607.9	1.1	0.6
10/23/2020 15:00	9.2	13.7	7.5	134.9	3,286,243.3	1,751.8	1.4	0.9
10/23/2020 16:00	10.8	13.4	8.5	169.6	3,291,236.3	2,066.9	1.8	1.4
10/23/2020 17:00	10.5	13.3	8.2	178.9	3,261,691.9	2,119.8	1.9	1.5
10/23/2020 18:00	10.2	13.5	8.1	153.5	3,314,007.0	1,936.0	1.6	1.2
10/23/2020 19:00	8.3	13.9	7.0	107.3	3,281,603.7	1,701.4	1.1	0.7
10/23/2020 20:00	9.7	13.6	7.8	140.4	3,312,745.7	1,838.5	1.4	0.9
10/23/2020 21:00	10.6	13.4	8.3	170.6	3,292,669.5	2,067.8	1.8	1.4
10/23/2020 22:00	10.4	13.4	8.2	164.0	3,356,079.7	2,034.1	1.7	1.4
10/23/2020 23:00	10.5	13.4	8.3	176.8	3,317,586.2	2,131.9	1.8	1.5
Average/Sum#:	9.7	13.6	7.8	146.8	3,284,198.0	1,907.9	1.5	1.1
Minimum:	7.8	13.3	6.7	102.6	3,145,567.8	1,607.9	1.1	0.6
Maximum:	10.8	14.0	8.5	182.8	3,356,079.7	2,156.6	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/24/2020 00:00	8.4	13.8	7.0	119.6	3,234,655.4	1,724.3	1.3	0.9
10/24/2020 01:00	8.2	13.9	6.9	104.1	3,267,716.6	1,694.2	1.1	0.7
10/24/2020 02:00	9.3	13.7	7.6	132.3	3,307,880.6	1,835.8	1.4	0.9
10/24/2020 03:00	10.4	13.4	8.2	171.1	3,323,766.1	2,111.6	1.8	1.5
10/24/2020 04:00	10.2	13.5	8.1	155.5	3,303,355.9	1,953.9	1.6	1.2
10/24/2020 05:00	8.1	13.9	6.8	110.6	3,241,871.1	1,680.8	1.1	0.7
10/24/2020 06:00	8.6	13.9	7.2	104.8	3,233,191.7	1,676.3	1.1	0.7
10/24/2020 07:00	8.6	13.9	7.2	101.8	3,146,590.1	1,631.4	1.1	0.7
10/24/2020 08:00	8.6	13.9	7.2	98.4	3,041,858.0	1,577.1	1.1	0.6
10/24/2020 09:00	8.6	13.9	7.2	102.6	3,128,845.4	1,622.2	1.1	0.6
10/24/2020 10:00	8.7	13.9	7.3	106.2	3,237,820.7	1,678.7	1.1	0.7
10/24/2020 11:00	8.7	13.9	7.3	103.3	3,158,162.7	1,637.4	1.1	0.7
10/24/2020 12:00	8.8	13.9	7.4	91.0	2,812,602.1	1,437.7	1.1	0.6
10/24/2020 13:00	8.8	14.0	7.5	91.6	2,803,407.3	1,433.0	1.1	0.6
10/24/2020 14:00	8.9	13.9	7.5	117.4	3,195,649.6	1,633.5	1.2	0.8
10/24/2020 15:00	8.9	13.9	7.5	109.8	3,322,027.9	1,698.1	1.1	0.7
10/24/2020 16:00	10.9	13.5	8.7	158.8	3,247,314.3	1,825.9	1.7	1.3
10/24/2020 17:00	11.0	13.3	8.5	186.8	3,251,317.8	2,136.8	2.0	1.7
10/24/2020 18:00	10.6	13.4	8.3	161.4	3,286,956.7	1,944.2	1.7	1.4
10/24/2020 19:00	8.6	13.8	7.1	108.0	3,280,446.5	1,700.8	1.1	0.7
10/24/2020 20:00	8.7	13.8	7.2	107.6	3,264,630.6	1,692.6	1.1	0.7
10/24/2020 21:00	9.5	13.6	7.7	135.8	3,275,446.9	1,817.8	1.4	0.9
10/24/2020 22:00	10.9	13.4	8.6	165.3	3,290,531.2	2,018.4	1.7	1.4
10/24/2020 23:00	10.5	13.5	8.4	158.0	3,247,020.7	1,968.0	1.7	1.4
Average/Sum#:	9.3	13.7	7.6	125.1	3,204,294.4	1,755.4	1.3	0.9
Minimum:	8.1	13.3	6.8	91.0	2,803,407.3	1,433.0	1.1	0.6
Maximum:	11.0	14.0	8.7	186.8	3,323,766.1	2,136.8	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/25/2020 00:00	8.3	13.9	7.0	107.3	3,243,799.9	1,681.8	1.1	0.7
10/25/2020 01:00	8.4	13.9	7.1	103.7	3,219,690.3	1,669.3	1.1	0.7
10/25/2020 02:00	8.4	13.9	7.1	103.1	3,191,723.2	1,654.8	1.1	0.7
10/25/2020 03:00	8.5	13.9	7.2	103.2	3,189,601.6	1,653.7	1.1	0.7
10/25/2020 04:00	8.5	13.9	7.2	103.1	3,187,672.8	1,652.7	1.1	0.7
10/25/2020 05:00	8.6	13.9	7.2	102.6	3,141,768.1	1,628.9	1.1	0.7
10/25/2020 06:00	8.8	13.9	7.4	100.2	3,076,575.8	1,595.1	1.1	0.6
10/25/2020 07:00	8.7	13.9	7.3	101.5	3,124,216.4	1,619.8	1.1	0.6
10/25/2020 08:00	8.5	13.9	7.2	101.1	3,159,457.7	1,615.0	1.1	0.6
10/25/2020 09:00	8.5	13.9	7.2	97.8	3,061,446.0	1,564.9	1.1	0.6
10/25/2020 10:00	8.6	14.0	7.4	88.9	2,784,235.4	1,423.2	1.1	0.6
10/25/2020 11:00	8.8	14.0	7.5	86.5	2,683,277.9	1,352.0	1.1	0.5
10/25/2020 12:00	8.4	14.0	7.2	96.4	3,045,404.2	1,556.7	1.0	0.6
10/25/2020 13:00	8.3	14.0	7.1	99.3	3,142,242.1	1,606.2	1.0	0.6
10/25/2020 14:00	8.3	14.0	7.1	104.8	3,251,991.6	1,662.3	1.1	0.7
10/25/2020 15:00	8.5	14.0	7.3	99.8	3,201,873.0	1,613.3	1.0	0.6
10/25/2020 16:00	9.8	13.7	8.0	153.4	3,375,357.2	1,848.6	1.5	1.1
10/25/2020 17:00	10.7	13.4	8.4	171.6	3,397,802.7	2,084.2	1.7	1.5
10/25/2020 18:00	10.1	13.5	8.1	163.4	3,318,245.7	2,035.4	1.7	1.4
10/25/2020 19:00	8.2	14.0	7.0	103.9	3,271,946.1	1,672.5	1.1	0.7
10/25/2020 20:00	9.8	13.7	8.0	142.0	3,302,835.4	1,833.0	1.5	1.1
10/25/2020 21:00	10.8	13.4	8.5	200.9	3,341,395.5	2,171.6	2.1	1.7
10/25/2020 22:00	10.3	13.4	8.1	202.5	3,340,330.4	2,195.3	2.1	1.8
10/25/2020 23:00	10.3	13.4	8.1	212.9	3,334,101.8	2,239.9	2.2	1.8
Average/Sum#:	9.0	13.8	7.5	122.9	3,182,791.3	1,734.6	1.3	0.9
Minimum:	8.2	13.4	7.0	86.5	2,683,277.9	1,352.0	1.0	0.5
Maximum:	10.8	14.0	8.5	212.9	3,397,802.7	2,239.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/26/2020 00:00	9.7	13.5	7.7	169.7	3,358,187.2	2,059.9	1.7	1.4
10/26/2020 01:00	9.4	13.6	7.6	149.8	3,407,983.8	1,990.9	1.5	1.2
10/26/2020 02:00	9.6	13.5	7.7	164.2	3,357,046.1	2,059.2	1.7	1.4
10/26/2020 03:00	7.6	13.9	6.4	102.7	3,260,965.9	1,690.7	1.1	0.7
10/26/2020 04:00	9.7	13.7	7.9	146.8	3,378,514.1	1,875.0	1.5	1.1
10/26/2020 05:00	10.4	13.4	8.2	168.2	3,301,530.0	2,169.8	1.8	1.5
10/26/2020 06:00	10.6	13.5	8.5	188.0	3,314,473.9	2,129.9	2.0	1.7
10/26/2020 07:00	8.8	13.8	7.3	120.0	3,452,106.7	1,789.8	1.2	0.9
10/26/2020 08:00	8.0	14.0	6.8	106.8	3,447,036.8	1,762.0	1.0	0.7
10/26/2020 09:00	8.2	14.0	7.0	106.7	3,423,756.6	1,750.1	1.0	0.7
10/26/2020 10:00	8.0	14.0	6.8	103.1	3,303,051.6	1,688.4	1.0	0.7
10/26/2020 11:00	8.5	14.1	7.4	89.8	2,758,298.6	1,389.8	1.1	0.6
10/26/2020 12:00	8.3	14.0	7.1	95.0	3,053,816.4	1,538.7	1.0	0.6
10/26/2020 13:00	8.2	14.0	7.0	93.7	3,008,168.9	1,515.7	1.0	0.6
10/26/2020 14:00	8.5	14.0	7.3	104.5	3,371,959.5	1,699.0	1.0	0.7
10/26/2020 15:00	8.3	14.0	7.1	103.5	3,277,489.0	1,651.4	1.0	0.7
10/26/2020 16:00	10.2	13.6	8.2	161.0	3,326,278.5	1,870.3	1.7	1.3
10/26/2020 17:00	10.8	13.4	8.5	192.7	3,364,629.6	2,186.7	2.0	1.7
10/26/2020 18:00	10.8	13.3	8.4	209.2	3,331,422.5	2,238.1	2.2	1.8
10/26/2020 19:00	10.4	13.4	8.2	178.5	3,362,892.3	2,111.9	1.8	1.5
10/26/2020 20:00	10.5	13.4	8.3	190.6	3,365,516.0	2,162.7	2.0	1.7
10/26/2020 21:00	10.6	13.4	8.3	184.3	3,348,163.9	2,127.1	1.9	1.5
10/26/2020 22:00	10.4	13.4	8.2	179.3	3,364,643.9	2,113.0	1.8	1.5
10/26/2020 23:00	10.3	13.5	8.2	170.9	3,354,767.5	2,082.3	1.8	1.5
Average/Sum#:	9.4	13.7	7.7	145.0	3,303,862.5	1,902.2	1.5	1.2
Minimum:	7.6	13.3	6.4	89.8	2,758,298.6	1,389.8	1.0	0.6
Maximum:	10.8	14.1	8.5	209.2	3,452,106.7	2,238.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/27/2020 00:00	7.8	14.0	6.7	107.5	3,312,246.3	1,693.1	1.1	0.7
10/27/2020 01:00	9.5	13.8	7.9	139.9	3,334,178.3	1,801.7	1.4	0.9
10/27/2020 02:00	10.8	13.5	8.6	188.4	3,298,266.5	2,095.4	2.0	1.7
10/27/2020 03:00	10.3	13.5	8.2	174.5	3,302,595.1	2,025.8	1.8	1.4
10/27/2020 04:00	7.6	14.0	6.5	102.3	3,253,556.7	1,663.1	1.1	0.7
10/27/2020 05:00	9.1	13.8	7.6	134.4	3,040,295.5	1,753.9	1.5	1.1
10/27/2020 06:00	10.9	13.4	8.6	205.0	3,290,786.3	2,210.8	2.2	1.8
10/27/2020 07:00	10.4	13.3	8.1	198.3	3,327,400.3	2,211.1	2.1	1.8
10/27/2020 08:00	10.4	13.4	8.2	185.3	3,342,640.4	2,148.0	1.9	1.5
10/27/2020 09:00	10.6	13.3	8.2	192.2	3,287,531.5	2,160.6	2.0	1.7
10/27/2020 10:00	10.4	13.3	8.1	194.1	3,298,334.7	2,167.7	2.1	1.7
10/27/2020 11:00	10.6	13.3	8.2	200.0	3,259,531.0	2,166.0	2.1	1.7
10/27/2020 12:00	10.8	13.3	8.4	201.4	3,279,923.6	2,155.6	2.1	1.7
10/27/2020 13:00	10.8	13.3	8.4	205.6	3,232,883.5	2,171.9	2.2	1.7
10/27/2020 14:00	10.7	13.3	8.3	205.8	3,239,730.6	2,176.5	2.2	1.7
10/27/2020 15:00	10.7	13.4	8.4	173.3	3,264,772.9	2,002.6	1.8	1.4
10/27/2020 16:00	10.7	13.3	8.3	203.5	3,236,158.2	2,174.1	2.2	1.7
10/27/2020 17:00	10.6	13.3	8.2	213.9	3,234,026.8	2,219.9	2.3	2.0
10/27/2020 18:00	10.5	13.3	8.2	212.9	3,236,503.4	2,221.6	2.3	2.0
10/27/2020 19:00	10.5	13.3	8.2	211.9	3,270,273.8	2,220.9	2.3	2.0
10/27/2020 20:00	10.4	13.3	8.1	205.3	3,277,836.3	2,202.1	2.2	1.8
10/27/2020 21:00	10.4	13.4	8.2	177.3	3,310,185.4	2,078.8	1.9	1.5
10/27/2020 22:00	10.4	13.4	8.2	174.2	3,343,973.2	2,075.6	1.8	1.5
10/27/2020 23:00	10.2	13.4	8.0	173.4	3,281,045.3	2,060.5	1.8	1.4
Average/Sum#:	10.2	13.4	8.1	182.5	3,273,111.5	2,077.4	1.9	1.5
Minimum:	7.6	13.3	6.5	102.3	3,040,295.5	1,663.1	1.1	0.7
Maximum:	10.9	14.0	8.6	213.9	3,343,973.2	2,221.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/28/2020 00:00	7.8	13.9	6.6	105.6	3,291,509.3	1,682.5	1.1	0.7
10/28/2020 01:00	8.0	13.9	6.7	102.3	3,267,837.8	1,670.4	1.0	0.7
10/28/2020 02:00	8.1	13.9	6.8	101.8	3,245,535.8	1,659.0	1.0	0.7
10/28/2020 03:00	8.2	13.9	6.9	101.8	3,239,862.5	1,656.1	1.0	0.7
10/28/2020 04:00	9.5	13.7	7.8	137.4	3,351,985.7	1,835.8	1.4	0.9
10/28/2020 05:00	10.7	13.4	8.4	176.6	3,298,620.2	2,143.8	1.8	1.5
10/28/2020 06:00	10.6	13.4	8.3	199.4	3,279,696.2	2,179.4	2.1	1.7
10/28/2020 07:00	9.9	13.7	8.1	146.4	3,441,249.4	1,809.3	1.4	0.9
10/28/2020 08:00	9.3	13.8	7.7	138.0	3,307,350.1	1,738.9	1.4	0.9
10/28/2020 09:00	8.8	13.8	7.3	117.4	3,153,919.4	1,635.2	1.3	0.8
10/28/2020 10:00	8.7	13.8	7.2	122.9	3,205,610.3	1,662.0	1.3	0.8
10/28/2020 11:00	9.3	14.0	8.0	87.9	2,554,759.0	1,305.9	1.1	0.5
10/28/2020 12:00	9.5	14.0	8.1	87.4	2,518,351.6	1,268.9	1.1	0.5
10/28/2020 13:00	8.7	13.9	7.3	92.3	2,888,898.6	1,476.7	1.1	0.6
10/28/2020 14:00	8.5	13.9	7.2	96.7	3,041,491.6	1,554.7	1.1	0.6
10/28/2020 15:00	9.1	14.0	7.8	86.8	2,571,342.4	1,295.6	1.1	0.5
10/28/2020 16:00	8.6	13.8	7.1	104.7	3,164,527.6	1,640.7	1.1	0.7
10/28/2020 17:00	8.8	13.8	7.3	114.8	3,302,048.7	1,712.0	1.2	0.9
10/28/2020 18:00	10.8	13.4	8.5	164.8	3,315,821.9	2,009.7	1.7	1.4
10/28/2020 19:00	10.6	13.3	8.2	167.9	3,287,255.5	2,064.4	1.8	1.4
10/28/2020 20:00	10.5	13.3	8.2	173.1	3,288,192.6	2,089.0	1.8	1.5
10/28/2020 21:00	10.3	13.3	8.0	169.8	3,325,790.4	2,088.6	1.8	1.5
10/28/2020 22:00	10.2	13.4	8.0	164.1	3,323,351.3	2,062.8	1.7	1.4
10/28/2020 23:00	10.0	13.5	8.0	148.5	3,288,843.8	1,921.3	1.5	1.2
Average/Sum#:	9.4	13.7	7.6	129.5	3,164,743.8	1,756.8	1.4	1.0
Minimum:	7.8	13.3	6.6	86.8	2,518,351.6	1,268.9	1.0	0.5
Maximum:	10.8	14.0	8.5	199.4	3,441,249.4	2,179.4	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/29/2020 00:00	7.9	13.9	6.7	104.2	3,322,027.9	1,698.1	1.0	0.7
10/29/2020 01:00	8.1	13.9	6.8	102.8	3,301,877.8	1,687.8	1.0	0.7
10/29/2020 02:00	8.3	13.9	7.0	95.5	3,024,275.9	1,545.9	1.0	0.6
10/29/2020 03:00	8.2	13.9	6.9	103.0	3,308,529.3	1,691.2	1.0	0.7
10/29/2020 04:00	9.7	13.7	7.9	134.3	3,292,826.6	1,803.4	1.4	0.9
10/29/2020 05:00	10.3	13.4	8.1	165.3	3,354,926.7	2,057.9	1.7	1.4
10/29/2020 06:00	10.5	13.4	8.3	162.0	3,327,701.3	2,065.5	1.7	1.4
10/29/2020 07:00	8.9	13.9	7.5	91.0	2,500,960.2	1,278.4	1.2	0.6
10/29/2020 08:00	9.0	13.9	7.6	86.9	2,534,804.5	1,295.7	1.1	0.5
10/29/2020 09:00	8.5	13.9	7.2	93.0	2,935,263.4	1,500.4	1.1	0.6
10/29/2020 10:00	8.6	13.9	7.2	93.6	2,936,828.4	1,501.2	1.1	0.6
10/29/2020 11:00	10.3	13.6	8.3	166.5	3,354,714.6	1,788.3	1.7	1.3
10/29/2020 12:00	10.5	13.6	8.5	162.4	3,390,919.9	1,807.6	1.6	1.1
10/29/2020 13:00	10.6	13.6	8.6	161.1	3,379,289.2	1,801.4	1.6	1.1
10/29/2020 14:00	10.6	13.6	8.6	161.3	3,379,664.3	1,801.6	1.6	1.1
10/29/2020 15:00	10.5	13.6	8.5	157.7	3,376,475.3	1,799.9	1.6	1.1
10/29/2020 16:00	9.4	13.7	7.7	136.4	3,352,997.6	1,762.9	1.4	0.9
10/29/2020 17:00	8.7	13.8	7.2	110.2	3,393,665.1	1,759.5	1.1	0.7
10/29/2020 18:00	10.9	13.4	8.6	170.6	3,309,279.2	2,029.9	1.8	1.4
10/29/2020 19:00	10.7	13.3	8.3	175.5	3,303,975.2	2,074.9	1.8	1.5
10/29/2020 20:00	10.6	13.3	8.2	178.3	3,301,886.8	2,097.7	1.9	1.5
10/29/2020 21:00	10.5	13.3	8.2	174.9	3,292,442.5	2,091.7	1.8	1.5
10/29/2020 22:00	10.6	13.3	8.2	177.3	3,326,108.9	2,088.8	1.8	1.5
10/29/2020 23:00	10.1	13.5	8.1	152.5	3,322,908.3	1,941.2	1.6	1.2
Average/Sum#:	9.7	13.6	7.8	138.2	3,221,847.9	1,790.5	1.4	1.0
Minimum:	7.9	13.3	6.7	86.9	2,500,960.2	1,278.4	1.0	0.5
Maximum:	10.9	13.9	8.6	178.3	3,393,665.1	2,097.7	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/30/2020 00:00	8.2	13.9	6.9	101.4	3,170,413.1	1,620.6	1.1	0.6
10/30/2020 01:00	9.2	13.8	7.6	120.8	3,181,754.4	1,696.1	1.3	0.8
10/30/2020 02:00	10.5	13.5	8.4	152.4	3,335,404.3	1,948.5	1.6	1.2
10/30/2020 03:00	10.2	13.5	8.1	155.3	3,296,086.1	1,949.6	1.6	1.2
10/30/2020 04:00	7.8	13.9	6.6	104.0	3,322,223.6	1,698.2	1.0	0.7
10/30/2020 05:00	8.9	13.7	7.3	139.7	3,131,873.6	1,829.6	1.5	1.1
10/30/2020 06:00	10.7	13.4	8.4	167.1	3,345,217.1	2,100.8	1.7	1.5
10/30/2020 07:00	10.3	13.3	8.0	208.4	3,336,036.9	2,241.2	2.2	1.8
10/30/2020 08:00	10.2	13.3	7.9	211.6	3,312,092.8	2,249.3	2.2	1.8
10/30/2020 09:00	10.4	13.3	8.1	213.0	3,254,665.3	2,210.3	2.3	2.0
10/30/2020 10:00	10.4	13.3	8.1	212.0	3,229,780.0	2,193.4	2.3	2.0
10/30/2020 11:00	10.0	13.5	8.0	168.7	3,248,959.4	1,992.9	1.8	1.4
10/30/2020 12:00	7.9	13.9	6.7	106.1	3,234,384.8	1,653.3	1.1	0.7
10/30/2020 13:00	9.5	13.6	7.7	141.0	3,267,158.3	1,813.2	1.5	1.1
10/30/2020 14:00	10.7	13.3	8.3	168.4	3,302,729.4	2,050.0	1.8	1.4
10/30/2020 15:00	10.5	13.3	8.2	180.9	3,257,845.2	2,117.3	1.9	1.5
10/30/2020 16:00	10.5	13.3	8.2	176.6	3,279,850.1	2,083.7	1.9	1.5
10/30/2020 17:00	10.4	13.3	8.1	190.4	3,264,497.1	2,169.3	2.0	1.7
10/30/2020 18:00	10.4	13.3	8.1	189.8	3,267,356.3	2,171.2	2.0	1.7
10/30/2020 19:00	10.3	13.3	8.0	196.4	3,283,343.8	2,205.8	2.1	1.8
10/30/2020 20:00	9.1	13.6	7.4	137.8	3,201,117.3	1,823.3	1.5	1.1
10/30/2020 21:00	9.6	13.6	7.8	140.5	3,312,385.3	1,838.3	1.4	0.9
10/30/2020 22:00	10.5	13.3	8.2	175.2	3,291,287.0	2,115.0	1.8	1.5
10/30/2020 23:00	9.5	13.5	7.6	139.3	3,311,781.7	1,934.7	1.4	1.0
Average/Sum#:	9.8	13.5	7.8	162.4	3,268,260.1	1,987.7	1.7	1.3
Minimum:	7.8	13.3	6.6	101.4	3,131,873.6	1,620.6	1.0	0.6
Maximum:	10.7	13.9	8.4	213.0	3,345,217.1	2,249.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/31/2020 00:00	8.3	13.9	7.0	108.5	3,070,053.8	1,569.3	1.2	0.8
10/31/2020 01:00	8.2	13.9	6.9	102.2	3,209,275.0	1,663.9	1.1	0.7
10/31/2020 02:00	9.1	13.8	7.6	119.0	3,114,596.3	1,660.3	1.3	0.8
10/31/2020 03:00	10.6	13.4	8.3	168.5	3,310,462.6	2,054.8	1.7	1.4
10/31/2020 04:00	10.0	13.5	8.0	151.2	3,300,483.9	1,928.1	1.6	1.2
10/31/2020 05:00	7.7	13.9	6.5	101.1	3,265,595.0	1,693.1	1.0	0.7
10/31/2020 06:00	8.3	13.9	7.0	103.7	3,266,945.1	1,693.8	1.1	0.7
10/31/2020 07:00	8.3	13.9	7.0	101.7	3,186,129.8	1,651.9	1.1	0.7
10/31/2020 08:00	8.5	13.9	7.2	95.7	2,955,256.4	1,532.2	1.1	0.6
10/31/2020 09:00	8.5	13.9	7.2	93.9	2,952,283.3	1,509.1	1.1	0.6
10/31/2020 10:00	8.4	13.9	7.1	101.0	3,207,387.5	1,639.5	1.0	0.7
10/31/2020 11:00	8.4	13.9	7.1	96.3	3,048,925.6	1,558.5	1.0	0.6
10/31/2020 12:00	8.4	14.0	7.2	96.7	3,045,012.9	1,556.5	1.1	0.6
10/31/2020 13:00	8.6	14.0	7.4	97.0	3,069,075.7	1,568.8	1.0	0.6
10/31/2020 14:00	9.2	13.9	7.8	101.3	3,138,720.7	1,604.4	1.1	0.6
10/31/2020 15:00	9.6	13.9	8.1	106.8	3,248,621.8	1,684.3	1.1	0.7
10/31/2020 16:00	10.0	13.6	8.1	114.1	3,278,690.3	1,819.6	1.2	0.9
10/31/2020 17:00	10.7	13.4	8.4	124.1	3,276,836.9	2,010.0	1.3	1.0
10/31/2020 18:00	10.5	13.4	8.3	126.4	3,278,724.2	2,035.1	1.3	1.0
10/31/2020 19:00	8.4	13.8	7.0	105.2	3,276,203.2	1,698.6	1.1	0.7
10/31/2020 20:00	9.6	13.6	7.8	113.5	3,288,420.4	1,825.0	1.2	0.9
10/31/2020 21:00	10.5	13.4	8.3	128.6	3,330,440.1	2,067.2	1.3	1.0
10/31/2020 22:00	10.4	13.4	8.2	126.9	3,332,918.1	2,044.4	1.3	1.0
10/31/2020 23:00	10.5	13.4	8.3	162.0	3,313,354.9	2,032.4	1.7	1.4
Average/Sum#:	9.2	13.7	7.6	114.4	3,198,517.2	1,754.2	1.2	0.8
Minimum:	7.7	13.4	6.5	93.9	2,952,283.3	1,509.1	1.0	0.6
Maximum:	10.7	14.0	8.4	168.5	3,332,918.1	2,067.2	1.7	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/01/2020 00:00	10.3	13.4	8.1	126.5	3,310,909.5	2,030.9	1.3	1.0
11/01/2020 01:00	10.1	13.4	7.9	124.8	3,280,097.5	2,012.0	1.3	1.0
11/01/2020 02:00	7.7	13.9	6.5	101.5	3,242,449.8	1,681.1	1.1	0.7
11/01/2020 03:00	7.9	13.9	6.7	102.4	3,312,246.3	1,693.1	1.0	0.7
11/01/2020 04:00	9.5	13.7	7.8	113.1	3,301,213.7	1,832.1	1.1	0.7
11/01/2020 05:00	10.3	13.4	8.1	160.4	3,290,280.9	2,066.3	1.7	1.4
11/01/2020 06:00	10.5	13.4	8.3	158.7	3,314,333.1	2,033.0	1.6	1.2
11/01/2020 07:00	8.1	13.9	6.8	98.3	3,029,166.7	1,548.4	1.1	0.6
11/01/2020 08:00	8.1	13.9	6.8	102.7	3,316,745.9	1,695.4	1.0	0.7
11/01/2020 09:00	8.3	13.9	7.0	92.8	2,945,045.0	1,505.4	1.0	0.6
11/01/2020 10:00	8.3	13.9	7.0	97.6	3,084,530.6	1,576.7	1.1	0.6
11/01/2020 11:00	8.4	14.0	7.2	93.0	2,922,742.9	1,494.0	1.1	0.6
11/01/2020 12:00	8.3	14.0	7.1	96.9	3,088,247.6	1,578.6	1.0	0.6
11/01/2020 13:00	8.9	13.9	7.5	122.5	3,259,034.4	1,665.9	1.3	0.8
11/01/2020 14:00	9.3	13.9	7.8	120.6	3,242,642.6	1,681.2	1.2	0.8
11/01/2020 15:00	9.8	13.8	8.1	130.6	3,148,175.3	1,678.2	1.4	0.8
11/01/2020 16:00	10.6	13.3	8.2	166.3	3,286,779.6	2,040.1	1.7	1.4
11/01/2020 17:00	10.6	13.3	8.2	189.2	3,278,097.7	2,154.4	2.0	1.7
11/01/2020 18:00	10.4	13.3	8.1	197.1	3,268,012.2	2,195.5	2.1	1.8
11/01/2020 19:00	10.3	13.3	8.0	186.5	3,283,118.9	2,157.7	2.0	1.7
11/01/2020 20:00	10.3	13.3	8.0	183.4	3,259,534.4	2,142.2	2.0	1.7
11/01/2020 21:00	10.2	13.3	7.9	197.0	3,251,278.5	2,208.0	2.1	1.8
11/01/2020 22:00	10.1	13.3	7.8	171.8	3,311,016.3	2,103.5	1.8	1.5
11/01/2020 23:00	10.1	13.3	7.8	170.0	3,352,701.2	2,105.5	1.8	1.5
Average/Sum#:	9.4	13.6	7.6	137.7	3,224,100.0	1,870.0	1.5	1.1
Minimum:	7.7	13.3	6.5	92.8	2,922,742.9	1,494.0	1.0	0.6
Maximum:	10.6	14.0	8.3	197.1	3,352,701.2	2,208.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/02/2020 00:00	10.2	13.4	8.0	184.8	3,304,203.2	2,123.3	1.9	1.5
11/02/2020 01:00	10.0	13.4	7.9	171.7	3,242,988.0	2,036.6	1.8	1.4
11/02/2020 02:00	7.8	13.9	6.6	107.0	3,237,514.9	1,654.9	1.1	0.7
11/02/2020 03:00	9.5	13.7	7.8	135.9	3,267,879.0	1,813.6	1.4	0.9
11/02/2020 04:00	10.0	13.4	7.9	176.4	3,299,845.9	2,120.5	1.9	1.5
11/02/2020 05:00	10.0	13.4	7.9	176.2	3,305,544.3	2,148.3	1.9	1.5
11/02/2020 06:00	10.4	13.4	8.2	180.3	3,257,673.9	2,093.4	1.9	1.5
11/02/2020 07:00	7.9	13.9	6.7	101.1	3,201,127.3	1,636.3	1.1	0.7
11/02/2020 08:00	8.0	13.9	6.7	101.3	3,264,120.8	1,668.5	1.0	0.7
11/02/2020 09:00	8.2	13.9	6.9	103.0	3,311,268.2	1,692.6	1.0	0.7
11/02/2020 10:00	8.2	13.9	6.9	101.5	3,242,210.0	1,657.3	1.0	0.7
11/02/2020 11:00	8.5	14.0	7.3	104.7	3,257,273.7	1,665.0	1.1	0.7
11/02/2020 12:00	9.6	13.9	8.1	144.6	3,263,859.1	1,692.2	1.5	1.0
11/02/2020 13:00	10.2	13.8	8.5	134.9	3,231,651.3	1,699.1	1.4	0.8
11/02/2020 14:00	10.3	13.7	8.4	140.4	3,240,470.8	1,727.4	1.5	1.0
11/02/2020 15:00	10.6	13.3	8.2	167.1	3,281,045.3	2,060.5	1.8	1.4
11/02/2020 16:00	10.5	13.3	8.2	198.6	3,208,386.5	2,202.3	2.2	1.8
11/02/2020 17:00	10.3	13.3	8.0	192.5	3,239,135.2	2,176.1	2.1	1.7
11/02/2020 18:00	10.2	13.3	7.9	195.8	3,242,149.0	2,201.8	2.1	1.8
11/02/2020 19:00	10.1	13.2	7.7	201.9	3,230,967.4	2,217.8	2.2	1.8
11/02/2020 20:00	10.2	13.3	7.9	200.6	3,249,069.8	2,206.5	2.2	1.8
11/02/2020 21:00	10.0	13.3	7.8	183.6	3,263,946.9	2,145.1	2.0	1.7
11/02/2020 22:00	10.0	13.3	7.8	177.1	3,270,154.7	2,125.3	1.9	1.5
11/02/2020 23:00	10.1	13.4	7.9	165.5	3,312,395.9	2,056.0	1.7	1.4
Average/Sum#:	9.6	13.6	7.7	156.1	3,259,370.0	1,950.9	1.7	1.3
Minimum:	7.8	13.2	6.6	101.1	3,201,127.3	1,636.3	1.0	0.7
Maximum:	10.6	14.0	8.5	201.9	3,312,395.9	2,217.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/03/2020 00:00	10.3	13.4	8.1	180.5	3,263,742.9	2,097.3	1.9	1.5
11/03/2020 01:00	10.0	13.5	8.0	163.4	3,219,125.5	1,974.6	1.7	1.4
11/03/2020 02:00	7.7	13.9	6.5	103.5	3,269,645.4	1,695.2	1.1	0.7
11/03/2020 03:00	8.9	13.7	7.3	128.6	3,296,348.6	1,829.4	1.3	0.9
11/03/2020 04:00	10.5	13.4	8.3	182.9	3,277,232.6	2,129.9	1.9	1.5
11/03/2020 05:00	10.3	13.4	8.1	181.6	3,273,989.4	2,151.7	1.9	1.5
11/03/2020 06:00	10.8	13.4	8.5	194.7	3,234,074.3	2,172.7	2.1	1.7
11/03/2020 07:00	9.6	13.5	7.7	167.6	3,257,796.9	2,045.9	1.8	1.4
11/03/2020 08:00	7.7	13.9	6.5	101.5	3,210,432.2	1,664.5	1.1	0.7
11/03/2020 09:00	7.9	13.9	6.7	102.3	3,292,487.5	1,683.0	1.0	0.7
11/03/2020 10:00	8.2	13.9	6.9	103.1	3,299,139.0	1,686.4	1.0	0.7
11/03/2020 11:00	8.3	13.9	7.0	95.2	3,005,299.6	1,536.2	1.1	0.6
11/03/2020 12:00	8.3	13.9	7.0	95.2	3,003,930.2	1,535.5	1.1	0.6
11/03/2020 13:00	8.6	13.9	7.2	99.7	3,140,090.1	1,605.1	1.1	0.6
11/03/2020 14:00	8.7	13.9	7.3	109.6	3,279,184.5	1,676.2	1.1	0.7
11/03/2020 15:00	9.8	13.6	7.9	143.7	3,266,437.5	1,812.8	1.5	1.1
11/03/2020 16:00	10.5	13.3	8.2	183.1	3,273,837.2	2,151.6	1.9	1.5
11/03/2020 17:00	10.3	13.3	8.0	190.9	3,258,485.8	2,189.1	2.0	1.8
11/03/2020 18:00	10.2	13.3	7.9	194.8	3,241,854.5	2,201.6	2.1	1.8
11/03/2020 19:00	10.1	13.3	7.8	195.1	3,254,812.5	2,210.4	2.1	1.8
11/03/2020 20:00	10.2	13.3	7.9	190.0	3,268,861.2	2,172.2	2.0	1.7
11/03/2020 21:00	10.2	13.3	7.9	186.6	3,279,619.2	2,155.4	2.0	1.7
11/03/2020 22:00	10.1	13.3	7.8	177.6	3,306,537.4	2,124.8	1.9	1.5
11/03/2020 23:00	9.9	13.4	7.8	158.6	3,355,741.8	2,058.4	1.6	1.2
Average/Sum#:	9.5	13.6	7.6	151.2	3,242,862.7	1,940.0	1.6	1.2
Minimum:	7.7	13.3	6.5	95.2	3,003,930.2	1,535.5	1.0	0.6
Maximum:	10.8	13.9	8.5	195.1	3,355,741.8	2,210.4	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/04/2020 00:00	10.0	13.4	7.9	167.9	3,329,956.8	2,066.9	1.7	1.4
11/04/2020 01:00	10.2	13.5	8.1	157.2	3,271,909.9	1,935.3	1.6	1.2
11/04/2020 02:00	7.8	13.9	6.6	106.5	3,269,259.6	1,695.0	1.1	0.7
11/04/2020 03:00	9.1	13.7	7.5	135.3	3,288,961.0	1,825.3	1.4	0.9
11/04/2020 04:00	10.4	13.4	8.2	178.3	3,315,266.2	2,106.2	1.9	1.5
11/04/2020 05:00	10.1	13.4	7.9	170.8	3,316,930.5	2,155.7	1.8	1.5
11/04/2020 06:00	10.4	13.3	8.1	180.8	3,346,627.0	2,175.0	1.9	1.5
11/04/2020 07:00	9.6	13.5	7.7	156.8	3,289,035.2	2,041.5	1.6	1.2
11/04/2020 08:00	7.8	13.9	6.6	103.5	3,272,538.5	1,696.7	1.1	0.7
11/04/2020 09:00	8.1	13.9	6.8	101.2	3,219,321.1	1,645.6	1.0	0.7
11/04/2020 10:00	8.3	13.9	7.0	95.7	3,022,710.9	1,545.1	1.1	0.6
11/04/2020 11:00	8.4	13.9	7.1	102.9	3,271,554.9	1,672.3	1.0	0.7
11/04/2020 12:00	8.6	13.9	7.2	107.0	3,315,376.4	1,694.7	1.1	0.7
11/04/2020 13:00	8.8	13.9	7.4	110.7	3,324,375.5	1,699.3	1.1	0.7
11/04/2020 14:00	9.3	13.8	7.7	137.5	3,305,067.7	1,737.7	1.4	0.9
11/04/2020 15:00	10.7	13.4	8.4	162.4	3,299,023.9	2,047.7	1.7	1.4
11/04/2020 16:00	10.5	13.3	8.2	184.2	3,267,294.4	2,147.3	2.0	1.7
11/04/2020 17:00	10.3	13.3	8.0	193.0	3,248,363.9	2,182.3	2.1	1.7
11/04/2020 18:00	10.2	13.3	7.9	208.2	3,257,336.1	2,235.9	2.2	1.8
11/04/2020 19:00	10.1	13.3	7.8	200.3	3,269,979.3	2,220.7	2.1	1.8
11/04/2020 20:00	10.1	13.3	7.8	190.8	3,249,554.8	2,183.1	2.1	1.7
11/04/2020 21:00	10.2	13.3	7.9	188.4	3,268,560.2	2,172.0	2.0	1.7
11/04/2020 22:00	10.1	13.3	7.8	186.7	3,265,249.5	2,169.8	2.0	1.7
11/04/2020 23:00	10.0	13.3	7.8	176.7	3,320,231.7	2,133.6	1.8	1.5
Average/Sum#:	9.5	13.5	7.6	154.3	3,275,186.9	1,966.0	1.6	1.2
Minimum:	7.8	13.3	6.6	95.7	3,022,710.9	1,545.1	1.0	0.6
Maximum:	10.7	13.9	8.4	208.2	3,346,627.0	2,235.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/05/2020 00:00	10.0	13.4	7.9	187.1	3,259,691.6	2,118.5	2.0	1.7
11/05/2020 01:00	9.9	13.4	7.8	176.6	3,223,341.7	2,047.8	1.9	1.4
11/05/2020 02:00	7.8	13.9	6.6	102.5	3,222,842.5	1,647.4	1.1	0.7
11/05/2020 03:00	9.5	13.7	7.8	140.1	3,248,203.5	1,826.4	1.5	1.1
11/05/2020 04:00	10.3	13.4	8.1	176.6	3,304,090.5	2,099.1	1.8	1.5
11/05/2020 05:00	10.2	13.4	8.0	178.7	3,255,121.8	2,139.3	1.9	1.5
11/05/2020 06:00	10.5	13.4	8.3	170.7	3,299,067.8	2,120.0	1.8	1.5
11/05/2020 07:00	9.9	13.5	7.9	163.3	3,304,437.5	2,002.8	1.7	1.4
11/05/2020 08:00	7.9	13.9	6.7	100.2	3,088,341.3	1,601.2	1.1	0.6
11/05/2020 09:00	8.1	13.9	6.8	102.6	3,247,271.7	1,683.6	1.1	0.7
11/05/2020 10:00	8.3	13.9	7.0	98.0	3,114,657.9	1,592.1	1.0	0.6
11/05/2020 11:00	8.5	13.9	7.2	99.5	3,102,528.8	1,585.9	1.1	0.6
11/05/2020 12:00	9.0	13.9	7.6	117.0	3,241,871.1	1,680.8	1.2	0.8
11/05/2020 13:00	9.1	13.9	7.7	121.5	3,037,421.9	1,574.8	1.3	0.8
11/05/2020 14:00	10.5	13.6	8.5	142.7	3,214,495.5	1,760.5	1.5	1.1
11/05/2020 15:00	10.7	13.3	8.3	189.4	3,212,491.0	2,158.2	2.0	1.7
11/05/2020 16:00	10.4	13.3	8.1	170.7	3,216,902.4	2,067.2	1.8	1.4
11/05/2020 17:00	10.4	13.3	8.1	188.8	3,235,754.2	2,150.2	2.0	1.7
11/05/2020 18:00	10.3	13.3	8.0	189.6	3,210,109.4	2,156.6	2.1	1.7
11/05/2020 19:00	10.2	13.3	7.9	170.7	3,241,801.0	2,083.2	1.8	1.5
11/05/2020 20:00	10.3	13.2	7.9	195.0	3,226,393.3	2,191.1	2.1	1.8
11/05/2020 21:00	10.2	13.2	7.8	198.8	3,232,424.3	2,218.8	2.2	1.8
11/05/2020 22:00	10.1	13.3	7.8	177.9	3,245,843.5	2,109.5	1.9	1.5
11/05/2020 23:00	10.3	13.3	8.0	179.0	3,254,152.4	2,114.9	1.9	1.5
Average/Sum#:	9.7	13.5	7.7	155.7	3,218,302.4	1,947.1	1.7	1.3
Minimum:	7.8	13.2	6.6	98.0	3,037,421.9	1,574.8	1.0	0.6
Maximum:	10.7	13.9	8.5	198.8	3,304,437.5	2,218.8	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/06/2020 00:00	10.3	13.3	8.0	176.8	3,234,149.6	2,101.9	1.9	1.5
11/06/2020 01:00	10.0	13.4	7.9	149.2	3,259,737.2	1,928.1	1.6	1.2
11/06/2020 02:00	8.3	13.8	6.9	105.4	3,184,586.8	1,651.1	1.1	0.7
11/06/2020 03:00	8.6	13.8	7.1	101.3	3,107,243.2	1,611.0	1.1	0.6
11/06/2020 04:00	9.6	13.6	7.8	136.2	3,251,760.4	1,828.4	1.4	0.9
11/06/2020 05:00	10.5	13.3	8.2	163.2	3,242,949.1	2,131.3	1.7	1.5
11/06/2020 06:00	10.7	13.4	8.4	159.5	3,293,868.4	2,044.5	1.7	1.4
11/06/2020 07:00	10.4	13.4	8.2	183.8	3,230,456.7	2,099.5	2.0	1.7
11/06/2020 08:00	8.1	14.0	6.9	93.0	2,795,190.8	1,428.8	1.1	0.6
11/06/2020 09:00	8.5	14.0	7.3	86.6	2,635,555.0	1,347.2	1.1	0.5
11/06/2020 10:00	8.7	14.0	7.4	85.7	2,579,213.0	1,318.4	1.1	0.5
11/06/2020 11:00	8.8	14.0	7.5	85.6	2,542,042.9	1,299.4	1.1	0.5
11/06/2020 12:00	8.5	13.9	7.2	89.5	2,804,581.1	1,433.6	1.1	0.6
11/06/2020 13:00	8.5	13.9	7.2	88.4	2,762,715.9	1,412.2	1.1	0.6
11/06/2020 14:00	8.7	14.0	7.4	85.7	2,607,188.4	1,332.7	1.1	0.5
11/06/2020 15:00	10.1	13.6	8.2	150.0	3,259,230.0	1,832.6	1.6	1.1
11/06/2020 16:00	10.6	13.3	8.2	184.3	3,259,230.0	2,142.0	2.0	1.7
11/06/2020 17:00	10.5	13.3	8.2	191.4	3,239,666.8	2,152.8	2.1	1.7
11/06/2020 18:00	10.3	13.3	8.0	192.5	3,253,812.5	2,162.2	2.1	1.7
11/06/2020 19:00	9.9	13.4	7.8	157.4	3,279,771.4	2,011.8	1.6	1.2
11/06/2020 20:00	9.4	13.5	7.5	142.8	3,275,967.4	1,937.7	1.5	1.2
11/06/2020 21:00	8.1	13.9	6.8	96.5	2,960,271.2	1,534.8	1.1	0.6
11/06/2020 22:00	8.9	13.7	7.3	121.0	3,285,117.8	1,751.2	1.2	0.9
11/06/2020 23:00	10.2	13.4	8.0	155.3	3,297,507.9	1,998.6	1.6	1.2
Average/Sum#:	9.4	13.6	7.6	132.5	3,068,408.9	1,770.5	1.5	1.0
Minimum:	8.1	13.3	6.8	85.6	2,542,042.9	1,299.4	1.1	0.5
Maximum:	10.7	14.0	8.4	192.5	3,297,507.9	2,162.2	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/07/2020 00:00	10.0	13.5	8.0	148.1	3,319,900.7	1,915.2	1.5	1.1
11/07/2020 01:00	7.9	13.9	6.7	104.7	3,259,808.7	1,690.1	1.1	0.7
11/07/2020 02:00	8.8	13.7	7.2	116.9	3,235,218.2	1,724.6	1.2	0.9
11/07/2020 03:00	10.1	13.5	8.1	144.1	3,348,676.0	1,931.8	1.5	1.2
11/07/2020 04:00	10.0	13.5	8.0	146.0	3,336,195.2	1,924.6	1.5	1.2
11/07/2020 05:00	7.9	13.9	6.7	121.8	3,173,207.0	1,645.2	1.3	0.8
11/07/2020 06:00	8.4	13.9	7.1	101.4	3,112,450.9	1,613.7	1.1	0.6
11/07/2020 07:00	8.4	13.9	7.1	99.7	3,078,890.3	1,596.3	1.1	0.6
11/07/2020 08:00	8.4	13.9	7.1	102.5	3,200,981.3	1,659.6	1.0	0.7
11/07/2020 09:00	8.3	13.9	7.0	97.0	3,005,018.6	1,558.0	1.1	0.6
11/07/2020 10:00	8.6	13.9	7.2	89.9	2,767,411.0	1,414.6	1.1	0.6
11/07/2020 11:00	8.6	13.9	7.2	88.9	2,702,009.3	1,400.9	1.1	0.6
11/07/2020 12:00	8.3	13.9	7.0	98.2	3,051,887.6	1,582.3	1.1	0.6
11/07/2020 13:00	8.5	13.9	7.2	93.5	2,872,319.4	1,489.2	1.1	0.6
11/07/2020 14:00	8.5	13.9	7.2	93.3	2,855,924.9	1,480.7	1.1	0.6
11/07/2020 15:00	8.8	13.9	7.4	97.2	3,000,582.4	1,555.7	1.1	0.6
11/07/2020 16:00	10.6	13.3	8.2	128.4	3,287,096.2	2,064.3	1.3	1.0
11/07/2020 17:00	10.4	13.3	8.1	136.9	3,251,622.1	2,137.0	1.4	1.1
11/07/2020 18:00	10.2	13.4	8.0	130.4	3,219,859.1	2,069.1	1.3	1.0
11/07/2020 19:00	9.9	13.4	7.8	127.5	3,269,739.6	2,053.4	1.3	1.0
11/07/2020 20:00	10.0	13.4	7.9	120.8	3,232,171.5	1,959.0	1.2	1.0
11/07/2020 21:00	7.9	13.9	6.7	104.9	1,035,651.8	1,580.6	3.7	2.2
11/07/2020 22:00	9.8	13.6	7.9	126.2	3,089,996.2	1,827.7	1.4	0.9
11/07/2020 23:00	10.5	13.3	8.2	174.7	3,216,321.4	2,113.8	1.9	1.5
Average/Sum#:	9.1	13.7	7.5	116.4	3,125,534.2	1,749.5	1.3	0.8
Minimum:	7.9	13.3	6.7	88.9	2,702,009.3	1,400.9	1.0	0.6
Maximum:	10.6	13.9	8.2	174.7	3,348,676.0	2,137.0	1.9	1.5
%SI	0.00	0.00	0.00	0.00	4.17	0.00	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/08/2020 00:00	10.0	13.5	8.0	148.7	3,223,201.1	1,977.1	1.6	1.2
11/08/2020 01:00	7.9	13.9	6.7	98.1	3,002,272.8	1,578.5	1.1	0.6
11/08/2020 02:00	8.8	13.9	7.4	99.7	2,970,699.9	1,561.9	1.1	0.6
11/08/2020 03:00	10.2	13.5	8.1	130.4	3,305,276.9	1,930.9	1.3	1.0
11/08/2020 04:00	10.0	13.5	8.0	132.9	3,282,681.4	1,917.7	1.4	1.0
11/08/2020 05:00	7.9	13.9	6.7	110.3	3,212,631.6	1,689.1	1.2	0.8
11/08/2020 06:00	8.3	13.9	7.0	103.5	3,149,295.7	1,655.8	1.1	0.7
11/08/2020 07:00	8.4	13.9	7.1	98.8	3,003,984.5	1,579.4	1.1	0.6
11/08/2020 08:00	8.2	13.9	6.9	102.5	3,164,701.7	1,663.9	1.1	0.7
11/08/2020 09:00	8.2	13.9	6.9	101.9	3,159,186.0	1,661.0	1.1	0.7
11/08/2020 10:00	8.1	13.9	6.8	103.6	3,281,603.7	1,701.4	1.1	0.7
11/08/2020 11:00	8.3	13.9	7.0	96.4	2,993,831.7	1,552.2	1.1	0.6
11/08/2020 12:00	8.5	14.0	7.3	91.1	2,785,910.7	1,444.4	1.1	0.6
11/08/2020 13:00	8.2	13.9	6.9	101.9	3,209,467.9	1,664.0	1.1	0.7
11/08/2020 14:00	8.1	13.9	6.8	102.1	3,221,812.0	1,670.4	1.1	0.7
11/08/2020 15:00	8.1	13.9	6.8	103.2	3,268,295.2	1,694.5	1.1	0.7
11/08/2020 16:00	9.9	13.7	8.1	127.0	3,253,436.3	1,853.1	1.3	0.9
11/08/2020 17:00	10.6	13.4	8.3	184.0	3,267,714.5	2,195.3	2.0	1.8
11/08/2020 18:00	10.0	13.4	7.9	162.3	3,265,610.3	2,098.5	1.7	1.5
11/08/2020 19:00	9.6	13.5	7.7	158.5	3,240,498.8	2,058.7	1.7	1.4
11/08/2020 20:00	7.7	13.9	6.5	104.1	3,171,929.2	1,667.7	1.1	0.7
11/08/2020 21:00	8.0	13.9	6.7	100.1	3,033,084.8	1,594.7	1.1	0.6
11/08/2020 22:00	9.0	13.7	7.4	119.6	3,281,573.3	1,821.2	1.2	0.9
11/08/2020 23:00	10.2	13.4	8.0	160.9	3,297,356.1	2,118.9	1.7	1.5
Average/Sum#:	8.8	13.8	7.3	118.4	3,168,585.7	1,764.6	1.3	0.9
Minimum:	7.7	13.4	6.5	91.1	2,785,910.7	1,444.4	1.1	0.6
Maximum:	10.6	14.0	8.3	184.0	3,305,276.9	2,195.3	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/09/2020 00:00	8.8	13.6	7.1	124.9	3,282,053.8	1,941.3	1.3	1.0
11/09/2020 01:00	7.9	13.9	6.7	95.7	2,918,395.5	1,534.4	1.1	0.6
11/09/2020 02:00	8.7	14.0	7.4	86.9	2,517,040.6	1,305.0	1.1	0.5
11/09/2020 03:00	8.6	14.0	7.4	86.6	2,548,672.4	1,321.4	1.1	0.5
11/09/2020 04:00	9.3	13.7	7.6	115.7	3,141,495.1	1,766.4	1.2	0.9
11/09/2020 05:00	10.3	13.4	8.1	161.5	3,279,094.2	2,179.0	1.7	1.5
11/09/2020 06:00	10.4	13.3	8.1	187.6	3,312,841.5	2,274.0	2.0	1.8
11/09/2020 07:00	9.9	13.4	7.8	151.2	3,332,956.0	2,093.1	1.6	1.3
11/09/2020 08:00	9.4	13.6	7.6	129.7	3,334,377.2	1,947.9	1.3	1.0
11/09/2020 09:00	7.9	13.9	6.7	95.3	2,942,526.5	1,525.6	1.1	0.6
11/09/2020 10:00	8.1	13.9	6.8	95.6	2,992,867.3	1,551.7	1.1	0.6
11/09/2020 11:00	8.1	14.0	6.9	89.3	2,792,854.2	1,448.0	1.1	0.6
11/09/2020 12:00	8.1	13.9	6.8	91.1	2,853,224.6	1,479.3	1.1	0.6
11/09/2020 13:00	8.4	14.0	7.2	89.0	2,737,691.5	1,419.4	1.1	0.6
11/09/2020 14:00	8.1	13.9	6.8	100.2	3,134,438.8	1,625.1	1.1	0.7
11/09/2020 15:00	9.4	13.7	7.7	121.7	3,271,482.8	1,815.6	1.2	0.9
11/09/2020 16:00	10.5	13.4	8.3	154.8	3,301,762.7	2,049.4	1.6	1.2
11/09/2020 17:00	10.2	13.4	8.0	159.5	3,306,045.2	2,076.2	1.7	1.5
11/09/2020 18:00	10.0	13.4	7.9	168.0	3,303,736.3	2,123.0	1.8	1.5
11/09/2020 19:00	9.8	13.4	7.7	167.2	3,310,894.7	2,127.6	1.7	1.5
11/09/2020 20:00	9.8	13.4	7.7	193.0	3,303,846.8	2,243.7	2.0	1.8
11/09/2020 21:00	9.7	13.4	7.6	176.0	3,277,240.9	2,201.7	1.9	1.5
11/09/2020 22:00	9.6	13.4	7.6	151.9	3,312,573.9	2,080.3	1.6	1.2
11/09/2020 23:00	9.6	13.5	7.7	143.1	3,365,649.2	2,039.9	1.4	1.0
Average/Sum#:	9.2	13.6	7.5	130.6	3,119,740.1	1,840.4	1.4	1.0
Minimum:	7.9	13.3	6.7	86.6	2,517,040.6	1,305.0	1.1	0.5
Maximum:	10.5	14.0	8.3	193.0	3,365,649.2	2,274.0	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/10/2020 00:00	9.6	13.4	7.6	141.4	3,377,693.5	2,047.2	1.4	1.0
11/10/2020 01:00	9.0	13.6	7.3	129.5	3,333,179.0	1,947.2	1.3	1.0
11/10/2020 02:00	7.7	13.9	6.5	102.6	3,209,208.0	1,687.3	1.1	0.7
11/10/2020 03:00	8.4	13.7	6.9	113.1	3,327,701.3	1,822.5	1.1	0.7
11/10/2020 04:00	9.9	13.4	7.8	138.2	3,373,293.1	2,019.9	1.4	1.0
11/10/2020 05:00	9.9	13.4	7.8	150.8	3,360,864.4	2,037.0	1.5	1.2
11/10/2020 06:00	10.1	13.5	8.1	140.4	3,382,313.2	2,050.0	1.4	1.0
11/10/2020 07:00	9.8	13.5	7.8	134.5	3,411,895.5	2,018.1	1.3	1.0
11/10/2020 08:00	8.4	13.6	6.8	117.9	3,385,598.4	1,953.1	1.2	1.0
11/10/2020 09:00	7.8	13.9	6.6	101.1	3,149,485.9	1,655.9	1.1	0.7
11/10/2020 10:00	8.0	13.9	6.7	101.5	3,165,842.9	1,664.5	1.1	0.7
11/10/2020 11:00	8.4	14.0	7.2	87.4	2,686,386.3	1,392.8	1.1	0.6
11/10/2020 12:00	8.4	13.9	7.1	93.7	2,914,366.5	1,511.0	1.1	0.6
11/10/2020 13:00	8.3	13.9	7.0	94.9	2,951,784.6	1,530.4	1.1	0.6
11/10/2020 14:00	8.5	13.9	7.2	88.6	2,723,804.4	1,412.2	1.1	0.6
11/10/2020 15:00	9.2	13.8	7.6	106.9	3,085,276.1	1,667.2	1.1	0.7
11/10/2020 16:00	10.5	13.5	8.4	145.9	3,284,662.2	2,014.8	1.5	1.2
11/10/2020 17:00	10.2	13.4	8.0	163.7	3,287,552.2	2,112.6	1.7	1.5
11/10/2020 18:00	10.1	13.3	7.8	194.4	3,254,568.2	2,234.0	2.1	1.8
11/10/2020 19:00	10.1	13.3	7.8	190.3	3,237,668.9	2,222.4	2.1	1.8
11/10/2020 20:00	9.9	13.4	7.8	168.1	3,272,163.5	2,150.5	1.8	1.5
11/10/2020 21:00	9.7	13.4	7.6	162.1	3,275,693.9	2,128.9	1.7	1.5
11/10/2020 22:00	9.8	13.4	7.7	152.5	3,311,936.9	2,079.9	1.6	1.2
11/10/2020 23:00	9.7	13.4	7.6	147.9	3,321,095.8	2,061.4	1.5	1.2
Average/Sum#:	9.2	13.6	7.4	132.0	3,211,834.8	1,892.5	1.4	1.0
Minimum:	7.7	13.3	6.5	87.4	2,686,386.3	1,392.8	1.1	0.6
Maximum:	10.5	14.0	8.4	194.4	3,411,895.5	2,234.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/11/2020 00:00	9.8	13.4	7.7	145.5	3,319,645.8	2,060.5	1.5	1.2
11/11/2020 01:00	8.8	13.6	7.1	121.8	3,322,565.9	1,941.0	1.2	1.0
11/11/2020 02:00	7.9	13.9	6.7	98.0	3,025,476.9	1,590.7	1.1	0.6
11/11/2020 03:00	8.7	13.7	7.1	113.8	3,327,881.4	1,846.9	1.1	0.7
11/11/2020 04:00	9.9	13.4	7.8	139.7	3,356,409.7	2,034.3	1.4	1.0
11/11/2020 05:00	10.0	13.4	7.9	154.9	3,300,631.2	2,072.8	1.6	1.2
11/11/2020 06:00	10.2	13.4	8.0	160.2	3,303,812.4	2,171.3	1.7	1.5
11/11/2020 07:00	9.2	13.5	7.3	132.6	3,334,214.4	1,996.5	1.4	1.0
11/11/2020 08:00	7.8	13.9	6.6	103.5	3,203,692.3	1,684.4	1.1	0.7
11/11/2020 09:00	8.0	13.9	6.7	102.9	3,200,458.9	1,682.7	1.1	0.7
11/11/2020 10:00	8.1	13.9	6.8	101.9	3,145,681.9	1,653.9	1.1	0.7
11/11/2020 11:00	8.3	13.9	7.0	97.7	2,988,007.9	1,571.0	1.1	0.6
11/11/2020 12:00	8.2	13.9	6.9	102.2	3,153,099.6	1,657.8	1.1	0.7
11/11/2020 13:00	8.3	13.9	7.0	95.3	2,947,155.6	1,528.0	1.1	0.6
11/11/2020 14:00	8.2	13.9	6.9	103.6	3,211,870.8	1,688.7	1.1	0.7
11/11/2020 15:00	8.5	14.0	7.3	87.4	2,672,884.9	1,385.8	1.1	0.6
11/11/2020 16:00	10.2	13.6	8.2	129.1	3,241,028.8	1,869.7	1.3	0.9
11/11/2020 17:00	10.4	13.4	8.2	149.3	3,270,507.6	2,030.0	1.6	1.2
11/11/2020 18:00	10.2	13.4	8.0	158.5	3,255,339.6	2,091.9	1.7	1.5
11/11/2020 19:00	10.0	13.4	7.9	153.2	3,289,962.5	2,066.1	1.6	1.2
11/11/2020 20:00	9.7	13.5	7.7	142.6	3,289,226.9	2,017.6	1.5	1.2
11/11/2020 21:00	7.7	13.9	6.5	102.7	3,167,744.9	1,665.5	1.1	0.7
11/11/2020 22:00	9.1	13.7	7.5	118.0	3,297,069.4	1,829.8	1.2	0.9
11/11/2020 23:00	10.0	13.4	7.9	140.7	3,357,234.6	2,034.8	1.4	1.0
Average/Sum#:	9.1	13.7	7.4	123.1	3,207,566.8	1,840.5	1.3	0.9
Minimum:	7.7	13.4	6.5	87.4	2,672,884.9	1,385.8	1.1	0.6
Maximum:	10.4	14.0	8.2	160.2	3,357,234.6	2,171.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/12/2020 00:00	10.0	13.4	7.9	145.0	3,335,363.5	2,045.9	1.5	1.2
11/12/2020 01:00	8.5	13.6	6.9	114.6	3,370,539.7	1,919.8	1.1	0.8
11/12/2020 02:00	8.0	13.9	6.7	97.1	2,987,817.7	1,570.9	1.1	0.6
11/12/2020 03:00	8.6	13.7	7.0	105.3	3,143,939.3	1,698.9	1.1	0.7
11/12/2020 04:00	10.0	13.4	7.9	136.1	3,373,733.7	2,044.8	1.4	1.0
11/12/2020 05:00	9.9	13.4	7.8	150.8	3,276,387.2	2,081.5	1.6	1.2
11/12/2020 06:00	10.2	13.3	7.9	170.1	3,308,264.3	2,246.7	1.8	1.6
11/12/2020 07:00	9.5	13.4	7.5	150.1	3,315,581.1	2,106.4	1.6	1.3
11/12/2020 08:00	7.8	13.9	6.6	100.5	3,100,414.8	1,630.1	1.1	0.7
11/12/2020 09:00	8.0	13.9	6.7	101.0	3,116,581.7	1,638.6	1.1	0.7
11/12/2020 10:00	8.1	13.9	6.8	103.0	3,191,900.0	1,678.2	1.1	0.7
11/12/2020 11:00	8.2	13.9	6.9	99.7	3,060,663.5	1,609.2	1.1	0.6
11/12/2020 12:00	8.1	13.9	6.8	104.1	3,228,418.0	1,697.4	1.1	0.7
11/12/2020 13:00	8.2	13.9	6.9	97.8	3,043,015.3	1,577.7	1.1	0.6
11/12/2020 14:00	8.3	13.9	7.0	97.4	3,024,692.0	1,568.2	1.1	0.6
11/12/2020 15:00	9.1	13.8	7.6	108.3	3,130,985.3	1,691.9	1.1	0.7
11/12/2020 16:00	10.7	13.4	8.4	157.5	3,258,915.2	2,070.4	1.6	1.2
11/12/2020 17:00	10.4	13.4	8.2	164.4	3,255,184.0	2,091.8	1.7	1.5
11/12/2020 18:00	10.3	13.4	8.1	167.7	3,253,229.2	2,114.3	1.8	1.5
11/12/2020 19:00	10.3	13.4	8.1	173.5	3,256,491.2	2,140.2	1.8	1.5
11/12/2020 20:00	9.8	13.5	7.8	152.0	3,233,115.4	2,030.4	1.6	1.2
11/12/2020 21:00	7.8	13.9	6.6	102.6	3,167,364.5	1,665.3	1.1	0.7
11/12/2020 22:00	9.0	13.7	7.4	121.3	3,297,069.4	1,829.8	1.2	0.9
11/12/2020 23:00	10.3	13.4	8.1	144.8	3,323,462.6	2,038.6	1.5	1.2
Average/Sum#:	9.1	13.6	7.4	127.7	3,210,547.0	1,866.1	1.3	1.0
Minimum:	7.8	13.3	6.6	97.1	2,987,817.7	1,568.2	1.1	0.6
Maximum:	10.7	13.9	8.4	173.5	3,373,733.7	2,246.7	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/13/2020 00:00	9.1	13.6	7.4	117.6	3,336,195.2	1,924.6	1.2	1.0
11/13/2020 01:00	8.9	13.8	7.4	99.1	2,819,513.5	1,503.0	1.2	0.8
11/13/2020 02:00	9.2	13.9	7.8	86.6	2,498,524.4	1,295.4	1.1	0.5
11/13/2020 03:00	8.6	13.9	7.2	85.6	2,592,016.0	1,362.8	1.1	0.5
11/13/2020 04:00	8.9	13.9	7.5	85.8	2,521,452.6	1,325.7	1.1	0.5
11/13/2020 05:00	8.6	13.8	7.1	94.9	3,030,231.8	1,593.2	1.0	0.6
11/13/2020 06:00	8.4	13.8	7.0	105.8	3,283,385.2	1,726.3	1.1	0.7
11/13/2020 07:00	9.1	13.6	7.4	116.3	3,289,321.3	1,825.5	1.2	0.9
11/13/2020 08:00	9.7	13.5	7.7	126.9	3,201,543.0	1,870.3	1.3	0.9
11/13/2020 09:00	8.1	13.9	6.8	103.5	3,199,698.1	1,682.3	1.1	0.7
11/13/2020 10:00	8.3	13.9	7.0	103.4	3,199,317.7	1,682.1	1.1	0.7
11/13/2020 11:00	8.3	13.9	7.0	102.4	3,152,529.1	1,657.5	1.1	0.7
11/13/2020 12:00	8.4	13.9	7.1	95.9	2,922,009.3	1,536.3	1.1	0.6
11/13/2020 13:00	8.4	13.8	7.0	102.1	3,148,915.3	1,655.6	1.1	0.7
11/13/2020 14:00	8.3	13.8	6.9	102.5	3,165,272.3	1,664.2	1.1	0.7
11/13/2020 15:00	9.4	13.6	7.6	114.7	3,147,719.8	1,769.9	1.2	0.9
11/13/2020 16:00	10.4	13.3	8.1	157.1	3,192,280.4	2,098.0	1.7	1.5
11/13/2020 17:00	10.3	13.3	8.0	152.1	3,187,989.2	2,071.9	1.6	1.2
11/13/2020 18:00	10.1	13.3	7.8	146.6	3,234,202.6	2,054.7	1.5	1.2
11/13/2020 19:00	9.6	13.4	7.6	131.0	3,253,312.8	1,924.3	1.4	1.0
11/13/2020 20:00	8.0	13.8	6.6	104.0	3,165,246.3	1,687.3	1.1	0.7
11/13/2020 21:00	8.9	13.7	7.3	106.8	3,089,604.0	1,692.1	1.2	0.8
11/13/2020 22:00	10.3	13.4	8.1	143.0	3,274,374.3	2,032.4	1.5	1.2
11/13/2020 23:00	8.7	13.7	7.1	106.4	2,964,443.4	1,645.2	1.2	0.8
Average/Sum#:	9.0	13.7	7.4	112.1	3,077,879.1	1,720.0	1.2	0.8
Minimum:	8.0	13.3	6.6	85.6	2,498,524.4	1,295.4	1.0	0.5
Maximum:	10.4	13.9	8.1	157.1	3,336,195.2	2,098.0	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/14/2020 00:00	8.8	13.9	7.4	88.1	2,586,690.5	1,360.0	1.1	0.5
11/14/2020 01:00	8.6	13.9	7.2	85.8	2,587,451.3	1,360.4	1.1	0.5
11/14/2020 02:00	8.7	13.9	7.3	85.9	2,574,708.0	1,353.7	1.1	0.5
11/14/2020 03:00	8.6	13.9	7.2	85.8	2,586,500.3	1,359.9	1.1	0.5
11/14/2020 04:00	8.7	13.9	7.3	85.9	2,603,063.6	1,349.6	1.1	0.5
11/14/2020 05:00	8.4	13.8	7.0	100.4	3,120,786.9	1,663.6	1.1	0.7
11/14/2020 06:00	8.6	13.8	7.1	95.9	2,890,056.0	1,519.5	1.1	0.6
11/14/2020 07:00	8.4	13.8	7.0	99.6	3,054,006.6	1,605.7	1.1	0.6
11/14/2020 08:00	8.3	13.8	6.9	105.0	3,171,624.4	1,690.7	1.1	0.7
11/14/2020 09:00	8.4	13.8	7.0	104.7	3,156,429.4	1,682.6	1.1	0.7
11/14/2020 10:00	8.3	13.8	6.9	104.9	3,216,625.7	1,691.2	1.1	0.7
11/14/2020 11:00	8.2	13.9	6.9	104.3	3,226,706.2	1,696.5	1.1	0.7
11/14/2020 12:00	8.2	13.9	6.9	103.8	3,208,637.4	1,687.0	1.1	0.7
11/14/2020 13:00	8.2	13.9	6.9	103.7	3,212,251.2	1,688.9	1.1	0.7
11/14/2020 14:00	8.2	13.9	6.9	102.2	3,155,572.2	1,659.1	1.1	0.7
11/14/2020 15:00	8.9	13.8	7.4	107.4	3,160,224.4	1,707.7	1.1	0.7
11/14/2020 16:00	10.5	13.4	8.3	149.1	3,292,096.2	2,043.4	1.5	1.2
11/14/2020 17:00	10.4	13.4	8.2	155.6	3,286,777.8	2,064.1	1.6	1.2
11/14/2020 18:00	10.1	13.4	7.9	152.3	3,287,573.9	2,064.6	1.6	1.2
11/14/2020 19:00	9.7	13.4	7.6	143.0	3,277,652.1	2,010.5	1.5	1.2
11/14/2020 20:00	7.8	13.9	6.6	102.0	3,173,450.8	1,668.5	1.1	0.7
11/14/2020 21:00	9.2	13.7	7.5	118.5	3,300,493.0	1,831.7	1.2	0.9
11/14/2020 22:00	10.0	13.4	7.9	143.1	3,331,287.8	2,043.4	1.5	1.2
11/14/2020 23:00	8.9	13.5	7.1	129.6	3,348,242.6	1,956.0	1.3	1.0
Average/Sum#:	8.8	13.7	7.3	110.7	3,075,371.2	1,698.3	1.2	0.8
Minimum:	7.8	13.4	6.6	85.8	2,574,708.0	1,349.6	1.1	0.5
Maximum:	10.5	13.9	8.3	155.6	3,348,242.6	2,064.6	1.6	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/15/2020 00:00	9.9	13.4	7.8	142.1	3,321,832.3	2,037.6	1.5	1.2
11/15/2020 01:00	8.9	13.6	7.2	123.7	3,318,800.0	1,938.8	1.3	1.0
11/15/2020 02:00	8.0	13.8	6.6	100.2	3,090,334.4	1,624.8	1.1	0.6
11/15/2020 03:00	8.5	13.7	7.0	103.8	3,148,750.8	1,701.5	1.1	0.7
11/15/2020 04:00	9.9	13.4	7.8	136.6	3,330,836.1	2,018.8	1.4	1.0
11/15/2020 05:00	8.3	13.6	6.7	132.7	3,382,302.7	1,926.5	1.3	1.0
11/15/2020 06:00	8.3	13.8	6.9	103.9	3,150,056.5	1,656.2	1.1	0.7
11/15/2020 07:00	8.5	13.9	7.2	92.3	2,823,677.0	1,484.6	1.1	0.6
11/15/2020 08:00	8.4	13.8	7.0	102.9	3,176,113.6	1,669.9	1.1	0.7
11/15/2020 09:00	8.3	13.8	6.9	104.0	3,213,392.4	1,689.5	1.1	0.7
11/15/2020 10:00	8.3	13.8	6.9	104.3	3,249,149.5	1,708.3	1.1	0.7
11/15/2020 11:00	8.3	13.9	7.0	103.9	3,231,080.8	1,698.8	1.1	0.7
11/15/2020 12:00	8.3	13.9	7.0	104.0	3,222,902.2	1,694.5	1.1	0.7
11/15/2020 13:00	8.3	13.9	7.0	103.8	3,226,516.0	1,696.4	1.1	0.7
11/15/2020 14:00	8.3	13.9	7.0	103.3	3,215,674.7	1,690.7	1.1	0.7
11/15/2020 15:00	8.8	13.8	7.3	93.2	2,781,453.1	1,462.4	1.1	0.6
11/15/2020 16:00	8.5	13.9	7.2	97.2	2,991,431.5	1,572.8	1.1	0.6
11/15/2020 17:00	8.4	13.9	7.1	97.5	2,992,192.3	1,573.2	1.1	0.6
11/15/2020 18:00	8.3	13.9	7.0	99.0	3,052,865.4	1,605.1	1.1	0.6
11/15/2020 19:00	8.3	13.9	7.0	101.0	3,114,869.9	1,637.7	1.1	0.7
11/15/2020 20:00	9.3	13.6	7.5	115.5	3,288,060.0	1,824.8	1.2	0.9
11/15/2020 21:00	9.8	13.5	7.8	134.0	3,215,273.2	1,901.8	1.4	1.0
11/15/2020 22:00	8.6	13.7	7.0	109.6	3,231,841.5	1,746.4	1.1	0.7
11/15/2020 23:00	10.3	13.4	8.1	142.2	3,308,627.1	2,029.5	1.5	1.2
Average/Sum#:	8.7	13.7	7.2	110.4	3,169,918.0	1,732.9	1.2	0.8
Minimum:	8.0	13.4	6.6	92.3	2,781,453.1	1,462.4	1.1	0.6
Maximum:	10.3	13.9	8.1	142.2	3,382,302.7	2,037.6	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/16/2020 00:00	8.8	13.6	7.1	116.7	3,206,033.2	1,826.1	1.2	0.9
11/16/2020 01:00	8.8	13.9	7.4	86.8	2,510,097.0	1,301.4	1.1	0.5
11/16/2020 02:00	9.1	13.9	7.7	86.6	2,497,367.2	1,294.8	1.1	0.5
11/16/2020 03:00	9.1	13.9	7.7	86.7	2,495,438.4	1,293.8	1.1	0.5
11/16/2020 04:00	8.9	13.7	7.3	104.5	3,165,996.6	1,687.7	1.1	0.7
11/16/2020 05:00	10.3	13.4	8.1	137.4	3,238,847.9	2,034.0	1.4	1.0
11/16/2020 06:00	10.5	13.3	8.2	154.4	3,251,138.0	2,089.2	1.6	1.3
11/16/2020 07:00	10.0	13.4	7.9	140.7	3,202,842.0	1,988.0	1.5	1.2
11/16/2020 08:00	7.8	13.9	6.6	102.3	3,224,043.4	1,695.1	1.1	0.7
11/16/2020 09:00	8.1	13.9	6.8	100.7	3,119,815.0	1,640.3	1.1	0.7
11/16/2020 10:00	8.2	13.9	6.9	102.7	3,197,605.9	1,681.2	1.1	0.7
11/16/2020 11:00	8.2	13.9	6.9	103.6	3,223,853.2	1,695.0	1.1	0.7
11/16/2020 12:00	8.2	13.9	6.9	103.3	3,201,980.5	1,683.5	1.1	0.7
11/16/2020 13:00	8.3	13.9	7.0	103.5	3,204,453.1	1,684.8	1.1	0.7
11/16/2020 14:00	8.3	13.9	7.0	100.5	3,098,322.7	1,629.0	1.1	0.7
11/16/2020 15:00	9.4	13.7	7.7	118.1	3,146,572.1	1,723.3	1.3	0.9
11/16/2020 16:00	10.6	13.3	8.2	151.5	3,212,480.7	2,040.9	1.6	1.2
11/16/2020 17:00	10.6	13.3	8.2	169.9	3,212,669.6	2,111.4	1.8	1.5
11/16/2020 18:00	10.4	13.2	8.0	176.3	3,185,846.7	2,140.3	1.9	1.5
11/16/2020 19:00	10.3	13.3	8.0	174.5	3,203,700.6	2,128.9	1.9	1.5
11/16/2020 20:00	10.4	13.3	8.1	172.3	3,193,919.0	2,122.4	1.9	1.5
11/16/2020 21:00	10.3	13.3	8.0	159.9	3,224,372.0	2,072.0	1.7	1.5
11/16/2020 22:00	10.3	13.3	8.0	163.1	3,243,357.2	2,084.2	1.7	1.5
11/16/2020 23:00	9.9	13.3	7.7	151.9	3,274,675.9	2,056.5	1.6	1.2
Average/Sum#:	9.4	13.6	7.6	127.8	3,113,976.2	1,821.0	1.4	1.0
Minimum:	7.8	13.2	6.6	86.6	2,495,438.4	1,293.8	1.1	0.5
Maximum:	10.6	13.9	8.2	176.3	3,274,675.9	2,140.3	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	12.50	12.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/17/2020 00:00	10.0	13.3	7.8	153.3	3,242,072.9	2,059.7	1.6	1.2
11/17/2020 01:00	9.8	13.4	7.7	149.3	3,209,286.3	1,992.0	1.6	1.2
11/17/2020 02:00	8.1	13.9	6.8	96.6	2,933,611.3	1,542.4	1.1	0.6
11/17/2020 03:00	8.2	13.8	6.8	93.8	2,909,075.8	1,529.5	1.1	0.6
11/17/2020 04:00	8.8	13.7	7.2	108.9	3,205,748.5	1,732.3	1.1	0.7
11/17/2020 05:00	10.3	13.3	8.0	143.4	3,228,536.0	2,051.1	1.5	1.2
11/17/2020 06:00	10.5	13.3	8.2	166.2	3,236,657.1	2,150.8	1.8	1.5
11/17/2020 07:00	9.9	13.4	7.8	146.5	3,226,363.8	2,002.6	1.6	1.2
11/17/2020 08:00	7.9	13.8	6.6	103.5	3,179,727.3	1,671.8	1.1	0.7
11/17/2020 09:00	8.2	13.9	6.9	97.4	2,984,584.4	1,569.2	1.1	0.6
11/17/2020 10:00	8.4	13.8	7.0	96.6	2,961,570.4	1,557.1	1.1	0.6
11/17/2020 11:00	8.4	13.8	7.0	104.7	3,188,132.5	1,699.5	1.1	0.7
11/17/2020 12:00	8.5	13.9	7.2	92.9	2,795,717.9	1,469.9	1.1	0.6
11/17/2020 13:00	8.5	13.8	7.1	98.2	2,956,455.9	1,576.0	1.1	0.6
11/17/2020 14:00	8.5	13.8	7.1	100.0	3,017,986.2	1,608.8	1.1	0.6
11/17/2020 15:00	9.8	13.6	7.9	123.2	3,163,890.4	1,825.2	1.3	0.9
11/17/2020 16:00	10.7	13.3	8.3	169.5	3,170,961.7	2,130.3	1.8	1.5
11/17/2020 17:00	10.5	13.3	8.2	179.3	3,151,278.6	2,163.1	2.0	1.7
11/17/2020 18:00	10.1	13.2	7.7	171.2	3,187,224.8	2,164.5	1.9	1.5
11/17/2020 19:00	9.9	13.3	7.7	161.1	3,170,961.7	2,130.3	1.8	1.5
11/17/2020 20:00	9.9	13.3	7.7	153.8	3,188,296.9	2,072.1	1.7	1.5
11/17/2020 21:00	10.0	13.3	7.8	153.3	3,186,604.4	2,071.0	1.7	1.4
11/17/2020 22:00	10.0	13.3	7.8	154.1	3,192,605.2	2,074.9	1.7	1.5
11/17/2020 23:00	9.8	13.4	7.7	139.1	3,231,515.5	1,982.2	1.5	1.2
Average/Sum#:	9.4	13.5	7.5	131.5	3,121,619.4	1,867.8	1.4	1.1
Minimum:	7.9	13.2	6.6	92.9	2,795,717.9	1,469.9	1.1	0.6
Maximum:	10.7	13.9	8.3	179.3	3,242,072.9	2,164.5	2.0	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/18/2020 00:00	9.8	13.3	7.6	148.4	3,215,035.0	2,066.0	1.6	1.2
11/18/2020 01:00	9.4	13.5	7.5	130.3	3,120,233.5	1,822.8	1.4	0.9
11/18/2020 02:00	8.7	13.9	7.3	91.7	2,672,659.9	1,405.2	1.1	0.6
11/18/2020 03:00	8.9	13.9	7.5	86.1	2,480,369.9	1,304.1	1.2	0.7
11/18/2020 04:00	9.0	13.7	7.4	107.8	3,105,124.1	1,700.6	1.2	0.9
11/18/2020 05:00	10.3	13.3	8.0	155.0	3,184,296.4	2,069.5	1.7	1.4
11/18/2020 06:00	10.6	13.3	8.2	165.2	3,176,915.7	2,134.3	1.8	1.5
11/18/2020 07:00	10.1	13.4	7.9	147.1	3,195,431.0	1,983.4	1.6	1.2
11/18/2020 08:00	8.1	13.9	6.8	95.0	2,888,534.5	1,518.7	1.1	0.6
11/18/2020 09:00	8.3	13.9	7.0	93.4	2,896,142.4	1,522.7	1.1	0.6
11/18/2020 10:00	8.3	13.9	7.0	97.3	3,014,445.4	1,584.9	1.1	0.6
11/18/2020 11:00	8.2	13.9	6.9	103.1	3,223,282.6	1,694.7	1.1	0.7
11/18/2020 12:00	8.2	13.9	6.9	102.3	3,185,243.1	1,674.7	1.1	0.7
11/18/2020 13:00	8.3	13.9	7.0	97.8	3,069,632.3	1,591.5	1.1	0.6
11/18/2020 14:00	8.4	13.9	7.1	94.1	2,936,547.4	1,522.5	1.1	0.6
11/18/2020 15:00	8.8	13.8	7.3	111.6	3,168,551.9	1,712.2	1.2	0.9
11/18/2020 16:00	10.4	13.4	8.2	143.4	3,320,111.7	2,012.3	1.5	1.2
11/18/2020 17:00	10.3	13.3	8.0	149.2	3,282,319.2	2,061.3	1.5	1.2
11/18/2020 18:00	10.1	13.3	7.8	156.1	3,286,929.8	2,112.2	1.6	1.3
11/18/2020 19:00	10.0	13.5	8.0	143.9	3,259,065.0	1,975.3	1.5	1.2
11/18/2020 20:00	9.9	13.5	7.9	137.2	3,322,052.4	1,940.7	1.4	1.0
11/18/2020 21:00	9.8	13.5	7.8	136.1	3,325,989.5	1,943.0	1.4	1.0
11/18/2020 22:00	9.4	13.5	7.5	129.4	3,337,629.6	1,949.8	1.3	1.0
11/18/2020 23:00	9.0	13.6	7.3	121.8	3,371,904.2	1,945.2	1.2	1.0
Average/Sum#:	9.3	13.6	7.5	122.6	3,126,601.9	1,802.0	1.3	0.9
Minimum:	8.1	13.3	6.8	86.1	2,480,369.9	1,304.1	1.1	0.6
Maximum:	10.6	13.9	8.2	165.2	3,371,904.2	2,134.3	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/19/2020 00:00	8.5	13.6	6.9	114.5	3,331,861.5	1,922.1	1.2	1.0
11/19/2020 01:00	8.0	13.9	6.7	95.2	2,916,113.1	1,533.2	1.1	0.6
11/19/2020 02:00	8.3	13.9	7.0	85.8	2,655,911.8	1,377.0	1.1	0.6
11/19/2020 03:00	9.0	13.9	7.6	86.8	2,519,933.7	1,306.5	1.1	0.5
11/19/2020 04:00	9.1	13.9	7.7	87.1	2,512,604.4	1,302.7	1.1	0.5
11/19/2020 05:00	8.9	13.8	7.4	96.9	2,961,380.2	1,557.0	1.1	0.6
11/19/2020 06:00	9.8	13.5	7.8	129.9	3,408,345.1	2,016.0	1.3	1.0
11/19/2020 07:00	9.0	13.6	7.3	123.5	3,372,207.5	1,970.0	1.2	1.0
11/19/2020 08:00	8.1	13.8	6.7	99.6	3,059,332.1	1,608.5	1.1	0.6
11/19/2020 09:00	8.2	13.8	6.8	102.6	3,178,205.8	1,671.0	1.1	0.7
11/19/2020 10:00	8.2	13.8	6.8	103.9	3,231,461.2	1,699.0	1.1	0.7
11/19/2020 11:00	8.3	13.9	7.0	99.0	3,041,263.3	1,599.0	1.1	0.6
11/19/2020 12:00	8.2	13.9	6.9	104.0	3,239,829.9	1,703.4	1.1	0.7
11/19/2020 13:00	8.2	13.9	6.9	101.6	3,187,672.8	1,652.7	1.1	0.7
11/19/2020 14:00	8.1	13.9	6.8	102.9	3,254,215.2	1,687.2	1.1	0.7
11/19/2020 15:00	8.9	14.0	7.6	87.4	2,587,625.2	1,322.7	1.1	0.5
11/19/2020 16:00	8.2	13.9	6.9	98.3	3,088,341.3	1,601.2	1.1	0.6
11/19/2020 17:00	8.2	13.9	6.9	104.7	3,273,114.5	1,720.9	1.1	0.7
11/19/2020 18:00	10.4	13.4	8.2	150.9	3,332,212.3	2,068.3	1.5	1.2
11/19/2020 19:00	10.3	13.4	8.1	171.5	3,295,235.1	2,141.6	1.8	1.5
11/19/2020 20:00	10.2	13.4	8.0	163.0	3,308,812.6	2,102.1	1.7	1.5
11/19/2020 21:00	9.7	13.5	7.7	150.6	3,318,626.8	2,011.4	1.6	1.2
11/19/2020 22:00	10.0	13.4	7.9	154.9	3,325,606.8	2,064.2	1.6	1.2
11/19/2020 23:00	9.1	13.6	7.4	134.4	3,348,585.0	1,956.2	1.4	1.0
Average/Sum#:	8.9	13.7	7.3	114.5	3,114,520.7	1,733.1	1.2	0.8
Minimum:	8.0	13.4	6.7	85.8	2,512,604.4	1,302.7	1.1	0.5
Maximum:	10.4	14.0	8.2	171.5	3,408,345.1	2,141.6	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/20/2020 00:00	9.9	13.4	7.8	150.2	3,309,334.9	2,054.1	1.6	1.2
11/20/2020 01:00	8.8	13.6	7.1	121.9	3,333,941.7	1,923.3	1.2	1.0
11/20/2020 02:00	7.8	13.9	6.6	98.7	3,077,733.1	1,595.7	1.1	0.6
11/20/2020 03:00	8.0	13.9	6.7	98.6	3,033,845.6	1,595.1	1.1	0.6
11/20/2020 04:00	8.7	13.8	7.2	111.0	3,220,368.0	1,740.2	1.2	0.9
11/20/2020 05:00	10.3	13.4	8.1	156.3	3,272,609.5	2,079.1	1.6	1.2
11/20/2020 06:00	10.4	13.4	8.2	163.0	3,319,142.4	2,132.9	1.7	1.5
11/20/2020 07:00	10.0	13.4	7.9	160.7	3,300,942.4	2,097.1	1.7	1.5
11/20/2020 08:00	9.9	13.5	7.9	154.1	3,315,311.2	2,033.6	1.6	1.2
11/20/2020 09:00	9.8	13.5	7.8	148.0	3,276,884.1	1,986.1	1.5	1.2
11/20/2020 10:00	7.6	13.9	6.4	103.0	3,216,604.3	1,667.7	1.1	0.7
11/20/2020 11:00	7.9	13.9	6.7	97.5	3,067,510.6	1,590.4	1.1	0.6
11/20/2020 12:00	7.9	13.9	6.7	100.2	3,182,465.1	1,650.0	1.0	0.7
11/20/2020 13:00	8.1	14.0	6.9	93.3	2,922,467.4	1,515.2	1.1	0.6
11/20/2020 14:00	8.1	14.0	6.9	95.5	2,990,552.8	1,550.5	1.1	0.6
11/20/2020 15:00	9.9	13.6	8.0	132.0	3,269,011.6	1,838.1	1.4	0.9
11/20/2020 16:00	10.5	13.4	8.3	157.6	3,329,452.8	2,090.9	1.6	1.3
11/20/2020 17:00	10.1	13.4	7.9	165.5	3,313,073.3	2,129.0	1.7	1.5
11/20/2020 18:00	10.3	13.4	8.1	181.4	3,267,385.0	2,123.5	1.9	1.5
11/20/2020 19:00	10.2	13.4	8.0	177.7	3,269,077.6	2,124.6	1.9	1.5
11/20/2020 20:00	10.1	13.4	7.9	175.5	3,281,848.6	2,132.9	1.9	1.5
11/20/2020 21:00	9.8	13.4	7.7	170.8	3,265,538.6	2,122.3	1.8	1.5
11/20/2020 22:00	9.9	13.4	7.8	175.5	3,283,233.4	2,133.8	1.9	1.5
11/20/2020 23:00	9.8	13.4	7.7	160.9	3,310,185.4	2,078.8	1.7	1.5
Average/Sum#:	9.3	13.6	7.5	139.5	3,226,188.3	1,916.0	1.5	1.1
Minimum:	7.6	13.4	6.4	93.3	2,922,467.4	1,515.2	1.0	0.6
Maximum:	10.5	14.0	8.3	181.4	3,333,941.7	2,133.8	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/21/2020 00:00	9.8	13.4	7.7	155.5	3,324,318.0	2,063.4	1.6	1.2
11/21/2020 01:00	9.7	13.5	7.7	139.5	3,337,458.4	1,949.7	1.4	1.0
11/21/2020 02:00	9.7	13.5	7.7	136.2	3,327,181.2	1,919.4	1.4	1.0
11/21/2020 03:00	7.6	13.9	6.4	105.4	3,380,742.3	1,752.8	1.0	0.7
11/21/2020 04:00	8.7	13.7	7.1	123.5	3,273,280.0	1,840.5	1.3	0.9
11/21/2020 05:00	10.2	13.4	8.0	158.2	3,272,457.4	2,102.9	1.7	1.5
11/21/2020 06:00	10.4	13.4	8.2	171.4	3,297,543.1	2,143.1	1.8	1.5
11/21/2020 07:00	7.8	13.8	6.5	107.6	3,002,555.5	1,622.5	1.2	0.8
11/21/2020 08:00	7.9	13.9	6.7	103.5	3,116,694.2	1,615.9	1.1	0.6
11/21/2020 09:00	8.0	13.9	6.7	104.0	3,128,652.5	1,622.1	1.1	0.6
11/21/2020 10:00	8.2	13.9	6.9	96.2	2,848,017.0	1,476.6	1.1	0.6
11/21/2020 11:00	8.0	13.9	6.7	106.9	3,225,283.7	1,672.2	1.1	0.7
11/21/2020 12:00	8.1	13.9	6.8	107.7	3,231,841.5	1,675.6	1.1	0.7
11/21/2020 13:00	8.2	14.0	7.0	109.0	3,273,888.7	1,697.4	1.1	0.7
11/21/2020 14:00	8.2	14.0	7.0	104.0	3,095,477.7	1,604.9	1.1	0.6
11/21/2020 15:00	9.4	13.6	7.6	123.6	3,291,598.2	1,850.8	1.3	0.9
11/21/2020 16:00	10.3	13.4	8.1	151.8	3,282,683.4	2,085.5	1.6	1.3
11/21/2020 17:00	10.1	13.4	7.9	157.8	3,293,621.3	2,116.5	1.6	1.3
11/21/2020 18:00	10.0	13.3	7.8	164.9	3,277,184.7	2,153.8	1.7	1.5
11/21/2020 19:00	9.9	13.3	7.7	164.8	3,299,235.7	2,144.2	1.7	1.5
11/21/2020 20:00	9.6	13.4	7.6	160.2	3,252,849.8	2,090.3	1.7	1.5
11/21/2020 21:00	7.9	13.8	6.6	103.9	3,208,257.0	1,686.8	1.1	0.7
11/21/2020 22:00	9.2	13.7	7.5	127.9	3,269,189.5	1,838.2	1.3	0.9
11/21/2020 23:00	10.1	13.4	7.9	154.9	3,311,777.7	2,079.8	1.6	1.2
Average/Sum#:	9.0	13.6	7.3	130.8	3,234,241.2	1,866.9	1.4	1.0
Minimum:	7.6	13.3	6.4	96.2	2,848,017.0	1,476.6	1.0	0.6
Maximum:	10.4	14.0	8.2	171.4	3,380,742.3	2,153.8	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/22/2020 00:00	10.1	13.4	7.9	155.6	3,313,201.5	2,056.5	1.6	1.2
11/22/2020 01:00	8.1	13.7	6.6	117.1	3,130,781.5	1,806.1	1.3	0.9
11/22/2020 02:00	8.5	13.9	7.2	85.8	2,518,776.5	1,305.9	1.1	0.5
11/22/2020 03:00	8.5	13.9	7.2	86.6	2,630,452.1	1,363.8	1.1	0.5
11/22/2020 04:00	8.1	13.9	6.8	99.7	3,088,622.6	1,623.9	1.1	0.6
11/22/2020 05:00	8.6	13.7	7.0	113.9	3,238,337.5	1,844.5	1.2	0.9
11/22/2020 06:00	9.4	13.6	7.6	124.6	3,298,908.2	1,879.0	1.3	0.9
11/22/2020 07:00	8.3	13.9	7.0	95.2	2,887,583.5	1,518.2	1.1	0.6
11/22/2020 08:00	8.2	13.9	6.9	102.8	3,192,851.0	1,678.7	1.1	0.7
11/22/2020 09:00	8.1	13.9	6.8	103.6	3,216,245.3	1,691.0	1.1	0.7
11/22/2020 10:00	8.2	13.9	6.9	100.3	3,087,101.0	1,623.1	1.1	0.6
11/22/2020 11:00	8.1	13.9	6.8	102.4	3,184,672.5	1,674.4	1.1	0.7
11/22/2020 12:00	8.1	13.9	6.8	101.2	3,137,693.6	1,649.7	1.1	0.7
11/22/2020 13:00	8.1	13.9	6.8	101.0	3,127,232.7	1,644.2	1.1	0.7
11/22/2020 14:00	8.1	13.9	6.8	103.6	3,230,320.0	1,698.4	1.1	0.7
11/22/2020 15:00	9.6	13.6	7.8	122.0	3,268,833.8	1,838.0	1.2	0.9
11/22/2020 16:00	10.3	13.4	8.1	160.0	3,264,209.8	2,097.6	1.7	1.5
11/22/2020 17:00	10.0	13.3	7.8	164.6	3,250,151.8	2,112.3	1.7	1.5
11/22/2020 18:00	9.9	13.4	7.8	162.5	3,266,699.6	2,099.2	1.7	1.5
11/22/2020 19:00	9.7	13.4	7.6	155.1	3,217,517.7	2,044.1	1.7	1.4
11/22/2020 20:00	7.6	13.9	6.4	102.9	3,214,533.5	1,690.1	1.1	0.7
11/22/2020 21:00	9.0	13.6	7.3	123.2	3,259,405.6	1,856.5	1.3	0.9
11/22/2020 22:00	10.1	13.4	7.9	155.8	3,254,561.5	2,091.4	1.6	1.3
11/22/2020 23:00	8.5	13.6	6.9	119.6	3,217,800.6	1,856.3	1.3	0.9
Average/Sum#:	8.8	13.7	7.2	119.1	3,145,687.2	1,781.0	1.3	0.9
Minimum:	7.6	13.3	6.4	85.8	2,518,776.5	1,305.9	1.1	0.5
Maximum:	10.3	13.9	8.1	164.6	3,313,201.5	2,112.3	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/23/2020 00:00	8.7	13.7	7.1	110.4	3,126,487.2	1,712.3	1.2	0.9
11/23/2020 01:00	8.3	13.7	6.8	112.3	3,273,609.0	1,912.4	1.2	1.0
11/23/2020 02:00	8.3	13.9	7.0	92.8	2,805,988.6	1,475.3	1.1	0.6
11/23/2020 03:00	8.3	13.9	7.0	85.8	2,635,951.7	1,385.9	1.1	0.6
11/23/2020 04:00	8.4	13.9	7.1	85.9	2,692,365.5	1,395.9	1.1	0.6
11/23/2020 05:00	8.3	13.8	6.9	105.2	3,249,339.7	1,708.4	1.1	0.7
11/23/2020 06:00	8.8	13.9	7.4	90.2	2,697,380.3	1,398.5	1.1	0.6
11/23/2020 07:00	8.3	13.9	7.0	103.9	3,227,086.6	1,696.7	1.1	0.7
11/23/2020 08:00	8.3	13.9	7.0	100.2	3,098,893.3	1,629.3	1.1	0.7
11/23/2020 09:00	8.2	13.9	6.9	101.9	3,158,235.0	1,660.5	1.1	0.7
11/23/2020 10:00	8.3	13.9	7.0	97.7	3,018,249.4	1,586.9	1.1	0.6
11/23/2020 11:00	8.2	13.9	6.9	102.1	3,175,923.4	1,669.8	1.1	0.7
11/23/2020 12:00	8.1	13.9	6.8	102.9	3,265,209.2	1,692.9	1.0	0.7
11/23/2020 13:00	8.1	13.9	6.8	100.6	3,176,100.2	1,646.7	1.1	0.7
11/23/2020 14:00	8.1	13.9	6.8	102.7	3,261,737.4	1,691.1	1.0	0.7
11/23/2020 15:00	9.6	13.7	7.9	125.7	3,265,151.9	1,764.4	1.3	0.9
11/23/2020 16:00	10.6	13.4	8.3	161.3	3,284,414.8	2,086.6	1.7	1.5
11/23/2020 17:00	10.1	13.3	7.8	157.1	3,277,592.8	2,106.2	1.6	1.3
11/23/2020 18:00	9.9	13.3	7.7	154.0	3,286,929.8	2,112.2	1.6	1.3
11/23/2020 19:00	9.9	13.5	7.9	149.1	3,240,751.1	1,964.2	1.6	1.2
11/23/2020 20:00	7.8	13.9	6.6	101.8	3,173,831.2	1,668.7	1.1	0.7
11/23/2020 21:00	8.5	13.8	7.1	108.8	3,145,974.9	1,700.0	1.2	0.9
11/23/2020 22:00	10.0	13.4	7.9	148.5	3,300,635.0	2,048.7	1.5	1.2
11/23/2020 23:00	8.6	13.6	7.0	120.3	3,294,634.7	1,972.8	1.2	1.0
Average/Sum#:	8.7	13.7	7.2	113.4	3,130,519.7	1,736.9	1.2	0.9
Minimum:	7.8	13.3	6.6	85.8	2,635,951.7	1,385.9	1.0	0.6
Maximum:	10.6	13.9	8.3	161.3	3,300,635.0	2,112.2	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/24/2020 00:00	8.3	13.6	6.7	115.8	3,284,758.8	1,942.9	1.2	1.0
11/24/2020 01:00	7.9	13.9	6.7	95.6	2,968,417.5	1,560.7	1.1	0.6
11/24/2020 02:00	8.1	13.9	6.8	96.2	2,979,068.6	1,566.3	1.1	0.6
11/24/2020 03:00	8.2	13.9	6.9	97.4	3,010,070.9	1,582.6	1.1	0.6
11/24/2020 04:00	9.3	13.7	7.6	122.9	3,305,177.8	1,834.3	1.2	0.9
11/24/2020 05:00	10.4	13.4	8.2	154.2	3,293,701.8	2,092.5	1.6	1.3
11/24/2020 06:00	10.6	13.3	8.2	187.6	3,307,755.3	2,222.2	2.0	1.8
11/24/2020 07:00	10.0	13.4	7.9	167.0	3,305,236.5	2,148.1	1.7	1.5
11/24/2020 08:00	9.6	13.5	7.7	141.6	3,278,644.7	1,891.4	1.5	1.1
11/24/2020 09:00	7.8	13.9	6.6	103.8	3,213,582.6	1,689.6	1.1	0.7
11/24/2020 10:00	7.9	13.9	6.7	101.9	3,225,862.4	1,672.5	1.1	0.7
11/24/2020 11:00	7.9	13.9	6.7	101.5	3,247,464.6	1,683.7	1.0	0.7
11/24/2020 12:00	8.0	13.9	6.7	101.0	3,221,812.0	1,670.4	1.0	0.7
11/24/2020 13:00	8.0	13.9	6.7	101.6	3,240,713.9	1,680.2	1.0	0.7
11/24/2020 14:00	8.1	13.9	6.8	97.5	3,084,483.8	1,599.2	1.1	0.6
11/24/2020 15:00	8.9	13.8	7.4	103.0	2,957,956.7	1,576.8	1.2	0.8
11/24/2020 16:00	10.6	13.4	8.3	155.8	3,286,618.5	2,088.0	1.6	1.3
11/24/2020 17:00	9.9	13.3	7.7	155.6	3,306,070.6	2,124.5	1.6	1.3
11/24/2020 18:00	10.0	13.3	7.8	168.1	3,297,389.3	2,143.0	1.8	1.5
11/24/2020 19:00	9.9	13.3	7.7	172.2	3,297,726.1	2,167.3	1.8	1.5
11/24/2020 20:00	9.8	13.3	7.6	171.1	3,309,137.9	2,174.8	1.8	1.5
11/24/2020 21:00	9.7	13.3	7.5	159.8	3,337,971.9	2,145.0	1.7	1.5
11/24/2020 22:00	9.7	13.3	7.5	157.0	3,346,117.6	2,125.8	1.6	1.3
11/24/2020 23:00	9.6	13.4	7.6	147.2	3,344,617.7	2,076.0	1.5	1.2
Average/Sum#:	9.1	13.6	7.3	132.3	3,227,098.2	1,894.1	1.4	1.1
Minimum:	7.8	13.3	6.6	95.6	2,957,956.7	1,560.7	1.0	0.6
Maximum:	10.6	13.9	8.3	187.6	3,346,117.6	2,222.2	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/25/2020 00:00	9.6	13.4	7.6	146.4	3,346,228.8	2,077.0	1.5	1.2
11/25/2020 01:00	8.5	13.6	6.9	117.0	3,346,769.2	1,930.7	1.2	1.0
11/25/2020 02:00	7.9	13.9	6.7	96.3	2,990,290.3	1,572.2	1.1	0.6
11/25/2020 03:00	8.3	13.9	7.0	85.4	2,622,257.5	1,378.7	1.1	0.6
11/25/2020 04:00	8.5	13.8	7.1	96.7	2,979,068.6	1,566.3	1.1	0.6
11/25/2020 05:00	10.1	13.4	7.9	139.0	3,295,911.0	2,021.7	1.4	1.0
11/25/2020 06:00	9.6	13.5	7.7	130.8	3,366,445.9	2,015.8	1.3	1.0
11/25/2020 07:00	9.3	13.5	7.4	125.4	3,321,761.6	2,013.3	1.3	1.0
11/25/2020 08:00	8.0	13.8	6.6	103.0	3,189,807.8	1,677.1	1.1	0.7
11/25/2020 09:00	8.2	13.8	6.8	100.9	3,120,575.8	1,640.7	1.1	0.7
11/25/2020 10:00	8.1	13.8	6.7	103.7	3,238,878.9	1,702.9	1.1	0.7
11/25/2020 11:00	8.1	13.9	6.8	103.6	3,238,308.3	1,702.6	1.1	0.7
11/25/2020 12:00	8.1	13.9	6.8	103.6	3,278,324.8	1,699.7	1.1	0.7
11/25/2020 13:00	8.2	13.9	6.9	103.1	3,255,951.1	1,688.1	1.1	0.7
11/25/2020 14:00	8.2	13.9	6.9	101.6	3,205,224.6	1,661.8	1.1	0.7
11/25/2020 15:00	8.3	14.0	7.1	86.4	2,617,722.2	1,357.2	1.1	0.5
11/25/2020 16:00	8.2	13.9	6.9	100.3	3,161,827.3	1,639.3	1.1	0.7
11/25/2020 17:00	8.2	13.9	6.9	99.4	3,071,885.2	1,615.1	1.1	0.6
11/25/2020 18:00	8.1	13.9	6.8	103.4	3,236,976.9	1,701.9	1.1	0.7
11/25/2020 19:00	9.8	13.7	8.0	116.5	3,271,344.2	1,863.3	1.2	0.9
11/25/2020 20:00	10.1	13.5	8.1	124.7	3,197,028.5	1,937.7	1.3	1.0
11/25/2020 21:00	8.9	13.8	7.4	109.9	3,322,149.5	1,795.2	1.1	0.7
11/25/2020 22:00	10.7	13.4	8.4	126.5	3,322,647.4	2,038.1	1.3	1.0
11/25/2020 23:00	17.0	14.7	16.2	150.6	2,571,497.1	1,276.9	1.9	0.9
Average/Sum#:	9.1	13.8	7.6	111.4	3,148,703.4	1,732.2	1.2	0.8
Minimum:	7.9	13.4	6.6	85.4	2,571,497.1	1,276.9	1.1	0.5
Maximum:	17.0	14.7	16.2	150.6	3,366,445.9	2,077.0	1.9	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 23:00	43.3	17.3	71.0	0.0	1,879,736.4	466.7	0.0	0.0
Average/Sum#:	43.3	17.3	71.0	0.0	1,879,736.4	466.7	0.0	0.0
Minimum:	43.3	17.3	71.0	0.0	1,879,736.4	466.7	0.0	0.0
Maximum:	43.3	17.3	71.0	0.0	1,879,736.4	466.7	0.0	0.0
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/27/2020 00:00	46.5	16.7	65.3	264.9	1,863,054.1	585.0	4.3	1.0
11/27/2020 01:00	42.8	15.0	42.8	267.3	2,231,477.0	977.7	3.9	1.5
11/27/2020 02:00	8.3	13.9	7.0	94.4	2,802,112.3	1,452.8	1.1	0.6
11/27/2020 03:00	8.5	14.0	7.3	86.4	2,718,789.6	1,409.6	1.0	0.6
11/27/2020 04:00	8.4	13.9	7.1	100.8	3,156,903.6	1,659.8	1.1	0.7
11/27/2020 05:00	8.8	13.9	7.4	96.5	2,812,334.8	1,458.1	1.1	0.6
11/27/2020 06:00	8.5	13.9	7.2	105.1	3,247,437.8	1,707.4	1.1	0.7
11/27/2020 07:00	8.5	13.9	7.2	100.6	3,111,486.5	1,613.2	1.1	0.6
11/27/2020 08:00	8.4	13.9	7.1	99.9	3,085,769.6	1,622.4	1.1	0.6
11/27/2020 09:00	8.4	13.9	7.1	104.8	3,252,002.5	1,709.8	1.1	0.7
11/27/2020 10:00	8.4	13.9	7.1	104.2	3,268,295.2	1,694.5	1.1	0.7
11/27/2020 11:00	8.4	13.9	7.1	104.6	3,295,876.6	1,708.8	1.1	0.7
11/27/2020 12:00	8.3	13.9	7.0	103.9	3,275,045.9	1,698.0	1.1	0.7
11/27/2020 13:00	8.4	13.9	7.1	100.4	3,138,103.5	1,627.0	1.1	0.7
11/27/2020 14:00	8.4	13.9	7.1	102.6	3,214,096.9	1,666.4	1.1	0.7
11/27/2020 15:00	8.8	13.9	7.4	98.9	3,059,216.9	1,586.1	1.1	0.6
11/27/2020 16:00	10.8	13.5	8.6	155.0	3,337,220.4	1,998.3	1.6	1.2
11/27/2020 17:00	10.7	13.4	8.4	167.5	3,283,039.3	2,109.7	1.7	1.5
11/27/2020 18:00	10.6	13.4	8.3	166.0	3,301,586.6	2,073.4	1.7	1.5
11/27/2020 19:00	10.4	13.4	8.2	163.7	3,294,739.5	2,069.1	1.7	1.4
11/27/2020 20:00	9.3	13.5	7.4	142.1	3,287,443.5	1,992.5	1.5	1.2
11/27/2020 21:00	8.0	13.9	6.7	105.4	3,260,561.4	1,714.3	1.1	0.7
11/27/2020 22:00	8.9	13.7	7.3	125.3	3,341,395.5	1,854.4	1.3	0.9
11/27/2020 23:00	10.3	13.4	8.1	151.8	3,386,603.0	2,052.6	1.5	1.2
Average/Sum#:	12.0	13.9	11.3	129.7	3,084,358.0	1,668.4	1.5	0.9
Minimum:	8.0	13.4	6.7	86.4	1,863,054.1	585.0	1.0	0.6
Maximum:	46.5	16.7	65.3	267.3	3,386,603.0	2,109.7	4.3	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/28/2020 00:00	10.3	13.4	8.1	156.3	3,360,306.6	2,061.2	1.6	1.2
11/28/2020 01:00	8.5	13.7	7.0	120.1	3,378,664.6	1,949.1	1.2	1.0
11/28/2020 02:00	8.1	13.9	6.8	99.3	3,034,606.4	1,595.5	1.1	0.6
11/28/2020 03:00	8.5	13.8	7.1	116.2	3,303,015.6	1,833.1	1.2	0.9
11/28/2020 04:00	8.3	13.7	6.8	111.5	3,381,958.2	1,951.0	1.1	0.8
11/28/2020 05:00	9.7	13.6	7.8	127.9	3,373,919.3	1,971.0	1.3	1.0
11/28/2020 06:00	8.3	13.9	7.0	105.8	3,240,971.0	1,704.0	1.1	0.7
11/28/2020 07:00	8.2	13.9	6.9	101.8	3,134,270.1	1,647.9	1.1	0.7
11/28/2020 08:00	8.2	13.9	6.9	104.0	3,217,386.5	1,691.6	1.1	0.7
11/28/2020 09:00	8.3	13.9	7.0	96.6	2,978,117.6	1,565.8	1.1	0.6
11/28/2020 10:00	8.3	13.9	7.0	101.1	3,113,918.9	1,637.2	1.1	0.7
11/28/2020 11:00	8.4	13.9	7.1	104.4	3,280,832.2	1,701.0	1.1	0.7
11/28/2020 12:00	8.4	13.9	7.1	104.6	3,291,633.3	1,706.6	1.1	0.7
11/28/2020 13:00	8.3	13.9	7.0	96.5	3,006,947.3	1,559.0	1.1	0.6
11/28/2020 14:00	8.3	13.9	7.0	100.3	3,161,441.6	1,639.1	1.1	0.7
11/28/2020 15:00	9.2	13.8	7.6	122.5	3,165,591.0	1,710.6	1.3	0.9
11/28/2020 16:00	10.8	13.5	8.6	165.0	3,302,890.5	2,050.1	1.7	1.4
11/28/2020 17:00	10.5	13.4	8.3	173.2	3,252,152.1	2,113.6	1.8	1.5
11/28/2020 18:00	10.3	13.4	8.1	180.6	3,276,880.4	2,153.6	1.9	1.5
11/28/2020 19:00	10.3	13.4	8.1	181.3	3,271,859.2	2,150.3	1.9	1.5
11/28/2020 20:00	10.3	13.4	8.1	199.0	3,258,641.0	2,213.0	2.1	1.8
11/28/2020 21:00	8.3	13.7	6.8	130.4	3,203,048.5	1,824.4	1.4	0.9
11/28/2020 22:00	8.5	13.7	7.0	121.3	3,330,404.1	1,848.3	1.2	0.9
11/28/2020 23:00	10.0	13.4	7.9	151.0	3,372,207.5	2,068.5	1.5	1.2
Average/Sum#:	9.0	13.7	7.4	127.9	3,237,152.6	1,847.7	1.3	1.0
Minimum:	8.1	13.4	6.8	96.5	2,978,117.6	1,559.0	1.1	0.6
Maximum:	10.8	13.9	8.6	199.0	3,381,958.2	2,213.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/29/2020 00:00	8.4	13.7	6.9	118.6	3,351,276.2	1,933.3	1.2	1.0
11/29/2020 01:00	7.9	13.9	6.7	99.0	3,002,653.2	1,578.7	1.1	0.6
11/29/2020 02:00	9.2	13.7	7.5	127.7	3,320,231.7	1,866.9	1.3	0.9
11/29/2020 03:00	10.0	13.5	8.0	156.1	3,364,056.2	2,063.5	1.6	1.2
11/29/2020 04:00	9.6	13.5	7.7	151.0	3,299,829.4	2,048.2	1.6	1.2
11/29/2020 05:00	7.8	13.9	6.6	116.3	3,256,567.3	1,712.2	1.2	0.9
11/29/2020 06:00	8.2	13.9	6.9	104.5	3,204,643.3	1,684.9	1.1	0.7
11/29/2020 07:00	8.1	13.9	6.8	99.6	3,061,043.9	1,609.4	1.1	0.6
11/29/2020 08:00	8.2	13.9	6.9	100.8	3,141,307.4	1,651.6	1.1	0.7
11/29/2020 09:00	8.3	13.9	7.0	98.6	3,042,594.7	1,599.7	1.1	0.6
11/29/2020 10:00	8.3	13.9	7.0	104.2	3,237,357.3	1,702.1	1.1	0.7
11/29/2020 11:00	8.3	13.9	7.0	103.2	3,191,329.4	1,677.9	1.1	0.7
11/29/2020 12:00	8.3	13.9	7.0	103.6	3,218,717.9	1,692.3	1.1	0.7
11/29/2020 13:00	8.3	13.9	7.0	103.4	3,212,441.4	1,689.0	1.1	0.7
11/29/2020 14:00	8.3	13.9	7.0	102.3	3,219,111.7	1,669.0	1.1	0.7
11/29/2020 15:00	8.2	13.9	6.9	103.3	3,254,601.0	1,687.4	1.1	0.7
11/29/2020 16:00	9.4	13.7	7.7	130.7	3,248,871.6	1,850.5	1.4	0.9
11/29/2020 17:00	10.5	13.4	8.3	169.1	3,290,926.8	2,138.8	1.8	1.5
11/29/2020 18:00	10.4	13.3	8.1	192.5	3,266,739.8	2,218.5	2.1	1.8
11/29/2020 19:00	9.7	13.4	7.6	180.1	3,227,124.6	2,120.9	1.9	1.5
11/29/2020 20:00	7.8	13.9	6.6	103.7	3,236,406.3	1,701.6	1.1	0.7
11/29/2020 21:00	9.0	13.7	7.4	125.4	3,296,044.4	1,853.3	1.3	0.9
11/29/2020 22:00	10.2	13.4	8.0	167.8	3,306,313.6	2,148.8	1.7	1.5
11/29/2020 23:00	9.7	13.4	7.6	156.8	3,352,028.7	2,080.6	1.6	1.2
Average/Sum#:	8.8	13.7	7.3	125.8	3,233,425.7	1,832.5	1.3	0.9
Minimum:	7.8	13.3	6.6	98.6	3,002,653.2	1,578.7	1.1	0.6
Maximum:	10.5	13.9	8.3	192.5	3,364,056.2	2,218.5	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/30/2020 00:00	9.8	13.4	7.7	154.5	3,377,483.9	2,096.4	1.6	1.3
11/30/2020 01:00	9.5	13.5	7.6	151.1	3,318,518.1	2,059.8	1.6	1.2
11/30/2020 02:00	7.8	13.9	6.6	97.8	3,009,500.3	1,582.3	1.1	0.6
11/30/2020 03:00	8.0	13.9	6.7	95.8	2,957,766.5	1,555.1	1.1	0.6
11/30/2020 04:00	8.9	13.7	7.3	121.9	3,214,723.7	1,784.1	1.3	0.9
11/30/2020 05:00	10.1	13.4	7.9	161.1	3,356,663.8	2,132.5	1.6	1.3
11/30/2020 06:00	10.3	13.4	8.1	158.0	3,336,104.5	2,143.8	1.6	1.3
11/30/2020 07:00	10.2	13.4	8.0	167.3	3,314,318.2	2,129.8	1.7	1.5
11/30/2020 08:00	9.5	13.5	7.6	148.8	3,318,349.1	1,987.0	1.5	1.2
11/30/2020 09:00	7.9	13.9	6.7	109.4	3,200,268.7	1,682.6	1.1	0.7
11/30/2020 10:00	8.2	13.9	6.9	97.6	2,999,039.4	1,576.8	1.1	0.6
11/30/2020 11:00	8.2	13.9	6.9	101.6	3,131,417.1	1,646.4	1.1	0.7
11/30/2020 12:00	8.2	13.9	6.9	100.8	3,146,590.1	1,631.4	1.1	0.7
11/30/2020 13:00	8.4	13.9	7.1	89.0	2,761,994.0	1,432.0	1.1	0.6
11/30/2020 14:00	8.3	13.9	7.0	102.9	3,241,678.3	1,680.7	1.1	0.7
11/30/2020 15:00	9.1	13.8	7.6	115.6	3,162,445.0	1,708.9	1.2	0.9
11/30/2020 16:00	10.7	13.4	8.4	161.3	3,300,949.7	2,073.0	1.7	1.5
11/30/2020 17:00	10.4	13.4	8.2	179.2	3,247,341.6	2,157.9	1.9	1.5
11/30/2020 18:00	10.3	13.4	8.1	186.0	3,267,356.3	2,171.2	2.0	1.7
11/30/2020 19:00	10.5	13.3	8.2	202.9	3,251,508.8	2,231.9	2.2	1.8
11/30/2020 20:00	10.3	13.4	8.1	185.9	3,294,074.3	2,164.9	2.0	1.7
11/30/2020 21:00	10.3	13.4	8.1	184.7	3,284,944.8	2,158.9	2.0	1.7
11/30/2020 22:00	10.2	13.4	8.0	174.9	3,305,915.0	2,124.4	1.8	1.5
11/30/2020 23:00	10.2	13.4	8.0	161.8	3,304,018.3	2,050.8	1.7	1.4
Average/Sum#:	9.4	13.6	7.6	142.1	3,212,623.7	1,915.1	1.5	1.2
Minimum:	7.8	13.3	6.6	89.0	2,761,994.0	1,432.0	1.1	0.6
Maximum:	10.7	13.9	8.4	202.9	3,377,483.9	2,231.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/01/2020 00:00	10.1	13.4	7.9	162.2	3,307,637.6	2,077.2	1.7	1.5
12/01/2020 01:00	9.8	13.4	7.7	162.4	3,249,628.3	2,064.5	1.7	1.4
12/01/2020 02:00	7.8	13.9	6.6	97.7	2,989,339.3	1,571.7	1.1	0.6
12/01/2020 03:00	8.9	13.7	7.3	125.4	3,290,353.3	1,850.1	1.3	0.9
12/01/2020 04:00	10.4	13.4	8.2	168.5	3,282,771.8	2,133.5	1.8	1.5
12/01/2020 05:00	10.4	13.3	8.1	174.6	3,197,822.2	2,218.4	1.9	1.6
12/01/2020 06:00	10.8	13.3	8.4	203.9	3,231,413.6	2,265.3	2.2	1.8
12/01/2020 07:00	10.3	13.4	8.1	189.6	3,285,866.1	2,183.5	2.0	1.7
12/01/2020 08:00	10.1	13.4	7.9	174.1	3,271,231.7	2,126.0	1.8	1.5
12/01/2020 09:00	8.0	13.8	6.6	108.2	3,222,086.7	1,717.6	1.1	0.7
12/01/2020 10:00	8.0	13.9	6.7	104.8	3,283,339.6	1,702.3	1.1	0.7
12/01/2020 11:00	8.1	13.9	6.8	103.5	3,231,841.5	1,675.6	1.1	0.7
12/01/2020 12:00	8.1	13.9	6.8	104.3	3,254,601.0	1,687.4	1.1	0.7
12/01/2020 13:00	8.5	14.0	7.3	91.1	2,756,260.0	1,408.9	1.1	0.6
12/01/2020 14:00	8.3	14.0	7.1	100.3	3,112,643.8	1,613.8	1.1	0.6
12/01/2020 15:00	8.7	13.9	7.3	101.8	2,993,060.2	1,551.8	1.1	0.6
12/01/2020 16:00	10.9	13.5	8.7	166.9	3,267,285.5	2,028.0	1.7	1.4
12/01/2020 17:00	10.7	13.4	8.4	198.7	3,219,914.3	2,186.7	2.2	1.7
12/01/2020 18:00	10.4	13.3	8.1	208.8	3,224,201.6	2,236.7	2.3	2.0
12/01/2020 19:00	10.3	13.4	8.1	209.5	3,224,345.7	2,236.8	2.3	2.0
12/01/2020 20:00	10.1	13.3	7.8	205.6	3,238,760.7	2,246.8	2.2	1.8
12/01/2020 21:00	10.0	13.3	7.8	200.3	3,240,202.2	2,247.8	2.2	1.8
12/01/2020 22:00	10.1	13.3	7.8	200.2	3,256,899.1	2,235.6	2.2	1.8
12/01/2020 23:00	9.9	13.4	7.8	175.7	3,309,898.7	2,175.3	1.8	1.5
Average/Sum#:	9.5	13.6	7.6	155.8	3,205,891.9	1,976.7	1.7	1.3
Minimum:	7.8	13.3	6.6	91.1	2,756,260.0	1,408.9	1.1	0.6
Maximum:	10.9	14.0	8.7	209.5	3,309,898.7	2,265.3	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/02/2020 00:00	9.9	13.4	7.8	171.0	3,342,951.7	2,148.2	1.8	1.5
12/02/2020 01:00	9.2	13.5	7.3	143.9	3,311,862.1	2,007.3	1.5	1.2
12/02/2020 02:00	7.9	13.9	6.7	96.8	3,004,935.5	1,579.9	1.1	0.6
12/02/2020 03:00	9.0	13.7	7.4	125.7	3,261,863.5	1,857.9	1.3	0.9
12/02/2020 04:00	10.4	13.4	8.2	164.0	3,330,886.0	2,091.8	1.7	1.5
12/02/2020 05:00	10.2	13.4	8.0	176.3	3,304,203.2	2,123.3	1.8	1.5
12/02/2020 06:00	10.4	13.4	8.2	168.2	3,320,469.5	2,158.0	1.7	1.5
12/02/2020 07:00	10.1	13.4	7.9	172.9	3,333,770.3	2,142.3	1.8	1.5
12/02/2020 08:00	9.9	13.4	7.8	159.0	3,350,900.9	2,079.9	1.6	1.2
12/02/2020 09:00	8.0	13.9	6.7	105.5	3,040,122.1	1,598.4	1.2	0.8
12/02/2020 10:00	8.1	13.9	6.8	102.8	3,233,384.6	1,676.4	1.1	0.7
12/02/2020 11:00	8.1	13.9	6.8	105.0	3,303,591.7	1,712.8	1.1	0.7
12/02/2020 12:00	8.1	14.0	6.9	102.8	3,216,025.7	1,667.4	1.1	0.7
12/02/2020 13:00	8.2	14.0	7.0	96.5	3,004,247.1	1,557.6	1.1	0.6
12/02/2020 14:00	8.4	13.9	7.1	98.7	3,068,667.9	1,591.0	1.1	0.6
12/02/2020 15:00	10.1	13.6	8.2	146.7	3,259,756.7	1,856.7	1.5	1.1
12/02/2020 16:00	10.6	13.3	8.2	168.6	3,280,463.8	2,132.0	1.8	1.5
12/02/2020 17:00	10.4	13.3	8.1	183.3	3,274,263.9	2,199.7	1.9	1.5
12/02/2020 18:00	10.3	13.3	8.0	194.9	3,267,971.0	2,243.2	2.1	1.8
12/02/2020 19:00	10.3	13.3	8.0	197.2	3,250,052.0	2,230.9	2.1	1.8
12/02/2020 20:00	10.4	13.4	8.2	195.7	3,257,890.4	2,188.7	2.1	1.8
12/02/2020 21:00	10.4	13.4	8.2	190.4	3,263,142.7	2,168.4	2.0	1.7
12/02/2020 22:00	10.1	13.4	7.9	174.7	3,305,698.1	2,148.4	1.8	1.5
12/02/2020 23:00	10.3	13.4	8.1	176.2	3,300,312.8	2,144.9	1.8	1.5
Average/Sum#:	9.5	13.6	7.6	150.7	3,245,309.7	1,971.0	1.6	1.2
Minimum:	7.9	13.3	6.7	96.5	3,004,247.1	1,557.6	1.1	0.6
Maximum:	10.6	14.0	8.2	197.2	3,350,900.9	2,243.2	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/03/2020 00:00	10.2	13.4	8.0	175.3	3,313,695.8	2,129.4	1.8	1.5
12/03/2020 01:00	10.2	13.4	8.0	173.6	3,351,312.0	2,129.1	1.8	1.5
12/03/2020 02:00	9.9	13.5	7.9	162.8	3,273,561.2	2,055.8	1.7	1.4
12/03/2020 03:00	7.8	13.9	6.6	99.2	3,063,706.7	1,610.8	1.1	0.6
12/03/2020 04:00	8.8	13.7	7.2	126.9	3,302,269.1	1,856.8	1.3	0.9
12/03/2020 05:00	10.3	13.4	8.1	168.0	3,308,775.5	2,150.4	1.7	1.5
12/03/2020 06:00	10.7	13.3	8.3	195.1	3,299,293.0	2,264.7	2.1	1.8
12/03/2020 07:00	10.1	13.4	7.9	167.5	3,327,701.3	2,138.4	1.7	1.5
12/03/2020 08:00	10.1	13.4	7.9	164.8	3,347,605.7	2,102.3	1.7	1.5
12/03/2020 09:00	9.0	13.5	7.2	133.3	3,345,114.9	1,978.6	1.4	1.0
12/03/2020 10:00	7.9	13.9	6.7	105.9	3,243,253.4	1,705.2	1.1	0.7
12/03/2020 11:00	8.1	13.9	6.8	103.7	3,148,725.1	1,655.5	1.1	0.7
12/03/2020 12:00	8.2	13.9	6.9	105.7	3,261,351.7	1,690.9	1.1	0.7
12/03/2020 13:00	8.3	13.9	7.0	105.9	3,262,701.8	1,691.6	1.1	0.7
12/03/2020 14:00	9.0	13.7	7.4	123.6	3,326,079.6	1,845.9	1.3	0.9
12/03/2020 15:00	10.3	13.4	8.1	153.9	3,332,319.1	2,092.7	1.6	1.3
12/03/2020 16:00	10.2	13.3	7.9	173.2	3,313,246.2	2,177.5	1.8	1.5
12/03/2020 17:00	10.2	13.3	7.9	189.1	3,273,513.3	2,223.1	2.0	1.8
12/03/2020 18:00	10.2	13.3	7.9	204.8	3,250,725.2	2,255.1	2.2	1.8
12/03/2020 19:00	10.0	13.3	7.8	204.7	3,254,761.4	2,257.9	2.2	1.8
12/03/2020 20:00	9.9	13.4	7.8	185.0	3,250,894.4	2,184.0	2.0	1.7
12/03/2020 21:00	10.0	13.3	7.8	194.4	3,266,298.0	2,218.2	2.1	1.8
12/03/2020 22:00	9.9	13.4	7.8	186.7	3,269,203.0	2,196.3	2.0	1.8
12/03/2020 23:00	9.6	13.4	7.6	168.3	3,314,622.5	2,154.2	1.8	1.5
Average/Sum#:	9.5	13.5	7.6	157.1	3,279,197.1	2,031.9	1.7	1.3
Minimum:	7.8	13.3	6.6	99.2	3,063,706.7	1,610.8	1.1	0.6
Maximum:	10.7	13.9	8.3	204.8	3,351,312.0	2,264.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/04/2020 00:00	9.8	13.4	7.7	168.2	3,379,802.3	2,147.2	1.7	1.5
12/04/2020 01:00	9.5	13.5	7.6	158.0	3,298,720.4	2,071.6	1.7	1.5
12/04/2020 02:00	7.6	13.9	6.4	103.1	3,231,271.0	1,698.9	1.1	0.7
12/04/2020 03:00	8.9	13.7	7.3	126.8	3,315,251.9	1,864.1	1.3	0.9
12/04/2020 04:00	10.2	13.4	8.0	165.9	3,334,548.4	2,142.8	1.7	1.5
12/04/2020 05:00	10.1	13.4	7.9	182.4	3,231,841.5	2,242.0	2.0	1.8
12/04/2020 06:00	10.5	13.3	8.2	201.4	3,288,492.5	2,281.3	2.1	1.8
12/04/2020 07:00	9.9	13.3	7.7	182.7	3,312,369.7	2,225.3	1.9	1.6
12/04/2020 08:00	9.8	13.4	7.7	155.8	3,391,822.5	2,105.3	1.6	1.3
12/04/2020 09:00	9.2	13.5	7.3	142.6	3,320,854.1	1,988.5	1.5	1.2
12/04/2020 10:00	7.8	13.9	6.6	99.4	3,144,661.3	1,630.4	1.1	0.7
12/04/2020 11:00	8.4	13.9	7.1	98.4	3,111,486.5	1,613.2	1.0	0.6
12/04/2020 12:00	9.4	13.6	7.6	132.5	3,355,436.4	1,935.7	1.3	1.0
12/04/2020 13:00	9.0	13.6	7.3	120.8	3,327,354.6	1,919.5	1.2	1.0
12/04/2020 14:00	8.2	13.8	6.8	103.2	3,186,764.7	1,675.5	1.1	0.7
12/04/2020 15:00	9.1	13.6	7.4	123.0	3,235,932.0	1,819.5	1.3	0.9
12/04/2020 16:00	10.4	13.3	8.1	165.2	3,315,407.6	2,130.5	1.7	1.5
12/04/2020 17:00	10.2	13.3	7.9	182.3	3,263,353.0	2,216.2	1.9	1.6
12/04/2020 18:00	10.0	13.3	7.8	183.9	3,255,254.3	2,210.7	2.0	1.8
12/04/2020 19:00	10.1	13.3	7.8	196.1	3,232,861.3	2,219.1	2.1	1.8
12/04/2020 20:00	10.0	13.3	7.8	195.4	3,263,353.0	2,216.2	2.1	1.8
12/04/2020 21:00	10.1	13.3	7.8	202.2	3,252,965.6	2,232.9	2.2	1.8
12/04/2020 22:00	9.8	13.4	7.7	183.4	3,289,778.7	2,186.1	1.9	1.5
12/04/2020 23:00	9.8	13.4	7.7	170.1	3,313,237.7	2,153.3	1.8	1.5
Average/Sum#:	9.5	13.5	7.6	156.0	3,277,200.9	2,038.6	1.6	1.3
Minimum:	7.6	13.3	6.4	98.4	3,111,486.5	1,613.2	1.0	0.6
Maximum:	10.5	13.9	8.2	202.2	3,391,822.5	2,281.3	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/05/2020 00:00	9.8	13.4	7.7	171.7	3,328,470.6	2,163.2	1.8	1.5
12/05/2020 01:00	9.8	13.4	7.7	162.9	3,308,716.1	2,126.2	1.7	1.5
12/05/2020 02:00	10.0	13.4	7.9	168.7	3,335,793.3	2,143.6	1.7	1.5
12/05/2020 03:00	9.8	13.4	7.7	166.2	3,342,484.8	2,147.9	1.7	1.5
12/05/2020 04:00	9.7	13.4	7.6	159.8	3,335,482.1	2,143.4	1.7	1.5
12/05/2020 05:00	10.0	13.4	7.9	169.0	3,344,819.1	2,149.4	1.7	1.5
12/05/2020 06:00	9.9	13.4	7.8	153.2	3,320,058.0	2,085.0	1.6	1.3
12/05/2020 07:00	7.8	13.9	6.6	102.7	3,188,666.6	1,676.5	1.1	0.7
12/05/2020 08:00	8.2	13.9	6.9	100.3	3,100,985.4	1,630.4	1.1	0.7
12/05/2020 09:00	8.2	13.9	6.9	103.5	3,210,159.0	1,687.8	1.1	0.7
12/05/2020 10:00	8.3	13.9	7.0	103.1	3,203,502.1	1,684.3	1.1	0.7
12/05/2020 11:00	8.3	13.9	7.0	104.7	3,256,757.5	1,712.3	1.1	0.7
12/05/2020 12:00	8.3	13.9	7.0	104.4	3,238,878.9	1,702.9	1.1	0.7
12/05/2020 13:00	8.2	13.9	6.9	102.2	3,168,695.9	1,666.0	1.1	0.7
12/05/2020 14:00	8.3	13.9	7.0	101.4	3,138,454.4	1,650.1	1.1	0.7
12/05/2020 15:00	9.6	13.7	7.9	130.3	3,271,857.2	1,839.7	1.3	0.9
12/05/2020 16:00	10.5	13.4	8.3	161.2	3,315,121.7	2,081.9	1.7	1.5
12/05/2020 17:00	10.3	13.3	8.0	179.4	3,289,929.2	2,186.2	1.9	1.5
12/05/2020 18:00	10.3	13.3	8.0	194.6	3,256,607.7	2,235.4	2.1	1.8
12/05/2020 19:00	10.3	13.3	8.0	202.4	3,251,878.4	2,255.9	2.2	1.8
12/05/2020 20:00	9.9	13.3	7.7	198.7	3,283,996.2	2,254.2	2.1	1.8
12/05/2020 21:00	9.9	13.3	7.7	193.8	3,300,312.8	2,241.3	2.1	1.8
12/05/2020 22:00	10.0	13.4	7.9	170.9	3,304,621.1	2,147.7	1.8	1.5
12/05/2020 23:00	9.9	13.4	7.8	167.5	3,329,879.9	2,139.8	1.7	1.5
Average/Sum#:	9.4	13.6	7.5	148.9	3,267,755.3	1,989.6	1.6	1.3
Minimum:	7.8	13.3	6.6	100.3	3,100,985.4	1,630.4	1.1	0.7
Maximum:	10.5	13.9	8.3	202.4	3,344,819.1	2,255.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/06/2020 00:00	9.9	13.4	7.8	165.2	3,361,385.9	2,135.5	1.7	1.5
12/06/2020 01:00	9.8	13.4	7.7	153.7	3,373,939.5	2,094.2	1.6	1.3
12/06/2020 02:00	9.9	13.4	7.8	155.5	3,360,245.2	2,085.7	1.6	1.3
12/06/2020 03:00	9.0	13.6	7.3	127.7	3,322,609.8	1,892.5	1.3	0.9
12/06/2020 04:00	8.3	13.8	6.9	112.8	3,344,541.5	1,807.3	1.1	0.7
12/06/2020 05:00	9.8	13.4	7.7	150.2	3,294,835.1	2,045.1	1.6	1.2
12/06/2020 06:00	9.2	13.6	7.4	128.3	3,282,777.5	1,965.7	1.3	1.0
12/06/2020 07:00	8.3	13.9	7.0	102.2	2,985,915.8	1,569.9	1.1	0.6
12/06/2020 08:00	8.4	13.9	7.1	101.3	2,989,149.1	1,571.6	1.1	0.6
12/06/2020 09:00	8.3	13.9	7.0	109.1	3,243,253.4	1,705.2	1.1	0.7
12/06/2020 10:00	8.2	13.9	6.9	108.7	3,237,547.5	1,702.2	1.1	0.7
12/06/2020 11:00	8.2	13.9	6.9	108.9	3,288,933.0	1,705.2	1.1	0.7
12/06/2020 12:00	8.3	13.9	7.0	104.8	3,145,047.0	1,630.6	1.1	0.7
12/06/2020 13:00	8.2	13.9	6.9	108.2	3,265,980.7	1,693.3	1.1	0.7
12/06/2020 14:00	8.2	13.9	6.9	106.6	3,213,904.0	1,666.3	1.1	0.7
12/06/2020 15:00	9.4	13.6	7.6	121.5	3,327,160.7	1,846.5	1.2	0.9
12/06/2020 16:00	10.4	13.4	8.2	157.3	3,350,312.7	2,104.0	1.6	1.3
12/06/2020 17:00	10.2	13.3	7.9	179.4	3,297,038.1	2,215.0	1.9	1.6
12/06/2020 18:00	10.1	13.3	7.8	191.1	3,281,082.6	2,252.2	2.0	1.8
12/06/2020 19:00	9.9	13.3	7.7	187.2	3,287,638.3	2,256.7	2.0	1.8
12/06/2020 20:00	9.9	13.3	7.7	184.7	3,285,016.0	2,254.9	2.0	1.8
12/06/2020 21:00	9.8	13.3	7.6	173.4	3,287,809.3	2,208.8	1.8	1.5
12/06/2020 22:00	9.8	13.3	7.6	162.2	3,296,466.1	2,142.4	1.7	1.5
12/06/2020 23:00	10.0	13.4	7.9	156.7	3,314,973.7	2,057.6	1.6	1.2
Average/Sum#:	9.2	13.6	7.4	139.9	3,268,231.8	1,942.0	1.5	1.1
Minimum:	8.2	13.3	6.9	101.3	2,985,915.8	1,569.9	1.1	0.6
Maximum:	10.4	13.9	8.2	191.1	3,373,939.5	2,256.7	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/07/2020 00:00	10.2	13.4	8.0	164.8	3,305,664.5	2,100.1	1.7	1.5
12/07/2020 01:00	10.0	13.5	8.0	153.9	3,283,648.7	1,990.2	1.6	1.2
12/07/2020 02:00	7.8	13.9	6.6	99.4	3,086,340.2	1,622.7	1.1	0.6
12/07/2020 03:00	9.1	13.7	7.5	126.6	3,263,498.4	1,835.0	1.3	0.9
12/07/2020 04:00	10.4	13.4	8.2	159.7	3,302,382.8	2,073.9	1.7	1.5
12/07/2020 05:00	10.3	13.4	8.1	157.2	3,304,720.1	2,099.5	1.6	1.3
12/07/2020 06:00	10.6	13.3	8.2	184.6	3,274,263.9	2,199.7	2.0	1.8
12/07/2020 07:00	10.3	13.4	8.1	190.2	3,264,737.5	2,193.3	2.0	1.8
12/07/2020 08:00	10.1	13.4	7.9	184.9	3,271,720.4	2,174.1	2.0	1.7
12/07/2020 09:00	10.2	13.4	8.0	185.1	3,247,191.1	2,157.8	2.0	1.7
12/07/2020 10:00	8.2	13.8	6.8	114.4	3,154,857.7	1,704.8	1.2	0.9
12/07/2020 11:00	8.0	13.9	6.7	97.1	3,094,513.4	1,604.4	1.0	0.6
12/07/2020 12:00	8.1	14.0	6.9	97.2	3,090,655.8	1,602.4	1.0	0.6
12/07/2020 13:00	8.2	14.0	7.0	101.8	3,241,292.5	1,680.5	1.0	0.7
12/07/2020 14:00	10.0	13.7	8.2	129.3	3,077,370.5	1,685.4	1.4	0.8
12/07/2020 15:00	10.8	13.5	8.6	178.8	3,229,351.7	2,075.2	1.9	1.5
12/07/2020 16:00	10.8	13.4	8.5	192.1	3,227,733.3	2,121.3	2.1	1.7
12/07/2020 17:00	10.6	13.4	8.3	203.5	3,201,248.0	2,197.4	2.2	1.8
12/07/2020 18:00	9.7	13.3	7.5	170.6	3,276,235.0	2,177.1	1.8	1.5
12/07/2020 19:00	9.8	13.3	7.6	169.3	3,287,371.0	2,184.5	1.8	1.5
12/07/2020 20:00	9.9	13.3	7.7	178.0	3,285,874.3	2,207.5	1.9	1.5
12/07/2020 21:00	9.9	13.3	7.7	185.3	3,289,121.8	2,233.7	2.0	1.8
12/07/2020 22:00	9.8	13.3	7.6	174.5	3,301,366.2	2,193.8	1.8	1.5
12/07/2020 23:00	9.8	13.4	7.7	157.1	3,312,118.1	2,104.2	1.6	1.3
Average/Sum#:	9.7	13.5	7.7	156.5	3,236,386.5	2,009.1	1.7	1.3
Minimum:	7.8	13.3	6.6	97.1	3,077,370.5	1,602.4	1.0	0.6
Maximum:	10.8	14.0	8.6	203.5	3,312,118.1	2,233.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/08/2020 00:00	9.9	13.4	7.8	153.8	3,310,503.8	2,079.0	1.6	1.2
12/08/2020 01:00	9.3	13.5	7.4	134.8	3,341,053.1	1,951.8	1.4	1.0
12/08/2020 02:00	8.2	13.8	6.8	103.1	3,172,880.2	1,668.2	1.1	0.7
12/08/2020 03:00	9.4	13.6	7.6	128.5	3,267,879.0	1,813.6	1.3	0.9
12/08/2020 04:00	10.2	13.4	8.0	150.0	3,339,765.2	2,048.6	1.5	1.2
12/08/2020 05:00	9.8	13.4	7.7	162.3	3,396,857.2	1,984.4	1.6	1.2
12/08/2020 06:00	10.5	13.4	8.3	151.9	3,335,663.0	2,094.8	1.5	1.3
12/08/2020 07:00	10.6	13.4	8.3	183.4	3,254,361.0	2,138.8	2.0	1.7
12/08/2020 08:00	10.2	13.4	8.0	167.4	3,281,581.6	2,084.8	1.8	1.5
12/08/2020 09:00	9.7	13.5	7.7	149.7	3,316,373.9	1,961.6	1.5	1.2
12/08/2020 10:00	7.8	13.9	6.6	102.4	3,205,031.7	1,661.7	1.1	0.7
12/08/2020 11:00	8.1	13.9	6.8	97.0	3,071,946.8	1,592.7	1.1	0.6
12/08/2020 12:00	8.2	13.9	6.9	99.0	3,112,258.0	1,613.6	1.1	0.6
12/08/2020 13:00	8.2	13.9	6.9	96.5	3,045,908.4	1,579.2	1.1	0.6
12/08/2020 14:00	8.3	13.9	7.0	95.7	3,002,125.4	1,556.5	1.1	0.6
12/08/2020 15:00	9.4	13.8	7.8	122.3	3,135,434.1	1,717.2	1.3	0.9
12/08/2020 16:00	10.6	13.4	8.3	160.3	3,257,000.7	2,045.4	1.7	1.4
12/08/2020 17:00	10.4	13.3	8.1	192.1	3,237,584.3	2,198.7	2.1	1.8
12/08/2020 18:00	10.2	13.3	7.9	199.4	3,234,755.2	2,220.4	2.2	1.8
12/08/2020 19:00	10.1	13.3	7.8	204.8	3,213,725.2	2,252.9	2.2	1.8
12/08/2020 20:00	9.9	13.3	7.7	190.0	3,250,542.3	2,207.5	2.0	1.8
12/08/2020 21:00	10.0	13.4	7.9	178.5	3,304,116.7	2,171.5	1.9	1.5
12/08/2020 22:00	9.7	13.4	7.6	165.1	3,350,839.8	2,128.8	1.7	1.5
12/08/2020 23:00	9.9	13.4	7.8	157.1	3,357,667.5	2,084.1	1.6	1.3
Average/Sum#:	9.5	13.5	7.6	147.7	3,241,493.9	1,952.3	1.6	1.2
Minimum:	7.8	13.3	6.6	95.7	3,002,125.4	1,556.5	1.1	0.6
Maximum:	10.6	13.9	8.3	204.8	3,396,857.2	2,252.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/09/2020 00:00	10.1	13.4	7.9	158.5	3,318,624.8	2,084.1	1.6	1.3
12/09/2020 01:00	9.8	13.4	7.7	150.8	3,333,017.8	2,068.8	1.5	1.2
12/09/2020 02:00	8.1	13.7	6.6	115.5	3,323,593.0	1,941.6	1.2	1.0
12/09/2020 03:00	8.0	13.8	6.6	106.4	3,342,346.5	1,757.3	1.1	0.7
12/09/2020 04:00	9.2	13.6	7.4	124.7	3,294,088.1	1,852.2	1.3	0.9
12/09/2020 05:00	10.2	13.4	8.0	153.0	3,351,666.2	2,055.9	1.6	1.2
12/09/2020 06:00	10.6	13.4	8.3	162.9	3,310,894.7	2,127.6	1.7	1.5
12/09/2020 07:00	9.9	13.4	7.8	158.6	3,356,506.4	2,132.4	1.6	1.3
12/09/2020 08:00	9.8	13.4	7.7	155.4	3,335,981.5	2,095.0	1.6	1.3
12/09/2020 09:00	9.8	13.5	7.8	146.7	3,323,764.2	1,941.7	1.5	1.2
12/09/2020 10:00	8.2	13.9	6.9	107.9	3,352,046.6	1,762.4	1.1	0.7
12/09/2020 11:00	8.9	13.8	7.4	110.1	3,357,942.7	1,765.5	1.1	0.7
12/09/2020 12:00	9.3	13.8	7.7	115.2	3,351,666.2	1,762.2	1.1	0.7
12/09/2020 13:00	9.4	13.8	7.8	115.6	3,345,009.3	1,758.7	1.1	0.7
12/09/2020 14:00	9.4	13.8	7.8	116.2	3,300,688.0	1,759.5	1.2	0.9
12/09/2020 15:00	10.2	13.6	8.2	138.0	3,224,292.2	1,836.5	1.4	0.9
12/09/2020 16:00	10.9	13.4	8.6	180.0	3,202,045.3	2,127.8	1.9	1.5
12/09/2020 17:00	10.6	13.3	8.2	197.0	3,216,380.3	2,184.3	2.1	1.7
12/09/2020 18:00	10.6	13.3	8.2	194.1	3,211,668.3	2,181.1	2.1	1.7
12/09/2020 19:00	10.1	13.2	7.7	188.3	3,250,926.1	2,231.5	2.0	1.8
12/09/2020 20:00	10.1	13.3	7.8	177.0	3,270,542.7	2,197.2	1.9	1.5
12/09/2020 21:00	10.2	13.2	7.8	197.4	3,265,572.6	2,265.4	2.1	1.8
12/09/2020 22:00	10.1	13.2	7.7	188.9	3,265,494.4	2,241.5	2.0	1.8
12/09/2020 23:00	10.1	13.3	7.8	165.6	3,292,311.6	2,139.7	1.7	1.5
Average/Sum#:	9.7	13.5	7.7	151.0	3,299,877.9	2,011.2	1.6	1.2
Minimum:	8.0	13.2	6.6	106.4	3,202,045.3	1,757.3	1.1	0.7
Maximum:	10.9	13.9	8.6	197.4	3,357,942.7	2,265.4	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/10/2020 00:00	10.0	13.3	7.8	162.8	3,278,925.1	2,131.0	1.7	1.5
12/10/2020 01:00	10.2	13.4	8.0	158.5	3,283,911.5	2,062.3	1.7	1.4
12/10/2020 02:00	10.6	13.4	8.3	176.6	3,218,458.5	2,068.2	1.9	1.4
12/10/2020 03:00	7.8	13.9	6.6	104.4	3,297,419.6	1,709.6	1.1	0.7
12/10/2020 04:00	10.0	13.6	8.1	139.0	3,276,836.9	1,842.5	1.4	0.9
12/10/2020 05:00	11.1	13.4	8.7	176.0	3,210,426.1	2,203.7	1.9	1.5
12/10/2020 06:00	11.0	13.4	8.7	187.4	3,246,428.9	2,181.0	2.0	1.7
12/10/2020 07:00	10.4	13.4	8.2	185.3	3,252,759.1	2,161.5	2.0	1.7
12/10/2020 08:00	10.4	13.4	8.2	191.1	3,272,171.8	2,174.4	2.0	1.7
12/10/2020 09:00	10.5	13.4	8.3	197.9	3,249,554.8	2,183.1	2.1	1.7
12/10/2020 10:00	8.4	13.8	7.0	118.0	3,169,847.3	1,712.9	1.3	0.9
12/10/2020 11:00	8.0	13.9	6.7	99.7	3,165,684.8	1,641.3	1.0	0.7
12/10/2020 12:00	8.2	13.9	6.9	95.0	2,979,751.7	1,544.9	1.1	0.6
12/10/2020 13:00	8.2	13.9	6.9	97.3	3,054,587.9	1,583.7	1.1	0.6
12/10/2020 14:00	8.3	13.9	7.0	94.9	2,985,345.2	1,547.8	1.1	0.6
12/10/2020 15:00	9.6	13.6	7.8	128.5	3,289,819.8	1,849.8	1.3	0.9
12/10/2020 16:00	10.6	13.3	8.2	157.3	3,325,472.0	2,088.4	1.6	1.3
12/10/2020 17:00	10.3	13.3	8.0	173.6	3,289,778.7	2,186.1	1.8	1.5
12/10/2020 18:00	10.5	13.3	8.2	205.5	3,245,824.1	2,251.7	2.2	1.8
12/10/2020 19:00	10.3	13.3	8.0	197.4	3,233,007.0	2,219.2	2.1	1.8
12/10/2020 20:00	10.1	13.3	7.8	178.1	3,277,641.2	2,154.1	1.9	1.5
12/10/2020 21:00	10.1	13.3	7.8	181.4	3,271,569.9	2,174.0	1.9	1.5
12/10/2020 22:00	10.2	13.3	7.9	181.1	3,262,691.2	2,168.1	1.9	1.5
12/10/2020 23:00	10.1	13.4	7.9	163.8	3,279,771.4	2,107.6	1.7	1.5
Average/Sum#:	9.8	13.5	7.8	156.3	3,225,736.9	1,997.8	1.7	1.3
Minimum:	7.8	13.3	6.6	94.9	2,979,751.7	1,544.9	1.0	0.6
Maximum:	11.1	13.9	8.7	205.5	3,325,472.0	2,251.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/11/2020 00:00	9.5	13.5	7.6	138.5	3,328,899.5	1,944.7	1.4	1.0
12/11/2020 01:00	7.9	13.9	6.7	105.1	3,252,382.9	1,710.0	1.1	0.7
12/11/2020 02:00	8.2	13.9	6.9	99.5	3,067,891.0	1,613.0	1.1	0.6
12/11/2020 03:00	8.3	13.8	6.9	99.0	3,055,718.4	1,606.6	1.1	0.6
12/11/2020 04:00	9.3	13.6	7.5	119.8	3,212,020.9	1,782.6	1.3	0.9
12/11/2020 05:00	10.4	13.4	8.2	156.9	3,353,800.9	2,081.7	1.6	1.2
12/11/2020 06:00	10.7	13.4	8.4	173.4	3,349,242.8	2,176.7	1.8	1.5
12/11/2020 07:00	10.4	13.4	8.2	169.6	3,330,813.6	2,140.4	1.8	1.5
12/11/2020 08:00	10.1	13.4	7.9	166.9	3,269,500.7	2,101.0	1.8	1.5
12/11/2020 09:00	7.9	13.9	6.7	103.7	3,195,704.0	1,680.2	1.1	0.7
12/11/2020 10:00	8.1	13.9	6.8	102.5	3,190,188.2	1,677.3	1.1	0.7
12/11/2020 11:00	8.2	13.9	6.9	101.9	3,157,664.4	1,660.2	1.1	0.7
12/11/2020 12:00	8.2	13.9	6.9	101.0	3,113,728.7	1,637.1	1.1	0.7
12/11/2020 13:00	8.3	13.9	7.0	103.2	3,190,188.2	1,677.3	1.1	0.7
12/11/2020 14:00	8.4	13.9	7.1	103.9	3,201,600.1	1,683.3	1.1	0.7
12/11/2020 15:00	9.6	13.6	7.8	126.6	3,315,628.7	1,840.1	1.3	0.9
12/11/2020 16:00	10.7	13.3	8.3	164.9	3,290,157.5	2,138.3	1.7	1.5
12/11/2020 17:00	10.6	13.3	8.2	175.6	3,283,608.8	2,182.0	1.8	1.5
12/11/2020 18:00	10.3	13.2	7.9	198.7	3,293,393.6	2,284.7	2.1	1.8
12/11/2020 19:00	10.2	13.2	7.8	199.9	3,272,353.7	2,294.0	2.1	1.8
12/11/2020 20:00	10.1	13.2	7.7	198.1	3,270,499.3	2,292.7	2.1	1.8
12/11/2020 21:00	10.1	13.2	7.7	195.6	3,268,216.9	2,291.1	2.1	1.8
12/11/2020 22:00	10.0	13.3	7.8	166.8	3,314,311.3	2,178.2	1.7	1.5
12/11/2020 23:00	9.9	13.3	7.7	159.9	3,327,234.4	2,138.1	1.7	1.5
Average/Sum#:	9.4	13.6	7.5	143.0	3,246,031.2	1,950.5	1.5	1.2
Minimum:	7.9	13.2	6.7	99.0	3,055,718.4	1,606.6	1.1	0.6
Maximum:	10.7	13.9	8.4	199.9	3,353,800.9	2,294.0	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/12/2020 00:00	10.1	13.3	7.8	167.8	3,322,469.7	2,159.3	1.7	1.5
12/12/2020 01:00	10.0	13.3	7.8	156.5	3,319,988.4	2,109.2	1.6	1.3
12/12/2020 02:00	8.8	13.5	7.0	122.8	3,311,640.1	1,958.8	1.3	1.0
12/12/2020 03:00	8.3	13.8	6.9	104.0	3,064,696.7	1,633.7	1.1	0.7
12/12/2020 04:00	8.7	13.7	7.1	112.9	3,297,249.6	1,829.9	1.1	0.7
12/12/2020 05:00	8.8	13.6	7.1	115.2	3,399,639.4	1,961.2	1.1	0.8
12/12/2020 06:00	9.0	13.6	7.3	113.5	3,377,971.3	1,948.7	1.1	0.8
12/12/2020 07:00	8.4	13.8	7.0	105.3	3,193,197.5	1,702.2	1.1	0.7
12/12/2020 08:00	8.4	13.8	7.0	104.2	3,196,274.6	1,680.5	1.1	0.7
12/12/2020 09:00	8.4	13.8	7.0	104.9	3,220,239.5	1,693.1	1.1	0.7
12/12/2020 10:00	8.4	13.8	7.0	104.2	3,190,568.6	1,677.5	1.1	0.7
12/12/2020 11:00	8.5	13.8	7.1	99.2	3,030,802.4	1,593.5	1.1	0.6
12/12/2020 12:00	8.4	13.8	7.0	102.0	3,147,393.7	1,654.8	1.1	0.7
12/12/2020 13:00	8.5	13.8	7.1	105.4	3,256,567.3	1,712.2	1.1	0.7
12/12/2020 14:00	8.4	13.9	7.1	103.8	3,204,072.7	1,684.6	1.1	0.7
12/12/2020 15:00	9.7	13.6	7.8	127.3	3,281,460.9	1,845.1	1.3	0.9
12/12/2020 16:00	10.7	13.4	8.4	163.6	3,281,794.4	2,108.9	1.7	1.5
12/12/2020 17:00	10.5	13.3	8.2	185.8	3,266,226.0	2,194.3	2.0	1.8
12/12/2020 18:00	10.4	13.3	8.1	207.8	3,263,554.5	2,264.0	2.2	1.8
12/12/2020 19:00	10.2	13.3	7.9	206.8	3,238,260.7	2,270.1	2.2	1.8
12/12/2020 20:00	10.1	13.3	7.8	205.4	3,234,266.6	2,267.3	2.2	1.8
12/12/2020 21:00	10.1	13.3	7.8	203.1	3,264,707.7	2,264.8	2.2	1.8
12/12/2020 22:00	10.1	13.3	7.8	202.7	3,252,455.0	2,256.3	2.2	1.8
12/12/2020 23:00	9.9	13.3	7.7	171.0	3,281,901.6	2,156.9	1.8	1.5
Average/Sum#:	9.3	13.6	7.5	141.5	3,245,725.0	1,942.8	1.5	1.1
Minimum:	8.3	13.3	6.9	99.2	3,030,802.4	1,593.5	1.1	0.6
Maximum:	10.7	13.9	8.4	207.8	3,399,639.4	2,270.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/13/2020 00:00	9.9	13.3	7.7	173.6	3,291,791.9	2,163.4	1.8	1.5
12/13/2020 01:00	10.0	13.4	7.9	161.6	3,297,322.1	2,094.8	1.7	1.5
12/13/2020 02:00	8.3	13.6	6.7	117.7	3,345,674.9	1,954.5	1.2	1.0
12/13/2020 03:00	8.4	13.6	6.8	112.9	3,342,593.7	1,952.7	1.1	0.8
12/13/2020 04:00	8.6	13.6	7.0	120.8	3,359,711.5	1,962.7	1.2	1.0
12/13/2020 05:00	10.3	13.4	8.1	156.1	3,320,934.7	2,061.3	1.6	1.2
12/13/2020 06:00	10.2	13.4	8.0	146.5	3,288,847.8	2,065.4	1.5	1.2
12/13/2020 07:00	8.4	13.8	7.0	101.6	3,027,928.6	1,614.1	1.1	0.6
12/13/2020 08:00	9.1	13.9	7.7	86.7	2,485,315.1	1,306.7	1.2	0.7
12/13/2020 09:00	9.2	13.9	7.8	86.9	2,486,836.6	1,307.5	1.2	0.7
12/13/2020 10:00	9.0	13.9	7.6	86.5	2,512,513.3	1,321.0	1.1	0.5
12/13/2020 11:00	8.5	13.8	7.1	93.0	2,872,748.0	1,510.4	1.1	0.6
12/13/2020 12:00	8.6	13.8	7.1	104.2	3,154,365.9	1,681.5	1.1	0.7
12/13/2020 13:00	8.6	13.8	7.1	104.8	3,180,441.2	1,695.4	1.1	0.7
12/13/2020 14:00	8.6	13.8	7.1	105.6	3,200,326.0	1,706.0	1.1	0.7
12/13/2020 15:00	9.7	13.6	7.8	124.8	3,247,314.3	1,825.9	1.3	0.9
12/13/2020 16:00	10.7	13.3	8.3	158.1	3,273,081.7	2,079.4	1.6	1.2
12/13/2020 17:00	10.6	13.3	8.2	193.0	3,254,859.5	2,234.2	2.1	1.8
12/13/2020 18:00	10.3	13.3	8.0	186.0	3,235,337.9	2,220.8	2.0	1.8
12/13/2020 19:00	9.9	13.3	7.7	166.5	3,286,009.9	2,159.6	1.8	1.5
12/13/2020 20:00	9.9	13.3	7.7	168.4	3,276,235.0	2,177.1	1.8	1.5
12/13/2020 21:00	9.8	13.3	7.6	159.7	3,302,024.5	2,121.9	1.7	1.5
12/13/2020 22:00	10.1	13.4	7.9	154.7	3,321,901.3	2,061.9	1.6	1.2
12/13/2020 23:00	9.9	13.4	7.8	148.0	3,328,516.4	2,041.7	1.5	1.2
Average/Sum#:	9.4	13.6	7.6	134.1	3,153,859.7	1,888.3	1.4	1.1
Minimum:	8.3	13.3	6.7	86.5	2,485,315.1	1,306.7	1.1	0.5
Maximum:	10.7	13.9	8.3	193.0	3,359,711.5	2,234.2	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/14/2020 00:00	21.1	15.9	24.9	170.6	1,797,929.7	722.1	3.1	0.9
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	21.1	15.9	24.9	170.6	1,797,929.7	722.1	3.1	0.9
Minimum:	21.1	15.9	24.9	170.6	1,797,929.7	722.1	3.1	0.9
Maximum:	21.1	15.9	24.9	170.6	1,797,929.7	722.1	3.1	0.9
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/15/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/16/2020 15:00	35.5	17.4	59.8	0.0	1,883,581.0	453.9	0.0	0.0
12/16/2020 16:00	39.4	15.7	44.7	175.1	2,120,282.4	820.6	0.0	0.0
12/16/2020 17:00	8.4	13.7	6.9	118.6	3,302,533.5	1,784.6	1.2	0.9
12/16/2020 18:00	9.7	13.5	7.7	132.6	3,338,275.3	1,925.8	1.3	1.0
12/16/2020 19:00	10.0	13.2	7.7	181.3	3,341,852.0	2,196.3	1.9	1.5
12/16/2020 20:00	10.0	13.2	7.7	185.2	3,301,196.3	2,241.9	2.0	1.8
12/16/2020 21:00	10.1	13.2	7.7	197.6	3,298,104.0	2,239.8	2.1	1.8
12/16/2020 22:00	10.3	13.2	7.9	191.2	3,322,938.0	2,232.4	2.0	1.8
12/16/2020 23:00	10.1	13.2	7.7	185.1	3,290,488.6	2,210.6	2.0	1.8
Average/Sum#:	15.9	14.0	17.5	151.9	3,022,139.0	1,789.5	1.4	1.2
Minimum:	8.4	13.2	6.9	0.0	1,883,581.0	453.9	0.0	0.0
Maximum:	39.4	17.4	59.8	197.6	3,341,852.0	2,241.9	2.1	1.8
%SI	62.50	62.50	62.50	62.50	62.50	62.50	62.50	62.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/17/2020 00:00	10.0	13.3	7.8	163.8	3,266,942.9	2,075.5	1.7	1.5
12/17/2020 01:00	9.4	13.5	7.5	143.3	3,192,094.8	1,911.4	1.5	1.1
12/17/2020 02:00	8.8	13.7	7.2	116.9	3,281,688.6	1,797.3	1.2	0.9
12/17/2020 03:00	10.5	13.3	8.2	154.7	3,314,973.7	2,057.6	1.6	1.2
12/17/2020 04:00	10.4	13.3	8.1	160.2	3,280,164.9	2,083.9	1.7	1.5
12/17/2020 05:00	10.5	13.3	8.2	179.3	3,314,636.6	2,105.8	1.9	1.5
12/17/2020 06:00	10.8	13.3	8.4	155.0	3,314,496.1	2,033.1	1.6	1.2
12/17/2020 07:00	10.5	13.3	8.2	176.9	3,282,662.4	2,157.4	1.9	1.5
12/17/2020 08:00	10.2	13.3	7.9	161.7	3,288,035.2	2,088.9	1.7	1.5
12/17/2020 09:00	9.8	13.4	7.7	146.0	3,281,173.8	1,988.7	1.5	1.2
12/17/2020 10:00	8.2	13.8	6.8	102.7	3,139,976.0	1,650.9	1.1	0.7
12/17/2020 11:00	8.5	13.8	7.1	104.5	3,223,282.6	1,694.7	1.1	0.7
12/17/2020 12:00	8.6	13.8	7.1	104.1	3,195,894.2	1,680.3	1.1	0.7
12/17/2020 13:00	8.7	13.9	7.3	105.2	3,217,766.9	1,691.8	1.1	0.7
12/17/2020 14:00	8.6	13.9	7.2	103.9	3,177,254.8	1,670.5	1.1	0.7
12/17/2020 15:00	8.6	13.9	7.2	103.4	3,157,854.6	1,660.3	1.1	0.7
12/17/2020 16:00	9.9	13.7	8.1	136.0	3,254,250.3	1,829.8	1.4	0.9
12/17/2020 17:00	11.0	13.3	8.5	176.8	3,329,257.4	2,139.4	1.8	1.5
12/17/2020 18:00	10.8	13.3	8.4	182.3	3,296,004.5	2,142.1	1.9	1.5
12/17/2020 19:00	10.5	13.4	8.3	171.3	3,299,683.1	2,096.3	1.8	1.5
12/17/2020 20:00	10.5	13.4	8.3	166.7	3,311,140.8	2,079.4	1.7	1.5
12/17/2020 21:00	10.6	13.3	8.2	183.6	3,316,776.6	2,155.6	1.9	1.5
12/17/2020 22:00	10.4	13.4	8.2	172.0	3,315,266.2	2,106.2	1.8	1.5
12/17/2020 23:00	10.4	13.4	8.2	167.4	3,343,651.0	2,075.4	1.7	1.5
Average/Sum#:	9.8	13.5	7.8	147.4	3,266,455.3	1,957.2	1.5	1.2
Minimum:	8.2	13.3	6.8	102.7	3,139,976.0	1,650.9	1.1	0.7
Maximum:	11.0	13.9	8.5	183.6	3,343,651.0	2,157.4	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/18/2020 00:00	10.5	13.4	8.3	168.3	3,360,245.2	2,085.7	1.7	1.5
12/18/2020 01:00	9.5	13.6	7.7	137.7	3,339,854.9	1,951.1	1.4	1.0
12/18/2020 02:00	8.5	13.9	7.2	120.4	3,257,898.6	1,712.9	1.2	0.9
12/18/2020 03:00	8.3	13.9	7.0	91.4	2,815,308.3	1,480.2	1.1	0.6
12/18/2020 04:00	9.2	13.7	7.5	121.3	3,171,142.7	1,713.6	1.3	0.9
12/18/2020 05:00	9.8	13.6	7.9	147.6	3,323,526.2	1,990.1	1.5	1.2
12/18/2020 06:00	11.2	13.3	8.7	182.7	3,348,319.6	2,176.1	1.9	1.5
12/18/2020 07:00	10.7	13.3	8.3	173.7	3,343,418.5	2,148.5	1.8	1.5
12/18/2020 08:00	9.3	13.6	7.5	133.0	3,371,037.5	1,944.7	1.3	1.0
12/18/2020 09:00	8.3	13.9	7.0	105.8	3,260,751.6	1,714.4	1.1	0.7
12/18/2020 10:00	8.4	13.9	7.1	97.3	2,986,296.1	1,570.1	1.1	0.6
12/18/2020 11:00	8.6	14.0	7.4	87.8	2,718,982.5	1,409.7	1.1	0.6
12/18/2020 12:00	8.6	13.9	7.2	93.0	2,907,230.1	1,507.3	1.1	0.6
12/18/2020 13:00	8.7	13.9	7.3	100.3	3,104,350.1	1,609.5	1.1	0.6
12/18/2020 14:00	8.6	14.0	7.4	88.5	2,740,391.8	1,420.8	1.1	0.6
12/18/2020 15:00	9.2	14.0	7.9	94.9	2,777,809.9	1,440.2	1.1	0.6
12/18/2020 16:00	10.6	13.6	8.6	153.2	3,322,258.7	1,892.3	1.6	1.1
12/18/2020 17:00	11.1	13.3	8.6	202.8	3,261,733.3	2,215.1	2.2	1.8
12/18/2020 18:00	10.8	13.2	8.3	213.5	3,268,502.2	2,291.3	2.3	2.1
12/18/2020 19:00	10.5	13.2	8.0	213.9	3,273,780.2	2,295.0	2.3	2.1
12/18/2020 20:00	10.6	13.2	8.1	207.4	3,272,636.0	2,270.3	2.2	1.8
12/18/2020 21:00	10.5	13.3	8.2	197.8	3,316,388.6	2,228.0	2.1	1.8
12/18/2020 22:00	10.5	13.3	8.2	180.4	3,346,375.2	2,150.4	1.9	1.5
12/18/2020 23:00	10.7	13.4	8.4	169.0	3,379,054.7	2,072.7	1.7	1.5
Average/Sum#:	9.7	13.6	7.8	145.1	3,177,803.9	1,887.1	1.6	1.2
Minimum:	8.3	13.2	7.0	87.8	2,718,982.5	1,409.7	1.1	0.6
Maximum:	11.2	14.0	8.7	213.9	3,379,054.7	2,295.0	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/19/2020 00:00	10.7	13.4	8.4	166.8	3,360,958.7	2,061.6	1.7	1.4
12/19/2020 01:00	9.8	13.5	7.8	142.6	3,342,230.5	2,001.3	1.4	1.0
12/19/2020 02:00	8.4	13.8	7.0	103.3	3,168,886.1	1,666.1	1.1	0.7
12/19/2020 03:00	8.5	13.8	7.1	96.5	2,968,988.1	1,561.0	1.1	0.6
12/19/2020 04:00	9.7	13.6	7.8	137.0	3,380,135.8	1,875.9	1.4	0.9
12/19/2020 05:00	11.1	13.3	8.6	165.5	3,385,056.0	2,101.1	1.7	1.5
12/19/2020 06:00	10.7	13.4	8.4	153.9	3,379,639.2	2,023.7	1.5	1.2
12/19/2020 07:00	8.6	13.8	7.1	104.6	3,201,790.3	1,683.4	1.1	0.7
12/19/2020 08:00	8.6	13.8	7.1	98.8	3,040,882.9	1,598.8	1.1	0.6
12/19/2020 09:00	8.7	13.8	7.2	101.4	3,125,711.2	1,643.4	1.1	0.7
12/19/2020 10:00	8.7	13.8	7.2	105.1	3,245,916.2	1,706.6	1.1	0.7
12/19/2020 11:00	8.8	13.8	7.3	105.8	3,258,279.0	1,713.1	1.1	0.7
12/19/2020 12:00	8.8	13.8	7.3	105.9	3,259,610.4	1,713.8	1.1	0.7
12/19/2020 13:00	8.8	13.9	7.4	105.3	3,233,172.9	1,699.9	1.1	0.7
12/19/2020 14:00	8.8	13.9	7.4	105.9	3,258,088.8	1,713.0	1.1	0.7
12/19/2020 15:00	9.5	13.8	7.9	128.7	3,278,661.1	1,771.7	1.3	0.9
12/19/2020 16:00	11.6	13.3	9.0	176.6	3,372,006.2	2,093.0	1.8	1.5
12/19/2020 17:00	11.2	13.3	8.7	189.7	3,345,857.7	2,174.5	2.0	1.7
12/19/2020 18:00	11.3	13.3	8.8	215.2	3,309,199.5	2,271.5	2.3	2.0
12/19/2020 19:00	11.1	13.3	8.6	217.6	3,318,043.2	2,301.8	2.3	2.1
12/19/2020 20:00	10.7	13.3	8.3	199.9	3,322,193.8	2,231.9	2.1	1.8
12/19/2020 21:00	10.9	13.3	8.5	193.3	3,303,355.9	2,171.0	2.0	1.7
12/19/2020 22:00	10.7	13.3	8.3	175.1	3,338,370.0	2,096.5	1.8	1.5
12/19/2020 23:00	10.8	13.4	8.5	165.0	3,360,266.8	2,012.1	1.7	1.4
Average/Sum#:	9.9	13.6	7.9	144.1	3,273,220.8	1,911.9	1.5	1.1
Minimum:	8.4	13.3	7.0	96.5	2,968,988.1	1,561.0	1.1	0.6
Maximum:	11.6	13.9	9.0	217.6	3,385,056.0	2,301.8	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/20/2020 00:00	9.2	13.6	7.4	132.2	3,368,955.2	1,968.1	1.3	1.0
12/20/2020 01:00	8.4	13.8	7.0	105.4	3,169,076.3	1,666.2	1.1	0.7
12/20/2020 02:00	8.5	13.8	7.1	96.5	2,948,066.4	1,550.0	1.1	0.6
12/20/2020 03:00	9.0	13.9	7.6	87.9	2,622,637.9	1,378.9	1.1	0.6
12/20/2020 04:00	8.6	13.8	7.1	97.6	3,011,402.3	1,583.3	1.1	0.6
12/20/2020 05:00	9.1	13.7	7.5	125.6	3,249,222.7	1,850.7	1.3	0.9
12/20/2020 06:00	10.2	13.6	8.2	136.4	3,326,999.0	1,895.0	1.4	0.9
12/20/2020 07:00	8.7	13.8	7.2	106.7	3,263,224.2	1,715.7	1.1	0.7
12/20/2020 08:00	8.7	13.8	7.2	105.2	3,219,668.9	1,692.8	1.1	0.7
12/20/2020 09:00	8.8	13.8	7.3	106.1	3,252,953.5	1,710.3	1.1	0.7
12/20/2020 10:00	8.7	13.8	7.2	106.1	3,253,524.1	1,710.6	1.1	0.7
12/20/2020 11:00	8.8	13.8	7.3	106.1	3,251,241.7	1,709.4	1.1	0.7
12/20/2020 12:00	8.8	13.9	7.4	106.1	3,261,702.6	1,714.9	1.1	0.7
12/20/2020 13:00	8.8	13.9	7.4	105.4	3,235,074.9	1,700.9	1.1	0.7
12/20/2020 14:00	8.8	13.9	7.4	102.1	3,116,201.3	1,638.4	1.1	0.7
12/20/2020 15:00	9.8	13.7	8.0	129.6	3,167,626.6	1,711.7	1.4	0.9
12/20/2020 16:00	11.6	13.4	9.1	173.0	3,303,857.2	2,050.7	1.8	1.4
12/20/2020 17:00	11.3	13.3	8.8	194.2	3,284,031.8	2,158.3	2.0	1.7
12/20/2020 18:00	11.1	13.3	8.6	200.6	3,286,468.0	2,183.9	2.1	1.7
12/20/2020 19:00	10.9	13.3	8.5	196.3	3,288,424.4	2,185.2	2.1	1.7
12/20/2020 20:00	10.7	13.3	8.3	207.3	3,268,699.5	2,243.7	2.2	1.8
12/20/2020 21:00	10.8	13.3	8.4	187.0	3,250,953.3	2,160.3	2.0	1.7
12/20/2020 22:00	10.8	13.3	8.4	186.7	3,304,159.5	2,147.4	2.0	1.7
12/20/2020 23:00	10.9	13.3	8.5	171.6	3,381,500.1	2,074.2	1.7	1.5
Average/Sum#:	9.6	13.6	7.8	136.3	3,211,903.0	1,850.0	1.4	1.0
Minimum:	8.4	13.3	7.0	87.9	2,622,637.9	1,378.9	1.1	0.6
Maximum:	11.6	13.9	9.1	207.3	3,381,500.1	2,243.7	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/21/2020 00:00	9.6	13.6	7.8	139.1	3,349,716.0	1,932.4	1.4	1.0
12/21/2020 01:00	8.4	13.8	7.0	104.4	3,156,617.0	1,682.7	1.1	0.7
12/21/2020 02:00	8.5	13.8	7.1	100.1	3,032,055.7	1,616.3	1.1	0.6
12/21/2020 03:00	8.7	13.8	7.2	97.3	2,970,319.5	1,561.7	1.1	0.6
12/21/2020 04:00	9.8	13.6	7.9	136.0	3,319,520.3	1,866.5	1.4	0.9
12/21/2020 05:00	11.1	13.3	8.6	160.2	3,346,968.7	2,101.9	1.6	1.3
12/21/2020 06:00	11.4	13.3	8.9	167.9	3,384,070.6	2,125.2	1.7	1.5
12/21/2020 07:00	10.9	13.3	8.5	169.4	3,370,694.8	2,116.8	1.7	1.5
12/21/2020 08:00	10.0	13.4	7.9	147.4	3,361,101.8	2,012.6	1.5	1.2
12/21/2020 09:00	8.5	13.8	7.1	105.7	3,182,317.2	1,696.4	1.1	0.7
12/21/2020 10:00	8.6	13.8	7.1	105.6	3,203,327.5	1,707.6	1.1	0.7
12/21/2020 11:00	8.8	13.8	7.3	106.1	3,208,767.7	1,710.5	1.1	0.7
12/21/2020 12:00	8.9	13.8	7.4	106.0	3,189,820.9	1,700.4	1.1	0.7
12/21/2020 13:00	8.9	13.8	7.4	106.4	3,202,764.7	1,707.3	1.1	0.7
12/21/2020 14:00	8.9	13.8	7.4	105.9	3,180,066.0	1,695.2	1.1	0.7
12/21/2020 15:00	10.4	13.6	8.4	147.1	3,283,595.1	1,846.3	1.5	1.1
12/21/2020 16:00	11.3	13.3	8.8	177.5	3,299,845.9	2,120.5	1.8	1.5
12/21/2020 17:00	11.0	13.3	8.5	178.6	3,325,055.8	2,136.7	1.8	1.5
12/21/2020 18:00	11.0	13.3	8.5	192.3	3,316,113.8	2,203.6	2.0	1.8
12/21/2020 19:00	10.8	13.3	8.4	183.4	3,315,985.1	2,179.3	1.9	1.5
12/21/2020 20:00	10.6	13.3	8.2	176.8	3,334,859.6	2,143.0	1.8	1.5
12/21/2020 21:00	10.8	13.3	8.4	172.4	3,353,019.7	2,105.7	1.8	1.5
12/21/2020 22:00	10.8	13.3	8.4	175.4	3,329,275.3	2,115.1	1.8	1.5
12/21/2020 23:00	10.8	13.3	8.4	166.2	3,359,165.4	2,060.5	1.7	1.4
Average/Sum#:	9.9	13.5	7.9	142.8	3,265,626.8	1,922.7	1.5	1.1
Minimum:	8.4	13.3	7.0	97.3	2,970,319.5	1,561.7	1.1	0.6
Maximum:	11.4	13.8	8.9	192.3	3,384,070.6	2,203.6	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/22/2020 00:00	9.9	13.5	7.9	141.5	3,342,764.9	1,952.8	1.4	1.0
12/22/2020 01:00	8.6	13.8	7.1	104.2	3,137,295.0	1,672.4	1.1	0.7
12/22/2020 02:00	8.6	13.8	7.1	96.5	2,912,371.7	1,552.5	1.1	0.6
12/22/2020 03:00	8.7	13.8	7.2	95.3	2,872,039.4	1,531.0	1.1	0.6
12/22/2020 04:00	9.3	13.7	7.6	127.8	3,156,431.9	1,728.7	1.4	0.9
12/22/2020 05:00	11.2	13.3	8.7	164.7	3,368,457.9	2,066.2	1.7	1.4
12/22/2020 06:00	11.4	13.3	8.9	166.3	3,388,600.4	2,103.3	1.7	1.5
12/22/2020 07:00	10.9	13.3	8.5	178.6	3,382,945.1	2,173.9	1.8	1.5
12/22/2020 08:00	8.5	13.7	7.0	109.7	3,215,186.4	1,737.4	1.1	0.7
12/22/2020 09:00	8.6	13.8	7.1	100.7	3,052,128.0	1,627.0	1.1	0.7
12/22/2020 10:00	8.7	13.9	7.3	105.7	3,249,149.5	1,708.3	1.1	0.7
12/22/2020 11:00	8.9	13.9	7.5	103.0	3,132,368.1	1,646.9	1.1	0.7
12/22/2020 12:00	8.9	13.9	7.5	100.0	3,034,416.2	1,595.4	1.1	0.6
12/22/2020 13:00	8.9	13.9	7.5	103.4	3,160,327.2	1,661.6	1.1	0.7
12/22/2020 14:00	8.8	13.9	7.4	105.6	3,222,712.1	1,694.4	1.1	0.7
12/22/2020 15:00	9.8	13.8	8.1	140.2	3,178,915.1	1,717.8	1.5	1.0
12/22/2020 16:00	11.3	13.5	9.0	179.5	3,374,393.7	2,045.2	1.8	1.4
12/22/2020 17:00	11.3	13.4	8.9	202.4	3,307,464.2	2,173.7	2.1	1.7
12/22/2020 18:00	11.1	13.3	8.6	206.3	3,317,468.2	2,204.5	2.2	1.8
12/22/2020 19:00	11.0	13.3	8.5	203.4	3,328,604.2	2,211.9	2.1	1.8
12/22/2020 20:00	10.9	13.3	8.5	203.0	3,317,877.1	2,229.0	2.1	1.8
12/22/2020 21:00	10.7	13.4	8.4	196.8	3,349,704.4	2,177.0	2.0	1.7
12/22/2020 22:00	10.8	13.4	8.5	192.9	3,333,459.1	2,142.1	2.0	1.7
12/22/2020 23:00	10.7	13.4	8.4	185.7	3,353,338.2	2,105.9	1.9	1.5
Average/Sum#:	9.9	13.6	8.0	146.4	3,228,684.1	1,894.1	1.5	1.1
Minimum:	8.5	13.3	7.0	95.3	2,872,039.4	1,531.0	1.1	0.6
Maximum:	11.4	13.9	9.0	206.3	3,388,600.4	2,229.0	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/23/2020 00:00	10.3	13.5	8.2	172.7	3,333,640.9	2,020.5	1.8	1.4
12/23/2020 01:00	8.7	13.8	7.2	124.1	3,265,506.6	1,716.9	1.3	0.9
12/23/2020 02:00	9.5	13.7	7.8	134.2	3,362,393.3	1,841.5	1.3	0.9
12/23/2020 03:00	9.8	13.6	7.9	142.7	3,391,318.8	1,956.4	1.4	1.0
12/23/2020 04:00	10.6	13.5	8.5	167.5	3,339,085.6	2,023.8	1.7	1.4
12/23/2020 05:00	8.4	13.9	7.1	126.7	3,251,622.1	1,709.6	1.3	0.9
12/23/2020 06:00	10.2	13.7	8.4	149.6	3,343,197.4	1,855.4	1.5	1.1
12/23/2020 07:00	11.5	13.4	9.0	199.1	3,375,319.9	2,169.0	2.0	1.7
12/23/2020 08:00	11.1	13.4	8.7	195.0	3,344,196.6	2,149.0	2.0	1.7
12/23/2020 09:00	10.6	13.5	8.5	171.8	3,331,331.1	2,019.1	1.8	1.4
12/23/2020 10:00	8.3	13.9	7.0	106.1	3,216,055.1	1,690.9	1.1	0.7
12/23/2020 11:00	8.5	13.9	7.2	102.3	3,136,753.3	1,626.3	1.1	0.7
12/23/2020 12:00	8.7	13.9	7.3	104.6	3,204,645.9	1,661.5	1.1	0.7
12/23/2020 13:00	8.8	13.9	7.4	106.4	3,264,052.0	1,692.3	1.1	0.7
12/23/2020 14:00	8.9	13.9	7.5	107.6	3,274,467.3	1,697.7	1.1	0.7
12/23/2020 15:00	10.2	13.8	8.5	143.2	3,137,462.3	1,695.4	1.5	1.0
12/23/2020 16:00	11.8	13.4	9.3	200.2	3,313,534.8	2,105.1	2.1	1.7
12/23/2020 17:00	11.3	13.3	8.8	217.4	3,291,571.8	2,259.4	2.3	2.0
12/23/2020 18:00	10.9	13.2	8.4	215.9	3,309,970.8	2,296.2	2.3	2.1
12/23/2020 19:00	10.8	13.2	8.3	213.1	3,325,394.9	2,306.9	2.2	1.8
12/23/2020 20:00	10.8	13.2	8.3	216.0	3,317,899.1	2,301.7	2.3	2.1
12/23/2020 21:00	10.5	13.3	8.2	190.3	3,351,550.8	2,178.2	2.0	1.7
12/23/2020 22:00	10.6	13.3	8.2	187.5	3,354,934.1	2,155.9	1.9	1.5
12/23/2020 23:00	10.6	13.3	8.2	182.5	3,408,115.1	2,140.3	1.8	1.5
Average/Sum#:	10.1	13.6	8.1	161.5	3,301,834.2	1,969.5	1.7	1.3
Minimum:	8.3	13.2	7.0	102.3	3,136,753.3	1,626.3	1.1	0.7
Maximum:	11.8	13.9	9.3	217.4	3,408,115.1	2,306.9	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/24/2020 00:00	10.5	13.4	8.3	167.3	3,473,828.9	2,080.1	1.6	1.2
12/24/2020 01:00	10.0	13.5	8.0	150.3	3,402,163.7	1,987.5	1.5	1.2
12/24/2020 02:00	8.8	13.8	7.3	127.3	3,298,436.8	1,758.3	1.3	0.9
12/24/2020 03:00	8.9	13.7	7.3	123.6	3,328,422.0	1,847.2	1.3	0.9
12/24/2020 04:00	8.9	13.6	7.2	127.5	3,418,293.9	1,947.0	1.3	1.0
12/24/2020 05:00	10.4	13.5	8.3	163.3	3,401,199.5	1,962.1	1.6	1.2
12/24/2020 06:00	8.8	13.8	7.3	109.4	3,272,734.1	1,720.7	1.1	0.7
12/24/2020 07:00	8.6	13.8	7.1	106.0	3,253,333.9	1,710.5	1.1	0.7
12/24/2020 08:00	8.6	13.8	7.1	105.8	3,202,014.4	1,706.9	1.1	0.7
12/24/2020 09:00	10.9	13.5	8.7	196.8	3,411,080.1	1,967.8	2.0	1.6
12/24/2020 10:00	11.3	13.4	8.9	171.9	3,372,696.6	2,068.8	1.7	1.4
12/24/2020 11:00	8.7	13.9	7.3	110.2	3,151,387.9	1,656.9	1.2	0.8
12/24/2020 12:00	8.8	13.9	7.4	103.3	3,139,215.2	1,650.5	1.1	0.7
12/24/2020 13:00	8.9	13.9	7.5	105.5	3,184,862.7	1,674.5	1.1	0.7
12/24/2020 14:00	8.9	13.9	7.5	106.6	3,228,608.2	1,697.5	1.1	0.7
12/24/2020 15:00	10.3	13.7	8.4	149.5	3,242,334.5	1,823.1	1.6	1.1
12/24/2020 16:00	11.4	13.4	9.0	183.8	3,314,325.5	2,081.4	1.9	1.5
12/24/2020 17:00	11.4	13.3	8.9	204.7	3,296,813.1	2,166.7	2.2	1.7
12/24/2020 18:00	11.0	13.3	8.5	203.0	3,288,255.9	2,209.1	2.1	1.8
12/24/2020 19:00	10.9	13.3	8.5	205.2	3,314,609.0	2,202.6	2.2	1.8
12/24/2020 20:00	10.9	13.3	8.5	212.2	3,287,796.5	2,232.8	2.3	2.0
12/24/2020 21:00	11.0	13.3	8.5	198.3	3,326,624.2	2,162.0	2.1	1.7
12/24/2020 22:00	10.9	13.3	8.5	201.9	3,305,128.3	2,196.3	2.1	1.8
12/24/2020 23:00	10.7	13.3	8.3	182.1	3,338,090.0	2,120.7	1.9	1.5
Average/Sum#:	10.0	13.6	8.0	154.8	3,302,177.3	1,943.0	1.6	1.2
Minimum:	8.6	13.3	7.1	103.3	3,139,215.2	1,650.5	1.1	0.7
Maximum:	11.4	13.9	9.0	212.2	3,473,828.9	2,232.8	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/25/2020 00:00	10.8	13.3	8.4	181.8	3,310,701.5	2,103.3	1.9	1.5
12/25/2020 01:00	11.0	13.3	8.5	183.7	3,298,109.1	2,095.3	1.9	1.5
12/25/2020 02:00	10.6	13.4	8.3	177.8	3,282,107.5	2,037.2	1.9	1.4
12/25/2020 03:00	8.5	13.8	7.1	108.1	3,263,985.0	1,716.1	1.1	0.7
12/25/2020 04:00	9.9	13.6	8.0	142.5	3,296,222.3	1,853.4	1.5	1.1
12/25/2020 05:00	11.4	13.4	9.0	159.5	3,282,840.8	2,085.6	1.6	1.3
12/25/2020 06:00	11.1	13.4	8.7	167.5	3,305,951.6	2,052.0	1.7	1.4
12/25/2020 07:00	8.8	13.8	7.3	106.2	3,140,484.1	1,674.1	1.1	0.7
12/25/2020 08:00	8.8	13.8	7.3	103.8	3,072,200.4	1,637.7	1.1	0.7
12/25/2020 09:00	8.9	13.8	7.4	103.6	3,068,073.4	1,635.5	1.1	0.7
12/25/2020 10:00	9.0	13.8	7.5	102.4	3,023,238.8	1,611.6	1.1	0.6
12/25/2020 11:00	9.1	13.8	7.6	108.6	3,175,751.4	1,692.9	1.1	0.7
12/25/2020 12:00	9.0	13.8	7.5	108.4	3,186,069.0	1,698.4	1.1	0.7
12/25/2020 13:00	9.1	13.8	7.6	108.4	3,188,507.7	1,699.7	1.1	0.7
12/25/2020 14:00	9.0	13.8	7.5	106.5	3,101,840.0	1,653.5	1.1	0.7
12/25/2020 15:00	9.7	13.7	7.9	133.9	3,202,992.3	1,754.2	1.4	0.9
12/25/2020 16:00	11.5	13.4	9.0	172.8	3,280,408.3	2,060.1	1.8	1.4
12/25/2020 17:00	11.3	13.3	8.8	189.3	3,262,153.5	2,120.1	2.0	1.7
12/25/2020 18:00	11.1	13.3	8.6	180.7	3,280,794.5	2,084.3	1.9	1.5
12/25/2020 19:00	11.3	13.3	8.8	196.1	3,254,665.3	2,139.0	2.1	1.7
12/25/2020 20:00	10.5	13.4	8.3	158.1	3,247,372.8	1,944.5	1.7	1.4
12/25/2020 21:00	8.8	13.8	7.3	108.8	3,213,832.7	1,713.2	1.1	0.7
12/25/2020 22:00	10.2	13.6	8.2	150.5	3,261,364.2	1,833.8	1.6	1.1
12/25/2020 23:00	11.4	13.4	9.0	163.9	3,323,643.7	1,965.9	1.7	1.4
Average/Sum#:	10.0	13.6	8.1	142.6	3,221,804.6	1,869.2	1.5	1.1
Minimum:	8.5	13.3	7.1	102.4	3,023,238.8	1,611.6	1.1	0.6
Maximum:	11.5	13.8	9.0	196.1	3,323,643.7	2,139.0	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/26/2020 00:00	11.4	13.3	8.9	179.8	3,267,988.0	2,052.3	1.9	1.4
12/26/2020 01:00	10.5	13.5	8.4	148.7	3,242,154.5	1,917.7	1.6	1.2
12/26/2020 02:00	8.8	13.8	7.3	108.5	3,194,698.3	1,703.0	1.1	0.7
12/26/2020 03:00	9.8	13.7	8.0	137.6	3,266,168.5	1,788.8	1.4	0.9
12/26/2020 04:00	11.7	13.3	9.1	179.3	3,266,236.4	2,051.2	1.9	1.4
12/26/2020 05:00	11.0	13.4	8.7	166.5	3,337,800.8	1,949.9	1.7	1.4
12/26/2020 06:00	9.1	13.8	7.6	111.2	3,256,377.1	1,712.1	1.1	0.7
12/26/2020 07:00	9.1	13.8	7.6	105.9	3,189,047.0	1,676.7	1.1	0.7
12/26/2020 08:00	9.0	13.8	7.5	103.9	3,084,818.6	1,621.9	1.1	0.6
12/26/2020 09:00	9.2	13.8	7.6	107.9	3,189,617.6	1,677.0	1.1	0.7
12/26/2020 10:00	9.2	13.8	7.6	101.8	2,999,419.8	1,577.0	1.1	0.6
12/26/2020 11:00	9.1	13.9	7.7	93.1	2,791,343.4	1,467.6	1.1	0.6
12/26/2020 12:00	9.2	13.9	7.8	104.3	3,032,324.0	1,594.3	1.1	0.6
12/26/2020 13:00	9.2	13.9	7.8	110.7	3,237,737.7	1,702.3	1.1	0.7
12/26/2020 14:00	9.1	13.9	7.7	107.8	3,188,476.4	1,676.4	1.1	0.7
12/26/2020 15:00	9.2	13.9	7.8	102.5	3,033,655.4	1,595.0	1.1	0.6
12/26/2020 16:00	10.2	13.7	8.4	139.3	3,145,604.8	1,699.8	1.5	1.0
12/26/2020 17:00	11.8	13.4	9.3	181.3	3,341,234.4	2,073.9	1.9	1.5
12/26/2020 18:00	11.3	13.4	8.9	172.3	3,350,747.7	2,006.4	1.8	1.4
12/26/2020 19:00	11.4	13.3	8.9	184.0	3,320,376.4	2,085.2	1.9	1.5
12/26/2020 20:00	11.1	13.3	8.6	180.7	3,363,467.4	2,087.7	1.8	1.5
12/26/2020 21:00	11.1	13.3	8.6	178.8	3,338,978.9	2,072.5	1.8	1.5
12/26/2020 22:00	11.0	13.3	8.5	183.1	3,345,217.1	2,100.8	1.9	1.5
12/26/2020 23:00	11.0	13.3	8.5	178.4	3,341,234.4	2,073.9	1.8	1.5
Average/Sum#:	10.1	13.6	8.2	140.3	3,213,530.2	1,831.8	1.5	1.0
Minimum:	8.8	13.3	7.3	93.1	2,791,343.4	1,467.6	1.1	0.6
Maximum:	11.8	13.9	9.3	184.0	3,363,467.4	2,100.8	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/27/2020 00:00	11.1	13.3	8.6	177.8	3,339,462.2	2,072.8	1.8	1.5
12/27/2020 01:00	11.0	13.3	8.5	176.8	3,327,217.9	2,065.2	1.8	1.4
12/27/2020 02:00	9.9	13.5	7.9	145.0	3,336,541.8	1,924.8	1.5	1.2
12/27/2020 03:00	8.6	13.8	7.1	107.8	3,267,788.9	1,718.1	1.1	0.7
12/27/2020 04:00	9.7	13.7	7.9	135.5	3,173,778.0	1,738.2	1.4	0.9
12/27/2020 05:00	11.4	13.4	9.0	173.2	3,266,628.1	2,075.3	1.8	1.5
12/27/2020 06:00	11.4	13.4	9.0	171.2	3,299,835.1	2,072.3	1.8	1.5
12/27/2020 07:00	8.7	13.8	7.2	107.1	3,205,953.8	1,709.0	1.1	0.7
12/27/2020 08:00	8.8	13.8	7.3	106.4	3,244,014.2	1,705.6	1.1	0.7
12/27/2020 09:00	8.9	13.8	7.4	105.2	3,144,048.3	1,676.0	1.1	0.7
12/27/2020 10:00	8.9	13.8	7.4	101.9	3,082,346.1	1,620.6	1.1	0.6
12/27/2020 11:00	8.9	13.8	7.4	105.4	3,144,160.3	1,653.1	1.1	0.7
12/27/2020 12:00	9.0	13.8	7.5	107.1	3,231,271.0	1,698.9	1.1	0.7
12/27/2020 13:00	9.0	13.8	7.5	102.3	3,086,720.6	1,622.9	1.1	0.6
12/27/2020 14:00	9.0	13.8	7.5	107.4	3,225,374.8	1,695.8	1.1	0.7
12/27/2020 15:00	9.8	13.7	8.0	134.2	3,211,300.2	1,735.3	1.4	0.9
12/27/2020 16:00	11.6	13.3	9.0	180.4	3,314,166.2	2,081.3	1.9	1.5
12/27/2020 17:00	11.3	13.3	8.8	194.8	3,293,161.3	2,164.3	2.0	1.7
12/27/2020 18:00	11.1	13.3	8.6	199.8	3,281,652.5	2,180.7	2.1	1.7
12/27/2020 19:00	11.0	13.3	8.5	216.3	3,254,328.9	2,257.6	2.3	2.0
12/27/2020 20:00	10.8	13.3	8.4	195.3	3,209,569.6	2,132.8	2.1	1.7
12/27/2020 21:00	8.4	13.8	7.0	108.9	3,268,739.9	1,718.6	1.1	0.7
12/27/2020 22:00	10.3	13.6	8.3	152.8	3,271,870.9	1,863.6	1.6	1.1
12/27/2020 23:00	11.4	13.3	8.9	195.2	3,277,386.4	2,130.0	2.1	1.7
Average/Sum#:	10.0	13.6	8.0	146.2	3,239,888.2	1,888.0	1.5	1.1
Minimum:	8.4	13.3	7.0	101.9	3,082,346.1	1,620.6	1.1	0.6
Maximum:	11.6	13.8	9.0	216.3	3,339,462.2	2,257.6	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/28/2020 00:00	10.9	13.4	8.6	170.6	3,247,818.2	1,992.2	1.8	1.4
12/28/2020 01:00	8.6	13.8	7.1	105.8	3,170,788.0	1,667.1	1.1	0.7
12/28/2020 02:00	10.6	13.6	8.6	154.4	3,295,866.6	1,853.2	1.6	1.1
12/28/2020 03:00	11.2	13.4	8.8	177.3	3,307,637.6	2,077.2	1.8	1.5
12/28/2020 04:00	10.9	13.5	8.7	166.1	3,245,201.8	1,943.2	1.7	1.4
12/28/2020 05:00	8.6	13.9	7.2	111.8	3,275,967.4	1,722.4	1.1	0.7
12/28/2020 06:00	10.6	13.6	8.6	148.2	3,280,749.6	1,844.7	1.5	1.1
12/28/2020 07:00	11.5	13.3	8.9	207.6	3,252,309.3	2,208.7	2.2	1.8
12/28/2020 08:00	11.0	13.3	8.5	197.5	3,266,754.3	2,170.8	2.1	1.7
12/28/2020 09:00	10.5	13.4	8.3	170.4	3,255,202.3	2,020.5	1.8	1.4
12/28/2020 10:00	8.6	13.9	7.2	105.8	3,189,807.8	1,677.1	1.1	0.7
12/28/2020 11:00	8.8	13.9	7.4	105.9	3,205,784.4	1,685.5	1.1	0.7
12/28/2020 12:00	9.0	13.9	7.6	108.5	3,246,677.0	1,707.0	1.1	0.7
12/28/2020 13:00	9.0	13.9	7.6	107.3	3,205,784.4	1,685.5	1.1	0.7
12/28/2020 14:00	9.0	13.9	7.6	109.1	3,242,682.8	1,704.9	1.1	0.7
12/28/2020 15:00	10.5	13.7	8.6	146.4	3,229,499.1	1,792.3	1.5	1.1
12/28/2020 16:00	11.7	13.4	9.2	190.3	3,315,121.7	2,081.9	2.0	1.7
12/28/2020 17:00	11.4	13.3	8.9	217.6	3,244,822.5	2,274.7	2.3	2.0
12/28/2020 18:00	11.3	13.3	8.8	212.6	3,250,813.8	2,278.9	2.3	2.1
12/28/2020 19:00	11.0	13.3	8.5	219.2	3,255,806.5	2,282.4	2.4	2.1
12/28/2020 20:00	10.9	13.3	8.5	218.1	3,242,112.2	2,272.8	2.4	2.0
12/28/2020 21:00	10.8	13.3	8.4	205.5	3,243,661.8	2,250.2	2.2	1.8
12/28/2020 22:00	10.7	13.3	8.3	208.1	3,263,942.0	2,216.6	2.2	1.8
12/28/2020 23:00	10.9	13.3	8.5	200.6	3,282,053.8	2,157.0	2.1	1.7
Average/Sum#:	10.3	13.5	8.3	165.2	3,250,702.7	1,982.0	1.7	1.4
Minimum:	8.6	13.3	7.1	105.8	3,170,788.0	1,667.1	1.1	0.7
Maximum:	11.7	13.9	9.2	219.2	3,315,121.7	2,282.4	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/29/2020 00:00	11.0	13.3	8.5	200.5	3,275,815.3	2,152.9	2.1	1.7
12/29/2020 01:00	10.7	13.4	8.4	186.2	3,260,961.5	2,071.7	2.0	1.7
12/29/2020 02:00	8.3	13.9	7.0	107.0	3,281,293.0	1,725.2	1.1	0.7
12/29/2020 03:00	10.3	13.6	8.3	156.7	3,352,206.7	1,860.4	1.6	1.1
12/29/2020 04:00	11.5	13.4	9.0	196.7	3,316,185.6	2,131.0	2.0	1.7
12/29/2020 05:00	11.2	13.4	8.8	212.8	3,351,977.4	2,154.0	2.2	1.7
12/29/2020 06:00	11.8	13.3	9.2	209.4	3,319,397.3	2,278.5	2.2	1.8
12/29/2020 07:00	11.2	13.3	8.7	210.3	3,327,105.9	2,235.2	2.2	1.8
12/29/2020 08:00	10.9	13.3	8.5	206.5	3,325,594.4	2,209.9	2.2	1.8
12/29/2020 09:00	9.1	13.7	7.5	139.3	3,215,301.7	1,807.9	1.5	1.1
12/29/2020 10:00	8.5	13.9	7.2	107.6	3,237,547.5	1,702.2	1.1	0.7
12/29/2020 11:00	8.7	13.9	7.3	107.1	3,203,311.9	1,684.2	1.1	0.7
12/29/2020 12:00	8.8	13.9	7.4	108.7	3,291,633.3	1,706.6	1.1	0.7
12/29/2020 13:00	8.9	13.9	7.5	106.3	3,199,631.1	1,658.9	1.1	0.7
12/29/2020 14:00	9.0	13.9	7.6	108.5	3,269,259.6	1,695.0	1.1	0.7
12/29/2020 15:00	9.0	13.9	7.6	107.8	3,257,494.1	1,688.9	1.1	0.7
12/29/2020 16:00	10.1	13.8	8.4	137.5	3,167,996.8	1,711.9	1.5	1.0
12/29/2020 17:00	11.8	13.4	9.3	204.6	3,304,421.0	2,171.7	2.1	1.7
12/29/2020 18:00	11.5	13.3	8.9	215.4	3,269,032.2	2,267.8	2.3	2.0
12/29/2020 19:00	11.0	13.3	8.5	213.6	3,272,347.7	2,270.1	2.3	2.0
12/29/2020 20:00	10.8	13.4	8.5	203.0	3,307,159.9	2,173.5	2.1	1.7
12/29/2020 21:00	10.8	13.4	8.5	193.5	3,316,210.7	2,106.8	2.0	1.7
12/29/2020 22:00	10.9	13.4	8.6	191.4	3,319,358.8	2,108.8	2.0	1.7
12/29/2020 23:00	11.0	13.4	8.7	184.7	3,379,706.8	2,073.1	1.9	1.5
Average/Sum#:	10.3	13.6	8.2	167.3	3,284,206.3	1,985.3	1.7	1.4
Minimum:	8.3	13.3	7.0	106.3	3,167,996.8	1,658.9	1.1	0.7
Maximum:	11.8	13.9	9.3	215.4	3,379,706.8	2,278.5	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/30/2020 00:00	10.8	13.4	8.5	173.9	3,403,597.1	2,062.9	1.8	1.4
12/30/2020 01:00	9.2	13.7	7.5	140.5	3,388,447.5	1,930.0	1.4	1.0
12/30/2020 02:00	8.5	13.9	7.2	107.3	3,255,426.1	1,711.6	1.1	0.7
12/30/2020 03:00	9.3	13.8	7.7	120.8	3,206,118.6	1,732.5	1.3	0.9
12/30/2020 04:00	11.1	13.4	8.7	168.7	3,451,625.7	2,041.6	1.7	1.4
12/30/2020 05:00	11.1	13.4	8.7	168.3	3,371,881.5	2,068.3	1.7	1.4
12/30/2020 06:00	11.6	13.3	9.0	192.8	3,392,633.5	2,204.9	2.0	1.8
12/30/2020 07:00	10.6	13.4	8.3	174.3	3,402,616.8	2,112.0	1.8	1.5
12/30/2020 08:00	11.0	13.4	8.7	169.6	3,409,198.7	2,041.4	1.7	1.4
12/30/2020 09:00	9.4	13.6	7.6	138.8	3,384,558.4	1,952.5	1.4	1.0
12/30/2020 10:00	8.7	13.8	7.2	107.9	3,274,445.9	1,721.6	1.1	0.7
12/30/2020 11:00	8.9	13.8	7.4	107.4	3,239,259.3	1,703.1	1.1	0.7
12/30/2020 12:00	9.0	13.8	7.5	108.9	3,234,314.1	1,700.5	1.1	0.7
12/30/2020 13:00	9.0	13.8	7.5	106.1	3,158,615.4	1,660.7	1.1	0.7
12/30/2020 14:00	9.1	13.8	7.6	105.7	3,158,044.8	1,660.4	1.1	0.7
12/30/2020 15:00	9.7	13.7	7.9	133.8	3,210,930.1	1,735.1	1.4	0.9
12/30/2020 16:00	11.6	13.4	9.1	176.8	3,336,178.6	2,046.4	1.8	1.4
12/30/2020 17:00	11.4	13.3	8.9	200.4	3,294,987.2	2,165.5	2.1	1.7
12/30/2020 18:00	11.2	13.3	8.7	197.0	3,277,641.2	2,154.1	2.1	1.7
12/30/2020 19:00	11.0	13.3	8.5	181.8	3,307,637.6	2,077.2	1.9	1.5
12/30/2020 20:00	10.9	13.3	8.5	182.1	3,305,821.9	2,100.2	1.9	1.5
12/30/2020 21:00	11.0	13.3	8.5	182.8	3,294,016.6	2,092.7	1.9	1.5
12/30/2020 22:00	11.2	13.3	8.7	181.9	3,288,688.6	2,065.3	1.9	1.4
12/30/2020 23:00	11.1	13.4	8.7	176.4	3,351,014.1	2,055.5	1.8	1.4
Average/Sum#:	10.3	13.5	8.2	154.3	3,308,237.5	1,949.8	1.6	1.2
Minimum:	8.5	13.3	7.2	105.7	3,158,044.8	1,660.4	1.1	0.7
Maximum:	11.6	13.9	9.1	200.4	3,451,625.7	2,204.9	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/31/2020 00:00	9.8	13.6	7.9	143.1	3,335,848.5	1,924.4	1.5	1.2
12/31/2020 01:00	8.8	13.8	7.3	104.3	3,084,206.3	1,644.1	1.1	0.7
12/31/2020 02:00	9.8	13.6	7.9	141.9	3,321,574.9	1,843.4	1.4	0.9
12/31/2020 03:00	10.1	13.6	8.2	143.1	3,377,797.9	1,948.6	1.4	1.0
12/31/2020 04:00	10.0	13.6	8.1	141.2	3,342,955.6	1,928.5	1.4	1.0
12/31/2020 05:00	8.8	13.8	7.3	118.4	3,212,331.9	1,712.4	1.2	0.9
12/31/2020 06:00	9.1	13.8	7.6	107.3	3,194,323.1	1,702.8	1.1	0.7
12/31/2020 07:00	9.0	13.8	7.5	104.8	3,115,909.5	1,661.0	1.1	0.7
12/31/2020 08:00	9.0	13.8	7.5	101.9	3,074,928.3	1,616.7	1.1	0.6
12/31/2020 09:00	9.1	13.8	7.6	107.1	3,201,600.1	1,683.3	1.1	0.7
12/31/2020 10:00	9.2	13.8	7.6	109.7	3,243,824.0	1,705.5	1.1	0.7
12/31/2020 11:00	9.2	13.8	7.6	109.8	3,233,743.5	1,700.2	1.1	0.7
12/31/2020 12:00	9.2	13.9	7.8	107.0	3,165,652.7	1,664.4	1.1	0.7
12/31/2020 13:00	9.2	13.9	7.8	106.6	3,139,215.2	1,650.5	1.1	0.7
12/31/2020 14:00	9.2	13.9	7.8	106.9	3,164,131.1	1,663.6	1.1	0.7
12/31/2020 15:00	9.2	13.9	7.8	108.8	3,249,720.1	1,708.6	1.1	0.7
12/31/2020 16:00	10.9	13.7	8.9	156.2	3,281,460.9	1,845.1	1.6	1.1
12/31/2020 17:00	11.6	13.4	9.1	189.1	3,291,442.6	2,115.1	2.0	1.7
12/31/2020 18:00	11.3	13.3	8.8	198.0	3,302,138.7	2,170.2	2.1	1.7
12/31/2020 19:00	11.3	13.3	8.8	199.1	3,300,312.8	2,169.0	2.1	1.7
12/31/2020 20:00	11.1	13.3	8.6	195.6	3,303,051.6	2,170.8	2.1	1.7
12/31/2020 21:00	11.2	13.3	8.7	197.9	3,298,030.4	2,167.5	2.1	1.7
12/31/2020 22:00	11.0	13.3	8.5	188.9	3,323,032.8	2,135.4	2.0	1.7
12/31/2020 23:00	10.9	13.4	8.6	181.3	3,299,368.3	2,096.1	1.9	1.5
Average/Sum#:	9.9	13.6	8.1	140.3	3,244,025.0	1,859.5	1.5	1.1
Minimum:	8.8	13.3	7.3	101.9	3,074,928.3	1,616.7	1.1	0.6
Maximum:	11.6	13.9	9.1	199.1	3,377,797.9	2,170.8	2.1	1.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/01/2020 00:00	7.4	13.7	6.1	101.2	3,166,304.8	1,618.5	1.0	0.6
10/01/2020 01:00	8.6	13.5	6.9	115.8	3,181,749.4	1,765.8	1.2	0.9
10/01/2020 02:00	8.3	13.3	6.4	132.5	3,238,771.2	1,963.0	1.3	1.0
10/01/2020 03:00	8.1	13.2	6.2	140.5	3,182,542.3	1,975.4	1.4	1.0
10/01/2020 04:00	7.0	13.7	5.7	100.6	3,225,385.7	1,648.7	1.0	0.7
10/01/2020 05:00	8.0	13.5	6.4	110.6	3,296,661.0	1,805.5	1.1	0.7
10/01/2020 06:00	8.9	13.1	6.7	144.5	3,340,254.3	2,048.9	1.4	1.0
10/01/2020 07:00	8.3	13.3	6.4	114.2	3,180,184.8	1,834.6	1.2	0.9
10/01/2020 08:00	8.1	13.7	6.6	100.7	3,008,821.0	1,538.0	1.1	0.6
10/01/2020 09:00	7.5	13.9	6.3	84.8	2,616,791.4	1,318.5	1.0	0.5
10/01/2020 10:00	7.8	13.8	6.5	95.0	2,927,242.4	1,496.3	1.0	0.6
10/01/2020 11:00	8.8	13.1	6.7	125.7	3,303,899.4	2,026.6	1.2	1.0
10/01/2020 12:00	8.8	13.1	6.7	141.0	3,277,748.4	2,106.3	1.4	1.1
10/01/2020 13:00	8.9	13.0	6.6	148.6	3,259,077.9	2,141.9	1.5	1.3
10/01/2020 14:00	8.8	13.0	6.6	151.6	3,232,142.5	2,147.8	1.5	1.3
10/01/2020 15:00	8.8	13.0	6.6	144.3	3,226,363.8	2,120.4	1.5	1.3
10/01/2020 16:00	8.8	13.0	6.6	141.2	3,235,996.0	2,103.1	1.4	1.1
10/01/2020 17:00	8.8	13.0	6.6	140.0	3,226,763.9	2,097.1	1.4	1.0
10/01/2020 18:00	8.6	13.0	6.4	134.7	3,260,961.5	2,071.7	1.3	1.0
10/01/2020 19:00	8.6	13.0	6.4	134.1	3,230,596.6	2,076.0	1.3	1.0
10/01/2020 20:00	8.6	13.0	6.4	134.0	3,248,181.3	2,087.3	1.3	1.0
10/01/2020 21:00	8.6	13.0	6.4	133.5	3,287,720.4	2,088.7	1.3	1.0
10/01/2020 22:00	8.4	13.1	6.4	128.2	3,288,210.9	2,065.0	1.3	1.0
10/01/2020 23:00	8.2	13.1	6.2	121.6	3,279,028.9	1,987.4	1.2	1.0
Average/Sum#:	8.4	13.3	6.5	125.8	3,196,725.0	1,922.2	1.3	0.9
Minimum:	7.0	13.0	5.7	84.8	2,616,791.4	1,318.5	1.0	0.5
Maximum:	8.9	13.9	6.9	151.6	3,340,254.3	2,147.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/02/2020 00:00	7.2	13.7	5.9	96.4	3,037,036.1	1,574.6	1.0	0.6
10/02/2020 01:00	7.5	13.7	6.1	103.0	3,276,396.1	1,698.7	1.0	0.7
10/02/2020 02:00	7.4	13.7	6.1	94.8	3,007,451.6	1,537.3	1.0	0.6
10/02/2020 03:00	7.5	13.7	6.1	97.1	3,090,595.2	1,579.8	1.0	0.6
10/02/2020 04:00	8.1	13.6	6.5	103.0	3,123,413.1	1,665.0	1.0	0.7
10/02/2020 05:00	8.8	13.1	6.7	123.6	3,354,429.8	2,033.1	1.2	1.0
10/02/2020 06:00	8.6	13.2	6.6	125.6	3,325,530.2	1,991.3	1.2	1.0
10/02/2020 07:00	7.9	13.6	6.4	108.4	3,378,042.1	1,751.4	1.0	0.7
10/02/2020 08:00	7.4	13.7	6.1	90.5	2,864,053.3	1,464.0	1.0	0.6
10/02/2020 09:00	7.4	13.8	6.1	97.0	3,144,515.9	1,584.4	1.0	0.6
10/02/2020 10:00	7.2	13.8	6.0	98.1	3,210,208.6	1,617.5	1.0	0.6
10/02/2020 11:00	8.0	13.6	6.5	103.6	3,130,354.1	1,668.7	1.0	0.7
10/02/2020 12:00	9.0	13.0	6.7	136.1	3,261,591.1	2,072.1	1.4	1.0
10/02/2020 13:00	8.9	13.0	6.6	150.4	3,257,123.2	2,164.4	1.5	1.3
10/02/2020 14:00	8.9	13.0	6.6	149.8	3,212,044.4	2,157.9	1.5	1.3
10/02/2020 15:00	8.8	13.0	6.6	147.7	3,216,943.4	2,137.7	1.5	1.3
10/02/2020 16:00	8.8	13.0	6.6	145.4	3,218,899.7	2,139.0	1.5	1.3
10/02/2020 17:00	8.7	13.0	6.5	144.9	3,224,768.7	2,142.9	1.5	1.3
10/02/2020 18:00	8.6	13.0	6.4	139.6	3,246,612.9	2,110.0	1.4	1.1
10/02/2020 19:00	8.5	13.0	6.3	135.8	3,244,602.1	2,085.0	1.4	1.0
10/02/2020 20:00	8.7	13.0	6.5	141.1	3,252,538.5	2,090.1	1.4	1.0
10/02/2020 21:00	8.5	13.1	6.4	129.6	3,268,735.5	2,028.9	1.3	1.0
10/02/2020 22:00	8.6	13.1	6.5	131.7	3,298,057.2	2,047.1	1.3	1.0
10/02/2020 23:00	8.6	13.1	6.5	134.4	3,274,994.3	2,056.7	1.3	1.0
Average/Sum#:	8.2	13.3	6.4	122.0	3,204,955.7	1,891.6	1.2	0.9
Minimum:	7.2	13.0	5.9	90.5	2,864,053.3	1,464.0	1.0	0.6
Maximum:	9.0	13.8	6.7	150.4	3,378,042.1	2,164.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/03/2020 00:00	14.5	14.5	13.4	149.0	2,532,428.2	1,257.5	1.8	0.9
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/03/2020 12:00	38.2	17.3	62.6	32.7	1,950,573.9	455.8	0.3	0.0
10/03/2020 13:00	26.2	14.5	24.2	194.1	2,498,004.0	1,149.2	2.4	1.0
10/03/2020 14:00	7.9	13.7	6.5	100.6	3,151,241.1	1,610.8	1.0	0.6
10/03/2020 15:00	8.0	13.6	6.5	102.7	3,061,132.5	1,631.8	1.1	0.7
10/03/2020 16:00	8.9	13.0	6.6	135.8	3,224,527.6	2,072.1	1.4	1.0
10/03/2020 17:00	8.9	13.0	6.6	155.1	3,239,064.9	2,152.4	1.6	1.3
10/03/2020 18:00	8.8	13.0	6.6	147.7	3,249,187.6	2,135.4	1.5	1.3
10/03/2020 19:00	8.6	13.0	6.4	147.9	3,254,513.1	2,138.9	1.5	1.3
10/03/2020 20:00	8.4	13.1	6.4	135.6	3,268,202.1	2,076.3	1.3	1.0
10/03/2020 21:00	8.4	13.2	6.4	126.6	3,276,184.8	2,009.6	1.2	1.0
10/03/2020 22:00	12.4	14.2	10.9	134.8	2,772,023.6	1,437.2	1.5	0.9
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.3	13.8	13.6	130.2	2,956,423.6	1,677.3	1.4	0.9
Minimum:	7.9	13.0	6.4	32.7	1,950,573.9	455.8	0.3	0.0
Maximum:	38.2	17.3	62.6	194.1	3,276,184.8	2,152.4	2.4	1.3
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/04/2020 13:00	42.4	16.7	59.6	80.1	1,875,409.1	534.1	1.2	0.3
10/04/2020 14:00	13.9	14.0	11.9	142.1	2,807,320.0	1,394.0	1.6	0.8
10/04/2020 15:00	7.8	13.6	6.3	105.4	3,280,446.5	1,700.8	1.0	0.7
10/04/2020 16:00	8.6	13.4	6.8	114.4	3,184,965.1	1,814.1	1.1	0.7
10/04/2020 17:00	8.9	13.0	6.6	143.8	3,247,714.4	2,087.0	1.4	1.0
10/04/2020 18:00	8.6	13.1	6.5	131.2	3,260,841.1	2,024.0	1.3	1.0
10/04/2020 19:00	8.6	13.1	6.5	131.4	3,288,900.9	2,017.4	1.3	1.0
10/04/2020 20:00	8.5	13.1	6.4	130.4	3,254,880.1	2,020.3	1.3	1.0
10/04/2020 21:00	8.6	13.1	6.5	133.3	3,260,663.2	2,047.7	1.3	1.0
10/04/2020 22:00	8.3	13.3	6.4	120.8	3,297,231.6	1,926.2	1.2	1.0
10/04/2020 23:00	8.3	13.3	6.4	118.9	3,291,818.9	1,899.0	1.2	0.9
Average/Sum#:	12.0	13.6	11.8	122.9	3,095,471.9	1,769.5	1.3	0.9
Minimum:	7.8	13.0	6.3	80.1	1,875,409.1	534.1	1.0	0.3
Maximum:	42.4	16.7	59.6	143.8	3,297,231.6	2,087.0	1.6	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/05/2020 00:00	7.3	13.7	6.0	102.2	3,227,733.3	1,649.9	1.0	0.7
10/05/2020 01:00	7.5	13.7	6.1	101.6	3,207,583.2	1,639.6	1.0	0.7
10/05/2020 02:00	7.4	13.7	6.1	98.7	3,111,332.2	1,590.4	1.0	0.6
10/05/2020 03:00	7.3	13.8	6.1	96.7	3,108,394.9	1,566.2	1.0	0.6
10/05/2020 04:00	7.8	13.6	6.3	103.0	3,165,462.5	1,664.3	1.0	0.7
10/05/2020 05:00	8.5	13.2	6.5	124.6	3,367,959.0	2,041.3	1.2	1.0
10/05/2020 06:00	8.4	13.2	6.4	137.6	3,301,290.9	2,025.0	1.4	1.0
10/05/2020 07:00	7.3	13.8	6.1	96.5	3,010,190.4	1,538.7	1.0	0.6
10/05/2020 08:00	7.1	13.8	5.9	93.5	2,991,996.6	1,529.4	1.0	0.6
10/05/2020 09:00	7.1	13.8	5.9	97.0	3,105,854.5	1,587.6	1.0	0.6
10/05/2020 10:00	6.9	13.9	5.8	95.6	3,131,020.2	1,577.6	1.0	0.6
10/05/2020 11:00	7.8	13.8	6.5	100.6	3,176,868.9	1,623.9	1.0	0.6
10/05/2020 12:00	7.5	13.7	6.1	101.5	3,233,993.5	1,653.1	1.0	0.7
10/05/2020 13:00	8.3	13.4	6.5	113.3	3,185,779.1	1,791.3	1.1	0.7
10/05/2020 14:00	8.9	13.0	6.6	152.0	3,277,336.9	2,153.9	1.5	1.3
10/05/2020 15:00	8.7	13.0	6.5	153.9	3,257,123.2	2,164.4	1.5	1.3
10/05/2020 16:00	8.6	13.0	6.4	155.2	3,251,856.2	2,160.9	1.6	1.3
10/05/2020 17:00	8.5	13.0	6.3	149.3	3,252,839.4	2,137.8	1.5	1.3
10/05/2020 18:00	8.5	13.0	6.3	149.8	3,238,011.5	2,151.7	1.5	1.3
10/05/2020 19:00	8.3	13.1	6.3	131.1	3,286,940.7	2,040.2	1.3	1.0
10/05/2020 20:00	8.3	13.2	6.4	131.4	3,283,557.5	2,038.1	1.3	1.0
10/05/2020 21:00	8.3	13.2	6.4	131.0	3,330,472.7	2,042.9	1.3	1.0
10/05/2020 22:00	14.3	14.6	13.4	143.8	2,505,039.7	1,243.9	1.8	0.9
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.2	13.5	6.6	120.0	3,174,288.6	1,809.2	1.2	0.9
Minimum:	6.9	13.0	5.8	93.5	2,505,039.7	1,243.9	1.0	0.6
Maximum:	14.3	14.6	13.4	155.2	3,367,959.0	2,164.4	1.8	1.3
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/06/2020 11:00	43.0	17.0	65.1	75.0	1,867,968.9	504.7	1.0	0.2
10/06/2020 12:00	19.0	14.1	16.5	160.9	2,767,067.2	1,333.6	1.9	0.9
10/06/2020 13:00	7.2	13.7	5.9	100.6	3,206,800.6	1,639.2	1.0	0.7
10/06/2020 14:00	8.1	13.5	6.5	107.9	3,250,600.8	1,732.8	1.1	0.7
10/06/2020 15:00	9.0	13.1	6.8	144.9	3,291,025.9	2,090.8	1.4	1.0
10/06/2020 16:00	8.9	13.0	6.6	154.3	3,249,187.6	2,135.4	1.6	1.3
10/06/2020 17:00	8.8	13.0	6.6	154.7	3,238,312.5	2,151.9	1.6	1.3
10/06/2020 18:00	8.7	13.0	6.5	153.6	3,239,064.9	2,152.4	1.6	1.3
10/06/2020 19:00	8.7	13.0	6.5	149.7	3,234,276.1	2,125.6	1.5	1.3
10/06/2020 20:00	7.6	13.6	6.1	106.4	3,109,156.1	1,657.4	1.1	0.7
10/06/2020 21:00	8.3	13.4	6.5	113.2	3,243,373.5	1,800.0	1.1	0.7
10/06/2020 22:00	8.6	13.1	6.5	134.0	3,314,168.1	2,057.1	1.3	1.0
10/06/2020 23:00	8.3	13.2	6.4	124.4	3,334,632.9	1,972.4	1.2	1.0
Average/Sum#:	11.9	13.6	11.7	129.2	3,103,510.4	1,796.4	1.3	0.9
Minimum:	7.2	13.0	5.9	75.0	1,867,968.9	504.7	1.0	0.2
Maximum:	43.0	17.0	65.1	160.9	3,334,632.9	2,152.4	1.9	1.3
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/07/2020 00:00	8.4	13.2	6.4	128.7	3,334,135.9	2,020.8	1.2	1.0
10/07/2020 01:00	8.2	13.2	6.3	123.6	3,302,341.5	1,953.3	1.2	1.0
10/07/2020 02:00	7.1	13.8	5.9	94.4	2,983,193.2	1,524.9	1.0	0.6
10/07/2020 03:00	7.1	13.8	5.9	97.2	3,160,393.3	1,592.4	1.0	0.6
10/07/2020 04:00	8.0	13.5	6.4	111.5	3,272,023.3	1,815.9	1.1	0.7
10/07/2020 05:00	8.4	13.1	6.4	134.3	3,336,936.9	2,095.6	1.3	1.0
10/07/2020 06:00	8.4	13.2	6.4	134.1	3,369,619.0	2,017.7	1.3	1.0
10/07/2020 07:00	7.2	13.7	5.9	98.7	3,104,680.7	1,587.0	1.0	0.6
10/07/2020 08:00	7.5	13.8	6.2	85.3	2,692,804.4	1,356.8	1.0	0.5
10/07/2020 09:00	7.6	13.9	6.4	84.8	2,565,586.8	1,292.7	1.0	0.5
10/07/2020 10:00	7.2	13.9	6.1	87.0	2,677,522.4	1,349.1	1.0	0.5
10/07/2020 11:00	8.4	13.5	6.7	111.7	3,212,487.0	1,759.4	1.1	0.7
10/07/2020 12:00	8.8	13.1	6.7	150.9	3,272,154.9	2,126.6	1.5	1.3
10/07/2020 13:00	8.8	13.1	6.7	152.3	3,249,187.6	2,135.4	1.5	1.3
10/07/2020 14:00	7.8	13.6	6.3	109.9	3,128,949.7	1,690.8	1.1	0.7
10/07/2020 15:00	8.4	13.4	6.6	113.7	3,156,434.3	1,774.8	1.2	0.9
10/07/2020 16:00	8.8	13.1	6.7	138.0	3,239,711.8	2,058.2	1.4	1.0
10/07/2020 17:00	8.7	13.0	6.5	145.8	3,234,276.1	2,125.6	1.5	1.3
10/07/2020 18:00	8.6	13.0	6.4	140.8	3,242,890.3	2,083.9	1.4	1.0
10/07/2020 19:00	8.4	13.1	6.4	132.4	3,208,752.4	2,015.1	1.3	1.0
10/07/2020 20:00	7.4	13.7	6.1	103.3	3,266,664.1	1,669.8	1.0	0.7
10/07/2020 21:00	8.2	13.4	6.5	112.3	3,251,842.3	1,804.7	1.1	0.7
10/07/2020 22:00	8.4	13.1	6.4	133.6	3,302,223.6	2,073.8	1.3	1.0
10/07/2020 23:00	14.3	14.6	13.4	142.7	2,464,350.7	1,205.7	1.8	0.8
Average/Sum#:	8.3	13.5	6.7	119.5	3,126,215.1	1,797.1	1.2	0.9
Minimum:	7.1	13.0	5.9	84.8	2,464,350.7	1,205.7	1.0	0.5
Maximum:	14.3	14.6	13.4	152.3	3,369,619.0	2,135.4	1.8	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2020 01:00	31.8	17.4	53.6	0.0	1,871,131.7	450.9	0.0	0.0
10/11/2020 02:00	42.0	16.2	52.7	207.7	1,870,157.4	628.2	3.4	0.8
10/11/2020 03:00	47.6	15.6	53.0	258.7	1,867,420.8	709.1	4.3	1.2
10/11/2020 04:00	39.3	15.2	40.7	242.6	2,164,437.5	869.3	3.5	1.1
10/11/2020 05:00	6.8	13.8	5.7	87.1	2,683,079.5	1,351.9	1.0	0.5
10/11/2020 06:00	7.2	13.8	6.0	82.9	2,661,049.6	1,340.8	1.0	0.5
10/11/2020 07:00	7.4	13.8	6.1	84.3	2,655,095.6	1,337.8	1.0	0.5
10/11/2020 08:00	7.4	13.8	6.1	84.2	2,655,691.0	1,338.1	1.0	0.5
10/11/2020 09:00	7.5	13.9	6.3	84.4	2,660,454.2	1,340.5	1.0	0.5
10/11/2020 10:00	7.4	13.9	6.2	84.3	2,666,011.3	1,343.3	1.0	0.5
10/11/2020 11:00	7.5	13.9	6.3	84.3	2,672,163.8	1,346.4	1.0	0.5
10/11/2020 12:00	7.4	13.9	6.2	84.3	2,675,736.2	1,348.2	1.0	0.5
10/11/2020 13:00	7.5	13.9	6.3	84.5	2,717,904.6	1,349.6	1.0	0.5
10/11/2020 14:00	7.5	13.9	6.3	84.4	2,722,133.7	1,351.7	1.0	0.5
10/11/2020 15:00	7.6	13.9	6.4	85.3	2,752,140.2	1,366.6	1.0	0.5
10/11/2020 16:00	8.8	13.3	6.8	126.3	3,343,475.6	1,928.8	1.2	1.0
10/11/2020 17:00	8.8	13.3	6.8	128.1	3,360,810.1	1,938.8	1.2	1.0
10/11/2020 18:00	8.8	13.3	6.8	126.5	3,339,488.7	1,926.5	1.2	1.0
10/11/2020 19:00	8.7	13.3	6.8	126.6	3,306,899.9	1,907.7	1.2	1.0
10/11/2020 20:00	7.6	13.9	6.4	87.5	2,684,667.2	1,352.7	1.0	0.5
10/11/2020 21:00	7.5	13.9	6.3	84.2	2,650,729.3	1,335.6	1.0	0.5
10/11/2020 22:00	7.4	13.9	6.2	83.8	2,650,927.8	1,335.7	1.0	0.5
10/11/2020 23:00	7.3	13.8	6.1	83.6	2,649,538.5	1,335.0	1.0	0.5
Average/Sum#:	13.3	14.2	13.9	108.1	2,664,397.6	1,327.5	1.3	0.6
Minimum:	6.8	13.3	5.7	0.0	1,867,420.8	450.9	0.0	0.0
Maximum:	47.6	17.4	53.6	258.7	3,360,810.1	1,938.8	4.3	1.2
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/12/2020 00:00	7.3	13.8	6.1	83.4	2,649,736.9	1,335.1	1.0	0.5
10/12/2020 01:00	7.3	13.8	6.1	83.2	2,651,126.2	1,335.8	1.0	0.5
10/12/2020 02:00	7.2	13.8	6.0	83.2	2,650,729.3	1,335.6	1.0	0.5
10/12/2020 03:00	7.2	13.8	6.0	83.2	2,647,553.8	1,334.0	1.0	0.5
10/12/2020 04:00	7.2	13.8	6.0	83.1	2,648,546.1	1,334.5	1.0	0.5
10/12/2020 05:00	7.2	13.8	6.0	83.5	2,645,569.1	1,333.0	1.0	0.5
10/12/2020 06:00	7.4	13.8	6.1	83.7	2,643,584.5	1,332.0	1.0	0.5
10/12/2020 07:00	7.6	13.8	6.3	84.5	2,654,897.1	1,337.7	1.0	0.5
10/12/2020 08:00	7.4	13.8	6.1	84.0	2,654,500.2	1,337.5	1.0	0.5
10/12/2020 09:00	7.3	13.8	6.1	83.9	2,664,622.0	1,342.6	1.0	0.5
10/12/2020 10:00	7.3	13.8	6.1	85.9	2,672,560.7	1,346.6	1.0	0.5
10/12/2020 11:00	7.3	13.9	6.2	86.0	2,673,950.0	1,347.3	1.0	0.5
10/12/2020 12:00	7.6	13.8	6.3	98.7	3,183,614.0	1,604.1	1.0	0.6
10/12/2020 13:00	7.6	13.9	6.4	95.1	3,044,091.5	1,533.8	1.0	0.6
10/12/2020 14:00	7.4	13.9	6.2	96.4	3,103,036.3	1,563.5	1.0	0.6
10/12/2020 15:00	8.2	13.6	6.6	104.1	3,097,900.6	1,651.4	1.1	0.7
10/12/2020 16:00	9.0	13.2	6.9	126.8	3,310,047.2	2,006.2	1.2	1.0
10/12/2020 17:00	8.9	13.2	6.8	129.3	3,286,783.5	1,992.1	1.3	1.0
10/12/2020 18:00	8.8	13.2	6.7	126.4	3,305,656.9	1,979.4	1.2	1.0
10/12/2020 19:00	8.6	13.3	6.7	124.0	3,276,519.0	1,914.1	1.2	1.0
10/12/2020 20:00	8.0	13.6	6.5	111.1	3,359,911.7	1,742.0	1.0	0.7
10/12/2020 21:00	8.4	13.5	6.7	112.1	3,264,525.1	1,787.9	1.1	0.7
10/12/2020 22:00	8.6	13.2	6.6	124.4	3,318,850.1	1,987.3	1.2	1.0
10/12/2020 23:00	8.4	13.3	6.5	123.7	3,337,629.6	1,949.8	1.2	1.0
Average/Sum#:	7.8	13.6	6.3	99.2	2,947,747.6	1,573.5	1.1	0.7
Minimum:	7.2	13.2	6.0	83.1	2,643,584.5	1,332.0	1.0	0.5
Maximum:	9.0	13.9	6.9	129.3	3,359,911.7	2,006.2	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/13/2020 00:00	7.5	13.7	6.1	104.0	3,240,840.6	1,656.6	1.0	0.7
10/13/2020 01:00	7.4	13.7	6.1	99.8	3,148,306.7	1,609.3	1.0	0.6
10/13/2020 02:00	7.5	13.8	6.2	86.3	2,712,634.1	1,386.6	1.0	0.6
10/13/2020 03:00	7.3	13.8	6.1	97.4	3,115,049.2	1,592.3	1.0	0.6
10/13/2020 04:00	8.4	13.5	6.7	111.4	3,281,323.4	1,797.1	1.1	0.7
10/13/2020 05:00	8.6	13.2	6.6	122.0	3,344,269.6	1,978.1	1.2	1.0
10/13/2020 06:00	8.4	13.3	6.5	129.9	3,347,809.3	1,931.3	1.2	1.0
10/13/2020 07:00	7.4	13.7	6.1	102.6	3,202,888.0	1,637.2	1.0	0.7
10/13/2020 08:00	7.4	13.7	6.1	91.7	2,883,812.1	1,474.1	1.0	0.6
10/13/2020 09:00	7.4	13.8	6.1	84.8	2,665,614.3	1,343.1	1.0	0.5
10/13/2020 10:00	7.4	13.7	6.1	99.3	3,150,067.3	1,610.2	1.0	0.6
10/13/2020 11:00	7.6	13.7	6.2	93.2	2,913,743.8	1,489.4	1.0	0.6
10/13/2020 12:00	7.6	13.7	6.2	93.1	2,915,700.1	1,490.4	1.0	0.6
10/13/2020 13:00	7.7	13.8	6.4	88.5	2,774,374.4	1,397.9	1.0	0.6
10/13/2020 14:00	7.6	13.7	6.2	99.4	3,134,416.8	1,602.2	1.0	0.6
10/13/2020 15:00	8.5	13.6	6.9	104.0	3,075,014.3	1,639.2	1.1	0.7
10/13/2020 16:00	9.0	13.2	6.9	128.3	3,296,889.2	2,022.3	1.2	1.0
10/13/2020 17:00	8.7	13.2	6.7	132.1	3,278,724.2	2,035.1	1.3	1.0
10/13/2020 18:00	8.5	13.2	6.5	128.5	3,272,924.3	2,007.6	1.3	1.0
10/13/2020 19:00	8.4	13.2	6.4	124.0	3,279,855.9	1,940.0	1.2	1.0
10/13/2020 20:00	7.4	13.7	6.1	104.3	3,307,551.2	1,690.7	1.0	0.7
10/13/2020 21:00	8.2	13.5	6.5	111.0	3,287,896.7	1,800.7	1.1	0.7
10/13/2020 22:00	8.6	13.1	6.5	136.0	3,315,266.2	2,106.2	1.3	1.1
10/13/2020 23:00	8.1	13.3	6.3	119.9	3,276,474.6	1,938.0	1.2	1.0
Average/Sum#:	7.9	13.5	6.4	108.0	3,134,226.9	1,715.7	1.1	0.8
Minimum:	7.3	13.1	6.1	84.8	2,665,614.3	1,343.1	1.0	0.5
Maximum:	9.0	13.8	6.9	136.0	3,347,809.3	2,106.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/14/2020 00:00	7.2	13.7	5.9	102.1	3,256,686.8	1,664.7	1.0	0.7
10/14/2020 01:00	8.1	13.6	6.5	103.2	3,153,099.6	1,657.8	1.0	0.7
10/14/2020 02:00	8.5	13.1	6.4	126.7	3,335,852.6	2,046.2	1.2	1.0
10/14/2020 03:00	8.1	13.3	6.3	119.1	3,299,970.4	1,927.8	1.2	1.0
10/14/2020 04:00	7.1	13.7	5.8	97.8	3,121,896.3	1,595.8	1.0	0.6
10/14/2020 05:00	8.2	13.4	6.5	109.6	3,333,438.0	1,801.3	1.0	0.7
10/14/2020 06:00	8.7	13.2	6.7	130.2	3,341,729.5	2,001.0	1.3	1.0
10/14/2020 07:00	8.5	13.2	6.5	119.3	3,274,807.2	1,913.1	1.2	1.0
10/14/2020 08:00	7.3	13.8	6.1	89.0	2,757,433.8	1,409.5	1.0	0.6
10/14/2020 09:00	7.3	13.9	6.2	84.9	2,587,219.7	1,303.6	1.0	0.5
10/14/2020 10:00	7.2	13.9	6.1	92.3	3,039,725.2	1,531.6	1.0	0.6
10/14/2020 11:00	8.0	13.6	6.5	110.3	3,247,386.4	1,754.8	1.1	0.7
10/14/2020 12:00	8.8	13.0	6.6	143.3	3,263,431.7	2,097.1	1.4	1.0
10/14/2020 13:00	8.8	13.0	6.6	144.2	3,239,905.9	2,129.3	1.4	1.1
10/14/2020 14:00	7.8	13.5	6.2	114.8	3,358,368.6	1,741.2	1.1	0.7
10/14/2020 15:00	8.4	13.4	6.6	115.1	3,449,998.5	1,813.9	1.1	0.7
10/14/2020 16:00	8.8	13.1	6.7	148.7	3,278,059.6	2,106.5	1.5	1.3
10/14/2020 17:00	8.6	13.0	6.4	153.2	3,276,686.4	2,177.4	1.5	1.3
10/14/2020 18:00	8.4	13.1	6.4	141.3	3,269,189.5	2,100.8	1.4	1.1
10/14/2020 19:00	8.4	13.1	6.4	138.0	3,218,147.3	2,044.5	1.4	1.0
10/14/2020 20:00	7.2	13.7	5.9	103.1	3,287,596.7	1,680.5	1.0	0.7
10/14/2020 21:00	8.3	13.4	6.5	115.4	3,259,763.6	1,832.9	1.1	0.7
10/14/2020 22:00	8.7	13.1	6.6	145.8	3,310,621.9	2,151.6	1.4	1.1
10/14/2020 23:00	8.2	13.2	6.3	125.7	3,282,823.7	1,989.7	1.2	1.0
Average/Sum#:	8.1	13.4	6.4	119.7	3,218,493.3	1,853.0	1.2	0.9
Minimum:	7.1	13.0	5.8	84.9	2,587,219.7	1,303.6	1.0	0.5
Maximum:	8.8	13.9	6.7	153.2	3,449,998.5	2,177.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/15/2020 00:00	7.2	13.7	5.9	102.6	3,268,424.7	1,670.7	1.0	0.7
10/15/2020 01:00	8.3	13.5	6.6	112.2	3,290,452.9	1,802.1	1.1	0.7
10/15/2020 02:00	8.9	13.1	6.7	141.7	3,339,821.4	2,121.8	1.4	1.1
10/15/2020 03:00	8.6	13.1	6.5	140.0	3,298,242.7	2,071.3	1.4	1.0
10/15/2020 04:00	7.4	13.7	6.1	104.8	3,302,269.1	1,688.0	1.0	0.7
10/15/2020 05:00	8.3	13.5	6.6	112.2	3,373,410.4	1,822.9	1.1	0.7
10/15/2020 06:00	9.0	13.1	6.8	138.0	3,352,807.4	2,056.6	1.3	1.0
10/15/2020 07:00	8.5	13.3	6.6	123.9	3,165,253.3	1,849.1	1.3	0.9
10/15/2020 08:00	7.5	13.9	6.3	84.7	2,581,861.1	1,300.9	1.0	0.5
10/15/2020 09:00	7.3	13.9	6.2	83.3	2,575,907.1	1,297.9	1.0	0.5
10/15/2020 10:00	7.1	13.9	6.0	82.8	2,612,028.2	1,316.1	1.0	0.5
10/15/2020 11:00	7.3	13.8	6.1	95.2	3,055,185.8	1,561.7	1.0	0.6
10/15/2020 12:00	7.5	13.7	6.1	101.0	3,198,584.1	1,635.0	1.0	0.7
10/15/2020 13:00	8.6	13.4	6.8	113.9	3,251,662.2	1,804.6	1.1	0.7
10/15/2020 14:00	9.1	13.0	6.8	151.2	3,293,770.0	2,164.7	1.5	1.3
10/15/2020 15:00	8.9	13.0	6.6	155.2	3,273,375.7	2,175.2	1.6	1.3
10/15/2020 16:00	8.8	13.0	6.6	155.6	3,262,691.2	2,168.1	1.6	1.3
10/15/2020 17:00	8.8	13.0	6.6	151.8	3,263,794.8	2,145.0	1.5	1.3
10/15/2020 18:00	8.7	13.0	6.5	152.5	3,279,467.1	2,155.3	1.5	1.3
10/15/2020 19:00	8.7	13.0	6.5	149.0	3,281,079.3	2,132.4	1.5	1.3
10/15/2020 20:00	8.7	13.0	6.5	153.2	3,280,227.9	2,155.8	1.5	1.3
10/15/2020 21:00	8.7	13.0	6.5	153.8	3,273,225.2	2,175.1	1.5	1.3
10/15/2020 22:00	8.6	13.1	6.5	147.6	3,288,003.3	2,136.9	1.5	1.3
10/15/2020 23:00	8.5	13.2	6.5	137.7	3,246,180.2	2,014.9	1.4	1.0
Average/Sum#:	8.3	13.3	6.5	126.8	3,183,655.2	1,892.6	1.3	1.0
Minimum:	7.1	13.0	5.9	82.8	2,575,907.1	1,297.9	1.0	0.5
Maximum:	9.1	13.9	6.8	155.6	3,373,410.4	2,175.2	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/16/2020 00:00	7.4	13.7	6.1	105.4	3,283,532.5	1,702.4	1.0	0.7
10/16/2020 01:00	7.5	13.9	6.3	85.3	2,604,287.9	1,312.2	1.0	0.5
10/16/2020 02:00	7.8	13.7	6.4	103.5	3,241,485.4	1,680.6	1.0	0.7
10/16/2020 03:00	8.5	13.4	6.7	113.3	3,294,469.9	1,804.3	1.1	0.7
10/16/2020 04:00	8.4	13.3	6.5	121.6	3,224,309.7	1,883.6	1.2	0.9
10/16/2020 05:00	8.4	13.6	6.8	109.1	3,260,194.4	1,690.3	1.1	0.7
10/16/2020 06:00	9.2	13.2	7.0	147.0	3,270,346.5	2,029.9	1.5	1.2
10/16/2020 07:00	8.7	13.2	6.7	126.8	3,287,294.8	1,944.4	1.2	1.0
10/16/2020 08:00	7.4	13.7	6.1	99.7	3,115,831.7	1,592.7	1.0	0.6
10/16/2020 09:00	7.5	13.9	6.3	86.9	2,765,840.3	1,393.6	1.0	0.6
10/16/2020 10:00	7.2	13.9	6.1	92.0	2,985,940.6	1,504.5	1.0	0.6
10/16/2020 11:00	7.7	13.7	6.3	97.8	3,004,174.7	1,579.5	1.0	0.6
10/16/2020 12:00	8.8	13.1	6.7	140.4	3,275,414.1	2,104.8	1.4	1.1
10/16/2020 13:00	8.7	13.1	6.6	137.5	3,260,489.3	2,071.4	1.4	1.0
10/16/2020 14:00	8.7	13.0	6.5	149.1	3,235,645.5	2,126.5	1.5	1.3
10/16/2020 15:00	8.7	13.0	6.5	149.7	3,243,405.6	2,131.6	1.5	1.3
10/16/2020 16:00	8.5	13.1	6.4	134.0	3,255,726.9	2,044.6	1.3	1.0
10/16/2020 17:00	8.6	13.1	6.5	140.6	3,253,472.2	2,090.7	1.4	1.0
10/16/2020 18:00	8.5	13.1	6.4	138.9	3,273,711.3	2,079.8	1.4	1.0
10/16/2020 19:00	8.6	13.0	6.4	149.3	3,265,772.8	2,146.3	1.5	1.3
10/16/2020 20:00	8.4	13.0	6.3	144.0	3,263,538.3	2,121.0	1.4	1.1
10/16/2020 21:00	8.4	13.1	6.4	138.2	3,257,673.9	2,093.4	1.4	1.0
10/16/2020 22:00	8.3	13.1	6.3	131.6	3,261,300.1	2,048.1	1.3	1.0
10/16/2020 23:00	8.3	13.2	6.4	126.5	3,273,413.4	2,007.9	1.2	1.0
Average/Sum#:	8.3	13.3	6.4	123.7	3,185,719.7	1,882.7	1.2	0.9
Minimum:	7.2	13.0	6.1	85.3	2,604,287.9	1,312.2	1.0	0.5
Maximum:	9.2	13.9	7.0	149.7	3,294,469.9	2,146.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/17/2020 00:00	8.1	13.2	6.2	119.1	3,258,384.7	1,927.3	1.2	1.0
10/17/2020 01:00	7.1	13.7	5.8	95.5	3,024,471.6	1,546.0	1.0	0.6
10/17/2020 02:00	7.3	13.8	6.1	84.0	2,604,287.9	1,312.2	1.0	0.5
10/17/2020 03:00	7.1	13.9	6.0	96.9	3,190,758.8	1,607.7	1.0	0.6
10/17/2020 04:00	6.8	13.8	5.7	96.7	3,180,835.4	1,602.7	1.0	0.6
10/17/2020 05:00	7.0	13.8	5.8	99.2	3,239,862.5	1,656.1	1.0	0.7
10/17/2020 06:00	7.9	13.5	6.3	108.0	3,235,265.1	1,795.5	1.1	0.7
10/17/2020 07:00	8.2	13.3	6.4	116.8	3,193,879.0	1,842.5	1.2	0.9
10/17/2020 08:00	7.4	13.7	6.1	102.8	3,220,461.8	1,669.7	1.0	0.7
10/17/2020 09:00	7.6	13.7	6.2	103.6	3,232,227.3	1,675.8	1.0	0.7
10/17/2020 10:00	7.6	13.7	6.2	101.1	3,179,607.8	1,625.3	1.0	0.7
10/17/2020 11:00	7.4	13.7	6.1	91.7	2,894,571.9	1,479.6	1.0	0.6
10/17/2020 12:00	7.5	13.9	6.3	90.3	2,904,767.4	1,463.6	1.0	0.6
10/17/2020 13:00	7.3	13.9	6.2	89.0	2,884,523.8	1,453.4	1.0	0.6
10/17/2020 14:00	7.9	13.6	6.4	102.1	3,081,017.3	1,642.4	1.0	0.7
10/17/2020 15:00	8.6	13.1	6.5	134.1	3,250,048.7	2,088.5	1.3	1.0
10/17/2020 16:00	8.5	13.0	6.3	145.4	3,243,128.0	2,155.1	1.5	1.3
10/17/2020 17:00	8.4	13.0	6.3	149.2	3,245,234.8	2,156.5	1.5	1.3
10/17/2020 18:00	8.2	13.1	6.2	128.7	3,235,185.5	2,031.7	1.3	1.0
10/17/2020 19:00	8.3	13.1	6.3	131.7	3,261,140.9	2,048.0	1.3	1.0
10/17/2020 20:00	8.2	13.0	6.1	131.3	3,284,866.9	2,062.9	1.3	1.0
10/17/2020 21:00	8.0	13.2	6.1	121.0	3,312,337.0	1,983.4	1.2	1.0
10/17/2020 22:00	8.2	13.1	6.2	132.4	3,281,363.8	2,060.7	1.3	1.0
10/17/2020 23:00	8.1	13.1	6.1	131.0	3,277,860.6	2,058.5	1.3	1.0
Average/Sum#:	7.8	13.5	6.2	112.6	3,154,837.0	1,789.4	1.1	0.8
Minimum:	6.8	13.0	5.7	84.0	2,604,287.9	1,312.2	1.0	0.5
Maximum:	8.6	13.9	6.5	149.2	3,312,337.0	2,156.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/18/2020 00:00	7.1	13.6	5.7	104.5	3,163,182.7	1,686.2	1.1	0.7
10/18/2020 01:00	8.0	13.4	6.3	112.0	3,243,193.4	1,799.9	1.1	0.7
10/18/2020 02:00	8.5	13.0	6.3	144.6	3,305,698.1	2,148.4	1.4	1.1
10/18/2020 03:00	8.1	13.1	6.1	137.4	3,238,844.3	2,081.3	1.4	1.0
10/18/2020 04:00	6.9	13.7	5.7	100.6	3,200,402.6	1,659.3	1.0	0.7
10/18/2020 05:00	6.9	13.7	5.7	96.5	3,077,926.0	1,595.8	1.0	0.6
10/18/2020 06:00	7.2	13.7	5.9	93.9	2,995,953.4	1,553.3	1.0	0.6
10/18/2020 07:00	7.3	13.7	6.0	91.8	2,934,285.2	1,499.9	1.0	0.6
10/18/2020 08:00	7.3	13.8	6.1	97.7	3,128,547.8	1,599.2	1.0	0.6
10/18/2020 09:00	7.1	13.8	5.9	97.7	3,145,372.2	1,607.8	1.0	0.6
10/18/2020 10:00	7.0	13.8	5.8	95.0	3,122,089.1	1,573.1	1.0	0.6
10/18/2020 11:00	6.9	13.9	5.8	96.5	3,189,171.1	1,606.9	1.0	0.6
10/18/2020 12:00	7.2	13.7	5.9	98.5	3,166,891.7	1,618.8	1.0	0.6
10/18/2020 13:00	7.3	13.7	6.0	98.0	3,079,469.0	1,596.6	1.0	0.6
10/18/2020 14:00	7.6	13.7	6.2	100.1	3,142,346.8	1,629.2	1.0	0.7
10/18/2020 15:00	8.2	13.5	6.5	109.7	3,215,926.6	1,737.8	1.1	0.7
10/18/2020 16:00	9.2	13.0	6.9	142.4	3,201,963.2	2,057.6	1.4	1.0
10/18/2020 17:00	8.4	13.4	6.6	119.2	3,085,945.2	1,757.7	1.2	0.9
10/18/2020 18:00	7.0	13.9	5.9	83.2	2,548,518.6	1,284.1	1.0	0.5
10/18/2020 19:00	6.9	13.8	5.7	83.5	2,734,482.5	1,377.8	1.0	0.6
10/18/2020 20:00	7.6	13.7	6.2	103.2	3,256,915.5	1,688.6	1.0	0.7
10/18/2020 21:00	7.0	13.7	5.7	101.4	3,290,139.9	1,681.8	1.0	0.7
10/18/2020 22:00	6.9	13.8	5.7	91.1	2,905,722.9	1,485.3	1.0	0.6
10/18/2020 23:00	7.9	13.5	6.3	110.2	3,278,767.2	1,795.7	1.1	0.7
Average/Sum#:	7.5	13.6	6.0	104.5	3,110,489.8	1,671.8	1.1	0.7
Minimum:	6.9	13.0	5.7	83.2	2,548,518.6	1,284.1	1.0	0.5
Maximum:	9.2	13.9	6.9	144.6	3,305,698.1	2,148.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/19/2020 00:00	7.7	13.4	6.1	111.6	3,213,231.4	1,830.2	1.1	0.7
10/19/2020 01:00	6.9	13.7	5.7	98.1	3,127,109.5	1,621.3	1.0	0.6
10/19/2020 02:00	7.1	13.7	5.8	96.1	3,034,528.7	1,573.3	1.0	0.6
10/19/2020 03:00	7.4	13.7	6.1	102.0	3,227,598.3	1,673.4	1.0	0.7
10/19/2020 04:00	7.9	13.5	6.3	110.3	3,293,922.1	1,804.0	1.1	0.7
10/19/2020 05:00	8.3	13.1	6.3	128.4	3,323,401.9	2,087.1	1.2	1.0
10/19/2020 06:00	8.1	13.1	6.1	134.8	3,306,757.1	2,052.5	1.3	1.0
10/19/2020 07:00	7.2	13.7	5.9	103.1	3,243,028.4	1,681.4	1.0	0.7
10/19/2020 08:00	6.9	13.8	5.7	94.3	3,032,883.7	1,550.3	1.0	0.6
10/19/2020 09:00	7.0	13.8	5.8	98.3	3,175,695.1	1,623.3	1.0	0.6
10/19/2020 10:00	7.0	13.8	5.8	97.5	3,205,842.3	1,615.3	1.0	0.6
10/19/2020 11:00	6.9	13.9	5.8	95.5	3,136,577.2	1,580.4	1.0	0.6
10/19/2020 12:00	6.9	13.9	5.8	87.3	2,871,821.9	1,447.0	1.0	0.6
10/19/2020 13:00	7.0	13.9	5.9	85.7	2,824,586.6	1,423.2	1.0	0.6
10/19/2020 14:00	7.7	13.7	6.3	100.2	3,113,158.1	1,636.8	1.0	0.7
10/19/2020 15:00	8.4	13.1	6.4	123.5	3,239,574.8	2,010.8	1.2	1.0
10/19/2020 16:00	8.4	13.0	6.3	137.1	3,222,917.2	2,094.6	1.4	1.0
10/19/2020 17:00	8.2	13.0	6.1	141.8	3,234,123.9	2,125.5	1.4	1.1
10/19/2020 18:00	8.1	13.0	6.0	132.9	3,226,706.2	2,073.5	1.3	1.0
10/19/2020 19:00	8.1	13.0	6.0	140.2	3,255,229.5	2,115.6	1.4	1.1
10/19/2020 20:00	7.4	13.4	5.8	111.8	3,086,471.9	1,758.0	1.2	0.9
10/19/2020 21:00	7.8	13.4	6.1	110.2	3,226,796.3	1,790.8	1.1	0.7
10/19/2020 22:00	8.1	13.1	6.1	125.8	3,285,813.0	2,039.5	1.2	1.0
10/19/2020 23:00	7.7	13.3	6.0	114.1	3,298,772.2	1,927.1	1.1	0.8
Average/Sum#:	7.6	13.5	6.0	111.7	3,175,272.8	1,797.3	1.1	0.8
Minimum:	6.9	13.0	5.7	85.7	2,824,586.6	1,423.2	1.0	0.6
Maximum:	8.4	13.9	6.4	141.8	3,323,401.9	2,125.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/20/2020 00:00	6.9	13.7	5.7	92.5	2,981,041.3	1,523.8	1.0	0.6
10/20/2020 01:00	7.2	13.8	6.0	83.0	2,569,357.7	1,294.6	1.0	0.5
10/20/2020 02:00	7.1	13.8	5.9	83.8	2,739,642.6	1,380.4	1.0	0.6
10/20/2020 03:00	8.0	13.5	6.4	107.9	3,265,255.5	1,788.3	1.0	0.7
10/20/2020 04:00	8.2	13.1	6.2	123.8	3,309,768.3	2,030.2	1.2	1.0
10/20/2020 05:00	8.1	13.1	6.1	125.1	3,350,851.0	2,055.4	1.2	1.0
10/20/2020 06:00	8.2	13.1	6.2	137.0	3,282,868.9	2,013.7	1.4	1.0
10/20/2020 07:00	7.1	13.7	5.8	101.3	3,185,551.1	1,651.6	1.0	0.7
10/20/2020 08:00	7.2	13.8	6.0	84.3	2,629,096.3	1,324.7	1.0	0.5
10/20/2020 09:00	7.1	13.9	6.0	88.0	2,880,157.5	1,451.2	1.0	0.6
10/20/2020 10:00	7.3	13.8	6.1	98.5	3,228,666.1	1,626.8	1.0	0.7
10/20/2020 11:00	7.7	13.6	6.2	104.9	3,188,507.7	1,699.7	1.0	0.7
10/20/2020 12:00	8.5	13.1	6.4	126.8	3,237,096.3	2,032.9	1.3	1.0
10/20/2020 13:00	8.3	13.0	6.2	129.0	3,195,166.2	2,029.9	1.3	1.0
10/20/2020 14:00	7.3	13.7	6.0	103.2	3,250,357.7	1,685.2	1.0	0.7
10/20/2020 15:00	8.2	13.3	6.4	116.0	3,142,568.9	1,812.9	1.2	0.9
10/20/2020 16:00	8.4	12.9	6.2	137.5	3,219,668.9	2,116.0	1.4	1.1
10/20/2020 17:00	8.2	13.0	6.1	133.7	3,211,684.9	2,087.3	1.4	1.0
10/20/2020 18:00	8.1	13.0	6.0	128.3	3,217,675.1	2,044.2	1.3	1.0
10/20/2020 19:00	8.0	13.1	6.1	121.3	3,243,905.5	1,989.8	1.2	1.0
10/20/2020 20:00	7.8	13.2	6.0	121.2	3,156,857.2	1,890.3	1.2	0.9
10/20/2020 21:00	7.8	13.5	6.2	107.7	3,186,687.6	1,722.0	1.1	0.7
10/20/2020 22:00	8.2	13.0	6.1	126.3	3,270,829.9	2,030.2	1.3	1.0
10/20/2020 23:00	8.1	13.0	6.0	134.7	3,256,740.2	2,092.8	1.4	1.0
Average/Sum#:	7.8	13.4	6.1	113.2	3,133,333.4	1,807.2	1.2	0.8
Minimum:	6.9	12.9	5.7	83.0	2,569,357.7	1,294.6	1.0	0.5
Maximum:	8.5	13.9	6.4	137.5	3,350,851.0	2,116.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/21/2020 00:00	7.9	13.1	6.0	129.3	3,246,650.4	2,038.9	1.3	1.0
10/21/2020 01:00	7.3	13.6	5.9	103.5	3,245,728.7	1,682.8	1.0	0.7
10/21/2020 02:00	7.9	13.4	6.2	112.3	3,130,576.2	1,737.4	1.2	0.9
10/21/2020 03:00	8.2	12.9	6.0	135.5	3,242,267.8	2,083.5	1.4	1.0
10/21/2020 04:00	7.9	13.1	6.0	128.1	3,268,943.4	2,052.9	1.3	1.0
10/21/2020 05:00	7.9	13.1	6.0	120.0	3,296,074.1	2,021.8	1.2	1.0
10/21/2020 06:00	8.2	13.0	6.1	139.2	3,291,183.3	2,090.9	1.4	1.0
10/21/2020 07:00	6.9	13.7	5.7	95.3	2,974,158.3	1,542.0	1.0	0.6
10/21/2020 08:00	7.0	13.8	5.8	92.9	2,973,998.5	1,520.2	1.0	0.6
10/21/2020 09:00	7.1	13.8	5.9	84.6	2,685,064.1	1,352.9	1.0	0.5
10/21/2020 10:00	7.1	13.8	5.9	95.2	3,108,394.9	1,566.2	1.0	0.6
10/21/2020 11:00	7.1	13.9	6.0	92.6	3,011,542.8	1,517.4	1.0	0.6
10/21/2020 12:00	7.1	13.8	5.9	96.6	3,161,187.2	1,592.8	1.0	0.6
10/21/2020 13:00	7.6	13.6	6.1	103.0	3,124,351.1	1,665.5	1.0	0.7
10/21/2020 14:00	8.4	13.0	6.3	130.7	3,223,438.3	2,071.4	1.3	1.0
10/21/2020 15:00	8.2	13.1	6.2	125.0	3,222,924.4	2,024.0	1.3	1.0
10/21/2020 16:00	8.2	13.0	6.1	134.2	3,213,377.4	2,088.4	1.4	1.0
10/21/2020 17:00	8.2	13.0	6.1	138.2	3,214,191.2	2,112.4	1.4	1.1
10/21/2020 18:00	8.1	13.0	6.0	136.7	3,212,517.4	2,111.3	1.4	1.1
10/21/2020 19:00	8.0	13.0	6.0	133.6	3,214,101.3	2,065.4	1.4	1.0
10/21/2020 20:00	8.0	13.0	6.0	143.9	3,261,097.4	2,095.6	1.4	1.0
10/21/2020 21:00	8.1	13.1	6.1	139.2	3,264,896.6	2,074.2	1.4	1.0
10/21/2020 22:00	8.3	13.1	6.3	145.3	3,241,285.9	2,059.2	1.5	1.2
10/21/2020 23:00	8.1	13.2	6.2	138.0	3,196,790.8	1,960.9	1.4	1.0
Average/Sum#:	7.8	13.3	6.0	120.5	3,167,697.6	1,880.3	1.2	0.9
Minimum:	6.9	12.9	5.7	84.6	2,685,064.1	1,352.9	1.0	0.5
Maximum:	8.4	13.9	6.3	145.3	3,296,074.1	2,112.4	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/22/2020 00:00	6.8	13.8	5.7	102.4	3,283,292.8	1,678.3	1.0	0.7
10/22/2020 01:00	7.9	13.4	6.2	113.4	3,243,914.1	1,800.3	1.1	0.7
10/22/2020 02:00	8.2	13.2	6.3	128.7	3,292,324.5	2,019.5	1.3	1.0
10/22/2020 03:00	8.0	13.2	6.1	122.9	3,297,177.9	1,998.4	1.2	1.0
10/22/2020 04:00	6.9	13.7	5.7	102.2	3,214,868.4	1,666.8	1.0	0.7
10/22/2020 05:00	7.7	13.5	6.1	106.6	3,268,609.7	1,742.4	1.0	0.7
10/22/2020 06:00	8.6	13.1	6.5	139.5	3,316,652.5	2,131.3	1.4	1.1
10/22/2020 07:00	8.3	13.1	6.3	132.0	3,283,752.3	2,062.2	1.3	1.0
10/22/2020 08:00	6.8	13.8	5.7	90.1	2,886,942.2	1,475.7	1.0	0.6
10/22/2020 09:00	7.0	13.8	5.8	95.5	3,125,661.5	1,574.9	1.0	0.6
10/22/2020 10:00	6.9	13.8	5.7	97.5	3,185,201.7	1,604.9	1.0	0.6
10/22/2020 11:00	8.3	13.5	6.6	111.1	3,274,932.8	1,793.6	1.1	0.7
10/22/2020 12:00	8.9	13.1	6.7	137.2	3,329,612.1	2,091.0	1.3	1.0
10/22/2020 13:00	8.5	13.2	6.5	127.2	3,273,592.3	1,960.2	1.3	1.0
10/22/2020 14:00	7.2	13.7	5.9	98.1	3,079,835.4	1,574.3	1.0	0.6
10/22/2020 15:00	8.0	13.6	6.5	104.1	3,175,733.2	1,669.7	1.0	0.7
10/22/2020 16:00	8.9	13.1	6.7	137.1	3,352,701.2	2,105.5	1.3	1.1
10/22/2020 17:00	8.6	13.1	6.5	138.7	3,340,293.7	2,122.1	1.3	1.1
10/22/2020 18:00	8.3	13.2	6.4	123.8	3,342,564.5	2,001.5	1.2	1.0
10/22/2020 19:00	8.5	13.1	6.4	130.6	3,368,294.9	2,066.1	1.3	1.0
10/22/2020 20:00	8.3	13.2	6.4	127.5	3,362,514.3	2,038.0	1.2	1.0
10/22/2020 21:00	8.3	13.2	6.4	125.9	3,362,019.4	2,037.7	1.2	1.0
10/22/2020 22:00	8.5	13.3	6.6	133.4	3,331,375.3	1,994.8	1.3	1.0
10/22/2020 23:00	8.4	13.3	6.5	137.4	3,286,280.4	1,943.8	1.4	1.0
Average/Sum#:	8.0	13.4	6.3	119.3	3,261,589.5	1,881.4	1.2	0.9
Minimum:	6.8	13.1	5.7	90.1	2,886,942.2	1,475.7	1.0	0.6
Maximum:	8.9	13.8	6.7	139.5	3,368,294.9	2,131.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/23/2020 00:00	6.4	13.8	5.3	97.1	3,224,498.3	1,624.7	1.0	0.6
10/23/2020 01:00	8.1	13.5	6.5	116.2	3,281,871.2	1,797.4	1.1	0.7
10/23/2020 02:00	8.4	13.2	6.4	135.1	3,347,517.6	2,077.8	1.3	1.0
10/23/2020 03:00	8.0	13.2	6.1	121.0	3,356,442.3	1,985.3	1.2	1.0
10/23/2020 04:00	6.8	13.8	5.7	101.2	3,283,292.8	1,678.3	1.0	0.7
10/23/2020 05:00	7.9	13.5	6.3	110.5	3,395,984.9	1,810.3	1.0	0.7
10/23/2020 06:00	8.6	13.1	6.5	134.4	3,365,478.5	2,138.1	1.3	1.1
10/23/2020 07:00	8.4	13.1	6.4	129.3	3,379,094.9	2,097.4	1.2	1.0
10/23/2020 08:00	8.1	13.2	6.2	118.3	3,400,109.6	1,986.3	1.1	0.8
10/23/2020 09:00	7.2	13.6	5.8	104.6	3,245,726.0	1,706.5	1.0	0.7
10/23/2020 10:00	7.3	13.7	6.0	103.1	3,280,749.6	1,677.0	1.0	0.7
10/23/2020 11:00	7.7	13.6	6.2	105.6	3,326,544.0	1,724.7	1.0	0.7
10/23/2020 12:00	8.6	13.2	6.6	125.4	3,348,079.6	2,053.7	1.2	1.0
10/23/2020 13:00	8.1	13.3	6.3	117.1	3,331,124.8	1,946.0	1.1	0.8
10/23/2020 14:00	7.0	13.8	5.8	97.2	3,121,505.1	1,595.6	1.0	0.6
10/23/2020 15:00	7.7	13.6	6.2	106.0	3,296,699.0	1,733.3	1.0	0.7
10/23/2020 16:00	8.4	13.2	6.4	123.3	3,357,564.6	2,035.0	1.2	1.0
10/23/2020 17:00	8.1	13.1	6.1	129.6	3,327,701.3	2,089.8	1.3	1.0
10/23/2020 18:00	7.8	13.3	6.1	112.2	3,318,167.3	1,914.2	1.1	0.8
10/23/2020 19:00	7.1	13.7	5.8	102.8	3,254,022.4	1,687.1	1.0	0.7
10/23/2020 20:00	8.0	13.5	6.4	111.8	3,288,060.0	1,824.8	1.1	0.7
10/23/2020 21:00	8.3	13.2	6.4	123.9	3,377,363.5	2,047.0	1.2	1.0
10/23/2020 22:00	8.1	13.2	6.2	119.7	3,359,264.8	2,011.5	1.1	0.8
10/23/2020 23:00	8.0	13.1	6.1	130.1	3,400,683.5	2,110.8	1.2	1.1
Average/Sum#:	7.8	13.4	6.2	115.6	3,319,481.1	1,889.7	1.1	0.8
Minimum:	6.4	13.1	5.3	97.1	3,121,505.1	1,595.6	1.0	0.6
Maximum:	8.6	13.8	6.6	135.1	3,400,683.5	2,138.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/24/2020 00:00	6.8	13.6	5.5	105.3	3,208,204.9	1,710.2	1.1	0.7
10/24/2020 01:00	7.0	13.7	5.7	101.7	3,296,791.4	1,685.2	1.0	0.7
10/24/2020 02:00	7.7	13.5	6.1	110.2	3,315,650.3	1,815.9	1.1	0.7
10/24/2020 03:00	8.2	13.2	6.3	128.0	3,358,956.4	2,084.9	1.2	1.0
10/24/2020 04:00	7.8	13.3	6.1	116.7	3,327,016.5	1,943.6	1.1	0.8
10/24/2020 05:00	6.8	13.7	5.6	100.1	3,221,812.0	1,670.4	1.0	0.7
10/24/2020 06:00	7.2	13.7	5.9	100.3	3,212,746.8	1,665.7	1.0	0.7
10/24/2020 07:00	7.2	13.7	5.9	99.2	3,125,180.7	1,620.3	1.0	0.6
10/24/2020 08:00	7.3	13.7	6.0	96.6	3,063,402.3	1,565.9	1.0	0.6
10/24/2020 09:00	7.3	13.7	6.0	98.8	3,151,828.0	1,611.1	1.0	0.6
10/24/2020 10:00	7.4	13.7	6.1	102.0	3,266,077.2	1,669.5	1.0	0.7
10/24/2020 11:00	7.4	13.8	6.1	99.9	3,184,498.6	1,627.8	1.0	0.7
10/24/2020 12:00	7.3	13.8	6.1	88.5	2,788,148.0	1,425.2	1.0	0.6
10/24/2020 13:00	7.4	13.8	6.1	87.4	2,779,149.0	1,420.6	1.0	0.6
10/24/2020 14:00	7.7	13.8	6.4	99.8	3,170,217.4	1,620.5	1.0	0.6
10/24/2020 15:00	7.7	13.7	6.3	103.7	3,296,987.0	1,685.3	1.0	0.7
10/24/2020 16:00	8.8	13.4	6.9	113.0	3,233,823.6	1,794.7	1.1	0.7
10/24/2020 17:00	8.7	13.0	6.5	135.8	3,291,131.4	2,114.9	1.3	1.1
10/24/2020 18:00	8.1	13.3	6.3	114.6	3,302,366.9	1,929.2	1.1	0.8
10/24/2020 19:00	7.2	13.7	5.9	102.7	3,250,743.5	1,685.4	1.0	0.7
10/24/2020 20:00	7.3	13.7	6.0	102.3	3,235,120.4	1,677.3	1.0	0.7
10/24/2020 21:00	7.8	13.5	6.2	110.5	3,252,382.9	1,805.0	1.1	0.7
10/24/2020 22:00	8.3	13.2	6.4	119.5	3,339,725.5	1,999.8	1.1	0.8
10/24/2020 23:00	8.0	13.2	6.1	118.0	3,276,598.3	1,962.0	1.2	1.0
Average/Sum#:	7.6	13.6	6.1	106.4	3,206,190.0	1,741.3	1.1	0.7
Minimum:	6.8	13.0	5.5	87.4	2,779,149.0	1,420.6	1.0	0.6
Maximum:	8.8	13.8	6.9	135.8	3,358,956.4	2,114.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/25/2020 00:00	6.9	13.7	5.7	101.2	3,225,862.4	1,672.5	1.0	0.7
10/25/2020 01:00	7.0	13.7	5.7	100.8	3,208,889.2	1,663.7	1.0	0.7
10/25/2020 02:00	7.0	13.7	5.7	100.1	3,178,800.5	1,648.1	1.0	0.7
10/25/2020 03:00	7.0	13.7	5.7	100.1	3,175,135.8	1,646.2	1.0	0.7
10/25/2020 04:00	7.0	13.7	5.7	99.8	3,166,070.6	1,641.5	1.0	0.7
10/25/2020 05:00	7.0	13.7	5.7	98.6	3,118,622.9	1,616.9	1.0	0.6
10/25/2020 06:00	7.1	13.7	5.8	97.7	3,054,395.0	1,583.6	1.0	0.6
10/25/2020 07:00	7.2	13.7	5.9	98.6	3,100,492.5	1,607.5	1.0	0.6
10/25/2020 08:00	7.1	13.8	5.9	98.4	3,145,959.1	1,608.1	1.0	0.6
10/25/2020 09:00	7.0	13.8	5.8	94.8	3,046,186.7	1,557.1	1.0	0.6
10/25/2020 10:00	7.1	13.8	5.9	86.5	2,805,930.7	1,413.8	1.0	0.6
10/25/2020 11:00	7.2	13.8	6.0	84.0	2,665,415.9	1,343.0	1.0	0.5
10/25/2020 12:00	7.1	13.8	5.9	93.7	3,063,144.3	1,543.4	1.0	0.6
10/25/2020 13:00	7.1	13.8	5.9	97.2	3,159,202.5	1,591.8	1.0	0.6
10/25/2020 14:00	7.0	13.9	5.9	99.8	3,276,099.8	1,650.7	1.0	0.7
10/25/2020 15:00	7.0	13.8	5.8	96.7	3,179,843.1	1,602.2	1.0	0.6
10/25/2020 16:00	8.3	13.5	6.6	114.7	3,380,257.5	1,826.6	1.1	0.7
10/25/2020 17:00	8.8	13.2	6.7	126.7	3,432,579.1	2,055.4	1.2	1.0
10/25/2020 18:00	8.4	13.2	6.4	127.9	3,363,105.9	2,013.8	1.2	1.0
10/25/2020 19:00	7.1	13.7	5.8	101.3	3,198,473.9	1,658.3	1.0	0.7
10/25/2020 20:00	8.3	13.5	6.6	119.4	3,281,393.1	1,821.1	1.2	0.9
10/25/2020 21:00	8.8	13.1	6.7	154.1	3,389,325.4	2,128.5	1.5	1.3
10/25/2020 22:00	8.3	13.1	6.3	153.7	3,371,774.7	2,142.1	1.5	1.3
10/25/2020 23:00	8.1	13.1	6.1	155.7	3,380,610.8	2,172.4	1.5	1.3
Average/Sum#:	7.5	13.6	6.0	108.4	3,181,982.1	1,717.0	1.1	0.8
Minimum:	6.9	13.1	5.7	84.0	2,665,415.9	1,343.0	1.0	0.5
Maximum:	8.8	13.9	6.7	155.7	3,432,579.1	2,172.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/26/2020 00:00	7.7	13.2	5.9	133.3	3,401,850.6	2,037.0	1.3	1.0
10/26/2020 01:00	7.7	13.3	6.0	122.8	3,436,561.8	1,982.5	1.2	1.0
10/26/2020 02:00	7.7	13.3	6.0	131.6	3,394,669.4	2,032.7	1.3	1.0
10/26/2020 03:00	6.3	13.8	5.2	98.7	3,228,948.4	1,674.1	1.0	0.7
10/26/2020 04:00	7.8	13.5	6.2	113.1	3,389,964.4	1,856.6	1.1	0.7
10/26/2020 05:00	8.3	13.2	6.4	144.4	3,433,710.8	2,131.3	1.4	1.1
10/26/2020 06:00	8.2	13.2	6.3	144.4	3,371,361.7	2,092.6	1.4	1.0
10/26/2020 07:00	7.5	13.7	6.1	109.0	3,439,955.5	1,783.5	1.0	0.7
10/26/2020 08:00	6.5	13.8	5.4	102.6	3,412,214.3	1,744.2	1.0	0.7
10/26/2020 09:00	6.7	13.8	5.6	102.8	3,392,846.7	1,734.3	1.0	0.7
10/26/2020 10:00	6.7	13.8	5.6	100.1	3,332,861.4	1,679.3	1.0	0.7
10/26/2020 11:00	6.9	13.9	5.8	87.1	2,736,467.2	1,378.8	1.0	0.6
10/26/2020 12:00	7.0	13.9	5.9	92.4	3,024,641.7	1,524.0	1.0	0.6
10/26/2020 13:00	6.9	13.9	5.8	91.5	2,982,963.5	1,503.0	1.0	0.6
10/26/2020 14:00	7.0	13.9	5.9	101.0	3,358,860.6	1,692.4	0.9	0.5
10/26/2020 15:00	6.9	13.9	5.8	99.0	3,255,459.2	1,640.3	1.0	0.7
10/26/2020 16:00	8.5	13.5	6.8	114.2	3,368,601.4	1,844.9	1.1	0.7
10/26/2020 17:00	8.8	13.1	6.7	140.1	3,409,866.7	2,141.4	1.3	1.1
10/26/2020 18:00	8.6	13.0	6.4	148.0	3,392,282.1	2,179.9	1.4	1.1
10/26/2020 19:00	8.4	13.2	6.4	131.9	3,388,510.2	2,078.5	1.3	1.0
10/26/2020 20:00	8.6	13.1	6.5	138.7	3,411,638.9	2,117.6	1.3	1.1
10/26/2020 21:00	8.4	13.1	6.4	132.9	3,404,160.8	2,088.1	1.3	1.0
10/26/2020 22:00	8.4	13.2	6.4	130.4	3,424,220.9	2,075.4	1.2	1.0
10/26/2020 23:00	8.1	13.2	6.2	128.1	3,395,677.5	2,058.1	1.2	1.0
Average/Sum#:	7.7	13.5	6.1	118.3	3,324,512.3	1,877.9	1.2	0.8
Minimum:	6.3	13.0	5.2	87.1	2,736,467.2	1,378.8	0.9	0.5
Maximum:	8.8	13.9	6.8	148.0	3,439,955.5	2,179.9	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/27/2020 00:00	6.5	13.8	5.4	99.9	3,301,486.6	1,687.6	1.0	0.7
10/27/2020 01:00	7.7	13.6	6.2	114.0	3,300,127.7	1,783.3	1.1	0.7
10/27/2020 02:00	8.8	13.2	6.7	151.8	3,344,003.9	2,051.2	1.5	1.2
10/27/2020 03:00	8.2	13.3	6.4	138.0	3,325,530.2	1,991.3	1.3	1.0
10/27/2020 04:00	6.2	13.8	5.2	97.4	3,265,977.9	1,645.6	1.0	0.7
10/27/2020 05:00	7.8	13.5	6.2	112.7	3,244,410.2	1,729.5	1.1	0.7
10/27/2020 06:00	8.8	13.1	6.7	156.1	3,334,237.1	2,142.6	1.5	1.3
10/27/2020 07:00	8.6	13.0	6.4	141.0	3,395,542.9	2,157.2	1.4	1.1
10/27/2020 08:00	8.3	13.1	6.3	133.6	3,394,078.1	2,106.7	1.3	1.1
10/27/2020 09:00	8.3	13.1	6.3	136.3	3,367,191.6	2,114.6	1.3	1.1
10/27/2020 10:00	8.4	13.1	6.4	138.7	3,329,432.7	2,115.2	1.4	1.1
10/27/2020 11:00	8.7	13.0	6.5	146.5	3,332,058.5	2,141.2	1.4	1.1
10/27/2020 12:00	8.7	13.0	6.5	149.9	3,305,852.0	2,148.5	1.5	1.3
10/27/2020 13:00	8.7	13.0	6.5	150.4	3,301,236.0	2,145.5	1.5	1.3
10/27/2020 14:00	8.7	13.0	6.5	146.3	3,278,771.3	2,130.9	1.5	1.3
10/27/2020 15:00	8.4	13.2	6.4	125.4	3,307,827.9	1,980.7	1.2	1.0
10/27/2020 16:00	8.7	13.0	6.5	141.9	3,331,164.2	2,116.3	1.4	1.1
10/27/2020 17:00	8.5	13.0	6.3	145.6	3,307,083.0	2,149.3	1.4	1.1
10/27/2020 18:00	8.4	13.0	6.3	146.2	3,308,006.2	2,149.9	1.4	1.1
10/27/2020 19:00	8.4	13.0	6.3	144.1	3,304,005.6	2,147.3	1.4	1.1
10/27/2020 20:00	8.3	13.0	6.2	139.9	3,319,764.8	2,133.3	1.4	1.1
10/27/2020 21:00	8.1	13.1	6.1	126.1	3,334,711.4	2,045.5	1.2	1.0
10/27/2020 22:00	8.0	13.2	6.1	124.2	3,373,733.7	2,044.8	1.2	1.0
10/27/2020 23:00	8.0	13.1	6.1	125.8	3,348,242.6	2,053.8	1.2	1.0
Average/Sum#:	8.2	13.2	6.3	134.7	3,323,103.2	2,038.0	1.3	1.1
Minimum:	6.2	13.0	5.2	97.4	3,244,410.2	1,645.6	1.0	0.7
Maximum:	8.8	13.8	6.7	156.1	3,395,542.9	2,157.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/28/2020 00:00	6.7	13.7	5.5	100.6	3,230,491.4	1,674.9	1.0	0.7
10/28/2020 01:00	6.9	13.7	5.7	100.2	3,202,910.0	1,660.6	1.0	0.7
10/28/2020 02:00	6.9	13.7	5.7	99.4	3,173,399.9	1,645.3	1.0	0.7
10/28/2020 03:00	7.0	13.7	5.7	99.5	3,209,343.9	1,640.5	1.0	0.7
10/28/2020 04:00	7.7	13.5	6.1	109.7	3,364,897.8	1,818.3	1.0	0.7
10/28/2020 05:00	8.3	13.2	6.4	135.2	3,401,328.0	2,111.2	1.3	1.1
10/28/2020 06:00	8.3	13.1	6.3	152.1	3,323,032.8	2,135.4	1.5	1.3
10/28/2020 07:00	6.7	13.8	5.6	83.9	2,495,091.2	1,275.4	1.1	0.5
10/28/2020 08:00	7.0	13.8	5.8	82.5	2,504,872.8	1,280.4	1.0	0.5
10/28/2020 09:00	6.7	13.8	5.6	88.9	2,900,440.8	1,482.6	1.0	0.6
10/28/2020 10:00	7.0	13.8	5.8	91.7	2,984,171.4	1,525.4	1.0	0.6
10/28/2020 11:00	8.4	13.5	6.7	111.7	3,422,229.6	1,799.3	1.0	0.7
10/28/2020 12:00	8.3	13.5	6.6	111.4	3,396,933.3	1,786.0	1.0	0.7
10/28/2020 13:00	8.3	13.5	6.6	111.2	3,389,705.7	1,782.2	1.0	0.7
10/28/2020 14:00	8.3	13.5	6.6	110.9	3,379,244.9	1,776.7	1.0	0.7
10/28/2020 15:00	8.4	13.5	6.7	111.0	3,373,919.3	1,773.9	1.0	0.7
10/28/2020 16:00	7.4	13.7	6.1	102.2	3,182,272.2	1,649.9	1.0	0.7
10/28/2020 17:00	7.5	13.7	6.1	104.1	3,274,660.2	1,697.8	1.0	0.7
10/28/2020 18:00	8.4	13.3	6.5	118.3	3,365,909.9	1,990.9	1.1	0.8
10/28/2020 19:00	8.1	13.2	6.2	122.9	3,371,093.9	2,043.2	1.2	1.0
10/28/2020 20:00	8.0	13.2	6.1	124.2	3,363,078.0	2,062.9	1.2	1.0
10/28/2020 21:00	7.9	13.2	6.1	123.8	3,361,610.8	2,062.0	1.2	1.0
10/28/2020 22:00	7.8	13.2	6.0	120.9	3,395,671.5	2,033.3	1.2	1.0
10/28/2020 23:00	7.6	13.4	6.0	116.2	3,339,639.8	1,902.2	1.1	0.8
Average/Sum#:	7.7	13.5	6.1	109.7	3,225,247.9	1,775.4	1.1	0.8
Minimum:	6.7	13.1	5.5	82.5	2,495,091.2	1,275.4	1.0	0.5
Maximum:	8.4	13.8	6.7	152.1	3,422,229.6	2,135.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/29/2020 00:00	6.5	13.8	5.4	99.4	3,290,726.8	1,682.1	1.0	0.7
10/29/2020 01:00	6.8	13.8	5.7	99.9	3,273,511.2	1,673.3	1.0	0.7
10/29/2020 02:00	6.7	13.8	5.6	91.9	2,996,300.6	1,531.6	1.0	0.6
10/29/2020 03:00	6.9	13.8	5.7	100.4	3,286,618.5	1,680.0	1.0	0.7
10/29/2020 04:00	7.7	13.6	6.2	107.9	3,300,867.9	1,783.7	1.0	0.7
10/29/2020 05:00	8.0	13.3	6.2	119.4	3,411,703.7	2,042.9	1.1	0.8
10/29/2020 06:00	8.0	13.2	6.1	133.7	3,390,892.8	2,055.2	1.3	1.0
10/29/2020 07:00	7.1	13.6	5.7	107.2	3,439,762.6	1,783.4	1.0	0.7
10/29/2020 08:00	7.0	13.8	5.8	83.5	2,564,736.2	1,311.0	1.0	0.5
10/29/2020 09:00	7.3	13.8	6.1	83.3	2,508,825.2	1,264.1	1.1	0.5
10/29/2020 10:00	7.4	13.9	6.2	83.7	2,535,816.7	1,277.7	1.0	0.5
10/29/2020 11:00	7.4	13.9	6.2	83.7	2,506,245.1	1,262.8	1.1	0.5
10/29/2020 12:00	7.4	13.9	6.2	83.4	2,505,649.7	1,262.5	1.1	0.5
10/29/2020 13:00	7.4	13.9	6.2	83.5	2,506,642.0	1,263.0	1.1	0.5
10/29/2020 14:00	7.4	13.9	6.2	83.4	2,506,642.0	1,263.0	1.1	0.5
10/29/2020 15:00	7.4	13.9	6.2	87.0	2,698,163.0	1,359.5	1.0	0.5
10/29/2020 16:00	7.6	13.8	6.3	96.0	3,004,712.7	1,535.9	1.0	0.6
10/29/2020 17:00	7.5	13.7	6.1	106.1	3,365,890.8	1,745.1	1.0	0.7
10/29/2020 18:00	8.6	13.2	6.6	120.3	3,393,636.5	2,007.3	1.1	0.8
10/29/2020 19:00	8.5	13.2	6.5	125.2	3,343,677.9	2,051.0	1.2	1.0
10/29/2020 20:00	8.4	13.2	6.4	128.2	3,378,402.6	2,072.3	1.2	1.0
10/29/2020 21:00	8.2	13.2	6.3	126.6	3,364,871.3	2,064.0	1.2	1.0
10/29/2020 22:00	8.2	13.2	6.3	125.7	3,356,883.0	2,059.1	1.2	1.0
10/29/2020 23:00	7.9	13.3	6.1	114.7	3,371,417.5	1,920.3	1.1	0.8
Average/Sum#:	7.6	13.6	6.1	103.1	3,054,274.8	1,664.6	1.1	0.7
Minimum:	6.5	13.2	5.4	83.3	2,505,649.7	1,262.5	1.0	0.5
Maximum:	8.6	13.9	6.6	133.7	3,439,762.6	2,072.3	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/30/2020 00:00	6.7	13.7	5.5	97.0	3,139,698.8	1,604.9	1.0	0.6
10/30/2020 01:00	7.4	13.6	6.0	101.5	3,192,470.6	1,678.5	1.0	0.7
10/30/2020 02:00	8.1	13.4	6.4	118.9	3,342,088.9	1,928.0	1.1	0.8
10/30/2020 03:00	7.8	13.4	6.1	120.6	3,334,288.4	1,923.5	1.2	1.0
10/30/2020 04:00	6.5	13.8	5.4	99.3	3,302,073.5	1,687.9	1.0	0.7
10/30/2020 05:00	7.4	13.5	5.9	107.1	3,376,287.7	1,799.8	1.0	0.7
10/30/2020 06:00	8.3	13.2	6.4	136.2	3,361,121.7	2,061.7	1.3	1.0
10/30/2020 07:00	8.0	13.2	6.1	121.0	3,401,582.5	2,012.0	1.1	0.8
10/30/2020 08:00	7.8	13.3	6.1	121.9	3,386,366.7	2,003.0	1.2	1.0
10/30/2020 09:00	7.9	13.3	6.1	126.2	3,325,672.5	1,967.1	1.2	1.0
10/30/2020 10:00	8.1	13.3	6.3	137.2	3,340,393.5	2,000.2	1.3	1.0
10/30/2020 11:00	8.0	13.3	6.2	131.8	3,246,871.8	1,944.2	1.3	1.0
10/30/2020 12:00	6.5	13.8	5.4	97.6	3,259,230.0	1,642.2	1.0	0.7
10/30/2020 13:00	7.8	13.5	6.2	108.5	3,258,134.5	1,784.4	1.1	0.7
10/30/2020 14:00	8.3	13.2	6.4	121.8	3,321,431.6	2,013.1	1.2	1.0
10/30/2020 15:00	8.4	13.1	6.4	129.7	3,289,166.3	2,065.6	1.3	1.0
10/30/2020 16:00	8.3	13.1	6.3	126.1	3,321,995.3	2,037.7	1.2	1.0
10/30/2020 17:00	8.3	13.1	6.3	134.4	3,314,007.0	2,105.4	1.3	1.1
10/30/2020 18:00	8.2	13.1	6.2	133.7	3,316,368.1	2,106.9	1.3	1.1
10/30/2020 19:00	8.2	13.0	6.1	136.5	3,321,321.0	2,134.3	1.3	1.1
10/30/2020 20:00	7.3	13.4	5.7	112.0	3,198,939.8	1,798.7	1.1	0.7
10/30/2020 21:00	7.7	13.5	6.1	109.3	3,325,692.8	1,821.4	1.0	0.7
10/30/2020 22:00	8.2	13.1	6.2	127.3	3,352,189.8	2,080.7	1.2	1.0
10/30/2020 23:00	7.6	13.3	5.9	112.0	3,345,035.7	1,929.7	1.1	0.8
Average/Sum#:	7.8	13.3	6.1	119.5	3,307,184.5	1,922.1	1.2	0.9
Minimum:	6.5	13.0	5.4	97.0	3,139,698.8	1,604.9	1.0	0.6
Maximum:	8.4	13.8	6.4	137.2	3,401,582.5	2,134.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/31/2020 00:00	6.6	13.8	5.5	93.5	3,045,599.8	1,556.8	1.0	0.6
10/31/2020 01:00	6.9	13.8	5.7	99.4	3,237,710.5	1,655.0	1.0	0.7
10/31/2020 02:00	7.4	13.7	6.1	100.6	3,132,177.9	1,646.8	1.0	0.7
10/31/2020 03:00	8.5	13.2	6.5	130.1	3,342,385.4	2,025.8	1.3	1.0
10/31/2020 04:00	7.8	13.4	6.1	119.2	3,307,419.9	1,908.0	1.2	1.0
10/31/2020 05:00	6.6	13.8	5.5	99.5	3,302,856.0	1,688.3	1.0	0.7
10/31/2020 06:00	7.0	13.8	5.8	100.1	3,299,334.6	1,686.5	1.0	0.7
10/31/2020 07:00	7.1	13.8	5.9	99.7	3,212,082.7	1,641.9	1.0	0.7
10/31/2020 08:00	6.9	13.8	5.7	92.6	2,973,216.0	1,519.8	1.0	0.6
10/31/2020 09:00	6.9	13.8	5.7	91.0	2,923,916.7	1,494.6	1.0	0.6
10/31/2020 10:00	7.1	13.8	5.9	98.3	3,190,367.6	1,630.8	1.0	0.7
10/31/2020 11:00	7.1	13.8	5.9	94.1	3,067,312.2	1,545.5	1.0	0.6
10/31/2020 12:00	7.1	13.8	5.9	94.3	3,064,930.5	1,544.3	1.0	0.6
10/31/2020 13:00	7.3	13.9	6.2	94.6	3,086,761.9	1,555.3	1.0	0.6
10/31/2020 14:00	7.6	13.8	6.3	98.1	3,108,006.5	1,588.7	1.0	0.6
10/31/2020 15:00	8.1	13.7	6.6	104.3	3,262,751.4	1,667.8	1.0	0.7
10/31/2020 16:00	8.0	13.5	6.4	109.4	3,258,864.9	1,784.8	1.1	0.7
10/31/2020 17:00	8.2	13.2	6.3	117.9	3,347,143.7	1,979.8	1.1	0.8
10/31/2020 18:00	8.1	13.2	6.2	120.1	3,347,908.6	2,004.7	1.2	1.0
10/31/2020 19:00	7.0	13.7	5.7	102.0	3,249,007.6	1,684.5	1.0	0.7
10/31/2020 20:00	7.8	13.5	6.2	109.6	3,305,973.1	1,810.6	1.1	0.7
10/31/2020 21:00	8.2	13.2	6.3	122.3	3,361,854.4	2,037.6	1.2	1.0
10/31/2020 22:00	7.9	13.2	6.1	121.1	3,402,685.6	2,037.5	1.1	0.8
10/31/2020 23:00	7.9	13.2	6.1	122.1	3,375,218.6	2,045.7	1.2	1.0
Average/Sum#:	7.5	13.6	6.0	105.6	3,216,895.3	1,739.2	1.1	0.7
Minimum:	6.6	13.2	5.5	91.0	2,923,916.7	1,494.6	1.0	0.6
Maximum:	8.5	13.9	6.6	130.1	3,402,685.6	2,045.7	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/01/2020 00:00	7.9	13.2	6.1	123.6	3,406,992.6	2,015.2	1.2	1.0
11/01/2020 01:00	7.8	13.3	6.1	126.0	3,352,046.6	1,982.7	1.2	1.0
11/01/2020 02:00	6.4	13.8	5.3	98.4	3,218,340.2	1,668.6	1.0	0.7
11/01/2020 03:00	6.7	13.8	5.6	99.4	3,284,857.8	1,679.1	1.0	0.7
11/01/2020 04:00	7.6	13.5	6.1	108.4	3,309,807.4	1,812.7	1.0	0.7
11/01/2020 05:00	8.1	13.2	6.2	126.7	3,395,003.5	2,032.9	1.2	1.0
11/01/2020 06:00	8.0	13.2	6.1	126.1	3,342,731.5	2,001.6	1.2	1.0
11/01/2020 07:00	6.7	13.8	5.6	92.3	3,005,299.6	1,536.2	1.0	0.6
11/01/2020 08:00	6.9	13.8	5.7	100.6	3,291,313.7	1,682.4	1.0	0.7
11/01/2020 09:00	6.8	13.8	5.7	89.9	2,917,852.1	1,491.5	1.0	0.6
11/01/2020 10:00	7.0	13.8	5.8	93.8	3,060,076.6	1,564.2	1.0	0.6
11/01/2020 11:00	6.9	13.8	5.7	90.3	2,941,880.8	1,482.3	1.0	0.6
11/01/2020 12:00	7.0	13.8	5.8	94.1	3,111,768.8	1,567.9	1.0	0.6
11/01/2020 13:00	7.7	13.8	6.4	101.5	3,240,840.6	1,656.6	1.0	0.7
11/01/2020 14:00	7.7	13.8	6.4	102.2	3,253,556.7	1,663.1	1.0	0.7
11/01/2020 15:00	8.0	13.7	6.6	102.4	3,133,699.5	1,647.6	1.0	0.7
11/01/2020 16:00	8.4	13.2	6.4	121.4	3,320,936.6	2,012.8	1.2	1.0
11/01/2020 17:00	8.3	13.1	6.3	131.5	3,344,102.5	2,100.1	1.3	1.1
11/01/2020 18:00	8.2	13.0	6.1	136.6	3,316,341.3	2,131.1	1.3	1.1
11/01/2020 19:00	8.1	13.1	6.1	131.5	3,352,064.3	2,105.1	1.3	1.1
11/01/2020 20:00	8.0	13.1	6.1	130.0	3,335,663.0	2,094.8	1.3	1.0
11/01/2020 21:00	8.1	13.0	6.0	137.5	3,334,081.5	2,142.5	1.3	1.1
11/01/2020 22:00	7.9	13.1	6.0	125.9	3,365,197.4	2,064.2	1.2	1.0
11/01/2020 23:00	7.8	13.1	5.9	125.2	3,386,390.9	2,077.2	1.2	1.0
Average/Sum#:	7.6	13.5	6.0	113.1	3,250,868.6	1,842.2	1.1	0.8
Minimum:	6.4	13.0	5.3	89.9	2,917,852.1	1,482.3	1.0	0.6
Maximum:	8.4	13.8	6.6	137.5	3,406,992.6	2,142.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/02/2020 00:00	8.0	13.1	6.1	135.7	3,366,528.5	2,089.6	1.3	1.0
11/02/2020 01:00	8.0	13.2	6.1	132.8	3,304,602.5	2,002.9	1.3	1.0
11/02/2020 02:00	6.5	13.8	5.4	101.3	3,209,539.5	1,640.6	1.0	0.7
11/02/2020 03:00	7.7	13.5	6.1	109.8	3,274,385.0	1,793.3	1.1	0.7
11/02/2020 04:00	8.1	13.1	6.1	136.6	3,352,028.7	2,080.6	1.3	1.0
11/02/2020 05:00	8.0	13.1	6.1	138.1	3,347,764.9	2,102.4	1.3	1.1
11/02/2020 06:00	8.1	13.2	6.2	139.3	3,342,536.7	2,050.3	1.4	1.0
11/02/2020 07:00	6.6	13.8	5.5	96.7	3,171,782.5	1,621.3	1.0	0.6
11/02/2020 08:00	6.8	13.8	5.7	98.8	3,240,645.0	1,656.5	1.0	0.7
11/02/2020 09:00	6.9	13.8	5.7	100.5	3,280,553.9	1,676.9	1.0	0.7
11/02/2020 10:00	6.9	13.8	5.7	98.8	3,261,413.2	1,643.3	1.0	0.7
11/02/2020 11:00	6.9	13.8	5.7	99.1	3,278,679.8	1,652.0	1.0	0.7
11/02/2020 12:00	8.1	13.7	6.6	104.1	3,232,805.9	1,676.1	1.0	0.7
11/02/2020 13:00	8.2	13.7	6.7	104.6	3,264,120.8	1,668.5	1.0	0.7
11/02/2020 14:00	8.1	13.6	6.5	105.3	3,227,467.0	1,696.9	1.0	0.7
11/02/2020 15:00	8.3	13.1	6.3	123.0	3,291,672.3	2,019.1	1.2	1.0
11/02/2020 16:00	8.3	13.0	6.2	138.2	3,282,156.4	2,133.1	1.4	1.1
11/02/2020 17:00	8.1	13.0	6.0	134.9	3,289,108.4	2,113.6	1.3	1.1
11/02/2020 18:00	8.1	13.0	6.0	136.7	3,275,232.3	2,128.6	1.4	1.1
11/02/2020 19:00	8.1	13.0	6.0	138.9	3,291,234.6	2,139.0	1.4	1.1
11/02/2020 20:00	8.0	13.0	6.0	137.2	3,322,254.7	2,134.9	1.4	1.1
11/02/2020 21:00	7.9	13.1	6.0	130.9	3,335,503.8	2,094.7	1.3	1.0
11/02/2020 22:00	7.9	13.1	6.0	129.5	3,318,624.8	2,084.1	1.3	1.0
11/02/2020 23:00	7.7	13.2	5.9	123.4	3,358,389.6	2,035.5	1.2	1.0
Average/Sum#:	7.7	13.4	6.0	120.6	3,288,293.0	1,913.9	1.2	0.9
Minimum:	6.5	13.0	5.4	96.7	3,171,782.5	1,621.3	1.0	0.6
Maximum:	8.3	13.8	6.7	139.3	3,366,528.5	2,139.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/03/2020 00:00	8.1	13.1	6.1	135.6	3,310,301.5	2,054.7	1.3	1.0
11/03/2020 01:00	7.9	13.3	6.1	125.8	3,288,478.2	1,945.1	1.2	1.0
11/03/2020 02:00	6.5	13.8	5.4	99.8	3,282,510.2	1,677.9	1.0	0.7
11/03/2020 03:00	7.4	13.5	5.9	109.2	3,317,658.8	1,817.0	1.1	0.7
11/03/2020 04:00	8.3	13.1	6.3	137.7	3,324,994.3	2,088.1	1.3	1.0
11/03/2020 05:00	8.1	13.1	6.1	139.9	3,303,775.7	2,098.9	1.4	1.0
11/03/2020 06:00	8.1	13.1	6.1	148.4	3,328,016.1	2,114.3	1.5	1.3
11/03/2020 07:00	8.0	13.2	6.1	127.6	3,314,337.0	2,008.8	1.2	1.0
11/03/2020 08:00	6.5	13.8	5.4	98.0	3,230,472.1	1,651.3	1.0	0.7
11/03/2020 09:00	6.8	13.8	5.7	100.1	3,258,838.8	1,665.8	1.0	0.7
11/03/2020 10:00	6.9	13.8	5.7	100.5	3,269,989.8	1,671.5	1.0	0.7
11/03/2020 11:00	6.8	13.8	5.7	92.3	3,021,664.7	1,522.5	1.0	0.6
11/03/2020 12:00	6.9	13.8	5.7	92.3	3,020,870.8	1,522.1	1.0	0.6
11/03/2020 13:00	7.3	13.8	6.1	97.1	3,113,875.4	1,591.7	1.0	0.6
11/03/2020 14:00	7.3	13.8	6.1	101.5	3,248,079.0	1,660.3	1.0	0.7
11/03/2020 15:00	8.1	13.5	6.5	111.3	3,260,690.8	1,785.8	1.1	0.7
11/03/2020 16:00	8.3	13.1	6.3	131.8	3,310,544.1	2,103.2	1.3	1.1
11/03/2020 17:00	8.1	13.0	6.0	135.7	3,313,695.8	2,129.4	1.3	1.1
11/03/2020 18:00	8.0	13.0	6.0	137.8	3,328,168.1	2,138.7	1.4	1.1
11/03/2020 19:00	8.0	13.0	6.0	137.4	3,334,704.0	2,142.9	1.3	1.1
11/03/2020 20:00	7.9	13.1	6.0	133.4	3,333,525.2	2,117.8	1.3	1.1
11/03/2020 21:00	7.9	13.1	6.0	131.8	3,317,155.1	2,107.4	1.3	1.1
11/03/2020 22:00	7.8	13.1	5.9	128.3	3,354,123.1	2,081.9	1.2	1.0
11/03/2020 23:00	7.7	13.2	5.9	120.8	3,404,355.6	2,038.5	1.1	0.8
Average/Sum#:	7.6	13.4	6.0	119.8	3,274,617.7	1,905.7	1.2	0.9
Minimum:	6.5	13.0	5.4	92.3	3,020,870.8	1,522.1	1.0	0.6
Maximum:	8.3	13.8	6.5	148.4	3,404,355.6	2,142.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/04/2020 00:00	7.8	13.2	6.0	126.3	3,380,333.3	2,048.8	1.2	1.0
11/04/2020 01:00	7.9	13.3	6.1	121.5	3,331,168.2	1,921.7	1.2	1.0
11/04/2020 02:00	6.6	13.8	5.5	100.3	3,302,464.7	1,688.1	1.0	0.7
11/04/2020 03:00	7.5	13.5	6.0	109.2	3,300,130.2	1,807.4	1.1	0.7
11/04/2020 04:00	8.3	13.2	6.4	136.9	3,320,773.6	2,061.2	1.3	1.0
11/04/2020 05:00	8.0	13.1	6.1	139.8	3,346,650.3	2,101.7	1.4	1.1
11/04/2020 06:00	7.9	13.1	6.0	155.9	3,378,497.3	2,121.7	1.5	1.3
11/04/2020 07:00	8.0	13.3	6.2	125.0	3,350,079.7	2,006.0	1.2	1.0
11/04/2020 08:00	6.7	13.8	5.6	100.9	3,295,422.0	1,684.5	1.0	0.7
11/04/2020 09:00	7.0	13.8	5.8	99.4	3,190,171.9	1,630.7	1.0	0.7
11/04/2020 10:00	6.8	13.8	5.7	92.8	2,998,843.8	1,532.9	1.0	0.6
11/04/2020 11:00	7.1	13.8	5.9	100.5	3,245,340.2	1,658.9	1.0	0.7
11/04/2020 12:00	7.1	13.8	5.9	101.5	3,334,052.2	1,679.9	1.0	0.7
11/04/2020 13:00	7.2	13.8	6.0	102.2	3,294,052.5	1,683.8	1.0	0.7
11/04/2020 14:00	7.8	13.7	6.4	106.0	3,309,185.1	1,715.7	1.0	0.7
11/04/2020 15:00	8.4	13.2	6.4	121.3	3,361,101.8	2,012.6	1.2	1.0
11/04/2020 16:00	8.2	13.1	6.2	130.8	3,304,090.5	2,099.1	1.3	1.0
11/04/2020 17:00	8.1	13.0	6.0	135.2	3,337,303.0	2,120.2	1.3	1.1
11/04/2020 18:00	8.1	13.0	6.0	140.1	3,317,238.2	2,155.9	1.4	1.1
11/04/2020 19:00	8.0	13.0	6.0	137.6	3,337,349.5	2,144.6	1.3	1.1
11/04/2020 20:00	7.9	13.0	5.9	134.4	3,340,136.3	2,122.0	1.3	1.1
11/04/2020 21:00	7.9	13.1	6.0	133.4	3,326,127.2	2,113.1	1.3	1.1
11/04/2020 22:00	7.9	13.0	5.9	133.2	3,325,655.0	2,112.8	1.3	1.1
11/04/2020 23:00	7.8	13.1	5.9	128.3	3,385,539.3	2,101.4	1.2	1.1
Average/Sum#:	7.7	13.4	6.0	121.4	3,308,821.1	1,930.2	1.2	0.9
Minimum:	6.6	13.0	5.5	92.8	2,998,843.8	1,532.9	1.0	0.6
Maximum:	8.4	13.8	6.4	155.9	3,385,539.3	2,155.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/05/2020 00:00	7.9	13.1	6.0	131.7	3,379,612.0	2,122.4	1.3	1.1
11/05/2020 01:00	7.8	13.1	5.9	127.9	3,332,534.5	2,068.5	1.2	1.0
11/05/2020 02:00	6.6	13.7	5.4	97.2	3,140,418.0	1,628.2	1.0	0.7
11/05/2020 03:00	7.8	13.5	6.2	113.5	3,255,626.3	1,806.8	1.1	0.7
11/05/2020 04:00	8.3	13.2	6.4	136.9	3,330,923.4	2,067.5	1.3	1.0
11/05/2020 05:00	8.2	13.1	6.2	141.4	3,332,000.6	2,092.5	1.4	1.0
11/05/2020 06:00	7.9	13.1	6.0	133.5	3,344,456.6	2,075.9	1.3	1.0
11/05/2020 07:00	8.2	13.3	6.4	123.7	3,339,366.7	1,975.2	1.2	1.0
11/05/2020 08:00	6.6	13.8	5.5	96.0	3,102,724.4	1,586.0	1.0	0.6
11/05/2020 09:00	7.0	13.8	5.8	100.7	3,264,316.5	1,668.6	1.0	0.7
11/05/2020 10:00	7.0	13.8	5.8	95.4	3,093,138.4	1,581.1	1.0	0.6
11/05/2020 11:00	7.1	13.8	5.9	96.5	3,084,530.6	1,576.7	1.0	0.6
11/05/2020 12:00	7.6	13.7	6.2	101.6	3,268,229.1	1,670.6	1.0	0.7
11/05/2020 13:00	7.7	13.8	6.4	98.7	3,053,816.4	1,561.0	1.0	0.6
11/05/2020 14:00	8.4	13.6	6.8	108.3	3,190,573.8	1,724.1	1.1	0.7
11/05/2020 15:00	8.6	13.0	6.4	135.5	3,273,391.1	2,103.5	1.3	1.1
11/05/2020 16:00	8.2	13.1	6.2	125.6	3,271,313.2	2,030.5	1.2	1.0
11/05/2020 17:00	8.3	13.0	6.2	134.4	3,293,544.3	2,092.4	1.3	1.0
11/05/2020 18:00	8.2	13.0	6.1	134.7	3,261,253.0	2,095.7	1.3	1.0
11/05/2020 19:00	8.2	13.1	6.2	125.9	3,288,068.5	2,040.9	1.2	1.0
11/05/2020 20:00	8.3	13.0	6.2	137.7	3,298,289.8	2,119.5	1.4	1.1
11/05/2020 21:00	8.2	13.0	6.1	139.1	3,300,158.9	2,144.8	1.4	1.1
11/05/2020 22:00	8.0	13.1	6.1	128.5	3,326,895.7	2,065.0	1.3	1.0
11/05/2020 23:00	8.0	13.0	6.0	128.7	3,297,765.0	2,071.0	1.3	1.0
Average/Sum#:	7.8	13.3	6.1	120.5	3,255,122.8	1,915.4	1.2	0.9
Minimum:	6.6	13.0	5.4	95.4	3,053,816.4	1,561.0	1.0	0.6
Maximum:	8.6	13.8	6.8	141.4	3,379,612.0	2,144.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/06/2020 00:00	8.1	13.1	6.1	129.0	3,282,956.1	2,061.7	1.3	1.0
11/06/2020 01:00	7.8	13.2	6.0	112.6	3,313,487.0	1,911.5	1.1	0.8
11/06/2020 02:00	6.9	13.7	5.7	99.7	3,156,426.8	1,636.5	1.0	0.7
11/06/2020 03:00	7.0	13.7	5.7	97.6	3,079,661.9	1,596.7	1.0	0.6
11/06/2020 04:00	8.0	13.4	6.3	110.7	3,257,968.7	1,808.1	1.1	0.7
11/06/2020 05:00	8.4	13.1	6.4	134.1	3,333,593.0	2,093.5	1.3	1.0
11/06/2020 06:00	8.1	13.2	6.2	128.1	3,290,368.1	2,018.3	1.3	1.0
11/06/2020 07:00	8.6	13.1	6.5	141.7	3,314,007.0	2,057.0	1.4	1.0
11/06/2020 08:00	6.6	13.8	5.5	87.4	2,773,866.9	1,417.9	1.0	0.6
11/06/2020 09:00	6.9	13.8	5.7	83.6	2,651,126.2	1,335.8	1.0	0.5
11/06/2020 10:00	7.1	13.8	5.9	82.9	2,594,364.6	1,307.2	1.0	0.5
11/06/2020 11:00	7.2	13.8	6.0	82.8	2,555,266.5	1,287.5	1.0	0.5
11/06/2020 12:00	7.0	13.8	5.8	86.6	2,815,457.1	1,418.6	1.0	0.6
11/06/2020 13:00	7.1	13.8	5.9	85.8	2,775,962.2	1,398.7	1.0	0.6
11/06/2020 14:00	7.2	13.8	6.0	83.2	2,622,348.5	1,321.3	1.0	0.5
11/06/2020 15:00	8.5	13.4	6.7	112.4	3,258,329.1	1,808.3	1.1	0.7
11/06/2020 16:00	8.4	13.1	6.4	132.5	3,337,414.6	2,095.9	1.3	1.0
11/06/2020 17:00	8.3	13.0	6.2	137.0	3,330,849.4	2,116.1	1.3	1.1
11/06/2020 18:00	8.2	13.0	6.1	139.0	3,320,775.4	2,109.7	1.4	1.1
11/06/2020 19:00	7.9	13.2	6.1	122.2	3,337,845.1	1,974.3	1.2	1.0
11/06/2020 20:00	7.7	13.3	6.0	115.6	3,315,740.5	1,912.8	1.1	0.8
11/06/2020 21:00	6.6	13.7	5.4	92.0	2,978,889.3	1,522.7	1.0	0.6
11/06/2020 22:00	7.4	13.6	6.0	105.5	3,264,107.4	1,740.0	1.0	0.7
11/06/2020 23:00	8.2	13.2	6.3	120.3	3,357,456.6	1,985.9	1.2	1.0
Average/Sum#:	7.6	13.4	6.0	109.3	3,096,594.5	1,747.3	1.1	0.8
Minimum:	6.6	13.0	5.4	82.8	2,555,266.5	1,287.5	1.0	0.5
Maximum:	8.6	13.8	6.7	141.7	3,357,456.6	2,116.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/07/2020 00:00	7.8	13.3	6.1	113.9	3,337,708.6	1,901.1	1.1	0.8
11/07/2020 01:00	6.8	13.7	5.6	101.4	3,289,357.4	1,681.4	1.0	0.7
11/07/2020 02:00	7.3	13.6	5.9	103.6	3,215,333.4	1,714.0	1.0	0.7
11/07/2020 03:00	8.0	13.3	6.2	111.8	3,356,494.3	1,911.8	1.1	0.8
11/07/2020 04:00	7.8	13.3	6.1	113.4	3,351,929.5	1,909.2	1.1	0.8
11/07/2020 05:00	6.6	13.7	5.4	98.3	3,201,714.2	1,636.6	1.0	0.7
11/07/2020 06:00	6.7	13.7	5.5	96.8	3,142,242.1	1,606.2	1.0	0.6
11/07/2020 07:00	7.0	13.7	5.7	96.1	3,103,311.3	1,586.3	1.0	0.6
11/07/2020 08:00	7.2	13.7	5.9	101.3	3,227,928.9	1,650.0	1.0	0.7
11/07/2020 09:00	7.0	13.8	5.8	94.7	3,030,927.4	1,549.3	1.0	0.6
11/07/2020 10:00	7.1	13.8	5.9	87.2	2,747,652.2	1,404.5	1.0	0.6
11/07/2020 11:00	7.1	13.8	5.9	86.1	2,719,089.9	1,389.9	1.0	0.6
11/07/2020 12:00	7.1	13.8	5.9	96.3	3,076,314.1	1,572.5	1.0	0.6
11/07/2020 13:00	7.0	13.8	5.8	90.5	2,888,898.6	1,476.7	1.0	0.6
11/07/2020 14:00	7.2	13.8	6.0	91.0	2,871,878.6	1,468.0	1.0	0.6
11/07/2020 15:00	7.7	13.7	6.3	95.6	3,021,341.5	1,544.4	1.0	0.6
11/07/2020 16:00	8.5	13.1	6.4	123.6	3,352,449.9	2,031.9	1.2	1.0
11/07/2020 17:00	8.2	13.1	6.2	135.0	3,302,201.6	2,097.9	1.3	1.0
11/07/2020 18:00	8.0	13.1	6.1	129.4	3,321,506.2	2,037.4	1.3	1.0
11/07/2020 19:00	7.9	13.2	6.1	124.6	3,338,755.6	2,023.6	1.2	1.0
11/07/2020 20:00	7.7	13.3	6.0	117.6	3,319,484.7	1,939.2	1.1	0.8
11/07/2020 21:00	6.5	13.7	5.3	93.7	3,072,792.7	1,570.7	1.0	0.6
11/07/2020 22:00	7.7	13.5	6.1	109.6	3,295,200.2	1,804.7	1.1	0.7
11/07/2020 23:00	8.3	13.1	6.3	137.1	3,326,745.8	2,089.2	1.3	1.0
Average/Sum#:	7.4	13.5	5.9	106.2	3,162,969.1	1,733.2	1.1	0.7
Minimum:	6.5	13.1	5.3	86.1	2,719,089.9	1,389.9	1.0	0.6
Maximum:	8.5	13.8	6.4	137.1	3,356,494.3	2,097.9	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/08/2020 00:00	7.8	13.3	6.1	124.1	3,316,543.0	1,961.7	1.2	1.0
11/08/2020 01:00	6.4	13.7	5.2	93.6	3,028,163.8	1,570.0	1.0	0.6
11/08/2020 02:00	7.2	13.7	5.9	94.5	3,036,209.5	1,552.0	1.0	0.6
11/08/2020 03:00	8.1	13.3	6.3	112.5	3,335,601.8	1,899.9	1.1	0.8
11/08/2020 04:00	7.8	13.3	6.1	114.3	3,337,533.0	1,901.0	1.1	0.8
11/08/2020 05:00	6.7	13.7	5.5	100.7	3,305,790.5	1,689.8	1.0	0.7
11/08/2020 06:00	6.7	13.7	5.5	97.6	3,233,993.5	1,653.1	1.0	0.7
11/08/2020 07:00	7.0	13.7	5.7	96.7	3,074,357.7	1,571.5	1.0	0.6
11/08/2020 08:00	7.1	13.8	5.9	100.4	3,241,036.3	1,656.7	1.0	0.7
11/08/2020 09:00	7.0	13.8	5.8	99.8	3,221,668.7	1,646.8	1.0	0.7
11/08/2020 10:00	6.9	13.8	5.7	101.3	3,288,379.2	1,680.9	1.0	0.7
11/08/2020 11:00	6.9	13.8	5.7	93.9	3,012,342.4	1,539.8	1.0	0.6
11/08/2020 12:00	7.0	13.8	5.8	88.0	2,850,387.4	1,436.2	1.0	0.6
11/08/2020 13:00	7.0	13.8	5.8	99.5	3,227,733.3	1,649.9	1.0	0.7
11/08/2020 14:00	6.9	13.8	5.7	99.5	3,242,210.0	1,657.3	1.0	0.7
11/08/2020 15:00	6.9	13.8	5.7	100.8	3,277,423.8	1,675.3	1.0	0.7
11/08/2020 16:00	7.9	13.5	6.3	112.6	3,301,033.5	1,832.0	1.1	0.7
11/08/2020 17:00	8.5	13.1	6.4	150.0	3,374,608.0	2,143.9	1.5	1.3
11/08/2020 18:00	8.0	13.2	6.1	134.7	3,369,273.1	2,066.7	1.3	1.0
11/08/2020 19:00	7.8	13.2	6.0	132.9	3,344,860.3	2,027.3	1.3	1.0
11/08/2020 20:00	6.4	13.8	5.3	99.9	3,243,383.8	1,657.9	1.0	0.7
11/08/2020 21:00	6.5	13.8	5.4	96.2	3,095,877.3	1,582.5	1.0	0.6
11/08/2020 22:00	7.5	13.5	6.0	109.5	3,352,313.9	1,811.5	1.0	0.7
11/08/2020 23:00	8.3	13.1	6.3	136.3	3,380,032.8	2,073.3	1.3	1.0
Average/Sum#:	7.3	13.6	5.8	107.9	3,228,781.5	1,747.4	1.1	0.8
Minimum:	6.4	13.1	5.2	88.0	2,850,387.4	1,436.2	1.0	0.6
Maximum:	8.5	13.8	6.4	150.0	3,380,032.8	2,143.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/09/2020 00:00	7.1	13.3	5.5	114.3	3,392,485.6	1,932.3	1.1	0.8
11/09/2020 01:00	6.4	13.8	5.3	91.9	2,984,171.4	1,525.4	1.0	0.6
11/09/2020 02:00	7.0	13.8	5.8	83.8	2,537,934.6	1,297.3	1.0	0.5
11/09/2020 03:00	7.0	13.8	5.8	83.8	2,570,409.6	1,313.9	1.0	0.5
11/09/2020 04:00	7.6	13.6	6.1	105.5	3,216,481.8	1,738.1	1.0	0.7
11/09/2020 05:00	8.4	13.1	6.4	140.7	3,435,644.1	2,132.5	1.3	1.1
11/09/2020 06:00	8.2	13.0	6.1	149.7	3,424,662.8	2,175.7	1.4	1.1
11/09/2020 07:00	8.2	13.2	6.3	130.3	3,441,096.3	2,060.5	1.2	1.0
11/09/2020 08:00	7.5	13.4	5.9	115.5	3,408,988.9	1,941.7	1.1	0.8
11/09/2020 09:00	6.5	13.8	5.4	90.9	2,965,195.1	1,515.7	1.0	0.6
11/09/2020 10:00	6.6	13.8	5.5	91.8	3,010,973.0	1,539.1	1.0	0.6
11/09/2020 11:00	6.7	13.8	5.6	86.4	2,854,555.2	1,438.3	1.0	0.6
11/09/2020 12:00	6.7	13.8	5.6	88.0	2,918,064.7	1,470.3	1.0	0.6
11/09/2020 13:00	6.9	13.8	5.7	85.8	2,799,976.7	1,410.8	1.0	0.6
11/09/2020 14:00	6.9	13.8	5.7	97.8	3,164,544.1	1,617.6	1.0	0.6
11/09/2020 15:00	7.7	13.6	6.2	108.1	3,331,217.3	1,800.1	1.0	0.7
11/09/2020 16:00	8.2	13.3	6.4	128.2	3,432,521.4	2,030.3	1.2	1.0
11/09/2020 17:00	8.0	13.2	6.1	133.5	3,395,842.5	2,058.2	1.3	1.0
11/09/2020 18:00	8.0	13.2	6.1	138.7	3,431,386.2	2,104.8	1.3	1.1
11/09/2020 19:00	7.9	13.2	6.1	139.8	3,393,272.5	2,106.2	1.3	1.1
11/09/2020 20:00	8.0	13.1	6.1	151.9	3,388,236.0	2,177.3	1.5	1.3
11/09/2020 21:00	7.8	13.1	5.9	144.3	3,416,395.4	2,145.5	1.4	1.1
11/09/2020 22:00	7.7	13.3	6.0	130.0	3,417,214.8	2,046.2	1.2	1.0
11/09/2020 23:00	7.6	13.3	5.9	123.1	3,448,724.1	2,014.7	1.2	1.0
Average/Sum#:	7.4	13.5	5.9	114.7	3,199,166.4	1,816.4	1.1	0.8
Minimum:	6.4	13.0	5.3	83.8	2,537,934.6	1,297.3	1.0	0.5
Maximum:	8.4	13.8	6.4	151.9	3,448,724.1	2,177.3	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/10/2020 00:00	7.6	13.3	5.9	121.9	3,461,391.3	2,022.1	1.1	0.8
11/10/2020 01:00	7.2	13.4	5.7	113.3	3,450,771.6	1,940.3	1.1	0.8
11/10/2020 02:00	6.4	13.8	5.3	98.8	3,282,705.9	1,678.0	1.0	0.7
11/10/2020 03:00	7.1	13.5	5.7	106.4	3,362,121.9	1,816.8	1.0	0.7
11/10/2020 04:00	7.9	13.3	6.1	121.6	3,446,156.5	2,013.2	1.1	0.8
11/10/2020 05:00	7.7	13.3	6.0	121.9	3,462,589.6	2,022.8	1.1	0.8
11/10/2020 06:00	7.6	13.3	5.9	120.7	3,515,607.1	2,028.1	1.1	0.8
11/10/2020 07:00	7.9	13.3	6.1	123.7	3,468,630.6	2,001.0	1.1	0.8
11/10/2020 08:00	7.0	13.4	5.5	110.3	3,457,174.1	1,943.9	1.0	0.8
11/10/2020 09:00	6.4	13.8	5.3	97.3	3,221,864.3	1,646.9	1.0	0.7
11/10/2020 10:00	6.7	13.8	5.6	98.4	3,232,819.7	1,652.5	1.0	0.7
11/10/2020 11:00	6.8	13.8	5.7	84.4	2,749,169.1	1,385.2	1.0	0.6
11/10/2020 12:00	6.7	13.8	5.6	89.8	2,937,806.6	1,501.7	1.0	0.6
11/10/2020 13:00	6.7	13.8	5.6	91.1	2,977,715.5	1,522.1	1.0	0.6
11/10/2020 14:00	6.9	13.8	5.7	85.5	2,784,694.7	1,403.1	1.0	0.6
11/10/2020 15:00	7.5	13.7	6.1	100.5	3,146,062.3	1,654.1	1.0	0.7
11/10/2020 16:00	8.3	13.3	6.4	123.4	3,408,154.9	1,991.0	1.2	1.0
11/10/2020 17:00	8.1	13.2	6.2	137.0	3,383,619.4	2,075.5	1.3	1.0
11/10/2020 18:00	8.2	13.1	6.2	153.1	3,372,985.6	2,167.5	1.5	1.3
11/10/2020 19:00	8.0	13.1	6.1	150.0	3,360,069.5	2,159.2	1.5	1.3
11/10/2020 20:00	7.9	13.1	6.0	139.4	3,397,300.2	2,108.7	1.3	1.1
11/10/2020 21:00	7.8	13.2	6.0	135.3	3,412,801.2	2,093.4	1.3	1.0
11/10/2020 22:00	7.7	13.2	5.9	127.7	3,423,394.0	2,049.9	1.2	1.0
11/10/2020 23:00	7.7	13.2	5.9	125.2	3,432,014.2	2,030.0	1.2	1.0
Average/Sum#:	7.4	13.4	5.9	115.7	3,297,817.5	1,871.1	1.1	0.8
Minimum:	6.4	13.1	5.3	84.4	2,749,169.1	1,385.2	1.0	0.6
Maximum:	8.3	13.8	6.4	153.1	3,515,607.1	2,167.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/11/2020 00:00	7.7	13.2	5.9	124.4	3,423,053.8	2,024.7	1.2	1.0
11/11/2020 01:00	7.1	13.4	5.6	111.5	3,425,873.0	1,926.3	1.0	0.8
11/11/2020 02:00	6.4	13.7	5.2	93.8	3,091,573.4	1,580.3	1.0	0.6
11/11/2020 03:00	7.3	13.5	5.8	107.4	3,400,428.8	1,837.5	1.0	0.7
11/11/2020 04:00	7.9	13.3	6.1	120.3	3,447,309.2	1,988.7	1.1	0.8
11/11/2020 05:00	7.9	13.2	6.1	127.6	3,439,259.2	2,059.4	1.2	1.0
11/11/2020 06:00	7.9	13.1	6.0	142.7	3,405,089.7	2,138.4	1.4	1.1
11/11/2020 07:00	7.7	13.3	6.0	119.5	3,430,841.4	1,979.2	1.1	0.8
11/11/2020 08:00	6.5	13.7	5.3	99.7	3,283,097.1	1,678.2	1.0	0.7
11/11/2020 09:00	6.8	13.7	5.6	100.3	3,268,033.5	1,670.5	1.0	0.7
11/11/2020 10:00	6.7	13.8	5.6	98.7	3,218,147.3	1,645.0	1.0	0.7
11/11/2020 11:00	6.6	13.8	5.5	93.7	3,053,229.5	1,560.7	1.0	0.6
11/11/2020 12:00	6.9	13.8	5.7	99.6	3,224,211.9	1,648.1	1.0	0.7
11/11/2020 13:00	6.8	13.8	5.7	91.6	2,966,955.7	1,516.6	1.0	0.6
11/11/2020 14:00	7.0	13.8	5.8	101.3	3,279,967.0	1,676.6	1.0	0.7
11/11/2020 15:00	7.1	13.8	5.9	85.0	2,730,513.1	1,375.8	1.0	0.6
11/11/2020 16:00	8.3	13.4	6.5	111.8	3,340,854.9	1,854.1	1.1	0.7
11/11/2020 17:00	8.3	13.3	6.4	127.6	3,395,158.1	2,008.2	1.2	1.0
11/11/2020 18:00	8.1	13.2	6.2	134.9	3,357,861.2	2,059.7	1.3	1.0
11/11/2020 19:00	7.9	13.2	6.1	130.2	3,400,013.5	2,035.9	1.2	1.0
11/11/2020 20:00	7.7	13.3	6.0	124.3	3,379,773.2	1,999.1	1.2	1.0
11/11/2020 21:00	6.5	13.8	5.4	98.4	3,233,015.3	1,652.6	1.0	0.7
11/11/2020 22:00	7.5	13.5	6.0	108.1	3,373,225.4	1,822.8	1.0	0.7
11/11/2020 23:00	7.9	13.3	6.1	120.4	3,451,634.2	2,016.4	1.1	0.8
Average/Sum#:	7.4	13.5	5.9	111.4	3,292,463.3	1,823.1	1.1	0.8
Minimum:	6.4	13.1	5.2	85.0	2,730,513.1	1,375.8	1.0	0.6
Maximum:	8.3	13.8	6.5	142.7	3,451,634.2	2,138.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/12/2020 00:00	7.8	13.3	6.1	122.6	3,421,532.2	2,023.8	1.2	1.0
11/12/2020 01:00	6.8	13.4	5.3	107.3	3,412,178.7	1,918.6	1.0	0.8
11/12/2020 02:00	6.4	13.7	5.2	92.9	3,057,729.0	1,563.0	1.0	0.6
11/12/2020 03:00	7.1	13.7	5.8	100.6	3,196,845.1	1,680.8	1.0	0.7
11/12/2020 04:00	8.1	13.3	6.3	119.9	3,459,508.3	2,021.0	1.1	0.8
11/12/2020 05:00	7.9	13.2	6.1	126.7	3,478,337.9	2,057.4	1.2	1.0
11/12/2020 06:00	8.0	13.1	6.1	144.0	3,445,125.5	2,188.7	1.4	1.1
11/12/2020 07:00	7.8	13.2	6.0	132.3	3,387,263.0	2,053.0	1.3	1.0
11/12/2020 08:00	6.4	13.7	5.2	96.6	3,176,868.9	1,623.9	1.0	0.6
11/12/2020 09:00	6.7	13.7	5.5	98.2	3,197,605.9	1,634.5	1.0	0.7
11/12/2020 10:00	6.8	13.7	5.6	100.3	3,252,382.9	1,662.5	1.0	0.7
11/12/2020 11:00	6.7	13.8	5.6	96.4	3,124,830.8	1,597.3	1.0	0.6
11/12/2020 12:00	7.0	13.8	5.8	102.1	3,312,442.0	1,693.2	1.0	0.7
11/12/2020 13:00	6.8	13.8	5.7	94.7	3,063,206.7	1,565.8	1.0	0.6
11/12/2020 14:00	6.7	13.8	5.6	93.7	3,041,882.8	1,554.9	1.0	0.6
11/12/2020 15:00	7.6	13.6	6.1	102.3	3,194,182.4	1,679.4	1.0	0.7
11/12/2020 16:00	8.7	13.2	6.7	133.0	3,354,264.8	2,033.0	1.3	1.0
11/12/2020 17:00	8.4	13.2	6.4	138.6	3,354,274.6	2,057.5	1.3	1.0
11/12/2020 18:00	8.4	13.2	6.4	139.4	3,341,717.7	2,074.2	1.4	1.0
11/12/2020 19:00	8.3	13.1	6.3	145.5	3,370,556.2	2,092.1	1.4	1.0
11/12/2020 20:00	7.9	13.2	6.1	130.4	3,336,719.4	1,998.0	1.3	1.0
11/12/2020 21:00	6.7	13.8	5.6	99.6	3,241,623.1	1,657.0	1.0	0.7
11/12/2020 22:00	7.5	13.5	6.0	108.3	3,360,641.5	1,816.0	1.0	0.7
11/12/2020 23:00	8.3	13.2	6.4	129.3	3,403,442.3	2,013.1	1.2	1.0
Average/Sum#:	7.5	13.5	5.9	114.8	3,291,048.4	1,844.1	1.1	0.8
Minimum:	6.4	13.1	5.2	92.9	3,041,882.8	1,554.9	1.0	0.6
Maximum:	8.7	13.8	6.7	145.5	3,478,337.9	2,188.7	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/13/2020 00:00	7.5	13.4	5.9	110.3	3,418,936.9	1,922.4	1.0	0.8
11/13/2020 01:00	7.2	13.7	5.9	94.9	2,843,267.4	1,494.9	1.1	0.6
11/13/2020 02:00	7.4	13.8	6.1	83.5	2,521,110.3	1,288.7	1.0	0.5
11/13/2020 03:00	7.2	13.7	5.9	83.3	2,655,313.9	1,357.3	1.0	0.5
11/13/2020 04:00	7.4	13.8	6.1	83.6	2,581,365.0	1,319.5	1.0	0.5
11/13/2020 05:00	7.1	13.7	5.8	96.2	3,098,224.9	1,583.7	1.0	0.6
11/13/2020 06:00	7.4	13.7	6.1	103.6	3,292,597.7	1,707.1	1.0	0.7
11/13/2020 07:00	8.1	13.5	6.5	109.6	3,348,057.6	1,809.2	1.0	0.7
11/13/2020 08:00	8.1	13.4	6.4	114.3	3,296,400.1	1,853.5	1.1	0.7
11/13/2020 09:00	7.1	13.7	5.8	101.7	3,264,316.5	1,668.6	1.0	0.7
11/13/2020 10:00	6.9	13.7	5.7	100.4	3,270,772.3	1,671.9	1.0	0.7
11/13/2020 11:00	7.0	13.7	5.7	99.7	3,220,494.9	1,646.2	1.0	0.7
11/13/2020 12:00	7.0	13.7	5.7	93.1	2,991,801.0	1,529.3	1.0	0.6
11/13/2020 13:00	7.3	13.7	6.0	100.4	3,167,999.4	1,642.5	1.0	0.7
11/13/2020 14:00	7.3	13.7	6.0	101.3	3,234,776.0	1,653.5	1.0	0.7
11/13/2020 15:00	7.8	13.5	6.2	107.4	3,206,461.5	1,756.1	1.1	0.7
11/13/2020 16:00	8.4	13.1	6.4	128.5	3,326,573.5	2,064.8	1.2	1.0
11/13/2020 17:00	8.1	13.1	6.1	125.4	3,334,711.4	2,045.5	1.2	1.0
11/13/2020 18:00	8.0	13.1	6.1	122.0	3,338,260.7	2,023.3	1.2	1.0
11/13/2020 19:00	7.7	13.3	6.0	111.4	3,282,756.0	1,869.8	1.1	0.7
11/13/2020 20:00	6.9	13.7	5.7	101.4	3,223,355.0	1,671.2	1.0	0.7
11/13/2020 21:00	7.5	13.6	6.1	102.5	3,158,868.1	1,683.9	1.0	0.7
11/13/2020 22:00	8.3	13.2	6.4	120.3	3,407,499.8	2,015.5	1.1	0.8
11/13/2020 23:00	7.2	13.6	5.8	100.4	3,030,499.2	1,637.6	1.1	0.7
Average/Sum#:	7.5	13.5	6.0	104.0	3,146,434.1	1,704.8	1.1	0.7
Minimum:	6.9	13.1	5.7	83.3	2,521,110.3	1,288.7	1.0	0.5
Maximum:	8.4	13.8	6.5	128.5	3,418,936.9	2,064.8	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/14/2020 00:00	15.4	15.0	15.4	128.8	2,058,473.1	901.9	1.9	0.6
11/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2020 05:00	32.9	17.5	57.1	146.7	1,888,949.8	441.4	1.9	0.3
11/14/2020 06:00	36.1	15.5	39.4	224.9	2,314,571.7	946.5	2.8	1.0
11/14/2020 07:00	6.8	13.7	5.6	101.0	3,080,626.2	1,597.2	1.0	0.6
11/14/2020 08:00	6.8	13.7	5.6	101.2	3,266,173.6	1,693.4	1.0	0.7
11/14/2020 09:00	6.8	13.7	5.6	101.2	3,248,621.8	1,684.3	1.0	0.7
11/14/2020 10:00	7.0	13.7	5.7	102.7	3,266,173.6	1,693.4	1.0	0.7
11/14/2020 11:00	7.2	13.7	5.9	103.0	3,303,247.2	1,688.5	1.0	0.7
11/14/2020 12:00	7.2	13.8	6.0	102.4	3,283,292.8	1,678.3	1.0	0.7
11/14/2020 13:00	7.1	13.8	5.9	101.9	3,282,705.9	1,678.0	1.0	0.7
11/14/2020 14:00	7.1	13.8	5.9	100.4	3,220,690.5	1,646.3	1.0	0.7
11/14/2020 15:00	7.6	13.7	6.2	103.2	3,223,092.4	1,694.6	1.0	0.7
11/14/2020 16:00	8.5	13.2	6.5	127.3	3,394,650.9	2,007.9	1.2	1.0
11/14/2020 17:00	8.2	13.2	6.3	131.6	3,382,812.2	2,025.6	1.3	1.0
11/14/2020 18:00	8.1	13.2	6.2	128.1	3,379,973.2	2,023.9	1.2	1.0
11/14/2020 19:00	7.9	13.3	6.1	125.2	3,355,089.7	1,984.5	1.2	1.0
11/14/2020 20:00	6.6	13.8	5.5	99.0	3,241,818.8	1,657.1	1.0	0.7
11/14/2020 21:00	7.6	13.5	6.1	109.1	3,369,709.3	1,820.9	1.0	0.7
11/14/2020 22:00	8.1	13.2	6.2	123.5	3,419,334.3	2,022.5	1.2	1.0
11/14/2020 23:00	7.4	13.4	5.8	112.4	3,468,022.8	1,950.0	1.0	0.8
Average/Sum#:	10.5	13.9	10.7	118.7	3,122,401.5	1,641.8	1.2	0.8
Minimum:	6.6	13.2	5.5	99.0	1,888,949.8	441.4	1.0	0.3
Maximum:	36.1	17.5	57.1	224.9	3,468,022.8	2,025.6	2.8	1.0
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/15/2020 00:00	7.9	13.2	6.1	122.9	3,408,683.3	2,016.2	1.2	1.0
11/15/2020 01:00	7.2	13.4	5.7	111.6	3,381,951.5	1,926.3	1.1	0.8
11/15/2020 02:00	6.5	13.7	5.3	96.5	3,158,870.8	1,614.7	1.0	0.6
11/15/2020 03:00	7.3	13.6	5.9	101.6	3,224,614.0	1,695.4	1.0	0.7
11/15/2020 04:00	8.0	13.2	6.1	117.8	3,430,408.1	2,004.0	1.1	0.8
11/15/2020 05:00	7.0	13.5	5.6	108.1	3,390,406.5	1,881.6	1.0	0.8
11/15/2020 06:00	6.6	13.7	5.4	98.8	3,188,058.5	1,652.9	1.0	0.7
11/15/2020 07:00	7.2	13.7	5.9	90.8	2,890,854.9	1,477.7	1.0	0.6
11/15/2020 08:00	7.0	13.7	5.7	100.6	3,210,625.1	1,664.6	1.0	0.7
11/15/2020 09:00	6.9	13.7	5.7	101.6	3,244,764.3	1,682.3	1.0	0.7
11/15/2020 10:00	7.1	13.7	5.8	102.8	3,301,877.8	1,687.8	1.0	0.7
11/15/2020 11:00	7.2	13.7	5.9	103.0	3,293,856.9	1,683.7	1.0	0.7
11/15/2020 12:00	7.2	13.8	6.0	102.8	3,297,378.3	1,685.5	1.0	0.7
11/15/2020 13:00	7.2	13.8	6.0	102.7	3,299,725.9	1,686.7	1.0	0.7
11/15/2020 14:00	7.2	13.8	6.0	102.2	3,283,488.4	1,678.4	1.0	0.7
11/15/2020 15:00	7.3	13.7	6.0	91.1	2,835,882.3	1,449.6	1.0	0.6
11/15/2020 16:00	7.0	13.8	5.8	94.5	3,049,121.2	1,558.6	1.0	0.6
11/15/2020 17:00	6.9	13.8	5.7	94.9	3,058,707.2	1,563.5	1.0	0.6
11/15/2020 18:00	6.9	13.8	5.7	96.3	3,118,766.2	1,594.2	1.0	0.6
11/15/2020 19:00	6.8	13.7	5.6	98.3	3,182,542.3	1,626.8	1.0	0.7
11/15/2020 20:00	7.8	13.5	6.2	108.7	3,358,790.9	1,815.0	1.0	0.7
11/15/2020 21:00	7.9	13.3	6.1	114.4	3,308,564.4	1,884.5	1.1	0.8
11/15/2020 22:00	7.1	13.6	5.7	103.5	3,337,730.8	1,730.5	1.0	0.7
11/15/2020 23:00	8.1	13.2	6.2	119.8	3,397,017.8	2,009.3	1.1	0.8
Average/Sum#:	7.2	13.6	5.8	103.6	3,235,528.6	1,719.6	1.0	0.7
Minimum:	6.5	13.2	5.3	90.8	2,835,882.3	1,449.6	1.0	0.6
Maximum:	8.1	13.8	6.2	122.9	3,430,408.1	2,016.2	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/16/2020 00:00	7.2	13.4	5.7	107.7	3,279,230.8	1,819.9	1.1	0.7
11/16/2020 01:00	6.8	13.8	5.7	82.4	2,529,718.1	1,293.1	1.0	0.5
11/16/2020 02:00	7.2	13.8	6.0	82.9	2,517,588.9	1,286.9	1.0	0.5
11/16/2020 03:00	7.4	13.8	6.1	83.8	2,515,437.0	1,285.8	1.1	0.5
11/16/2020 04:00	7.5	13.6	6.1	101.4	3,200,839.3	1,682.9	1.0	0.7
11/16/2020 05:00	8.3	13.2	6.4	121.3	3,395,496.2	2,008.4	1.1	0.8
11/16/2020 06:00	8.2	13.1	6.2	134.1	3,386,603.0	2,052.6	1.3	1.0
11/16/2020 07:00	8.3	13.2	6.4	120.6	3,318,402.7	1,962.8	1.2	1.0
11/16/2020 08:00	6.9	13.7	5.7	101.6	3,296,987.0	1,685.3	1.0	0.7
11/16/2020 09:00	6.9	13.8	5.7	98.6	3,185,476.7	1,628.3	1.0	0.7
11/16/2020 10:00	7.0	13.8	5.8	100.6	3,263,925.2	1,668.4	1.0	0.7
11/16/2020 11:00	7.0	13.8	5.8	101.5	3,283,488.4	1,678.4	1.0	0.7
11/16/2020 12:00	7.1	13.8	5.9	101.5	3,266,272.8	1,669.6	1.0	0.7
11/16/2020 13:00	7.1	13.8	5.9	101.6	3,272,533.0	1,672.8	1.0	0.7
11/16/2020 14:00	7.2	13.8	6.0	98.6	3,166,696.1	1,618.7	1.0	0.6
11/16/2020 15:00	7.8	13.6	6.3	105.2	3,195,823.8	1,703.6	1.0	0.7
11/16/2020 16:00	8.3	13.1	6.3	121.6	3,327,866.2	2,017.0	1.2	1.0
11/16/2020 17:00	8.1	13.0	6.0	128.4	3,312,892.4	2,080.5	1.3	1.0
11/16/2020 18:00	8.1	13.0	6.0	132.1	3,316,682.9	2,107.1	1.3	1.1
11/16/2020 19:00	7.9	13.0	5.9	130.0	3,297,164.7	2,094.7	1.3	1.0
11/16/2020 20:00	7.9	13.0	5.9	129.1	3,328,497.4	2,090.3	1.3	1.0
11/16/2020 21:00	7.8	13.1	5.9	123.5	3,327,212.2	2,040.9	1.2	1.0
11/16/2020 22:00	7.8	13.1	5.9	124.3	3,342,373.7	2,050.2	1.2	1.0
11/16/2020 23:00	7.7	13.2	5.9	120.6	3,382,144.2	2,025.2	1.2	1.0
Average/Sum#:	7.6	13.4	6.0	110.5	3,196,223.0	1,801.0	1.1	0.8
Minimum:	6.8	13.0	5.7	82.4	2,515,437.0	1,285.8	1.0	0.5
Maximum:	8.3	13.8	6.4	134.1	3,395,496.2	2,107.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/17/2020 00:00	7.8	13.2	6.0	122.3	3,339,910.6	2,024.3	1.2	1.0
11/17/2020 01:00	7.7	13.2	5.9	117.7	3,323,981.8	1,966.1	1.1	0.8
11/17/2020 02:00	6.6	13.7	5.4	91.9	2,999,430.7	1,533.2	1.0	0.6
11/17/2020 03:00	6.8	13.7	5.6	90.8	2,971,846.5	1,519.1	1.0	0.6
11/17/2020 04:00	7.5	13.6	6.1	103.8	3,225,088.2	1,719.2	1.0	0.7
11/17/2020 05:00	8.4	13.1	6.4	122.3	3,375,798.1	2,021.4	1.2	1.0
11/17/2020 06:00	8.3	13.0	6.2	133.5	3,369,106.2	2,091.2	1.3	1.0
11/17/2020 07:00	8.2	13.2	6.3	121.1	3,339,197.7	1,975.1	1.2	1.0
11/17/2020 08:00	6.9	13.7	5.7	100.9	3,254,143.6	1,663.4	1.0	0.7
11/17/2020 09:00	7.2	13.7	5.9	96.1	3,055,185.8	1,561.7	1.0	0.6
11/17/2020 10:00	7.2	13.7	5.9	94.6	3,029,753.6	1,548.7	1.0	0.6
11/17/2020 11:00	7.3	13.7	6.0	103.3	3,266,945.1	1,693.8	1.0	0.7
11/17/2020 12:00	7.2	13.7	5.9	91.0	2,861,510.1	1,462.7	1.0	0.6
11/17/2020 13:00	7.1	13.7	5.8	95.4	3,023,534.7	1,567.6	1.0	0.6
11/17/2020 14:00	7.4	13.7	6.1	98.3	3,083,905.1	1,598.9	1.0	0.6
11/17/2020 15:00	8.1	13.4	6.4	111.9	3,269,320.5	1,814.4	1.1	0.7
11/17/2020 16:00	8.4	13.0	6.3	130.8	3,301,586.6	2,073.4	1.3	1.0
11/17/2020 17:00	8.1	13.0	6.0	133.4	3,293,386.9	2,092.3	1.3	1.0
11/17/2020 18:00	8.0	13.0	6.0	132.6	3,287,090.7	2,088.3	1.3	1.0
11/17/2020 19:00	7.9	13.0	5.9	128.6	3,285,822.3	2,063.5	1.3	1.0
11/17/2020 20:00	7.9	13.0	5.9	123.0	3,299,171.6	2,023.7	1.2	1.0
11/17/2020 21:00	7.9	13.0	5.9	122.7	3,295,748.0	2,021.6	1.2	1.0
11/17/2020 22:00	7.9	13.0	5.9	123.2	3,300,638.8	2,024.6	1.2	1.0
11/17/2020 23:00	7.7	13.2	5.9	114.5	3,345,161.4	1,954.2	1.1	0.8
Average/Sum#:	7.6	13.3	6.0	112.7	3,216,552.7	1,837.6	1.1	0.8
Minimum:	6.6	13.0	5.4	90.8	2,861,510.1	1,462.7	1.0	0.6
Maximum:	8.4	13.7	6.4	133.5	3,375,798.1	2,092.3	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/18/2020 00:00	7.9	13.1	6.0	122.4	3,293,465.6	2,020.2	1.2	1.0
11/18/2020 01:00	7.4	13.3	5.7	108.4	3,207,832.2	1,803.7	1.1	0.7
11/18/2020 02:00	7.1	13.7	5.8	88.1	2,728,871.5	1,394.9	1.0	0.6
11/18/2020 03:00	7.4	13.7	6.1	83.7	2,535,391.4	1,296.0	1.0	0.5
11/18/2020 04:00	7.7	13.5	6.1	102.6	3,166,747.0	1,688.1	1.0	0.7
11/18/2020 05:00	8.3	13.1	6.3	124.5	3,321,180.2	2,037.2	1.2	1.0
11/18/2020 06:00	8.3	13.1	6.3	141.3	3,288,035.2	2,088.9	1.4	1.0
11/18/2020 07:00	8.4	13.2	6.4	122.3	3,269,083.2	1,957.5	1.2	1.0
11/18/2020 08:00	6.7	13.7	5.5	90.9	2,948,957.6	1,507.4	1.0	0.6
11/18/2020 09:00	6.9	13.7	5.7	90.5	2,954,239.7	1,510.1	1.0	0.6
11/18/2020 10:00	7.0	13.7	5.7	94.7	3,076,705.3	1,572.7	1.0	0.6
11/18/2020 11:00	7.3	13.8	6.1	102.1	3,306,964.3	1,690.4	1.0	0.7
11/18/2020 12:00	7.2	13.8	6.0	101.2	3,263,729.6	1,668.3	1.0	0.7
11/18/2020 13:00	7.0	13.8	5.8	95.7	3,090,595.2	1,579.8	1.0	0.6
11/18/2020 14:00	7.1	13.8	5.9	91.6	2,952,283.3	1,509.1	1.0	0.6
11/18/2020 15:00	7.3	13.7	6.0	101.9	3,305,986.1	1,689.9	1.0	0.7
11/18/2020 16:00	8.3	13.2	6.4	116.0	3,391,893.0	1,981.5	1.1	0.8
11/18/2020 17:00	8.1	13.1	6.1	120.6	3,388,490.3	2,029.0	1.1	0.8
11/18/2020 18:00	8.0	13.1	6.1	127.0	3,389,651.4	2,079.2	1.2	1.0
11/18/2020 19:00	8.0	13.3	6.2	121.9	3,354,918.6	1,959.9	1.2	1.0
11/18/2020 20:00	7.8	13.3	6.1	113.7	3,378,089.0	1,924.1	1.1	0.8
11/18/2020 21:00	7.8	13.3	6.1	113.7	3,413,245.8	1,919.2	1.1	0.8
11/18/2020 22:00	7.7	13.3	6.0	113.2	3,429,252.1	1,928.2	1.1	0.8
11/18/2020 23:00	7.6	13.3	5.9	110.9	3,428,362.8	1,927.7	1.0	0.8
Average/Sum#:	7.6	13.4	6.0	108.3	3,203,498.8	1,781.8	1.1	0.8
Minimum:	6.7	13.1	5.5	83.7	2,535,391.4	1,296.0	1.0	0.5
Maximum:	8.4	13.8	6.4	141.3	3,429,252.1	2,088.9	1.4	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/19/2020 00:00	7.1	13.4	5.6	107.6	3,395,283.2	1,909.1	1.0	0.8
11/19/2020 01:00	6.6	13.7	5.4	90.8	2,979,084.9	1,522.8	1.0	0.6
11/19/2020 02:00	6.9	13.8	5.7	83.1	2,680,941.7	1,370.4	1.0	0.5
11/19/2020 03:00	7.3	13.8	6.1	83.7	2,538,717.2	1,297.7	1.0	0.5
11/19/2020 04:00	7.4	13.8	6.1	83.8	2,533,239.5	1,294.9	1.0	0.5
11/19/2020 05:00	7.3	13.7	6.0	94.7	2,988,238.3	1,549.3	1.0	0.6
11/19/2020 06:00	7.9	13.3	6.1	119.2	3,461,350.1	1,996.8	1.1	0.8
11/19/2020 07:00	7.6	13.4	6.0	112.1	3,436,904.1	1,957.6	1.0	0.8
11/19/2020 08:00	6.7	13.7	5.5	95.7	3,133,438.6	1,601.7	1.0	0.6
11/19/2020 09:00	6.8	13.7	5.6	98.5	3,253,165.4	1,662.9	1.0	0.7
11/19/2020 10:00	7.0	13.7	5.7	101.0	3,308,138.0	1,691.0	1.0	0.7
11/19/2020 11:00	6.8	13.8	5.7	95.2	3,107,419.6	1,588.4	1.0	0.6
11/19/2020 12:00	7.1	13.8	5.9	101.7	3,316,550.2	1,695.3	1.0	0.7
11/19/2020 13:00	7.0	13.8	5.8	99.2	3,208,561.3	1,640.1	1.0	0.7
11/19/2020 14:00	7.0	13.8	5.8	100.5	3,274,098.1	1,673.6	1.0	0.7
11/19/2020 15:00	7.3	13.9	6.2	84.3	2,606,272.6	1,313.2	1.0	0.5
11/19/2020 16:00	6.8	13.8	5.7	94.7	3,110,940.9	1,590.2	1.0	0.6
11/19/2020 17:00	7.1	13.8	5.9	102.3	3,350,590.2	1,712.7	1.0	0.7
11/19/2020 18:00	8.5	13.2	6.5	126.2	3,403,186.6	2,037.8	1.2	1.0
11/19/2020 19:00	8.3	13.2	6.4	139.1	3,386,344.8	2,101.9	1.3	1.1
11/19/2020 20:00	8.1	13.2	6.2	132.9	3,409,536.7	2,066.5	1.3	1.0
11/19/2020 21:00	7.7	13.3	6.0	124.7	3,409,524.4	1,991.8	1.2	1.0
11/19/2020 22:00	7.9	13.2	6.1	127.3	3,396,840.5	2,034.0	1.2	1.0
11/19/2020 23:00	7.5	13.4	5.9	116.8	3,420,927.5	1,948.5	1.1	0.8
Average/Sum#:	7.3	13.6	5.9	104.8	3,171,220.6	1,718.7	1.1	0.7
Minimum:	6.6	13.2	5.4	83.1	2,533,239.5	1,294.9	1.0	0.5
Maximum:	8.5	13.9	6.5	139.1	3,461,350.1	2,101.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/20/2020 00:00	8.0	13.3	6.2	126.6	3,433,028.6	2,030.6	1.2	1.0
11/20/2020 01:00	7.3	13.4	5.7	111.5	3,408,799.6	1,916.7	1.1	0.8
11/20/2020 02:00	6.3	13.8	5.2	94.4	3,101,159.3	1,585.2	1.0	0.6
11/20/2020 03:00	6.5	13.8	5.4	95.0	3,098,420.5	1,583.8	1.0	0.6
11/20/2020 04:00	7.3	13.7	6.0	104.1	3,324,229.5	1,723.5	1.0	0.7
11/20/2020 05:00	8.3	13.2	6.4	128.9	3,434,416.2	2,056.5	1.2	1.0
11/20/2020 06:00	8.1	13.2	6.2	136.4	3,425,517.3	2,101.2	1.3	1.1
11/20/2020 07:00	8.4	13.2	6.4	137.6	3,414,816.4	2,069.7	1.3	1.0
11/20/2020 08:00	8.0	13.3	6.2	129.9	3,400,399.1	2,011.3	1.2	1.0
11/20/2020 09:00	7.9	13.3	6.1	127.0	3,361,081.0	1,963.5	1.2	1.0
11/20/2020 10:00	6.5	13.8	5.4	98.6	3,239,275.6	1,655.8	1.0	0.7
11/20/2020 11:00	6.8	13.8	5.7	95.5	3,138,958.8	1,581.6	1.0	0.6
11/20/2020 12:00	6.8	13.8	5.7	97.9	3,257,443.8	1,641.3	1.0	0.7
11/20/2020 13:00	6.7	13.8	5.6	90.7	2,980,383.5	1,501.7	1.0	0.6
11/20/2020 14:00	6.9	13.8	5.7	93.0	3,055,205.6	1,539.4	1.0	0.6
11/20/2020 15:00	8.2	13.5	6.5	112.0	3,361,751.8	1,816.6	1.1	0.7
11/20/2020 16:00	8.2	13.2	6.3	125.2	3,440,261.3	2,060.0	1.2	1.0
11/20/2020 17:00	8.1	13.1	6.1	131.8	3,434,157.7	2,106.5	1.2	1.1
11/20/2020 18:00	8.0	13.0	6.0	134.6	3,418,566.6	2,121.9	1.3	1.1
11/20/2020 19:00	8.0	13.0	6.0	133.9	3,410,833.4	2,117.1	1.3	1.1
11/20/2020 20:00	8.0	13.0	6.0	133.0	3,417,438.8	2,121.2	1.3	1.1
11/20/2020 21:00	7.9	13.1	6.0	131.7	3,441,004.8	2,110.7	1.2	1.1
11/20/2020 22:00	8.1	13.1	6.1	140.1	3,394,542.2	2,082.2	1.3	1.0
11/20/2020 23:00	8.0	13.2	6.1	134.9	3,403,854.6	2,038.2	1.3	1.0
Average/Sum#:	7.6	13.4	6.0	118.5	3,324,814.4	1,897.3	1.2	0.9
Minimum:	6.3	13.0	5.2	90.7	2,980,383.5	1,501.7	1.0	0.6
Maximum:	8.4	13.8	6.5	140.1	3,441,004.8	2,121.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/21/2020 00:00	7.9	13.2	6.1	132.3	3,384,649.3	2,026.7	1.3	1.0
11/21/2020 01:00	7.8	13.4	6.1	119.4	3,393,187.8	1,932.7	1.1	0.8
11/21/2020 02:00	7.8	13.4	6.1	118.2	3,381,766.8	1,901.5	1.1	0.8
11/21/2020 03:00	6.4	13.8	5.3	102.1	3,420,430.8	1,748.4	1.0	0.7
11/21/2020 04:00	7.2	13.5	5.7	109.7	3,343,038.8	1,830.9	1.1	0.7
11/21/2020 05:00	8.2	13.2	6.3	137.0	3,402,607.1	2,062.3	1.3	1.0
11/21/2020 06:00	8.1	13.1	6.1	140.3	3,403,997.8	2,088.0	1.3	1.0
11/21/2020 07:00	6.7	13.7	5.5	105.0	3,068,081.2	1,613.1	1.1	0.6
11/21/2020 08:00	6.8	13.8	5.7	101.0	3,139,307.6	1,604.7	1.0	0.6
11/21/2020 09:00	6.8	13.8	5.7	101.6	3,151,828.0	1,611.1	1.0	0.6
11/21/2020 10:00	6.8	13.8	5.7	93.3	2,915,484.7	1,469.0	1.0	0.6
11/21/2020 11:00	6.9	13.8	5.7	104.6	3,307,060.7	1,666.3	1.0	0.7
11/21/2020 12:00	6.9	13.8	5.7	105.1	3,305,869.8	1,665.7	1.0	0.7
11/21/2020 13:00	6.8	13.9	5.7	105.8	3,345,166.4	1,685.5	1.0	0.7
11/21/2020 14:00	6.9	13.8	5.7	101.3	3,161,187.2	1,592.8	1.0	0.6
11/21/2020 15:00	7.8	13.5	6.2	113.8	3,350,890.2	1,835.2	1.1	0.7
11/21/2020 16:00	8.2	13.2	6.3	123.5	3,393,532.6	2,056.8	1.2	1.0
11/21/2020 17:00	8.0	13.1	6.1	127.4	3,397,639.7	2,084.1	1.2	1.0
11/21/2020 18:00	8.0	13.1	6.1	131.2	3,401,166.8	2,111.1	1.3	1.1
11/21/2020 19:00	7.9	13.1	6.0	129.0	3,382,961.6	2,099.8	1.2	1.0
11/21/2020 20:00	7.8	13.2	6.0	128.1	3,344,330.0	2,051.4	1.2	1.0
11/21/2020 21:00	6.6	13.7	5.4	100.0	3,280,358.3	1,676.8	1.0	0.7
11/21/2020 22:00	7.5	13.5	6.0	110.4	3,316,928.4	1,816.6	1.1	0.7
11/21/2020 23:00	8.1	13.2	6.2	129.4	3,390,892.8	2,055.2	1.2	1.0
Average/Sum#:	7.4	13.5	5.9	115.4	3,307,598.5	1,845.2	1.1	0.8
Minimum:	6.4	13.1	5.3	93.3	2,915,484.7	1,469.0	1.0	0.6
Maximum:	8.2	13.9	6.3	140.3	3,420,430.8	2,111.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/22/2020 00:00	7.9	13.2	6.1	127.6	3,394,836.4	2,032.8	1.2	1.0
11/22/2020 01:00	6.7	13.5	5.3	106.9	3,239,950.0	1,798.1	1.1	0.7
11/22/2020 02:00	6.9	13.8	5.7	82.3	2,538,325.9	1,297.5	1.0	0.5
11/22/2020 03:00	6.9	13.8	5.7	83.4	2,649,640.6	1,354.4	1.0	0.5
11/22/2020 04:00	6.6	13.7	5.4	95.9	3,158,283.9	1,614.4	1.0	0.6
11/22/2020 05:00	7.4	13.5	5.9	107.6	3,388,029.9	1,830.8	1.0	0.7
11/22/2020 06:00	7.6	13.4	6.0	113.7	3,450,579.3	1,864.6	1.1	0.7
11/22/2020 07:00	7.0	13.7	5.7	93.5	2,955,609.1	1,510.8	1.0	0.6
11/22/2020 08:00	6.9	13.7	5.7	100.0	3,266,468.4	1,669.7	1.0	0.7
11/22/2020 09:00	7.1	13.7	5.8	102.2	3,297,769.5	1,685.7	1.0	0.7
11/22/2020 10:00	6.8	13.8	5.7	97.3	3,157,892.6	1,614.2	1.0	0.6
11/22/2020 11:00	7.0	13.8	5.8	100.7	3,262,751.4	1,667.8	1.0	0.7
11/22/2020 12:00	7.0	13.8	5.8	99.6	3,199,757.9	1,635.6	1.0	0.7
11/22/2020 13:00	7.1	13.8	5.9	99.3	3,187,041.8	1,629.1	1.0	0.7
11/22/2020 14:00	7.1	13.8	5.9	101.9	3,300,312.8	1,687.0	1.0	0.7
11/22/2020 15:00	8.0	13.5	6.4	110.7	3,321,493.2	1,819.1	1.1	0.7
11/22/2020 16:00	8.4	13.2	6.4	134.1	3,361,447.8	2,061.9	1.3	1.0
11/22/2020 17:00	8.1	13.1	6.1	136.5	3,344,939.9	2,076.2	1.3	1.0
11/22/2020 18:00	8.0	13.2	6.1	135.1	3,359,980.5	2,061.0	1.3	1.0
11/22/2020 19:00	7.8	13.2	6.0	129.9	3,323,081.5	2,014.1	1.3	1.0
11/22/2020 20:00	6.5	13.7	5.3	99.4	3,287,596.7	1,680.5	1.0	0.7
11/22/2020 21:00	7.5	13.5	6.0	111.1	3,313,466.4	1,838.9	1.1	0.7
11/22/2020 22:00	8.1	13.2	6.2	126.7	3,365,034.4	2,064.1	1.2	1.0
11/22/2020 23:00	6.9	13.5	5.5	107.9	3,342,296.4	1,854.9	1.0	0.7
Average/Sum#:	7.3	13.5	5.9	108.5	3,227,774.4	1,765.1	1.1	0.7
Minimum:	6.5	13.1	5.3	82.3	2,538,325.9	1,297.5	1.0	0.5
Maximum:	8.4	13.8	6.4	136.5	3,450,579.3	2,076.2	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/23/2020 00:00	7.1	13.6	5.7	102.1	3,226,706.2	1,696.5	1.0	0.7
11/23/2020 01:00	7.0	13.4	5.5	110.6	3,371,210.8	1,944.8	1.1	0.8
11/23/2020 02:00	10.5	14.4	9.5	107.3	2,567,776.1	1,218.8	1.3	0.6
11/23/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/23/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/23/2020 05:00	35.4	17.1	55.0	227.7	1,907,303.9	501.4	3.2	0.6
11/23/2020 06:00	24.6	14.4	22.3	168.2	2,503,906.9	1,170.2	2.1	0.9
11/23/2020 07:00	7.2	13.7	5.9	99.2	3,316,159.0	1,695.1	0.9	0.5
11/23/2020 08:00	7.0	13.7	5.7	97.8	3,172,760.7	1,621.8	1.0	0.6
11/23/2020 09:00	7.0	13.8	5.8	98.9	3,231,254.6	1,651.7	1.0	0.7
11/23/2020 10:00	7.0	13.8	5.8	96.9	3,089,421.4	1,579.2	1.0	0.6
11/23/2020 11:00	7.0	13.8	5.8	100.2	3,249,057.2	1,660.8	1.0	0.7
11/23/2020 12:00	7.1	13.8	5.9	101.1	3,290,335.5	1,681.9	1.0	0.7
11/23/2020 13:00	7.0	13.8	5.8	98.6	3,196,823.4	1,634.1	1.0	0.7
11/23/2020 14:00	7.1	13.8	5.9	101.0	3,288,183.6	1,680.8	1.0	0.7
11/23/2020 15:00	8.1	13.6	6.5	108.2	3,326,940.5	1,749.2	1.0	0.7
11/23/2020 16:00	8.4	13.2	6.4	131.0	3,385,613.1	2,052.0	1.3	1.0
11/23/2020 17:00	8.0	13.1	6.1	125.4	3,378,076.5	2,072.1	1.2	1.0
11/23/2020 18:00	7.9	13.1	6.0	125.1	3,389,814.4	2,079.3	1.2	1.0
11/23/2020 19:00	7.8	13.3	6.1	121.6	3,327,530.1	1,943.9	1.2	1.0
11/23/2020 20:00	6.5	13.8	5.4	98.0	3,244,362.0	1,658.4	1.0	0.7
11/23/2020 21:00	7.1	13.6	5.7	100.4	3,207,686.4	1,686.5	1.0	0.7
11/23/2020 22:00	8.2	13.2	6.3	128.4	3,355,924.8	2,009.5	1.2	1.0
11/23/2020 23:00	7.2	13.3	5.6	114.8	3,384,385.0	1,952.4	1.1	0.8
Average/Sum#:	9.6	13.8	9.0	116.5	3,155,056.0	1,679.1	1.2	0.8
Minimum:	6.5	13.1	5.4	96.9	1,907,303.9	501.4	0.9	0.5
Maximum:	35.4	17.1	55.0	227.7	3,389,814.4	2,079.3	3.2	1.0
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/24/2020 00:00	7.0	13.4	5.5	109.7	3,337,061.9	1,925.1	1.1	0.8
11/24/2020 01:00	6.5	13.8	5.4	92.0	3,038,752.7	1,553.3	1.0	0.6
11/24/2020 02:00	6.6	13.8	5.5	92.4	3,047,947.4	1,558.0	1.0	0.6
11/24/2020 03:00	6.8	13.8	5.7	94.5	3,081,204.9	1,575.0	1.0	0.6
11/24/2020 04:00	7.8	13.5	6.2	109.1	3,310,720.4	1,813.2	1.0	0.7
11/24/2020 05:00	8.4	13.2	6.4	132.4	3,397,987.4	2,059.5	1.3	1.0
11/24/2020 06:00	8.4	13.0	6.3	156.9	3,386,991.1	2,176.5	1.5	1.3
11/24/2020 07:00	8.4	13.1	6.4	134.6	3,398,428.0	2,109.4	1.3	1.1
11/24/2020 08:00	7.7	13.4	6.1	116.2	3,311,872.8	1,862.2	1.1	0.7
11/24/2020 09:00	6.7	13.8	5.6	101.2	3,292,487.5	1,683.0	1.0	0.7
11/24/2020 10:00	6.8	13.8	5.7	100.1	3,252,187.3	1,662.4	1.0	0.7
11/24/2020 11:00	6.9	13.8	5.7	101.0	3,265,685.9	1,669.3	1.0	0.7
11/24/2020 12:00	7.0	13.8	5.8	100.5	3,287,809.3	1,656.6	1.0	0.7
11/24/2020 13:00	6.9	13.8	5.7	101.0	3,309,442.3	1,667.5	1.0	0.7
11/24/2020 14:00	6.9	13.8	5.7	96.6	3,148,088.3	1,586.2	1.0	0.6
11/24/2020 15:00	7.4	13.7	6.1	95.3	3,019,870.1	1,565.7	1.0	0.6
11/24/2020 16:00	8.6	13.1	6.5	134.6	3,379,543.7	2,073.0	1.3	1.0
11/24/2020 17:00	8.1	13.1	6.1	131.1	3,377,860.4	2,121.3	1.3	1.1
11/24/2020 18:00	8.1	13.0	6.0	136.3	3,374,293.2	2,143.7	1.3	1.1
11/24/2020 19:00	8.2	13.1	6.2	143.6	3,365,635.9	2,138.2	1.4	1.1
11/24/2020 20:00	8.1	13.0	6.0	141.3	3,378,543.1	2,146.4	1.4	1.1
11/24/2020 21:00	8.0	13.1	6.1	135.9	3,419,372.1	2,122.4	1.3	1.1
11/24/2020 22:00	7.9	13.1	6.0	131.6	3,398,589.1	2,109.5	1.3	1.1
11/24/2020 23:00	7.8	13.2	6.0	125.5	3,452,285.5	2,067.2	1.2	1.0
Average/Sum#:	7.5	13.4	5.9	117.2	3,293,027.5	1,876.9	1.2	0.9
Minimum:	6.5	13.0	5.4	92.0	3,019,870.1	1,553.3	1.0	0.6
Maximum:	8.6	13.8	6.5	156.9	3,452,285.5	2,176.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/25/2020 00:00	7.9	13.2	6.1	124.8	3,415,311.4	2,070.0	1.2	1.0
11/25/2020 01:00	7.1	13.4	5.6	112.2	3,398,630.4	1,935.8	1.1	0.8
11/25/2020 02:00	6.5	13.7	5.3	92.8	3,054,403.3	1,561.3	1.0	0.6
11/25/2020 03:00	7.0	13.7	5.7	83.2	2,687,006.3	1,373.5	1.0	0.5
11/25/2020 04:00	7.2	13.7	5.9	94.4	3,048,338.7	1,558.2	1.0	0.6
11/25/2020 05:00	8.3	13.2	6.4	117.4	3,438,111.1	2,008.5	1.1	0.8
11/25/2020 06:00	7.6	13.3	5.9	119.8	3,459,443.3	1,995.7	1.1	0.8
11/25/2020 07:00	7.9	13.3	6.1	122.6	3,401,479.0	1,987.1	1.2	1.0
11/25/2020 08:00	6.7	13.7	5.5	99.4	3,222,969.2	1,671.0	1.0	0.7
11/25/2020 09:00	6.8	13.7	5.6	97.1	3,193,888.9	1,632.6	1.0	0.7
11/25/2020 10:00	6.9	13.7	5.7	100.7	3,313,224.5	1,693.6	1.0	0.7
11/25/2020 11:00	7.1	13.8	5.9	101.8	3,315,572.1	1,694.8	1.0	0.7
11/25/2020 12:00	7.0	13.8	5.8	101.3	3,314,985.2	1,694.5	1.0	0.7
11/25/2020 13:00	7.0	13.8	5.8	100.3	3,284,270.9	1,678.8	1.0	0.7
11/25/2020 14:00	6.9	13.8	5.7	98.6	3,268,359.5	1,646.8	1.0	0.7
11/25/2020 15:00	7.2	13.9	6.1	84.5	2,673,354.6	1,347.0	1.0	0.5
11/25/2020 16:00	7.0	13.8	5.8	97.6	3,188,411.2	1,629.8	1.0	0.7
11/25/2020 17:00	6.7	13.8	5.6	95.7	3,137,351.3	1,603.7	1.0	0.6
11/25/2020 18:00	7.0	13.8	5.8	100.9	3,300,508.4	1,687.1	1.0	0.7
11/25/2020 19:00	7.8	13.5	6.2	111.5	3,374,444.3	1,848.1	1.1	0.7
11/25/2020 20:00	8.0	13.4	6.3	124.7	3,319,034.0	1,914.7	1.2	1.0
11/25/2020 21:00	7.2	13.6	5.8	105.4	3,402,258.8	1,788.8	1.0	0.7
11/25/2020 22:00	8.2	13.2	6.3	127.7	3,424,575.3	2,025.6	1.2	1.0
11/25/2020 23:00	14.5	14.7	13.8	137.4	2,600,010.2	1,234.1	1.6	0.7
Average/Sum#:	7.6	13.6	6.2	106.3	3,218,164.2	1,720.0	1.1	0.7
Minimum:	6.5	13.2	5.3	83.2	2,600,010.2	1,234.1	1.0	0.5
Maximum:	14.5	14.7	13.8	137.4	3,459,443.3	2,070.0	1.6	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2020 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2020 04:00	36.0	17.3	59.0	50.4	1,924,444.0	477.8	0.8	0.1
11/27/2020 05:00	27.1	14.7	25.8	194.7	2,452,410.8	1,074.5	2.5	1.1
11/27/2020 06:00	6.1	13.8	5.1	97.6	3,334,744.0	1,704.6	0.9	0.5
11/27/2020 07:00	6.7	13.8	5.6	95.4	3,149,284.8	1,609.8	1.0	0.6
11/27/2020 08:00	6.6	13.8	5.5	94.1	3,162,392.2	1,616.5	0.9	0.5
11/27/2020 09:00	6.9	13.8	5.7	101.2	3,315,767.7	1,694.9	1.0	0.7
11/27/2020 10:00	6.9	13.8	5.7	100.8	3,300,312.8	1,687.0	1.0	0.7
11/27/2020 11:00	6.8	13.8	5.7	101.1	3,331,613.9	1,703.0	1.0	0.7
11/27/2020 12:00	6.8	13.8	5.7	100.5	3,348,540.3	1,687.2	1.0	0.7
11/27/2020 13:00	6.8	13.8	5.7	96.6	3,203,063.8	1,613.9	1.0	0.6
11/27/2020 14:00	6.9	13.8	5.7	98.9	3,287,412.4	1,656.4	1.0	0.7
11/27/2020 15:00	7.0	13.8	5.8	94.9	3,088,834.5	1,578.9	1.0	0.6
11/27/2020 16:00	8.4	13.3	6.5	121.6	3,422,705.1	1,999.5	1.1	0.8
11/27/2020 17:00	8.3	13.2	6.4	133.4	3,438,740.1	2,084.2	1.3	1.0
11/27/2020 18:00	8.1	13.2	6.2	128.3	3,420,220.9	2,048.0	1.2	1.0
11/27/2020 19:00	8.1	13.2	6.2	128.9	3,410,868.7	2,042.4	1.2	1.0
11/27/2020 20:00	7.5	13.3	5.8	119.3	3,391,208.3	1,981.1	1.1	0.8
11/27/2020 21:00	6.7	13.8	5.6	102.0	3,338,461.0	1,706.5	1.0	0.7
11/27/2020 22:00	7.4	13.5	5.9	109.3	3,410,236.8	1,842.8	1.0	0.7
11/27/2020 23:00	8.1	13.3	6.3	122.1	3,475,941.4	2,030.6	1.1	0.8
Average/Sum#:	9.7	13.8	9.5	109.6	3,210,360.2	1,692.0	1.1	0.7
Minimum:	6.1	13.2	5.1	50.4	1,924,444.0	477.8	0.8	0.1
Maximum:	36.0	17.3	59.0	194.7	3,475,941.4	2,084.2	2.5	1.1
%SI	16.67	16.67	16.67	16.67	16.67	16.67	16.67	16.67

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/28/2020 00:00	8.0	13.3	6.2	124.8	3,489,122.2	2,038.3	1.2	1.0
11/28/2020 01:00	7.0	13.5	5.6	110.2	3,453,795.0	1,942.0	1.0	0.8
11/28/2020 02:00	6.5	13.8	5.4	95.3	3,103,506.9	1,586.4	1.0	0.6
11/28/2020 03:00	7.1	13.5	5.7	107.2	3,381,367.9	1,827.2	1.0	0.7
11/28/2020 04:00	7.1	13.4	5.6	108.6	3,461,086.7	1,946.1	1.0	0.8
11/28/2020 05:00	7.6	13.4	6.0	115.1	3,452,178.4	1,966.3	1.1	0.8
11/28/2020 06:00	6.6	13.7	5.4	101.8	3,313,811.4	1,693.9	1.0	0.7
11/28/2020 07:00	6.9	13.7	5.7	98.9	3,214,625.9	1,643.2	1.0	0.7
11/28/2020 08:00	6.9	13.7	5.7	101.4	3,302,660.3	1,688.2	1.0	0.7
11/28/2020 09:00	6.8	13.8	5.7	93.4	3,044,034.8	1,556.0	1.0	0.6
11/28/2020 10:00	6.8	13.8	5.7	97.4	3,185,085.5	1,628.1	1.0	0.7
11/28/2020 11:00	7.1	13.8	5.9	101.9	3,314,789.5	1,694.4	1.0	0.7
11/28/2020 12:00	7.1	13.8	5.9	102.1	3,318,310.9	1,696.2	1.0	0.7
11/28/2020 13:00	6.7	13.8	5.6	92.7	3,069,693.8	1,546.7	1.0	0.6
11/28/2020 14:00	6.9	13.8	5.7	97.3	3,228,467.6	1,626.7	1.0	0.7
11/28/2020 15:00	7.6	13.6	6.1	103.8	3,230,320.0	1,698.4	1.0	0.7
11/28/2020 16:00	8.6	13.3	6.7	131.8	3,374,128.1	2,020.4	1.3	1.0
11/28/2020 17:00	8.3	13.2	6.4	139.9	3,380,032.8	2,073.3	1.3	1.0
11/28/2020 18:00	8.2	13.2	6.3	143.4	3,391,983.6	2,105.4	1.4	1.1
11/28/2020 19:00	8.0	13.2	6.1	139.8	3,390,855.9	2,104.7	1.3	1.1
11/28/2020 20:00	8.1	13.1	6.1	149.2	3,387,043.0	2,151.8	1.4	1.1
11/28/2020 21:00	6.9	13.5	5.5	111.7	3,254,184.8	1,806.0	1.1	0.7
11/28/2020 22:00	7.2	13.5	5.7	109.2	3,405,980.5	1,840.5	1.0	0.7
11/28/2020 23:00	7.9	13.3	6.1	122.3	3,462,276.8	2,047.9	1.1	0.8
Average/Sum#:	7.3	13.5	5.9	112.5	3,317,055.9	1,830.3	1.1	0.8
Minimum:	6.5	13.1	5.4	92.7	3,044,034.8	1,546.7	1.0	0.6
Maximum:	8.6	13.8	6.7	149.2	3,489,122.2	2,151.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/29/2020 00:00	6.8	13.4	5.3	108.2	3,439,745.1	1,934.1	1.0	0.8
11/29/2020 01:00	6.4	13.8	5.3	93.8	3,071,032.0	1,569.8	1.0	0.6
11/29/2020 02:00	7.5	13.5	6.0	111.2	3,387,043.0	1,855.0	1.0	0.7
11/29/2020 03:00	7.8	13.3	6.1	122.9	3,450,442.3	2,040.9	1.1	0.8
11/29/2020 04:00	7.6	13.3	5.9	124.2	3,423,391.9	2,024.9	1.2	1.0
11/29/2020 05:00	6.4	13.7	5.2	101.2	3,337,678.5	1,706.1	1.0	0.7
11/29/2020 06:00	6.4	13.7	5.2	99.1	3,296,791.4	1,685.2	1.0	0.7
11/29/2020 07:00	6.8	13.7	5.6	96.8	3,148,502.3	1,609.4	1.0	0.6
11/29/2020 08:00	6.6	13.7	5.4	97.0	3,208,561.3	1,640.1	1.0	0.7
11/29/2020 09:00	6.5	13.7	5.3	94.3	3,105,854.5	1,587.6	1.0	0.6
11/29/2020 10:00	6.9	13.7	5.7	100.7	3,307,746.8	1,690.8	1.0	0.7
11/29/2020 11:00	6.9	13.8	5.7	100.2	3,266,859.7	1,669.9	1.0	0.7
11/29/2020 12:00	6.9	13.8	5.7	100.8	3,291,509.3	1,682.5	1.0	0.7
11/29/2020 13:00	6.9	13.8	5.7	100.7	3,284,662.2	1,679.0	1.0	0.7
11/29/2020 14:00	6.8	13.8	5.7	99.0	3,247,492.1	1,660.0	1.0	0.7
11/29/2020 15:00	6.9	13.8	5.7	100.8	3,282,119.0	1,677.7	1.0	0.7
11/29/2020 16:00	7.6	13.5	6.1	110.1	3,342,125.9	1,830.4	1.1	0.7
11/29/2020 17:00	8.2	13.2	6.3	134.2	3,412,475.1	2,093.2	1.3	1.0
11/29/2020 18:00	8.1	13.1	6.1	145.6	3,391,922.5	2,154.9	1.4	1.1
11/29/2020 19:00	7.7	13.2	5.9	136.1	3,342,684.4	2,074.8	1.3	1.0
11/29/2020 20:00	6.4	13.8	5.3	99.3	3,314,398.3	1,694.2	1.0	0.7
11/29/2020 21:00	7.3	13.5	5.8	107.9	3,350,342.4	1,834.9	1.0	0.7
11/29/2020 22:00	8.0	13.2	6.1	130.9	3,431,386.2	2,104.8	1.2	1.1
11/29/2020 23:00	7.6	13.3	5.9	122.8	3,453,823.5	2,042.9	1.2	1.0
Average/Sum#:	7.1	13.6	5.7	109.9	3,316,191.2	1,814.3	1.1	0.8
Minimum:	6.4	13.1	5.2	93.8	3,071,032.0	1,569.8	1.0	0.6
Maximum:	8.2	13.8	6.3	145.6	3,453,823.5	2,154.9	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/30/2020 00:00	7.6	13.3	5.9	122.6	3,481,212.0	2,059.1	1.1	0.8
11/30/2020 01:00	7.5	13.3	5.8	122.5	3,424,068.2	2,025.3	1.2	1.0
11/30/2020 02:00	6.2	13.8	5.2	91.9	3,076,705.3	1,572.7	1.0	0.6
11/30/2020 03:00	6.4	13.8	5.3	90.4	3,024,080.3	1,545.8	1.0	0.6
11/30/2020 04:00	7.1	13.5	5.7	103.7	3,330,140.0	1,775.2	1.0	0.7
11/30/2020 05:00	8.0	13.2	6.1	125.7	3,512,406.5	2,103.2	1.2	1.1
11/30/2020 06:00	7.8	13.2	6.0	128.2	3,484,442.6	2,111.9	1.2	1.1
11/30/2020 07:00	8.1	13.2	6.2	128.1	3,462,498.8	2,098.6	1.2	1.0
11/30/2020 08:00	7.4	13.4	5.8	115.6	3,394,767.9	1,933.6	1.1	0.8
11/30/2020 09:00	6.5	13.8	5.4	98.7	3,263,338.3	1,668.1	1.0	0.7
11/30/2020 10:00	6.5	13.8	5.4	92.3	3,067,315.0	1,567.9	1.0	0.6
11/30/2020 11:00	6.7	13.8	5.6	96.7	3,203,474.9	1,637.5	1.0	0.7
11/30/2020 12:00	6.6	13.8	5.5	96.0	3,165,717.9	1,618.2	1.0	0.6
11/30/2020 13:00	6.8	13.8	5.7	85.0	2,818,831.1	1,420.3	1.0	0.6
11/30/2020 14:00	6.9	13.8	5.7	98.8	3,271,554.9	1,672.3	1.0	0.7
11/30/2020 15:00	7.4	13.7	6.1	101.5	3,226,135.6	1,696.2	1.0	0.7
11/30/2020 16:00	8.4	13.2	6.4	130.7	3,401,349.6	2,036.7	1.2	1.0
11/30/2020 17:00	8.1	13.1	6.1	140.0	3,362,096.1	2,111.4	1.4	1.1
11/30/2020 18:00	8.0	13.1	6.1	140.2	3,376,427.3	2,120.4	1.4	1.1
11/30/2020 19:00	8.0	13.1	6.1	147.4	3,367,694.7	2,164.1	1.4	1.1
11/30/2020 20:00	7.9	13.2	6.1	139.6	3,404,550.1	2,113.2	1.3	1.1
11/30/2020 21:00	7.9	13.2	6.1	136.8	3,392,628.1	2,105.8	1.3	1.1
11/30/2020 22:00	7.8	13.2	6.0	132.1	3,387,206.0	2,077.7	1.3	1.0
11/30/2020 23:00	7.8	13.3	6.1	125.9	3,410,204.8	2,017.1	1.2	1.0
Average/Sum#:	7.4	13.4	5.9	116.3	3,304,535.3	1,885.5	1.1	0.9
Minimum:	6.2	13.1	5.2	85.0	2,818,831.1	1,420.3	1.0	0.6
Maximum:	8.4	13.8	6.4	147.4	3,512,406.5	2,164.1	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/01/2020 00:00	7.8	13.2	6.0	124.9	3,410,033.7	2,041.9	1.2	1.0
12/01/2020 01:00	7.7	13.2	5.9	128.4	3,343,375.4	2,026.4	1.3	1.0
12/01/2020 02:00	6.3	13.8	5.2	91.8	3,055,968.3	1,562.1	1.0	0.6
12/01/2020 03:00	7.3	13.5	5.8	109.2	3,358,741.5	1,839.5	1.0	0.7
12/01/2020 04:00	8.1	13.2	6.2	133.2	3,419,159.2	2,097.3	1.3	1.0
12/01/2020 05:00	8.0	13.1	6.1	147.1	3,405,931.6	2,163.8	1.4	1.1
12/01/2020 06:00	8.0	13.0	6.0	151.2	3,381,401.2	2,197.6	1.5	1.3
12/01/2020 07:00	8.3	13.1	6.3	139.5	3,405,567.4	2,138.7	1.3	1.1
12/01/2020 08:00	8.0	13.2	6.1	135.8	3,401,552.4	2,086.5	1.3	1.0
12/01/2020 09:00	6.7	13.7	5.5	103.3	3,255,426.1	1,711.6	1.0	0.7
12/01/2020 10:00	6.7	13.8	5.6	102.1	3,370,371.7	1,698.2	1.0	0.7
12/01/2020 11:00	6.7	13.8	5.6	100.2	3,305,076.0	1,665.3	1.0	0.7
12/01/2020 12:00	6.8	13.8	5.7	101.6	3,325,319.6	1,675.5	1.0	0.7
12/01/2020 13:00	6.9	13.9	5.8	88.1	2,775,763.7	1,398.6	1.0	0.6
12/01/2020 14:00	6.9	13.8	5.7	97.1	3,182,423.2	1,603.5	1.0	0.6
12/01/2020 15:00	7.5	13.8	6.2	96.2	3,027,014.8	1,547.3	1.0	0.6
12/01/2020 16:00	8.8	13.3	6.8	133.3	3,380,280.4	1,999.4	1.3	1.0
12/01/2020 17:00	8.6	13.1	6.5	155.8	3,337,460.4	2,120.3	1.5	1.3
12/01/2020 18:00	8.4	13.1	6.4	159.9	3,355,867.8	2,156.5	1.6	1.3
12/01/2020 19:00	8.4	13.1	6.4	162.8	3,350,265.6	2,152.9	1.6	1.3
12/01/2020 20:00	8.1	13.1	6.1	155.3	3,368,005.9	2,164.3	1.5	1.3
12/01/2020 21:00	7.9	13.1	6.0	147.9	3,370,184.5	2,165.7	1.4	1.1
12/01/2020 22:00	8.0	13.1	6.1	148.8	3,404,042.7	2,162.6	1.4	1.1
12/01/2020 23:00	7.7	13.1	5.8	134.6	3,419,694.3	2,122.6	1.3	1.1
Average/Sum#:	7.7	13.4	6.0	127.0	3,308,705.3	1,937.4	1.2	1.0
Minimum:	6.3	13.0	5.2	88.1	2,775,763.7	1,398.6	1.0	0.6
Maximum:	8.8	13.9	6.8	162.8	3,419,694.3	2,197.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/02/2020 00:00	7.7	13.2	5.9	129.6	3,467,448.5	2,101.6	1.2	1.1
12/02/2020 01:00	7.3	13.3	5.7	116.7	3,396,172.5	1,984.0	1.1	0.8
12/02/2020 02:00	6.3	13.8	5.2	92.0	3,073,966.5	1,571.3	1.0	0.6
12/02/2020 03:00	7.5	13.5	6.0	111.0	3,373,531.3	1,847.6	1.1	0.7
12/02/2020 04:00	8.2	13.2	6.3	133.5	3,419,931.2	2,072.8	1.3	1.0
12/02/2020 05:00	7.9	13.2	6.1	131.7	3,448,969.6	2,090.4	1.2	1.0
12/02/2020 06:00	7.9	13.2	6.1	138.2	3,411,316.7	2,117.4	1.3	1.1
12/02/2020 07:00	8.5	13.1	6.4	136.3	3,428,125.7	2,102.8	1.3	1.1
12/02/2020 08:00	8.0	13.2	6.1	126.8	3,416,713.8	2,045.9	1.2	1.0
12/02/2020 09:00	6.5	13.8	5.4	96.4	3,102,333.1	1,585.8	1.0	0.6
12/02/2020 10:00	6.7	13.8	5.6	99.6	3,260,795.1	1,666.8	1.0	0.7
12/02/2020 11:00	6.8	13.8	5.7	102.1	3,373,745.7	1,699.9	1.0	0.7
12/02/2020 12:00	6.8	13.8	5.7	100.1	3,280,466.0	1,652.9	1.0	0.7
12/02/2020 13:00	6.8	13.8	5.7	93.3	3,073,266.2	1,548.5	1.0	0.6
12/02/2020 14:00	7.1	13.8	5.9	96.2	3,142,729.7	1,583.5	1.0	0.6
12/02/2020 15:00	8.3	13.5	6.6	114.9	3,360,750.0	1,840.6	1.1	0.7
12/02/2020 16:00	8.5	13.1	6.4	129.2	3,432,690.5	2,105.6	1.2	1.1
12/02/2020 17:00	8.2	13.1	6.2	137.6	3,396,172.5	2,157.6	1.3	1.1
12/02/2020 18:00	8.1	13.0	6.0	142.2	3,403,175.2	2,186.9	1.4	1.1
12/02/2020 19:00	8.1	13.0	6.0	143.8	3,400,841.0	2,185.4	1.4	1.1
12/02/2020 20:00	8.3	13.1	6.3	151.7	3,382,637.5	2,124.3	1.5	1.3
12/02/2020 21:00	8.1	13.2	6.2	143.3	3,398,911.3	2,109.7	1.4	1.1
12/02/2020 22:00	8.0	13.2	6.1	136.6	3,424,213.1	2,100.4	1.3	1.1
12/02/2020 23:00	8.0	13.2	6.1	136.0	3,419,159.2	2,097.3	1.3	1.0
Average/Sum#:	7.7	13.4	6.0	122.5	3,345,335.9	1,940.8	1.2	0.9
Minimum:	6.3	13.0	5.2	92.0	3,073,266.2	1,548.5	1.0	0.6
Maximum:	8.5	13.8	6.6	151.7	3,467,448.5	2,186.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/03/2020 00:00	7.9	13.2	6.1	134.9	3,438,575.1	2,084.1	1.3	1.0
12/03/2020 01:00	7.9	13.2	6.1	131.8	3,440,885.0	2,085.5	1.2	1.0
12/03/2020 02:00	7.7	13.3	6.0	127.3	3,375,130.1	2,021.0	1.2	1.0
12/03/2020 03:00	6.3	13.8	5.2	93.9	3,131,677.9	1,600.8	1.0	0.6
12/03/2020 04:00	7.3	13.5	5.8	108.9	3,420,229.9	1,848.2	1.0	0.7
12/03/2020 05:00	8.2	13.2	6.3	135.3	3,467,252.1	2,126.8	1.3	1.1
12/03/2020 06:00	8.2	13.0	6.1	149.0	3,445,658.5	2,214.2	1.4	1.1
12/03/2020 07:00	8.3	13.2	6.4	132.4	3,432,364.4	2,105.4	1.2	1.1
12/03/2020 08:00	8.0	13.2	6.1	128.9	3,462,472.7	2,073.3	1.2	1.0
12/03/2020 09:00	7.3	13.4	5.7	115.6	3,411,773.5	1,968.2	1.1	0.8
12/03/2020 10:00	6.6	13.8	5.5	102.3	3,319,289.1	1,696.7	1.0	0.7
12/03/2020 11:00	6.7	13.8	5.6	100.1	3,218,147.3	1,645.0	1.0	0.7
12/03/2020 12:00	6.9	13.8	5.7	102.8	3,283,292.8	1,678.3	1.0	0.7
12/03/2020 13:00	6.9	13.8	5.7	103.0	3,280,749.6	1,677.0	1.0	0.7
12/03/2020 14:00	7.5	13.5	6.0	109.6	3,393,211.6	1,833.6	1.0	0.7
12/03/2020 15:00	8.1	13.2	6.2	122.1	3,405,247.0	2,063.9	1.2	1.0
12/03/2020 16:00	8.0	13.1	6.1	131.1	3,397,924.1	2,133.9	1.3	1.1
12/03/2020 17:00	8.0	13.1	6.1	142.8	3,374,074.9	2,168.2	1.4	1.1
12/03/2020 18:00	8.2	13.1	6.2	156.4	3,356,320.7	2,181.3	1.5	1.3
12/03/2020 19:00	8.1	13.1	6.1	153.0	3,356,782.3	2,181.6	1.5	1.3
12/03/2020 20:00	7.9	13.1	6.0	144.1	3,387,733.0	2,127.5	1.4	1.1
12/03/2020 21:00	8.0	13.1	6.1	148.3	3,386,728.2	2,151.6	1.4	1.1
12/03/2020 22:00	8.0	13.1	6.1	145.3	3,396,650.2	2,133.1	1.4	1.1
12/03/2020 23:00	7.7	13.2	5.9	134.4	3,433,016.5	2,105.8	1.3	1.1
Average/Sum#:	7.7	13.3	6.0	127.2	3,375,632.8	1,996.0	1.2	1.0
Minimum:	6.3	13.0	5.2	93.9	3,131,677.9	1,600.8	1.0	0.6
Maximum:	8.3	13.8	6.4	156.4	3,467,252.1	2,214.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/04/2020 00:00	7.7	13.2	5.9	131.7	3,472,233.3	2,104.5	1.2	1.1
12/04/2020 01:00	7.6	13.2	5.8	128.2	3,399,846.5	2,035.8	1.2	1.0
12/04/2020 02:00	6.3	13.8	5.2	98.8	3,301,095.3	1,687.4	1.0	0.7
12/04/2020 03:00	7.4	13.5	5.9	110.1	3,382,478.2	1,852.5	1.0	0.7
12/04/2020 04:00	8.2	13.2	6.3	136.8	3,439,537.6	2,109.8	1.3	1.1
12/04/2020 05:00	8.2	13.1	6.2	152.3	3,432,533.1	2,180.7	1.5	1.3
12/04/2020 06:00	8.2	13.0	6.1	164.6	3,392,633.5	2,204.9	1.6	1.3
12/04/2020 07:00	8.3	13.1	6.3	144.0	3,408,450.1	2,165.4	1.4	1.1
12/04/2020 08:00	7.7	13.2	5.9	126.3	3,451,283.5	2,066.6	1.2	1.0
12/04/2020 09:00	7.4	13.3	5.7	120.0	3,414,373.7	1,969.7	1.1	0.8
12/04/2020 10:00	6.4	13.8	5.3	95.4	3,169,630.6	1,620.2	1.0	0.6
12/04/2020 11:00	6.8	13.8	5.7	94.5	3,131,482.3	1,600.7	1.0	0.6
12/04/2020 12:00	7.6	13.4	6.0	110.3	3,430,852.7	1,929.1	1.0	0.8
12/04/2020 13:00	7.3	13.3	5.7	109.6	3,403,721.9	1,938.7	1.0	0.8
12/04/2020 14:00	6.6	13.7	5.4	98.5	3,253,948.0	1,663.3	1.0	0.7
12/04/2020 15:00	7.4	13.5	5.9	107.3	3,334,178.3	1,801.7	1.0	0.7
12/04/2020 16:00	8.1	13.1	6.1	127.5	3,421,278.6	2,098.6	1.2	1.0
12/04/2020 17:00	7.9	13.0	5.9	138.9	3,408,607.5	2,165.5	1.3	1.1
12/04/2020 18:00	7.9	13.0	5.9	138.7	3,421,514.7	2,173.7	1.3	1.1
12/04/2020 19:00	7.8	13.0	5.8	141.7	3,409,866.7	2,191.2	1.4	1.1
12/04/2020 20:00	8.0	13.1	6.1	149.2	3,393,339.2	2,155.8	1.4	1.1
12/04/2020 21:00	8.0	13.1	6.1	150.8	3,370,651.4	2,166.0	1.5	1.3
12/04/2020 22:00	7.8	13.1	5.9	140.4	3,397,924.1	2,133.9	1.4	1.1
12/04/2020 23:00	7.8	13.2	6.0	134.3	3,432,527.4	2,105.5	1.3	1.1
Average/Sum#:	7.6	13.3	5.9	127.1	3,378,082.8	2,005.1	1.2	1.0
Minimum:	6.3	13.0	5.2	94.5	3,131,482.3	1,600.7	1.0	0.6
Maximum:	8.3	13.8	6.3	164.6	3,472,233.3	2,204.9	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/05/2020 00:00	7.8	13.2	6.0	134.4	3,442,309.0	2,111.5	1.3	1.1
12/05/2020 01:00	7.8	13.2	6.0	132.4	3,440,720.0	2,085.4	1.3	1.0
12/05/2020 02:00	7.8	13.2	6.0	132.1	3,467,613.5	2,101.7	1.2	1.1
12/05/2020 03:00	7.9	13.2	6.1	132.3	3,471,573.3	2,104.1	1.2	1.1
12/05/2020 04:00	7.8	13.2	6.0	130.9	3,468,768.5	2,102.4	1.2	1.1
12/05/2020 05:00	7.9	13.1	6.0	132.6	3,435,135.9	2,107.1	1.3	1.1
12/05/2020 06:00	7.8	13.2	6.0	131.9	3,468,025.0	2,051.3	1.2	1.0
12/05/2020 07:00	6.6	13.7	5.4	100.7	3,267,642.2	1,670.3	1.0	0.7
12/05/2020 08:00	6.7	13.7	5.5	96.4	3,187,041.8	1,629.1	1.0	0.7
12/05/2020 09:00	6.7	13.7	5.5	100.0	3,291,313.7	1,682.4	1.0	0.7
12/05/2020 10:00	6.8	13.7	5.6	99.9	3,275,663.1	1,674.4	1.0	0.7
12/05/2020 11:00	7.1	13.8	5.9	102.6	3,337,678.5	1,706.1	1.0	0.7
12/05/2020 12:00	7.1	13.8	5.9	102.1	3,320,462.9	1,697.3	1.0	0.7
12/05/2020 13:00	7.0	13.8	5.8	99.8	3,239,862.5	1,656.1	1.0	0.7
12/05/2020 14:00	6.9	13.8	5.7	98.3	3,209,735.1	1,640.7	1.0	0.7
12/05/2020 15:00	7.6	13.5	6.1	109.3	3,364,036.6	1,842.4	1.0	0.7
12/05/2020 16:00	8.1	13.2	6.2	124.0	3,445,009.8	2,088.0	1.2	1.0
12/05/2020 17:00	8.3	13.1	6.3	142.2	3,424,675.6	2,150.7	1.3	1.1
12/05/2020 18:00	8.3	13.1	6.3	150.3	3,398,973.6	2,184.2	1.4	1.1
12/05/2020 19:00	8.2	13.0	6.1	153.0	3,397,249.5	2,207.9	1.5	1.3
12/05/2020 20:00	8.2	13.0	6.1	152.1	3,412,512.2	2,192.9	1.5	1.3
12/05/2020 21:00	8.1	13.1	6.1	148.0	3,441,977.4	2,186.7	1.4	1.1
12/05/2020 22:00	7.9	13.2	6.1	134.6	3,449,971.3	2,116.2	1.3	1.1
12/05/2020 23:00	7.9	13.2	6.1	133.0	3,484,442.6	2,111.9	1.2	1.1
Average/Sum#:	7.6	13.4	6.0	123.9	3,380,933.1	1,962.5	1.2	1.0
Minimum:	6.6	13.0	5.4	96.4	3,187,041.8	1,629.1	1.0	0.7
Maximum:	8.3	13.8	6.3	153.0	3,484,442.6	2,207.9	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/06/2020 00:00	7.9	13.2	6.1	132.2	3,479,822.9	2,109.1	1.2	1.1
12/06/2020 01:00	7.8	13.2	6.0	127.0	3,501,330.7	2,071.0	1.2	1.0
12/06/2020 02:00	7.9	13.2	6.1	126.5	3,500,654.5	2,070.6	1.2	1.0
12/06/2020 03:00	7.2	13.4	5.7	112.6	3,407,884.7	1,891.3	1.1	0.8
12/06/2020 04:00	7.0	13.6	5.7	107.0	3,424,511.9	1,800.5	1.0	0.7
12/06/2020 05:00	8.1	13.2	6.2	124.5	3,434,212.0	2,031.3	1.2	1.0
12/06/2020 06:00	7.3	13.3	5.7	116.3	3,389,238.7	1,955.2	1.1	0.8
12/06/2020 07:00	6.9	13.8	5.7	99.6	3,051,077.5	1,559.6	1.0	0.6
12/06/2020 08:00	6.9	13.8	5.7	97.7	3,060,076.6	1,564.2	1.0	0.6
12/06/2020 09:00	7.0	13.8	5.8	106.4	3,304,421.0	1,689.1	1.0	0.7
12/06/2020 10:00	7.0	13.8	5.8	106.3	3,304,029.8	1,688.9	1.0	0.7
12/06/2020 11:00	7.0	13.8	5.8	106.2	3,322,614.8	1,698.4	1.0	0.7
12/06/2020 12:00	6.9	13.8	5.7	101.7	3,210,208.6	1,617.5	1.0	0.6
12/06/2020 13:00	6.9	13.8	5.7	105.1	3,342,784.8	1,684.3	1.0	0.7
12/06/2020 14:00	6.9	13.8	5.7	103.6	3,283,840.0	1,654.6	1.0	0.7
12/06/2020 15:00	7.7	13.5	6.1	111.6	3,403,389.7	1,839.1	1.0	0.7
12/06/2020 16:00	8.2	13.2	6.3	124.4	3,427,190.8	2,077.2	1.2	1.0
12/06/2020 17:00	8.1	13.0	6.0	136.9	3,413,644.4	2,168.7	1.3	1.1
12/06/2020 18:00	8.1	13.0	6.0	140.8	3,413,912.7	2,193.8	1.3	1.1
12/06/2020 19:00	8.0	13.0	6.0	140.8	3,415,002.1	2,194.5	1.3	1.1
12/06/2020 20:00	7.9	13.0	5.9	139.5	3,410,800.4	2,191.8	1.3	1.1
12/06/2020 21:00	7.8	13.0	5.8	132.8	3,431,363.5	2,154.9	1.3	1.1
12/06/2020 22:00	7.7	13.1	5.8	125.8	3,424,702.1	2,100.7	1.2	1.1
12/06/2020 23:00	7.7	13.2	5.9	123.8	3,414,041.8	2,044.3	1.2	1.0
Average/Sum#:	7.5	13.4	5.9	118.7	3,365,448.2	1,918.8	1.1	0.9
Minimum:	6.9	13.0	5.7	97.7	3,051,077.5	1,559.6	1.0	0.6
Maximum:	8.2	13.8	6.3	140.8	3,501,330.7	2,194.5	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/07/2020 00:00	8.1	13.2	6.2	134.2	3,405,577.0	2,064.1	1.3	1.0
12/07/2020 01:00	7.8	13.3	6.1	124.6	3,365,360.4	1,966.0	1.2	1.0
12/07/2020 02:00	6.3	13.8	5.2	94.2	3,147,719.8	1,609.0	1.0	0.6
12/07/2020 03:00	7.5	13.6	6.1	108.7	3,367,673.6	1,819.8	1.0	0.7
12/07/2020 04:00	8.3	13.2	6.4	131.5	3,426,734.0	2,051.9	1.2	1.0
12/07/2020 05:00	8.1	13.2	6.2	135.5	3,421,086.1	2,073.5	1.3	1.0
12/07/2020 06:00	8.2	13.1	6.2	163.7	3,387,357.8	2,152.0	1.6	1.3
12/07/2020 07:00	8.6	13.1	6.5	148.5	3,378,857.9	2,146.6	1.4	1.1
12/07/2020 08:00	8.3	13.1	6.3	147.2	3,386,618.3	2,126.8	1.4	1.1
12/07/2020 09:00	8.3	13.1	6.3	148.8	3,357,319.0	2,108.4	1.4	1.1
12/07/2020 10:00	6.7	13.7	5.5	104.9	3,217,576.7	1,691.7	1.0	0.7
12/07/2020 11:00	6.6	13.8	5.5	93.8	3,166,545.8	1,595.5	0.9	0.5
12/07/2020 12:00	6.7	13.8	5.6	94.1	3,153,843.9	1,589.1	0.9	0.5
12/07/2020 13:00	6.8	13.8	5.7	99.0	3,312,220.8	1,668.9	0.9	0.5
12/07/2020 14:00	8.2	13.7	6.7	106.0	3,113,845.9	1,659.9	1.1	0.7
12/07/2020 15:00	8.9	13.2	6.8	151.2	3,308,301.1	2,029.3	1.5	1.2
12/07/2020 16:00	8.6	13.2	6.6	153.7	3,336,401.1	2,070.9	1.5	1.2
12/07/2020 17:00	8.6	13.1	6.5	161.2	3,352,728.7	2,130.0	1.6	1.3
12/07/2020 18:00	7.8	13.1	5.9	130.4	3,391,236.2	2,129.7	1.3	1.1
12/07/2020 19:00	7.9	13.1	6.0	130.8	3,397,127.9	2,133.4	1.3	1.1
12/07/2020 20:00	7.8	13.1	5.9	132.8	3,422,287.1	2,149.2	1.3	1.1
12/07/2020 21:00	7.8	13.0	5.8	137.2	3,414,431.5	2,169.2	1.3	1.1
12/07/2020 22:00	7.7	13.1	5.8	132.4	3,404,452.7	2,138.0	1.3	1.1
12/07/2020 23:00	7.6	13.2	5.8	122.0	3,448,444.4	2,064.9	1.1	0.8
Average/Sum#:	7.8	13.3	6.1	128.6	3,336,822.8	1,972.4	1.2	1.0
Minimum:	6.3	13.0	5.2	93.8	3,113,845.9	1,589.1	0.9	0.5
Maximum:	8.9	13.8	6.8	163.7	3,448,444.4	2,169.2	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/08/2020 00:00	7.6	13.2	5.8	119.6	3,452,132.9	2,041.9	1.1	0.8
12/08/2020 01:00	7.3	13.3	5.7	110.3	3,402,844.0	1,938.2	1.0	0.8
12/08/2020 02:00	6.5	13.7	5.3	98.1	3,247,883.4	1,660.2	1.0	0.7
12/08/2020 03:00	7.5	13.5	6.0	106.4	3,319,743.8	1,793.9	1.0	0.7
12/08/2020 04:00	7.8	13.2	6.0	117.6	3,424,237.2	2,025.4	1.1	0.8
12/08/2020 05:00	7.4	13.3	5.7	111.5	3,463,590.3	1,972.8	1.0	0.8
12/08/2020 06:00	7.8	13.2	6.0	124.3	3,418,611.2	2,072.0	1.2	1.0
12/08/2020 07:00	8.2	13.1	6.2	136.5	3,422,764.8	2,149.5	1.3	1.1
12/08/2020 08:00	7.8	13.1	5.9	125.0	3,419,811.3	2,097.7	1.2	1.0
12/08/2020 09:00	7.5	13.3	5.8	116.3	3,400,679.4	1,961.8	1.1	0.8
12/08/2020 10:00	6.5	13.8	5.4	98.1	3,234,384.8	1,653.3	1.0	0.7
12/08/2020 11:00	6.7	13.8	5.6	93.5	3,134,394.1	1,579.3	0.9	0.5
12/08/2020 12:00	6.8	13.8	5.7	96.2	3,178,453.8	1,601.5	1.0	0.6
12/08/2020 13:00	6.8	13.8	5.7	93.5	3,109,585.7	1,566.8	1.0	0.6
12/08/2020 14:00	6.9	13.8	5.7	92.9	3,066,121.3	1,544.9	1.0	0.6
12/08/2020 15:00	8.3	13.6	6.7	107.9	3,248,959.4	1,708.2	1.0	0.7
12/08/2020 16:00	8.5	13.2	6.5	132.2	3,374,796.1	2,020.8	1.3	1.0
12/08/2020 17:00	8.4	13.1	6.4	149.2	3,370,200.6	2,141.1	1.4	1.1
12/08/2020 18:00	8.3	13.1	6.3	152.8	3,351,043.7	2,153.4	1.5	1.3
12/08/2020 19:00	8.2	13.0	6.1	152.8	3,355,089.7	2,180.5	1.5	1.3
12/08/2020 20:00	7.9	13.0	5.9	139.7	3,393,496.6	2,155.9	1.3	1.1
12/08/2020 21:00	8.0	13.1	6.1	138.6	3,410,833.4	2,117.1	1.3	1.1
12/08/2020 22:00	7.8	13.2	6.0	128.6	3,439,895.1	2,084.9	1.2	1.0
12/08/2020 23:00	7.8	13.2	6.0	124.3	3,466,503.4	2,050.4	1.2	1.0
Average/Sum#:	7.6	13.4	5.9	119.4	3,337,752.3	1,928.0	1.2	0.9
Minimum:	6.5	13.0	5.3	92.9	3,066,121.3	1,544.9	0.9	0.5
Maximum:	8.5	13.8	6.7	152.8	3,466,503.4	2,180.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/09/2020 00:00	7.9	13.2	6.1	125.6	3,432,412.1	2,055.3	1.2	1.0
12/09/2020 01:00	7.8	13.2	6.0	123.2	3,442,496.2	2,036.2	1.2	1.0
12/09/2020 02:00	6.9	13.4	5.4	109.6	3,437,610.9	1,932.9	1.0	0.8
12/09/2020 03:00	6.7	13.7	5.5	103.2	3,427,864.9	1,752.2	1.0	0.7
12/09/2020 04:00	7.5	13.5	6.0	109.3	3,376,741.5	1,824.7	1.0	0.7
12/09/2020 05:00	8.2	13.2	6.3	125.6	3,444,186.9	2,037.2	1.2	1.0
12/09/2020 06:00	8.1	13.1	6.1	137.3	3,408,073.4	2,090.5	1.3	1.0
12/09/2020 07:00	8.3	13.2	6.4	129.5	3,444,514.8	2,087.7	1.2	1.0
12/09/2020 08:00	8.0	13.2	6.1	128.1	3,460,969.6	2,072.4	1.2	1.0
12/09/2020 09:00	7.7	13.3	6.0	118.6	3,386,568.7	1,904.2	1.1	0.8
12/09/2020 10:00	6.7	13.7	5.5	103.3	3,430,016.8	1,753.3	1.0	0.7
12/09/2020 11:00	7.1	13.7	5.8	104.6	3,431,581.9	1,754.1	1.0	0.7
12/09/2020 12:00	7.8	13.7	6.4	107.5	3,377,849.2	1,751.3	1.0	0.7
12/09/2020 13:00	8.5	13.6	6.9	114.3	3,384,599.9	1,754.8	1.1	0.7
12/09/2020 14:00	8.4	13.6	6.8	112.2	3,378,620.7	1,751.7	1.0	0.7
12/09/2020 15:00	8.5	13.4	6.7	119.6	3,272,744.1	1,816.3	1.2	0.9
12/09/2020 16:00	8.5	13.1	6.4	141.1	3,310,140.4	2,054.6	1.4	1.0
12/09/2020 17:00	8.3	13.0	6.2	145.4	3,325,153.5	2,088.2	1.4	1.0
12/09/2020 18:00	8.2	13.0	6.1	144.8	3,323,561.1	2,087.2	1.4	1.0
12/09/2020 19:00	7.9	13.0	5.9	136.3	3,395,854.0	2,132.6	1.3	1.1
12/09/2020 20:00	7.9	13.0	5.9	131.5	3,401,005.7	2,111.0	1.3	1.1
12/09/2020 21:00	8.0	12.9	5.9	137.8	3,383,265.3	2,149.4	1.3	1.1
12/09/2020 22:00	7.9	13.0	5.9	136.5	3,371,459.9	2,141.9	1.3	1.1
12/09/2020 23:00	7.7	13.1	5.8	126.5	3,393,401.0	2,081.5	1.2	1.0
Average/Sum#:	7.9	13.3	6.1	123.8	3,393,362.2	1,967.6	1.2	0.9
Minimum:	6.7	12.9	5.4	103.2	3,272,744.1	1,751.3	1.0	0.7
Maximum:	8.5	13.7	6.9	145.4	3,460,969.6	2,149.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/10/2020 00:00	7.8	13.1	5.9	125.9	3,422,571.0	2,074.4	1.2	1.0
12/10/2020 01:00	7.7	13.1	5.8	121.7	3,415,544.8	2,045.2	1.2	1.0
12/10/2020 02:00	7.7	13.1	5.8	125.6	3,396,007.5	2,058.3	1.2	1.0
12/10/2020 03:00	6.4	13.7	5.2	98.7	3,316,159.0	1,695.1	1.0	0.7
12/10/2020 04:00	7.5	13.5	6.0	110.0	3,341,395.5	1,830.0	1.1	0.7
12/10/2020 05:00	8.6	13.0	6.4	152.8	3,379,771.2	2,122.5	1.5	1.3
12/10/2020 06:00	8.3	13.1	6.3	148.3	3,397,783.6	2,109.0	1.4	1.1
12/10/2020 07:00	8.6	13.1	6.5	141.7	3,377,967.2	2,096.7	1.4	1.0
12/10/2020 08:00	8.4	13.1	6.4	146.3	3,385,056.0	2,101.1	1.4	1.1
12/10/2020 09:00	8.3	13.1	6.3	150.2	3,383,928.2	2,100.4	1.5	1.3
12/10/2020 10:00	6.7	13.7	5.5	106.3	3,226,135.6	1,696.2	1.1	0.7
12/10/2020 11:00	6.6	13.8	5.5	95.9	3,228,666.1	1,626.8	0.9	0.5
12/10/2020 12:00	6.6	13.8	5.5	91.1	3,041,312.9	1,532.4	0.9	0.5
12/10/2020 13:00	6.7	13.8	5.6	93.6	3,125,661.5	1,574.9	0.9	0.5
12/10/2020 14:00	6.7	13.8	5.6	91.1	3,049,847.0	1,536.7	0.9	0.5
12/10/2020 15:00	7.7	13.5	6.1	109.1	3,366,378.2	1,819.1	1.0	0.7
12/10/2020 16:00	8.0	13.1	6.1	122.3	3,439,426.2	2,059.5	1.1	0.8
12/10/2020 17:00	8.0	13.0	6.0	131.9	3,435,966.3	2,132.7	1.2	1.1
12/10/2020 18:00	8.1	13.0	6.0	146.8	3,385,468.9	2,150.8	1.4	1.1
12/10/2020 19:00	8.1	13.0	6.0	143.8	3,385,185.2	2,125.9	1.4	1.1
12/10/2020 20:00	7.9	13.1	6.0	133.9	3,417,692.0	2,096.4	1.3	1.0
12/10/2020 21:00	8.0	13.1	6.1	135.5	3,404,550.1	2,113.2	1.3	1.1
12/10/2020 22:00	8.0	13.1	6.1	135.3	3,394,561.4	2,107.0	1.3	1.1
12/10/2020 23:00	7.9	13.1	6.0	128.4	3,456,961.6	2,070.0	1.2	1.0
Average/Sum#:	7.7	13.3	5.9	124.4	3,340,583.2	1,953.1	1.2	0.9
Minimum:	6.4	13.0	5.2	91.1	3,041,312.9	1,532.4	0.9	0.5
Maximum:	8.6	13.8	6.5	152.8	3,456,961.6	2,150.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/11/2020 00:00	7.5	13.3	5.8	114.2	3,411,622.4	1,943.2	1.1	0.8
12/11/2020 01:00	6.5	13.7	5.3	100.5	3,331,418.3	1,702.9	1.0	0.7
12/11/2020 02:00	6.5	13.7	5.3	94.9	3,136,960.0	1,603.5	1.0	0.6
12/11/2020 03:00	6.6	13.7	5.4	94.6	3,120,135.6	1,594.9	1.0	0.6
12/11/2020 04:00	7.4	13.5	5.9	104.4	3,283,657.6	1,774.4	1.0	0.7
12/11/2020 05:00	8.2	13.2	6.3	124.4	3,488,819.9	2,063.6	1.1	0.8
12/11/2020 06:00	8.1	13.1	6.1	137.5	3,478,990.0	2,134.0	1.3	1.1
12/11/2020 07:00	8.5	13.1	6.4	134.7	3,443,450.2	2,112.2	1.3	1.1
12/11/2020 08:00	8.1	13.2	6.2	134.0	3,424,550.9	2,075.6	1.3	1.0
12/11/2020 09:00	6.4	13.8	5.3	98.7	3,263,729.6	1,668.3	1.0	0.7
12/11/2020 10:00	6.6	13.8	5.5	98.4	3,261,382.0	1,667.1	1.0	0.7
12/11/2020 11:00	6.6	13.8	5.5	97.8	3,228,124.5	1,650.1	1.0	0.7
12/11/2020 12:00	6.6	13.8	5.5	96.7	3,183,520.4	1,627.3	1.0	0.7
12/11/2020 13:00	6.9	13.8	5.7	99.7	3,267,837.8	1,670.4	1.0	0.7
12/11/2020 14:00	6.9	13.7	5.7	100.7	3,277,423.8	1,675.3	1.0	0.7
12/11/2020 15:00	7.9	13.5	6.3	110.1	3,374,335.7	1,823.4	1.0	0.7
12/11/2020 16:00	8.5	13.1	6.4	132.1	3,411,660.0	2,092.7	1.3	1.0
12/11/2020 17:00	8.3	13.0	6.2	136.7	3,415,505.5	2,120.0	1.3	1.1
12/11/2020 18:00	8.2	12.9	6.0	142.9	3,388,080.4	2,177.2	1.4	1.1
12/11/2020 19:00	8.0	12.9	5.9	141.3	3,395,550.0	2,182.0	1.4	1.1
12/11/2020 20:00	7.9	12.9	5.8	141.0	3,394,927.5	2,181.6	1.4	1.1
12/11/2020 21:00	7.9	12.9	5.8	140.5	3,391,192.7	2,179.2	1.4	1.1
12/11/2020 22:00	7.8	13.0	5.8	130.2	3,405,677.9	2,113.9	1.2	1.1
12/11/2020 23:00	7.8	13.1	5.9	126.1	3,438,740.1	2,084.2	1.2	1.0
Average/Sum#:	7.5	13.4	5.8	118.0	3,342,387.2	1,913.2	1.2	0.9
Minimum:	6.4	12.9	5.3	94.6	3,120,135.6	1,594.9	1.0	0.6
Maximum:	8.5	13.8	6.4	142.9	3,488,819.9	2,182.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/12/2020 00:00	7.9	13.0	5.9	128.5	3,420,626.5	2,098.2	1.2	1.0
12/12/2020 01:00	7.8	13.1	5.9	123.7	3,405,577.0	2,064.1	1.2	1.0
12/12/2020 02:00	7.1	13.3	5.5	110.5	3,416,713.8	1,946.1	1.0	0.8
12/12/2020 03:00	6.5	13.7	5.3	95.9	3,130,195.5	1,622.9	1.0	0.6
12/12/2020 04:00	7.2	13.5	5.7	105.9	3,363,232.3	1,817.4	1.0	0.7
12/12/2020 05:00	7.2	13.3	5.6	108.6	3,462,687.4	1,947.0	1.0	0.8
12/12/2020 06:00	7.1	13.4	5.6	107.5	3,444,369.1	1,936.7	1.0	0.8
12/12/2020 07:00	6.8	13.7	5.6	102.5	3,260,580.2	1,690.5	1.0	0.7
12/12/2020 08:00	6.8	13.7	5.6	100.3	3,231,070.0	1,675.2	1.0	0.7
12/12/2020 09:00	6.8	13.7	5.6	101.0	3,254,408.1	1,687.3	1.0	0.7
12/12/2020 10:00	6.8	13.7	5.6	100.3	3,271,554.9	1,672.3	1.0	0.7
12/12/2020 11:00	6.8	13.7	5.6	95.3	3,096,268.5	1,582.7	1.0	0.6
12/12/2020 12:00	6.9	13.7	5.7	98.5	3,216,191.0	1,644.0	1.0	0.7
12/12/2020 13:00	7.1	13.7	5.8	102.8	3,328,092.5	1,701.2	1.0	0.7
12/12/2020 14:00	6.9	13.7	5.7	100.1	3,271,163.6	1,672.1	1.0	0.7
12/12/2020 15:00	7.8	13.5	6.2	110.8	3,333,179.0	1,825.5	1.1	0.7
12/12/2020 16:00	8.4	13.1	6.4	131.4	3,414,981.4	2,069.8	1.2	1.0
12/12/2020 17:00	8.2	13.0	6.1	141.5	3,389,484.6	2,128.6	1.4	1.1
12/12/2020 18:00	8.2	13.0	6.1	148.1	3,406,089.0	2,163.9	1.4	1.1
12/12/2020 19:00	8.1	13.0	6.0	149.7	3,407,190.8	2,164.6	1.4	1.1
12/12/2020 20:00	8.1	13.0	6.0	147.1	3,404,200.1	2,162.7	1.4	1.1
12/12/2020 21:00	8.1	13.0	6.0	148.8	3,399,163.2	2,159.5	1.4	1.1
12/12/2020 22:00	8.0	13.0	6.0	146.5	3,376,496.8	2,145.1	1.4	1.1
12/12/2020 23:00	7.8	13.1	5.9	133.3	3,406,117.1	2,089.3	1.3	1.0
Average/Sum#:	7.4	13.4	5.8	118.3	3,337,901.4	1,902.8	1.1	0.9
Minimum:	6.5	13.0	5.3	95.3	3,096,268.5	1,582.7	1.0	0.6
Maximum:	8.4	13.7	6.4	149.7	3,462,687.4	2,164.6	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/13/2020 00:00	7.8	13.1	5.9	133.1	3,414,268.4	2,094.3	1.3	1.0
12/13/2020 01:00	7.7	13.2	5.9	126.9	3,422,391.9	2,049.3	1.2	1.0
12/13/2020 02:00	6.9	13.4	5.4	108.9	3,460,019.7	1,945.5	1.0	0.8
12/13/2020 03:00	7.0	13.4	5.5	108.9	3,460,553.2	1,945.8	1.0	0.8
12/13/2020 04:00	7.1	13.4	5.6	110.0	3,481,717.0	1,957.7	1.0	0.8
12/13/2020 05:00	7.8	13.2	6.0	119.2	3,441,989.0	2,035.9	1.1	0.8
12/13/2020 06:00	7.8	13.1	5.9	119.9	3,425,927.9	2,026.4	1.1	0.8
12/13/2020 07:00	7.1	13.7	5.8	99.8	3,097,985.1	1,606.2	1.0	0.6
12/13/2020 08:00	7.2	13.8	6.0	83.4	2,542,238.6	1,299.5	1.0	0.5
12/13/2020 09:00	7.3	13.8	6.1	83.6	2,543,608.0	1,300.2	1.0	0.5
12/13/2020 10:00	7.3	13.7	6.0	83.5	2,570,996.5	1,314.2	1.0	0.5
12/13/2020 11:00	7.0	13.7	5.7	89.8	2,936,045.9	1,500.8	1.0	0.6
12/13/2020 12:00	6.9	13.7	5.7	100.2	3,217,761.5	1,668.3	1.0	0.7
12/13/2020 13:00	7.0	13.7	5.7	101.1	3,246,307.3	1,683.1	1.0	0.7
12/13/2020 14:00	7.0	13.7	5.7	101.7	3,266,945.1	1,693.8	1.0	0.7
12/13/2020 15:00	7.7	13.5	6.1	108.4	3,299,217.2	1,806.9	1.0	0.7
12/13/2020 16:00	8.3	13.1	6.3	123.1	3,369,608.9	2,042.3	1.2	1.0
12/13/2020 17:00	8.3	12.9	6.1	142.5	3,369,728.4	2,140.8	1.4	1.1
12/13/2020 18:00	8.0	13.0	6.0	140.8	3,363,904.4	2,137.1	1.4	1.1
12/13/2020 19:00	7.9	13.0	5.9	130.9	3,396,333.6	2,108.1	1.3	1.1
12/13/2020 20:00	7.9	13.0	5.9	131.9	3,416,150.0	2,120.4	1.3	1.1
12/13/2020 21:00	7.8	13.0	5.8	125.8	3,434,615.3	2,081.7	1.2	1.0
12/13/2020 22:00	7.7	13.1	5.8	121.4	3,445,539.4	2,038.0	1.1	0.8
12/13/2020 23:00	7.7	13.2	5.9	118.5	3,402,089.7	2,012.3	1.1	0.8
Average/Sum#:	7.5	13.4	5.9	113.1	3,251,080.9	1,858.7	1.1	0.8
Minimum:	6.9	12.9	5.4	83.4	2,542,238.6	1,299.5	1.0	0.5
Maximum:	8.3	13.8	6.3	142.5	3,481,717.0	2,140.8	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/14/2020 00:00	19.0	15.7	21.6	151.6	1,814,994.5	715.7	2.6	0.7
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/14/2020 05:00	34.8	17.2	55.5	145.2	2,002,179.0	497.1	1.9	0.3
12/14/2020 06:00	20.8	14.1	18.0	174.8	3,012,146.7	1,539.7	1.8	1.1
12/14/2020 07:00	8.3	13.2	6.4	133.8	3,494,399.1	2,066.9	1.2	1.0
12/14/2020 08:00	8.1	13.2	6.2	128.6	3,514,798.9	2,053.3	1.2	1.0
12/14/2020 09:00	8.0	13.2	6.1	127.0	3,500,872.8	2,019.6	1.2	1.0
12/14/2020 10:00	6.8	13.7	5.6	104.5	2,986,910.2	1,526.8	1.1	0.6
12/14/2020 11:00	6.9	13.7	5.7	92.3	3,020,754.6	1,544.1	1.0	0.6
12/14/2020 12:00	7.2	13.8	6.0	86.0	2,780,909.7	1,421.5	1.0	0.6
12/14/2020 13:00	7.1	13.8	5.9	83.1	2,729,719.3	1,375.4	1.0	0.6
12/14/2020 14:00	0.0	0.0	0.0	85.9	934,812.3	1,426.7	3.2	1.7
12/14/2020 15:00	0.0	0.0	0.0	106.4	1,213,611.4	1,852.2	3.1	2.2
12/14/2020 16:00	0.0	0.0	0.0	168.7	3,280,678.8	1,988.4	1.8	1.4
12/14/2020 17:00	9.5	13.0	7.1	149.2	3,401,996.5	2,161.3	1.4	1.1
12/14/2020 18:00	9.0	13.0	6.7	155.8	3,423,246.1	2,174.8	1.5	1.3
12/14/2020 19:00	8.9	13.0	6.6	154.9	3,419,153.6	2,172.2	1.5	1.3
12/14/2020 20:00	8.8	13.0	6.6	155.4	3,419,940.6	2,172.7	1.5	1.3
12/14/2020 21:00	8.8	13.0	6.6	154.7	3,417,894.4	2,171.4	1.5	1.3
12/14/2020 22:00	8.5	13.1	6.4	139.5	3,396,172.5	2,108.0	1.3	1.1
12/14/2020 23:00	7.2	13.4	5.7	108.6	3,447,748.2	1,938.6	1.0	0.8
Average/Sum#:	11.0	13.7	10.7	130.3	3,114,695.3	1,746.3	1.4	0.9
Minimum:	6.8	13.0	5.6	83.1	1,814,994.5	497.1	1.0	0.3
Maximum:	34.8	17.2	55.5	174.8	3,514,798.9	2,174.8	2.6	1.3
%SI	29.17	29.17	29.17	16.67	25.00	16.67	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/15/2020 00:00	8.2	13.2	6.3	122.3	3,439,994.1	2,009.6	1.1	0.8
12/15/2020 01:00	7.4	13.4	5.8	109.0	3,451,838.7	1,940.9	1.0	0.8
12/15/2020 02:00	7.5	13.3	5.8	109.3	3,450,593.8	1,940.2	1.0	0.8
12/15/2020 03:00	7.3	13.4	5.7	108.2	3,486,626.6	1,935.0	1.0	0.8
12/15/2020 04:00	8.2	13.2	6.3	127.7	3,473,887.3	2,029.4	1.2	1.0
12/15/2020 05:00	8.7	13.0	6.5	148.4	3,436,459.0	2,158.1	1.4	1.1
12/15/2020 06:00	8.5	13.0	6.3	146.0	3,453,019.5	2,168.5	1.4	1.1
12/15/2020 07:00	8.8	13.0	6.6	138.0	3,439,510.7	2,134.9	1.3	1.1
12/15/2020 08:00	8.2	13.2	6.3	120.2	3,456,084.8	2,019.0	1.1	0.8
12/15/2020 09:00	7.5	13.3	5.8	112.3	3,480,827.8	1,957.2	1.0	0.8
12/15/2020 10:00	7.1	13.4	5.6	107.4	3,478,518.1	1,930.5	1.0	0.8
12/15/2020 11:00	7.1	13.4	5.6	107.6	3,497,618.0	1,941.1	1.0	0.8
12/15/2020 12:00	7.2	13.4	5.7	108.1	3,455,751.3	1,943.1	1.0	0.8
12/15/2020 13:00	7.4	13.4	5.8	109.1	3,453,439.3	1,941.8	1.0	0.8
12/15/2020 14:00	7.9	13.3	6.1	113.6	3,459,841.8	1,945.4	1.1	0.8
12/15/2020 15:00	7.9	13.3	6.1	112.6	3,461,086.7	1,946.1	1.0	0.8
12/15/2020 16:00	7.9	13.2	6.1	119.9	3,452,832.4	2,017.1	1.1	0.8
12/15/2020 17:00	8.5	13.0	6.3	142.8	3,438,210.6	2,159.2	1.4	1.1
12/15/2020 18:00	8.5	13.0	6.3	145.2	3,422,301.7	2,174.2	1.4	1.1
12/15/2020 19:00	8.5	13.0	6.3	143.4	3,453,656.4	2,168.9	1.4	1.1
12/15/2020 20:00	8.4	13.0	6.3	141.2	3,439,484.5	2,160.0	1.3	1.1
12/15/2020 21:00	8.4	13.0	6.3	137.8	3,463,999.3	2,150.1	1.3	1.1
12/15/2020 22:00	8.4	13.0	6.3	137.9	3,447,082.8	2,139.6	1.3	1.1
12/15/2020 23:00	8.1	13.1	6.1	125.6	3,449,780.4	2,065.7	1.2	1.0
Average/Sum#:	8.0	13.2	6.1	124.7	3,455,935.2	2,040.7	1.2	0.9
Minimum:	7.1	13.0	5.6	107.4	3,422,301.7	1,930.5	1.0	0.8
Maximum:	8.8	13.4	6.6	148.4	3,497,618.0	2,174.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/16/2020 00:00	8.1	13.1	6.1	122.1	3,446,215.6	2,038.4	1.1	0.8
12/16/2020 01:00	7.7	13.3	6.0	115.4	3,454,763.0	1,993.0	1.1	0.8
12/16/2020 02:00	7.0	13.4	5.5	107.3	3,498,338.7	1,941.5	1.0	0.8
12/16/2020 03:00	7.1	13.4	5.6	107.9	3,502,843.4	1,944.0	1.0	0.8
12/16/2020 04:00	7.7	13.3	6.0	113.6	3,478,513.5	1,981.3	1.0	0.8
12/16/2020 05:00	8.3	13.1	6.3	131.4	3,455,404.2	2,094.3	1.2	1.0
12/16/2020 06:00	8.3	13.1	6.3	136.3	3,425,655.4	2,126.3	1.3	1.1
12/16/2020 07:00	8.7	13.0	6.5	138.8	3,471,249.2	2,154.6	1.3	1.1
12/16/2020 08:00	8.2	13.1	6.2	127.6	3,495,038.2	2,092.8	1.2	1.0
12/16/2020 09:00	7.0	13.4	5.5	107.6	3,493,113.3	1,938.6	1.0	0.8
12/16/2020 10:00	7.1	13.4	5.6	107.7	3,485,004.9	1,934.1	1.0	0.8
12/16/2020 11:00	7.7	13.3	6.0	110.5	3,451,127.3	1,940.5	1.0	0.8
12/16/2020 12:00	8.1	13.3	6.3	112.6	3,445,614.0	1,937.4	1.0	0.8
12/16/2020 13:00	8.1	13.3	6.3	113.7	3,406,004.2	1,940.0	1.1	0.8
12/16/2020 14:00	8.0	13.3	6.2	114.4	3,394,065.7	1,933.2	1.1	0.8
12/16/2020 15:00	6.7	13.7	5.5	100.1	3,302,856.0	1,688.3	1.0	0.7
12/16/2020 16:00	6.8	13.7	5.6	91.1	2,950,327.0	1,508.1	1.0	0.6
12/16/2020 17:00	7.1	13.5	5.7	104.5	3,375,250.7	1,774.6	1.0	0.7
12/16/2020 18:00	7.8	13.3	6.1	111.0	3,395,638.9	1,909.3	1.0	0.8
12/16/2020 19:00	8.3	13.0	6.2	134.2	3,399,516.4	2,134.9	1.3	1.1
12/16/2020 20:00	8.1	12.9	6.0	139.4	3,372,207.5	2,167.0	1.4	1.1
12/16/2020 21:00	8.0	12.9	5.9	139.4	3,368,472.8	2,164.6	1.4	1.1
12/16/2020 22:00	8.0	12.9	5.9	137.8	3,363,181.8	2,161.2	1.3	1.1
12/16/2020 23:00	8.0	12.9	5.9	135.9	3,380,117.2	2,147.4	1.3	1.1
Average/Sum#:	7.7	13.2	6.0	119.2	3,408,771.6	1,985.2	1.1	0.9
Minimum:	6.7	12.9	5.5	91.1	2,950,327.0	1,508.1	1.0	0.6
Maximum:	8.7	13.7	6.5	139.4	3,502,843.4	2,167.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/17/2020 00:00	7.7	13.0	5.8	125.6	3,379,706.8	2,073.1	1.2	1.0
12/17/2020 01:00	7.3	13.2	5.6	113.8	3,281,764.9	1,893.2	1.1	0.8
12/17/2020 02:00	7.1	13.5	5.7	105.8	3,347,961.2	1,784.7	1.0	0.7
12/17/2020 03:00	7.9	13.1	6.0	119.3	3,398,677.5	2,035.1	1.1	0.8
12/17/2020 04:00	7.8	13.1	5.9	121.8	3,393,532.6	2,056.8	1.2	1.0
12/17/2020 05:00	7.8	13.0	5.8	124.0	3,381,337.0	2,074.1	1.2	1.0
12/17/2020 06:00	7.6	13.1	5.7	116.1	3,362,437.9	2,013.4	1.1	0.8
12/17/2020 07:00	8.4	13.0	6.3	131.2	3,405,677.9	2,113.9	1.2	1.1
12/17/2020 08:00	7.9	13.1	6.0	123.0	3,401,452.2	2,061.6	1.2	1.0
12/17/2020 09:00	7.6	13.2	5.8	114.5	3,383,334.1	1,976.5	1.1	0.8
12/17/2020 10:00	6.4	13.7	5.2	96.4	3,203,670.5	1,637.6	1.0	0.7
12/17/2020 11:00	6.7	13.7	5.5	99.7	3,298,356.4	1,686.0	1.0	0.7
12/17/2020 12:00	6.8	13.7	5.6	99.6	3,270,576.7	1,671.8	1.0	0.7
12/17/2020 13:00	7.0	13.7	5.7	100.9	3,297,573.9	1,685.6	1.0	0.7
12/17/2020 14:00	6.9	13.7	5.7	99.6	3,248,861.5	1,660.7	1.0	0.7
12/17/2020 15:00	6.8	13.7	5.6	98.7	3,235,949.8	1,654.1	1.0	0.7
12/17/2020 16:00	7.7	13.5	6.1	107.9	3,349,538.0	1,810.0	1.0	0.7
12/17/2020 17:00	8.3	13.1	6.3	126.9	3,440,060.0	2,085.0	1.2	1.0
12/17/2020 18:00	8.1	13.1	6.1	129.0	3,413,616.3	2,093.9	1.2	1.0
12/17/2020 19:00	8.1	13.1	6.1	125.7	3,412,341.6	2,068.2	1.2	1.0
12/17/2020 20:00	8.0	13.1	6.1	122.3	3,436,921.2	2,058.0	1.1	0.8
12/17/2020 21:00	8.1	13.1	6.1	131.7	3,444,102.3	2,112.6	1.2	1.1
12/17/2020 22:00	7.9	13.1	6.0	123.8	3,470,989.8	2,078.4	1.2	1.0
12/17/2020 23:00	7.8	13.2	6.0	119.7	3,470,561.0	2,052.8	1.1	0.8
Average/Sum#:	7.6	13.3	5.9	115.7	3,363,708.4	1,934.9	1.1	0.9
Minimum:	6.4	13.0	5.2	96.4	3,203,670.5	1,637.6	1.0	0.7
Maximum:	8.4	13.7	6.3	131.7	3,470,989.8	2,113.9	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/18/2020 00:00	7.8	13.1	5.9	121.3	3,483,578.9	2,060.5	1.1	0.8
12/18/2020 01:00	7.1	13.3	5.5	109.0	3,479,227.2	1,956.3	1.0	0.8
12/18/2020 02:00	6.6	13.7	5.4	100.4	3,315,572.1	1,694.8	1.0	0.7
12/18/2020 03:00	6.7	13.7	5.5	87.4	2,871,487.3	1,467.8	1.0	0.6
12/18/2020 04:00	7.2	13.7	5.9	100.4	3,258,844.3	1,689.6	1.0	0.7
12/18/2020 05:00	7.6	13.3	5.9	112.2	3,472,544.2	1,977.9	1.0	0.8
12/18/2020 06:00	8.2	13.1	6.2	134.5	3,457,796.6	2,121.0	1.3	1.1
12/18/2020 07:00	8.3	13.1	6.3	128.4	3,480,977.8	2,109.8	1.2	1.1
12/18/2020 08:00	7.0	13.3	5.4	107.9	3,457,529.8	1,944.1	1.0	0.8
12/18/2020 09:00	6.6	13.7	5.4	100.5	3,322,810.5	1,698.5	1.0	0.7
12/18/2020 10:00	6.6	13.7	5.4	92.5	3,051,860.1	1,560.0	1.0	0.6
12/18/2020 11:00	6.8	13.8	5.7	84.2	2,788,664.1	1,405.1	0.9	0.4
12/18/2020 12:00	6.8	13.8	5.7	88.8	2,933,893.9	1,499.7	1.0	0.6
12/18/2020 13:00	6.8	13.8	5.7	95.3	3,123,657.0	1,596.7	1.0	0.6
12/18/2020 14:00	6.9	13.8	5.7	85.0	2,799,778.2	1,410.7	1.0	0.6
12/18/2020 15:00	7.2	13.8	6.0	87.9	2,838,280.9	1,430.1	1.0	0.6
12/18/2020 16:00	8.1	13.4	6.4	110.8	3,395,442.1	1,859.6	1.0	0.7
12/18/2020 17:00	8.5	13.0	6.3	139.8	3,416,713.8	2,145.7	1.3	1.1
12/18/2020 18:00	8.2	12.9	6.0	142.3	3,416,091.4	2,195.2	1.4	1.1
12/18/2020 19:00	8.1	12.9	6.0	141.0	3,426,673.3	2,202.0	1.3	1.1
12/18/2020 20:00	8.0	12.9	5.9	138.8	3,441,662.5	2,186.5	1.3	1.1
12/18/2020 21:00	8.0	13.0	6.0	134.6	3,442,350.7	2,161.8	1.3	1.1
12/18/2020 22:00	7.8	13.0	5.8	125.6	3,489,392.3	2,114.9	1.2	1.1
12/18/2020 23:00	7.7	13.2	5.9	118.0	3,477,323.5	2,056.8	1.1	0.8
Average/Sum#:	7.4	13.4	5.8	111.9	3,276,756.4	1,856.0	1.1	0.8
Minimum:	6.6	12.9	5.4	84.2	2,788,664.1	1,405.1	0.9	0.4
Maximum:	8.5	13.8	6.4	142.3	3,489,392.3	2,202.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/19/2020 00:00	7.8	13.2	6.0	117.4	3,502,987.6	2,046.4	1.1	0.8
12/19/2020 01:00	7.4	13.3	5.7	113.2	3,461,350.1	1,996.8	1.1	0.8
12/19/2020 02:00	6.4	13.7	5.2	96.9	3,182,272.2	1,649.9	1.0	0.7
12/19/2020 03:00	6.5	13.7	5.3	91.1	3,025,449.7	1,546.5	1.0	0.6
12/19/2020 04:00	7.5	13.4	5.9	108.9	3,449,283.9	1,863.9	1.0	0.7
12/19/2020 05:00	8.0	13.1	6.1	120.9	3,501,330.7	2,071.0	1.1	0.8
12/19/2020 06:00	7.7	13.2	5.9	118.0	3,477,644.6	2,006.2	1.1	0.8
12/19/2020 07:00	6.7	13.7	5.5	99.8	3,219,304.6	1,669.1	1.0	0.7
12/19/2020 08:00	6.6	13.7	5.4	93.2	3,056,516.6	1,584.7	1.0	0.6
12/19/2020 09:00	6.7	13.7	5.5	95.9	3,142,539.6	1,629.3	1.0	0.7
12/19/2020 10:00	6.6	13.7	5.4	99.5	3,267,523.7	1,694.1	1.0	0.7
12/19/2020 11:00	6.7	13.7	5.5	100.1	3,332,787.7	1,703.6	1.0	0.7
12/19/2020 12:00	6.8	13.7	5.6	100.7	3,335,526.5	1,705.0	1.0	0.7
12/19/2020 13:00	6.9	13.7	5.7	100.8	3,315,572.1	1,694.8	1.0	0.7
12/19/2020 14:00	7.0	13.7	5.7	101.5	3,333,374.6	1,703.9	1.0	0.7
12/19/2020 15:00	7.5	13.6	6.1	105.0	3,348,623.0	1,760.6	1.0	0.7
12/19/2020 16:00	8.4	13.1	6.4	121.8	3,418,884.9	2,047.2	1.1	0.8
12/19/2020 17:00	8.2	13.1	6.2	132.1	3,443,287.2	2,112.1	1.2	1.1
12/19/2020 18:00	8.2	13.0	6.1	142.6	3,413,487.0	2,168.6	1.4	1.1
12/19/2020 19:00	8.1	12.9	6.0	141.6	3,436,940.4	2,183.5	1.3	1.1
12/19/2020 20:00	7.9	13.0	5.9	134.0	3,429,611.9	2,153.8	1.3	1.1
12/19/2020 21:00	7.8	13.0	5.8	128.7	3,455,840.2	2,119.8	1.2	1.1
12/19/2020 22:00	7.7	13.1	5.8	120.9	3,454,456.5	2,068.5	1.1	0.8
12/19/2020 23:00	7.6	13.2	5.8	113.5	3,469,670.7	2,001.6	1.1	0.8
Average/Sum#:	7.4	13.4	5.8	112.4	3,353,094.4	1,882.5	1.1	0.8
Minimum:	6.4	12.9	5.2	91.1	3,025,449.7	1,546.5	1.0	0.6
Maximum:	8.4	13.7	6.4	142.6	3,502,987.6	2,183.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/20/2020 00:00	6.9	13.3	5.4	109.1	3,453,934.1	1,967.3	1.0	0.8
12/20/2020 01:00	6.3	13.7	5.2	98.3	3,236,732.3	1,654.5	1.0	0.7
12/20/2020 02:00	6.5	13.7	5.3	90.5	3,020,558.9	1,544.0	1.0	0.6
12/20/2020 03:00	6.9	13.7	5.7	83.6	2,687,201.9	1,373.6	1.0	0.5
12/20/2020 04:00	6.6	13.7	5.4	92.0	3,029,706.8	1,570.8	1.0	0.6
12/20/2020 05:00	7.3	13.5	5.8	107.7	3,419,859.8	1,848.0	1.0	0.7
12/20/2020 06:00	7.5	13.3	5.8	110.5	3,434,881.5	1,881.2	1.0	0.8
12/20/2020 07:00	6.7	13.7	5.5	101.6	3,270,802.6	1,695.8	1.0	0.7
12/20/2020 08:00	6.6	13.7	5.4	99.2	3,225,669.5	1,672.4	1.0	0.7
12/20/2020 09:00	6.6	13.7	5.4	100.0	3,260,001.5	1,690.2	1.0	0.7
12/20/2020 10:00	6.6	13.7	5.4	100.3	3,260,387.3	1,690.4	1.0	0.7
12/20/2020 11:00	6.8	13.7	5.6	100.4	3,305,007.9	1,689.4	1.0	0.7
12/20/2020 12:00	7.0	13.7	5.7	101.8	3,323,006.1	1,698.6	1.0	0.7
12/20/2020 13:00	7.0	13.7	5.7	101.0	3,288,183.6	1,680.8	1.0	0.7
12/20/2020 14:00	6.6	13.7	5.4	96.1	3,169,239.3	1,620.0	1.0	0.6
12/20/2020 15:00	7.4	13.6	6.0	101.7	3,236,976.9	1,701.9	1.0	0.7
12/20/2020 16:00	8.2	13.2	6.3	119.2	3,413,586.1	2,019.1	1.1	0.8
12/20/2020 17:00	8.1	13.0	6.0	128.6	3,387,633.7	2,102.7	1.2	1.1
12/20/2020 18:00	8.0	13.0	6.0	131.1	3,412,283.3	2,118.0	1.2	1.1
12/20/2020 19:00	7.9	13.0	5.9	131.0	3,416,955.5	2,120.9	1.2	1.1
12/20/2020 20:00	7.9	13.0	5.9	136.3	3,388,931.8	2,153.0	1.3	1.1
12/20/2020 21:00	7.8	13.0	5.8	128.6	3,388,117.0	2,103.0	1.2	1.1
12/20/2020 22:00	7.7	13.0	5.8	125.8	3,411,007.9	2,092.3	1.2	1.0
12/20/2020 23:00	7.6	13.1	5.7	117.8	3,444,694.1	2,037.5	1.1	0.8
Average/Sum#:	7.2	13.4	5.7	108.8	3,286,890.0	1,821.9	1.1	0.8
Minimum:	6.3	13.0	5.2	83.6	2,687,201.9	1,373.6	1.0	0.5
Maximum:	8.2	13.7	6.3	136.3	3,453,934.1	2,153.0	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/21/2020 00:00	6.9	13.3	5.4	107.2	3,430,497.0	1,928.9	1.0	0.8
12/21/2020 01:00	6.4	13.7	5.2	97.4	3,211,589.5	1,665.1	1.0	0.7
12/21/2020 02:00	6.5	13.7	5.3	94.3	3,089,498.6	1,601.8	1.0	0.6
12/21/2020 03:00	6.6	13.7	5.4	91.8	2,989,974.2	1,550.2	1.0	0.6
12/21/2020 04:00	7.5	13.4	5.9	108.5	3,434,479.3	1,855.9	1.0	0.7
12/21/2020 05:00	8.0	13.1	6.1	121.1	3,504,712.0	2,073.0	1.1	0.8
12/21/2020 06:00	7.8	13.1	5.9	121.2	3,488,358.1	2,088.8	1.1	0.8
12/21/2020 07:00	8.1	13.1	6.1	122.4	3,494,537.2	2,092.5	1.1	0.8
12/21/2020 08:00	7.4	13.2	5.7	113.4	3,470,537.4	2,002.1	1.1	0.8
12/21/2020 09:00	6.3	13.6	5.1	98.3	3,243,799.9	1,681.8	1.0	0.7
12/21/2020 10:00	6.5	13.6	5.3	99.4	3,260,965.9	1,690.7	1.0	0.7
12/21/2020 11:00	6.6	13.6	5.3	100.0	3,260,387.3	1,690.4	1.0	0.7
12/21/2020 12:00	6.7	13.6	5.4	99.9	3,241,099.6	1,680.4	1.0	0.7
12/21/2020 13:00	6.8	13.7	5.6	100.3	3,258,265.7	1,689.3	1.0	0.7
12/21/2020 14:00	6.8	13.7	5.6	100.0	3,292,096.2	1,682.8	1.0	0.7
12/21/2020 15:00	7.7	13.5	6.1	109.5	3,349,723.1	1,810.1	1.0	0.7
12/21/2020 16:00	8.3	13.1	6.3	125.4	3,426,365.8	2,076.7	1.2	1.0
12/21/2020 17:00	8.0	13.0	6.0	125.8	3,411,497.0	2,092.6	1.2	1.0
12/21/2020 18:00	8.0	13.0	6.0	131.8	3,449,821.7	2,141.3	1.2	1.1
12/21/2020 19:00	7.9	13.0	5.9	128.9	3,455,840.2	2,119.8	1.2	1.1
12/21/2020 20:00	7.8	13.0	5.8	124.9	3,449,629.5	2,090.8	1.2	1.0
12/21/2020 21:00	7.7	13.1	5.8	121.5	3,452,619.5	2,067.4	1.1	0.8
12/21/2020 22:00	7.7	13.1	5.8	122.2	3,449,780.4	2,065.7	1.1	0.8
12/21/2020 23:00	7.6	13.1	5.7	116.7	3,462,760.7	2,022.9	1.1	0.8
Average/Sum#:	7.3	13.3	5.7	111.7	3,357,451.5	1,894.2	1.1	0.8
Minimum:	6.3	13.0	5.1	91.8	2,989,974.2	1,550.2	1.0	0.6
Maximum:	8.3	13.7	6.3	131.8	3,504,712.0	2,141.3	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/22/2020 00:00	7.2	13.3	5.6	109.3	3,457,707.6	1,944.2	1.0	0.8
12/22/2020 01:00	6.4	13.6	5.2	97.2	3,191,916.1	1,654.9	1.0	0.7
12/22/2020 02:00	6.5	13.7	5.3	90.9	2,969,722.1	1,539.7	1.0	0.6
12/22/2020 03:00	6.7	13.7	5.5	90.3	2,930,761.1	1,519.5	1.0	0.6
12/22/2020 04:00	7.3	13.6	5.9	101.6	3,261,892.8	1,715.0	1.0	0.7
12/22/2020 05:00	8.1	13.1	6.1	118.2	3,499,735.2	2,044.5	1.1	0.8
12/22/2020 06:00	7.8	13.1	5.9	123.8	3,459,132.6	2,071.3	1.2	1.0
12/22/2020 07:00	8.3	13.0	6.2	127.7	3,461,546.2	2,123.3	1.2	1.1
12/22/2020 08:00	6.5	13.6	5.3	101.4	3,231,654.0	1,722.7	1.0	0.7
12/22/2020 09:00	6.5	13.7	5.3	94.9	3,108,786.2	1,611.8	1.0	0.6
12/22/2020 10:00	6.8	13.7	5.6	100.7	3,308,333.7	1,691.1	1.0	0.7
12/22/2020 11:00	6.8	13.7	5.6	97.7	3,190,367.6	1,630.8	1.0	0.7
12/22/2020 12:00	6.6	13.8	5.5	93.7	3,102,137.5	1,585.7	1.0	0.6
12/22/2020 13:00	6.9	13.8	5.7	98.2	3,229,885.2	1,651.0	1.0	0.7
12/22/2020 14:00	7.0	13.8	5.8	101.1	3,296,400.1	1,685.0	1.0	0.7
12/22/2020 15:00	7.4	13.7	6.1	101.5	3,273,117.2	1,697.0	1.0	0.7
12/22/2020 16:00	8.3	13.2	6.4	119.9	3,430,065.7	2,003.8	1.1	0.8
12/22/2020 17:00	8.4	13.1	6.4	138.7	3,430,897.2	2,104.5	1.3	1.1
12/22/2020 18:00	8.3	13.0	6.2	141.0	3,419,049.9	2,122.2	1.3	1.1
12/22/2020 19:00	8.2	13.0	6.1	142.3	3,423,883.2	2,125.2	1.4	1.1
12/22/2020 20:00	8.2	13.0	6.1	143.2	3,440,316.3	2,135.4	1.4	1.1
12/22/2020 21:00	8.0	13.1	6.1	137.0	3,430,734.1	2,104.4	1.3	1.1
12/22/2020 22:00	8.0	13.1	6.1	133.1	3,444,844.8	2,087.9	1.3	1.0
12/22/2020 23:00	7.9	13.2	6.1	128.6	3,485,100.5	2,061.4	1.2	1.0
Average/Sum#:	7.4	13.4	5.8	113.8	3,311,582.8	1,859.7	1.1	0.8
Minimum:	6.4	13.0	5.2	90.3	2,930,761.1	1,519.5	1.0	0.6
Maximum:	8.4	13.8	6.4	143.2	3,499,735.2	2,135.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/23/2020 00:00	7.6	13.3	5.9	122.5	3,412,776.7	1,993.7	1.2	1.0
12/23/2020 01:00	6.6	13.7	5.4	102.8	3,325,549.3	1,699.9	1.0	0.7
12/23/2020 02:00	7.1	13.5	5.7	107.5	3,396,727.6	1,835.5	1.0	0.7
12/23/2020 03:00	7.2	13.4	5.7	108.7	3,477,270.9	1,955.2	1.0	0.8
12/23/2020 04:00	7.9	13.2	6.1	123.3	3,421,164.5	1,998.6	1.2	1.0
12/23/2020 05:00	6.5	13.7	5.3	100.9	3,310,094.4	1,692.0	1.0	0.7
12/23/2020 06:00	7.2	13.5	5.7	108.2	3,304,276.9	1,833.8	1.1	0.7
12/23/2020 07:00	8.9	13.0	6.6	143.5	3,451,609.4	2,092.0	1.3	1.0
12/23/2020 08:00	8.4	13.0	6.3	137.5	3,431,480.5	2,079.8	1.3	1.0
12/23/2020 09:00	7.9	13.2	6.1	124.9	3,406,443.2	1,990.0	1.2	1.0
12/23/2020 10:00	6.4	13.8	5.3	99.5	3,276,641.3	1,674.9	1.0	0.7
12/23/2020 11:00	6.6	13.8	5.5	96.7	3,210,407.1	1,617.6	1.0	0.6
12/23/2020 12:00	6.8	13.8	5.7	99.5	3,288,801.7	1,657.1	1.0	0.7
12/23/2020 13:00	6.8	13.8	5.7	101.1	3,344,967.9	1,685.4	1.0	0.7
12/23/2020 14:00	6.8	13.8	5.7	101.1	3,348,937.3	1,687.4	1.0	0.7
12/23/2020 15:00	7.4	13.7	6.1	102.1	3,224,512.2	1,671.8	1.0	0.7
12/23/2020 16:00	8.7	13.2	6.7	139.9	3,413,661.5	2,069.0	1.3	1.0
12/23/2020 17:00	8.2	13.0	6.1	146.8	3,417,336.3	2,196.0	1.4	1.1
12/23/2020 18:00	8.1	13.0	6.0	148.0	3,412,482.5	2,217.8	1.4	1.1
12/23/2020 19:00	8.0	13.0	6.0	146.6	3,420,329.7	2,222.9	1.4	1.1
12/23/2020 20:00	7.9	13.0	5.9	145.6	3,459,975.2	2,223.4	1.4	1.1
12/23/2020 21:00	7.7	13.1	5.8	128.9	3,426,984.5	2,102.1	1.2	1.1
12/23/2020 22:00	7.8	13.1	5.9	128.6	3,483,617.6	2,111.4	1.2	1.1
12/23/2020 23:00	7.7	13.1	5.8	124.5	3,501,217.3	2,096.5	1.2	1.0
Average/Sum#:	7.5	13.4	5.9	120.4	3,381,969.4	1,933.5	1.2	0.9
Minimum:	6.4	13.0	5.3	96.7	3,210,407.1	1,617.6	1.0	0.6
Maximum:	8.9	13.8	6.7	148.0	3,501,217.3	2,223.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/24/2020 00:00	7.6	13.2	5.8	118.0	3,511,204.1	2,051.2	1.1	0.8
12/24/2020 01:00	7.4	13.3	5.7	113.7	3,518,353.6	1,978.3	1.0	0.8
12/24/2020 02:00	6.6	13.6	5.3	102.0	3,369,555.5	1,747.0	1.0	0.7
12/24/2020 03:00	7.0	13.5	5.6	106.0	3,412,642.6	1,844.1	1.0	0.7
12/24/2020 04:00	6.9	13.4	5.4	106.8	3,512,033.0	1,949.1	1.0	0.8
12/24/2020 05:00	7.4	13.3	5.7	111.2	3,475,136.7	1,954.0	1.0	0.8
12/24/2020 06:00	6.3	13.7	5.2	100.6	3,285,461.3	1,703.4	1.0	0.7
12/24/2020 07:00	6.7	13.7	5.5	100.5	3,266,752.2	1,693.7	1.0	0.7
12/24/2020 08:00	6.6	13.7	5.4	100.0	3,259,037.2	1,689.7	1.0	0.7
12/24/2020 09:00	7.8	13.4	6.1	112.2	3,491,671.8	1,937.8	1.0	0.8
12/24/2020 10:00	7.8	13.2	6.0	121.1	3,434,687.5	2,006.5	1.1	0.8
12/24/2020 11:00	6.4	13.7	5.2	96.9	3,213,060.9	1,642.4	1.0	0.7
12/24/2020 12:00	6.6	13.7	5.4	96.6	3,211,104.5	1,641.4	1.0	0.7
12/24/2020 13:00	6.8	13.7	5.6	99.4	3,267,250.9	1,670.1	1.0	0.7
12/24/2020 14:00	6.9	13.7	5.7	100.9	3,311,659.4	1,692.8	1.0	0.7
12/24/2020 15:00	7.6	13.5	6.1	108.2	3,343,246.1	1,806.6	1.0	0.7
12/24/2020 16:00	8.2	13.2	6.3	126.9	3,428,738.1	2,053.1	1.2	1.0
12/24/2020 17:00	8.1	13.1	6.1	136.3	3,450,623.4	2,116.6	1.3	1.1
12/24/2020 18:00	8.0	13.0	6.0	139.2	3,452,399.4	2,142.9	1.3	1.1
12/24/2020 19:00	7.9	13.0	5.9	137.2	3,447,405.1	2,139.8	1.3	1.1
12/24/2020 20:00	7.9	13.0	5.9	139.8	3,435,822.1	2,157.7	1.3	1.1
12/24/2020 21:00	7.8	13.1	5.9	132.1	3,445,080.5	2,113.2	1.2	1.1
12/24/2020 22:00	7.8	13.0	5.8	135.3	3,478,011.9	2,133.4	1.3	1.1
12/24/2020 23:00	7.7	13.1	5.8	125.1	3,478,170.9	2,082.7	1.2	1.0
Average/Sum#:	7.3	13.4	5.7	115.3	3,395,796.2	1,914.5	1.1	0.9
Minimum:	6.3	13.0	5.2	96.6	3,211,104.5	1,641.4	1.0	0.7
Maximum:	8.2	13.7	6.3	139.8	3,518,353.6	2,157.7	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/25/2020 00:00	7.8	13.1	5.9	123.9	3,449,279.4	2,065.4	1.2	1.0
12/25/2020 01:00	7.8	13.1	5.9	122.6	3,440,595.3	2,060.2	1.2	1.0
12/25/2020 02:00	7.5	13.2	5.7	120.4	3,390,424.3	2,005.4	1.2	1.0
12/25/2020 03:00	6.5	13.7	5.3	100.4	3,271,959.9	1,696.4	1.0	0.7
12/25/2020 04:00	7.3	13.4	5.7	107.8	3,397,838.0	1,836.1	1.0	0.7
12/25/2020 05:00	8.0	13.1	6.1	122.1	3,459,233.6	2,046.1	1.1	0.8
12/25/2020 06:00	7.8	13.1	5.9	123.3	3,458,652.5	2,020.5	1.2	1.0
12/25/2020 07:00	6.7	13.7	5.5	99.0	3,197,123.7	1,657.6	1.0	0.7
12/25/2020 08:00	6.7	13.7	5.5	96.6	3,130,002.7	1,622.8	1.0	0.6
12/25/2020 09:00	6.7	13.7	5.5	97.0	3,125,952.3	1,620.7	1.0	0.6
12/25/2020 10:00	6.8	13.7	5.6	95.7	3,081,012.0	1,597.4	1.0	0.6
12/25/2020 11:00	6.8	13.6	5.5	99.8	3,240,521.0	1,680.1	1.0	0.7
12/25/2020 12:00	6.8	13.6	5.5	100.5	3,248,428.9	1,684.2	1.0	0.7
12/25/2020 13:00	6.8	13.6	5.5	100.4	3,243,221.3	1,681.5	1.0	0.7
12/25/2020 14:00	6.8	13.6	5.5	98.2	3,156,233.9	1,636.4	1.0	0.7
12/25/2020 15:00	7.3	13.6	5.9	104.3	3,333,873.3	1,728.5	1.0	0.7
12/25/2020 16:00	8.3	13.1	6.3	121.0	3,418,320.0	2,021.9	1.1	0.8
12/25/2020 17:00	8.1	13.0	6.0	127.1	3,377,587.4	2,071.8	1.2	1.0
12/25/2020 18:00	7.8	13.1	5.9	121.9	3,369,443.9	2,042.2	1.2	1.0
12/25/2020 19:00	7.9	13.0	5.9	128.7	3,352,189.8	2,080.7	1.2	1.0
12/25/2020 20:00	7.4	13.2	5.7	111.4	3,359,596.7	1,938.1	1.1	0.8
12/25/2020 21:00	6.6	13.6	5.3	100.6	3,280,446.5	1,700.8	1.0	0.7
12/25/2020 22:00	7.4	13.4	5.8	107.6	3,364,897.8	1,818.3	1.0	0.7
12/25/2020 23:00	7.9	13.2	6.1	111.7	3,409,866.7	1,942.2	1.0	0.8
Average/Sum#:	7.3	13.4	5.7	110.1	3,314,862.5	1,844.0	1.1	0.8
Minimum:	6.5	13.0	5.3	95.7	3,081,012.0	1,597.4	1.0	0.6
Maximum:	8.3	13.7	6.3	128.7	3,459,233.6	2,080.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/26/2020 00:00	7.9	13.1	6.0	119.8	3,378,971.2	2,023.3	1.1	0.8
12/26/2020 01:00	7.3	13.3	5.7	108.6	3,363,341.4	1,915.7	1.0	0.8
12/26/2020 02:00	6.5	13.7	5.3	99.8	3,261,544.6	1,691.0	1.0	0.7
12/26/2020 03:00	7.3	13.5	5.8	106.3	3,360,415.3	1,766.8	1.0	0.7
12/26/2020 04:00	8.1	13.1	6.1	121.0	3,386,987.3	2,028.1	1.2	1.0
12/26/2020 05:00	7.6	13.3	5.9	113.2	3,369,304.0	1,943.7	1.1	0.8
12/26/2020 06:00	6.7	13.7	5.5	102.7	3,319,876.0	1,697.0	1.0	0.7
12/26/2020 07:00	7.0	13.7	5.7	100.7	3,249,252.8	1,660.9	1.0	0.7
12/26/2020 08:00	6.8	13.7	5.6	96.7	3,147,915.4	1,609.1	1.0	0.6
12/26/2020 09:00	6.9	13.7	5.7	100.2	3,259,034.4	1,665.9	1.0	0.7
12/26/2020 10:00	6.8	13.7	5.6	94.3	3,063,989.2	1,566.2	1.0	0.6
12/26/2020 11:00	6.9	13.7	5.7	87.7	2,848,598.4	1,456.1	1.0	0.6
12/26/2020 12:00	6.9	13.7	5.7	94.4	3,092,160.3	1,580.6	1.0	0.6
12/26/2020 13:00	7.1	13.7	5.8	102.1	3,314,789.5	1,694.4	1.0	0.7
12/26/2020 14:00	7.0	13.7	5.7	100.4	3,264,707.7	1,668.8	1.0	0.7
12/26/2020 15:00	6.8	13.7	5.6	95.1	3,091,769.0	1,580.4	1.0	0.6
12/26/2020 16:00	7.5	13.6	6.1	101.6	3,207,115.8	1,686.2	1.0	0.7
12/26/2020 17:00	8.3	13.2	6.4	121.8	3,408,864.7	2,041.2	1.1	0.8
12/26/2020 18:00	7.8	13.3	6.1	116.1	3,433,615.0	1,980.8	1.1	0.8
12/26/2020 19:00	7.9	13.2	6.1	122.8	3,423,060.0	2,049.7	1.2	1.0
12/26/2020 20:00	7.7	13.2	5.9	120.6	3,441,931.3	2,061.0	1.1	0.8
12/26/2020 21:00	7.7	13.2	5.9	119.8	3,418,049.9	2,046.7	1.1	0.8
12/26/2020 22:00	7.7	13.1	5.8	123.1	3,416,466.4	2,070.7	1.2	1.0
12/26/2020 23:00	7.6	13.2	5.8	119.8	3,457,035.8	2,044.8	1.1	0.8
Average/Sum#:	7.3	13.5	5.8	107.9	3,290,783.1	1,813.7	1.1	0.8
Minimum:	6.5	13.1	5.3	87.7	2,848,598.4	1,456.1	1.0	0.6
Maximum:	8.3	13.7	6.4	123.1	3,457,035.8	2,070.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/27/2020 00:00	7.7	13.2	5.9	120.0	3,453,147.3	2,042.5	1.1	0.8
12/27/2020 01:00	7.7	13.2	5.9	118.6	3,440,129.3	2,034.8	1.1	0.8
12/27/2020 02:00	6.9	13.3	5.4	107.6	3,418,581.2	1,922.2	1.0	0.8
12/27/2020 03:00	6.6	13.7	5.4	100.6	3,324,766.8	1,699.5	1.0	0.7
12/27/2020 04:00	7.2	13.6	5.8	102.5	3,279,200.8	1,724.1	1.0	0.7
12/27/2020 05:00	8.1	13.1	6.1	122.2	3,416,546.8	2,045.8	1.2	1.0
12/27/2020 06:00	8.0	13.1	6.1	123.4	3,450,949.4	2,041.2	1.2	1.0
12/27/2020 07:00	6.8	13.7	5.6	103.3	3,255,372.5	1,687.8	1.0	0.7
12/27/2020 08:00	6.7	13.7	5.5	100.3	3,299,725.9	1,686.7	1.0	0.7
12/27/2020 09:00	6.6	13.7	5.4	98.4	3,196,352.2	1,657.2	1.0	0.7
12/27/2020 10:00	6.6	13.7	5.4	95.5	3,144,198.4	1,607.2	1.0	0.6
12/27/2020 11:00	6.7	13.7	5.5	97.6	3,209,539.5	1,640.6	1.0	0.7
12/27/2020 12:00	6.9	13.7	5.7	101.0	3,303,834.1	1,688.8	1.0	0.7
12/27/2020 13:00	6.6	13.7	5.4	95.9	3,151,045.5	1,610.7	1.0	0.6
12/27/2020 14:00	6.8	13.7	5.6	100.3	3,305,594.8	1,689.7	1.0	0.7
12/27/2020 15:00	7.3	13.6	5.9	102.8	3,282,244.0	1,725.7	1.0	0.7
12/27/2020 16:00	8.2	13.2	6.3	121.9	3,438,591.2	2,059.0	1.1	0.8
12/27/2020 17:00	7.9	13.1	6.0	131.5	3,430,005.3	2,129.0	1.2	1.1
12/27/2020 18:00	7.8	13.0	5.8	134.3	3,410,822.1	2,142.0	1.3	1.1
12/27/2020 19:00	7.9	13.0	5.9	143.8	3,375,092.6	2,193.5	1.4	1.1
12/27/2020 20:00	7.7	13.1	5.8	133.6	3,328,179.0	2,090.1	1.3	1.0
12/27/2020 21:00	6.5	13.7	5.3	99.9	3,329,070.7	1,701.7	1.0	0.7
12/27/2020 22:00	7.5	13.4	5.9	110.2	3,370,792.5	1,846.1	1.0	0.7
12/27/2020 23:00	8.1	13.0	6.0	131.9	3,395,031.3	2,082.5	1.3	1.0
Average/Sum#:	7.3	13.4	5.7	112.4	3,333,700.6	1,864.5	1.1	0.8
Minimum:	6.5	13.0	5.3	95.5	3,144,198.4	1,607.2	1.0	0.6
Maximum:	8.2	13.7	6.3	143.8	3,453,147.3	2,193.5	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/28/2020 00:00	7.7	13.2	5.9	117.6	3,376,829.4	1,972.7	1.1	0.8
12/28/2020 01:00	6.4	13.7	5.2	97.3	3,228,515.8	1,650.3	1.0	0.7
12/28/2020 02:00	7.6	13.4	6.0	109.1	3,363,123.7	1,841.9	1.0	0.7
12/28/2020 03:00	8.2	13.1	6.2	128.8	3,360,699.4	2,036.9	1.2	1.0
12/28/2020 04:00	7.7	13.2	5.9	114.1	3,342,088.9	1,928.0	1.1	0.8
12/28/2020 05:00	6.5	13.7	5.3	100.2	3,332,200.8	1,703.3	1.0	0.7
12/28/2020 06:00	7.3	13.5	5.8	108.1	3,263,676.2	1,835.1	1.1	0.7
12/28/2020 07:00	8.7	13.0	6.5	146.7	3,402,153.9	2,161.4	1.4	1.1
12/28/2020 08:00	8.0	13.1	6.1	135.8	3,399,038.7	2,134.6	1.3	1.1
12/28/2020 09:00	7.4	13.2	5.7	121.0	3,381,294.8	2,000.0	1.2	1.0
12/28/2020 10:00	6.4	13.7	5.2	97.7	3,253,165.4	1,662.9	1.0	0.7
12/28/2020 11:00	6.7	13.7	5.5	99.2	3,280,553.9	1,676.9	1.0	0.7
12/28/2020 12:00	6.8	13.7	5.6	100.8	3,315,376.4	1,694.7	1.0	0.7
12/28/2020 13:00	6.8	13.7	5.6	100.0	3,274,098.1	1,673.6	1.0	0.7
12/28/2020 14:00	6.9	13.7	5.7	100.9	3,314,007.0	1,694.0	1.0	0.7
12/28/2020 15:00	7.6	13.5	6.1	107.1	3,282,177.1	1,773.6	1.0	0.7
12/28/2020 16:00	8.1	13.2	6.2	124.5	3,374,629.1	2,020.7	1.2	1.0
12/28/2020 17:00	8.2	13.0	6.1	151.4	3,378,016.1	2,195.4	1.5	1.3
12/28/2020 18:00	8.1	13.0	6.0	152.3	3,380,477.9	2,197.0	1.5	1.3
12/28/2020 19:00	7.9	13.0	5.9	150.0	3,389,402.3	2,202.8	1.5	1.3
12/28/2020 20:00	8.0	13.0	6.0	149.6	3,386,324.9	2,200.8	1.5	1.3
12/28/2020 21:00	7.9	13.0	5.9	145.6	3,400,062.9	2,184.9	1.4	1.1
12/28/2020 22:00	7.8	13.0	5.8	139.5	3,399,635.4	2,159.8	1.3	1.1
12/28/2020 23:00	7.8	13.1	5.9	135.4	3,402,616.8	2,112.0	1.3	1.1
Average/Sum#:	7.5	13.3	5.8	122.2	3,345,006.9	1,946.4	1.2	0.9
Minimum:	6.4	13.0	5.2	97.3	3,228,515.8	1,650.3	1.0	0.7
Maximum:	8.7	13.7	6.5	152.3	3,402,616.8	2,202.8	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/29/2020 00:00	7.9	13.1	6.0	135.2	3,434,646.8	2,106.8	1.3	1.1
12/29/2020 01:00	7.7	13.2	5.9	127.8	3,367,794.0	2,041.2	1.2	1.0
12/29/2020 02:00	6.4	13.7	5.2	100.0	3,338,265.4	1,706.4	1.0	0.7
12/29/2020 03:00	7.3	13.5	5.8	108.3	3,399,873.6	1,837.2	1.0	0.7
12/29/2020 04:00	8.2	13.1	6.2	132.7	3,459,199.0	2,096.6	1.2	1.0
12/29/2020 05:00	8.0	13.1	6.1	139.0	3,448,830.1	2,115.5	1.3	1.1
12/29/2020 06:00	8.1	13.0	6.0	152.2	3,442,390.5	2,212.1	1.5	1.3
12/29/2020 07:00	8.4	13.0	6.3	143.3	3,435,996.0	2,182.9	1.4	1.1
12/29/2020 08:00	8.0	13.1	6.1	144.2	3,441,873.0	2,161.5	1.4	1.1
12/29/2020 09:00	6.7	13.5	5.3	109.5	3,270,002.8	1,790.9	1.1	0.7
12/29/2020 10:00	6.6	13.7	5.4	101.4	3,294,248.2	1,683.9	1.0	0.7
12/29/2020 11:00	6.7	13.8	5.6	101.4	3,265,294.6	1,669.1	1.0	0.7
12/29/2020 12:00	6.7	13.8	5.6	102.5	3,315,767.7	1,694.9	1.0	0.7
12/29/2020 13:00	6.7	13.8	5.6	100.4	3,273,718.1	1,649.5	1.0	0.7
12/29/2020 14:00	6.8	13.8	5.7	102.1	3,334,052.2	1,679.9	1.0	0.7
12/29/2020 15:00	6.8	13.8	5.7	101.7	3,321,548.8	1,673.6	1.0	0.7
12/29/2020 16:00	7.3	13.7	6.0	101.1	3,275,045.9	1,698.0	1.0	0.7
12/29/2020 17:00	8.6	13.1	6.5	143.5	3,420,016.6	2,122.8	1.4	1.1
12/29/2020 18:00	8.3	13.0	6.2	159.4	3,387,248.1	2,201.4	1.5	1.3
12/29/2020 19:00	8.2	13.0	6.1	160.6	3,385,709.5	2,200.4	1.6	1.3
12/29/2020 20:00	8.0	13.1	6.1	143.1	3,429,360.9	2,128.6	1.4	1.1
12/29/2020 21:00	7.9	13.2	6.1	134.2	3,420,426.1	2,073.1	1.3	1.0
12/29/2020 22:00	7.9	13.2	6.1	132.6	3,428,675.7	2,078.1	1.3	1.0
12/29/2020 23:00	7.7	13.2	5.9	125.7	3,446,215.6	2,038.4	1.2	1.0
Average/Sum#:	7.5	13.4	5.9	125.1	3,376,508.3	1,951.8	1.2	0.9
Minimum:	6.4	13.0	5.2	100.0	3,265,294.6	1,649.5	1.0	0.7
Maximum:	8.6	13.8	6.5	160.6	3,459,199.0	2,212.1	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/30/2020 00:00	7.7	13.3	6.0	120.0	3,478,509.1	2,032.1	1.1	0.8
12/30/2020 01:00	6.6	13.4	5.2	106.3	3,475,995.5	1,929.1	1.0	0.8
12/30/2020 02:00	6.3	13.7	5.2	99.1	3,311,855.1	1,692.9	1.0	0.7
12/30/2020 03:00	7.0	13.6	5.7	100.8	3,275,587.0	1,722.2	1.0	0.7
12/30/2020 04:00	8.1	13.2	6.2	115.9	3,540,664.3	2,016.7	1.0	0.8
12/30/2020 05:00	7.9	13.2	6.1	124.4	3,502,816.4	2,046.3	1.1	0.8
12/30/2020 06:00	7.9	13.1	6.0	139.9	3,480,110.1	2,160.1	1.3	1.1
12/30/2020 07:00	7.9	13.2	6.1	124.8	3,496,596.9	2,068.2	1.1	0.8
12/30/2020 08:00	7.8	13.2	6.0	117.4	3,518,380.6	2,029.7	1.1	0.8
12/30/2020 09:00	7.0	13.4	5.5	108.6	3,459,486.1	1,945.2	1.0	0.8
12/30/2020 10:00	6.4	13.7	5.2	99.4	3,290,090.3	1,705.8	1.0	0.7
12/30/2020 11:00	6.5	13.7	5.3	98.7	3,312,050.7	1,693.0	0.9	0.5
12/30/2020 12:00	6.6	13.7	5.4	99.4	3,305,203.6	1,689.5	1.0	0.7
12/30/2020 13:00	6.6	13.7	5.4	97.2	3,222,451.2	1,647.2	1.0	0.7
12/30/2020 14:00	6.7	13.7	5.5	97.4	3,219,908.0	1,645.9	1.0	0.7
12/30/2020 15:00	7.2	13.6	5.8	102.3	3,273,875.3	1,721.3	1.0	0.7
12/30/2020 16:00	8.2	13.2	6.3	119.0	3,458,994.8	2,020.7	1.1	0.8
12/30/2020 17:00	8.2	13.0	6.1	134.4	3,404,066.8	2,112.9	1.3	1.1
12/30/2020 18:00	8.0	13.0	6.0	134.1	3,387,633.7	2,102.7	1.3	1.1
12/30/2020 19:00	7.8	13.1	5.9	123.1	3,415,878.8	2,045.4	1.2	1.0
12/30/2020 20:00	7.9	13.1	6.0	124.3	3,404,917.0	2,063.7	1.2	1.0
12/30/2020 21:00	7.9	13.1	6.0	125.0	3,390,562.8	2,055.0	1.2	1.0
12/30/2020 22:00	7.9	13.1	6.0	122.1	3,393,834.4	2,032.2	1.2	1.0
12/30/2020 23:00	7.7	13.1	5.8	117.2	3,416,798.4	2,021.0	1.1	0.8
Average/Sum#:	7.4	13.3	5.8	114.6	3,393,177.8	1,925.0	1.1	0.8
Minimum:	6.3	13.0	5.2	97.2	3,219,908.0	1,645.9	0.9	0.5
Maximum:	8.2	13.7	6.3	139.9	3,540,664.3	2,160.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/31/2020 00:00	6.9	13.3	5.4	107.2	3,414,312.9	1,919.8	1.0	0.8
12/31/2020 01:00	6.5	13.7	5.3	96.5	3,135,403.2	1,625.6	1.0	0.7
12/31/2020 02:00	7.3	13.5	5.8	107.1	3,374,890.9	1,823.7	1.0	0.7
12/31/2020 03:00	7.2	13.3	5.6	108.4	3,460,908.9	1,946.0	1.0	0.8
12/31/2020 04:00	7.1	13.3	5.5	107.7	3,431,208.4	1,929.3	1.0	0.8
12/31/2020 05:00	6.5	13.7	5.3	99.8	3,271,188.4	1,696.0	1.0	0.7
12/31/2020 06:00	6.6	13.7	5.4	99.9	3,262,894.7	1,691.7	1.0	0.7
12/31/2020 07:00	6.9	13.7	5.7	98.8	3,175,135.8	1,646.2	1.0	0.7
12/31/2020 08:00	6.8	13.7	5.6	95.7	3,082,169.2	1,598.0	1.0	0.6
12/31/2020 09:00	6.8	13.7	5.6	99.3	3,211,203.7	1,664.9	1.0	0.7
12/31/2020 10:00	6.9	13.7	5.7	100.9	3,304,812.3	1,689.3	1.0	0.7
12/31/2020 11:00	7.0	13.7	5.7	101.6	3,299,139.0	1,686.4	1.0	0.7
12/31/2020 12:00	6.9	13.7	5.7	99.4	3,232,819.7	1,652.5	1.0	0.7
12/31/2020 13:00	7.5	13.7	6.1	99.3	3,218,342.9	1,645.1	1.0	0.7
12/31/2020 14:00	7.3	13.7	6.0	101.2	3,233,602.2	1,652.9	1.0	0.7
12/31/2020 15:00	7.4	13.7	6.1	103.5	3,327,701.3	1,701.0	1.0	0.7
12/31/2020 16:00	8.1	13.5	6.5	111.3	3,327,153.5	1,822.2	1.1	0.7
12/31/2020 17:00	8.7	13.1	6.6	127.6	3,400,462.2	2,061.0	1.2	1.0
12/31/2020 18:00	8.5	13.0	6.3	132.5	3,383,928.2	2,100.4	1.3	1.1
12/31/2020 19:00	8.3	13.0	6.2	131.1	3,425,028.2	2,100.9	1.2	1.1
12/31/2020 20:00	8.4	13.0	6.3	132.1	3,424,213.1	2,100.4	1.2	1.1
12/31/2020 21:00	8.4	13.0	6.3	132.4	3,421,767.7	2,098.9	1.3	1.0
12/31/2020 22:00	8.1	13.1	6.1	126.8	3,460,683.9	2,097.5	1.2	1.0
12/31/2020 23:00	8.1	13.1	6.1	124.7	3,451,784.5	2,066.9	1.2	1.0
Average/Sum#:	7.4	13.4	5.9	110.2	3,322,114.8	1,834.0	1.1	0.8
Minimum:	6.5	13.0	5.3	95.7	3,082,169.2	1,598.0	1.0	0.6
Maximum:	8.7	13.7	6.6	132.5	3,460,908.9	2,100.9	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:01 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:02 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,989.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 219.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,989.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:03 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:04 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,060.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 148.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,060.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9

Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:05 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
October	4.2	1.4	0.6	3.1	0.0
November	3.9	1.2	0.6	3.4	0.0
December	4.4	1.1	0.7	3.8	0.0
Quarter 4	12.5	3.7	1.9	10.3	0.0
YTD	12.5	3.7	1.9	10.3	0.0

Cumulative Emissions Report

CT1

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:06 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
October	9,851,871	891,668	10,743,536.3	610	147.1
November	11,428,439	814,189	12,242,627.8	697	128.9
December	11,605,643	1,128,456	12,734,098.7	682	149.3
Quarter 4	32,885,953	2,834,313	35,720,262.8	1,989	141.8
YTD	32,885,953	2,834,313	35,720,262.8	1,989	141.8

Cumulative Emissions Report

CT2

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:06 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
October	10,215,372	866,223	11,081,590.3	634	73,381.5
November	11,309,578	781,262	12,090,835.3	686	77,295.5
December	12,690,291	1,147,836	13,838,124.4	740	87,766.3
Quarter 4	34,215,241	2,795,321	37,010,550.0	2,060	238,443.3
YTD	34,215,241	2,795,321	37,010,550.0	2,060	238,443.3

Monthly Summary By Day Report

VOC PM10

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:07 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
10/01/2020	32.9	117.2	13.5	138.4
10/02/2020	32.1	115.5	13.3	136.3
10/03/2020	17.4	62.3	5.5	56.7
10/04/2020	17.7	63.2	5.8	58.3
10/05/2020	29.1	104.1	12.2	123.1
10/06/2020	21.1	75.5	6.7	69.8
10/07/2020	30.3	107.8	12.5	127.8
10/08/2020	0.0	0.0	0.0	0.0
10/09/2020	0.0	0.0	0.0	0.0
10/10/2020	0.0	0.0	0.0	0.0
10/11/2020	0.0	0.0	9.2	91.1
10/12/2020	13.9	49.8	11.4	113.1
10/13/2020	29.3	104.3	12.2	123.5
10/14/2020	31.8	112.8	13.1	133.3
10/15/2020	32.3	115.5	13.4	136.2
10/16/2020	32.2	114.9	13.3	135.4
10/17/2020	30.5	109.2	12.7	128.9
10/18/2020	24.2	87.0	11.9	120.5
10/19/2020	30.6	109.7	12.7	129.4
10/20/2020	31.0	110.3	12.8	130.4
10/21/2020	32.4	115.3	13.4	135.6
10/22/2020	31.9	114.1	13.3	135.4
10/23/2020	32.1	114.5	13.3	136.0
10/24/2020	29.6	105.3	12.4	125.5
10/25/2020	29.2	104.0	12.4	123.6
10/26/2020	32.1	114.0	13.4	135.1
10/27/2020	34.9	124.6	14.0	146.3
10/28/2020	29.5	105.4	12.5	127.6
10/29/2020	30.5	107.4	12.0	119.9
10/30/2020	33.6	119.2	13.6	138.3
10/31/2020	29.5	105.1	12.6	125.3
Monthly Avg/Sum*:	781.7 *	2,788.0 *	335.1 *	3,400.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	34.9	124.6	14.0	146.3
Oct 2020 - Oct 2020	781.7	2,788.0	335.1	3,400.8
QTD:	781.7 *	2,788.0 *	335.1 *	3,400.8 *
YTD 2020:	5,697.8 *	20,336.0 *	2,515.7 *	25,421.0 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:07 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
11/01/2020	31.4	112.3	13.0	132.3
11/02/2020	32.8	116.8	13.4	137.9
11/03/2020	32.6	116.1	13.4	137.3
11/04/2020	33.1	117.9	13.5	139.0
11/05/2020	32.8	116.8	13.5	137.9
11/06/2020	29.7	106.1	12.4	125.9
11/07/2020	29.3	104.9	12.5	124.6
11/08/2020	29.9	105.8	12.6	125.7
11/09/2020	31.0	110.3	13.0	130.5
11/10/2020	32.1	113.6	13.4	134.8
11/11/2020	31.1	110.5	13.2	131.1
11/12/2020	31.3	111.9	13.3	133.0
11/13/2020	29.1	103.0	12.3	122.9
11/14/2020	28.7	101.9	9.6	96.5
11/15/2020	29.0	103.9	12.4	123.8
11/16/2020	30.7	109.2	12.8	129.9
11/17/2020	31.4	112.0	13.2	132.6
11/18/2020	30.5	108.5	13.0	128.4
11/19/2020	29.1	104.0	12.5	123.7
11/20/2020	32.4	114.9	13.5	136.7
11/21/2020	31.4	112.2	13.1	132.9
11/22/2020	30.2	106.6	12.7	127.1
11/23/2020	29.4	104.4	11.1	110.1
11/24/2020	32.1	113.7	13.4	135.1
11/25/2020	28.8	102.2	12.3	122.0
11/26/2020	0.2	0.8	0.0	0.0
11/27/2020	28.0	100.1	10.1	101.2
11/28/2020	31.0	111.1	13.1	131.8
11/29/2020	31.0	109.8	13.0	130.6
11/30/2020	32.2	114.9	13.3	135.7
Monthly Avg/Sum*:	892.3 *	3,176.2 *	368.6 *	3,711.0 *
Daily Min:	0.2	0.8	0.0	0.0
Daily Max:	33.1	117.9	13.5	139.0
Oct 2020 - Nov 2020	1,674.0	5,964.2	703.7	7,111.8
QTD:	1,674.0 *	5,964.2 *	703.7 *	7,111.8 *
YTD 2020:	6,590.1 *	23,512.2 *	2,884.3 *	29,132.0 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:07 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
12/01/2020	33.4	118.6	13.6	139.6
12/02/2020	33.2	118.3	13.9	139.9
12/03/2020	34.3	121.6	14.3	143.6
12/04/2020	34.5	122.3	14.3	144.4
12/05/2020	33.7	119.5	14.0	141.3
12/06/2020	32.8	116.3	13.9	138.4
12/07/2020	33.7	120.7	13.8	142.1
12/08/2020	33.0	117.0	13.7	138.9
12/09/2020	33.7	120.7	13.6	141.9
12/10/2020	33.4	120.0	13.6	140.7
12/11/2020	32.8	117.0	13.7	137.6
12/12/2020	32.9	116.8	13.3	137.0
12/13/2020	31.8	113.5	13.2	133.5
12/14/2020	0.1	0.5	10.5	102.8
12/15/2020	0.0	0.0	14.7	146.9
12/16/2020	11.1	39.9	14.2	142.8
12/17/2020	33.3	117.5	13.6	139.4
12/18/2020	31.9	113.3	13.2	133.7
12/19/2020	32.2	114.8	13.5	135.5
12/20/2020	31.1	111.2	13.0	131.3
12/21/2020	32.4	115.4	13.4	136.5
12/22/2020	31.8	113.7	13.2	134.1
12/23/2020	33.1	118.2	14.0	139.5
12/24/2020	32.8	116.6	13.5	137.6
12/25/2020	31.5	112.0	13.2	132.8
12/26/2020	31.0	110.1	13.0	130.4
12/27/2020	31.8	113.3	13.3	134.3
12/28/2020	33.6	119.0	14.1	140.2
12/29/2020	33.6	119.2	13.9	140.3
12/30/2020	32.7	117.2	13.6	138.7
12/31/2020	31.4	111.6	13.0	132.3
Monthly Avg/Sum*:	928.6 *	3,305.8 *	419.8 *	4,248.0 *
Daily Min:	0.0	0.0	10.5	102.8
Daily Max:	34.5	122.3	14.7	146.9
Oct 2020 - Dec 2020	2,602.6	9,270.0	1,123.5	11,359.8
QTD:	2,602.6 *	9,270.0 *	1,123.5 *	11,359.8 *
YTD 2020:	7,518.7 *	26,818.0 *	3,304.1 *	33,380.0 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:13 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
10/01/2020	45.0	142.80	28.2	28.2	171.70	27.9
10/02/2020	38.4	138.60	27.8	28.6	162.60	27.3
10/03/2020	115.5	149.83	15.0	62.2	164.70	11.4
10/04/2020	113.6	191.31	15.2	60.7	164.21	11.6
10/05/2020	37.8	126.95	24.7	29.4	146.45	24.6
10/06/2020	70.6	162.62	18.1	43.3	182.06	14.0
10/07/2020	50.3	133.62	26.0	33.7	157.55	25.8
10/08/2020	0.0	0.00	0.0	0.0	0.00	0.0
10/09/2020	0.0	0.00	0.0	0.0	0.00	0.0
10/10/2020	0.0	0.00	0.0	0.0	0.00	0.0
10/11/2020	0.0	0.00	0.0	272.9	311.64	18.2
10/12/2020	133.4	216.03	11.9	22.8	113.00	22.6
10/13/2020	23.7	129.00	25.0	27.1	130.60	25.0
10/14/2020	53.9	135.20	27.2	24.8	155.10	26.8
10/15/2020	68.3	146.30	27.4	27.4	163.90	27.3
10/16/2020	64.7	143.20	27.6	24.7	163.50	27.1
10/17/2020	51.7	137.40	26.3	22.3	148.50	25.9
10/18/2020	77.0	160.67	21.0	16.7	115.00	24.2
10/19/2020	52.6	138.80	26.5	20.0	141.90	26.1
10/20/2020	54.6	140.80	26.5	20.9	147.30	26.0
10/21/2020	55.0	143.10	27.7	18.8	159.90	27.0
10/22/2020	66.7	143.20	27.6	26.7	159.40	27.1
10/23/2020	68.8	147.50	27.5	27.7	159.30	27.2
10/24/2020	51.8	129.80	25.4	23.2	126.50	25.4
10/25/2020	44.3	127.00	25.1	21.0	114.00	24.9
10/26/2020	60.1	150.00	27.3	26.1	150.90	26.9
10/27/2020	80.2	162.40	29.7	30.0	185.60	29.5
10/28/2020	56.9	130.90	25.4	24.9	138.90	25.7
10/29/2020	65.4	141.70	26.0	22.6	115.80	24.0
10/30/2020	82.0	148.80	28.7	28.5	167.40	27.9
10/31/2020	59.1	165.10	25.0	22.5	125.20	24.9
Monthly Avg/Sum*:	1,741.4 *	3,982.63 *	669.8 *	1,037.7 *	4,342.61 *	682.3 *
Daily Min:	23.7	126.95	11.9	16.7	113.00	11.4
Daily Max:	133.4	216.03	29.7	272.9	311.64	29.5
Oct 2020 - Oct 2020	1,741.4	3,982.63	669.8	1,037.7	4,342.61	682.3
QTD:	1,741.4 *	3,982.63 *	669.8 *	1,037.7 *	4,342.61 *	682.3 *
YTD 2020:	16,875.3 *	32,333.65 *	4,898.7 *	9,431.6 *	34,354.36 *	5,085.7 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:13 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
11/01/2020	66.4	156.30	26.7	23.8	144.80	26.5
11/02/2020	67.9	145.00	28.0	23.8	163.80	27.8
11/03/2020	69.8	141.80	27.9	24.6	155.20	27.7
11/04/2020	72.5	141.30	28.1	26.0	160.10	28.0
11/05/2020	71.8	140.30	28.2	25.5	163.10	27.5
11/06/2020	66.1	124.20	25.8	23.8	135.30	25.3
11/07/2020	58.9	54.20	25.0	23.6	125.60	24.8
11/08/2020	31.7	104.70	25.4	21.5	115.70	24.9
11/09/2020	35.6	119.10	26.6	24.0	144.40	26.2
11/10/2020	45.4	125.50	27.0	27.8	152.80	26.9
11/11/2020	43.3	116.50	26.3	27.1	139.40	26.1
11/12/2020	45.6	119.60	26.7	26.7	139.10	26.4
11/13/2020	40.2	110.20	24.8	24.4	128.00	24.6
11/14/2020	30.8	98.80	24.2	74.7	145.49	19.2
11/15/2020	33.0	108.70	24.8	23.0	109.40	24.7
11/16/2020	37.6	107.50	26.3	24.0	138.60	26.0
11/17/2020	46.5	126.60	26.6	27.5	148.10	26.4
11/18/2020	49.7	120.50	26.0	27.2	141.80	25.7
11/19/2020	37.7	104.70	25.0	22.3	114.60	24.8
11/20/2020	46.1	126.90	27.8	27.9	158.20	27.4
11/21/2020	43.3	119.60	27.2	25.8	138.70	26.7
11/22/2020	38.6	108.90	25.7	22.5	120.40	25.3
11/23/2020	33.6	104.40	25.0	73.0	151.37	21.9
11/24/2020	49.1	121.60	27.2	25.2	147.40	27.0
11/25/2020	42.6	123.99	24.4	29.5	119.30	24.3
11/26/2020	62.6	73.64	0.2	0.0	0.00	0.0
11/27/2020	122.6	199.80	24.0	117.8	225.40	20.2
11/28/2020	43.5	128.20	26.5	25.8	132.10	26.4
11/29/2020	37.4	125.50	26.2	24.1	123.80	26.1
11/30/2020	47.5	130.30	27.5	27.4	151.80	27.3
Monthly Avg/Sum*:	1,517.4 *	3,628.33 *	761.1 *	920.3 *	4,133.76 *	742.1 *
Daily Min:	30.8	54.20	0.2	21.5	109.40	19.2
Daily Max:	122.6	199.80	28.2	117.8	225.40	28.0
Oct 2020 - Nov 2020	3,258.8	7,610.96	1,430.9	1,958.0	8,476.37	1,424.4
QTD:	3,258.8 *	7,610.96 *	1,430.9 *	1,958.0 *	8,476.37 *	1,424.4 *
YTD 2020:	18,392.7 *	35,961.98 *	5,659.8 *	10,351.9 *	38,488.12 *	5,827.8 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:13 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
12/01/2020	44.7	140.00	28.0	23.3	161.90	27.9
12/02/2020	53.9	137.10	28.3	28.4	164.80	28.2
12/03/2020	54.5	145.40	29.4	29.9	171.30	28.9
12/04/2020	60.3	145.30	29.3	30.5	173.80	29.1
12/05/2020	55.1	140.00	28.7	30.2	157.60	28.5
12/06/2020	53.3	128.60	28.0	28.2	154.10	27.4
12/07/2020	55.5	143.00	28.9	26.8	171.00	28.5
12/08/2020	55.9	137.40	28.2	29.1	164.00	27.8
12/09/2020	56.6	150.10	29.3	30.3	176.10	28.7
12/10/2020	54.2	136.30	28.7	28.2	166.30	28.2
12/11/2020	52.0	128.60	28.3	29.1	150.30	27.8
12/12/2020	53.4	141.90	28.3	27.8	145.50	27.5
12/13/2020	58.7	134.30	27.1	31.2	146.50	26.9
12/14/2020	6.1	2.54	0.1	75.2	167.79	20.5
12/15/2020	0.0	0.00	0.0	48.0	184.20	29.7
12/16/2020	146.1	185.30	9.5	42.0	170.90	29.0
12/17/2020	16.9	141.00	28.2	31.4	156.50	27.7
12/18/2020	19.8	137.70	27.2	27.4	135.20	26.7
12/19/2020	17.5	139.60	27.5	26.6	138.30	27.0
12/20/2020	15.7	131.80	26.3	24.3	123.50	26.2
12/21/2020	24.6	140.30	27.7	32.9	146.80	27.3
12/22/2020	23.3	138.40	27.1	28.2	135.00	26.9
12/23/2020	21.2	140.30	28.4	28.8	153.30	27.8
12/24/2020	28.2	139.60	27.8	31.0	149.20	27.6
12/25/2020	24.9	145.00	27.1	30.4	135.00	26.4
12/26/2020	19.4	143.80	26.4	27.0	131.50	25.8
12/27/2020	19.6	141.40	26.9	28.7	135.10	26.7
12/28/2020	19.3	147.60	28.5	27.7	157.60	28.0
12/29/2020	19.2	142.90	28.5	27.0	156.80	28.0
12/30/2020	30.7	147.00	27.8	34.4	153.90	27.5
12/31/2020	21.8	147.20	26.9	27.5	126.90	26.7
Monthly Avg/Sum*:	1,182.4 *	4,119.44 *	792.4 *	971.5 *	4,760.69 *	850.9 *
Daily Min:	6.1	2.54	0.1	23.3	123.50	20.5
Daily Max:	146.1	185.30	29.4	75.2	184.20	29.7
Oct 2020 - Dec 2020	4,441.2	11,730.40	2,223.3	2,929.5	13,237.06	2,275.3
QTD:	4,441.2 *	11,730.40 *	2,223.3 *	2,929.5 *	13,237.06 *	2,275.3 *
YTD 2020:	19,575.1 *	40,081.42 *	6,452.2 *	11,323.4 *	43,248.81 *	6,678.7 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020	24.00	397,061.6	17.75	53,590.5	450,652.1	3,907.2	46,777.600
10/02/2020	24.00	396,321.5	14.51	48,575.2	444,896.7	3,729.8	46,180.400
10/03/2020	14.62	217,018.5	6.98	22,234.1	239,252.6	2,421.0	24,834.372
10/04/2020	14.95	225,320.6	7.61	18,722.6	244,043.2	2,202.0	25,331.655
10/05/2020	22.50	365,066.2	10.98	35,128.8	400,195.0	3,417.6	41,540.250
10/06/2020	17.37	265,367.3	8.05	25,492.1	290,859.4	2,663.2	30,191.159
10/07/2020	23.48	378,671.6	13.49	36,608.4	415,280.1	3,626.9	43,106.268
10/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/09/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/10/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/11/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/12/2020	11.70	178,675.0	6.65	13,274.4	191,949.4	1,783.7	19,924.350
10/13/2020	24.00	381,550.1	9.26	19,609.1	401,159.2	3,025.0	41,640.400
10/14/2020	24.00	396,317.1	14.58	38,834.0	435,151.1	3,622.2	45,168.600
10/15/2020	24.00	393,428.1	15.18	51,121.6	444,549.7	4,043.6	46,144.400
10/16/2020	24.00	394,409.9	15.80	48,502.8	442,912.7	3,952.8	45,974.300
10/17/2020	24.00	386,949.8	11.45	33,148.2	420,098.0	3,404.7	43,606.100
10/18/2020	20.88	322,423.8	4.90	12,842.3	335,266.1	2,905.5	34,800.653
10/19/2020	24.00	391,409.8	11.52	31,214.4	422,624.2	3,463.4	43,868.300
10/20/2020	24.00	388,127.3	13.35	37,612.2	425,739.5	3,542.1	44,191.700
10/21/2020	24.00	392,538.8	15.78	52,976.3	445,515.1	3,798.9	46,244.600
10/22/2020	24.00	400,596.1	15.82	39,232.0	439,828.1	3,696.0	45,654.100
10/23/2020	24.00	407,908.1	14.95	33,216.9	441,125.0	3,524.3	45,788.900
10/24/2020	24.00	391,202.6	7.70	14,680.5	405,883.1	3,001.8	42,130.500
10/25/2020	24.00	384,243.9	6.01	16,819.9	401,063.8	2,949.9	41,630.200
10/26/2020	24.00	404,386.6	13.31	35,424.6	439,811.2	3,479.0	45,652.400
10/27/2020	24.00	412,740.4	20.89	67,581.4	480,321.8	4,380.4	49,857.300
10/28/2020	24.00	385,763.0	8.49	20,429.0	406,192.0	3,108.4	42,162.700
10/29/2020	24.00	394,973.5	8.50	19,005.0	413,978.5	3,316.3	42,970.900
10/30/2020	24.00	410,074.5	18.25	49,518.0	459,592.5	3,896.8	47,705.600
10/31/2020	24.00	389,321.8	8.33	16,274.4	405,596.2	2,745.4	42,100.800
Monthly Avg/Sum*:	605.50 *	9,851,867.5 *	320.09 *	891,668.7 *	10,743,536.3 *	89,607.9 *	1,115,178.507 *
Daily Min:	11.70	178,675.0	4.90	12,842.3	191,949.4	1,783.7	19,924.350
Daily Max:	24.00	412,740.4	20.89	67,581.4	480,321.8	4,380.4	49,857.300
Oct 2020 - Oct 2020	605.50	9,851,867.5	320.09	891,668.7	10,743,536.3	89,607.9	1,115,178.507
QTD:	605.50 *	9,851,867.5 *	320.09 *	891,668.7 *	10,743,536.3 *	89,607.9 *	1,115,178.507 *
YTD 2020:	4,476.44 *	72,351,274.0 *	2,372.42 *	6,890,684.0 *	79,241,958.3 *	647,182.8 *	8,135,964.745 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020	24.00	397,077.6	12.96	35,284.5	432,362.1	3,303.7	44,879.200
11/02/2020	24.00	404,382.9	14.72	46,681.0	451,063.9	3,746.5	46,820.400
11/03/2020	24.00	402,246.6	14.98	46,307.5	448,554.1	3,629.8	46,559.900
11/04/2020	24.00	406,942.1	15.68	47,629.7	454,571.8	3,702.8	47,184.700
11/05/2020	24.00	401,771.0	15.87	48,420.0	450,191.0	3,737.0	46,729.900
11/06/2020	24.00	379,153.3	12.26	30,209.5	409,362.8	3,181.1	42,491.800
11/07/2020	24.00	384,506.0	9.73	19,996.5	404,502.5	2,793.0	41,987.400
11/08/2020	24.00	390,887.7	8.09	17,112.4	408,000.1	2,841.6	42,350.300
11/09/2020	24.00	389,979.9	14.02	35,540.0	425,519.9	3,135.5	44,169.000
11/10/2020	24.00	402,752.0	15.76	34,828.6	437,580.6	3,167.4	45,420.800
11/11/2020	24.00	400,702.1	12.82	24,842.4	425,544.5	2,955.1	44,171.700
11/12/2020	24.00	401,586.7	13.02	29,887.0	431,473.7	3,064.7	44,787.000
11/13/2020	24.00	383,288.6	8.77	14,402.8	397,691.4	2,690.1	41,280.600
11/14/2020	24.00	380,083.9	6.78	12,578.4	392,662.3	2,656.6	40,758.300
11/15/2020	24.00	391,024.3	6.84	9,655.9	400,680.2	2,650.7	41,590.600
11/16/2020	24.00	391,348.3	12.15	29,687.9	421,036.2	3,067.9	43,703.800
11/17/2020	24.00	395,858.4	13.79	35,996.1	431,854.5	3,155.9	44,826.300
11/18/2020	24.00	391,676.3	13.29	24,968.4	416,644.7	2,943.3	43,247.600
11/19/2020	24.00	382,956.4	9.07	17,756.0	400,712.4	2,749.0	41,593.900
11/20/2020	24.00	403,425.2	15.78	39,588.2	443,013.4	3,348.9	45,984.900
11/21/2020	24.00	403,167.9	12.76	28,482.3	431,650.2	3,138.4	44,804.900
11/22/2020	24.00	392,131.5	9.74	19,650.9	411,782.4	2,859.1	42,742.900
11/23/2020	24.00	385,959.3	7.78	15,642.5	401,601.8	2,721.2	41,686.400
11/24/2020	24.00	401,985.2	13.39	35,948.9	437,934.1	3,175.4	45,457.800
11/25/2020	23.48	381,555.4	7.80	12,562.0	394,117.4	2,674.2	40,909.312
11/26/2020	0.68	3,057.3	0.00	0.0	3,057.3	0.0	317.356
11/27/2020	24.00	372,229.0	6.50	13,521.8	385,750.8	3,112.1	40,040.900
11/28/2020	24.00	401,709.9	11.72	25,509.0	427,218.9	3,070.7	44,345.500
11/29/2020	24.00	401,588.7	9.52	22,103.4	423,692.1	3,018.3	43,979.100
11/30/2020	24.00	403,406.3	14.74	39,394.4	442,800.7	3,409.9	45,962.600
Monthly Avg/Sum*:	696.16 *	11,428,439.8 *	340.33 *	814,188.0 *	12,242,627.8 *	89,699.9 *	1,270,784.868 *
Daily Min:	0.68	3,057.3	0.00	0.0	3,057.3	0.0	317.356
Daily Max:	24.00	406,942.1	15.87	48,420.0	454,571.8	3,746.5	47,184.700
Oct 2020 - Nov 2020	1,301.66	21,280,307.3	660.42	1,705,856.7	22,986,164.1	179,307.8	2,385,963.375
QTD:	1,301.66 *	21,280,307.3 *	660.42 *	1,705,856.7 *	22,986,164.1 *	179,307.8 *	2,385,963.375 *
YTD 2020:	5,172.60 *	83,779,713.8 *	2,712.75 *	7,704,872.0 *	91,484,586.1 *	736,882.7 *	9,406,749.613 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:30 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
12/01/2020	24.00	403,763.2	15.75	53,280.6	457,043.8	3,738.1	47,441.300
12/02/2020	24.00	409,255.8	16.10	46,475.9	455,731.7	3,616.8	47,305.100
12/03/2020	24.00	415,813.0	18.02	53,979.0	469,792.0	3,771.4	48,764.400
12/04/2020	24.00	416,392.4	18.94	54,956.1	471,348.5	3,742.8	48,925.800
12/05/2020	24.00	413,262.0	15.52	46,767.0	460,029.0	3,572.6	47,751.100
12/06/2020	24.00	411,143.6	14.54	37,878.8	449,022.4	3,356.7	46,608.400
12/07/2020	24.00	410,448.2	18.04	54,084.3	464,532.5	3,755.4	48,218.500
12/08/2020	24.00	408,357.1	16.62	43,045.1	451,402.2	3,545.1	46,855.800
12/09/2020	24.00	417,984.9	17.04	47,040.9	465,025.8	3,623.8	48,269.900
12/10/2020	24.00	408,721.7	17.26	53,195.4	461,917.1	3,750.6	47,946.900
12/11/2020	24.00	409,499.0	13.98	41,473.8	450,972.8	3,431.0	46,811.300
12/12/2020	24.00	408,644.1	14.08	40,553.5	449,197.6	3,395.2	46,626.900
12/13/2020	24.00	399,034.0	15.48	37,572.9	436,606.9	3,217.7	45,319.900
12/14/2020	0.27	1,878.4	0.00	0.0	1,878.4	170.6	194.967
12/15/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
12/16/2020	8.62	133,754.1	5.82	19,747.8	153,501.9	1,366.7	15,933.418
12/17/2020	24.00	414,021.4	16.42	38,505.0	452,526.4	3,537.7	46,972.300
12/18/2020	24.00	398,868.1	14.04	37,449.5	436,317.6	3,481.7	45,290.000
12/19/2020	24.00	410,377.0	12.84	31,693.6	442,070.6	3,459.5	45,886.700
12/20/2020	24.00	401,285.8	10.52	26,464.3	427,750.1	3,271.7	44,400.600
12/21/2020	24.00	413,999.4	14.02	30,550.2	444,549.6	3,427.2	46,144.200
12/22/2020	24.00	406,165.8	12.71	31,782.1	437,947.9	3,513.2	45,458.900
12/23/2020	24.00	415,125.8	15.21	40,260.5	455,386.3	3,876.5	47,269.000
12/24/2020	24.00	415,731.9	14.79	33,509.4	449,241.3	3,715.5	46,631.000
12/25/2020	24.00	407,232.2	12.27	24,957.1	432,189.3	3,422.9	44,861.400
12/26/2020	24.00	401,244.0	11.49	22,294.8	423,538.8	3,367.4	43,963.400
12/27/2020	24.00	406,825.3	12.17	29,714.3	436,539.6	3,507.8	45,312.800
12/28/2020	24.00	411,879.3	15.37	46,374.1	458,253.4	3,964.7	47,566.800
12/29/2020	24.00	412,886.6	15.25	46,134.3	459,020.9	4,015.1	47,646.200
12/30/2020	24.00	417,037.2	16.49	33,791.6	450,828.8	3,704.0	46,796.000
12/31/2020	24.00	405,012.5	11.00	24,923.0	429,935.5	3,368.0	44,627.200
Monthly Avg/Sum*:	680.89 *	11,605,643.8 *	421.78 *	1,128,454.9 *	12,734,098.7 *	101,687.4 *	1,321,800.185 *
Daily Min:	0.27	1,878.4	0.00	0.0	1,878.4	170.6	194.967
Daily Max:	24.00	417,984.9	18.94	54,956.1	471,348.5	4,015.1	48,925.800
Oct 2020 - Dec 2020	1,982.55	32,885,951.1	1,082.20	2,834,311.6	35,720,262.8	280,995.2	3,707,763.560
QTD:	1,982.55 *	32,885,951.1 *	1,082.20 *	2,834,311.6 *	35,720,262.8 *	280,995.2 *	3,707,763.560 *
YTD 2020:	5,853.49 *	95,385,357.6 *	3,134.53 *	8,833,326.9 *	104,218,684.8 *	838,570.1 *	10,728,549.798 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:32 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020	24.00	396,870.8	17.94	54,084.4	450,955.2	3,018.9	46,132.500
10/02/2020	24.00	396,601.1	14.50	47,167.1	443,768.2	2,927.6	45,397.600
10/03/2020	10.83	163,277.4	6.93	21,937.5	185,214.9	1,562.6	18,947.514
10/04/2020	10.87	170,944.4	7.61	18,647.1	189,591.5	1,351.8	19,395.167
10/05/2020	22.50	365,795.3	11.01	34,891.5	400,686.8	2,759.9	40,990.150
10/06/2020	12.73	201,754.3	8.05	25,196.1	226,950.4	1,679.6	23,217.031
10/07/2020	23.50	378,813.2	13.49	36,896.6	415,709.8	2,867.0	42,527.150
10/08/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/09/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/10/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/11/2020	22.70	290,777.4	3.98	6,368.2	297,145.6	2,485.6	30,397.930
10/12/2020	24.00	355,959.8	6.64	13,184.1	369,143.9	2,379.7	37,763.300
10/13/2020	24.00	382,730.7	9.26	19,769.5	402,500.2	2,591.5	41,175.600
10/14/2020	24.00	396,841.8	14.52	37,884.8	434,726.6	2,873.1	44,472.600
10/15/2020	24.00	394,038.1	15.16	49,974.2	444,012.3	3,043.9	45,422.100
10/16/2020	24.00	394,389.5	15.73	47,292.3	441,681.8	2,968.2	45,184.100
10/17/2020	24.00	387,993.1	11.45	31,804.5	419,797.6	2,701.6	42,945.100
10/18/2020	24.00	380,450.0	5.11	11,750.6	392,200.6	2,508.7	40,122.100
10/19/2020	24.00	392,438.1	11.49	29,209.6	421,647.7	2,680.6	43,134.900
10/20/2020	24.00	388,758.2	13.35	35,226.5	423,984.7	2,715.8	43,373.900
10/21/2020	24.00	392,733.6	15.76	48,399.7	441,133.3	2,892.9	45,128.000
10/22/2020	24.00	403,047.2	15.63	38,329.6	441,376.8	2,862.9	45,153.000
10/23/2020	24.00	409,632.6	14.97	33,698.0	443,330.6	2,775.5	45,352.600
10/24/2020	24.00	393,295.5	7.73	15,213.6	408,509.1	2,554.6	41,790.400
10/25/2020	24.00	386,832.4	6.00	15,985.6	402,818.0	2,601.5	41,208.300
10/26/2020	24.00	406,917.3	13.25	33,655.5	440,572.8	2,838.1	45,070.500
10/27/2020	24.00	414,299.0	20.89	63,821.8	478,120.8	3,231.8	48,911.800
10/28/2020	24.00	396,315.6	8.53	20,206.8	416,522.4	2,632.5	42,610.300
10/29/2020	24.00	371,360.1	8.52	19,167.0	390,527.1	2,474.1	39,950.800
10/30/2020	24.00	410,558.5	18.20	40,378.1	450,936.6	2,867.6	46,130.900
10/31/2020	24.00	391,947.2	8.33	16,077.8	408,025.0	2,533.9	41,741.100
Monthly Avg/Sum*:	631.13 *	10,215,372.2 *	324.03 *	866,218.1 *	11,081,590.3 *	73,381.5 *	1,133,646.442 *
Daily Min:	10.83	163,277.4	3.98	6,368.2	185,214.9	1,351.8	18,947.514
Daily Max:	24.00	414,299.0	20.89	63,821.8	478,120.8	3,231.8	48,911.800
Oct 2020 - Oct 2020	631.13	10,215,372.2	324.03	866,218.1	11,081,590.3	73,381.5	1,133,646.442
QTD:	631.13 *	10,215,372.2 *	324.03 *	866,218.1 *	11,081,590.3 *	73,381.5 *	1,133,646.442 *
YTD 2020:	4,818.89 *	76,026,685.0 *	2,413.39 *	6,638,693.4 *	82,665,378.9 *	547,651.5 *	8,473,804.100 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:32 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020	24.00	398,980.6	12.96	33,200.7	432,181.3	2,715.3	44,212.400
11/02/2020	24.00	405,546.0	14.72	43,466.8	449,012.8	2,894.2	45,933.800
11/03/2020	24.00	403,825.4	14.97	43,248.6	447,074.0	2,874.1	45,735.600
11/04/2020	24.00	408,505.7	15.68	44,326.3	452,832.0	2,912.5	46,324.700
11/05/2020	24.00	403,990.6	15.86	45,360.7	449,351.3	2,893.1	45,968.400
11/06/2020	24.00	380,738.9	12.24	29,191.8	409,930.7	2,622.3	41,936.000
11/07/2020	24.00	386,871.2	9.70	19,740.7	406,611.9	2,548.6	41,596.500
11/08/2020	24.00	393,219.1	8.19	16,721.9	409,941.0	2,589.3	41,937.000
11/09/2020	24.00	392,337.1	13.90	33,788.4	426,125.5	2,753.8	43,592.500
11/10/2020	24.00	404,921.2	15.75	34,052.7	438,973.9	2,776.7	44,907.000
11/11/2020	24.00	403,021.2	12.78	24,689.6	427,710.8	2,672.8	43,754.800
11/12/2020	24.00	403,820.4	12.88	28,817.0	432,637.4	2,754.7	44,258.700
11/13/2020	24.00	386,076.0	8.55	13,885.6	399,961.6	2,495.2	40,916.000
11/14/2020	18.94	301,288.6	6.80	12,505.8	313,794.4	2,373.6	32,101.226
11/15/2020	24.00	394,034.5	6.55	9,385.1	403,419.6	2,485.3	41,269.800
11/16/2020	24.00	393,121.4	12.26	29,390.8	422,512.2	2,653.0	43,223.400
11/17/2020	24.00	398,222.0	13.79	32,886.9	431,108.9	2,703.7	44,102.400
11/18/2020	24.00	393,918.6	13.07	24,098.1	418,016.7	2,598.9	42,763.000
11/19/2020	24.00	385,738.9	9.06	17,471.1	403,210.0	2,515.1	41,248.200
11/20/2020	24.00	407,677.6	15.66	37,446.4	445,124.0	2,844.3	45,536.200
11/21/2020	24.00	405,663.9	12.69	27,235.6	432,899.5	2,769.5	44,285.700
11/22/2020	24.00	394,533.7	9.74	19,572.8	414,106.5	2,603.3	42,363.200
11/23/2020	21.62	343,031.7	7.77	15,642.6	358,674.3	2,562.5	36,692.476
11/24/2020	24.00	404,347.2	13.39	35,971.2	440,318.4	2,813.4	45,044.600
11/25/2020	23.50	384,612.3	7.80	12,886.5	397,498.8	2,551.8	40,664.050
11/26/2020	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/27/2020	19.92	316,877.1	6.55	13,538.4	330,415.5	2,191.1	33,801.376
11/28/2020	24.00	404,640.7	11.75	24,764.3	429,405.0	2,699.2	43,928.100
11/29/2020	24.00	404,397.5	9.52	21,243.9	425,641.4	2,637.8	43,543.100
11/30/2020	24.00	405,616.8	14.60	36,729.1	442,345.9	2,790.4	45,252.300
Monthly Avg/Sum*:	683.98 *	11,309,575.9 *	339.18 *	781,259.4 *	12,090,835.3 *	77,295.5 *	1,236,892.528 *
Daily Min:	18.94	301,288.6	6.55	9,385.1	313,794.4	2,191.1	32,101.226
Daily Max:	24.00	408,505.7	15.86	45,360.7	452,832.0	2,912.5	46,324.700
Oct 2020 - Nov 2020	1,315.11	21,524,948.1	663.21	1,647,477.5	23,172,425.6	150,677.0	2,370,538.970
QTD:	1,315.11 *	21,524,948.1 *	663.21 *	1,647,477.5 *	23,172,425.6 *	150,677.0 *	2,370,538.970 *
YTD 2020:	5,502.87 *	87,336,260.9 *	2,752.57 *	7,419,952.8 *	94,756,214.2 *	624,947.0 *	9,710,696.628 *

Monthly Summary By Day Report

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:32 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020	24.00	405,665.7	15.75	48,864.0	454,529.7	3,048.1	46,498.100
12/02/2020	24.00	411,327.4	16.10	43,989.4	455,316.8	2,938.8	46,579.000
12/03/2020	24.00	417,607.0	18.02	50,671.9	468,278.9	3,053.3	47,905.000
12/04/2020	24.00	418,520.3	18.89	51,872.8	470,393.1	3,049.9	48,121.200
12/05/2020	24.00	416,598.9	15.52	43,819.0	460,417.9	2,972.9	47,100.800
12/06/2020	24.00	414,015.4	14.54	36,135.7	450,151.1	2,849.1	46,050.600
12/07/2020	24.00	411,855.8	18.03	50,876.6	462,732.4	3,086.4	47,337.800
12/08/2020	24.00	411,286.0	16.64	41,025.9	452,311.9	2,865.9	46,271.500
12/09/2020	24.00	419,738.5	16.83	41,860.7	461,599.2	2,971.4	47,221.200
12/10/2020	24.00	411,795.5	17.16	46,408.9	458,204.4	2,986.2	46,874.300
12/11/2020	24.00	412,248.1	13.98	36,595.4	448,843.5	2,832.1	45,917.000
12/12/2020	24.00	411,298.0	14.08	35,100.8	446,398.8	2,838.6	45,666.700
12/13/2020	24.00	401,304.2	15.48	34,748.7	436,052.9	2,713.3	44,608.600
12/14/2020	18.92	305,640.9	12.02	28,962.7	334,603.6	2,606.0	34,229.954
12/15/2020	24.00	429,542.8	24.00	49,202.0	478,744.8	2,993.6	48,975.600
12/16/2020	24.00	422,801.3	20.80	42,940.4	465,741.7	2,860.3	47,645.400
12/17/2020	24.00	416,787.9	16.52	37,143.7	453,931.6	2,777.0	46,437.100
12/18/2020	24.00	402,161.3	13.68	33,279.3	435,440.6	2,686.6	44,545.100
12/19/2020	24.00	412,604.9	12.84	29,043.3	441,648.2	2,698.1	45,180.900
12/20/2020	24.00	403,452.5	10.57	23,970.6	427,423.1	2,612.2	43,725.400
12/21/2020	24.00	415,278.3	13.91	29,109.6	444,387.9	2,681.9	45,461.000
12/22/2020	24.00	407,094.1	12.61	29,192.6	436,286.7	2,732.0	44,632.300
12/23/2020	24.00	416,600.3	15.10	37,004.9	453,605.2	2,888.7	46,403.800
12/24/2020	24.00	419,097.5	14.57	30,049.0	449,146.5	2,766.0	45,947.500
12/25/2020	24.00	409,274.3	12.03	23,330.3	432,604.6	2,642.0	44,255.300
12/26/2020	24.00	403,135.7	11.44	22,369.1	425,504.8	2,588.6	43,529.100
12/27/2020	24.00	409,082.1	12.13	28,344.4	437,426.5	2,697.1	44,748.400
12/28/2020	24.00	413,759.8	15.34	42,872.5	456,632.3	2,932.7	46,713.300
12/29/2020	24.00	414,488.5	15.18	43,408.5	457,897.0	3,001.9	46,842.800
12/30/2020	24.00	418,887.0	16.49	32,714.4	451,601.4	2,750.8	46,198.800
12/31/2020	24.00	407,339.9	10.89	22,927.4	430,267.3	2,644.8	44,016.600
Monthly Avg/Sum*:	738.92 *	12,690,289.9 *	471.14 *	1,147,834.5 *	13,838,124.4 *	87,766.3 *	1,415,640.154 *
Daily Min:	18.92	305,640.9	10.57	22,369.1	334,603.6	2,588.6	34,229.954
Daily Max:	24.00	429,542.8	24.00	51,872.8	478,744.8	3,086.4	48,975.600
Oct 2020 - Dec 2020	2,054.03	34,215,238.0	1,134.35	2,795,312.0	37,010,550.0	238,443.3	3,786,179.124
QTD:	2,054.03 *	34,215,238.0 *	1,134.35 *	2,795,312.0 *	37,010,550.0 *	238,443.3 *	3,786,179.124 *
YTD 2020:	6,241.79 *	100,026,550.8 *	3,223.71 *	8,567,787.3 *	108,594,338.6 *	712,713.3 *	11,126,336.782 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25
Title V: #6

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:34 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
10/01/2020	314.5	73.2	46.4	255.6	27.9
10/02/2020	301.2	67.0	45.4	251.8	27.3
10/03/2020	314.5	177.7	22.9	119.0	11.4
10/04/2020	355.5	174.3	23.5	121.5	11.6
10/05/2020	273.5	67.2	41.3	227.2	24.6
10/06/2020	344.7	113.9	27.8	145.3	14.0
10/07/2020	291.2	84.0	42.8	235.6	25.8
10/08/2020	0.0	0.0	0.0	0.0	0.0
10/09/2020	0.0	0.0	0.0	0.0	0.0
10/10/2020	0.0	0.0	0.0	0.0	0.0
10/11/2020	311.6	272.9	9.2	91.1	18.2
10/12/2020	329.0	156.2	25.3	162.9	22.6
10/13/2020	259.6	50.8	41.5	227.8	25.0
10/14/2020	290.3	78.7	44.9	246.1	26.8
10/15/2020	310.2	95.7	45.7	251.7	27.3
10/16/2020	306.7	89.4	45.5	250.3	27.1
10/17/2020	285.9	74.0	43.2	238.1	25.9
10/18/2020	275.7	93.7	36.1	207.5	24.2
10/19/2020	280.7	72.6	43.3	239.1	26.1
10/20/2020	288.1	75.5	43.8	240.7	26.0
10/21/2020	303.0	73.8	45.8	250.9	27.0
10/22/2020	302.6	93.4	45.2	249.5	27.1
10/23/2020	306.8	96.5	45.4	250.5	27.2
10/24/2020	256.3	75.0	42.0	230.8	25.4
10/25/2020	241.0	65.3	41.6	227.6	24.9
10/26/2020	300.9	86.2	45.5	249.1	26.9
10/27/2020	348.0	110.2	48.9	270.9	29.5
10/28/2020	269.8	81.8	42.0	233.0	25.7
10/29/2020	257.5	88.0	42.5	227.3	24.0
10/30/2020	316.2	110.5	47.2	257.5	27.9
10/31/2020	290.3	81.6	42.1	230.4	24.9
Monthly Avg/Sum*:	8,325.3 *	2,779.1 *	1,116.8 *	6,188.8 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	355.5	272.9	48.9	270.9	-
Oct 2020 - Oct 2020	8,325.3	2,779.1	1,116.8	6,188.8	-
QTD:	8,325.3 *	2,779.1 *	1,116.8 *	6,188.8 *	0.0 *
YTD 2020:	66,688.5 *	26,306.9 *	8,213.5 *	45,757.0 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:34 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
11/01/2020	301.1	90.2	44.4	244.6	26.5
11/02/2020	308.8	91.7	46.2	254.7	27.8
11/03/2020	297.0	94.4	46.0	253.4	27.7
11/04/2020	301.4	98.5	46.6	256.9	28.0
11/05/2020	303.4	97.3	46.3	254.7	27.5
11/06/2020	259.5	89.9	42.1	232.0	25.3
11/07/2020	179.8	82.5	41.8	229.5	24.8
11/08/2020	220.4	53.2	42.5	231.5	24.9
11/09/2020	263.5	59.6	44.0	240.8	26.2
11/10/2020	278.3	73.2	45.5	248.4	26.9
11/11/2020	255.9	70.4	44.3	241.6	26.1
11/12/2020	258.7	72.3	44.6	244.9	26.4
11/13/2020	238.2	64.6	41.4	225.9	24.6
11/14/2020	244.3	105.5	38.3	198.4	19.2
11/15/2020	218.1	56.0	41.4	227.7	24.7
11/16/2020	246.1	61.6	43.5	239.1	26.0
11/17/2020	274.7	74.0	44.6	244.6	26.4
11/18/2020	262.3	76.9	43.5	236.9	25.7
11/19/2020	219.3	60.0	41.6	227.7	24.8
11/20/2020	285.1	74.0	45.9	251.6	27.4
11/21/2020	258.3	69.1	44.5	245.1	26.7
11/22/2020	229.3	61.1	42.9	233.7	25.3
11/23/2020	255.8	106.6	40.5	214.5	21.9
11/24/2020	269.0	74.3	45.5	248.8	27.0
11/25/2020	243.3	72.1	41.1	224.2	24.3
11/26/2020	73.6	62.6	0.2	0.8	0.0
11/27/2020	425.2	240.4	38.1	201.3	20.2
11/28/2020	260.3	69.3	44.1	242.9	26.4
11/29/2020	249.3	61.5	44.0	240.4	26.1
11/30/2020	282.1	74.9	45.5	250.6	27.3
Monthly Avg/Sum*:	7,762.1 *	2,437.7 *	1,260.9 *	6,887.2 *	- *
Daily Min:	73.6	53.2	0.2	0.8	-
Daily Max:	425.2	240.4	46.6	256.9	-
Oct 2020 - Nov 2020	16,087.4	5,216.8	2,377.7	13,076.0	-
QTD:	16,087.4 *	5,216.8 *	2,377.7 *	13,076.0 *	0.0 *
YTD 2020:	74,450.6 *	28,744.6 *	9,474.4 *	52,644.2 *	46.1 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:34 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
12/01/2020	301.9	68.0	47.0	258.2	27.9
12/02/2020	301.9	82.3	47.1	258.2	28.2
12/03/2020	316.7	84.4	48.6	265.2	28.9
12/04/2020	319.1	90.8	48.8	266.7	29.1
12/05/2020	297.6	85.3	47.7	260.8	28.5
12/06/2020	282.7	81.5	46.7	254.7	27.4
12/07/2020	314.0	82.3	47.5	262.8	28.5
12/08/2020	301.4	85.0	46.7	255.9	27.8
12/09/2020	326.2	86.9	47.3	262.6	28.7
12/10/2020	302.6	82.4	47.0	260.7	28.2
12/11/2020	278.9	81.1	46.5	254.6	27.8
12/12/2020	287.4	81.2	46.2	253.8	27.5
12/13/2020	280.8	89.9	45.0	247.0	26.9
12/14/2020	170.3	81.3	10.6	103.3	20.5
12/15/2020	184.2	48.0	14.7	146.9	29.7
12/16/2020	356.2	188.1	25.3	182.7	29.0
12/17/2020	297.5	48.3	46.9	256.9	27.7
12/18/2020	272.9	47.2	45.1	247.0	26.7
12/19/2020	277.9	44.1	45.7	250.3	27.0
12/20/2020	255.3	40.0	44.1	242.5	26.2
12/21/2020	287.1	57.5	45.8	251.9	27.3
12/22/2020	273.4	51.5	45.0	247.8	26.9
12/23/2020	293.6	50.0	47.1	257.7	27.8
12/24/2020	288.8	59.2	46.3	254.2	27.6
12/25/2020	280.0	55.3	44.7	244.8	26.4
12/26/2020	275.3	46.4	44.0	240.5	25.8
12/27/2020	276.5	48.3	45.1	247.6	26.7
12/28/2020	305.2	47.0	47.7	259.2	28.0
12/29/2020	299.7	46.2	47.5	259.5	28.0
12/30/2020	300.9	65.1	46.3	255.9	27.5
12/31/2020	274.1	49.3	44.4	243.9	26.7
Monthly Avg/Sum*:	8,880.1 *	2,153.9 *	1,348.4 *	7,553.8 *	- *
Daily Min:	170.3	40.0	10.6	103.3	-
Daily Max:	356.2	188.1	48.8	266.7	-
Oct 2020 - Dec 2020	24,967.5	7,370.7	3,726.1	20,629.8	-
QTD:	24,967.5 *	7,370.7 *	3,726.1 *	20,629.8 *	0.0 *
YTD 2020:	83,330.7 *	30,898.5 *	10,822.8 *	60,198.0 *	46.1 *

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/01/2020 00:00	9.8	0.9	1.6	9.0	2.0
10/01/2020 01:00	12.5	2.1	1.8	9.8	2.2
10/01/2020 02:00	13.9	2.5	2.0	10.9	2.4
10/01/2020 03:00	13.9	1.8	2.0	10.9	2.4
10/01/2020 04:00	9.9	0.6	1.7	9.1	2.0
10/01/2020 05:00	12.7	4.3	1.8	10.0	2.2
10/01/2020 06:00	12.3	4.8	2.1	11.3	2.4
10/01/2020 07:00	12.7	4.0	1.9	10.0	2.2
10/01/2020 08:00	9.3	0.9	1.6	8.5	1.8
10/01/2020 09:00	5.3	0.5	1.3	7.3	1.6
10/01/2020 10:00	9.0	0.6	1.5	8.3	1.8
10/01/2020 11:00	16.4	4.5	2.0	11.3	2.4
10/01/2020 12:00	14.8	3.8	2.1	11.7	2.6
10/01/2020 13:00	15.1	3.5	2.1	11.9	2.6
10/01/2020 14:00	15.2	3.4	2.1	11.9	2.6
10/01/2020 15:00	15.0	3.4	2.1	11.8	2.6
10/01/2020 16:00	14.8	3.7	2.1	11.7	2.6
10/01/2020 17:00	14.8	3.7	2.1	11.6	2.6
10/01/2020 18:00	14.6	4.1	2.1	11.5	2.5
10/01/2020 19:00	14.6	3.7	2.1	11.5	2.5
10/01/2020 20:00	14.6	3.8	2.1	11.6	2.6
10/01/2020 21:00	14.8	3.8	2.1	11.6	2.6
10/01/2020 22:00	14.6	4.4	2.1	11.4	2.5
10/01/2020 23:00	13.9	4.4	2.0	11.0	2.4
Average/Sum#:	314.5 #	73.2 #	46.4 #	255.6 #	56.1 #
Minimum:	5.3	0.5	1.3	7.3	1.6
Maximum:	16.4	4.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/02/2020 00:00	9.5	0.9	1.6	8.7	1.9
10/02/2020 01:00	10.2	0.9	1.7	9.4	2.0
10/02/2020 02:00	7.8	1.2	1.6	8.5	1.8
10/02/2020 03:00	9.5	1.2	1.6	8.7	1.9
10/02/2020 04:00	10.0	2.7	1.7	9.2	2.0
10/02/2020 05:00	14.3	5.1	2.0	11.2	2.4
10/02/2020 06:00	14.0	5.1	2.0	11.0	2.4
10/02/2020 07:00	10.6	1.0	1.7	9.7	2.2
10/02/2020 08:00	7.3	1.1	1.4	8.1	1.8
10/02/2020 09:00	9.6	0.6	1.6	8.8	2.0
10/02/2020 10:00	9.8	0.6	1.6	9.0	2.0
10/02/2020 11:00	10.1	1.5	1.7	9.2	2.0
10/02/2020 12:00	14.7	4.4	2.1	11.5	2.5
10/02/2020 13:00	15.3	3.5	2.1	12.0	2.6
10/02/2020 14:00	15.2	3.3	2.1	12.0	2.6
10/02/2020 15:00	15.1	3.3	2.1	11.9	2.6
10/02/2020 16:00	15.2	3.3	2.1	11.9	2.6
10/02/2020 17:00	15.2	3.0	2.1	11.9	2.6
10/02/2020 18:00	14.9	3.5	2.1	11.7	2.6
10/02/2020 19:00	14.7	3.8	2.1	11.6	2.6
10/02/2020 20:00	14.9	3.8	2.1	11.7	2.6
10/02/2020 21:00	14.3	4.4	2.1	11.3	2.4
10/02/2020 22:00	14.5	4.4	2.1	11.3	2.5
10/02/2020 23:00	14.5	4.4	2.1	11.5	2.5
Average/Sum#:	301.2 #	67.0 #	45.4 #	251.8 #	55.1 #
Minimum:	7.3	0.6	1.4	8.1	1.8
Maximum:	15.3	5.1	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/03/2020 00:00	10.1	16.0	0.7	3.5	0.8
10/03/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 06:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 07:00	0.0	0.0	0.0	0.0	0.0
10/03/2020 08:00	19.8	12.0	0.1	0.4	0.1
10/03/2020 09:00	51.9	67.3	0.7	2.4	0.6
10/03/2020 10:00	2.8	0.0	1.0	3.5	0.8
10/03/2020 11:00	4.1	0.0	1.0	3.4	0.8
10/03/2020 12:00	56.4	15.1	1.2	4.8	1.2
10/03/2020 13:00	45.8	23.4	1.3	7.1	1.6
10/03/2020 14:00	9.7	0.6	1.6	8.9	2.0
10/03/2020 15:00	9.9	1.8	1.7	9.1	2.0
10/03/2020 16:00	14.6	4.0	2.1	11.5	2.5
10/03/2020 17:00	15.2	3.0	2.1	12.0	2.6
10/03/2020 18:00	15.0	3.0	2.1	11.9	2.6
10/03/2020 19:00	15.2	3.5	2.1	11.9	2.6
10/03/2020 20:00	14.7	3.8	2.1	11.5	2.5
10/03/2020 21:00	14.1	4.4	2.0	11.1	2.4
10/03/2020 22:00	15.2	19.8	1.1	6.0	1.3
10/03/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	314.5 #	177.7 #	22.9 #	119.0 #	26.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	56.4	67.3	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/04/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 06:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 07:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 08:00	0.0	0.0	0.0	0.0	0.0
10/04/2020 09:00	74.0	54.9	0.4	1.3	0.3
10/04/2020 10:00	39.2	35.2	0.8	2.9	0.7
10/04/2020 11:00	4.1	0.0	1.0	3.4	0.8
10/04/2020 12:00	4.1	0.0	1.0	3.4	0.8
10/04/2020 13:00	84.3	38.9	1.3	5.4	1.3
10/04/2020 14:00	23.9	7.6	1.4	7.9	1.7
10/04/2020 15:00	10.2	0.9	1.7	9.4	2.0
10/04/2020 16:00	14.7	4.0	1.8	10.0	2.2
10/04/2020 17:00	14.7	4.4	2.1	11.6	2.6
10/04/2020 18:00	14.3	4.7	2.0	11.3	2.4
10/04/2020 19:00	14.3	4.7	2.0	11.2	2.4
10/04/2020 20:00	14.3	4.7	2.0	11.2	2.4
10/04/2020 21:00	14.5	4.4	2.1	11.3	2.5
10/04/2020 22:00	13.6	4.8	2.0	10.7	2.4
10/04/2020 23:00	15.3	5.1	1.9	10.5	2.3
Average/Sum#:	355.5 #	174.3 #	23.5 #	121.5 #	26.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	84.3	54.9	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/05/2020 00:00	9.9	0.9	1.7	9.1	2.0
10/05/2020 01:00	9.9	1.2	1.7	9.0	2.0
10/05/2020 02:00	9.6	1.2	1.6	8.8	2.0
10/05/2020 03:00	9.4	0.9	1.6	8.7	1.8
10/05/2020 04:00	10.0	2.4	1.7	9.2	2.0
10/05/2020 05:00	14.4	5.4	2.0	11.3	2.4
10/05/2020 06:00	12.2	4.7	2.0	11.2	2.4
10/05/2020 07:00	9.3	0.9	1.6	8.5	1.8
10/05/2020 08:00	7.7	0.6	1.6	8.5	1.8
10/05/2020 09:00	8.0	0.6	1.6	8.8	2.0
10/05/2020 10:00	9.5	0.6	1.6	8.7	1.9
10/05/2020 11:00	9.9	0.6	1.7	9.0	2.0
10/05/2020 12:00	10.0	0.9	1.7	9.2	2.0
10/05/2020 13:00	12.6	3.1	1.8	9.9	2.2
10/05/2020 14:00	15.2	3.5	2.1	12.0	2.6
10/05/2020 15:00	15.3	3.0	2.1	12.0	2.6
10/05/2020 16:00	15.2	3.0	2.1	12.0	2.6
10/05/2020 17:00	15.1	3.1	2.1	11.9	2.6
10/05/2020 18:00	15.2	3.1	2.1	12.0	2.6
10/05/2020 19:00	14.4	3.8	2.1	11.3	2.4
10/05/2020 20:00	14.4	3.8	2.0	11.3	2.4
10/05/2020 21:00	14.4	4.4	2.1	11.3	2.4
10/05/2020 22:00	11.8	15.5	0.7	3.5	0.8
10/05/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	273.4 #	67.2 #	41.3 #	227.2 #	49.3 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	15.3	15.5	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/06/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/06/2020 06:00	24.7	10.4	0.1	0.4	0.1
10/06/2020 07:00	51.6	38.6	0.6	2.1	0.5
10/06/2020 08:00	2.8	0.0	1.0	3.5	0.8
10/06/2020 09:00	4.2	0.0	1.0	3.5	0.8
10/06/2020 10:00	4.2	0.0	1.0	3.5	0.8
10/06/2020 11:00	68.3	17.4	1.2	5.2	1.2
10/06/2020 12:00	40.5	12.5	1.4	7.7	1.7
10/06/2020 13:00	9.9	0.6	1.7	9.0	2.0
10/06/2020 14:00	12.2	2.3	1.7	9.6	2.1
10/06/2020 15:00	14.8	4.4	2.1	11.6	2.6
10/06/2020 16:00	15.0	3.4	2.1	11.9	2.6
10/06/2020 17:00	15.2	3.0	2.1	12.0	2.6
10/06/2020 18:00	15.2	3.0	2.1	12.0	2.6
10/06/2020 19:00	15.0	3.4	2.1	11.8	2.6
10/06/2020 20:00	10.0	1.5	1.7	9.2	2.0
10/06/2020 21:00	12.7	3.5	1.8	10.0	2.2
10/06/2020 22:00	14.5	4.8	2.1	11.4	2.5
10/06/2020 23:00	13.9	5.1	2.0	10.9	2.4
Average/Sum#:	344.7 #	113.9 #	27.8 #	145.3 #	32.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	68.3	38.6	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/07/2020 00:00	14.3	4.7	2.0	11.2	2.4
10/07/2020 01:00	13.7	4.8	2.0	10.9	2.4
10/07/2020 02:00	9.2	0.9	1.6	8.5	1.8
10/07/2020 03:00	9.6	0.6	1.6	8.8	2.0
10/07/2020 04:00	10.9	3.8	1.8	10.0	2.2
10/07/2020 05:00	14.8	5.1	2.1	11.6	2.6
10/07/2020 06:00	14.2	4.8	2.0	11.2	2.4
10/07/2020 07:00	9.6	1.2	1.6	8.8	2.0
10/07/2020 08:00	6.8	0.5	1.4	7.5	1.6
10/07/2020 09:00	6.5	0.5	1.3	7.2	1.6
10/07/2020 10:00	6.8	0.3	1.4	7.4	1.6
10/07/2020 11:00	12.4	2.8	1.8	9.8	2.2
10/07/2020 12:00	15.0	4.1	2.1	11.8	2.6
10/07/2020 13:00	15.1	3.8	2.1	11.9	2.6
10/07/2020 14:00	13.6	1.5	1.7	9.4	2.0
10/07/2020 15:00	12.5	3.3	1.8	9.8	2.2
10/07/2020 16:00	14.5	4.7	2.1	11.4	2.5
10/07/2020 17:00	15.0	4.0	2.1	11.8	2.6
10/07/2020 18:00	14.7	4.1	2.1	11.6	2.6
10/07/2020 19:00	14.3	4.3	2.0	11.1	2.4
10/07/2020 20:00	10.1	0.9	1.7	9.2	2.0
10/07/2020 21:00	12.7	3.5	1.8	10.0	2.2
10/07/2020 22:00	14.6	4.8	2.1	11.4	2.5
10/07/2020 23:00	10.3	15.0	0.6	3.3	0.8
Average/Sum#:	291.2 #	84.0 #	42.8 #	235.6 #	51.8 #
Minimum:	6.5	0.3	0.6	3.3	0.8
Maximum:	15.1	15.0	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/08/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 06:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 07:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 08:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 09:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 10:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 11:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 12:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 13:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 14:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 15:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 16:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 17:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 18:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 19:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 20:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 21:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 22:00	0.0	0.0	0.0	0.0	0.0
10/08/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 06:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 07:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 08:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 09:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 10:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 11:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 12:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 13:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 14:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 15:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 16:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 17:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 18:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 19:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 20:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 21:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 22:00	0.0	0.0	0.0	0.0	0.0
10/09/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 01:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 02:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 03:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 04:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 05:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 06:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 07:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 08:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 09:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 10:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 11:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 12:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 13:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 14:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 15:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 16:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 17:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 18:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 19:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 20:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 21:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 22:00	0.0	0.0	0.0	0.0	0.0
10/10/2020 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	0.0	0.0
10/11/2020 01:00	59.6	87.9	0.1	1.0	0.2
10/11/2020 02:00	63.4	36.8	0.2	1.9	0.4
10/11/2020 03:00	61.7	66.5	0.2	2.1	0.4
10/11/2020 04:00	55.6	64.9	0.3	2.6	0.5
10/11/2020 05:00	2.7	0.5	0.4	4.1	0.8
10/11/2020 06:00	2.7	0.5	0.4	4.0	0.8
10/11/2020 07:00	2.7	0.5	0.4	4.0	0.8
10/11/2020 08:00	2.7	0.5	0.4	4.0	0.8
10/11/2020 09:00	2.7	0.3	0.4	4.0	0.8
10/11/2020 10:00	2.7	0.3	0.4	4.0	0.8
10/11/2020 11:00	2.7	0.3	0.4	4.0	0.8
10/11/2020 12:00	2.7	0.3	0.4	4.0	0.8
10/11/2020 13:00	2.7	0.3	0.4	4.0	0.8
10/11/2020 14:00	2.7	0.3	0.4	4.1	0.8
10/11/2020 15:00	2.7	0.3	0.4	4.1	0.8
10/11/2020 16:00	7.7	2.6	0.6	5.8	1.2
10/11/2020 17:00	7.8	2.6	0.6	5.8	1.2
10/11/2020 18:00	7.7	2.6	0.6	5.8	1.2
10/11/2020 19:00	7.6	2.6	0.6	5.7	1.1
10/11/2020 20:00	2.7	0.8	0.4	4.1	0.8
10/11/2020 21:00	2.7	0.5	0.4	4.0	0.8
10/11/2020 22:00	2.7	0.5	0.4	4.0	0.8
10/11/2020 23:00	2.7	0.5	0.4	4.0	0.8
Average/Sum#:	311.6 #	272.9 #	9.2 #	91.1 #	18.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	63.4	87.9	0.6	5.8	1.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/12/2020 00:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 01:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 02:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 03:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 04:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 05:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 06:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 07:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 08:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 09:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 10:00	2.7	0.5	0.4	4.0	0.8
10/12/2020 11:00	2.7	0.3	0.4	4.0	0.8
10/12/2020 12:00	83.1	76.3	0.7	5.6	1.2
10/12/2020 13:00	85.2	38.9	1.0	6.5	1.3
10/12/2020 14:00	7.9	0.6	1.6	8.6	1.8
10/12/2020 15:00	10.0	1.2	1.7	9.2	2.0
10/12/2020 16:00	16.2	4.7	2.0	11.1	2.4
10/12/2020 17:00	14.1	5.1	2.0	11.1	2.4
10/12/2020 18:00	14.0	5.1	2.0	10.9	2.4
10/12/2020 19:00	13.5	4.7	2.0	10.6	2.3
10/12/2020 20:00	12.3	1.0	1.7	9.6	2.1
10/12/2020 21:00	12.7	3.2	1.8	10.0	2.2
10/12/2020 22:00	13.9	4.8	2.0	11.0	2.4
10/12/2020 23:00	13.7	4.8	2.0	10.7	2.4
Average/Sum#:	329.0 #	156.2 #	25.3 #	162.9 #	34.5 #
Minimum:	2.7	0.3	0.4	4.0	0.8
Maximum:	85.2	76.3	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/13/2020 00:00	10.0	0.9	1.7	9.2	2.0
10/13/2020 01:00	9.7	0.9	1.6	8.9	2.0
10/13/2020 02:00	7.0	0.5	1.4	7.7	1.6
10/13/2020 03:00	8.0	0.6	1.6	8.8	2.0
10/13/2020 04:00	12.7	2.9	1.8	10.0	2.2
10/13/2020 05:00	13.9	4.8	2.0	10.9	2.4
10/13/2020 06:00	13.6	4.8	2.0	10.7	2.4
10/13/2020 07:00	9.9	0.9	1.7	9.0	2.0
10/13/2020 08:00	7.4	0.8	1.4	8.1	1.8
10/13/2020 09:00	6.8	0.5	1.3	7.4	1.6
10/13/2020 10:00	9.7	0.9	1.6	8.9	2.0
10/13/2020 11:00	7.5	0.8	1.5	8.3	1.8
10/13/2020 12:00	7.5	0.8	1.5	8.3	1.8
10/13/2020 13:00	8.4	0.5	1.4	7.7	1.6
10/13/2020 14:00	9.6	0.9	1.6	8.8	2.0
10/13/2020 15:00	9.9	1.8	1.7	9.1	2.0
10/13/2020 16:00	16.3	4.7	2.0	11.2	2.4
10/13/2020 17:00	14.3	4.1	2.1	11.3	2.4
10/13/2020 18:00	14.1	4.1	2.0	11.1	2.4
10/13/2020 19:00	13.7	4.1	2.0	10.7	2.4
10/13/2020 20:00	10.2	0.6	1.7	9.4	2.0
10/13/2020 21:00	10.9	2.6	1.8	10.0	2.2
10/13/2020 22:00	14.8	3.5	2.1	11.6	2.6
10/13/2020 23:00	13.7	3.8	2.0	10.7	2.4
Average/Sum#:	259.6 #	50.8 #	41.5 #	227.8 #	50.0 #
Minimum:	6.8	0.5	1.3	7.4	1.6
Maximum:	16.3	4.8	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/14/2020 00:00	10.0	0.6	1.7	9.2	2.0
10/14/2020 01:00	10.0	1.2	1.7	9.2	2.0
10/14/2020 02:00	14.4	3.8	2.1	11.3	2.4
10/14/2020 03:00	13.6	3.8	2.0	10.7	2.4
10/14/2020 04:00	9.6	0.6	1.6	8.8	2.0
10/14/2020 05:00	12.7	3.7	1.8	10.0	2.2
10/14/2020 06:00	14.1	4.1	2.0	11.1	2.4
10/14/2020 07:00	7.7	1.6	2.0	10.5	2.3
10/14/2020 08:00	7.1	1.1	1.4	7.7	1.7
10/14/2020 09:00	6.5	1.0	1.3	7.2	1.6
10/14/2020 10:00	9.2	1.2	1.6	8.5	1.8
10/14/2020 11:00	12.4	4.2	1.8	9.8	2.2
10/14/2020 12:00	14.9	5.2	2.1	11.7	2.6
10/14/2020 13:00	15.1	4.0	2.1	11.9	2.6
10/14/2020 14:00	10.5	3.4	1.7	9.6	2.1
10/14/2020 15:00	10.9	4.5	1.8	10.0	2.2
10/14/2020 16:00	12.7	5.3	2.1	11.7	2.6
10/14/2020 17:00	15.4	4.0	2.3	12.1	2.6
10/14/2020 18:00	14.8	4.7	2.1	11.6	2.6
10/14/2020 19:00	14.5	4.6	2.1	11.3	2.5
10/14/2020 20:00	10.1	1.9	1.7	9.2	2.0
10/14/2020 21:00	12.9	4.1	1.8	10.1	2.2
10/14/2020 22:00	15.1	4.7	2.1	11.9	2.6
10/14/2020 23:00	16.1	5.4	2.0	11.0	2.4
Average/Sum#:	282.6 #	77.1 #	44.9 #	246.1 #	54.0 #
Minimum:	6.5	0.6	1.3	7.2	1.6
Maximum:	16.1	5.4	2.3	12.1	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/15/2020 00:00	10.1	1.9	1.7	9.2	2.0
10/15/2020 01:00	10.9	4.1	1.8	10.0	2.2
10/15/2020 02:00	14.9	5.7	2.1	11.8	2.6
10/15/2020 03:00	14.6	5.6	2.1	11.4	2.5
10/15/2020 04:00	10.2	2.6	1.7	9.4	2.0
10/15/2020 05:00	14.7	5.5	1.8	10.1	2.2
10/15/2020 06:00	14.4	6.3	2.1	11.4	2.4
10/15/2020 07:00	13.0	4.8	1.9	10.2	2.2
10/15/2020 08:00	6.5	1.5	1.3	7.2	1.6
10/15/2020 09:00	6.5	0.9	1.3	7.2	1.6
10/15/2020 10:00	6.6	1.1	1.3	7.2	1.6
10/15/2020 11:00	7.8	1.8	1.6	8.6	1.8
10/15/2020 12:00	11.5	2.4	1.7	9.0	2.0
10/15/2020 13:00	12.7	4.7	1.8	10.0	2.2
10/15/2020 14:00	15.3	5.0	2.1	12.0	2.6
10/15/2020 15:00	15.4	4.7	2.3	12.1	2.6
10/15/2020 16:00	15.4	4.3	2.3	12.1	2.6
10/15/2020 17:00	15.2	4.7	2.1	11.9	2.6
10/15/2020 18:00	15.2	4.7	2.1	12.0	2.6
10/15/2020 19:00	17.2	4.7	2.1	11.9	2.6
10/15/2020 20:00	17.4	4.7	2.1	12.0	2.6
10/15/2020 21:00	15.4	4.3	2.3	12.1	2.6
10/15/2020 22:00	15.0	4.7	2.1	11.8	2.6
10/15/2020 23:00	14.3	5.0	2.0	11.1	2.4
Average/Sum#:	310.2 #	95.7 #	45.7 #	251.7 #	54.7 #
Minimum:	6.5	0.9	1.3	7.2	1.6
Maximum:	17.4	6.3	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/16/2020 00:00	10.2	1.9	1.7	9.4	2.0
10/16/2020 01:00	6.6	1.5	1.3	7.2	1.6
10/16/2020 02:00	10.1	1.9	1.7	9.2	2.0
10/16/2020 03:00	12.7	4.8	1.8	10.0	2.2
10/16/2020 04:00	13.2	5.0	1.9	10.5	2.2
10/16/2020 05:00	12.0	2.7	1.7	9.4	2.0
10/16/2020 06:00	12.3	4.4	2.1	11.3	2.4
10/16/2020 07:00	13.7	5.4	2.0	10.7	2.4
10/16/2020 08:00	9.6	1.8	1.6	8.8	2.0
10/16/2020 09:00	7.0	1.6	1.4	7.7	1.6
10/16/2020 10:00	9.1	1.2	1.6	8.3	1.8
10/16/2020 11:00	11.1	2.6	1.6	8.7	1.9
10/16/2020 12:00	14.8	5.0	2.1	11.7	2.6
10/16/2020 13:00	14.6	5.0	2.1	11.5	2.5
10/16/2020 14:00	15.0	4.0	2.1	11.8	2.6
10/16/2020 15:00	15.0	4.0	2.1	11.9	2.6
10/16/2020 16:00	14.5	4.7	2.1	11.3	2.5
10/16/2020 17:00	14.8	4.7	2.1	11.7	2.6
10/16/2020 18:00	14.7	4.7	2.1	11.5	2.5
10/16/2020 19:00	15.2	4.0	2.1	11.9	2.6
10/16/2020 20:00	15.0	4.0	2.1	11.8	2.6
10/16/2020 21:00	14.8	4.7	2.1	11.6	2.6
10/16/2020 22:00	14.5	4.7	2.1	11.3	2.5
10/16/2020 23:00	16.2	5.1	2.0	11.1	2.4
Average/Sum#:	306.7 #	89.4 #	45.5 #	250.3 #	54.7 #
Minimum:	6.6	1.2	1.3	7.2	1.6
Maximum:	16.2	5.4	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/17/2020 00:00	13.6	5.0	2.0	10.7	2.4
10/17/2020 01:00	9.3	1.8	1.6	8.5	1.8
10/17/2020 02:00	6.6	1.3	1.3	7.2	1.6
10/17/2020 03:00	9.7	1.5	1.6	8.9	2.0
10/17/2020 04:00	9.7	1.5	1.6	8.8	2.0
10/17/2020 05:00	8.3	1.5	1.7	9.2	2.0
10/17/2020 06:00	12.7	4.1	1.8	10.0	2.2
10/17/2020 07:00	13.0	4.3	1.9	10.2	2.2
10/17/2020 08:00	11.7	1.8	1.7	9.2	2.0
10/17/2020 09:00	11.7	1.9	1.7	9.2	2.0
10/17/2020 10:00	11.4	1.8	1.6	9.0	2.0
10/17/2020 11:00	9.0	1.7	1.4	8.1	1.8
10/17/2020 12:00	8.8	1.7	1.4	8.1	1.8
10/17/2020 13:00	8.8	1.1	1.4	8.1	1.8
10/17/2020 14:00	9.9	2.7	1.7	9.1	2.0
10/17/2020 15:00	14.8	4.7	2.1	11.6	2.6
10/17/2020 16:00	15.2	3.7	2.1	12.0	2.6
10/17/2020 17:00	15.2	3.7	2.1	12.0	2.6
10/17/2020 18:00	14.3	4.6	2.1	11.3	2.4
10/17/2020 19:00	14.5	4.7	2.1	11.4	2.5
10/17/2020 20:00	14.7	4.7	2.1	11.5	2.5
10/17/2020 21:00	14.0	4.8	2.0	11.0	2.4
10/17/2020 22:00	14.5	4.7	2.1	11.5	2.5
10/17/2020 23:00	14.5	4.7	2.1	11.5	2.5
Average/Sum#:	285.9 #	74.0 #	43.2 #	238.1 #	52.2 #
Minimum:	6.6	1.1	1.3	7.2	1.6
Maximum:	15.2	5.0	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/18/2020 00:00	10.2	2.7	1.7	9.4	2.0
10/18/2020 01:00	10.9	3.8	1.8	10.0	2.2
10/18/2020 02:00	15.2	4.1	2.1	11.9	2.6
10/18/2020 03:00	14.7	4.0	2.1	11.5	2.5
10/18/2020 04:00	10.0	1.8	1.7	9.2	2.0
10/18/2020 05:00	8.0	1.8	1.6	8.8	2.0
10/18/2020 06:00	9.4	1.8	1.6	8.6	1.8
10/18/2020 07:00	7.5	2.0	1.5	8.3	1.8
10/18/2020 08:00	8.0	1.5	1.6	8.8	2.0
10/18/2020 09:00	8.1	1.2	1.6	8.8	2.0
10/18/2020 10:00	9.5	1.2	1.6	8.7	1.9
10/18/2020 11:00	9.6	1.2	1.6	8.8	2.0
10/18/2020 12:00	8.1	1.8	1.6	9.0	2.0
10/18/2020 13:00	8.0	1.8	1.6	8.8	2.0
10/18/2020 14:00	9.8	1.8	1.6	9.0	2.0
10/18/2020 15:00	12.4	4.3	1.8	9.7	2.1
10/18/2020 16:00	16.8	5.5	2.1	11.6	2.5
10/18/2020 17:00	13.9	3.0	1.7	9.6	2.1
10/18/2020 18:00	4.9	6.6	0.7	4.8	1.0
10/18/2020 19:00	2.8	0.3	0.4	4.1	0.8
10/18/2020 20:00	5.1	0.6	0.5	5.1	1.0
10/18/2020 21:00	22.2	10.3	0.6	5.5	1.1
10/18/2020 22:00	39.7	26.8	1.2	7.5	1.6
10/18/2020 23:00	10.9	3.8	1.8	10.0	2.2
Average/Sum#:	275.7 #	93.7 #	36.1 #	207.5 #	45.2 #
Minimum:	2.8	0.3	0.4	4.1	0.8
Maximum:	39.7	26.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/19/2020 00:00	12.9	4.3	1.8	10.1	2.2
10/19/2020 01:00	8.1	1.8	1.6	9.0	2.0
10/19/2020 02:00	7.9	1.8	1.6	8.7	1.9
10/19/2020 03:00	10.1	1.9	1.7	9.2	2.0
10/19/2020 04:00	10.9	4.5	1.8	10.0	2.2
10/19/2020 05:00	16.8	5.1	2.1	11.6	2.6
10/19/2020 06:00	14.5	4.4	2.1	11.4	2.5
10/19/2020 07:00	10.1	1.9	1.7	9.2	2.0
10/19/2020 08:00	7.8	1.8	1.6	8.6	1.8
10/19/2020 09:00	9.7	1.8	1.6	9.0	2.0
10/19/2020 10:00	11.3	1.5	1.6	8.9	2.0
10/19/2020 11:00	9.5	1.2	1.6	8.7	1.9
10/19/2020 12:00	7.3	1.1	1.4	7.9	1.8
10/19/2020 13:00	7.1	1.1	1.4	7.9	1.8
10/19/2020 14:00	11.6	2.4	1.7	9.1	2.0
10/19/2020 15:00	14.2	4.6	2.0	11.1	2.4
10/19/2020 16:00	14.9	4.0	2.1	11.7	2.6
10/19/2020 17:00	15.1	3.7	2.1	11.9	2.6
10/19/2020 18:00	14.7	4.0	2.1	11.6	2.5
10/19/2020 19:00	15.1	3.7	2.1	11.8	2.6
10/19/2020 20:00	12.4	3.0	1.8	9.8	2.2
10/19/2020 21:00	10.8	3.4	1.8	9.9	2.2
10/19/2020 22:00	14.4	4.8	2.0	11.3	2.4
10/19/2020 23:00	13.5	4.8	2.0	10.7	2.4
Average/Sum#:	280.7 #	72.6 #	43.3 #	239.1 #	52.6 #
Minimum:	7.1	1.1	1.4	7.9	1.8
Maximum:	16.8	5.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/20/2020 00:00	7.6	1.5	1.6	8.4	1.8
10/20/2020 01:00	6.5	0.9	1.3	7.1	1.6
10/20/2020 02:00	7.0	1.1	1.4	7.6	1.6
10/20/2020 03:00	10.8	3.8	1.8	9.9	2.2
10/20/2020 04:00	16.3	5.4	2.0	11.2	2.4
10/20/2020 05:00	16.6	4.7	2.1	11.4	2.5
10/20/2020 06:00	12.1	4.7	2.0	11.1	2.4
10/20/2020 07:00	10.0	1.8	1.7	9.2	2.0
10/20/2020 08:00	6.6	1.1	1.3	7.3	1.6
10/20/2020 09:00	7.3	1.1	1.4	8.1	1.8
10/20/2020 10:00	9.8	1.5	1.6	9.0	2.0
10/20/2020 11:00	10.3	2.7	1.7	9.4	2.0
10/20/2020 12:00	14.3	4.6	2.1	11.3	2.4
10/20/2020 13:00	14.3	4.3	2.1	11.3	2.4
10/20/2020 14:00	10.2	1.9	1.7	9.3	2.0
10/20/2020 15:00	12.8	3.3	1.8	10.0	2.2
10/20/2020 16:00	15.1	3.6	2.1	11.8	2.6
10/20/2020 17:00	14.8	4.0	2.1	11.7	2.6
10/20/2020 18:00	14.5	4.0	2.1	11.4	2.5
10/20/2020 19:00	14.1	4.7	2.0	11.1	2.4
10/20/2020 20:00	13.4	3.6	2.0	10.5	2.3
10/20/2020 21:00	12.2	2.5	1.7	9.6	2.1
10/20/2020 22:00	14.4	4.7	2.1	11.3	2.5
10/20/2020 23:00	17.1	4.0	2.1	11.7	2.6
Average/Sum#:	288.1 #	75.5 #	43.8 #	240.7 #	52.5 #
Minimum:	6.5	0.9	1.3	7.1	1.6
Maximum:	17.1	5.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/21/2020 00:00	14.5	4.0	2.1	11.3	2.5
10/21/2020 01:00	10.1	1.2	1.7	9.2	2.0
10/21/2020 02:00	12.2	2.4	1.7	9.6	2.1
10/21/2020 03:00	14.8	4.0	2.1	11.7	2.6
10/21/2020 04:00	14.6	4.0	2.1	11.5	2.5
10/21/2020 05:00	16.3	4.8	2.0	11.2	2.4
10/21/2020 06:00	12.7	4.8	2.1	11.6	2.6
10/21/2020 07:00	7.8	1.7	1.6	8.5	1.8
10/21/2020 08:00	7.6	1.5	1.6	8.4	1.8
10/21/2020 09:00	6.8	1.1	1.4	7.5	1.6
10/21/2020 10:00	9.4	1.2	1.6	8.6	1.8
10/21/2020 11:00	7.6	1.2	1.6	8.4	1.8
10/21/2020 12:00	9.6	1.2	1.6	8.8	2.0
10/21/2020 13:00	10.1	2.7	1.7	9.2	2.0
10/21/2020 14:00	14.7	4.3	2.1	11.5	2.5
10/21/2020 15:00	14.3	4.6	2.1	11.3	2.4
10/21/2020 16:00	17.1	4.0	2.1	11.7	2.6
10/21/2020 17:00	15.0	3.6	2.1	11.8	2.6
10/21/2020 18:00	15.0	3.7	2.1	11.8	2.6
10/21/2020 19:00	14.8	4.0	2.1	11.6	2.5
10/21/2020 20:00	14.9	3.7	2.1	11.7	2.6
10/21/2020 21:00	14.6	3.3	2.1	11.5	2.5
10/21/2020 22:00	14.6	3.4	2.1	11.5	2.5
10/21/2020 23:00	13.9	3.4	2.0	11.0	2.4
Average/Sum#:	303.0 #	73.8 #	45.8 #	250.9 #	54.7 #
Minimum:	6.8	1.1	1.4	7.5	1.6
Maximum:	17.1	4.8	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/22/2020 00:00	10.1	1.3	1.7	9.2	2.0
10/22/2020 01:00	10.9	3.1	1.8	10.0	2.2
10/22/2020 02:00	14.1	4.1	2.0	11.1	2.4
10/22/2020 03:00	13.9	4.1	2.0	10.9	2.4
10/22/2020 04:00	10.1	1.6	1.7	9.2	2.0
10/22/2020 05:00	12.3	3.9	1.7	9.6	2.1
10/22/2020 06:00	15.0	4.8	2.1	11.8	2.6
10/22/2020 07:00	14.5	4.4	2.1	11.4	2.5
10/22/2020 08:00	7.5	1.1	1.4	8.1	1.8
10/22/2020 09:00	7.9	1.2	1.6	8.7	1.9
10/22/2020 10:00	8.1	1.5	1.6	8.8	2.0
10/22/2020 11:00	10.9	4.2	1.8	10.0	2.2
10/22/2020 12:00	14.8	5.7	2.1	11.6	2.6
10/22/2020 13:00	13.8	5.7	2.0	10.9	2.4
10/22/2020 14:00	9.5	1.8	1.6	8.7	1.9
10/22/2020 15:00	10.1	3.3	1.7	9.2	2.0
10/22/2020 16:00	14.8	5.7	2.1	11.6	2.6
10/22/2020 17:00	14.9	5.1	2.1	11.8	2.6
10/22/2020 18:00	14.1	5.4	2.0	11.1	2.4
10/22/2020 19:00	14.6	5.7	2.1	11.4	2.5
10/22/2020 20:00	16.4	5.7	2.0	11.3	2.4
10/22/2020 21:00	16.5	5.4	2.0	11.3	2.4
10/22/2020 22:00	14.1	4.8	2.0	11.1	2.4
10/22/2020 23:00	13.7	3.8	2.0	10.7	2.4
Average/Sum#:	302.6 #	93.4 #	45.2 #	249.5 #	54.7 #
Minimum:	7.5	1.1	1.4	8.1	1.8
Maximum:	16.5	5.7	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/23/2020 00:00	9.8	1.2	1.6	9.0	2.0
10/23/2020 01:00	10.9	3.1	1.8	9.9	2.2
10/23/2020 02:00	14.6	4.8	2.1	11.5	2.5
10/23/2020 03:00	13.9	5.4	2.0	11.0	2.4
10/23/2020 04:00	8.5	1.9	1.7	9.2	2.0
10/23/2020 05:00	12.7	4.1	1.8	10.0	2.2
10/23/2020 06:00	15.1	5.8	2.1	11.8	2.6
10/23/2020 07:00	14.7	5.5	2.1	11.6	2.6
10/23/2020 08:00	13.9	5.5	2.0	11.0	2.4
10/23/2020 09:00	10.3	2.2	1.7	9.4	2.0
10/23/2020 10:00	10.1	1.9	1.7	9.2	2.0
10/23/2020 11:00	10.4	2.2	1.7	9.5	2.0
10/23/2020 12:00	16.5	5.7	2.1	11.4	2.4
10/23/2020 13:00	13.7	5.1	2.0	10.7	2.4
10/23/2020 14:00	8.0	1.8	1.6	8.8	2.0
10/23/2020 15:00	10.5	2.9	1.7	9.6	2.1
10/23/2020 16:00	16.4	5.4	2.0	11.3	2.4
10/23/2020 17:00	14.8	4.8	2.1	11.6	2.6
10/23/2020 18:00	15.4	4.8	2.0	10.5	2.3
10/23/2020 19:00	10.2	1.9	1.7	9.4	2.0
10/23/2020 20:00	11.0	4.5	1.8	10.1	2.2
10/23/2020 21:00	16.5	5.7	2.0	11.3	2.4
10/23/2020 22:00	14.1	5.5	2.0	11.1	2.4
10/23/2020 23:00	14.8	4.8	2.1	11.6	2.6
Average/Sum#:	306.8 #	96.5 #	45.4 #	250.5 #	54.7 #
Minimum:	8.0	1.2	1.6	8.8	2.0
Maximum:	16.5	5.8	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/24/2020 00:00	10.3	2.2	1.7	9.4	2.0
10/24/2020 01:00	8.5	1.9	1.7	9.3	2.0
10/24/2020 02:00	10.9	3.9	1.8	10.0	2.2
10/24/2020 03:00	14.6	4.8	2.1	11.6	2.6
10/24/2020 04:00	13.7	4.8	2.0	10.7	2.4
10/24/2020 05:00	10.0	1.9	1.7	9.2	2.0
10/24/2020 06:00	8.3	1.8	1.7	9.2	2.0
10/24/2020 07:00	8.1	1.8	1.6	9.0	2.0
10/24/2020 08:00	7.8	1.8	1.6	8.6	1.8
10/24/2020 09:00	8.1	1.8	1.6	8.9	2.0
10/24/2020 10:00	10.0	1.8	1.7	9.2	2.0
10/24/2020 11:00	8.2	1.8	1.6	9.0	2.0
10/24/2020 12:00	7.2	1.6	1.4	7.9	1.8
10/24/2020 13:00	7.1	1.6	1.4	7.9	1.8
10/24/2020 14:00	9.8	1.8	1.6	9.0	2.0
10/24/2020 15:00	10.2	1.9	1.7	9.3	2.0
10/24/2020 16:00	12.7	4.4	1.8	10.0	2.2
10/24/2020 17:00	14.9	6.0	2.1	11.6	2.6
10/24/2020 18:00	13.5	6.0	2.0	10.7	2.4
10/24/2020 19:00	11.9	2.5	1.7	9.4	2.0
10/24/2020 20:00	11.8	2.5	1.7	9.2	2.0
10/24/2020 21:00	10.9	5.1	1.8	9.9	2.2
10/24/2020 22:00	14.1	6.3	2.0	11.0	2.4
10/24/2020 23:00	13.7	5.0	2.0	10.8	2.4
Average/Sum#:	256.3 #	75.0 #	42.0 #	230.8 #	50.8 #
Minimum:	7.1	1.6	1.4	7.9	1.8
Maximum:	14.9	6.3	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/25/2020 00:00	10.0	1.9	1.7	9.2	2.0
10/25/2020 01:00	8.3	1.8	1.7	9.2	2.0
10/25/2020 02:00	8.3	1.8	1.7	9.0	2.0
10/25/2020 03:00	8.3	1.8	1.7	9.0	2.0
10/25/2020 04:00	8.3	1.8	1.7	9.0	2.0
10/25/2020 05:00	8.1	2.1	1.6	9.0	2.0
10/25/2020 06:00	8.0	2.1	1.6	8.8	2.0
10/25/2020 07:00	8.1	1.8	1.6	8.8	2.0
10/25/2020 08:00	8.0	1.8	1.6	8.8	2.0
10/25/2020 09:00	7.8	1.8	1.6	8.6	1.8
10/25/2020 10:00	7.1	1.6	1.4	7.8	1.7
10/25/2020 11:00	6.8	1.5	1.3	7.4	1.6
10/25/2020 12:00	7.8	1.8	1.6	8.5	1.8
10/25/2020 13:00	8.0	1.8	1.6	8.8	2.0
10/25/2020 14:00	10.0	1.9	1.7	9.2	2.0
10/25/2020 15:00	8.0	1.8	1.6	8.8	2.0
10/25/2020 16:00	12.8	4.9	1.8	10.1	2.2
10/25/2020 17:00	16.5	6.9	2.1	11.4	2.5
10/25/2020 18:00	14.2	6.4	2.0	11.1	2.4
10/25/2020 19:00	10.0	2.2	1.7	9.2	2.0
10/25/2020 20:00	11.0	3.8	1.8	10.1	2.2
10/25/2020 21:00	15.0	4.5	2.1	11.8	2.6
10/25/2020 22:00	15.2	3.9	2.1	11.9	2.6
10/25/2020 23:00	15.4	3.6	2.3	12.1	2.6
Average/Sum#:	241.0 #	65.3 #	41.6 #	227.6 #	50.0 #
Minimum:	6.8	1.5	1.3	7.4	1.6
Maximum:	16.5	6.9	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/26/2020 00:00	14.3	3.9	2.0	11.2	2.4
10/26/2020 01:00	15.9	4.3	2.0	10.9	2.4
10/26/2020 02:00	14.3	4.2	2.0	11.2	2.4
10/26/2020 03:00	8.4	1.5	1.7	9.2	2.0
10/26/2020 04:00	11.2	3.9	1.9	10.3	2.2
10/26/2020 05:00	17.2	4.5	2.1	11.8	2.6
10/26/2020 06:00	14.8	3.9	2.1	11.6	2.6
10/26/2020 07:00	10.8	1.7	1.8	9.9	2.2
10/26/2020 08:00	8.8	1.7	1.7	9.6	2.1
10/26/2020 09:00	8.8	1.7	1.7	9.6	2.1
10/26/2020 10:00	8.5	1.6	1.7	9.2	2.0
10/26/2020 11:00	7.0	1.1	1.4	7.6	1.6
10/26/2020 12:00	7.6	1.5	1.6	8.4	1.8
10/26/2020 13:00	7.5	1.5	1.6	8.3	1.8
10/26/2020 14:00	10.2	1.9	1.7	9.3	2.0
10/26/2020 15:00	9.9	1.5	1.7	9.0	2.0
10/26/2020 16:00	13.0	4.8	1.9	10.2	2.2
10/26/2020 17:00	15.2	6.1	2.1	11.9	2.6
10/26/2020 18:00	17.7	5.8	2.3	12.1	2.6
10/26/2020 19:00	16.7	5.8	2.1	11.5	2.5
10/26/2020 20:00	15.0	5.8	2.1	11.8	2.6
10/26/2020 21:00	14.8	5.8	2.1	11.6	2.6
10/26/2020 22:00	16.8	6.2	2.1	11.5	2.5
10/26/2020 23:00	16.5	5.5	2.1	11.4	2.4
Average/Sum#:	300.9 #	86.2 #	45.5 #	249.1 #	54.2 #
Minimum:	7.0	1.1	1.4	7.6	1.6
Maximum:	17.7	6.2	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/27/2020 00:00	8.5	1.9	1.7	9.3	2.0
10/27/2020 01:00	10.7	2.9	1.8	9.8	2.2
10/27/2020 02:00	14.5	4.5	2.1	11.4	2.5
10/27/2020 03:00	14.1	3.9	2.0	11.1	2.4
10/27/2020 04:00	8.3	1.5	1.7	9.1	2.0
10/27/2020 05:00	10.5	3.5	1.7	9.6	2.1
10/27/2020 06:00	15.2	4.2	2.1	11.9	2.6
10/27/2020 07:00	15.2	5.2	2.1	12.0	2.6
10/27/2020 08:00	14.8	5.5	2.1	11.7	2.6
10/27/2020 09:00	15.0	5.1	2.1	11.7	2.6
10/27/2020 10:00	15.0	5.1	2.1	11.7	2.6
10/27/2020 11:00	15.1	5.4	2.1	11.8	2.6
10/27/2020 12:00	15.1	5.4	2.1	11.8	2.6
10/27/2020 13:00	15.1	5.0	2.1	11.8	2.6
10/27/2020 14:00	17.2	5.0	2.1	11.8	2.6
10/27/2020 15:00	13.9	5.4	2.0	10.9	2.4
10/27/2020 16:00	17.2	5.0	2.1	11.7	2.6
10/27/2020 17:00	15.3	4.7	2.2	11.9	2.6
10/27/2020 18:00	15.3	4.7	2.2	12.0	2.6
10/27/2020 19:00	17.5	4.8	2.2	12.0	2.6
10/27/2020 20:00	15.1	4.8	2.1	11.9	2.6
10/27/2020 21:00	16.5	5.8	2.1	11.3	2.4
10/27/2020 22:00	16.5	5.8	2.1	11.3	2.4
10/27/2020 23:00	16.4	5.1	2.0	11.4	2.4
Average/Sum#:	348.0 #	110.2 #	48.9 #	270.9 #	59.2 #
Minimum:	8.3	1.5	1.7	9.1	2.0
Maximum:	17.5	5.8	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/28/2020 00:00	8.3	1.9	1.7	9.2	2.0
10/28/2020 01:00	8.3	2.2	1.7	9.2	2.0
10/28/2020 02:00	8.3	2.2	1.7	9.0	2.0
10/28/2020 03:00	8.3	2.1	1.7	9.0	2.0
10/28/2020 04:00	11.0	3.9	1.8	10.1	2.2
10/28/2020 05:00	14.8	4.8	2.1	11.7	2.6
10/28/2020 06:00	15.0	3.8	2.1	11.8	2.6
10/28/2020 07:00	9.8	1.5	1.7	8.3	1.9
10/28/2020 08:00	7.8	1.5	1.6	8.1	1.8
10/28/2020 09:00	7.9	2.1	1.5	8.5	1.9
10/28/2020 10:00	8.1	2.5	1.7	8.8	1.9
10/28/2020 11:00	9.8	2.5	1.4	8.7	1.9
10/28/2020 12:00	10.9	2.2	1.4	8.6	1.9
10/28/2020 13:00	11.5	2.4	1.5	9.0	2.0
10/28/2020 14:00	11.8	2.5	1.6	9.2	2.0
10/28/2020 15:00	11.0	2.2	1.4	8.5	1.9
10/28/2020 16:00	9.8	2.7	1.6	9.0	2.0
10/28/2020 17:00	10.2	3.1	1.7	9.4	2.0
10/28/2020 18:00	12.0	6.7	2.0	11.0	2.4
10/28/2020 19:00	14.4	6.0	2.0	11.3	2.4
10/28/2020 20:00	14.6	6.0	2.1	11.4	2.5
10/28/2020 21:00	16.6	6.1	2.1	11.4	2.5
10/28/2020 22:00	14.3	5.8	2.0	11.3	2.4
10/28/2020 23:00	15.3	5.1	1.9	10.5	2.3
Average/Sum#:	269.8 #	81.8 #	42.0 #	233.0 #	51.1 #
Minimum:	7.8	1.5	1.4	8.1	1.8
Maximum:	16.6	6.7	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/29/2020 00:00	8.5	2.2	1.7	9.2	2.0
10/29/2020 01:00	8.4	2.2	1.7	9.2	2.0
10/29/2020 02:00	7.7	2.1	1.6	8.5	1.8
10/29/2020 03:00	8.5	2.2	1.7	9.2	2.0
10/29/2020 04:00	10.8	4.2	1.8	9.9	2.2
10/29/2020 05:00	14.4	5.5	2.0	11.2	2.4
10/29/2020 06:00	12.4	5.2	2.0	11.4	2.4
10/29/2020 07:00	8.0	1.9	1.4	8.6	1.9
10/29/2020 08:00	5.2	1.7	1.3	7.1	1.6
10/29/2020 09:00	7.0	1.6	1.5	7.6	1.7
10/29/2020 10:00	7.1	1.9	1.5	7.6	1.7
10/29/2020 11:00	9.7	2.1	1.7	8.3	1.9
10/29/2020 12:00	9.7	2.2	1.7	8.3	1.9
10/29/2020 13:00	9.7	2.2	1.7	8.3	1.9
10/29/2020 14:00	9.7	2.2	1.7	8.3	1.9
10/29/2020 15:00	9.9	2.3	1.7	8.6	1.9
10/29/2020 16:00	8.4	2.5	1.7	9.0	2.0
10/29/2020 17:00	10.5	3.3	1.7	9.6	2.1
10/29/2020 18:00	14.1	7.1	2.0	11.1	2.4
10/29/2020 19:00	16.5	6.7	2.1	11.4	2.4
10/29/2020 20:00	14.6	6.8	2.1	11.4	2.5
10/29/2020 21:00	14.6	6.4	2.1	11.4	2.5
10/29/2020 22:00	16.6	6.4	2.1	11.4	2.5
10/29/2020 23:00	15.5	7.1	2.0	10.7	2.4
Average/Sum#:	257.5 #	88.0 #	42.5 #	227.3 #	50.0 #
Minimum:	5.2	1.6	1.3	7.1	1.6
Maximum:	16.6	7.1	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/30/2020 00:00	8.1	2.1	1.6	8.9	2.0
10/30/2020 01:00	10.1	3.4	1.7	9.2	2.0
10/30/2020 02:00	15.5	5.2	2.0	10.7	2.4
10/30/2020 03:00	13.5	4.8	2.0	10.7	2.4
10/30/2020 04:00	8.5	2.2	1.7	9.3	2.0
10/30/2020 05:00	12.7	4.6	1.8	10.0	2.2
10/30/2020 06:00	14.5	5.2	2.1	11.5	2.5
10/30/2020 07:00	14.7	4.8	2.2	11.6	2.5
10/30/2020 08:00	14.7	4.5	2.2	11.6	2.5
10/30/2020 09:00	14.5	4.4	2.1	11.4	2.5
10/30/2020 10:00	14.6	3.8	2.1	11.5	2.5
10/30/2020 11:00	13.8	4.0	2.0	10.8	2.4
10/30/2020 12:00	9.9	1.5	1.7	9.0	2.0
10/30/2020 13:00	10.8	4.5	1.8	9.9	2.2
10/30/2020 14:00	14.3	6.1	2.0	11.1	2.4
10/30/2020 15:00	14.7	6.0	2.1	11.5	2.5
10/30/2020 16:00	14.5	6.0	2.1	11.3	2.5
10/30/2020 17:00	14.9	5.7	2.1	11.7	2.6
10/30/2020 18:00	14.9	5.4	2.1	11.7	2.6
10/30/2020 19:00	15.1	5.4	2.1	11.9	2.6
10/30/2020 20:00	10.9	4.0	1.8	10.0	2.2
10/30/2020 21:00	11.0	4.8	1.8	10.1	2.2
10/30/2020 22:00	14.6	6.0	2.1	11.5	2.5
10/30/2020 23:00	15.4	6.1	2.0	10.6	2.4
Average/Sum#:	316.2 #	110.5 #	47.2 #	257.5 #	56.6 #
Minimum:	8.1	1.5	1.6	8.9	2.0
Maximum:	15.5	6.1	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/31/2020 00:00	7.8	2.1	1.6	8.6	1.8
10/31/2020 01:00	8.3	2.1	1.7	9.2	2.0
10/31/2020 02:00	9.9	3.3	1.7	9.1	2.0
10/31/2020 03:00	14.3	5.1	2.0	11.2	2.4
10/31/2020 04:00	13.4	5.1	1.9	10.5	2.3
10/31/2020 05:00	8.5	2.2	1.7	9.3	2.0
10/31/2020 06:00	8.5	2.2	1.7	9.3	2.0
10/31/2020 07:00	8.3	2.1	1.7	9.0	2.0
10/31/2020 08:00	7.6	2.3	1.6	8.4	1.8
10/31/2020 09:00	7.5	2.0	1.5	8.3	1.8
10/31/2020 10:00	8.2	2.1	1.6	9.0	2.0
10/31/2020 11:00	7.8	2.1	1.6	8.5	1.8
10/31/2020 12:00	7.8	2.1	1.6	8.5	1.8
10/31/2020 13:00	9.4	2.1	1.6	8.6	1.8
10/31/2020 14:00	11.2	2.1	1.6	8.8	2.0
10/31/2020 15:00	15.1	2.2	1.7	9.2	2.0
10/31/2020 16:00	14.5	4.1	1.8	9.9	2.2
10/31/2020 17:00	20.0	6.0	2.0	10.9	2.4
10/31/2020 18:00	20.2	6.0	2.0	11.1	2.4
10/31/2020 19:00	11.9	2.5	1.7	9.3	2.0
10/31/2020 20:00	12.7	4.8	1.8	10.0	2.2
10/31/2020 21:00	20.6	6.1	2.0	11.3	2.4
10/31/2020 22:00	20.5	5.8	2.0	11.2	2.4
10/31/2020 23:00	16.3	5.1	2.0	11.2	2.4
Average/Sum#:	290.3 #	81.6 #	42.1 #	230.4 #	49.9 #
Minimum:	7.5	2.0	1.5	8.3	1.8
Maximum:	20.6	6.1	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/01/2020 00:00	20.3	4.8	2.0	11.1	2.4
11/01/2020 01:00	22.0	4.8	2.0	10.9	2.4
11/01/2020 02:00	10.0	2.2	1.7	9.2	2.0
11/01/2020 03:00	8.5	2.2	1.7	9.2	2.0
11/01/2020 04:00	12.7	3.9	1.8	10.0	2.2
11/01/2020 05:00	16.4	5.1	2.0	11.3	2.4
11/01/2020 06:00	14.1	4.8	2.0	11.1	2.4
11/01/2020 07:00	7.7	1.5	1.6	8.5	1.8
11/01/2020 08:00	8.5	2.2	1.7	9.2	2.0
11/01/2020 09:00	7.5	2.0	1.5	8.3	1.8
11/01/2020 10:00	7.8	2.1	1.6	8.6	1.8
11/01/2020 11:00	7.5	2.0	1.4	8.1	1.8
11/01/2020 12:00	7.8	2.1	1.6	8.6	1.8
11/01/2020 13:00	10.0	2.2	1.7	9.2	2.0
11/01/2020 14:00	10.0	2.2	1.7	9.2	2.0
11/01/2020 15:00	9.9	3.0	1.7	9.1	2.0
11/01/2020 16:00	14.2	6.0	2.0	11.1	2.4
11/01/2020 17:00	14.9	5.4	2.1	11.7	2.6
11/01/2020 18:00	15.1	5.1	2.1	11.9	2.6
11/01/2020 19:00	14.9	5.1	2.1	11.7	2.6
11/01/2020 20:00	14.8	5.4	2.1	11.7	2.6
11/01/2020 21:00	15.2	5.1	2.1	11.9	2.6
11/01/2020 22:00	14.6	5.5	2.1	11.5	2.5
11/01/2020 23:00	16.7	5.5	2.1	11.5	2.5
Average/Sum#:	301.1 #	90.2 #	44.4 #	244.6 #	53.2 #
Minimum:	7.5	1.5	1.4	8.1	1.8
Maximum:	22.0	6.0	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/02/2020 00:00	14.8	4.8	2.1	11.6	2.6
11/02/2020 01:00	14.1	4.4	2.0	11.1	2.4
11/02/2020 02:00	8.3	2.2	1.7	9.0	2.0
11/02/2020 03:00	10.8	3.4	1.8	9.9	2.2
11/02/2020 04:00	14.7	5.1	2.1	11.5	2.5
11/02/2020 05:00	17.0	4.5	2.1	11.7	2.6
11/02/2020 06:00	14.5	4.8	2.1	11.4	2.5
11/02/2020 07:00	8.1	1.8	1.6	9.0	2.0
11/02/2020 08:00	8.3	2.2	1.7	9.2	2.0
11/02/2020 09:00	8.5	2.2	1.7	9.2	2.0
11/02/2020 10:00	9.9	2.2	1.7	9.0	2.0
11/02/2020 11:00	10.0	2.2	1.7	9.2	2.0
11/02/2020 12:00	10.1	2.2	1.7	9.2	2.0
11/02/2020 13:00	11.8	2.2	1.7	9.2	2.0
11/02/2020 14:00	12.0	3.4	1.7	9.4	2.0
11/02/2020 15:00	14.3	5.7	2.0	11.3	2.4
11/02/2020 16:00	15.1	4.3	2.1	11.9	2.6
11/02/2020 17:00	15.0	5.0	2.1	11.7	2.6
11/02/2020 18:00	17.3	4.7	2.1	11.9	2.6
11/02/2020 19:00	15.3	4.4	2.2	11.9	2.6
11/02/2020 20:00	15.1	4.7	2.1	11.9	2.6
11/02/2020 21:00	14.8	5.1	2.1	11.7	2.6
11/02/2020 22:00	14.7	5.1	2.1	11.6	2.6
11/02/2020 23:00	14.3	5.1	2.0	11.2	2.4
Average/Sum#:	308.8 #	91.7 #	46.2 #	254.7 #	55.8 #
Minimum:	8.1	1.8	1.6	9.0	2.0
Maximum:	17.3	5.7	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/03/2020 00:00	14.5	4.8	2.1	11.4	2.5
11/03/2020 01:00	13.7	4.7	2.0	10.7	2.4
11/03/2020 02:00	8.5	2.2	1.7	9.2	2.0
11/03/2020 03:00	11.0	4.2	1.8	10.1	2.2
11/03/2020 04:00	14.8	5.1	2.1	11.6	2.6
11/03/2020 05:00	17.0	4.5	2.1	11.7	2.6
11/03/2020 06:00	15.0	4.4	2.1	11.7	2.6
11/03/2020 07:00	14.1	4.1	2.0	11.1	2.4
11/03/2020 08:00	8.3	2.1	1.7	9.2	2.0
11/03/2020 09:00	8.3	2.2	1.7	9.2	2.0
11/03/2020 10:00	8.4	2.2	1.7	9.2	2.0
11/03/2020 11:00	7.6	2.0	1.6	8.4	1.8
11/03/2020 12:00	7.6	2.0	1.6	8.4	1.8
11/03/2020 13:00	8.0	2.1	1.6	8.8	2.0
11/03/2020 14:00	10.0	2.2	1.7	9.2	2.0
11/03/2020 15:00	10.8	4.1	1.8	9.9	2.2
11/03/2020 16:00	14.9	5.4	2.1	11.7	2.6
11/03/2020 17:00	15.1	5.1	2.1	11.9	2.6
11/03/2020 18:00	15.2	5.1	2.1	11.9	2.6
11/03/2020 19:00	15.2	4.8	2.1	11.9	2.6
11/03/2020 20:00	15.0	5.1	2.1	11.8	2.6
11/03/2020 21:00	14.9	5.1	2.1	11.7	2.6
11/03/2020 22:00	14.7	5.1	2.1	11.5	2.5
11/03/2020 23:00	14.4	5.8	2.0	11.2	2.4
Average/Sum#:	297.0 #	94.4 #	46.0 #	253.4 #	55.6 #
Minimum:	7.6	2.0	1.6	8.4	1.8
Maximum:	17.0	5.8	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/04/2020 00:00	14.4	5.2	2.0	11.3	2.4
11/04/2020 01:00	13.5	4.8	2.0	10.6	2.4
11/04/2020 02:00	8.5	2.2	1.7	9.3	2.0
11/04/2020 03:00	10.9	4.2	1.8	10.0	2.2
11/04/2020 04:00	14.5	5.1	2.1	11.5	2.5
11/04/2020 05:00	14.9	5.1	2.1	11.7	2.6
11/04/2020 06:00	12.9	5.2	2.1	11.8	2.6
11/04/2020 07:00	14.1	4.8	2.0	11.1	2.4
11/04/2020 08:00	8.5	2.2	1.7	9.3	2.0
11/04/2020 09:00	8.2	2.2	1.7	9.0	2.0
11/04/2020 10:00	7.7	2.1	1.6	8.5	1.8
11/04/2020 11:00	8.3	2.2	1.7	9.2	2.0
11/04/2020 12:00	10.1	2.2	1.7	9.2	2.0
11/04/2020 13:00	10.2	2.2	1.7	9.3	2.0
11/04/2020 14:00	10.3	3.2	1.7	9.4	2.0
11/04/2020 15:00	14.2	5.7	2.0	11.1	2.4
11/04/2020 16:00	14.8	5.1	2.1	11.7	2.6
11/04/2020 17:00	15.0	5.1	2.1	11.9	2.6
11/04/2020 18:00	15.3	4.8	2.2	12.1	2.6
11/04/2020 19:00	15.3	4.5	2.2	12.0	2.6
11/04/2020 20:00	15.0	5.1	2.1	11.9	2.6
11/04/2020 21:00	15.0	5.1	2.1	11.7	2.6
11/04/2020 22:00	15.0	5.1	2.1	11.7	2.6
11/04/2020 23:00	14.8	5.1	2.1	11.6	2.6
Average/Sum#:	301.4 #	98.5 #	46.6 #	256.9 #	56.1 #
Minimum:	7.7	2.1	1.6	8.5	1.8
Maximum:	15.3	5.7	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/05/2020 00:00	14.9	4.8	2.1	11.7	2.6
11/05/2020 01:00	14.4	4.4	2.0	11.3	2.4
11/05/2020 02:00	8.2	2.2	1.7	9.0	2.0
11/05/2020 03:00	10.9	3.7	1.8	10.0	2.2
11/05/2020 04:00	14.6	5.1	2.1	11.4	2.5
11/05/2020 05:00	14.8	4.8	2.1	11.6	2.6
11/05/2020 06:00	14.7	4.8	2.1	11.5	2.5
11/05/2020 07:00	13.9	4.8	2.0	10.9	2.4
11/05/2020 08:00	8.0	2.1	1.6	8.8	2.0
11/05/2020 09:00	8.4	2.2	1.7	9.2	2.0
11/05/2020 10:00	8.0	2.1	1.6	8.7	1.9
11/05/2020 11:00	8.0	2.1	1.6	8.7	1.9
11/05/2020 12:00	10.0	2.2	1.7	9.2	2.0
11/05/2020 13:00	9.4	2.1	1.6	8.6	1.8
11/05/2020 14:00	12.2	3.4	1.7	9.6	2.1
11/05/2020 15:00	14.9	5.0	2.1	11.7	2.6
11/05/2020 16:00	14.3	5.3	2.0	11.3	2.4
11/05/2020 17:00	14.9	5.0	2.1	11.7	2.6
11/05/2020 18:00	14.9	5.0	2.1	11.7	2.6
11/05/2020 19:00	14.4	5.4	2.1	11.3	2.4
11/05/2020 20:00	15.1	5.0	2.1	11.9	2.6
11/05/2020 21:00	15.3	5.0	2.2	11.9	2.6
11/05/2020 22:00	14.6	5.4	2.1	11.5	2.5
11/05/2020 23:00	14.6	5.4	2.1	11.5	2.5
Average/Sum#:	303.4 #	97.3 #	46.3 #	254.7 #	55.7 #
Minimum:	8.0	2.1	1.6	8.6	1.8
Maximum:	15.3	5.4	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/06/2020 00:00	14.5	5.4	2.1	11.5	2.5
11/06/2020 01:00	13.4	6.0	1.9	10.5	2.3
11/06/2020 02:00	9.9	2.7	1.7	9.0	2.0
11/06/2020 03:00	8.0	2.4	1.6	8.8	2.0
11/06/2020 04:00	10.9	4.7	1.8	10.0	2.2
11/06/2020 05:00	16.9	5.7	2.1	11.6	2.6
11/06/2020 06:00	14.2	5.1	2.0	11.2	2.4
11/06/2020 07:00	14.5	4.7	2.1	11.4	2.5
11/06/2020 08:00	5.7	1.6	1.4	7.9	1.8
11/06/2020 09:00	5.4	1.8	1.3	7.4	1.6
11/06/2020 10:00	5.2	1.7	1.3	7.2	1.6
11/06/2020 11:00	5.2	1.4	1.3	7.1	1.6
11/06/2020 12:00	7.1	1.9	1.4	7.9	1.8
11/06/2020 13:00	7.0	1.8	1.4	7.7	1.6
11/06/2020 14:00	6.6	2.0	1.3	7.3	1.6
11/06/2020 15:00	10.9	4.8	1.8	10.0	2.2
11/06/2020 16:00	14.8	6.0	2.1	11.7	2.6
11/06/2020 17:00	15.0	5.0	2.1	11.7	2.6
11/06/2020 18:00	14.9	4.8	2.1	11.7	2.6
11/06/2020 19:00	13.9	5.1	2.0	10.9	2.4
11/06/2020 20:00	13.5	5.1	2.0	10.5	2.3
11/06/2020 21:00	7.6	2.0	1.6	8.4	1.8
11/06/2020 22:00	10.5	3.1	1.7	9.6	2.1
11/06/2020 23:00	13.9	5.1	2.0	11.0	2.4
Average/Sum#:	259.5 #	89.9 #	42.1 #	232.0 #	51.1 #
Minimum:	5.2	1.4	1.3	7.1	1.6
Maximum:	16.9	6.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/07/2020 00:00	13.3	5.1	1.9	10.5	2.2
11/07/2020 01:00	10.1	2.2	1.7	9.2	2.0
11/07/2020 02:00	10.3	3.4	1.7	9.4	2.0
11/07/2020 03:00	13.4	5.8	2.0	10.5	2.3
11/07/2020 04:00	15.3	5.8	1.9	10.5	2.3
11/07/2020 05:00	6.6	2.4	1.7	9.0	2.0
11/07/2020 06:00	8.0	2.4	1.6	8.8	2.0
11/07/2020 07:00	8.0	2.1	1.6	8.8	2.0
11/07/2020 08:00	3.3	2.5	1.7	9.1	2.0
11/07/2020 09:00	3.1	2.3	1.6	8.5	1.8
11/07/2020 10:00	2.8	2.1	1.4	7.7	1.6
11/07/2020 11:00	2.8	2.1	1.4	7.7	1.6
11/07/2020 12:00	3.1	2.1	1.6	8.7	1.8
11/07/2020 13:00	3.0	2.0	1.4	8.1	1.8
11/07/2020 14:00	2.9	2.3	1.4	8.1	1.8
11/07/2020 15:00	4.6	2.3	1.6	8.5	1.8
11/07/2020 16:00	8.1	6.7	2.0	11.3	2.4
11/07/2020 17:00	8.4	5.4	2.1	11.6	2.6
11/07/2020 18:00	8.1	5.0	2.0	11.3	2.4
11/07/2020 19:00	8.1	5.7	2.0	11.2	2.4
11/07/2020 20:00	7.8	5.3	2.0	10.7	2.4
11/07/2020 21:00	3.1	0.6	1.6	8.7	1.8
11/07/2020 22:00	10.9	3.4	1.8	10.0	2.2
11/07/2020 23:00	14.7	3.5	2.1	11.6	2.6
Average/Sum#:	176.7 #	81.9 #	41.8 #	229.5 #	49.8 #
Minimum:	2.8	2.0	1.4	7.7	1.6
Maximum:	15.3	6.7	2.1	11.6	2.6
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/08/2020 00:00	13.7	3.5	2.0	10.8	2.4
11/08/2020 01:00	6.3	1.5	1.6	8.6	1.8
11/08/2020 02:00	6.2	1.2	1.6	8.6	1.8
11/08/2020 03:00	15.3	5.1	2.0	10.5	2.3
11/08/2020 04:00	13.4	4.8	1.9	10.5	2.3
11/08/2020 05:00	6.8	1.2	1.7	9.3	2.0
11/08/2020 06:00	6.6	1.2	1.7	9.1	2.0
11/08/2020 07:00	6.3	1.2	1.6	8.6	1.8
11/08/2020 08:00	6.6	1.2	1.7	9.2	2.0
11/08/2020 09:00	6.6	1.2	1.7	9.1	2.0
11/08/2020 10:00	6.8	1.2	1.7	9.3	2.0
11/08/2020 11:00	6.2	1.2	1.6	8.5	1.8
11/08/2020 12:00	5.8	1.0	1.4	7.9	1.8
11/08/2020 13:00	6.6	1.2	1.7	9.1	2.0
11/08/2020 14:00	6.6	1.2	1.7	9.2	2.0
11/08/2020 15:00	6.8	1.2	1.7	9.2	2.0
11/08/2020 16:00	11.1	3.2	1.8	10.1	2.2
11/08/2020 17:00	15.2	3.8	2.1	11.9	2.6
11/08/2020 18:00	14.6	3.8	2.1	11.4	2.5
11/08/2020 19:00	14.3	3.8	2.0	11.2	2.4
11/08/2020 20:00	6.6	0.9	1.7	9.2	2.0
11/08/2020 21:00	6.4	1.2	1.6	8.7	1.9
11/08/2020 22:00	10.9	3.2	1.8	10.0	2.2
11/08/2020 23:00	14.7	4.2	2.1	11.5	2.5
Average/Sum#:	220.4 #	53.2 #	42.5 #	231.5 #	50.3 #
Minimum:	5.8	0.9	1.4	7.9	1.8
Maximum:	15.3	5.1	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/09/2020 00:00	13.5	3.8	2.0	10.7	2.4
11/09/2020 01:00	6.2	0.9	1.6	8.4	1.8
11/09/2020 02:00	5.2	0.7	1.3	7.2	1.6
11/09/2020 03:00	5.2	1.0	1.3	7.2	1.6
11/09/2020 04:00	10.5	2.4	1.7	9.6	2.1
11/09/2020 05:00	15.0	3.6	2.1	11.8	2.6
11/09/2020 06:00	15.5	3.5	2.3	12.2	2.7
11/09/2020 07:00	14.5	3.6	2.1	11.4	2.5
11/09/2020 08:00	13.6	3.9	2.0	10.7	2.4
11/09/2020 09:00	6.1	0.9	1.6	8.3	1.8
11/09/2020 10:00	6.2	1.2	1.6	8.5	1.8
11/09/2020 11:00	5.8	0.9	1.4	7.9	1.8
11/09/2020 12:00	5.9	0.9	1.4	8.1	1.8
11/09/2020 13:00	5.6	1.0	1.4	7.7	1.7
11/09/2020 14:00	6.5	1.2	1.6	9.0	2.0
11/09/2020 15:00	10.8	2.9	1.8	9.9	2.2
11/09/2020 16:00	14.2	3.5	2.0	11.2	2.4
11/09/2020 17:00	14.4	3.2	2.1	11.4	2.4
11/09/2020 18:00	14.8	3.2	2.1	11.6	2.6
11/09/2020 19:00	14.8	3.2	2.1	11.6	2.6
11/09/2020 20:00	15.4	3.2	2.3	12.1	2.6
11/09/2020 21:00	15.2	3.5	2.1	11.9	2.6
11/09/2020 22:00	14.4	3.5	2.1	11.3	2.4
11/09/2020 23:00	14.2	3.9	2.0	11.1	2.4
Average/Sum#:	263.5 #	59.6 #	44.0 #	240.8 #	52.8 #
Minimum:	5.2	0.7	1.3	7.2	1.6
Maximum:	15.5	3.9	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/10/2020 00:00	14.2	3.9	2.0	11.2	2.4
11/10/2020 01:00	13.6	4.6	2.0	10.7	2.4
11/10/2020 02:00	6.8	0.9	1.7	9.2	2.0
11/10/2020 03:00	11.0	2.6	1.8	10.1	2.2
11/10/2020 04:00	14.2	4.0	2.0	11.0	2.4
11/10/2020 05:00	14.2	4.0	2.0	11.2	2.4
11/10/2020 06:00	14.3	4.6	2.0	11.2	2.4
11/10/2020 07:00	14.1	4.3	2.0	11.0	2.4
11/10/2020 08:00	11.7	5.0	2.0	10.7	2.4
11/10/2020 09:00	6.6	1.2	1.7	9.0	2.0
11/10/2020 10:00	6.6	1.2	1.7	9.2	2.0
11/10/2020 11:00	5.6	1.0	1.4	7.7	1.6
11/10/2020 12:00	6.0	1.2	1.6	8.3	1.8
11/10/2020 13:00	6.1	1.2	1.6	8.4	1.8
11/10/2020 14:00	5.6	1.0	1.4	7.7	1.6
11/10/2020 15:00	10.0	2.1	1.7	9.2	2.0
11/10/2020 16:00	14.0	4.5	2.0	11.0	2.4
11/10/2020 17:00	14.6	3.8	2.1	11.5	2.5
11/10/2020 18:00	15.4	3.5	2.3	12.1	2.6
11/10/2020 19:00	15.3	3.2	2.2	12.1	2.6
11/10/2020 20:00	14.9	3.8	2.1	11.7	2.6
11/10/2020 21:00	14.8	3.8	2.1	11.6	2.6
11/10/2020 22:00	14.4	3.9	2.1	11.3	2.4
11/10/2020 23:00	14.3	3.9	2.0	11.3	2.4
Average/Sum#:	278.3 #	73.2 #	45.5 #	248.4 #	53.9 #
Minimum:	5.6	0.9	1.4	7.7	1.6
Maximum:	15.4	5.0	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/11/2020 00:00	14.3	4.3	2.0	11.3	2.4
11/11/2020 01:00	13.5	4.6	2.0	10.7	2.4
11/11/2020 02:00	6.4	1.2	1.6	8.7	1.9
11/11/2020 03:00	11.0	3.2	1.9	10.1	2.2
11/11/2020 04:00	14.1	4.3	2.0	11.1	2.4
11/11/2020 05:00	14.4	4.6	2.1	11.4	2.4
11/11/2020 06:00	15.1	4.2	2.1	11.8	2.6
11/11/2020 07:00	13.9	4.6	2.0	10.9	2.4
11/11/2020 08:00	6.8	1.2	1.7	9.2	2.0
11/11/2020 09:00	6.7	1.2	1.7	9.2	2.0
11/11/2020 10:00	6.6	1.2	1.7	9.0	2.0
11/11/2020 11:00	6.2	1.2	1.6	8.6	1.8
11/11/2020 12:00	6.6	1.2	1.7	9.0	2.0
11/11/2020 13:00	6.1	1.2	1.6	8.3	1.8
11/11/2020 14:00	6.8	1.2	1.7	9.2	2.0
11/11/2020 15:00	5.6	1.0	1.4	7.6	1.6
11/11/2020 16:00	13.0	3.8	1.9	10.3	2.2
11/11/2020 17:00	14.1	4.4	2.0	11.1	2.4
11/11/2020 18:00	14.5	4.1	2.1	11.4	2.5
11/11/2020 19:00	14.3	4.5	2.0	11.3	2.4
11/11/2020 20:00	14.1	4.2	2.0	11.0	2.4
11/11/2020 21:00	6.6	1.2	1.7	9.2	2.0
11/11/2020 22:00	11.0	3.2	1.8	10.1	2.2
11/11/2020 23:00	14.2	4.6	2.0	11.1	2.4
Average/Sum#:	255.9 #	70.4 #	44.3 #	241.6 #	52.4 #
Minimum:	5.6	1.0	1.4	7.6	1.6
Maximum:	15.1	4.6	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/12/2020 00:00	14.2	4.5	2.0	11.2	2.4
11/12/2020 01:00	11.6	4.9	1.9	10.6	2.4
11/12/2020 02:00	6.2	1.2	1.6	8.6	1.8
11/12/2020 03:00	8.5	2.1	1.7	9.2	2.0
11/12/2020 04:00	14.2	4.6	2.0	11.2	2.4
11/12/2020 05:00	14.4	4.9	2.1	11.4	2.4
11/12/2020 06:00	15.5	4.2	2.3	12.2	2.6
11/12/2020 07:00	14.5	3.9	2.1	11.5	2.5
11/12/2020 08:00	6.5	1.2	1.6	9.0	2.0
11/12/2020 09:00	6.6	1.2	1.6	9.0	2.0
11/12/2020 10:00	6.7	1.2	1.7	9.2	2.0
11/12/2020 11:00	6.4	1.2	1.6	8.8	2.0
11/12/2020 12:00	6.8	1.2	1.7	9.3	2.0
11/12/2020 13:00	6.3	1.2	1.6	8.6	1.8
11/12/2020 14:00	6.2	1.2	1.6	8.6	1.8
11/12/2020 15:00	10.1	2.4	1.7	9.2	2.0
11/12/2020 16:00	14.3	4.7	2.0	11.3	2.4
11/12/2020 17:00	14.5	4.4	2.1	11.4	2.5
11/12/2020 18:00	14.6	4.4	2.1	11.5	2.5
11/12/2020 19:00	14.8	4.1	2.1	11.7	2.6
11/12/2020 20:00	14.1	4.1	2.0	11.1	2.4
11/12/2020 21:00	6.6	1.2	1.7	9.2	2.0
11/12/2020 22:00	10.9	3.5	1.8	10.0	2.2
11/12/2020 23:00	14.2	4.8	2.0	11.1	2.4
Average/Sum#:	258.7 #	72.3 #	44.6 #	244.9 #	53.1 #
Minimum:	6.2	1.2	1.6	8.6	1.8
Maximum:	15.5	4.9	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/13/2020 00:00	13.5	5.5	1.9	10.6	2.4
11/13/2020 01:00	9.0	2.4	1.5	8.3	1.8
11/13/2020 02:00	5.2	1.2	1.3	7.1	1.6
11/13/2020 03:00	5.4	1.5	1.4	7.5	1.6
11/13/2020 04:00	5.3	1.7	1.3	7.3	1.6
11/13/2020 05:00	8.0	1.8	1.6	8.8	2.0
11/13/2020 06:00	10.3	1.9	1.7	9.4	2.0
11/13/2020 07:00	10.9	4.2	1.8	10.0	2.2
11/13/2020 08:00	13.0	4.4	1.9	10.3	2.2
11/13/2020 09:00	8.4	1.2	1.7	9.2	2.0
11/13/2020 10:00	8.4	1.2	1.7	9.2	2.0
11/13/2020 11:00	6.6	1.2	1.7	9.0	2.0
11/13/2020 12:00	6.2	1.2	1.6	8.4	1.8
11/13/2020 13:00	9.9	1.5	1.7	9.0	2.0
11/13/2020 14:00	8.3	1.2	1.7	9.2	2.0
11/13/2020 15:00	10.6	3.0	1.7	9.7	2.2
11/13/2020 16:00	14.6	4.7	2.1	11.4	2.5
11/13/2020 17:00	14.4	4.4	2.1	11.3	2.4
11/13/2020 18:00	14.3	4.4	2.0	11.2	2.4
11/13/2020 19:00	13.3	4.7	1.9	10.4	2.3
11/13/2020 20:00	8.4	1.2	1.7	9.2	2.0
11/13/2020 21:00	10.2	2.7	1.7	9.3	2.0
11/13/2020 22:00	14.2	4.8	2.0	11.1	2.4
11/13/2020 23:00	9.8	2.6	1.7	9.0	2.0
Average/Sum#:	238.2 #	64.6 #	41.4 #	225.9 #	49.4 #
Minimum:	5.2	1.2	1.3	7.1	1.6
Maximum:	14.6	5.5	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/14/2020 00:00	6.1	7.0	1.1	4.5	1.0
11/14/2020 01:00	2.7	0.7	1.0	3.4	0.8
11/14/2020 02:00	2.7	0.7	0.9	3.4	0.8
11/14/2020 03:00	2.7	0.7	1.0	3.4	0.8
11/14/2020 04:00	2.7	0.8	0.9	3.4	0.8
11/14/2020 05:00	20.4	12.5	1.3	4.9	1.1
11/14/2020 06:00	40.9	40.3	1.4	6.6	1.5
11/14/2020 07:00	6.4	1.5	1.6	8.8	2.0
11/14/2020 08:00	6.8	1.5	1.7	9.3	2.0
11/14/2020 09:00	6.8	1.2	1.7	9.3	2.0
11/14/2020 10:00	6.8	1.5	1.7	9.3	2.0
11/14/2020 11:00	6.8	1.2	1.7	9.3	2.0
11/14/2020 12:00	6.8	1.2	1.7	9.2	2.0
11/14/2020 13:00	6.8	1.2	1.7	9.2	2.0
11/14/2020 14:00	6.6	1.2	1.7	9.0	2.0
11/14/2020 15:00	10.2	2.1	1.7	9.4	2.0
11/14/2020 16:00	14.1	4.5	2.0	11.1	2.4
11/14/2020 17:00	14.3	4.5	2.0	11.3	2.4
11/14/2020 18:00	14.3	4.2	2.0	11.3	2.4
11/14/2020 19:00	13.9	4.1	2.0	11.0	2.4
11/14/2020 20:00	6.6	1.2	1.7	9.2	2.0
11/14/2020 21:00	11.0	3.2	1.8	10.1	2.2
11/14/2020 22:00	14.2	4.2	2.0	11.2	2.4
11/14/2020 23:00	13.7	4.3	2.0	10.8	2.4
Average/Sum#:	244.3 #	105.5 #	38.3 #	198.4 #	43.4 #
Minimum:	2.7	0.7	0.9	3.4	0.8
Maximum:	40.9	40.3	2.0	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/15/2020 00:00	14.2	4.2	2.0	11.1	2.4
11/15/2020 01:00	13.5	4.2	2.0	10.6	2.4
11/15/2020 02:00	6.4	1.2	1.6	8.9	2.0
11/15/2020 03:00	10.2	2.7	1.7	9.4	2.0
11/15/2020 04:00	14.1	4.9	2.0	11.0	2.4
11/15/2020 05:00	11.4	5.5	1.9	10.4	2.3
11/15/2020 06:00	6.6	1.2	1.7	9.1	2.0
11/15/2020 07:00	6.0	1.6	1.4	8.1	1.8
11/15/2020 08:00	8.3	1.8	1.7	9.2	2.0
11/15/2020 09:00	8.5	1.8	1.7	9.2	2.0
11/15/2020 10:00	8.5	1.9	1.7	9.4	2.0
11/15/2020 11:00	8.5	1.2	1.7	9.3	2.0
11/15/2020 12:00	8.5	1.2	1.7	9.3	2.0
11/15/2020 13:00	6.8	1.2	1.7	9.3	2.0
11/15/2020 14:00	6.8	1.2	1.7	9.2	2.0
11/15/2020 15:00	5.8	1.3	1.4	8.0	1.8
11/15/2020 16:00	6.2	1.2	1.6	8.6	1.8
11/15/2020 17:00	6.2	1.2	1.6	8.6	1.8
11/15/2020 18:00	6.4	1.2	1.6	8.8	2.0
11/15/2020 19:00	6.6	1.2	1.6	9.0	2.0
11/15/2020 20:00	10.9	3.2	1.8	10.0	2.2
11/15/2020 21:00	13.2	3.8	1.9	10.5	2.2
11/15/2020 22:00	10.4	2.6	1.7	9.6	2.0
11/15/2020 23:00	14.1	4.5	2.0	11.1	2.4
Average/Sum#:	218.1 #	56.0 #	41.4 #	227.7 #	49.5 #
Minimum:	5.8	1.2	1.4	8.0	1.8
Maximum:	14.2	5.5	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/16/2020 00:00	12.8	3.8	1.8	10.1	2.2
11/16/2020 01:00	5.2	1.0	1.3	7.2	1.6
11/16/2020 02:00	5.2	1.2	1.3	7.1	1.6
11/16/2020 03:00	5.2	1.2	1.3	7.1	1.6
11/16/2020 04:00	10.1	2.1	1.7	9.2	2.0
11/16/2020 05:00	8.0	4.1	2.0	11.1	2.4
11/16/2020 06:00	8.2	3.5	2.1	11.4	2.5
11/16/2020 07:00	7.9	3.5	2.0	10.9	2.4
11/16/2020 08:00	8.5	1.2	1.7	9.3	2.0
11/16/2020 09:00	6.6	1.2	1.6	9.0	2.0
11/16/2020 10:00	8.3	1.2	1.7	9.2	2.0
11/16/2020 11:00	8.5	0.9	1.7	9.2	2.0
11/16/2020 12:00	8.4	0.9	1.7	9.2	2.0
11/16/2020 13:00	8.4	1.2	1.7	9.2	2.0
11/16/2020 14:00	8.1	1.2	1.6	9.0	2.0
11/16/2020 15:00	10.3	2.1	1.7	9.4	2.0
11/16/2020 16:00	14.2	4.4	2.0	11.2	2.4
11/16/2020 17:00	14.6	3.8	2.1	11.5	2.5
11/16/2020 18:00	14.8	3.8	2.1	11.7	2.6
11/16/2020 19:00	14.8	3.8	2.1	11.6	2.6
11/16/2020 20:00	14.8	3.8	2.1	11.6	2.6
11/16/2020 21:00	14.4	3.8	2.1	11.3	2.4
11/16/2020 22:00	14.5	3.8	2.1	11.4	2.5
11/16/2020 23:00	14.3	4.1	2.0	11.2	2.4
Average/Sum#:	222.0 #	61.6 #	43.5 #	239.1 #	52.3 #
Minimum:	5.2	0.9	1.3	7.1	1.6
Maximum:	14.8	4.4	2.1	11.7	2.6
%SI	12.50	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/17/2020 00:00	14.3	4.1	2.0	11.2	2.4
11/17/2020 01:00	13.9	3.8	2.0	10.9	2.4
11/17/2020 02:00	6.2	1.2	1.6	8.5	1.8
11/17/2020 03:00	7.6	1.4	1.6	8.4	1.8
11/17/2020 04:00	10.4	2.7	1.7	9.5	2.0
11/17/2020 05:00	14.3	4.7	2.0	11.2	2.4
11/17/2020 06:00	14.9	4.7	2.1	11.7	2.6
11/17/2020 07:00	13.9	4.7	2.0	10.9	2.4
11/17/2020 08:00	8.3	1.8	1.7	9.2	2.0
11/17/2020 09:00	6.2	1.8	1.6	8.6	1.8
11/17/2020 10:00	6.2	1.5	1.6	8.5	1.8
11/17/2020 11:00	10.2	1.2	1.7	9.3	2.0
11/17/2020 12:00	5.8	1.4	1.4	8.1	1.8
11/17/2020 13:00	7.8	1.5	1.6	8.6	1.8
11/17/2020 14:00	8.0	1.5	1.6	8.8	2.0
11/17/2020 15:00	10.9	3.7	1.8	10.0	2.2
11/17/2020 16:00	14.7	4.4	2.1	11.5	2.5
11/17/2020 17:00	14.9	3.7	2.1	11.7	2.6
11/17/2020 18:00	14.9	3.8	2.1	11.7	2.6
11/17/2020 19:00	14.7	3.7	2.1	11.5	2.5
11/17/2020 20:00	14.3	4.1	2.1	11.3	2.4
11/17/2020 21:00	14.3	4.1	2.0	11.3	2.4
11/17/2020 22:00	14.3	4.1	2.1	11.3	2.4
11/17/2020 23:00	13.7	4.4	2.0	10.9	2.4
Average/Sum#:	274.7 #	74.0 #	44.6 #	244.6 #	53.0 #
Minimum:	5.8	1.2	1.4	8.1	1.8
Maximum:	14.9	4.7	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/18/2020 00:00	14.3	4.4	2.0	11.3	2.4
11/18/2020 01:00	12.7	3.6	1.8	10.0	2.2
11/18/2020 02:00	5.6	1.3	1.4	7.7	1.6
11/18/2020 03:00	5.2	1.2	1.3	7.2	1.6
11/18/2020 04:00	10.2	2.4	1.7	9.4	2.0
11/18/2020 05:00	14.3	4.7	2.0	11.3	2.4
11/18/2020 06:00	14.8	4.1	2.1	11.6	2.6
11/18/2020 07:00	13.8	3.8	2.0	10.9	2.4
11/18/2020 08:00	6.0	1.2	1.6	8.3	1.8
11/18/2020 09:00	7.6	1.2	1.6	8.3	1.8
11/18/2020 10:00	7.9	1.2	1.6	8.7	1.9
11/18/2020 11:00	10.2	1.2	1.7	9.3	2.0
11/18/2020 12:00	6.6	1.2	1.7	9.2	2.0
11/18/2020 13:00	6.4	1.2	1.6	8.7	1.9
11/18/2020 14:00	6.0	1.2	1.6	8.3	1.8
11/18/2020 15:00	10.2	2.5	1.7	9.4	2.0
11/18/2020 16:00	13.9	5.8	2.0	10.9	2.4
11/18/2020 17:00	14.3	5.1	2.0	11.3	2.4
11/18/2020 18:00	14.6	4.8	2.1	11.5	2.5
11/18/2020 19:00	13.7	4.1	2.0	10.8	2.4
11/18/2020 20:00	13.5	5.1	2.0	10.7	2.4
11/18/2020 21:00	13.5	5.1	2.0	10.7	2.4
11/18/2020 22:00	13.5	5.2	2.0	10.7	2.4
11/18/2020 23:00	13.5	5.3	2.0	10.7	2.4
Average/Sum#:	262.3 #	76.9 #	43.5 #	236.9 #	51.7 #
Minimum:	5.2	1.2	1.3	7.2	1.6
Maximum:	14.8	5.8	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/19/2020 00:00	11.5	5.1	1.9	10.5	2.3
11/19/2020 01:00	6.1	1.2	1.6	8.4	1.8
11/19/2020 02:00	5.5	1.3	1.4	7.5	1.6
11/19/2020 03:00	5.2	1.2	1.3	7.2	1.6
11/19/2020 04:00	5.2	1.2	1.3	7.2	1.6
11/19/2020 05:00	6.2	1.8	1.6	8.5	1.8
11/19/2020 06:00	12.0	5.9	2.0	11.0	2.4
11/19/2020 07:00	13.7	5.3	2.0	10.8	2.4
11/19/2020 08:00	6.4	1.2	1.6	8.8	2.0
11/19/2020 09:00	8.3	1.2	1.7	9.2	2.0
11/19/2020 10:00	8.5	1.2	1.7	9.3	2.0
11/19/2020 11:00	6.4	1.2	1.6	8.8	2.0
11/19/2020 12:00	6.8	1.2	1.7	9.4	2.0
11/19/2020 13:00	6.6	0.9	1.7	9.0	2.0
11/19/2020 14:00	6.7	0.9	1.7	9.2	2.0
11/19/2020 15:00	5.2	1.0	1.3	7.2	1.6
11/19/2020 16:00	6.4	1.2	1.6	8.8	2.0
11/19/2020 17:00	6.8	1.2	1.7	9.4	2.0
11/19/2020 18:00	14.4	4.8	2.0	11.3	2.4
11/19/2020 19:00	14.8	4.2	2.1	11.7	2.6
11/19/2020 20:00	14.6	4.2	2.1	11.5	2.5
11/19/2020 21:00	14.0	4.2	2.0	11.0	2.4
11/19/2020 22:00	14.3	4.2	2.0	11.3	2.4
11/19/2020 23:00	13.7	4.2	2.0	10.7	2.4
Average/Sum#:	219.3 #	60.0 #	41.6 #	227.7 #	49.8 #
Minimum:	5.2	0.9	1.3	7.2	1.6
Maximum:	14.8	5.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/20/2020 00:00	14.3	4.6	2.0	11.2	2.4
11/20/2020 01:00	13.5	4.5	1.9	10.6	2.4
11/20/2020 02:00	6.4	0.9	1.6	8.8	2.0
11/20/2020 03:00	6.4	1.2	1.6	8.8	2.0
11/20/2020 04:00	8.6	2.2	1.7	9.6	2.0
11/20/2020 05:00	14.4	4.5	2.1	11.4	2.4
11/20/2020 06:00	14.8	4.2	2.1	11.6	2.6
11/20/2020 07:00	14.6	3.8	2.1	11.4	2.5
11/20/2020 08:00	14.1	3.9	2.0	11.1	2.4
11/20/2020 09:00	13.9	3.8	2.0	10.9	2.4
11/20/2020 10:00	6.6	0.9	1.7	9.2	2.0
11/20/2020 11:00	6.4	0.9	1.6	8.7	1.9
11/20/2020 12:00	8.2	0.9	1.7	9.0	2.0
11/20/2020 13:00	6.0	0.9	1.6	8.3	1.8
11/20/2020 14:00	6.2	0.9	1.6	8.5	1.8
11/20/2020 15:00	12.8	3.2	1.8	10.0	2.2
11/20/2020 16:00	14.5	5.2	2.1	11.4	2.5
11/20/2020 17:00	14.8	4.6	2.1	11.6	2.6
11/20/2020 18:00	14.9	3.8	2.1	11.7	2.6
11/20/2020 19:00	14.9	3.8	2.1	11.7	2.6
11/20/2020 20:00	14.9	3.8	2.1	11.7	2.6
11/20/2020 21:00	14.8	3.8	2.1	11.6	2.6
11/20/2020 22:00	14.7	3.8	2.1	11.5	2.5
11/20/2020 23:00	14.4	3.9	2.1	11.3	2.4
Average/Sum#:	285.1 #	74.0 #	45.9 #	251.6 #	55.2 #
Minimum:	6.0	0.9	1.6	8.3	1.8
Maximum:	14.9	5.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/21/2020 00:00	14.3	3.9	2.0	11.3	2.4
11/21/2020 01:00	13.5	4.2	2.0	10.7	2.4
11/21/2020 02:00	13.4	4.5	1.9	10.5	2.3
11/21/2020 03:00	7.0	1.4	1.7	9.6	2.1
11/21/2020 04:00	11.0	2.9	1.8	10.1	2.2
11/21/2020 05:00	14.5	4.1	2.1	11.5	2.5
11/21/2020 06:00	14.8	3.8	2.1	11.7	2.6
11/21/2020 07:00	6.4	1.5	1.6	8.9	2.0
11/21/2020 08:00	6.4	0.9	1.6	8.8	2.0
11/21/2020 09:00	6.4	1.2	1.6	8.9	2.0
11/21/2020 10:00	5.9	1.1	1.4	8.1	1.8
11/21/2020 11:00	6.6	0.9	1.7	9.2	2.0
11/21/2020 12:00	6.7	0.9	1.7	9.2	2.0
11/21/2020 13:00	6.8	0.9	1.7	9.3	2.0
11/21/2020 14:00	6.4	0.9	1.6	8.8	2.0
11/21/2020 15:00	11.1	3.5	1.9	10.1	2.2
11/21/2020 16:00	14.5	4.8	2.1	11.4	2.5
11/21/2020 17:00	14.6	4.8	2.1	11.6	2.6
11/21/2020 18:00	14.9	4.8	2.1	11.7	2.6
11/21/2020 19:00	14.8	4.8	2.1	11.7	2.6
11/21/2020 20:00	14.5	4.7	2.1	11.4	2.5
11/21/2020 21:00	8.5	1.2	1.7	9.2	2.0
11/21/2020 22:00	10.9	3.2	1.8	10.0	2.2
11/21/2020 23:00	14.4	4.2	2.1	11.4	2.4
Average/Sum#:	258.3 #	69.1 #	44.5 #	245.1 #	53.9 #
Minimum:	5.9	0.9	1.4	8.1	1.8
Maximum:	14.9	4.8	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/22/2020 00:00	14.3	4.2	2.0	11.2	2.4
11/22/2020 01:00	10.8	2.7	1.8	9.9	2.2
11/22/2020 02:00	5.2	0.7	1.3	7.2	1.6
11/22/2020 03:00	5.4	1.3	1.4	7.5	1.6
11/22/2020 04:00	6.4	1.2	1.6	8.9	2.0
11/22/2020 05:00	11.0	4.4	1.8	10.1	2.2
11/22/2020 06:00	11.2	4.2	1.9	10.3	2.2
11/22/2020 07:00	6.0	1.2	1.6	8.3	1.8
11/22/2020 08:00	6.7	1.2	1.7	9.2	2.0
11/22/2020 09:00	6.8	1.2	1.7	9.3	2.0
11/22/2020 10:00	6.4	1.2	1.6	8.9	2.0
11/22/2020 11:00	6.6	1.2	1.7	9.2	2.0
11/22/2020 12:00	6.6	1.2	1.7	9.0	2.0
11/22/2020 13:00	6.6	1.2	1.7	9.0	2.0
11/22/2020 14:00	6.8	1.2	1.7	9.3	2.0
11/22/2020 15:00	11.0	3.2	1.8	10.1	2.2
11/22/2020 16:00	14.5	4.7	2.1	11.4	2.5
11/22/2020 17:00	14.6	4.1	2.1	11.5	2.5
11/22/2020 18:00	14.5	4.1	2.1	11.4	2.5
11/22/2020 19:00	14.2	4.1	2.0	11.1	2.4
11/22/2020 20:00	6.8	1.2	1.7	9.2	2.0
11/22/2020 21:00	11.1	3.2	1.9	10.1	2.2
11/22/2020 22:00	14.6	4.7	2.1	11.4	2.5
11/22/2020 23:00	11.2	3.5	1.9	10.2	2.2
Average/Sum#:	229.3 #	61.1 #	42.9 #	233.7 #	51.0 #
Minimum:	5.2	0.7	1.3	7.2	1.6
Maximum:	14.6	4.7	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/23/2020 00:00	10.2	2.1	1.7	9.4	2.0
11/23/2020 01:00	11.5	4.4	1.9	10.6	2.3
11/23/2020 02:00	9.7	8.0	1.4	7.1	1.6
11/23/2020 03:00	2.8	0.8	1.0	3.5	0.8
11/23/2020 04:00	2.8	0.8	1.0	3.5	0.8
11/23/2020 05:00	15.3	19.4	1.3	5.4	1.2
11/23/2020 06:00	37.9	29.3	1.4	7.0	1.5
11/23/2020 07:00	6.8	1.2	1.7	9.3	2.0
11/23/2020 08:00	6.5	1.2	1.6	9.0	2.0
11/23/2020 09:00	6.6	1.2	1.7	9.2	2.0
11/23/2020 10:00	6.4	1.2	1.6	8.7	1.9
11/23/2020 11:00	6.6	1.2	1.7	9.2	2.0
11/23/2020 12:00	6.8	1.2	1.7	9.2	2.0
11/23/2020 13:00	6.6	1.2	1.7	9.0	2.0
11/23/2020 14:00	6.8	1.2	1.7	9.2	2.0
11/23/2020 15:00	10.5	2.3	1.7	9.6	2.1
11/23/2020 16:00	14.5	4.8	2.1	11.4	2.5
11/23/2020 17:00	14.6	4.8	2.1	11.5	2.5
11/23/2020 18:00	14.6	4.5	2.1	11.5	2.5
11/23/2020 19:00	13.7	4.1	2.0	10.7	2.4
11/23/2020 20:00	6.6	1.2	1.7	9.2	2.0
11/23/2020 21:00	10.2	2.1	1.7	9.4	2.0
11/23/2020 22:00	14.1	4.2	2.0	11.1	2.4
11/23/2020 23:00	13.7	4.2	2.0	10.8	2.4
Average/Sum#:	255.8 #	106.6 #	40.5 #	214.5 #	46.9 #
Minimum:	2.8	0.8	1.0	3.5	0.8
Maximum:	37.9	29.3	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/24/2020 00:00	11.6	4.2	2.0	10.7	2.4
11/24/2020 01:00	6.2	1.2	1.6	8.6	1.8
11/24/2020 02:00	6.2	1.2	1.6	8.6	1.8
11/24/2020 03:00	6.4	1.2	1.6	8.7	1.8
11/24/2020 04:00	10.9	3.2	1.8	10.0	2.2
11/24/2020 05:00	14.5	4.5	2.1	11.4	2.5
11/24/2020 06:00	15.4	4.2	2.3	12.1	2.6
11/24/2020 07:00	14.8	3.9	2.1	11.7	2.6
11/24/2020 08:00	13.1	2.9	1.9	10.3	2.2
11/24/2020 09:00	6.8	1.2	1.7	9.2	2.0
11/24/2020 10:00	6.6	1.2	1.7	9.2	2.0
11/24/2020 11:00	6.7	1.2	1.7	9.2	2.0
11/24/2020 12:00	8.3	0.9	1.7	9.2	2.0
11/24/2020 13:00	8.4	1.2	1.7	9.2	2.0
11/24/2020 14:00	6.4	1.2	1.6	8.8	2.0
11/24/2020 15:00	7.8	2.3	1.6	8.6	1.8
11/24/2020 16:00	14.6	6.4	2.1	11.4	2.5
11/24/2020 17:00	14.9	5.4	2.1	11.7	2.6
11/24/2020 18:00	15.0	5.1	2.1	11.8	2.6
11/24/2020 19:00	15.1	5.1	2.1	11.8	2.6
11/24/2020 20:00	15.1	4.5	2.1	11.8	2.6
11/24/2020 21:00	14.9	3.9	2.1	11.8	2.6
11/24/2020 22:00	14.8	3.9	2.1	11.6	2.6
11/24/2020 23:00	14.5	4.3	2.1	11.4	2.4
Average/Sum#:	269.0 #	74.3 #	45.5 #	248.8 #	54.2 #
Minimum:	6.2	0.9	1.6	8.6	1.8
Maximum:	15.4	6.4	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/25/2020 00:00	14.5	4.2	2.1	11.4	2.4
11/25/2020 01:00	11.6	4.2	2.0	10.6	2.4
11/25/2020 02:00	6.2	1.2	1.6	8.6	1.8
11/25/2020 03:00	5.5	1.5	1.4	7.5	1.6
11/25/2020 04:00	6.2	2.0	1.6	8.6	1.8
11/25/2020 05:00	14.1	5.2	2.0	11.1	2.4
11/25/2020 06:00	14.0	5.6	2.0	11.0	2.4
11/25/2020 07:00	16.0	5.1	2.0	11.0	2.4
11/25/2020 08:00	8.3	1.2	1.7	9.2	2.0
11/25/2020 09:00	8.2	1.2	1.6	9.0	2.0
11/25/2020 10:00	6.8	1.2	1.7	9.4	2.0
11/25/2020 11:00	6.8	1.2	1.7	9.4	2.0
11/25/2020 12:00	6.8	1.2	1.7	9.3	2.0
11/25/2020 13:00	6.8	1.2	1.7	9.2	2.0
11/25/2020 14:00	8.2	1.2	1.7	9.1	2.0
11/25/2020 15:00	5.4	1.0	1.4	7.4	1.6
11/25/2020 16:00	6.6	1.2	1.6	9.0	2.0
11/25/2020 17:00	6.4	1.2	1.6	8.8	2.0
11/25/2020 18:00	6.8	1.2	1.7	9.4	2.0
11/25/2020 19:00	13.0	3.5	1.9	10.2	2.2
11/25/2020 20:00	17.4	3.8	2.0	10.5	2.3
11/25/2020 21:00	10.8	2.6	1.8	9.9	2.2
11/25/2020 22:00	20.3	4.9	2.0	11.2	2.4
11/25/2020 23:00	16.6	15.3	0.6	3.4	0.8
Average/Sum#:	243.3 #	72.1 #	41.1 #	224.2 #	48.7 #
Minimum:	5.4	1.0	0.6	3.4	0.8
Maximum:	20.3	15.3	2.1	11.4	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 01:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 02:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 03:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 04:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 05:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 06:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 07:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 08:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 09:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 10:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 11:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 12:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 13:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 14:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 15:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 16:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 17:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 18:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 19:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 20:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 21:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 22:00	0.0	0.0	0.0	0.0	0.0
11/26/2020 23:00	73.6	62.6	0.2	0.8	0.2
Average/Sum#:	73.6 #	62.6 #	0.2 #	0.8 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	73.6	62.6	0.2	0.8	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/27/2020 00:00	40.4	35.0	0.4	1.5	0.4
11/27/2020 01:00	49.9	56.4	0.7	2.4	0.6
11/27/2020 02:00	2.9	0.5	1.0	3.6	0.9
11/27/2020 03:00	2.8	0.8	1.0	3.5	0.8
11/27/2020 04:00	89.0	71.0	1.3	5.4	1.3
11/27/2020 05:00	50.2	31.1	1.3	6.8	1.5
11/27/2020 06:00	8.5	1.2	1.7	9.4	2.0
11/27/2020 07:00	6.4	1.2	1.6	8.8	2.0
11/27/2020 08:00	8.1	1.5	1.6	8.9	2.0
11/27/2020 09:00	8.5	1.2	1.7	9.4	2.0
11/27/2020 10:00	8.5	1.2	1.7	9.3	2.0
11/27/2020 11:00	8.5	1.2	1.7	9.4	2.0
11/27/2020 12:00	10.2	1.2	1.7	9.3	2.0
11/27/2020 13:00	8.1	1.2	1.6	8.9	2.0
11/27/2020 14:00	10.0	1.2	1.7	9.2	2.0
11/27/2020 15:00	8.0	1.5	1.6	8.7	1.9
11/27/2020 16:00	14.0	4.9	2.0	11.0	2.4
11/27/2020 17:00	14.6	4.5	2.1	11.6	2.6
11/27/2020 18:00	14.4	4.2	2.1	11.3	2.4
11/27/2020 19:00	14.4	4.8	2.0	11.3	2.4
11/27/2020 20:00	13.9	4.8	2.0	10.9	2.4
11/27/2020 21:00	8.5	1.2	1.7	9.4	2.0
11/27/2020 22:00	11.1	3.6	1.9	10.1	2.2
11/27/2020 23:00	14.3	5.0	2.0	11.2	2.4
Average/Sum#:	425.2 #	240.4 #	38.1 #	201.3 #	44.2 #
Minimum:	2.8	0.5	0.4	1.5	0.4
Maximum:	89.0	71.0	2.1	11.6	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/28/2020 00:00	14.4	4.9	2.0	11.3	2.4
11/28/2020 01:00	11.6	5.0	2.0	10.7	2.4
11/28/2020 02:00	6.4	1.2	1.6	8.8	2.0
11/28/2020 03:00	11.0	3.5	1.8	10.1	2.2
11/28/2020 04:00	11.7	5.3	2.0	10.7	2.4
11/28/2020 05:00	13.8	5.0	2.0	10.8	2.4
11/28/2020 06:00	8.5	1.2	1.7	9.4	2.0
11/28/2020 07:00	6.6	1.5	1.7	9.0	2.0
11/28/2020 08:00	8.5	1.9	1.7	9.3	2.0
11/28/2020 09:00	6.2	1.2	1.6	8.6	1.8
11/28/2020 10:00	8.2	1.2	1.6	9.0	2.0
11/28/2020 11:00	8.5	1.2	1.7	9.4	2.0
11/28/2020 12:00	8.5	1.2	1.7	9.4	2.0
11/28/2020 13:00	7.8	1.2	1.6	8.5	1.8
11/28/2020 14:00	8.2	1.2	1.6	9.0	2.0
11/28/2020 15:00	10.2	2.1	1.7	9.4	2.0
11/28/2020 16:00	14.3	4.2	2.0	11.2	2.4
11/28/2020 17:00	14.6	4.1	2.1	11.5	2.5
11/28/2020 18:00	14.9	4.1	2.1	11.7	2.6
11/28/2020 19:00	14.9	4.1	2.1	11.7	2.6
11/28/2020 20:00	15.2	3.8	2.1	12.0	2.6
11/28/2020 21:00	10.9	2.4	1.8	10.0	2.2
11/28/2020 22:00	11.0	3.2	1.9	10.1	2.2
11/28/2020 23:00	14.4	4.6	2.0	11.3	2.4
Average/Sum#:	260.3 #	69.3 #	44.1 #	242.9 #	52.9 #
Minimum:	6.2	1.2	1.6	8.5	1.8
Maximum:	15.2	5.3	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/29/2020 00:00	11.6	4.9	2.0	10.6	2.4
11/29/2020 01:00	6.3	1.2	1.6	8.6	1.8
11/29/2020 02:00	11.2	3.2	1.9	10.3	2.2
11/29/2020 03:00	14.4	4.9	2.0	11.3	2.4
11/29/2020 04:00	14.2	4.6	2.0	11.2	2.4
11/29/2020 05:00	6.8	1.2	1.7	9.4	2.0
11/29/2020 06:00	6.8	1.2	1.7	9.3	2.0
11/29/2020 07:00	6.4	1.2	1.6	8.8	2.0
11/29/2020 08:00	8.3	1.2	1.7	9.0	2.0
11/29/2020 09:00	8.0	1.2	1.6	8.8	2.0
11/29/2020 10:00	8.5	1.2	1.7	9.4	2.0
11/29/2020 11:00	8.3	1.2	1.7	9.2	2.0
11/29/2020 12:00	8.5	1.2	1.7	9.2	2.0
11/29/2020 13:00	8.5	1.2	1.7	9.2	2.0
11/29/2020 14:00	8.3	1.2	1.7	9.2	2.0
11/29/2020 15:00	8.5	1.2	1.7	9.2	2.0
11/29/2020 16:00	11.1	3.2	1.8	10.1	2.2
11/29/2020 17:00	14.8	4.5	2.1	11.6	2.6
11/29/2020 18:00	15.3	4.1	2.2	12.0	2.6
11/29/2020 19:00	14.7	3.8	2.1	11.5	2.5
11/29/2020 20:00	8.5	1.2	1.7	9.4	2.0
11/29/2020 21:00	11.1	3.5	1.9	10.1	2.2
11/29/2020 22:00	14.8	4.6	2.1	11.7	2.6
11/29/2020 23:00	14.4	4.6	2.1	11.3	2.4
Average/Sum#:	249.3 #	61.5 #	44.0 #	240.4 #	52.3 #
Minimum:	6.3	1.2	1.6	8.6	1.8
Maximum:	15.3	4.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/30/2020 00:00	14.5	4.6	2.1	11.4	2.5
11/30/2020 01:00	14.3	4.6	2.0	11.2	2.4
11/30/2020 02:00	6.3	1.2	1.6	8.7	1.8
11/30/2020 03:00	6.2	1.2	1.6	8.5	1.8
11/30/2020 04:00	10.7	3.2	1.7	9.8	2.2
11/30/2020 05:00	14.8	4.9	2.1	11.6	2.6
11/30/2020 06:00	14.8	4.9	2.1	11.7	2.6
11/30/2020 07:00	14.8	4.6	2.1	11.6	2.6
11/30/2020 08:00	13.7	4.5	2.0	10.8	2.4
11/30/2020 09:00	6.7	1.2	1.7	9.2	2.0
11/30/2020 10:00	6.3	1.2	1.6	8.6	1.8
11/30/2020 11:00	8.2	1.2	1.7	9.0	2.0
11/30/2020 12:00	8.1	1.2	1.6	9.0	2.0
11/30/2020 13:00	5.7	1.0	1.4	7.9	1.8
11/30/2020 14:00	8.3	1.2	1.7	9.2	2.0
11/30/2020 15:00	10.2	2.1	1.7	9.4	2.0
11/30/2020 16:00	14.3	4.8	2.1	11.3	2.4
11/30/2020 17:00	14.9	4.1	2.1	11.7	2.6
11/30/2020 18:00	15.0	4.1	2.1	11.8	2.6
11/30/2020 19:00	15.4	3.8	2.2	12.1	2.6
11/30/2020 20:00	15.0	3.8	2.1	11.7	2.6
11/30/2020 21:00	14.9	3.8	2.1	11.7	2.6
11/30/2020 22:00	14.7	3.9	2.1	11.5	2.5
11/30/2020 23:00	14.3	3.8	2.0	11.2	2.4
Average/Sum#:	282.1 #	74.9 #	45.5 #	250.6 #	54.8 #
Minimum:	5.7	1.0	1.4	7.9	1.8
Maximum:	15.4	4.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/01/2020 00:00	14.4	4.2	2.1	11.3	2.4
12/01/2020 01:00	14.3	4.1	2.0	11.3	2.4
12/01/2020 02:00	6.2	1.2	1.6	8.6	1.8
12/01/2020 03:00	11.1	3.2	1.9	10.1	2.2
12/01/2020 04:00	14.8	4.1	2.1	11.6	2.6
12/01/2020 05:00	17.6	3.8	2.2	12.0	2.6
12/01/2020 06:00	15.6	3.5	2.3	12.3	2.7
12/01/2020 07:00	15.2	3.8	2.1	11.9	2.6
12/01/2020 08:00	14.7	3.8	2.1	11.6	2.6
12/01/2020 09:00	10.3	1.5	1.7	9.4	2.0
12/01/2020 10:00	8.5	1.3	1.7	9.4	2.0
12/01/2020 11:00	8.3	1.2	1.7	9.2	2.0
12/01/2020 12:00	10.1	0.9	1.7	9.2	2.0
12/01/2020 13:00	5.6	0.6	1.4	7.7	1.6
12/01/2020 14:00	8.0	1.2	1.6	8.8	2.0
12/01/2020 15:00	6.2	1.2	1.6	8.5	1.8
12/01/2020 16:00	14.1	4.1	2.0	11.1	2.4
12/01/2020 17:00	15.1	3.5	2.1	11.9	2.6
12/01/2020 18:00	15.3	3.2	2.2	12.1	2.6
12/01/2020 19:00	15.3	3.2	2.2	12.1	2.6
12/01/2020 20:00	15.4	3.2	2.2	12.1	2.6
12/01/2020 21:00	15.4	3.5	2.2	12.1	2.6
12/01/2020 22:00	15.4	3.5	2.2	12.1	2.6
12/01/2020 23:00	15.0	4.2	2.1	11.8	2.6
Average/Sum#:	301.9 #	68.0 #	47.0 #	258.2 #	55.9 #
Minimum:	5.6	0.6	1.4	7.7	1.6
Maximum:	17.6	4.2	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/02/2020 00:00	14.8	4.2	2.1	11.7	2.6
12/02/2020 01:00	13.9	4.5	2.0	11.0	2.4
12/02/2020 02:00	6.3	1.2	1.6	8.6	1.8
12/02/2020 03:00	11.1	3.2	1.9	10.1	2.2
12/02/2020 04:00	14.6	4.5	2.1	11.4	2.5
12/02/2020 05:00	14.8	4.6	2.1	11.6	2.6
12/02/2020 06:00	15.0	4.2	2.1	11.8	2.6
12/02/2020 07:00	14.8	4.2	2.1	11.7	2.6
12/02/2020 08:00	14.4	4.2	2.1	11.3	2.4
12/02/2020 09:00	6.4	1.2	1.6	8.8	2.0
12/02/2020 10:00	8.3	1.2	1.7	9.2	2.0
12/02/2020 11:00	10.2	1.3	1.7	9.4	2.0
12/02/2020 12:00	10.0	1.2	1.7	9.2	2.0
12/02/2020 13:00	6.2	1.2	1.6	8.5	1.8
12/02/2020 14:00	9.6	1.5	1.6	8.8	2.0
12/02/2020 15:00	11.1	4.1	1.9	10.1	2.2
12/02/2020 16:00	14.8	5.5	2.1	11.6	2.6
12/02/2020 17:00	15.2	5.1	2.1	12.0	2.6
12/02/2020 18:00	15.4	4.5	2.3	12.2	2.6
12/02/2020 19:00	15.4	4.1	2.3	12.2	2.6
12/02/2020 20:00	15.1	4.1	2.1	11.9	2.6
12/02/2020 21:00	14.9	4.1	2.1	11.7	2.6
12/02/2020 22:00	14.8	4.2	2.1	11.7	2.6
12/02/2020 23:00	14.8	4.2	2.1	11.7	2.6
Average/Sum#:	301.9 #	82.3 #	47.1 #	258.2 #	56.5 #
Minimum:	6.2	1.2	1.6	8.5	1.8
Maximum:	15.4	5.5	2.3	12.2	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/03/2020 00:00	14.7	4.2	2.1	11.6	2.6
12/03/2020 01:00	14.7	4.6	2.1	11.6	2.6
12/03/2020 02:00	14.3	4.4	2.0	11.2	2.4
12/03/2020 03:00	6.4	1.2	1.6	8.8	2.0
12/03/2020 04:00	11.1	3.2	1.9	10.1	2.2
12/03/2020 05:00	17.1	4.9	2.1	11.8	2.6
12/03/2020 06:00	15.7	4.2	2.3	12.3	2.7
12/03/2020 07:00	14.8	4.6	2.1	11.6	2.6
12/03/2020 08:00	14.6	4.6	2.1	11.5	2.5
12/03/2020 09:00	13.8	4.5	2.0	10.8	2.4
12/03/2020 10:00	8.5	1.2	1.7	9.4	2.0
12/03/2020 11:00	6.6	1.2	1.7	9.0	2.0
12/03/2020 12:00	8.5	1.2	1.7	9.2	2.0
12/03/2020 13:00	8.5	1.2	1.7	9.2	2.0
12/03/2020 14:00	11.0	3.5	1.9	10.1	2.2
12/03/2020 15:00	14.6	4.8	2.1	11.4	2.5
12/03/2020 16:00	15.0	4.8	2.1	11.8	2.6
12/03/2020 17:00	15.4	4.1	2.3	12.1	2.6
12/03/2020 18:00	15.5	3.2	2.3	12.1	2.7
12/03/2020 19:00	15.5	3.2	2.3	12.1	2.7
12/03/2020 20:00	15.1	3.8	2.1	11.9	2.6
12/03/2020 21:00	15.3	3.8	2.2	12.0	2.6
12/03/2020 22:00	15.1	3.8	2.1	11.9	2.6
12/03/2020 23:00	14.9	4.2	2.1	11.7	2.6
Average/Sum#:	316.7 #	84.4 #	48.6 #	265.2 #	58.3 #
Minimum:	6.4	1.2	1.6	8.8	2.0
Maximum:	17.1	4.9	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/04/2020 00:00	14.8	4.2	2.1	11.7	2.6
12/04/2020 01:00	14.3	4.2	2.1	11.3	2.4
12/04/2020 02:00	6.8	1.2	1.7	9.3	2.0
12/04/2020 03:00	11.2	3.2	1.9	10.3	2.2
12/04/2020 04:00	14.8	4.9	2.1	11.7	2.6
12/04/2020 05:00	15.4	3.8	2.3	12.1	2.6
12/04/2020 06:00	15.6	3.8	2.3	12.3	2.7
12/04/2020 07:00	15.4	4.2	2.2	12.1	2.6
12/04/2020 08:00	14.6	4.6	2.1	11.5	2.5
12/04/2020 09:00	13.9	4.8	2.0	10.9	2.4
12/04/2020 10:00	6.5	1.2	1.6	9.0	2.0
12/04/2020 11:00	8.0	1.2	1.6	8.8	2.0
12/04/2020 12:00	11.6	5.6	2.0	10.6	2.4
12/04/2020 13:00	15.5	5.8	1.9	10.6	2.4
12/04/2020 14:00	8.3	1.2	1.7	9.2	2.0
12/04/2020 15:00	10.9	3.5	1.8	9.9	2.2
12/04/2020 16:00	14.8	5.1	2.1	11.6	2.6
12/04/2020 17:00	15.3	4.4	2.2	12.0	2.6
12/04/2020 18:00	15.3	4.1	2.2	12.0	2.6
12/04/2020 19:00	15.5	3.8	2.3	12.1	2.6
12/04/2020 20:00	15.2	3.8	2.2	12.0	2.6
12/04/2020 21:00	15.4	3.8	2.2	12.1	2.6
12/04/2020 22:00	15.1	4.2	2.1	11.9	2.6
12/04/2020 23:00	14.9	4.2	2.1	11.7	2.6
Average/Sum#:	319.1 #	90.8 #	48.8 #	266.7 #	58.4 #
Minimum:	6.5	1.2	1.6	8.8	2.0
Maximum:	15.6	5.8	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/05/2020 00:00	14.9	4.5	2.1	11.7	2.6
12/05/2020 01:00	14.7	4.6	2.1	11.6	2.6
12/05/2020 02:00	14.8	4.9	2.1	11.7	2.6
12/05/2020 03:00	14.8	4.9	2.1	11.7	2.6
12/05/2020 04:00	14.8	4.9	2.1	11.7	2.6
12/05/2020 05:00	14.8	4.9	2.1	11.7	2.6
12/05/2020 06:00	12.5	4.9	2.1	11.4	2.5
12/05/2020 07:00	6.7	1.2	1.7	9.2	2.0
12/05/2020 08:00	6.6	1.5	1.6	9.0	2.0
12/05/2020 09:00	8.5	1.5	1.7	9.2	2.0
12/05/2020 10:00	8.4	1.2	1.7	9.2	2.0
12/05/2020 11:00	8.5	1.2	1.7	9.4	2.0
12/05/2020 12:00	8.5	1.5	1.7	9.4	2.0
12/05/2020 13:00	8.3	1.5	1.7	9.2	2.0
12/05/2020 14:00	8.3	1.8	1.7	9.0	2.0
12/05/2020 15:00	11.0	4.1	1.9	10.1	2.2
12/05/2020 16:00	14.6	4.9	2.1	11.5	2.5
12/05/2020 17:00	15.2	4.9	2.1	12.0	2.6
12/05/2020 18:00	15.4	4.1	2.3	12.2	2.6
12/05/2020 19:00	15.6	4.1	2.3	12.2	2.7
12/05/2020 20:00	15.6	4.2	2.3	12.2	2.7
12/05/2020 21:00	15.4	4.2	2.3	12.2	2.6
12/05/2020 22:00	14.9	4.9	2.1	11.7	2.6
12/05/2020 23:00	14.8	4.9	2.1	11.6	2.6
Average/Sum#:	297.6 #	85.3 #	47.7 #	260.8 #	57.2 #
Minimum:	6.6	1.2	1.6	9.0	2.0
Maximum:	15.6	4.9	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/06/2020 00:00	14.8	4.9	2.1	11.6	2.6
12/06/2020 01:00	14.6	5.0	2.1	11.4	2.5
12/06/2020 02:00	14.6	4.9	2.1	11.4	2.5
12/06/2020 03:00	13.3	4.8	1.9	10.4	2.2
12/06/2020 04:00	10.8	2.6	1.8	9.9	2.2
12/06/2020 05:00	16.3	4.9	2.0	11.2	2.4
12/06/2020 06:00	11.8	4.4	2.0	10.8	2.4
12/06/2020 07:00	6.2	1.2	1.6	8.6	1.8
12/06/2020 08:00	6.2	1.2	1.6	8.6	1.8
12/06/2020 09:00	6.8	1.2	1.7	9.4	2.0
12/06/2020 10:00	6.8	1.2	1.7	9.4	2.0
12/06/2020 11:00	6.8	1.2	1.7	9.4	2.0
12/06/2020 12:00	6.5	1.2	1.6	9.0	2.0
12/06/2020 13:00	8.5	1.2	1.7	9.3	2.0
12/06/2020 14:00	6.6	1.2	1.7	9.2	2.0
12/06/2020 15:00	11.0	3.9	1.9	10.1	2.2
12/06/2020 16:00	14.6	5.3	2.1	11.5	2.5
12/06/2020 17:00	15.3	4.5	2.3	12.0	2.6
12/06/2020 18:00	15.6	4.5	2.3	12.2	2.7
12/06/2020 19:00	15.6	4.5	2.3	12.2	2.7
12/06/2020 20:00	15.6	4.2	2.3	12.2	2.7
12/06/2020 21:00	15.2	4.5	2.1	12.0	2.6
12/06/2020 22:00	14.8	4.5	2.1	11.7	2.6
12/06/2020 23:00	14.4	4.5	2.0	11.2	2.4
Average/Sum#:	282.7 #	81.5 #	46.7 #	254.7 #	55.4 #
Minimum:	6.2	1.2	1.6	8.6	1.8
Maximum:	16.3	5.3	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/07/2020 00:00	14.6	4.2	2.1	11.5	2.5
12/07/2020 01:00	13.9	4.2	2.0	10.9	2.4
12/07/2020 02:00	6.4	1.2	1.6	8.9	2.0
12/07/2020 03:00	11.0	3.2	1.8	10.1	2.2
12/07/2020 04:00	14.4	4.9	2.1	11.4	2.4
12/07/2020 05:00	14.6	4.5	2.1	11.4	2.5
12/07/2020 06:00	13.1	4.1	2.1	12.0	2.6
12/07/2020 07:00	15.2	4.1	2.1	11.9	2.6
12/07/2020 08:00	15.0	4.1	2.1	11.8	2.6
12/07/2020 09:00	14.9	3.5	2.1	11.7	2.6
12/07/2020 10:00	10.2	1.5	1.7	9.4	2.0
12/07/2020 11:00	8.0	1.2	1.6	8.8	2.0
12/07/2020 12:00	8.0	1.2	1.6	8.8	2.0
12/07/2020 13:00	10.0	1.2	1.7	9.2	2.0
12/07/2020 14:00	10.1	2.1	1.7	9.2	2.0
12/07/2020 15:00	14.3	4.1	2.1	11.3	2.4
12/07/2020 16:00	14.7	3.5	2.1	11.5	2.5
12/07/2020 17:00	15.1	3.5	2.1	11.9	2.6
12/07/2020 18:00	15.0	4.1	2.1	11.8	2.6
12/07/2020 19:00	15.1	4.5	2.1	11.9	2.6
12/07/2020 20:00	15.2	4.5	2.1	11.9	2.6
12/07/2020 21:00	15.4	4.2	2.3	12.1	2.6
12/07/2020 22:00	15.2	4.2	2.1	11.9	2.6
12/07/2020 23:00	14.6	4.5	2.1	11.5	2.5
Average/Sum#:	314.0 #	82.3 #	47.5 #	262.8 #	57.4 #
Minimum:	6.4	1.2	1.6	8.8	2.0
Maximum:	15.4	4.9	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/08/2020 00:00	14.4	4.5	2.1	11.3	2.4
12/08/2020 01:00	13.7	5.5	2.0	10.7	2.4
12/08/2020 02:00	8.3	1.2	1.7	9.2	2.0
12/08/2020 03:00	10.8	2.9	1.8	9.9	2.2
12/08/2020 04:00	14.2	4.9	2.0	11.2	2.4
12/08/2020 05:00	13.9	5.6	2.0	10.9	2.4
12/08/2020 06:00	14.6	4.8	2.1	11.4	2.5
12/08/2020 07:00	15.0	4.1	2.1	11.7	2.6
12/08/2020 08:00	14.7	4.1	2.1	11.5	2.6
12/08/2020 09:00	13.7	4.5	2.0	10.8	2.4
12/08/2020 10:00	6.6	1.2	1.7	9.2	2.0
12/08/2020 11:00	8.0	1.2	1.6	8.7	1.9
12/08/2020 12:00	9.6	1.2	1.6	8.8	2.0
12/08/2020 13:00	7.8	1.2	1.6	8.6	1.8
12/08/2020 14:00	6.2	1.2	1.6	8.5	1.8
12/08/2020 15:00	10.3	2.1	1.7	9.4	2.0
12/08/2020 16:00	14.2	4.7	2.0	11.2	2.4
12/08/2020 17:00	15.2	4.1	2.1	11.9	2.6
12/08/2020 18:00	15.3	4.1	2.2	12.1	2.6
12/08/2020 19:00	15.5	3.8	2.3	12.1	2.7
12/08/2020 20:00	15.2	4.1	2.1	12.0	2.6
12/08/2020 21:00	15.0	4.2	2.1	11.8	2.6
12/08/2020 22:00	14.7	4.9	2.1	11.6	2.6
12/08/2020 23:00	14.5	4.9	2.1	11.4	2.5
Average/Sum#:	301.4 #	85.0 #	46.7 #	255.9 #	56.0 #
Minimum:	6.2	1.2	1.6	8.5	1.8
Maximum:	15.5	5.6	2.3	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/09/2020 00:00	14.5	4.9	2.1	11.4	2.5
12/09/2020 01:00	14.3	4.9	2.0	11.3	2.4
12/09/2020 02:00	11.6	4.9	2.0	10.7	2.4
12/09/2020 03:00	10.6	2.0	1.7	9.7	2.2
12/09/2020 04:00	11.1	3.5	1.8	10.1	2.2
12/09/2020 05:00	14.3	4.9	2.0	11.2	2.4
12/09/2020 06:00	12.7	4.8	2.1	11.6	2.6
12/09/2020 07:00	14.8	4.9	2.1	11.6	2.6
12/09/2020 08:00	14.6	4.9	2.1	11.4	2.5
12/09/2020 09:00	13.4	5.1	2.0	10.6	2.3
12/09/2020 10:00	10.6	1.3	1.7	9.7	2.2
12/09/2020 11:00	10.6	1.3	1.7	9.7	2.2
12/09/2020 12:00	12.3	1.3	1.7	9.7	2.2
12/09/2020 13:00	14.0	1.3	1.7	9.7	2.2
12/09/2020 14:00	14.0	1.3	1.7	9.7	2.2
12/09/2020 15:00	12.8	3.2	1.8	10.0	2.2
12/09/2020 16:00	14.6	4.1	2.1	11.5	2.5
12/09/2020 17:00	15.0	3.5	2.1	11.8	2.6
12/09/2020 18:00	14.8	3.5	2.1	11.8	2.6
12/09/2020 19:00	15.2	4.1	2.2	12.0	2.6
12/09/2020 20:00	15.0	4.5	2.1	11.8	2.6
12/09/2020 21:00	15.4	4.1	2.2	12.1	2.7
12/09/2020 22:00	15.3	4.1	2.2	12.0	2.6
12/09/2020 23:00	14.7	4.5	2.1	11.5	2.5
Average/Sum#:	326.2 #	86.9 #	47.3 #	262.6 #	58.0 #
Minimum:	10.6	1.3	1.7	9.7	2.2
Maximum:	15.4	5.1	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/10/2020 00:00	14.7	4.5	2.1	11.5	2.5
12/10/2020 01:00	14.4	4.5	2.0	11.3	2.4
12/10/2020 02:00	14.4	4.4	2.0	11.4	2.4
12/10/2020 03:00	6.8	1.2	1.7	9.4	2.0
12/10/2020 04:00	11.0	2.9	1.8	10.1	2.2
12/10/2020 05:00	17.3	4.1	2.1	11.9	2.6
12/10/2020 06:00	14.9	4.1	2.1	11.8	2.6
12/10/2020 07:00	14.9	4.1	2.1	11.7	2.6
12/10/2020 08:00	14.9	4.1	2.1	11.7	2.6
12/10/2020 09:00	14.9	3.8	2.1	11.8	2.6
12/10/2020 10:00	8.5	1.5	1.7	9.4	2.0
12/10/2020 11:00	6.6	1.2	1.6	9.0	2.0
12/10/2020 12:00	6.2	1.2	1.6	8.5	1.8
12/10/2020 13:00	6.3	1.2	1.6	8.7	1.9
12/10/2020 14:00	6.2	1.2	1.6	8.5	1.8
12/10/2020 15:00	11.0	3.2	1.8	10.1	2.2
12/10/2020 16:00	14.5	5.2	2.1	11.4	2.5
12/10/2020 17:00	15.1	4.9	2.1	11.9	2.6
12/10/2020 18:00	15.4	3.8	2.2	12.1	2.7
12/10/2020 19:00	15.2	4.1	2.2	11.9	2.6
12/10/2020 20:00	14.9	4.1	2.1	11.7	2.6
12/10/2020 21:00	15.0	4.1	2.1	11.7	2.6
12/10/2020 22:00	14.9	4.1	2.1	11.7	2.6
12/10/2020 23:00	14.6	4.9	2.1	11.5	2.5
Average/Sum#:	302.6 #	82.4 #	47.0 #	260.7 #	56.9 #
Minimum:	6.2	1.2	1.6	8.5	1.8
Maximum:	17.3	5.2	2.2	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/11/2020 00:00	13.6	4.8	2.0	10.7	2.4
12/11/2020 01:00	6.8	1.2	1.7	9.4	2.0
12/11/2020 02:00	6.4	1.2	1.6	8.8	2.0
12/11/2020 03:00	6.4	1.5	1.6	8.8	2.0
12/11/2020 04:00	10.6	3.5	1.7	9.8	2.2
12/11/2020 05:00	14.5	4.9	2.1	11.4	2.4
12/11/2020 06:00	15.0	4.9	2.1	11.8	2.6
12/11/2020 07:00	14.8	4.9	2.1	11.7	2.6
12/11/2020 08:00	14.6	4.9	2.1	11.5	2.5
12/11/2020 09:00	6.7	1.2	1.7	9.2	2.0
12/11/2020 10:00	6.7	1.2	1.7	9.2	2.0
12/11/2020 11:00	6.6	1.2	1.7	9.2	2.0
12/11/2020 12:00	6.6	1.5	1.6	9.0	2.0
12/11/2020 13:00	8.3	1.8	1.7	9.2	2.0
12/11/2020 14:00	8.4	1.8	1.7	9.2	2.0
12/11/2020 15:00	11.0	3.5	1.8	10.1	2.2
12/11/2020 16:00	14.8	5.5	2.1	11.6	2.6
12/11/2020 17:00	15.0	5.1	2.1	11.9	2.6
12/11/2020 18:00	15.6	4.5	2.3	12.2	2.7
12/11/2020 19:00	15.6	4.1	2.3	12.2	2.7
12/11/2020 20:00	15.6	4.1	2.3	12.2	2.7
12/11/2020 21:00	15.6	4.1	2.3	12.2	2.7
12/11/2020 22:00	15.0	4.8	2.1	11.7	2.6
12/11/2020 23:00	14.7	4.9	2.1	11.6	2.6
Average/Sum#:	278.9 #	81.1 #	46.5 #	254.6 #	56.1 #
Minimum:	6.4	1.2	1.6	8.8	2.0
Maximum:	15.6	5.5	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/12/2020 00:00	14.9	4.8	2.1	11.7	2.6
12/12/2020 01:00	14.6	4.8	2.1	11.5	2.5
12/12/2020 02:00	13.7	5.1	2.0	10.7	2.4
12/12/2020 03:00	8.1	1.2	1.6	9.0	2.0
12/12/2020 04:00	11.0	3.8	1.8	10.1	2.2
12/12/2020 05:00	11.7	6.3	2.0	10.7	2.4
12/12/2020 06:00	13.6	6.2	2.0	10.7	2.4
12/12/2020 07:00	8.5	1.5	1.7	9.4	2.0
12/12/2020 08:00	8.4	1.5	1.7	9.2	2.0
12/12/2020 09:00	8.5	1.8	1.7	9.3	2.0
12/12/2020 10:00	8.3	1.5	1.7	9.2	2.0
12/12/2020 11:00	8.0	1.5	1.6	8.7	1.9
12/12/2020 12:00	8.3	1.5	1.7	9.0	2.0
12/12/2020 13:00	8.5	1.5	1.7	9.4	2.0
12/12/2020 14:00	8.4	1.5	1.7	9.2	2.0
12/12/2020 15:00	11.0	3.5	1.8	10.1	2.2
12/12/2020 16:00	14.6	5.1	2.1	11.5	2.5
12/12/2020 17:00	15.1	4.4	2.1	11.9	2.6
12/12/2020 18:00	15.5	4.1	2.2	12.2	2.7
12/12/2020 19:00	15.5	4.1	2.2	12.2	2.7
12/12/2020 20:00	15.5	3.8	2.2	12.2	2.7
12/12/2020 21:00	15.4	3.8	2.2	12.2	2.7
12/12/2020 22:00	15.4	3.8	2.2	12.0	2.7
12/12/2020 23:00	14.9	4.1	2.1	11.7	2.6
Average/Sum#:	287.4 #	81.2 #	46.2 #	253.8 #	55.8 #
Minimum:	8.0	1.2	1.6	8.7	1.9
Maximum:	15.5	6.3	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/13/2020 00:00	14.9	4.5	2.1	11.7	2.6
12/13/2020 01:00	14.5	4.9	2.1	11.3	2.5
12/13/2020 02:00	11.7	4.9	2.0	10.7	2.4
12/13/2020 03:00	13.6	4.9	2.0	10.7	2.4
12/13/2020 04:00	13.8	5.3	2.0	10.8	2.4
12/13/2020 05:00	14.3	4.9	2.0	11.3	2.4
12/13/2020 06:00	14.3	4.9	2.0	11.3	2.4
12/13/2020 07:00	6.4	1.5	1.6	8.8	2.0
12/13/2020 08:00	5.2	1.7	1.3	7.2	1.6
12/13/2020 09:00	5.2	1.7	1.3	7.2	1.6
12/13/2020 10:00	5.2	1.7	1.3	7.2	1.6
12/13/2020 11:00	7.5	1.4	1.6	8.3	1.8
12/13/2020 12:00	8.3	1.8	1.7	9.2	2.0
12/13/2020 13:00	8.5	1.8	1.7	9.2	2.0
12/13/2020 14:00	8.5	1.8	1.7	9.4	2.0
12/13/2020 15:00	10.9	4.1	1.8	10.0	2.2
12/13/2020 16:00	14.4	5.4	2.1	11.3	2.4
12/13/2020 17:00	15.3	4.4	2.2	12.0	2.6
12/13/2020 18:00	15.2	4.1	2.2	12.0	2.6
12/13/2020 19:00	14.9	4.8	2.1	11.7	2.6
12/13/2020 20:00	15.0	4.8	2.1	11.8	2.6
12/13/2020 21:00	14.7	4.9	2.1	11.5	2.5
12/13/2020 22:00	14.4	4.9	2.0	11.3	2.4
12/13/2020 23:00	14.1	4.8	2.0	11.1	2.4
Average/Sum#:	280.8 #	89.9 #	45.0 #	247.0 #	54.0 #
Minimum:	5.2	1.4	1.3	7.2	1.6
Maximum:	15.3	5.4	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/14/2020 00:00	7.4	11.2	0.2	1.1	0.2
12/14/2020 01:00	0.0	0.0	0.0	0.0	0.0
12/14/2020 02:00	0.0	0.0	0.0	0.0	0.0
12/14/2020 03:00	0.0	0.0	0.0	0.0	0.0
12/14/2020 04:00	0.0	0.0	0.0	0.0	0.0
12/14/2020 05:00	29.1	21.3	0.1	1.0	0.2
12/14/2020 06:00	33.9	27.0	0.5	4.6	0.9
12/14/2020 07:00	8.3	2.0	0.6	6.2	1.2
12/14/2020 08:00	8.2	2.0	0.6	6.2	1.2
12/14/2020 09:00	8.1	2.0	0.6	6.1	1.2
12/14/2020 10:00	3.1	0.6	0.5	4.6	0.9
12/14/2020 11:00	3.1	0.6	0.5	4.6	0.9
12/14/2020 12:00	2.8	0.5	0.4	4.3	0.9
12/14/2020 13:00	2.8	0.5	0.4	4.1	0.8
12/14/2020 14:00	0.0	0.0	0.4	4.3	0.9
12/14/2020 15:00	0.0	0.0	0.6	5.6	1.1
12/14/2020 16:00	6.0	1.9	0.6	6.0	1.2
12/14/2020 17:00	8.6	1.6	0.6	6.5	1.3
12/14/2020 18:00	8.7	1.7	0.7	6.5	1.3
12/14/2020 19:00	8.7	1.6	0.7	6.5	1.3
12/14/2020 20:00	8.7	1.6	0.7	6.5	1.3
12/14/2020 21:00	8.7	1.6	0.7	6.5	1.3
12/14/2020 22:00	8.4	1.6	0.6	6.3	1.3
12/14/2020 23:00	5.8	2.0	0.6	5.8	1.2
Average/Sum#:	170.4 #	81.3 #	10.6 #	103.3 #	20.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	33.9	27.0	0.7	6.5	1.3
%SI	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/15/2020 00:00	8.0	2.0	0.6	6.0	1.2
12/15/2020 01:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 02:00	7.8	2.0	0.6	5.8	1.2
12/15/2020 03:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 04:00	8.1	2.0	0.6	6.1	1.2
12/15/2020 05:00	8.6	2.0	0.6	6.5	1.3
12/15/2020 06:00	8.7	2.0	0.7	6.5	1.3
12/15/2020 07:00	8.5	2.0	0.6	6.4	1.3
12/15/2020 08:00	8.1	2.0	0.6	6.1	1.2
12/15/2020 09:00	7.8	2.0	0.6	5.9	1.2
12/15/2020 10:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 11:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 12:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 13:00	5.8	2.0	0.6	5.8	1.2
12/15/2020 14:00	7.8	2.0	0.6	5.8	1.2
12/15/2020 15:00	7.8	2.0	0.6	5.8	1.2
12/15/2020 16:00	8.1	2.0	0.6	6.1	1.2
12/15/2020 17:00	8.6	2.0	0.6	6.5	1.3
12/15/2020 18:00	8.7	2.0	0.7	6.5	1.3
12/15/2020 19:00	8.7	2.0	0.7	6.5	1.3
12/15/2020 20:00	8.6	2.0	0.6	6.5	1.3
12/15/2020 21:00	8.6	2.0	0.6	6.5	1.3
12/15/2020 22:00	8.6	2.0	0.6	6.4	1.3
12/15/2020 23:00	8.3	2.0	0.6	6.2	1.2
Average/Sum#:	184.2 #	48.0 #	14.7 #	146.9 #	29.7 #
Minimum:	5.8	2.0	0.6	5.8	1.2
Maximum:	8.7	2.0	0.7	6.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/16/2020 00:00	8.2	2.0	0.6	6.1	1.2
12/16/2020 01:00	8.0	2.0	0.6	6.0	1.2
12/16/2020 02:00	5.8	2.0	0.6	5.8	1.2
12/16/2020 03:00	5.8	2.0	0.6	5.8	1.2
12/16/2020 04:00	7.9	2.3	0.6	5.9	1.2
12/16/2020 05:00	8.4	2.0	0.6	6.3	1.3
12/16/2020 06:00	8.5	2.0	0.6	6.4	1.3
12/16/2020 07:00	8.6	2.0	0.6	6.5	1.3
12/16/2020 08:00	8.4	2.0	0.6	6.3	1.3
12/16/2020 09:00	5.8	2.0	0.6	5.8	1.2
12/16/2020 10:00	5.8	2.4	0.6	5.8	1.2
12/16/2020 11:00	7.8	2.0	0.6	5.8	1.2
12/16/2020 12:00	7.7	2.3	0.6	5.8	1.2
12/16/2020 13:00	7.8	2.0	0.6	5.8	1.2
12/16/2020 14:00	7.7	2.0	0.6	5.8	1.2
12/16/2020 15:00	59.7	106.1	0.7	5.8	1.2
12/16/2020 16:00	87.5	37.6	1.1	6.6	1.4
12/16/2020 17:00	8.9	1.0	1.7	9.8	2.2
12/16/2020 18:00	11.5	2.2	1.9	10.5	2.3
12/16/2020 19:00	15.1	2.6	2.1	11.9	2.6
12/16/2020 20:00	15.4	1.9	2.3	12.1	2.6
12/16/2020 21:00	15.4	1.9	2.2	12.1	2.6
12/16/2020 22:00	15.3	1.9	2.2	12.1	2.6
12/16/2020 23:00	15.2	1.9	2.1	11.9	2.6
Average/Sum#:	356.2 #	188.1 #	25.3 #	182.7 #	38.5 #
Minimum:	5.8	1.0	0.6	5.8	1.2
Maximum:	87.5	106.1	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/17/2020 00:00	14.5	2.5	2.1	11.4	2.4
12/17/2020 01:00	11.4	1.6	1.9	10.5	2.2
12/17/2020 02:00	9.0	1.0	1.8	9.9	2.2
12/17/2020 03:00	12.3	2.6	2.0	11.2	2.4
12/17/2020 04:00	14.5	2.5	2.1	11.4	2.5
12/17/2020 05:00	14.6	2.6	2.1	11.5	2.5
12/17/2020 06:00	14.2	2.6	2.0	11.1	2.4
12/17/2020 07:00	15.0	2.2	2.1	11.7	2.6
12/17/2020 08:00	14.5	2.2	2.1	11.4	2.5
12/17/2020 09:00	13.9	2.5	2.0	10.9	2.4
12/17/2020 10:00	8.3	0.6	1.7	9.0	2.0
12/17/2020 11:00	8.5	0.6	1.7	9.3	2.0
12/17/2020 12:00	8.3	0.6	1.7	9.2	2.0
12/17/2020 13:00	8.5	0.6	1.7	9.3	2.0
12/17/2020 14:00	8.3	0.6	1.7	9.2	2.0
12/17/2020 15:00	8.3	0.6	1.7	9.2	2.0
12/17/2020 16:00	10.9	1.6	1.8	10.0	2.2
12/17/2020 17:00	14.7	3.3	2.1	11.6	2.6
12/17/2020 18:00	14.8	2.6	2.1	11.7	2.6
12/17/2020 19:00	14.6	2.9	2.1	11.4	2.5
12/17/2020 20:00	14.4	3.0	2.1	11.4	2.4
12/17/2020 21:00	15.0	3.0	2.1	11.7	2.6
12/17/2020 22:00	14.6	3.0	2.1	11.5	2.5
12/17/2020 23:00	14.4	3.0	2.1	11.4	2.4
Average/Sum#:	297.5 #	48.3 #	46.9 #	256.9 #	55.9 #
Minimum:	8.3	0.6	1.7	9.0	2.0
Maximum:	15.0	3.3	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/18/2020 00:00	14.5	3.0	2.1	11.4	2.5
12/18/2020 01:00	11.8	3.6	2.0	10.8	2.4
12/18/2020 02:00	8.5	0.6	1.7	9.4	2.0
12/18/2020 03:00	5.9	0.6	1.4	8.1	1.8
12/18/2020 04:00	8.5	1.2	1.7	9.4	2.0
12/18/2020 05:00	13.9	3.6	2.0	10.9	2.4
12/18/2020 06:00	15.0	3.3	2.1	11.8	2.6
12/18/2020 07:00	14.8	3.3	2.1	11.7	2.6
12/18/2020 08:00	11.6	3.7	2.0	10.7	2.4
12/18/2020 09:00	8.5	0.6	1.7	9.4	2.0
12/18/2020 10:00	7.8	0.6	1.6	8.6	1.8
12/18/2020 11:00	5.6	0.5	1.4	7.7	1.6
12/18/2020 12:00	7.5	0.6	1.5	8.3	1.8
12/18/2020 13:00	8.0	0.6	1.6	8.8	2.0
12/18/2020 14:00	5.7	0.5	1.4	7.8	1.7
12/18/2020 15:00	7.2	0.5	1.4	7.9	1.8
12/18/2020 16:00	11.3	2.6	1.9	10.3	2.2
12/18/2020 17:00	15.2	2.6	2.2	11.9	2.6
12/18/2020 18:00	15.7	2.2	2.3	12.3	2.7
12/18/2020 19:00	15.7	2.2	2.3	12.3	2.7
12/18/2020 20:00	15.5	2.2	2.3	12.3	2.7
12/18/2020 21:00	15.3	2.6	2.2	12.1	2.6
12/18/2020 22:00	15.0	3.0	2.1	11.7	2.6
12/18/2020 23:00	14.4	3.0	2.1	11.4	2.4
Average/Sum#:	272.9 #	47.2 #	45.1 #	247.0 #	53.9 #
Minimum:	5.6	0.5	1.4	7.7	1.6
Maximum:	15.7	3.7	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/19/2020 00:00	14.4	3.0	2.0	11.3	2.4
12/19/2020 01:00	14.0	3.3	2.0	11.0	2.4
12/19/2020 02:00	8.3	0.6	1.7	9.1	2.0
12/19/2020 03:00	7.8	0.6	1.6	8.5	1.8
12/19/2020 04:00	9.3	1.6	1.9	10.3	2.2
12/19/2020 05:00	16.7	3.3	2.1	11.5	2.5
12/19/2020 06:00	12.1	3.7	2.0	11.1	2.4
12/19/2020 07:00	8.4	0.6	1.7	9.2	2.0
12/19/2020 08:00	8.0	0.6	1.6	8.8	2.0
12/19/2020 09:00	8.2	0.6	1.7	9.0	2.0
12/19/2020 10:00	8.5	0.6	1.7	9.4	2.0
12/19/2020 11:00	8.5	0.6	1.7	9.4	2.0
12/19/2020 12:00	8.5	0.6	1.7	9.4	2.0
12/19/2020 13:00	8.5	0.6	1.7	9.3	2.0
12/19/2020 14:00	8.5	0.6	1.7	9.4	2.0
12/19/2020 15:00	8.8	1.0	1.7	9.7	2.2
12/19/2020 16:00	14.5	3.2	2.1	11.3	2.5
12/19/2020 17:00	14.9	3.3	2.1	11.7	2.6
12/19/2020 18:00	15.5	2.6	2.3	12.2	2.7
12/19/2020 19:00	15.6	2.3	2.3	12.4	2.7
12/19/2020 20:00	15.3	2.6	2.2	12.1	2.6
12/19/2020 21:00	15.0	2.6	2.1	11.8	2.6
12/19/2020 22:00	14.6	2.6	2.1	11.4	2.5
12/19/2020 23:00	14.0	3.0	2.0	11.0	2.4
Average/Sum#:	277.9 #	44.1 #	45.7 #	250.3 #	54.5 #
Minimum:	7.8	0.6	1.6	8.5	1.8
Maximum:	16.7	3.7	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/20/2020 00:00	11.8	3.3	2.0	10.8	2.4
12/20/2020 01:00	8.3	0.6	1.7	9.2	2.0
12/20/2020 02:00	7.8	0.6	1.6	8.5	1.8
12/20/2020 03:00	4.2	1.0	1.4	7.5	1.6
12/20/2020 04:00	7.8	0.6	1.6	8.7	1.9
12/20/2020 05:00	9.3	2.9	1.9	10.1	2.2
12/20/2020 06:00	11.3	2.3	1.9	10.3	2.2
12/20/2020 07:00	8.5	0.6	1.7	9.4	2.0
12/20/2020 08:00	8.4	0.9	1.7	9.2	2.0
12/20/2020 09:00	8.5	0.6	1.7	9.4	2.0
12/20/2020 10:00	8.5	0.6	1.7	9.4	2.0
12/20/2020 11:00	8.5	0.6	1.7	9.4	2.0
12/20/2020 12:00	8.5	0.6	1.7	9.4	2.0
12/20/2020 13:00	8.5	0.6	1.7	9.3	2.0
12/20/2020 14:00	8.1	0.6	1.6	9.0	2.0
12/20/2020 15:00	8.5	0.9	1.7	9.4	2.0
12/20/2020 16:00	14.3	3.2	2.0	11.2	2.4
12/20/2020 17:00	14.9	3.2	2.1	11.7	2.6
12/20/2020 18:00	15.1	2.6	2.1	11.9	2.6
12/20/2020 19:00	15.1	2.6	2.1	11.9	2.6
12/20/2020 20:00	15.3	2.6	2.2	12.1	2.6
12/20/2020 21:00	14.9	2.6	2.1	11.7	2.6
12/20/2020 22:00	14.8	2.9	2.1	11.7	2.6
12/20/2020 23:00	14.4	3.0	2.1	11.3	2.4
Average/Sum#:	255.3 #	40.0 #	44.1 #	242.5 #	52.5 #
Minimum:	4.2	0.6	1.4	7.5	1.6
Maximum:	15.3	3.3	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/21/2020 00:00	11.6	4.0	2.0	10.6	2.4
12/21/2020 01:00	8.3	0.9	1.7	9.2	2.0
12/21/2020 02:00	8.0	0.6	1.6	8.8	2.0
12/21/2020 03:00	7.8	0.6	1.6	8.6	1.8
12/21/2020 04:00	11.2	2.7	1.9	10.3	2.2
12/21/2020 05:00	16.7	3.9	2.1	11.5	2.5
12/21/2020 06:00	14.8	3.3	2.1	11.6	2.6
12/21/2020 07:00	14.8	3.3	2.1	11.6	2.6
12/21/2020 08:00	14.0	3.6	2.0	11.0	2.4
12/21/2020 09:00	8.5	0.9	1.7	9.2	2.0
12/21/2020 10:00	8.5	0.9	1.7	9.4	2.0
12/21/2020 11:00	8.5	0.9	1.7	9.4	2.0
12/21/2020 12:00	8.5	0.9	1.7	9.3	2.0
12/21/2020 13:00	8.5	0.9	1.7	9.4	2.0
12/21/2020 14:00	8.5	1.0	1.7	9.2	2.0
12/21/2020 15:00	10.9	1.6	1.8	10.0	2.2
12/21/2020 16:00	14.7	3.6	2.1	11.5	2.5
12/21/2020 17:00	14.8	3.5	2.1	11.6	2.6
12/21/2020 18:00	15.2	3.6	2.1	11.9	2.6
12/21/2020 19:00	15.0	3.6	2.1	11.8	2.6
12/21/2020 20:00	14.8	3.3	2.1	11.7	2.6
12/21/2020 21:00	14.6	3.3	2.1	11.5	2.5
12/21/2020 22:00	14.6	3.3	2.1	11.5	2.5
12/21/2020 23:00	14.3	3.3	2.0	11.3	2.4
Average/Sum#:	287.1 #	57.5 #	45.8 #	251.9 #	55.0 #
Minimum:	7.8	0.6	1.6	8.6	1.8
Maximum:	16.7	4.0	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/22/2020 00:00	11.7	4.6	2.0	10.7	2.4
12/22/2020 01:00	8.3	1.2	1.7	9.2	2.0
12/22/2020 02:00	7.8	1.5	1.6	8.5	1.8
12/22/2020 03:00	7.6	1.6	1.6	8.4	1.8
12/22/2020 04:00	8.6	2.5	1.7	9.4	2.0
12/22/2020 05:00	16.5	3.9	2.0	11.3	2.4
12/22/2020 06:00	12.5	4.0	2.1	11.5	2.5
12/22/2020 07:00	15.0	3.7	2.1	11.8	2.6
12/22/2020 08:00	8.6	1.2	1.7	9.5	2.0
12/22/2020 09:00	8.1	0.9	1.6	8.9	2.0
12/22/2020 10:00	8.5	0.6	1.7	9.4	2.0
12/22/2020 11:00	8.2	0.6	1.7	9.0	2.0
12/22/2020 12:00	8.0	0.6	1.6	8.8	2.0
12/22/2020 13:00	8.3	0.6	1.7	9.2	2.0
12/22/2020 14:00	8.5	0.6	1.7	9.3	2.0
12/22/2020 15:00	8.6	0.9	1.7	9.4	2.0
12/22/2020 16:00	14.1	3.3	2.0	11.1	2.4
12/22/2020 17:00	14.9	2.9	2.1	11.7	2.6
12/22/2020 18:00	15.1	2.9	2.1	11.9	2.6
12/22/2020 19:00	15.1	2.6	2.1	11.9	2.6
12/22/2020 20:00	15.2	2.6	2.2	12.0	2.6
12/22/2020 21:00	14.9	2.6	2.1	11.7	2.6
12/22/2020 22:00	14.8	2.6	2.1	11.7	2.6
12/22/2020 23:00	14.5	3.0	2.1	11.5	2.5
Average/Sum#:	273.4 #	51.5 #	45.0 #	247.8 #	54.0 #
Minimum:	7.6	0.6	1.6	8.4	1.8
Maximum:	16.5	4.6	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/23/2020 00:00	14.1	2.9	2.0	11.1	2.4
12/23/2020 01:00	8.6	0.6	1.7	9.4	2.0
12/23/2020 02:00	11.0	1.6	1.9	10.1	2.2
12/23/2020 03:00	11.8	3.0	2.0	10.8	2.4
12/23/2020 04:00	14.1	3.2	2.0	11.1	2.4
12/23/2020 05:00	6.8	0.6	1.7	9.4	2.0
12/23/2020 06:00	11.1	1.6	1.9	10.1	2.2
12/23/2020 07:00	14.9	3.3	2.1	11.7	2.6
12/23/2020 08:00	14.7	2.9	2.1	11.6	2.5
12/23/2020 09:00	14.1	2.6	2.0	11.0	2.4
12/23/2020 10:00	8.4	0.6	1.7	9.2	2.0
12/23/2020 11:00	8.1	0.6	1.6	9.0	2.0
12/23/2020 12:00	8.3	0.6	1.7	9.2	2.0
12/23/2020 13:00	8.5	0.6	1.7	9.3	2.0
12/23/2020 14:00	8.5	0.6	1.7	9.3	2.0
12/23/2020 15:00	8.4	0.9	1.7	9.2	2.0
12/23/2020 16:00	14.6	3.2	2.1	11.5	2.5
12/23/2020 17:00	15.6	2.9	2.3	12.2	2.7
12/23/2020 18:00	15.8	2.6	2.3	12.4	2.7
12/23/2020 19:00	15.8	2.6	2.3	12.5	2.7
12/23/2020 20:00	15.8	2.6	2.3	12.5	2.7
12/23/2020 21:00	14.9	3.3	2.1	11.7	2.6
12/23/2020 22:00	14.9	3.3	2.1	11.7	2.6
12/23/2020 23:00	14.8	3.3	2.1	11.7	2.6
Average/Sum#:	293.6 #	50.0 #	47.1 #	257.7 #	56.2 #
Minimum:	6.8	0.6	1.6	9.0	2.0
Maximum:	15.8	3.3	2.3	12.5	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/24/2020 00:00	14.4	3.4	2.1	11.4	2.4
12/24/2020 01:00	13.9	4.0	2.0	10.9	2.4
12/24/2020 02:00	8.8	0.6	1.7	9.6	2.1
12/24/2020 03:00	11.0	2.6	1.9	10.1	2.2
12/24/2020 04:00	11.6	4.0	2.0	10.7	2.4
12/24/2020 05:00	13.7	3.7	2.0	10.8	2.4
12/24/2020 06:00	8.6	1.0	1.7	9.4	2.0
12/24/2020 07:00	8.5	1.5	1.7	9.4	2.0
12/24/2020 08:00	8.5	1.5	1.7	9.4	2.0
12/24/2020 09:00	9.7	3.7	2.0	10.7	2.4
12/24/2020 10:00	14.2	3.7	2.0	11.2	2.4
12/24/2020 11:00	8.3	0.6	1.7	9.0	2.0
12/24/2020 12:00	8.3	0.6	1.7	9.0	2.0
12/24/2020 13:00	8.3	0.6	1.7	9.2	2.0
12/24/2020 14:00	10.2	0.6	1.7	9.3	2.0
12/24/2020 15:00	10.9	1.9	1.8	10.0	2.2
12/24/2020 16:00	14.4	3.3	2.1	11.4	2.4
12/24/2020 17:00	15.0	3.3	2.1	11.7	2.6
12/24/2020 18:00	15.2	2.9	2.1	11.9	2.6
12/24/2020 19:00	15.2	2.9	2.1	11.9	2.6
12/24/2020 20:00	15.3	2.9	2.2	12.1	2.6
12/24/2020 21:00	15.0	3.3	2.1	11.7	2.6
12/24/2020 22:00	15.1	3.3	2.1	11.9	2.6
12/24/2020 23:00	14.7	3.3	2.1	11.5	2.5
Average/Sum#:	288.8 #	59.2 #	46.3 #	254.2 #	55.4 #
Minimum:	8.3	0.6	1.7	9.0	2.0
Maximum:	15.3	4.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/25/2020 00:00	14.6	3.3	2.1	11.5	2.5
12/25/2020 01:00	14.5	3.3	2.1	11.4	2.5
12/25/2020 02:00	14.1	3.2	2.0	11.1	2.4
12/25/2020 03:00	8.5	0.6	1.7	9.4	2.0
12/25/2020 04:00	11.1	2.3	1.9	10.1	2.2
12/25/2020 05:00	16.5	3.6	2.1	11.3	2.5
12/25/2020 06:00	14.3	3.6	2.0	11.2	2.4
12/25/2020 07:00	8.3	0.9	1.7	9.2	2.0
12/25/2020 08:00	8.1	1.2	1.6	9.0	2.0
12/25/2020 09:00	8.1	1.2	1.6	9.0	2.0
12/25/2020 10:00	9.6	1.5	1.6	8.8	2.0
12/25/2020 11:00	10.2	1.2	1.7	9.2	2.0
12/25/2020 12:00	10.2	1.2	1.7	9.3	2.0
12/25/2020 13:00	10.2	1.2	1.7	9.2	2.0
12/25/2020 14:00	9.9	1.2	1.7	9.0	2.0
12/25/2020 15:00	8.8	1.6	1.7	9.6	2.1
12/25/2020 16:00	12.3	4.2	2.0	11.3	2.4
12/25/2020 17:00	14.7	3.5	2.1	11.5	2.5
12/25/2020 18:00	14.5	3.5	2.1	11.3	2.5
12/25/2020 19:00	14.7	3.2	2.1	11.5	2.5
12/25/2020 20:00	13.6	3.5	2.0	10.7	2.4
12/25/2020 21:00	8.5	0.6	1.7	9.4	2.0
12/25/2020 22:00	11.0	2.2	1.8	10.1	2.2
12/25/2020 23:00	13.7	3.5	2.0	10.7	2.4
Average/Sum#:	280.0 #	55.3 #	44.7 #	244.8 #	53.5 #
Minimum:	8.1	0.6	1.6	8.8	2.0
Maximum:	16.5	4.2	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/26/2020 00:00	14.3	3.2	2.0	11.2	2.4
12/26/2020 01:00	13.5	3.5	1.9	10.5	2.3
12/26/2020 02:00	8.5	0.6	1.7	9.4	2.0
12/26/2020 03:00	8.9	1.3	1.8	9.8	2.2
12/26/2020 04:00	14.3	3.5	2.0	11.2	2.4
12/26/2020 05:00	15.6	3.5	2.0	10.7	2.4
12/26/2020 06:00	8.5	0.6	1.7	9.4	2.0
12/26/2020 07:00	8.3	0.6	1.7	9.2	2.0
12/26/2020 08:00	9.7	0.9	1.6	8.9	2.0
12/26/2020 09:00	10.0	0.9	1.7	9.2	2.0
12/26/2020 10:00	9.4	0.6	1.6	8.6	1.8
12/26/2020 11:00	7.3	0.5	1.4	8.1	1.8
12/26/2020 12:00	9.6	0.6	1.6	8.7	1.9
12/26/2020 13:00	10.2	0.6	1.7	9.4	2.0
12/26/2020 14:00	10.0	0.6	1.7	9.2	2.0
12/26/2020 15:00	8.0	0.6	1.6	8.7	1.9
12/26/2020 16:00	8.5	1.2	1.7	9.3	2.0
12/26/2020 17:00	14.4	3.5	2.1	11.3	2.4
12/26/2020 18:00	13.9	3.3	2.0	10.9	2.4
12/26/2020 19:00	14.5	3.3	2.1	11.3	2.5
12/26/2020 20:00	14.5	3.3	2.1	11.4	2.5
12/26/2020 21:00	14.4	3.2	2.1	11.3	2.4
12/26/2020 22:00	14.6	3.2	2.1	11.5	2.5
12/26/2020 23:00	14.4	3.3	2.1	11.3	2.4
Average/Sum#:	275.3 #	46.4 #	44.0 #	240.5 #	52.2 #
Minimum:	7.3	0.5	1.4	8.1	1.8
Maximum:	15.6	3.5	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/27/2020 00:00	14.4	3.3	2.1	11.3	2.4
12/27/2020 01:00	14.3	3.3	2.0	11.3	2.4
12/27/2020 02:00	11.6	3.6	1.9	10.6	2.4
12/27/2020 03:00	8.6	0.6	1.7	9.4	2.0
12/27/2020 04:00	8.6	1.5	1.7	9.5	2.0
12/27/2020 05:00	16.5	3.5	2.1	11.3	2.4
12/27/2020 06:00	14.4	3.3	2.1	11.3	2.4
12/27/2020 07:00	8.5	0.6	1.7	9.4	2.0
12/27/2020 08:00	8.5	0.6	1.7	9.4	2.0
12/27/2020 09:00	8.3	0.9	1.7	9.2	2.0
12/27/2020 10:00	8.1	0.9	1.6	8.9	2.0
12/27/2020 11:00	9.9	0.9	1.7	9.0	2.0
12/27/2020 12:00	8.5	1.0	1.7	9.3	2.0
12/27/2020 13:00	8.1	0.6	1.6	8.9	2.0
12/27/2020 14:00	10.2	1.0	1.7	9.3	2.0
12/27/2020 15:00	8.7	1.5	1.7	9.5	2.0
12/27/2020 16:00	14.4	3.9	2.1	11.4	2.4
12/27/2020 17:00	15.0	3.6	2.1	11.8	2.6
12/27/2020 18:00	15.1	3.2	2.1	11.9	2.6
12/27/2020 19:00	15.6	2.6	2.3	12.2	2.7
12/27/2020 20:00	14.8	2.5	2.1	11.6	2.6
12/27/2020 21:00	8.6	0.6	1.7	9.4	2.0
12/27/2020 22:00	11.1	1.9	1.9	10.2	2.2
12/27/2020 23:00	14.7	2.9	2.1	11.5	2.5
Average/Sum#:	276.5 #	48.3 #	45.1 #	247.6 #	53.6 #
Minimum:	8.1	0.6	1.6	8.9	2.0
Maximum:	16.5	3.9	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/28/2020 00:00	13.9	3.2	2.0	10.9	2.4
12/28/2020 01:00	8.3	0.6	1.7	9.2	2.0
12/28/2020 02:00	11.1	1.6	1.9	10.1	2.2
12/28/2020 03:00	14.3	3.2	2.1	11.3	2.4
12/28/2020 04:00	13.5	3.2	2.0	10.7	2.4
12/28/2020 05:00	8.6	0.6	1.7	9.4	2.0
12/28/2020 06:00	11.0	2.2	1.9	10.1	2.2
12/28/2020 07:00	15.2	2.9	2.1	12.0	2.6
12/28/2020 08:00	15.0	2.6	2.1	11.8	2.6
12/28/2020 09:00	14.1	2.9	2.0	11.1	2.4
12/28/2020 10:00	8.3	0.6	1.7	9.2	2.0
12/28/2020 11:00	8.5	0.6	1.7	9.2	2.0
12/28/2020 12:00	10.2	0.6	1.7	9.4	2.0
12/28/2020 13:00	10.0	0.6	1.7	9.2	2.0
12/28/2020 14:00	10.2	0.6	1.7	9.4	2.0
12/28/2020 15:00	10.7	1.2	1.8	9.8	2.2
12/28/2020 16:00	14.3	3.2	2.1	11.3	2.4
12/28/2020 17:00	15.6	2.6	2.3	12.3	2.7
12/28/2020 18:00	15.6	2.2	2.3	12.3	2.7
12/28/2020 19:00	15.6	2.2	2.3	12.3	2.7
12/28/2020 20:00	15.6	2.2	2.3	12.3	2.7
12/28/2020 21:00	15.5	2.2	2.3	12.2	2.7
12/28/2020 22:00	15.2	2.6	2.2	12.0	2.6
12/28/2020 23:00	14.9	2.6	2.1	11.7	2.6
Average/Sum#:	305.2 #	47.0 #	47.7 #	259.2 #	56.5 #
Minimum:	8.3	0.6	1.7	9.2	2.0
Maximum:	15.6	3.2	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/29/2020 00:00	14.9	2.6	2.1	11.7	2.6
12/29/2020 01:00	14.4	2.6	2.1	11.3	2.4
12/29/2020 02:00	8.6	0.6	1.7	9.4	2.0
12/29/2020 03:00	11.1	1.9	1.9	10.2	2.2
12/29/2020 04:00	14.8	3.3	2.1	11.6	2.6
12/29/2020 05:00	15.0	3.3	2.1	11.7	2.6
12/29/2020 06:00	15.6	2.6	2.3	12.3	2.7
12/29/2020 07:00	15.4	2.6	2.3	12.1	2.6
12/29/2020 08:00	15.2	2.6	2.1	12.0	2.6
12/29/2020 09:00	10.8	1.2	1.8	9.9	2.2
12/29/2020 10:00	8.5	0.6	1.7	9.4	2.0
12/29/2020 11:00	8.4	0.6	1.7	9.2	2.0
12/29/2020 12:00	8.5	0.6	1.7	9.4	2.0
12/29/2020 13:00	8.3	0.6	1.7	9.0	2.0
12/29/2020 14:00	8.5	0.6	1.7	9.2	2.0
12/29/2020 15:00	8.4	0.6	1.7	9.2	2.0
12/29/2020 16:00	8.5	0.9	1.7	9.4	2.0
12/29/2020 17:00	15.0	3.2	2.1	11.8	2.6
12/29/2020 18:00	15.6	2.2	2.3	12.3	2.7
12/29/2020 19:00	15.6	2.2	2.3	12.3	2.7
12/29/2020 20:00	15.0	2.6	2.1	11.8	2.6
12/29/2020 21:00	14.6	2.6	2.1	11.5	2.5
12/29/2020 22:00	14.6	2.6	2.1	11.5	2.5
12/29/2020 23:00	14.4	3.0	2.1	11.3	2.4
Average/Sum#:	299.7 #	46.2 #	47.5 #	259.5 #	56.5 #
Minimum:	8.3	0.6	1.7	9.0	2.0
Maximum:	15.6	3.3	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/30/2020 00:00	14.3	3.0	2.0	11.3	2.4
12/30/2020 01:00	11.6	3.7	2.0	10.6	2.4
12/30/2020 02:00	8.5	0.6	1.7	9.4	2.0
12/30/2020 03:00	8.6	1.8	1.7	9.5	2.0
12/30/2020 04:00	14.2	3.4	2.0	11.2	2.4
12/30/2020 05:00	14.4	3.3	2.0	11.3	2.4
12/30/2020 06:00	15.2	3.7	2.1	12.0	2.6
12/30/2020 07:00	14.6	3.7	2.1	11.5	2.5
12/30/2020 08:00	14.2	3.7	2.0	11.2	2.4
12/30/2020 09:00	11.7	4.9	2.0	10.7	2.4
12/30/2020 10:00	8.6	1.0	1.7	9.4	2.0
12/30/2020 11:00	10.2	1.0	1.7	9.4	2.0
12/30/2020 12:00	10.2	1.0	1.7	9.4	2.0
12/30/2020 13:00	9.9	0.9	1.7	9.1	2.0
12/30/2020 14:00	9.9	0.9	1.7	9.1	2.0
12/30/2020 15:00	8.6	1.9	1.7	9.5	2.0
12/30/2020 16:00	14.2	3.9	2.0	11.2	2.4
12/30/2020 17:00	15.0	3.5	2.1	11.7	2.6
12/30/2020 18:00	14.9	3.2	2.1	11.7	2.6
12/30/2020 19:00	14.4	3.2	2.1	11.3	2.4
12/30/2020 20:00	14.6	3.2	2.1	11.5	2.5
12/30/2020 21:00	14.5	3.2	2.1	11.4	2.5
12/30/2020 22:00	14.3	3.2	2.0	11.3	2.4
12/30/2020 23:00	14.3	3.2	2.0	11.2	2.4
Average/Sum#:	300.9 #	65.1 #	46.3 #	255.9 #	55.3 #
Minimum:	8.5	0.6	1.7	9.1	2.0
Maximum:	15.2	4.9	2.1	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/31/2020 00:00	11.6	4.3	1.9	10.6	2.4
12/31/2020 01:00	8.2	0.9	1.7	9.0	2.0
12/31/2020 02:00	11.0	2.6	1.8	10.1	2.2
12/31/2020 03:00	11.6	4.6	2.0	10.7	2.4
12/31/2020 04:00	11.6	4.6	1.9	10.6	2.4
12/31/2020 05:00	8.5	0.6	1.7	9.4	2.0
12/31/2020 06:00	10.2	1.2	1.7	9.4	2.0
12/31/2020 07:00	8.3	1.2	1.7	9.1	2.0
12/31/2020 08:00	8.1	1.2	1.6	8.8	2.0
12/31/2020 09:00	10.0	0.9	1.7	9.2	2.0
12/31/2020 10:00	10.2	1.0	1.7	9.4	2.0
12/31/2020 11:00	10.2	1.0	1.7	9.4	2.0
12/31/2020 12:00	10.0	0.6	1.7	9.2	2.0
12/31/2020 13:00	9.9	0.6	1.7	9.0	2.0
12/31/2020 14:00	10.0	0.6	1.7	9.2	2.0
12/31/2020 15:00	10.2	0.6	1.7	9.4	2.0
12/31/2020 16:00	11.0	1.9	1.8	10.1	2.2
12/31/2020 17:00	14.5	3.5	2.1	11.5	2.5
12/31/2020 18:00	14.9	2.9	2.1	11.7	2.6
12/31/2020 19:00	14.9	2.9	2.1	11.7	2.6
12/31/2020 20:00	14.9	2.9	2.1	11.7	2.6
12/31/2020 21:00	14.9	2.9	2.1	11.7	2.6
12/31/2020 22:00	14.8	2.9	2.1	11.6	2.6
12/31/2020 23:00	14.6	2.9	2.1	11.4	2.5
Average/Sum#:	274.1 #	49.3 #	44.4 #	243.9 #	53.6 #
Minimum:	8.1	0.6	1.6	8.8	2.0
Maximum:	14.9	4.6	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:36 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 89.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 3.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**89.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:38 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 2,084.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 124.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,084.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:38 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 89.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 3.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**89.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:39 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H

Total Operating Time: 2,084.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 124.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,084.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:40 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 89.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 3.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**89.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:40 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H

Total Operating Time: 2,084.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 124.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,084.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 10:42 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 89.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 3.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**89.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:43 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H

Total Operating Time: 2,084.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 124.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,084.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:44 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D

Total Operating Time: 89.00 Day(s) **No Exclusions Allowed**

Non-Operating Time: 3.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**89.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:45 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H

Total Operating Time: 2,084.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 124.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,084.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
Linearity

FCD: AQ-19
Title V: #13

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A12	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	10/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	98	Highest Error:	3.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2020	1039	L	25.0	5.6	5.4		22.4 %
10/14/2020	1045	M	25.0	13.1	13.0		52.4 %
10/14/2020	1051	H	25.0	21.1	21.1		84.4 %
10/14/2020	1100	L	25.0	5.6	5.4		22.4 %
10/14/2020	1106	M	25.0	13.1	13.0		52.4 %
10/14/2020	1112	H	25.0	21.1	21.1		84.4 %
10/14/2020	1120	L	25.0	5.6	5.5		22.4 %
10/14/2020	1126	M	25.0	13.1	13.0		52.4 %
10/14/2020	1132	H	25.0	21.1	21.1		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.600	5.433	No	**3.0**
M	13.100	13.000	No	**0.8**
H	21.100	21.100	No	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	99	Highest Error:	0.8
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2020	1427	L	200.0	50.7	50.1		25.4 %
10/14/2020	1433	M	200.0	110.9	111.5		55.5 %
10/14/2020	1439	H	200.0	179.0	180.2		89.5 %
10/14/2020	1448	L	200.0	50.7	50.4		25.4 %
10/14/2020	1454	M	200.0	110.9	111.5		55.5 %
10/14/2020	1500	H	200.0	179.0	180.6		89.5 %
10/14/2020	1508	L	200.0	50.7	50.4		25.4 %
10/14/2020	1514	M	200.0	110.9	111.7		55.5 %
10/14/2020	1520	H	200.0	179.0	180.4		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.700	50.300	No	**0.8**
M	110.900	111.567	No	**0.6**
H	179.000	180.400	No	**0.8**

Airgas
an Air Liquide company

In Service SW 10/13/2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT1
SW CV1

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401710127-1
Cylinder Number:	CC137855	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 04, 2020

Expiration Date: Feb 04, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	179.0 PPM	G1	+/- 0.6% NIST Traceable	01/28/2020, 02/04/2020
NITRIC OXIDE	180.0 PPM	178.9 PPM	G1	+/- 0.6% NIST Traceable	01/28/2020, 02/04/2020
CARBON MONOXIDE	1150 PPM	1147 PPM	G1	+/- 0.5% NIST Traceable	01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060132	KAL004328	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020
NTRM	09010357	KAL004691	970.0 PPM CARBON MONOXIDE/NITROGEN	0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 CO HCO	FTIR	Jan 02, 2020
Nicolet 6700 AMP0900119 NO MNO	FTIR	Jan 22, 2020
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jan 22, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 02 OCT 20

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT1
CV2

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401826971-1
Cylinder Number:	CC57068	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
		Certification Date:	Jun 08, 2020

Expiration Date: Jun 08, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.05 %	G1	+/- 0.3% NIST Traceable	06/08/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	May 21, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:
NO: 0.00 ppm
CO: 0.04 ppm
CO2: 0.01 ppm

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 08SEP 20-8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CV3

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401710135-1A
Cylinder Number:	CC734247	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 17, 2020

Expiration Date: Feb 17, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.046 PPM	G1	+/- 1.1% NIST Traceable	02/10/2020, 02/17/2020
NITRIC OXIDE	9.000 PPM	8.973 PPM	G1	+/- 1.0% NIST Traceable	02/10/2020, 02/17/2020
CARBON MONOXIDE	11.00 PPM	11.09 PPM	G1	+/- 0.7% NIST Traceable	02/10/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060708	CC437400	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	16060708	CC437400-NOX	10.08 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 07, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 14, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 14, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 13 JAN 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV4

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC268605	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.9 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	110.7 PPM	G1	+/- 1.0% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

IN SERVICE : 09 Jul 19 CV-5

Airgas

Airgas Specialty Gases
11711 South Alameda Street
Los Angeles, CA 90059
(323) 568-2203 Fax: (323) 567-3686
www.airgas.com

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	48-124363135-1
Cylinder Number:	CC276685	Cylinder Volume:	144.3 CF
Laboratory:	ASG - Los Angeles - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32013	Valve Outlet:	660
Gas Code:	NO	Certification Date:	Mar 12, 2013

Expiration Date: Mar 12, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.71 PPM	G1	+/- 1.2% NIST Traceable	03/05/2013, 03/12/2013
NITRIC OXIDE	50.00 PPM	50.55 PPM	G1	+/- 1.0% NIST Traceable	03/05/2013, 03/12/2013
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12060833	CC283887	49.95 PPM NITRIC OXIDE/NITROGEN	+/- 0.8%	Dec 16, 2017
PRM	12312	680179	10.01 PPM NITROGEN DIOXIDE/NITROGEN	+/- 2.0%	Feb 14, 2012
GMIS	124208889129	CC323206	4.835 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.0%	Oct 11, 2013

The SRM or PRM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801551 NO	FTIR	Feb 16, 2013
Nicolet 6700 AHR0801551 NO2	FTIR	Mar 07, 2013

Triad Data Available Upon Request

Notes:

Approved for Release

In Service 10/14/2020 SW

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

Unit 1

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CV6

Part Number:	E03NI99E15A42C9	Reference Number:	48-401144294-1
Cylinder Number:	EB0061713	Cylinder Volume:	144.3 Cubic Feet
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 28, 2018

Expiration Date: Mar 28, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.540 PPM	G1	+/- 1.4% NIST Traceable	03/19/2018, 03/26/2018
NITRIC OXIDE	5.500 PPM	5.515 PPM	G1	+/- 1.1% NIST Traceable	03/19/2018, 03/26/2018
CARBON MONOXIDE	500.0 PPM	503.0 PPM	G1	+/- 1% NIST Traceable	03/28/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
HORIBA VIA 510	NDIR	Mar 27, 2018
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Mar 23, 2018
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Mar 23, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

INSERVICE 15 JAN 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT 1

CV 7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401144293-1
Cylinder Number:	EB0061551	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 13, 2018

Expiration Date: Mar 13, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.404 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	2.500 PPM	2.397 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
CARBON MONOXIDE	4.750 PPM	4.653 PPM	G1	+/- 0.6% NIST Traceable	03/06/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 02, 2018
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 02, 2018
NTRM	1	CC401502	9.766 PPM CARBON MONOXIDE/NITROGEN	0.3	Sep 07, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 13, 2018
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 22, 2018
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 22, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE: 09 JULY 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

UNIT #1
CV-8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124604208-1
Cylinder Number:	CC25033	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 20, 2017

Expiration Date: Feb 20, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.05 %	G1	+/- 0.7% NIST Traceable	02/20/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Feb 17, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE date 2020-8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 1
CV 9

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401707983-1
Cylinder Number:	SG9173546BAL	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.581 %	G1	+/- 0.7% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM
CO: 0.001 PPM
CO2: 0.001 PPM

Approved for Release

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	10/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	100	Highest Error:	1.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2020	1527	L	200.0	51.2	50.9		25.6 %
10/14/2020	1533	M	200.0	110.4	111.4		55.2 %
10/14/2020	1539	H	200.0	180.8	182.1		90.4 %
10/14/2020	1548	L	200.0	51.2	51.1		25.6 %
10/14/2020	1554	M	200.0	110.4	111.6		55.2 %
10/14/2020	1600	H	200.0	180.8	182.1		90.4 %
10/14/2020	1608	L	200.0	51.2	51.1		25.6 %
10/14/2020	1614	M	200.0	110.4	111.6		55.2 %
10/14/2020	1620	H	200.0	180.8	182.1		90.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.200	51.033	No	**0.3**
M	110.400	111.533	No	**1.0**
H	180.800	182.100	No	**0.7**

Linearity Report

10/15/2020

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	10/14/2020	Scale:	High
Performance Spec:	5 %	Test No.:	99	Highest Error:	0.5
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/14/2020	1328	L	25.0	5.5	5.5		22.0 %
10/14/2020	1334	M	25.0	13.0	13.0		52.0 %
10/14/2020	1340	H	25.0	21.1	21.0		84.4 %
10/14/2020	1349	L	25.0	5.5	5.5		22.0 %
10/14/2020	1355	M	25.0	13.0	13.0		52.0 %
10/14/2020	1401	H	25.0	21.1	21.0		84.4 %
10/14/2020	1409	L	25.0	5.5	5.5		22.0 %
10/14/2020	1415	M	25.0	13.0	13.0		52.0 %
10/14/2020	1421	H	25.0	21.1	21.0		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.000	13.000	No	**0.0**
H	21.100	21.000	No	**0.5**

Airgas
an Air Liquide company

IN SERVICE 21 SEP 20

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2
CV1

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-401765434-1
Cylinder Number:	CC429933	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 30, 2020

Expiration Date: Mar 30, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	180.8 PPM	G1	+/- 0.8% NIST Traceable	03/23/2020, 03/30/2020
NITRIC OXIDE	180.0 PPM	180.4 PPM	G1	+/- 0.8% NIST Traceable	03/23/2020, 03/30/2020
CARBON MONOXIDE	1150 PPM	1140 PPM	G1	+/- 0.9% NIST Traceable	03/23/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060136	KAL004861	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7302017111	CC511391	4.634 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 15, 2021
NTRM	14060129	CC434393	990.9 PPM CARBON MONOXIDE/NITROGEN	0.6%	Nov 15, 2025

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Mar 11, 2020
Nicolet 6700 AHR0801550 NO MNO	FTIR	Mar 25, 2020
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 26, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SOLVIS 24SEP20 8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 2

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-401826971-1
Cylinder Number:	ALM035522	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
		Certification Date:	Jun 08, 2020

Expiration Date: Jun 08, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.05 %	G1	+/- 0.3% NIST Traceable	06/08/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	May 21, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:
NO: 0.00 ppm
CO: 0.04 ppm
CO2: 0.01 ppm

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 24SEP20 8

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 3

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-401710135-1
Cylinder Number:	EB0086815	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 04, 2020

Expiration Date: Feb 04, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.104 PPM	G1	+/- 1.2% NIST Traceable	01/28/2020, 02/04/2020
NITRIC OXIDE	9.000 PPM	9.045 PPM	G1	+/- 1.4% NIST Traceable	01/28/2020, 02/04/2020
CARBON MONOXIDE	11.00 PPM	11.00 PPM	G1	+/- 0.7% NIST Traceable	01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060708	CC437400	10.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	16060708	CC437400-NOX	10.08 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

IN SERVICE 01OCT18

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2

CV5

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0147	Reference Number:	153-400996727-1
Cylinder Number:	CC254020	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	51.16 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	50.00 PPM	51.12 PPM	G1	+/- 1.2% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060632	CC442611	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	May 27, 2020
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 9 April 19

Airgas
an Air Liquide company

CT 2
CV 6

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-401198488-1
Cylinder Number:	CC437300	Cylinder Volume:	128.9 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	1800 PSIG
PGVP Number:	B32018	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	May 18, 2018

Expiration Date: May 18, 2021

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.207 PPM	G1	+/- 1.4% NIST Traceable	05/18/2018
NITRIC OXIDE	5.500 PPM	4.934 PPM	G1	+/- 1.2% NIST Traceable	05/18/2018
CARBON MONOXIDE	500.0 PPM	500.5 PPM	G1	+/- 0.7% NIST Traceable	05/10/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	103107A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	103107A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jun 02, 2018
NTRM	12062427	CC366878	487.1 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jun 22, 2018

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Apr 23, 2018
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Apr 24, 2018
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Apr 24, 2018

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 03 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 7

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401707981-1
Cylinder Number:	CC472917	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service: 9 April 19

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-124618307-1
Cylinder Number:	CC420243	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	May 09, 2017

Expiration Date: May 09, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.04 %	G1	+/- 0.7% NIST Traceable	05/09/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051014	SG9162888BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 02, 2017

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 X9A4UGL8 O2	O2 Paramagnetic (Dixon)	Apr 12, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 03 APR 2020

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT.2
CV.9

CERTIFICATE OF ANALYSIS
Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401707983-1
Cylinder Number:	CC54718	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jan 21, 2020

Expiration Date: Jan 21, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.507 %	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Dec 30, 2019

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.001 PPM
CO: 0.001 PPM
CO2: 0.001 PPM

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13, #14

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:46 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	1.9		
10/03/2020 08:38 10/03/2020 09:48 Warm Start - Gas	71	135.4		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	1.6		
10/04/2020 09:03 10/04/2020 10:30 Warm Start - Gas	88	158.4		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	1.3		
10/06/2020 06:38 10/06/2020 07:50 Warm Start - Gas	73	122.5		
10/07/2020 23:24 10/07/2020 23:28 Shut Down - Gas	5	0.9		
10/12/2020 12:18 10/12/2020 14:01 Cold Start - Gas	104	177.2		
10/18/2020 18:19 10/18/2020 18:25 Shut Down - Gas	7	2.1		
10/18/2020 21:33 10/18/2020 22:32 Hot Start - Gas	60	106.0		
11/25/2020 23:24 11/25/2020 23:28 Shut Down - Gas	5	1.1		
11/26/2020 23:19 11/27/2020 01:46 Warm Start - Gas	148	250.7		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	1.8		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:46 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
12/16/2020 15:23 12/16/2020 16:53 Warm Start - Gas	91	153.4		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:46 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:46 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	1.9	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	12.0	0	1	0	0	0
10/03/2020 09:00	55.2	0	1	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	1
10/03/2020 11:00	0.0	0	0	0	0	1
10/03/2020 12:00	0.0	0	0	0	0	1
10/03/2020 13:00	0.0	0	0	0	0	1
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	1.5	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	70.6 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	54.9	0	1	0	0	0
10/04/2020 10:00	18.3	0	1	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	1
10/04/2020 12:00	0.0	0	0	0	0	1
10/04/2020 13:00	0.0	0	0	0	0	1
10/04/2020 14:00	0.0	0	0	0	0	1
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	73.2 #	0 #	2 #	0 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	1.8	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	10.4	0	1	0	0	0
10/06/2020 07:00	32.8	0	1	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	1
10/06/2020 09:00	0.0	0	0	0	0	1
10/06/2020 10:00	0.0	0	0	0	0	1
10/06/2020 11:00	0.0	0	0	0	0	1
10/06/2020 12:00	0.0	0	0	0	0	1
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.2 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	1.5	0	0	0	1	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	0.0	0	0	0	0	0
10/11/2020 02:00	0.0	0	0	0	0	0
10/11/2020 03:00	0.0	0	0	0	0	0
10/11/2020 04:00	0.0	0	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	0
10/11/2020 06:00	0.0	0	0	0	0	0
10/11/2020 07:00	0.0	0	0	0	0	0
10/11/2020 08:00	0.0	0	0	0	0	0
10/11/2020 09:00	0.0	0	0	0	0	0
10/11/2020 10:00	0.0	0	0	0	0	0
10/11/2020 11:00	0.0	0	0	0	0	0
10/11/2020 12:00	0.0	0	0	0	0	0
10/11/2020 13:00	0.0	0	0	0	0	0
10/11/2020 14:00	0.0	0	0	0	0	0
10/11/2020 15:00	0.0	0	0	0	0	0
10/11/2020 16:00	0.0	0	0	0	0	0
10/11/2020 17:00	0.0	0	0	0	0	0
10/11/2020 18:00	0.0	0	0	0	0	0
10/11/2020 19:00	0.0	0	0	0	0	0
10/11/2020 20:00	0.0	0	0	0	0	0
10/11/2020 21:00	0.0	0	0	0	0	0
10/11/2020 22:00	0.0	0	0	0	0	0
10/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	0
10/12/2020 01:00	0.0	0	0	0	0	0
10/12/2020 02:00	0.0	0	0	0	0	0
10/12/2020 03:00	0.0	0	0	0	0	0
10/12/2020 04:00	0.0	0	0	0	0	0
10/12/2020 05:00	0.0	0	0	0	0	0
10/12/2020 06:00	0.0	0	0	0	0	0
10/12/2020 07:00	0.0	0	0	0	0	0
10/12/2020 08:00	0.0	0	0	0	0	0
10/12/2020 09:00	0.0	0	0	0	0	0
10/12/2020 10:00	0.0	0	0	0	0	0
10/12/2020 11:00	0.0	0	0	0	0	0
10/12/2020 12:00	75.7	1	0	0	0	0
10/12/2020 13:00	38.3	1	0	0	0	0
10/12/2020 14:00	0.0	1	0	0	0	0
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	114.0 #	3 #	0 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	75.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	1.8	0	0	0	1	0
10/18/2020 19:00	0.0	0	0	0	0	0
10/18/2020 20:00	0.0	0	0	0	0	0
10/18/2020 21:00	9.7	0	0	1	0	0
10/18/2020 22:00	14.6	0	0	1	0	0
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.1 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	0.0	0	0	0	0	1
11/14/2020 01:00	0.0	0	0	0	0	1
11/14/2020 02:00	0.0	0	0	0	0	1
11/14/2020 03:00	0.0	0	0	0	0	1
11/14/2020 04:00	0.0	0	0	0	0	1
11/14/2020 05:00	0.0	0	0	0	0	1
11/14/2020 06:00	0.0	0	0	0	0	1
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	0.0	0	0	0	0	1
11/23/2020 03:00	0.0	0	0	0	0	1
11/23/2020 04:00	0.0	0	0	0	0	1
11/23/2020 05:00	0.0	0	0	0	0	1
11/23/2020 06:00	0.0	0	0	0	0	1
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	62.6	0	1	0	0	0
Average/Sum#:	62.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	35.0	0	1	0	0	0
11/27/2020 01:00	44.0	0	1	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	1
11/27/2020 03:00	0.0	0	0	0	0	1
11/27/2020 04:00	0.0	0	0	0	0	1
11/27/2020 05:00	0.0	0	0	0	0	1
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.0 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	2.3	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	0.0	0	0	0	0	0
12/14/2020 06:00	0.0	0	0	0	0	0
12/14/2020 07:00	0.0	0	0	0	0	0
12/14/2020 08:00	0.0	0	0	0	0	0
12/14/2020 09:00	0.0	0	0	0	0	0
12/14/2020 10:00	0.0	0	0	0	0	0
12/14/2020 11:00	0.0	0	0	0	0	0
12/14/2020 12:00	0.0	0	0	0	0	0
12/14/2020 13:00	0.0	0	0	0	0	0
12/14/2020 14:00	0.0	0	0	0	0	0
12/14/2020 15:00	0.0	0	0	0	0	0
12/14/2020 16:00	0.0	0	0	0	0	0
12/14/2020 17:00	0.0	0	0	0	0	0
12/14/2020 18:00	0.0	0	0	0	0	0
12/14/2020 19:00	0.0	0	0	0	0	0
12/14/2020 20:00	0.0	0	0	0	0	0
12/14/2020 21:00	0.0	0	0	0	0	0
12/14/2020 22:00	0.0	0	0	0	0	0
12/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.3 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.3	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	0
12/15/2020 01:00	0.0	0	0	0	0	0
12/15/2020 02:00	0.0	0	0	0	0	0
12/15/2020 03:00	0.0	0	0	0	0	0
12/15/2020 04:00	0.0	0	0	0	0	0
12/15/2020 05:00	0.0	0	0	0	0	0
12/15/2020 06:00	0.0	0	0	0	0	0
12/15/2020 07:00	0.0	0	0	0	0	0
12/15/2020 08:00	0.0	0	0	0	0	0
12/15/2020 09:00	0.0	0	0	0	0	0
12/15/2020 10:00	0.0	0	0	0	0	0
12/15/2020 11:00	0.0	0	0	0	0	0
12/15/2020 12:00	0.0	0	0	0	0	0
12/15/2020 13:00	0.0	0	0	0	0	0
12/15/2020 14:00	0.0	0	0	0	0	0
12/15/2020 15:00	0.0	0	0	0	0	0
12/15/2020 16:00	0.0	0	0	0	0	0
12/15/2020 17:00	0.0	0	0	0	0	0
12/15/2020 18:00	0.0	0	0	0	0	0
12/15/2020 19:00	0.0	0	0	0	0	0
12/15/2020 20:00	0.0	0	0	0	0	0
12/15/2020 21:00	0.0	0	0	0	0	0
12/15/2020 22:00	0.0	0	0	0	0	0
12/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	0
12/16/2020 01:00	0.0	0	0	0	0	0
12/16/2020 02:00	0.0	0	0	0	0	0
12/16/2020 03:00	0.0	0	0	0	0	0
12/16/2020 04:00	0.0	0	0	0	0	0
12/16/2020 05:00	0.0	0	0	0	0	0
12/16/2020 06:00	0.0	0	0	0	0	0
12/16/2020 07:00	0.0	0	0	0	0	0
12/16/2020 08:00	0.0	0	0	0	0	0
12/16/2020 09:00	0.0	0	0	0	0	0
12/16/2020 10:00	0.0	0	0	0	0	0
12/16/2020 11:00	0.0	0	0	0	0	0
12/16/2020 12:00	0.0	0	0	0	0	0
12/16/2020 13:00	0.0	0	0	0	0	0
12/16/2020 14:00	0.0	0	0	0	0	0
12/16/2020 15:00	105.1	0	1	0	0	0
12/16/2020 16:00	33.3	0	1	0	0	0
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	138.4 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	105.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:48 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	112.7	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	1,370.9	0	1	0	0	0
10/03/2020 09:00	6,752.1	0	1	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	1
10/03/2020 11:00	0.0	0	0	0	0	1
10/03/2020 12:00	0.0	0	0	0	0	1
10/03/2020 13:00	0.0	0	0	0	0	1
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	96.1	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	8,331.8 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,752.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	4,987.2	0	1	0	0	0
10/04/2020 10:00	4,513.9	0	1	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	1
10/04/2020 12:00	0.0	0	0	0	0	1
10/04/2020 13:00	0.0	0	0	0	0	1
10/04/2020 14:00	0.0	0	0	0	0	1
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,501.1 #	0 #	2 #	0 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,987.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	78.9	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	78.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	1,380.0	0	1	0	0	0
10/06/2020 07:00	5,969.0	0	1	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	1
10/06/2020 09:00	0.0	0	0	0	0	1
10/06/2020 10:00	0.0	0	0	0	0	1
10/06/2020 11:00	0.0	0	0	0	0	1
10/06/2020 12:00	0.0	0	0	0	0	1
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,349.0 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,969.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	55.7	0	0	0	1	0
Average/Sum#:	55.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	0.0	0	0	0	0	0
10/11/2020 02:00	0.0	0	0	0	0	0
10/11/2020 03:00	0.0	0	0	0	0	0
10/11/2020 04:00	0.0	0	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	0
10/11/2020 06:00	0.0	0	0	0	0	0
10/11/2020 07:00	0.0	0	0	0	0	0
10/11/2020 08:00	0.0	0	0	0	0	0
10/11/2020 09:00	0.0	0	0	0	0	0
10/11/2020 10:00	0.0	0	0	0	0	0
10/11/2020 11:00	0.0	0	0	0	0	0
10/11/2020 12:00	0.0	0	0	0	0	0
10/11/2020 13:00	0.0	0	0	0	0	0
10/11/2020 14:00	0.0	0	0	0	0	0
10/11/2020 15:00	0.0	0	0	0	0	0
10/11/2020 16:00	0.0	0	0	0	0	0
10/11/2020 17:00	0.0	0	0	0	0	0
10/11/2020 18:00	0.0	0	0	0	0	0
10/11/2020 19:00	0.0	0	0	0	0	0
10/11/2020 20:00	0.0	0	0	0	0	0
10/11/2020 21:00	0.0	0	0	0	0	0
10/11/2020 22:00	0.0	0	0	0	0	0
10/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	0
10/12/2020 01:00	0.0	0	0	0	0	0
10/12/2020 02:00	0.0	0	0	0	0	0
10/12/2020 03:00	0.0	0	0	0	0	0
10/12/2020 04:00	0.0	0	0	0	0	0
10/12/2020 05:00	0.0	0	0	0	0	0
10/12/2020 06:00	0.0	0	0	0	0	0
10/12/2020 07:00	0.0	0	0	0	0	0
10/12/2020 08:00	0.0	0	0	0	0	0
10/12/2020 09:00	0.0	0	0	0	0	0
10/12/2020 10:00	0.0	0	0	0	0	0
10/12/2020 11:00	0.0	0	0	0	0	0
10/12/2020 12:00	3,017.4	1	0	0	0	0
10/12/2020 13:00	7,190.9	1	0	0	0	0
10/12/2020 14:00	422.2	1	0	0	0	0
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,630.5 #	3 #	0 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,190.9	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	127.5	0	0	0	1	0
10/18/2020 19:00	0.0	0	0	0	0	0
10/18/2020 20:00	0.0	0	0	0	0	0
10/18/2020 21:00	1,723.1	0	0	1	0	0
10/18/2020 22:00	4,638.3	0	0	1	0	0
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,488.9 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,638.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	0.0	0	0	0	0	1
11/14/2020 01:00	0.0	0	0	0	0	1
11/14/2020 02:00	0.0	0	0	0	0	1
11/14/2020 03:00	0.0	0	0	0	0	1
11/14/2020 04:00	0.0	0	0	0	0	1
11/14/2020 05:00	0.0	0	0	0	0	1
11/14/2020 06:00	0.0	0	0	0	0	1
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	0.0	0	0	0	0	1
11/23/2020 03:00	0.0	0	0	0	0	1
11/23/2020 04:00	0.0	0	0	0	0	1
11/23/2020 05:00	0.0	0	0	0	0	1
11/23/2020 06:00	0.0	0	0	0	0	1
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	64.9	0	0	0	1	0
Average/Sum#:	64.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	3,072.3	0	1	0	0	0
Average/Sum#:	3,072.3 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,072.3	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	5,635.9	0	1	0	0	0
11/27/2020 01:00	6,333.8	0	1	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	1
11/27/2020 03:00	0.0	0	0	0	0	1
11/27/2020 04:00	0.0	0	0	0	0	1
11/27/2020 05:00	0.0	0	0	0	0	1
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,969.7 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,333.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	105.0	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	0.0	0	0	0	0	0
12/14/2020 06:00	0.0	0	0	0	0	0
12/14/2020 07:00	0.0	0	0	0	0	0
12/14/2020 08:00	0.0	0	0	0	0	0
12/14/2020 09:00	0.0	0	0	0	0	0
12/14/2020 10:00	0.0	0	0	0	0	0
12/14/2020 11:00	0.0	0	0	0	0	0
12/14/2020 12:00	0.0	0	0	0	0	0
12/14/2020 13:00	0.0	0	0	0	0	0
12/14/2020 14:00	0.0	0	0	0	0	0
12/14/2020 15:00	0.0	0	0	0	0	0
12/14/2020 16:00	0.0	0	0	0	0	0
12/14/2020 17:00	0.0	0	0	0	0	0
12/14/2020 18:00	0.0	0	0	0	0	0
12/14/2020 19:00	0.0	0	0	0	0	0
12/14/2020 20:00	0.0	0	0	0	0	0
12/14/2020 21:00	0.0	0	0	0	0	0
12/14/2020 22:00	0.0	0	0	0	0	0
12/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	105.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	105.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	0
12/15/2020 01:00	0.0	0	0	0	0	0
12/15/2020 02:00	0.0	0	0	0	0	0
12/15/2020 03:00	0.0	0	0	0	0	0
12/15/2020 04:00	0.0	0	0	0	0	0
12/15/2020 05:00	0.0	0	0	0	0	0
12/15/2020 06:00	0.0	0	0	0	0	0
12/15/2020 07:00	0.0	0	0	0	0	0
12/15/2020 08:00	0.0	0	0	0	0	0
12/15/2020 09:00	0.0	0	0	0	0	0
12/15/2020 10:00	0.0	0	0	0	0	0
12/15/2020 11:00	0.0	0	0	0	0	0
12/15/2020 12:00	0.0	0	0	0	0	0
12/15/2020 13:00	0.0	0	0	0	0	0
12/15/2020 14:00	0.0	0	0	0	0	0
12/15/2020 15:00	0.0	0	0	0	0	0
12/15/2020 16:00	0.0	0	0	0	0	0
12/15/2020 17:00	0.0	0	0	0	0	0
12/15/2020 18:00	0.0	0	0	0	0	0
12/15/2020 19:00	0.0	0	0	0	0	0
12/15/2020 20:00	0.0	0	0	0	0	0
12/15/2020 21:00	0.0	0	0	0	0	0
12/15/2020 22:00	0.0	0	0	0	0	0
12/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	0
12/16/2020 01:00	0.0	0	0	0	0	0
12/16/2020 02:00	0.0	0	0	0	0	0
12/16/2020 03:00	0.0	0	0	0	0	0
12/16/2020 04:00	0.0	0	0	0	0	0
12/16/2020 05:00	0.0	0	0	0	0	0
12/16/2020 06:00	0.0	0	0	0	0	0
12/16/2020 07:00	0.0	0	0	0	0	0
12/16/2020 08:00	0.0	0	0	0	0	0
12/16/2020 09:00	0.0	0	0	0	0	0
12/16/2020 10:00	0.0	0	0	0	0	0
12/16/2020 11:00	0.0	0	0	0	0	0
12/16/2020 12:00	0.0	0	0	0	0	0
12/16/2020 13:00	0.0	0	0	0	0	0
12/16/2020 14:00	0.0	0	0	0	0	0
12/16/2020 15:00	2,696.5	0	1	0	0	0
12/16/2020 16:00	6,505.6	0	1	0	0	0
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,202.1 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,505.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	0.8	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	19.8	0	1	0	0	0
10/03/2020 09:00	42.6	0	1	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	1
10/03/2020 11:00	0.0	0	0	0	0	1
10/03/2020 12:00	0.0	0	0	0	0	1
10/03/2020 13:00	0.0	0	0	0	0	1
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	0.9	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	64.1 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	74.0	0	1	0	0	0
10/04/2020 10:00	20.4	0	1	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	1
10/04/2020 12:00	0.0	0	0	0	0	1
10/04/2020 13:00	0.0	0	0	0	0	1
10/04/2020 14:00	0.0	0	0	0	0	1
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	94.4 #	0 #	2 #	0 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	0.9	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	24.7	0	1	0	0	0
10/06/2020 07:00	43.9	0	1	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	1
10/06/2020 09:00	0.0	0	0	0	0	1
10/06/2020 10:00	0.0	0	0	0	0	1
10/06/2020 11:00	0.0	0	0	0	0	1
10/06/2020 12:00	0.0	0	0	0	0	1
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.6 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	0.7	0	0	0	1	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	0.0	0	0	0	0	0
10/11/2020 02:00	0.0	0	0	0	0	0
10/11/2020 03:00	0.0	0	0	0	0	0
10/11/2020 04:00	0.0	0	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	0
10/11/2020 06:00	0.0	0	0	0	0	0
10/11/2020 07:00	0.0	0	0	0	0	0
10/11/2020 08:00	0.0	0	0	0	0	0
10/11/2020 09:00	0.0	0	0	0	0	0
10/11/2020 10:00	0.0	0	0	0	0	0
10/11/2020 11:00	0.0	0	0	0	0	0
10/11/2020 12:00	0.0	0	0	0	0	0
10/11/2020 13:00	0.0	0	0	0	0	0
10/11/2020 14:00	0.0	0	0	0	0	0
10/11/2020 15:00	0.0	0	0	0	0	0
10/11/2020 16:00	0.0	0	0	0	0	0
10/11/2020 17:00	0.0	0	0	0	0	0
10/11/2020 18:00	0.0	0	0	0	0	0
10/11/2020 19:00	0.0	0	0	0	0	0
10/11/2020 20:00	0.0	0	0	0	0	0
10/11/2020 21:00	0.0	0	0	0	0	0
10/11/2020 22:00	0.0	0	0	0	0	0
10/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	0
10/12/2020 01:00	0.0	0	0	0	0	0
10/12/2020 02:00	0.0	0	0	0	0	0
10/12/2020 03:00	0.0	0	0	0	0	0
10/12/2020 04:00	0.0	0	0	0	0	0
10/12/2020 05:00	0.0	0	0	0	0	0
10/12/2020 06:00	0.0	0	0	0	0	0
10/12/2020 07:00	0.0	0	0	0	0	0
10/12/2020 08:00	0.0	0	0	0	0	0
10/12/2020 09:00	0.0	0	0	0	0	0
10/12/2020 10:00	0.0	0	0	0	0	0
10/12/2020 11:00	0.0	0	0	0	0	0
10/12/2020 12:00	78.3	1	0	0	0	0
10/12/2020 13:00	80.6	1	0	0	0	0
10/12/2020 14:00	0.1	1	0	0	0	0
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	159.0 #	3 #	0 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	0.6	0	0	0	1	0
10/18/2020 19:00	0.0	0	0	0	0	0
10/18/2020 20:00	0.0	0	0	0	0	0
10/18/2020 21:00	17.2	0	0	1	0	0
10/18/2020 22:00	20.2	0	0	1	0	0
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.0 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	0.0	0	0	0	0	1
11/14/2020 01:00	0.0	0	0	0	0	1
11/14/2020 02:00	0.0	0	0	0	0	1
11/14/2020 03:00	0.0	0	0	0	0	1
11/14/2020 04:00	0.0	0	0	0	0	1
11/14/2020 05:00	0.0	0	0	0	0	1
11/14/2020 06:00	0.0	0	0	0	0	1
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	0.0	0	0	0	0	1
11/23/2020 03:00	0.0	0	0	0	0	1
11/23/2020 04:00	0.0	0	0	0	0	1
11/23/2020 05:00	0.0	0	0	0	0	1
11/23/2020 06:00	0.0	0	0	0	0	1
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	73.6	0	1	0	0	0
Average/Sum#:	73.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	40.4	0	1	0	0	0
11/27/2020 01:00	38.9	0	1	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	1
11/27/2020 03:00	0.0	0	0	0	0	1
11/27/2020 04:00	0.0	0	0	0	0	1
11/27/2020 05:00	0.0	0	0	0	0	1
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.3 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	0.9	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	0.0	0	0	0	0	0
12/14/2020 06:00	0.0	0	0	0	0	0
12/14/2020 07:00	0.0	0	0	0	0	0
12/14/2020 08:00	0.0	0	0	0	0	0
12/14/2020 09:00	0.0	0	0	0	0	0
12/14/2020 10:00	0.0	0	0	0	0	0
12/14/2020 11:00	0.0	0	0	0	0	0
12/14/2020 12:00	0.0	0	0	0	0	0
12/14/2020 13:00	0.0	0	0	0	0	0
12/14/2020 14:00	0.0	0	0	0	0	0
12/14/2020 15:00	0.0	0	0	0	0	0
12/14/2020 16:00	0.0	0	0	0	0	0
12/14/2020 17:00	0.0	0	0	0	0	0
12/14/2020 18:00	0.0	0	0	0	0	0
12/14/2020 19:00	0.0	0	0	0	0	0
12/14/2020 20:00	0.0	0	0	0	0	0
12/14/2020 21:00	0.0	0	0	0	0	0
12/14/2020 22:00	0.0	0	0	0	0	0
12/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	0
12/15/2020 01:00	0.0	0	0	0	0	0
12/15/2020 02:00	0.0	0	0	0	0	0
12/15/2020 03:00	0.0	0	0	0	0	0
12/15/2020 04:00	0.0	0	0	0	0	0
12/15/2020 05:00	0.0	0	0	0	0	0
12/15/2020 06:00	0.0	0	0	0	0	0
12/15/2020 07:00	0.0	0	0	0	0	0
12/15/2020 08:00	0.0	0	0	0	0	0
12/15/2020 09:00	0.0	0	0	0	0	0
12/15/2020 10:00	0.0	0	0	0	0	0
12/15/2020 11:00	0.0	0	0	0	0	0
12/15/2020 12:00	0.0	0	0	0	0	0
12/15/2020 13:00	0.0	0	0	0	0	0
12/15/2020 14:00	0.0	0	0	0	0	0
12/15/2020 15:00	0.0	0	0	0	0	0
12/15/2020 16:00	0.0	0	0	0	0	0
12/15/2020 17:00	0.0	0	0	0	0	0
12/15/2020 18:00	0.0	0	0	0	0	0
12/15/2020 19:00	0.0	0	0	0	0	0
12/15/2020 20:00	0.0	0	0	0	0	0
12/15/2020 21:00	0.0	0	0	0	0	0
12/15/2020 22:00	0.0	0	0	0	0	0
12/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	0
12/16/2020 01:00	0.0	0	0	0	0	0
12/16/2020 02:00	0.0	0	0	0	0	0
12/16/2020 03:00	0.0	0	0	0	0	0
12/16/2020 04:00	0.0	0	0	0	0	0
12/16/2020 05:00	0.0	0	0	0	0	0
12/16/2020 06:00	0.0	0	0	0	0	0
12/16/2020 07:00	0.0	0	0	0	0	0
12/16/2020 08:00	0.0	0	0	0	0	0
12/16/2020 09:00	0.0	0	0	0	0	0
12/16/2020 10:00	0.0	0	0	0	0	0
12/16/2020 11:00	0.0	0	0	0	0	0
12/16/2020 12:00	0.0	0	0	0	0	0
12/16/2020 13:00	0.0	0	0	0	0	0
12/16/2020 14:00	0.0	0	0	0	0	0
12/16/2020 15:00	56.3	0	1	0	0	0
12/16/2020 16:00	76.1	0	1	0	0	0
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	132.4 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:53 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:54 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	1.4	483.5		
10/03/2020 08:38 10/03/2020 09:48 Warm Start - Gas	71	68.2	790.5		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	1.1	483.5		
10/04/2020 09:03 10/04/2020 10:30 Warm Start - Gas	88	78.5	790.5		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	0.9	483.5		
10/06/2020 06:38 10/06/2020 07:50 Warm Start - Gas	73	44.0	790.5		
10/07/2020 23:24 10/07/2020 23:28 Shut Down - Gas	5	0.6	483.5		
10/12/2020 12:18 10/12/2020 14:01 Cold Start - Gas	104	106.8	1,355.6		
10/18/2020 18:19 10/18/2020 18:25 Shut Down - Gas	7	1.2	483.5		
10/18/2020 21:33 10/18/2020 22:32 Hot Start - Gas	60	29.2	679.6		
11/25/2020 23:24 11/25/2020 23:28 Shut Down - Gas	5	0.7	483.5		
11/26/2020 23:19 11/27/2020 01:46 Warm Start - Gas	148	139.6	790.5		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:54 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/16/2020 15:23 12/16/2020 16:53 Warm Start - Gas	91	127.3	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:54 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:54 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Hr Per Event Report

CT1 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:55 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	0.4	115.0		
10/03/2020 08:38 10/03/2020 09:48 Warm Start - Gas	71	64.5	249.9		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	0.2	115.0		
10/04/2020 09:03 10/04/2020 10:30 Warm Start - Gas	88	105.6	249.9		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	0.3	115.0		
10/06/2020 06:38 10/06/2020 07:50 Warm Start - Gas	73	70.2	249.9		
10/07/2020 23:24 10/07/2020 23:28 Shut Down - Gas	5	0.1	115.0		
10/12/2020 12:18 10/12/2020 14:01 Cold Start - Gas	104	155.5	333.3		
10/18/2020 18:19 10/18/2020 18:25 Shut Down - Gas	7	0.3	115.0		
10/18/2020 21:33 10/18/2020 22:32 Hot Start - Gas	60	45.1	152.0		
11/25/2020 23:24 11/25/2020 23:28 Shut Down - Gas	5	0.4	115.0		
11/26/2020 23:19 11/27/2020 01:46 Warm Start - Gas	148	157.3	249.9		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	0.4	115.0		

Pound Per Hr Per Event Report

CT1 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:55 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
12/16/2020 15:23 12/16/2020 16:53 Warm Start - Gas	91	130.5	249.9		

No excess emissions were found in the reporting period.

Pound Per Hr Per Event Report

CT1 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:55 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Hr Per Event Report

CT1 - NOx LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:55 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,982.52 Hours

Non-Operating Time: 225.48 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:57 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	2.4		
10/03/2020 12:25 10/03/2020 13:33 Warm Start - Gas	69	123.4		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	1.7		
10/04/2020 13:08 10/04/2020 14:13 Warm Start - Gas	66	116.0		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	1.8		
10/06/2020 11:16 10/06/2020 12:20 Warm Start - Gas	65	115.4		
10/07/2020 23:24 10/07/2020 23:29 Shut Down - Gas	6	1.4		
10/11/2020 01:18 10/11/2020 04:52 Cold Start - Gas	215	384.7		
11/14/2020 00:19 11/14/2020 00:24 Shut Down - Gas	6	1.9		
11/14/2020 05:29 11/14/2020 06:46 Hot Start - Gas	78	140.6		
11/23/2020 02:49 11/23/2020 02:54 Shut Down - Gas	6	1.5		
11/23/2020 05:18 11/23/2020 06:27 Hot Start - Gas	70	127.7		
11/25/2020 23:24 11/25/2020 23:29 Shut Down - Gas	6	1.6		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:57 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/27/2020 04:05 11/27/2020 05:35 Warm Start - Gas	91	154.8		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	1.9		
12/14/2020 05:21 12/14/2020 06:22 Hot Start - Gas	62	112.7		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:57 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:57 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	1.3	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	0.0	0	0	0	0	0
10/03/2020 09:00	0.0	0	0	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	0
10/03/2020 11:00	0.0	0	0	0	0	0
10/03/2020 12:00	15.1	0	1	0	0	0
10/03/2020 13:00	13.3	0	1	0	0	0
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	1.1	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	30.8 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	0.0	0	0	0	0	0
10/04/2020 10:00	0.0	0	0	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	0
10/04/2020 12:00	0.0	0	0	0	0	0
10/04/2020 13:00	38.9	0	1	0	0	0
10/04/2020 14:00	1.7	0	1	0	0	0
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	40.6 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	1.3	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	0.0	0	0	0	0	0
10/06/2020 07:00	0.0	0	0	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	0
10/06/2020 09:00	0.0	0	0	0	0	0
10/06/2020 10:00	0.0	0	0	0	0	0
10/06/2020 11:00	17.4	0	1	0	0	0
10/06/2020 12:00	4.4	0	1	0	0	0
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	21.8 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	1.2	0	0	0	1	0
Average/Sum#:	1.2 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	87.9	1	0	0	0	0
10/11/2020 02:00	36.8	1	0	0	0	0
10/11/2020 03:00	66.5	1	0	0	0	0
10/11/2020 04:00	57.1	1	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	1
10/11/2020 06:00	0.0	0	0	0	0	1
10/11/2020 07:00	0.0	0	0	0	0	1
10/11/2020 08:00	0.0	0	0	0	0	1
10/11/2020 09:00	0.0	0	0	0	0	1
10/11/2020 10:00	0.0	0	0	0	0	1
10/11/2020 11:00	0.0	0	0	0	0	1
10/11/2020 12:00	0.0	0	0	0	0	1
10/11/2020 13:00	0.0	0	0	0	0	1
10/11/2020 14:00	0.0	0	0	0	0	1
10/11/2020 15:00	0.0	0	0	0	0	1
10/11/2020 16:00	0.0	0	0	0	0	1
10/11/2020 17:00	0.0	0	0	0	0	1
10/11/2020 18:00	0.0	0	0	0	0	1
10/11/2020 19:00	0.0	0	0	0	0	1
10/11/2020 20:00	0.0	0	0	0	0	1
10/11/2020 21:00	0.0	0	0	0	0	1
10/11/2020 22:00	0.0	0	0	0	0	1
10/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	248.3 #	4 #	0 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	87.9	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	1
10/12/2020 01:00	0.0	0	0	0	0	1
10/12/2020 02:00	0.0	0	0	0	0	1
10/12/2020 03:00	0.0	0	0	0	0	1
10/12/2020 04:00	0.0	0	0	0	0	1
10/12/2020 05:00	0.0	0	0	0	0	1
10/12/2020 06:00	0.0	0	0	0	0	1
10/12/2020 07:00	0.0	0	0	0	0	1
10/12/2020 08:00	0.0	0	0	0	0	1
10/12/2020 09:00	0.0	0	0	0	0	1
10/12/2020 10:00	0.0	0	0	0	0	1
10/12/2020 11:00	0.0	0	0	0	0	1
10/12/2020 12:00	0.0	0	0	0	0	1
10/12/2020 13:00	0.0	0	0	0	0	1
10/12/2020 14:00	0.0	0	0	0	0	1
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	0.0	0	0	0	0	1
10/18/2020 19:00	0.0	0	0	0	0	1
10/18/2020 20:00	0.0	0	0	0	0	1
10/18/2020 21:00	0.0	0	0	0	0	1
10/18/2020 22:00	0.0	0	0	0	0	1
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	1.5	0	0	0	1	0
11/14/2020 01:00	0.0	0	0	0	0	0
11/14/2020 02:00	0.0	0	0	0	0	0
11/14/2020 03:00	0.0	0	0	0	0	0
11/14/2020 04:00	0.0	0	0	0	0	0
11/14/2020 05:00	11.6	0	0	1	0	0
11/14/2020 06:00	30.8	0	0	1	0	0
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.9 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	0.8	0	0	0	1	0
11/23/2020 03:00	0.0	0	0	0	0	0
11/23/2020 04:00	0.0	0	0	0	0	0
11/23/2020 05:00	18.8	0	0	1	0	0
11/23/2020 06:00	13.4	0	0	1	0	0
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	33.0 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	0.0	0	0	0	0	0
11/27/2020 01:00	0.0	0	0	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	0
11/27/2020 03:00	0.0	0	0	0	0	0
11/27/2020 04:00	70.4	0	1	0	0	0
11/27/2020 05:00	18.2	0	1	0	0	0
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.6 #	0 #	2 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	1.9	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	21.3	0	0	1	0	0
12/14/2020 06:00	10.3	0	0	1	0	0
12/14/2020 07:00	0.0	0	0	0	0	1
12/14/2020 08:00	0.0	0	0	0	0	1
12/14/2020 09:00	0.0	0	0	0	0	1
12/14/2020 10:00	0.0	0	0	0	0	1
12/14/2020 11:00	0.0	0	0	0	0	1
12/14/2020 12:00	0.0	0	0	0	0	1
12/14/2020 13:00	0.0	0	0	0	0	1
12/14/2020 14:00	0.0	0	0	0	0	1
12/14/2020 15:00	0.0	0	0	0	0	1
12/14/2020 16:00	0.0	0	0	0	0	1
12/14/2020 17:00	0.0	0	0	0	0	1
12/14/2020 18:00	0.0	0	0	0	0	1
12/14/2020 19:00	0.0	0	0	0	0	1
12/14/2020 20:00	0.0	0	0	0	0	1
12/14/2020 21:00	0.0	0	0	0	0	1
12/14/2020 22:00	0.0	0	0	0	0	1
12/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	33.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	1
12/15/2020 01:00	0.0	0	0	0	0	1
12/15/2020 02:00	0.0	0	0	0	0	1
12/15/2020 03:00	0.0	0	0	0	0	1
12/15/2020 04:00	0.0	0	0	0	0	1
12/15/2020 05:00	0.0	0	0	0	0	1
12/15/2020 06:00	0.0	0	0	0	0	1
12/15/2020 07:00	0.0	0	0	0	0	1
12/15/2020 08:00	0.0	0	0	0	0	1
12/15/2020 09:00	0.0	0	0	0	0	1
12/15/2020 10:00	0.0	0	0	0	0	1
12/15/2020 11:00	0.0	0	0	0	0	1
12/15/2020 12:00	0.0	0	0	0	0	1
12/15/2020 13:00	0.0	0	0	0	0	1
12/15/2020 14:00	0.0	0	0	0	0	1
12/15/2020 15:00	0.0	0	0	0	0	1
12/15/2020 16:00	0.0	0	0	0	0	1
12/15/2020 17:00	0.0	0	0	0	0	1
12/15/2020 18:00	0.0	0	0	0	0	1
12/15/2020 19:00	0.0	0	0	0	0	1
12/15/2020 20:00	0.0	0	0	0	0	1
12/15/2020 21:00	0.0	0	0	0	0	1
12/15/2020 22:00	0.0	0	0	0	0	1
12/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	1
12/16/2020 01:00	0.0	0	0	0	0	1
12/16/2020 02:00	0.0	0	0	0	0	1
12/16/2020 03:00	0.0	0	0	0	0	1
12/16/2020 04:00	0.0	0	0	0	0	1
12/16/2020 05:00	0.0	0	0	0	0	1
12/16/2020 06:00	0.0	0	0	0	0	1
12/16/2020 07:00	0.0	0	0	0	0	1
12/16/2020 08:00	0.0	0	0	0	0	1
12/16/2020 09:00	0.0	0	0	0	0	1
12/16/2020 10:00	0.0	0	0	0	0	1
12/16/2020 11:00	0.0	0	0	0	0	1
12/16/2020 12:00	0.0	0	0	0	0	1
12/16/2020 13:00	0.0	0	0	0	0	1
12/16/2020 14:00	0.0	0	0	0	0	1
12/16/2020 15:00	0.0	0	0	0	0	1
12/16/2020 16:00	0.0	0	0	0	0	1
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	144.8	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	0.0	0	0	0	0	0
10/03/2020 09:00	0.0	0	0	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	0
10/03/2020 11:00	0.0	0	0	0	0	0
10/03/2020 12:00	2,599.4	0	1	0	0	0
10/03/2020 13:00	4,802.8	0	1	0	0	0
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	101.7	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,648.7 #	0 #	2 #	0 #	2 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,802.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	0.0	0	0	0	0	0
10/04/2020 10:00	0.0	0	0	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	0
10/04/2020 12:00	0.0	0	0	0	0	0
10/04/2020 13:00	4,525.0	0	1	0	0	0
10/04/2020 14:00	2,436.8	0	1	0	0	0
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,961.8 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,525.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	105.6	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	105.6 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	105.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	0.0	0	0	0	0	0
10/06/2020 07:00	0.0	0	0	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	0
10/06/2020 09:00	0.0	0	0	0	0	0
10/06/2020 10:00	0.0	0	0	0	0	0
10/06/2020 11:00	3,618.3	0	1	0	0	0
10/06/2020 12:00	3,308.4	0	1	0	0	0
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,926.7 #	0 #	2 #	0 #	0 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,618.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	86.5	0	0	0	1	0
Average/Sum#:	86.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	86.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	3,085.7	1	0	0	0	0
10/11/2020 02:00	6,140.7	1	0	0	0	0
10/11/2020 03:00	6,931.7	1	0	0	0	0
10/11/2020 04:00	6,926.6	1	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	1
10/11/2020 06:00	0.0	0	0	0	0	1
10/11/2020 07:00	0.0	0	0	0	0	1
10/11/2020 08:00	0.0	0	0	0	0	1
10/11/2020 09:00	0.0	0	0	0	0	1
10/11/2020 10:00	0.0	0	0	0	0	1
10/11/2020 11:00	0.0	0	0	0	0	1
10/11/2020 12:00	0.0	0	0	0	0	1
10/11/2020 13:00	0.0	0	0	0	0	1
10/11/2020 14:00	0.0	0	0	0	0	1
10/11/2020 15:00	0.0	0	0	0	0	1
10/11/2020 16:00	0.0	0	0	0	0	1
10/11/2020 17:00	0.0	0	0	0	0	1
10/11/2020 18:00	0.0	0	0	0	0	1
10/11/2020 19:00	0.0	0	0	0	0	1
10/11/2020 20:00	0.0	0	0	0	0	1
10/11/2020 21:00	0.0	0	0	0	0	1
10/11/2020 22:00	0.0	0	0	0	0	1
10/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	23,084.7 #	4 #	0 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,931.7	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	1
10/12/2020 01:00	0.0	0	0	0	0	1
10/12/2020 02:00	0.0	0	0	0	0	1
10/12/2020 03:00	0.0	0	0	0	0	1
10/12/2020 04:00	0.0	0	0	0	0	1
10/12/2020 05:00	0.0	0	0	0	0	1
10/12/2020 06:00	0.0	0	0	0	0	1
10/12/2020 07:00	0.0	0	0	0	0	1
10/12/2020 08:00	0.0	0	0	0	0	1
10/12/2020 09:00	0.0	0	0	0	0	1
10/12/2020 10:00	0.0	0	0	0	0	1
10/12/2020 11:00	0.0	0	0	0	0	1
10/12/2020 12:00	0.0	0	0	0	0	1
10/12/2020 13:00	0.0	0	0	0	0	1
10/12/2020 14:00	0.0	0	0	0	0	1
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	0.0	0	0	0	0	1
10/18/2020 19:00	0.0	0	0	0	0	1
10/18/2020 20:00	0.0	0	0	0	0	1
10/18/2020 21:00	0.0	0	0	0	0	1
10/18/2020 22:00	0.0	0	0	0	0	1
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:58 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	111.3	0	0	0	1	0
11/14/2020 01:00	0.0	0	0	0	0	0
11/14/2020 02:00	0.0	0	0	0	0	0
11/14/2020 03:00	0.0	0	0	0	0	0
11/14/2020 04:00	0.0	0	0	0	0	0
11/14/2020 05:00	2,229.1	0	0	1	0	0
11/14/2020 06:00	6,209.1	0	0	1	0	0
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,549.5 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,209.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	88.7	0	0	0	1	0
11/23/2020 03:00	0.0	0	0	0	0	0
11/23/2020 04:00	0.0	0	0	0	0	0
11/23/2020 05:00	3,431.5	0	0	1	0	0
11/23/2020 06:00	4,228.0	0	0	1	0	0
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,748.2 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,228.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	98.5	0	0	0	1	0
Average/Sum#:	98.5 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	98.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	0.0	0	0	0	0	0
11/27/2020 01:00	0.0	0	0	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	0
11/27/2020 03:00	0.0	0	0	0	0	0
11/27/2020 04:00	4,281.3	0	1	0	0	0
11/27/2020 05:00	5,008.3	0	1	0	0	0
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,289.6 #	0 #	2 #	0 #	0 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,008.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	111.2	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	3,158.4	0	0	1	0	0
12/14/2020 06:00	3,601.2	0	0	1	0	0
12/14/2020 07:00	0.0	0	0	0	0	1
12/14/2020 08:00	0.0	0	0	0	0	1
12/14/2020 09:00	0.0	0	0	0	0	1
12/14/2020 10:00	0.0	0	0	0	0	1
12/14/2020 11:00	0.0	0	0	0	0	1
12/14/2020 12:00	0.0	0	0	0	0	1
12/14/2020 13:00	0.0	0	0	0	0	1
12/14/2020 14:00	0.0	0	0	0	0	1
12/14/2020 15:00	0.0	0	0	0	0	1
12/14/2020 16:00	0.0	0	0	0	0	1
12/14/2020 17:00	0.0	0	0	0	0	1
12/14/2020 18:00	0.0	0	0	0	0	1
12/14/2020 19:00	0.0	0	0	0	0	1
12/14/2020 20:00	0.0	0	0	0	0	1
12/14/2020 21:00	0.0	0	0	0	0	1
12/14/2020 22:00	0.0	0	0	0	0	1
12/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,870.8 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,601.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	1
12/15/2020 01:00	0.0	0	0	0	0	1
12/15/2020 02:00	0.0	0	0	0	0	1
12/15/2020 03:00	0.0	0	0	0	0	1
12/15/2020 04:00	0.0	0	0	0	0	1
12/15/2020 05:00	0.0	0	0	0	0	1
12/15/2020 06:00	0.0	0	0	0	0	1
12/15/2020 07:00	0.0	0	0	0	0	1
12/15/2020 08:00	0.0	0	0	0	0	1
12/15/2020 09:00	0.0	0	0	0	0	1
12/15/2020 10:00	0.0	0	0	0	0	1
12/15/2020 11:00	0.0	0	0	0	0	1
12/15/2020 12:00	0.0	0	0	0	0	1
12/15/2020 13:00	0.0	0	0	0	0	1
12/15/2020 14:00	0.0	0	0	0	0	1
12/15/2020 15:00	0.0	0	0	0	0	1
12/15/2020 16:00	0.0	0	0	0	0	1
12/15/2020 17:00	0.0	0	0	0	0	1
12/15/2020 18:00	0.0	0	0	0	0	1
12/15/2020 19:00	0.0	0	0	0	0	1
12/15/2020 20:00	0.0	0	0	0	0	1
12/15/2020 21:00	0.0	0	0	0	0	1
12/15/2020 22:00	0.0	0	0	0	0	1
12/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	1
12/16/2020 01:00	0.0	0	0	0	0	1
12/16/2020 02:00	0.0	0	0	0	0	1
12/16/2020 03:00	0.0	0	0	0	0	1
12/16/2020 04:00	0.0	0	0	0	0	1
12/16/2020 05:00	0.0	0	0	0	0	1
12/16/2020 06:00	0.0	0	0	0	0	1
12/16/2020 07:00	0.0	0	0	0	0	1
12/16/2020 08:00	0.0	0	0	0	0	1
12/16/2020 09:00	0.0	0	0	0	0	1
12/16/2020 10:00	0.0	0	0	0	0	1
12/16/2020 11:00	0.0	0	0	0	0	1
12/16/2020 12:00	0.0	0	0	0	0	1
12/16/2020 13:00	0.0	0	0	0	0	1
12/16/2020 14:00	0.0	0	0	0	0	1
12/16/2020 15:00	0.0	0	0	0	0	1
12/16/2020 16:00	0.0	0	0	0	0	1
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 10:59 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2020 00:00	0.0	0	0	0	0	1
10/01/2020 01:00	0.0	0	0	0	0	1
10/01/2020 02:00	0.0	0	0	0	0	1
10/01/2020 03:00	0.0	0	0	0	0	1
10/01/2020 04:00	0.0	0	0	0	0	1
10/01/2020 05:00	0.0	0	0	0	0	1
10/01/2020 06:00	0.0	0	0	0	0	1
10/01/2020 07:00	0.0	0	0	0	0	1
10/01/2020 08:00	0.0	0	0	0	0	1
10/01/2020 09:00	0.0	0	0	0	0	1
10/01/2020 10:00	0.0	0	0	0	0	1
10/01/2020 11:00	0.0	0	0	0	0	1
10/01/2020 12:00	0.0	0	0	0	0	1
10/01/2020 13:00	0.0	0	0	0	0	1
10/01/2020 14:00	0.0	0	0	0	0	1
10/01/2020 15:00	0.0	0	0	0	0	1
10/01/2020 16:00	0.0	0	0	0	0	1
10/01/2020 17:00	0.0	0	0	0	0	1
10/01/2020 18:00	0.0	0	0	0	0	1
10/01/2020 19:00	0.0	0	0	0	0	1
10/01/2020 20:00	0.0	0	0	0	0	1
10/01/2020 21:00	0.0	0	0	0	0	1
10/01/2020 22:00	0.0	0	0	0	0	1
10/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2020 00:00	0.0	0	0	0	0	1
10/02/2020 01:00	0.0	0	0	0	0	1
10/02/2020 02:00	0.0	0	0	0	0	1
10/02/2020 03:00	0.0	0	0	0	0	1
10/02/2020 04:00	0.0	0	0	0	0	1
10/02/2020 05:00	0.0	0	0	0	0	1
10/02/2020 06:00	0.0	0	0	0	0	1
10/02/2020 07:00	0.0	0	0	0	0	1
10/02/2020 08:00	0.0	0	0	0	0	1
10/02/2020 09:00	0.0	0	0	0	0	1
10/02/2020 10:00	0.0	0	0	0	0	1
10/02/2020 11:00	0.0	0	0	0	0	1
10/02/2020 12:00	0.0	0	0	0	0	1
10/02/2020 13:00	0.0	0	0	0	0	1
10/02/2020 14:00	0.0	0	0	0	0	1
10/02/2020 15:00	0.0	0	0	0	0	1
10/02/2020 16:00	0.0	0	0	0	0	1
10/02/2020 17:00	0.0	0	0	0	0	1
10/02/2020 18:00	0.0	0	0	0	0	1
10/02/2020 19:00	0.0	0	0	0	0	1
10/02/2020 20:00	0.0	0	0	0	0	1
10/02/2020 21:00	0.0	0	0	0	0	1
10/02/2020 22:00	0.0	0	0	0	0	1
10/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2020 00:00	0.8	0	0	0	1	0
10/03/2020 01:00	0.0	0	0	0	0	0
10/03/2020 02:00	0.0	0	0	0	0	0
10/03/2020 03:00	0.0	0	0	0	0	0
10/03/2020 04:00	0.0	0	0	0	0	0
10/03/2020 05:00	0.0	0	0	0	0	0
10/03/2020 06:00	0.0	0	0	0	0	0
10/03/2020 07:00	0.0	0	0	0	0	0
10/03/2020 08:00	19.8	0	1	0	0	0
10/03/2020 09:00	42.6	0	1	0	0	0
10/03/2020 10:00	0.0	0	0	0	0	1
10/03/2020 11:00	0.0	0	0	0	0	1
10/03/2020 12:00	0.0	0	0	0	0	1
10/03/2020 13:00	0.0	0	0	0	0	1
10/03/2020 14:00	0.0	0	0	0	0	1
10/03/2020 15:00	0.0	0	0	0	0	1
10/03/2020 16:00	0.0	0	0	0	0	1
10/03/2020 17:00	0.0	0	0	0	0	1
10/03/2020 18:00	0.0	0	0	0	0	1
10/03/2020 19:00	0.0	0	0	0	0	1
10/03/2020 20:00	0.0	0	0	0	0	1
10/03/2020 21:00	0.0	0	0	0	0	1
10/03/2020 22:00	0.9	0	0	0	1	0
10/03/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	64.1 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2020 00:00	0.0	0	0	0	0	0
10/04/2020 01:00	0.0	0	0	0	0	0
10/04/2020 02:00	0.0	0	0	0	0	0
10/04/2020 03:00	0.0	0	0	0	0	0
10/04/2020 04:00	0.0	0	0	0	0	0
10/04/2020 05:00	0.0	0	0	0	0	0
10/04/2020 06:00	0.0	0	0	0	0	0
10/04/2020 07:00	0.0	0	0	0	0	0
10/04/2020 08:00	0.0	0	0	0	0	0
10/04/2020 09:00	74.0	0	1	0	0	0
10/04/2020 10:00	20.4	0	1	0	0	0
10/04/2020 11:00	0.0	0	0	0	0	1
10/04/2020 12:00	0.0	0	0	0	0	1
10/04/2020 13:00	0.0	0	0	0	0	1
10/04/2020 14:00	0.0	0	0	0	0	1
10/04/2020 15:00	0.0	0	0	0	0	1
10/04/2020 16:00	0.0	0	0	0	0	1
10/04/2020 17:00	0.0	0	0	0	0	1
10/04/2020 18:00	0.0	0	0	0	0	1
10/04/2020 19:00	0.0	0	0	0	0	1
10/04/2020 20:00	0.0	0	0	0	0	1
10/04/2020 21:00	0.0	0	0	0	0	1
10/04/2020 22:00	0.0	0	0	0	0	1
10/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	94.4 #	0 #	2 #	0 #	0 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2020 00:00	0.0	0	0	0	0	1
10/05/2020 01:00	0.0	0	0	0	0	1
10/05/2020 02:00	0.0	0	0	0	0	1
10/05/2020 03:00	0.0	0	0	0	0	1
10/05/2020 04:00	0.0	0	0	0	0	1
10/05/2020 05:00	0.0	0	0	0	0	1
10/05/2020 06:00	0.0	0	0	0	0	1
10/05/2020 07:00	0.0	0	0	0	0	1
10/05/2020 08:00	0.0	0	0	0	0	1
10/05/2020 09:00	0.0	0	0	0	0	1
10/05/2020 10:00	0.0	0	0	0	0	1
10/05/2020 11:00	0.0	0	0	0	0	1
10/05/2020 12:00	0.0	0	0	0	0	1
10/05/2020 13:00	0.0	0	0	0	0	1
10/05/2020 14:00	0.0	0	0	0	0	1
10/05/2020 15:00	0.0	0	0	0	0	1
10/05/2020 16:00	0.0	0	0	0	0	1
10/05/2020 17:00	0.0	0	0	0	0	1
10/05/2020 18:00	0.0	0	0	0	0	1
10/05/2020 19:00	0.0	0	0	0	0	1
10/05/2020 20:00	0.0	0	0	0	0	1
10/05/2020 21:00	0.0	0	0	0	0	1
10/05/2020 22:00	0.9	0	0	0	1	0
10/05/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2020 00:00	0.0	0	0	0	0	0
10/06/2020 01:00	0.0	0	0	0	0	0
10/06/2020 02:00	0.0	0	0	0	0	0
10/06/2020 03:00	0.0	0	0	0	0	0
10/06/2020 04:00	0.0	0	0	0	0	0
10/06/2020 05:00	0.0	0	0	0	0	0
10/06/2020 06:00	24.7	0	1	0	0	0
10/06/2020 07:00	43.9	0	1	0	0	0
10/06/2020 08:00	0.0	0	0	0	0	1
10/06/2020 09:00	0.0	0	0	0	0	1
10/06/2020 10:00	0.0	0	0	0	0	1
10/06/2020 11:00	0.0	0	0	0	0	1
10/06/2020 12:00	0.0	0	0	0	0	1
10/06/2020 13:00	0.0	0	0	0	0	1
10/06/2020 14:00	0.0	0	0	0	0	1
10/06/2020 15:00	0.0	0	0	0	0	1
10/06/2020 16:00	0.0	0	0	0	0	1
10/06/2020 17:00	0.0	0	0	0	0	1
10/06/2020 18:00	0.0	0	0	0	0	1
10/06/2020 19:00	0.0	0	0	0	0	1
10/06/2020 20:00	0.0	0	0	0	0	1
10/06/2020 21:00	0.0	0	0	0	0	1
10/06/2020 22:00	0.0	0	0	0	0	1
10/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.6 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2020 00:00	0.0	0	0	0	0	1
10/07/2020 01:00	0.0	0	0	0	0	1
10/07/2020 02:00	0.0	0	0	0	0	1
10/07/2020 03:00	0.0	0	0	0	0	1
10/07/2020 04:00	0.0	0	0	0	0	1
10/07/2020 05:00	0.0	0	0	0	0	1
10/07/2020 06:00	0.0	0	0	0	0	1
10/07/2020 07:00	0.0	0	0	0	0	1
10/07/2020 08:00	0.0	0	0	0	0	1
10/07/2020 09:00	0.0	0	0	0	0	1
10/07/2020 10:00	0.0	0	0	0	0	1
10/07/2020 11:00	0.0	0	0	0	0	1
10/07/2020 12:00	0.0	0	0	0	0	1
10/07/2020 13:00	0.0	0	0	0	0	1
10/07/2020 14:00	0.0	0	0	0	0	1
10/07/2020 15:00	0.0	0	0	0	0	1
10/07/2020 16:00	0.0	0	0	0	0	1
10/07/2020 17:00	0.0	0	0	0	0	1
10/07/2020 18:00	0.0	0	0	0	0	1
10/07/2020 19:00	0.0	0	0	0	0	1
10/07/2020 20:00	0.0	0	0	0	0	1
10/07/2020 21:00	0.0	0	0	0	0	1
10/07/2020 22:00	0.0	0	0	0	0	1
10/07/2020 23:00	0.7	0	0	0	1	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2020 00:00	0.0	0	0	0	0	0
10/08/2020 01:00	0.0	0	0	0	0	0
10/08/2020 02:00	0.0	0	0	0	0	0
10/08/2020 03:00	0.0	0	0	0	0	0
10/08/2020 04:00	0.0	0	0	0	0	0
10/08/2020 05:00	0.0	0	0	0	0	0
10/08/2020 06:00	0.0	0	0	0	0	0
10/08/2020 07:00	0.0	0	0	0	0	0
10/08/2020 08:00	0.0	0	0	0	0	0
10/08/2020 09:00	0.0	0	0	0	0	0
10/08/2020 10:00	0.0	0	0	0	0	0
10/08/2020 11:00	0.0	0	0	0	0	0
10/08/2020 12:00	0.0	0	0	0	0	0
10/08/2020 13:00	0.0	0	0	0	0	0
10/08/2020 14:00	0.0	0	0	0	0	0
10/08/2020 15:00	0.0	0	0	0	0	0
10/08/2020 16:00	0.0	0	0	0	0	0
10/08/2020 17:00	0.0	0	0	0	0	0
10/08/2020 18:00	0.0	0	0	0	0	0
10/08/2020 19:00	0.0	0	0	0	0	0
10/08/2020 20:00	0.0	0	0	0	0	0
10/08/2020 21:00	0.0	0	0	0	0	0
10/08/2020 22:00	0.0	0	0	0	0	0
10/08/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2020 00:00	0.0	0	0	0	0	0
10/09/2020 01:00	0.0	0	0	0	0	0
10/09/2020 02:00	0.0	0	0	0	0	0
10/09/2020 03:00	0.0	0	0	0	0	0
10/09/2020 04:00	0.0	0	0	0	0	0
10/09/2020 05:00	0.0	0	0	0	0	0
10/09/2020 06:00	0.0	0	0	0	0	0
10/09/2020 07:00	0.0	0	0	0	0	0
10/09/2020 08:00	0.0	0	0	0	0	0
10/09/2020 09:00	0.0	0	0	0	0	0
10/09/2020 10:00	0.0	0	0	0	0	0
10/09/2020 11:00	0.0	0	0	0	0	0
10/09/2020 12:00	0.0	0	0	0	0	0
10/09/2020 13:00	0.0	0	0	0	0	0
10/09/2020 14:00	0.0	0	0	0	0	0
10/09/2020 15:00	0.0	0	0	0	0	0
10/09/2020 16:00	0.0	0	0	0	0	0
10/09/2020 17:00	0.0	0	0	0	0	0
10/09/2020 18:00	0.0	0	0	0	0	0
10/09/2020 19:00	0.0	0	0	0	0	0
10/09/2020 20:00	0.0	0	0	0	0	0
10/09/2020 21:00	0.0	0	0	0	0	0
10/09/2020 22:00	0.0	0	0	0	0	0
10/09/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2020 00:00	0.0	0	0	0	0	0
10/10/2020 01:00	0.0	0	0	0	0	0
10/10/2020 02:00	0.0	0	0	0	0	0
10/10/2020 03:00	0.0	0	0	0	0	0
10/10/2020 04:00	0.0	0	0	0	0	0
10/10/2020 05:00	0.0	0	0	0	0	0
10/10/2020 06:00	0.0	0	0	0	0	0
10/10/2020 07:00	0.0	0	0	0	0	0
10/10/2020 08:00	0.0	0	0	0	0	0
10/10/2020 09:00	0.0	0	0	0	0	0
10/10/2020 10:00	0.0	0	0	0	0	0
10/10/2020 11:00	0.0	0	0	0	0	0
10/10/2020 12:00	0.0	0	0	0	0	0
10/10/2020 13:00	0.0	0	0	0	0	0
10/10/2020 14:00	0.0	0	0	0	0	0
10/10/2020 15:00	0.0	0	0	0	0	0
10/10/2020 16:00	0.0	0	0	0	0	0
10/10/2020 17:00	0.0	0	0	0	0	0
10/10/2020 18:00	0.0	0	0	0	0	0
10/10/2020 19:00	0.0	0	0	0	0	0
10/10/2020 20:00	0.0	0	0	0	0	0
10/10/2020 21:00	0.0	0	0	0	0	0
10/10/2020 22:00	0.0	0	0	0	0	0
10/10/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2020 00:00	0.0	0	0	0	0	0
10/11/2020 01:00	0.0	0	0	0	0	0
10/11/2020 02:00	0.0	0	0	0	0	0
10/11/2020 03:00	0.0	0	0	0	0	0
10/11/2020 04:00	0.0	0	0	0	0	0
10/11/2020 05:00	0.0	0	0	0	0	0
10/11/2020 06:00	0.0	0	0	0	0	0
10/11/2020 07:00	0.0	0	0	0	0	0
10/11/2020 08:00	0.0	0	0	0	0	0
10/11/2020 09:00	0.0	0	0	0	0	0
10/11/2020 10:00	0.0	0	0	0	0	0
10/11/2020 11:00	0.0	0	0	0	0	0
10/11/2020 12:00	0.0	0	0	0	0	0
10/11/2020 13:00	0.0	0	0	0	0	0
10/11/2020 14:00	0.0	0	0	0	0	0
10/11/2020 15:00	0.0	0	0	0	0	0
10/11/2020 16:00	0.0	0	0	0	0	0
10/11/2020 17:00	0.0	0	0	0	0	0
10/11/2020 18:00	0.0	0	0	0	0	0
10/11/2020 19:00	0.0	0	0	0	0	0
10/11/2020 20:00	0.0	0	0	0	0	0
10/11/2020 21:00	0.0	0	0	0	0	0
10/11/2020 22:00	0.0	0	0	0	0	0
10/11/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2020 00:00	0.0	0	0	0	0	0
10/12/2020 01:00	0.0	0	0	0	0	0
10/12/2020 02:00	0.0	0	0	0	0	0
10/12/2020 03:00	0.0	0	0	0	0	0
10/12/2020 04:00	0.0	0	0	0	0	0
10/12/2020 05:00	0.0	0	0	0	0	0
10/12/2020 06:00	0.0	0	0	0	0	0
10/12/2020 07:00	0.0	0	0	0	0	0
10/12/2020 08:00	0.0	0	0	0	0	0
10/12/2020 09:00	0.0	0	0	0	0	0
10/12/2020 10:00	0.0	0	0	0	0	0
10/12/2020 11:00	0.0	0	0	0	0	0
10/12/2020 12:00	78.3	1	0	0	0	0
10/12/2020 13:00	80.6	1	0	0	0	0
10/12/2020 14:00	0.1	1	0	0	0	0
10/12/2020 15:00	0.0	0	0	0	0	1
10/12/2020 16:00	0.0	0	0	0	0	1
10/12/2020 17:00	0.0	0	0	0	0	1
10/12/2020 18:00	0.0	0	0	0	0	1
10/12/2020 19:00	0.0	0	0	0	0	1
10/12/2020 20:00	0.0	0	0	0	0	1
10/12/2020 21:00	0.0	0	0	0	0	1
10/12/2020 22:00	0.0	0	0	0	0	1
10/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	159.0 #	3 #	0 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.6	1	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2020 00:00	0.0	0	0	0	0	1
10/13/2020 01:00	0.0	0	0	0	0	1
10/13/2020 02:00	0.0	0	0	0	0	1
10/13/2020 03:00	0.0	0	0	0	0	1
10/13/2020 04:00	0.0	0	0	0	0	1
10/13/2020 05:00	0.0	0	0	0	0	1
10/13/2020 06:00	0.0	0	0	0	0	1
10/13/2020 07:00	0.0	0	0	0	0	1
10/13/2020 08:00	0.0	0	0	0	0	1
10/13/2020 09:00	0.0	0	0	0	0	1
10/13/2020 10:00	0.0	0	0	0	0	1
10/13/2020 11:00	0.0	0	0	0	0	1
10/13/2020 12:00	0.0	0	0	0	0	1
10/13/2020 13:00	0.0	0	0	0	0	1
10/13/2020 14:00	0.0	0	0	0	0	1
10/13/2020 15:00	0.0	0	0	0	0	1
10/13/2020 16:00	0.0	0	0	0	0	1
10/13/2020 17:00	0.0	0	0	0	0	1
10/13/2020 18:00	0.0	0	0	0	0	1
10/13/2020 19:00	0.0	0	0	0	0	1
10/13/2020 20:00	0.0	0	0	0	0	1
10/13/2020 21:00	0.0	0	0	0	0	1
10/13/2020 22:00	0.0	0	0	0	0	1
10/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2020 00:00	0.0	0	0	0	0	1
10/14/2020 01:00	0.0	0	0	0	0	1
10/14/2020 02:00	0.0	0	0	0	0	1
10/14/2020 03:00	0.0	0	0	0	0	1
10/14/2020 04:00	0.0	0	0	0	0	1
10/14/2020 05:00	0.0	0	0	0	0	1
10/14/2020 06:00	0.0	0	0	0	0	1
10/14/2020 07:00	0.0	0	0	0	0	1
10/14/2020 08:00	0.0	0	0	0	0	1
10/14/2020 09:00	0.0	0	0	0	0	1
10/14/2020 10:00	0.0	0	0	0	0	1
10/14/2020 11:00	0.0	0	0	0	0	1
10/14/2020 12:00	0.0	0	0	0	0	1
10/14/2020 13:00	0.0	0	0	0	0	1
10/14/2020 14:00	0.0	0	0	0	0	1
10/14/2020 15:00	0.0	0	0	0	0	1
10/14/2020 16:00	0.0	0	0	0	0	1
10/14/2020 17:00	0.0	0	0	0	0	1
10/14/2020 18:00	0.0	0	0	0	0	1
10/14/2020 19:00	0.0	0	0	0	0	1
10/14/2020 20:00	0.0	0	0	0	0	1
10/14/2020 21:00	0.0	0	0	0	0	1
10/14/2020 22:00	0.0	0	0	0	0	1
10/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2020 00:00	0.0	0	0	0	0	1
10/15/2020 01:00	0.0	0	0	0	0	1
10/15/2020 02:00	0.0	0	0	0	0	1
10/15/2020 03:00	0.0	0	0	0	0	1
10/15/2020 04:00	0.0	0	0	0	0	1
10/15/2020 05:00	0.0	0	0	0	0	1
10/15/2020 06:00	0.0	0	0	0	0	1
10/15/2020 07:00	0.0	0	0	0	0	1
10/15/2020 08:00	0.0	0	0	0	0	1
10/15/2020 09:00	0.0	0	0	0	0	1
10/15/2020 10:00	0.0	0	0	0	0	1
10/15/2020 11:00	0.0	0	0	0	0	1
10/15/2020 12:00	0.0	0	0	0	0	1
10/15/2020 13:00	0.0	0	0	0	0	1
10/15/2020 14:00	0.0	0	0	0	0	1
10/15/2020 15:00	0.0	0	0	0	0	1
10/15/2020 16:00	0.0	0	0	0	0	1
10/15/2020 17:00	0.0	0	0	0	0	1
10/15/2020 18:00	0.0	0	0	0	0	1
10/15/2020 19:00	0.0	0	0	0	0	1
10/15/2020 20:00	0.0	0	0	0	0	1
10/15/2020 21:00	0.0	0	0	0	0	1
10/15/2020 22:00	0.0	0	0	0	0	1
10/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2020 00:00	0.0	0	0	0	0	1
10/16/2020 01:00	0.0	0	0	0	0	1
10/16/2020 02:00	0.0	0	0	0	0	1
10/16/2020 03:00	0.0	0	0	0	0	1
10/16/2020 04:00	0.0	0	0	0	0	1
10/16/2020 05:00	0.0	0	0	0	0	1
10/16/2020 06:00	0.0	0	0	0	0	1
10/16/2020 07:00	0.0	0	0	0	0	1
10/16/2020 08:00	0.0	0	0	0	0	1
10/16/2020 09:00	0.0	0	0	0	0	1
10/16/2020 10:00	0.0	0	0	0	0	1
10/16/2020 11:00	0.0	0	0	0	0	1
10/16/2020 12:00	0.0	0	0	0	0	1
10/16/2020 13:00	0.0	0	0	0	0	1
10/16/2020 14:00	0.0	0	0	0	0	1
10/16/2020 15:00	0.0	0	0	0	0	1
10/16/2020 16:00	0.0	0	0	0	0	1
10/16/2020 17:00	0.0	0	0	0	0	1
10/16/2020 18:00	0.0	0	0	0	0	1
10/16/2020 19:00	0.0	0	0	0	0	1
10/16/2020 20:00	0.0	0	0	0	0	1
10/16/2020 21:00	0.0	0	0	0	0	1
10/16/2020 22:00	0.0	0	0	0	0	1
10/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2020 00:00	0.0	0	0	0	0	1
10/17/2020 01:00	0.0	0	0	0	0	1
10/17/2020 02:00	0.0	0	0	0	0	1
10/17/2020 03:00	0.0	0	0	0	0	1
10/17/2020 04:00	0.0	0	0	0	0	1
10/17/2020 05:00	0.0	0	0	0	0	1
10/17/2020 06:00	0.0	0	0	0	0	1
10/17/2020 07:00	0.0	0	0	0	0	1
10/17/2020 08:00	0.0	0	0	0	0	1
10/17/2020 09:00	0.0	0	0	0	0	1
10/17/2020 10:00	0.0	0	0	0	0	1
10/17/2020 11:00	0.0	0	0	0	0	1
10/17/2020 12:00	0.0	0	0	0	0	1
10/17/2020 13:00	0.0	0	0	0	0	1
10/17/2020 14:00	0.0	0	0	0	0	1
10/17/2020 15:00	0.0	0	0	0	0	1
10/17/2020 16:00	0.0	0	0	0	0	1
10/17/2020 17:00	0.0	0	0	0	0	1
10/17/2020 18:00	0.0	0	0	0	0	1
10/17/2020 19:00	0.0	0	0	0	0	1
10/17/2020 20:00	0.0	0	0	0	0	1
10/17/2020 21:00	0.0	0	0	0	0	1
10/17/2020 22:00	0.0	0	0	0	0	1
10/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2020 00:00	0.0	0	0	0	0	1
10/18/2020 01:00	0.0	0	0	0	0	1
10/18/2020 02:00	0.0	0	0	0	0	1
10/18/2020 03:00	0.0	0	0	0	0	1
10/18/2020 04:00	0.0	0	0	0	0	1
10/18/2020 05:00	0.0	0	0	0	0	1
10/18/2020 06:00	0.0	0	0	0	0	1
10/18/2020 07:00	0.0	0	0	0	0	1
10/18/2020 08:00	0.0	0	0	0	0	1
10/18/2020 09:00	0.0	0	0	0	0	1
10/18/2020 10:00	0.0	0	0	0	0	1
10/18/2020 11:00	0.0	0	0	0	0	1
10/18/2020 12:00	0.0	0	0	0	0	1
10/18/2020 13:00	0.0	0	0	0	0	1
10/18/2020 14:00	0.0	0	0	0	0	1
10/18/2020 15:00	0.0	0	0	0	0	1
10/18/2020 16:00	0.0	0	0	0	0	1
10/18/2020 17:00	0.0	0	0	0	0	1
10/18/2020 18:00	0.6	0	0	0	1	0
10/18/2020 19:00	0.0	0	0	0	0	0
10/18/2020 20:00	0.0	0	0	0	0	0
10/18/2020 21:00	17.2	0	0	1	0	0
10/18/2020 22:00	20.2	0	0	1	0	0
10/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.0 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2020 00:00	0.0	0	0	0	0	1
10/19/2020 01:00	0.0	0	0	0	0	1
10/19/2020 02:00	0.0	0	0	0	0	1
10/19/2020 03:00	0.0	0	0	0	0	1
10/19/2020 04:00	0.0	0	0	0	0	1
10/19/2020 05:00	0.0	0	0	0	0	1
10/19/2020 06:00	0.0	0	0	0	0	1
10/19/2020 07:00	0.0	0	0	0	0	1
10/19/2020 08:00	0.0	0	0	0	0	1
10/19/2020 09:00	0.0	0	0	0	0	1
10/19/2020 10:00	0.0	0	0	0	0	1
10/19/2020 11:00	0.0	0	0	0	0	1
10/19/2020 12:00	0.0	0	0	0	0	1
10/19/2020 13:00	0.0	0	0	0	0	1
10/19/2020 14:00	0.0	0	0	0	0	1
10/19/2020 15:00	0.0	0	0	0	0	1
10/19/2020 16:00	0.0	0	0	0	0	1
10/19/2020 17:00	0.0	0	0	0	0	1
10/19/2020 18:00	0.0	0	0	0	0	1
10/19/2020 19:00	0.0	0	0	0	0	1
10/19/2020 20:00	0.0	0	0	0	0	1
10/19/2020 21:00	0.0	0	0	0	0	1
10/19/2020 22:00	0.0	0	0	0	0	1
10/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2020 00:00	0.0	0	0	0	0	1
10/20/2020 01:00	0.0	0	0	0	0	1
10/20/2020 02:00	0.0	0	0	0	0	1
10/20/2020 03:00	0.0	0	0	0	0	1
10/20/2020 04:00	0.0	0	0	0	0	1
10/20/2020 05:00	0.0	0	0	0	0	1
10/20/2020 06:00	0.0	0	0	0	0	1
10/20/2020 07:00	0.0	0	0	0	0	1
10/20/2020 08:00	0.0	0	0	0	0	1
10/20/2020 09:00	0.0	0	0	0	0	1
10/20/2020 10:00	0.0	0	0	0	0	1
10/20/2020 11:00	0.0	0	0	0	0	1
10/20/2020 12:00	0.0	0	0	0	0	1
10/20/2020 13:00	0.0	0	0	0	0	1
10/20/2020 14:00	0.0	0	0	0	0	1
10/20/2020 15:00	0.0	0	0	0	0	1
10/20/2020 16:00	0.0	0	0	0	0	1
10/20/2020 17:00	0.0	0	0	0	0	1
10/20/2020 18:00	0.0	0	0	0	0	1
10/20/2020 19:00	0.0	0	0	0	0	1
10/20/2020 20:00	0.0	0	0	0	0	1
10/20/2020 21:00	0.0	0	0	0	0	1
10/20/2020 22:00	0.0	0	0	0	0	1
10/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2020 00:00	0.0	0	0	0	0	1
10/21/2020 01:00	0.0	0	0	0	0	1
10/21/2020 02:00	0.0	0	0	0	0	1
10/21/2020 03:00	0.0	0	0	0	0	1
10/21/2020 04:00	0.0	0	0	0	0	1
10/21/2020 05:00	0.0	0	0	0	0	1
10/21/2020 06:00	0.0	0	0	0	0	1
10/21/2020 07:00	0.0	0	0	0	0	1
10/21/2020 08:00	0.0	0	0	0	0	1
10/21/2020 09:00	0.0	0	0	0	0	1
10/21/2020 10:00	0.0	0	0	0	0	1
10/21/2020 11:00	0.0	0	0	0	0	1
10/21/2020 12:00	0.0	0	0	0	0	1
10/21/2020 13:00	0.0	0	0	0	0	1
10/21/2020 14:00	0.0	0	0	0	0	1
10/21/2020 15:00	0.0	0	0	0	0	1
10/21/2020 16:00	0.0	0	0	0	0	1
10/21/2020 17:00	0.0	0	0	0	0	1
10/21/2020 18:00	0.0	0	0	0	0	1
10/21/2020 19:00	0.0	0	0	0	0	1
10/21/2020 20:00	0.0	0	0	0	0	1
10/21/2020 21:00	0.0	0	0	0	0	1
10/21/2020 22:00	0.0	0	0	0	0	1
10/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2020 00:00	0.0	0	0	0	0	1
10/22/2020 01:00	0.0	0	0	0	0	1
10/22/2020 02:00	0.0	0	0	0	0	1
10/22/2020 03:00	0.0	0	0	0	0	1
10/22/2020 04:00	0.0	0	0	0	0	1
10/22/2020 05:00	0.0	0	0	0	0	1
10/22/2020 06:00	0.0	0	0	0	0	1
10/22/2020 07:00	0.0	0	0	0	0	1
10/22/2020 08:00	0.0	0	0	0	0	1
10/22/2020 09:00	0.0	0	0	0	0	1
10/22/2020 10:00	0.0	0	0	0	0	1
10/22/2020 11:00	0.0	0	0	0	0	1
10/22/2020 12:00	0.0	0	0	0	0	1
10/22/2020 13:00	0.0	0	0	0	0	1
10/22/2020 14:00	0.0	0	0	0	0	1
10/22/2020 15:00	0.0	0	0	0	0	1
10/22/2020 16:00	0.0	0	0	0	0	1
10/22/2020 17:00	0.0	0	0	0	0	1
10/22/2020 18:00	0.0	0	0	0	0	1
10/22/2020 19:00	0.0	0	0	0	0	1
10/22/2020 20:00	0.0	0	0	0	0	1
10/22/2020 21:00	0.0	0	0	0	0	1
10/22/2020 22:00	0.0	0	0	0	0	1
10/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2020 00:00	0.0	0	0	0	0	1
10/23/2020 01:00	0.0	0	0	0	0	1
10/23/2020 02:00	0.0	0	0	0	0	1
10/23/2020 03:00	0.0	0	0	0	0	1
10/23/2020 04:00	0.0	0	0	0	0	1
10/23/2020 05:00	0.0	0	0	0	0	1
10/23/2020 06:00	0.0	0	0	0	0	1
10/23/2020 07:00	0.0	0	0	0	0	1
10/23/2020 08:00	0.0	0	0	0	0	1
10/23/2020 09:00	0.0	0	0	0	0	1
10/23/2020 10:00	0.0	0	0	0	0	1
10/23/2020 11:00	0.0	0	0	0	0	1
10/23/2020 12:00	0.0	0	0	0	0	1
10/23/2020 13:00	0.0	0	0	0	0	1
10/23/2020 14:00	0.0	0	0	0	0	1
10/23/2020 15:00	0.0	0	0	0	0	1
10/23/2020 16:00	0.0	0	0	0	0	1
10/23/2020 17:00	0.0	0	0	0	0	1
10/23/2020 18:00	0.0	0	0	0	0	1
10/23/2020 19:00	0.0	0	0	0	0	1
10/23/2020 20:00	0.0	0	0	0	0	1
10/23/2020 21:00	0.0	0	0	0	0	1
10/23/2020 22:00	0.0	0	0	0	0	1
10/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2020 00:00	0.0	0	0	0	0	1
10/24/2020 01:00	0.0	0	0	0	0	1
10/24/2020 02:00	0.0	0	0	0	0	1
10/24/2020 03:00	0.0	0	0	0	0	1
10/24/2020 04:00	0.0	0	0	0	0	1
10/24/2020 05:00	0.0	0	0	0	0	1
10/24/2020 06:00	0.0	0	0	0	0	1
10/24/2020 07:00	0.0	0	0	0	0	1
10/24/2020 08:00	0.0	0	0	0	0	1
10/24/2020 09:00	0.0	0	0	0	0	1
10/24/2020 10:00	0.0	0	0	0	0	1
10/24/2020 11:00	0.0	0	0	0	0	1
10/24/2020 12:00	0.0	0	0	0	0	1
10/24/2020 13:00	0.0	0	0	0	0	1
10/24/2020 14:00	0.0	0	0	0	0	1
10/24/2020 15:00	0.0	0	0	0	0	1
10/24/2020 16:00	0.0	0	0	0	0	1
10/24/2020 17:00	0.0	0	0	0	0	1
10/24/2020 18:00	0.0	0	0	0	0	1
10/24/2020 19:00	0.0	0	0	0	0	1
10/24/2020 20:00	0.0	0	0	0	0	1
10/24/2020 21:00	0.0	0	0	0	0	1
10/24/2020 22:00	0.0	0	0	0	0	1
10/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2020 00:00	0.0	0	0	0	0	1
10/25/2020 01:00	0.0	0	0	0	0	1
10/25/2020 02:00	0.0	0	0	0	0	1
10/25/2020 03:00	0.0	0	0	0	0	1
10/25/2020 04:00	0.0	0	0	0	0	1
10/25/2020 05:00	0.0	0	0	0	0	1
10/25/2020 06:00	0.0	0	0	0	0	1
10/25/2020 07:00	0.0	0	0	0	0	1
10/25/2020 08:00	0.0	0	0	0	0	1
10/25/2020 09:00	0.0	0	0	0	0	1
10/25/2020 10:00	0.0	0	0	0	0	1
10/25/2020 11:00	0.0	0	0	0	0	1
10/25/2020 12:00	0.0	0	0	0	0	1
10/25/2020 13:00	0.0	0	0	0	0	1
10/25/2020 14:00	0.0	0	0	0	0	1
10/25/2020 15:00	0.0	0	0	0	0	1
10/25/2020 16:00	0.0	0	0	0	0	1
10/25/2020 17:00	0.0	0	0	0	0	1
10/25/2020 18:00	0.0	0	0	0	0	1
10/25/2020 19:00	0.0	0	0	0	0	1
10/25/2020 20:00	0.0	0	0	0	0	1
10/25/2020 21:00	0.0	0	0	0	0	1
10/25/2020 22:00	0.0	0	0	0	0	1
10/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2020 00:00	0.0	0	0	0	0	1
10/26/2020 01:00	0.0	0	0	0	0	1
10/26/2020 02:00	0.0	0	0	0	0	1
10/26/2020 03:00	0.0	0	0	0	0	1
10/26/2020 04:00	0.0	0	0	0	0	1
10/26/2020 05:00	0.0	0	0	0	0	1
10/26/2020 06:00	0.0	0	0	0	0	1
10/26/2020 07:00	0.0	0	0	0	0	1
10/26/2020 08:00	0.0	0	0	0	0	1
10/26/2020 09:00	0.0	0	0	0	0	1
10/26/2020 10:00	0.0	0	0	0	0	1
10/26/2020 11:00	0.0	0	0	0	0	1
10/26/2020 12:00	0.0	0	0	0	0	1
10/26/2020 13:00	0.0	0	0	0	0	1
10/26/2020 14:00	0.0	0	0	0	0	1
10/26/2020 15:00	0.0	0	0	0	0	1
10/26/2020 16:00	0.0	0	0	0	0	1
10/26/2020 17:00	0.0	0	0	0	0	1
10/26/2020 18:00	0.0	0	0	0	0	1
10/26/2020 19:00	0.0	0	0	0	0	1
10/26/2020 20:00	0.0	0	0	0	0	1
10/26/2020 21:00	0.0	0	0	0	0	1
10/26/2020 22:00	0.0	0	0	0	0	1
10/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2020 00:00	0.0	0	0	0	0	1
10/27/2020 01:00	0.0	0	0	0	0	1
10/27/2020 02:00	0.0	0	0	0	0	1
10/27/2020 03:00	0.0	0	0	0	0	1
10/27/2020 04:00	0.0	0	0	0	0	1
10/27/2020 05:00	0.0	0	0	0	0	1
10/27/2020 06:00	0.0	0	0	0	0	1
10/27/2020 07:00	0.0	0	0	0	0	1
10/27/2020 08:00	0.0	0	0	0	0	1
10/27/2020 09:00	0.0	0	0	0	0	1
10/27/2020 10:00	0.0	0	0	0	0	1
10/27/2020 11:00	0.0	0	0	0	0	1
10/27/2020 12:00	0.0	0	0	0	0	1
10/27/2020 13:00	0.0	0	0	0	0	1
10/27/2020 14:00	0.0	0	0	0	0	1
10/27/2020 15:00	0.0	0	0	0	0	1
10/27/2020 16:00	0.0	0	0	0	0	1
10/27/2020 17:00	0.0	0	0	0	0	1
10/27/2020 18:00	0.0	0	0	0	0	1
10/27/2020 19:00	0.0	0	0	0	0	1
10/27/2020 20:00	0.0	0	0	0	0	1
10/27/2020 21:00	0.0	0	0	0	0	1
10/27/2020 22:00	0.0	0	0	0	0	1
10/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2020 00:00	0.0	0	0	0	0	1
10/28/2020 01:00	0.0	0	0	0	0	1
10/28/2020 02:00	0.0	0	0	0	0	1
10/28/2020 03:00	0.0	0	0	0	0	1
10/28/2020 04:00	0.0	0	0	0	0	1
10/28/2020 05:00	0.0	0	0	0	0	1
10/28/2020 06:00	0.0	0	0	0	0	1
10/28/2020 07:00	0.0	0	0	0	0	1
10/28/2020 08:00	0.0	0	0	0	0	1
10/28/2020 09:00	0.0	0	0	0	0	1
10/28/2020 10:00	0.0	0	0	0	0	1
10/28/2020 11:00	0.0	0	0	0	0	1
10/28/2020 12:00	0.0	0	0	0	0	1
10/28/2020 13:00	0.0	0	0	0	0	1
10/28/2020 14:00	0.0	0	0	0	0	1
10/28/2020 15:00	0.0	0	0	0	0	1
10/28/2020 16:00	0.0	0	0	0	0	1
10/28/2020 17:00	0.0	0	0	0	0	1
10/28/2020 18:00	0.0	0	0	0	0	1
10/28/2020 19:00	0.0	0	0	0	0	1
10/28/2020 20:00	0.0	0	0	0	0	1
10/28/2020 21:00	0.0	0	0	0	0	1
10/28/2020 22:00	0.0	0	0	0	0	1
10/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2020 00:00	0.0	0	0	0	0	1
10/29/2020 01:00	0.0	0	0	0	0	1
10/29/2020 02:00	0.0	0	0	0	0	1
10/29/2020 03:00	0.0	0	0	0	0	1
10/29/2020 04:00	0.0	0	0	0	0	1
10/29/2020 05:00	0.0	0	0	0	0	1
10/29/2020 06:00	0.0	0	0	0	0	1
10/29/2020 07:00	0.0	0	0	0	0	1
10/29/2020 08:00	0.0	0	0	0	0	1
10/29/2020 09:00	0.0	0	0	0	0	1
10/29/2020 10:00	0.0	0	0	0	0	1
10/29/2020 11:00	0.0	0	0	0	0	1
10/29/2020 12:00	0.0	0	0	0	0	1
10/29/2020 13:00	0.0	0	0	0	0	1
10/29/2020 14:00	0.0	0	0	0	0	1
10/29/2020 15:00	0.0	0	0	0	0	1
10/29/2020 16:00	0.0	0	0	0	0	1
10/29/2020 17:00	0.0	0	0	0	0	1
10/29/2020 18:00	0.0	0	0	0	0	1
10/29/2020 19:00	0.0	0	0	0	0	1
10/29/2020 20:00	0.0	0	0	0	0	1
10/29/2020 21:00	0.0	0	0	0	0	1
10/29/2020 22:00	0.0	0	0	0	0	1
10/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2020 00:00	0.0	0	0	0	0	1
10/30/2020 01:00	0.0	0	0	0	0	1
10/30/2020 02:00	0.0	0	0	0	0	1
10/30/2020 03:00	0.0	0	0	0	0	1
10/30/2020 04:00	0.0	0	0	0	0	1
10/30/2020 05:00	0.0	0	0	0	0	1
10/30/2020 06:00	0.0	0	0	0	0	1
10/30/2020 07:00	0.0	0	0	0	0	1
10/30/2020 08:00	0.0	0	0	0	0	1
10/30/2020 09:00	0.0	0	0	0	0	1
10/30/2020 10:00	0.0	0	0	0	0	1
10/30/2020 11:00	0.0	0	0	0	0	1
10/30/2020 12:00	0.0	0	0	0	0	1
10/30/2020 13:00	0.0	0	0	0	0	1
10/30/2020 14:00	0.0	0	0	0	0	1
10/30/2020 15:00	0.0	0	0	0	0	1
10/30/2020 16:00	0.0	0	0	0	0	1
10/30/2020 17:00	0.0	0	0	0	0	1
10/30/2020 18:00	0.0	0	0	0	0	1
10/30/2020 19:00	0.0	0	0	0	0	1
10/30/2020 20:00	0.0	0	0	0	0	1
10/30/2020 21:00	0.0	0	0	0	0	1
10/30/2020 22:00	0.0	0	0	0	0	1
10/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2020 00:00	0.0	0	0	0	0	1
10/31/2020 01:00	0.0	0	0	0	0	1
10/31/2020 02:00	0.0	0	0	0	0	1
10/31/2020 03:00	0.0	0	0	0	0	1
10/31/2020 04:00	0.0	0	0	0	0	1
10/31/2020 05:00	0.0	0	0	0	0	1
10/31/2020 06:00	0.0	0	0	0	0	1
10/31/2020 07:00	0.0	0	0	0	0	1
10/31/2020 08:00	0.0	0	0	0	0	1
10/31/2020 09:00	0.0	0	0	0	0	1
10/31/2020 10:00	0.0	0	0	0	0	1
10/31/2020 11:00	0.0	0	0	0	0	1
10/31/2020 12:00	0.0	0	0	0	0	1
10/31/2020 13:00	0.0	0	0	0	0	1
10/31/2020 14:00	0.0	0	0	0	0	1
10/31/2020 15:00	0.0	0	0	0	0	1
10/31/2020 16:00	0.0	0	0	0	0	1
10/31/2020 17:00	0.0	0	0	0	0	1
10/31/2020 18:00	0.0	0	0	0	0	1
10/31/2020 19:00	0.0	0	0	0	0	1
10/31/2020 20:00	0.0	0	0	0	0	1
10/31/2020 21:00	0.0	0	0	0	0	1
10/31/2020 22:00	0.0	0	0	0	0	1
10/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2020 00:00	0.0	0	0	0	0	1
11/01/2020 01:00	0.0	0	0	0	0	1
11/01/2020 02:00	0.0	0	0	0	0	1
11/01/2020 03:00	0.0	0	0	0	0	1
11/01/2020 04:00	0.0	0	0	0	0	1
11/01/2020 05:00	0.0	0	0	0	0	1
11/01/2020 06:00	0.0	0	0	0	0	1
11/01/2020 07:00	0.0	0	0	0	0	1
11/01/2020 08:00	0.0	0	0	0	0	1
11/01/2020 09:00	0.0	0	0	0	0	1
11/01/2020 10:00	0.0	0	0	0	0	1
11/01/2020 11:00	0.0	0	0	0	0	1
11/01/2020 12:00	0.0	0	0	0	0	1
11/01/2020 13:00	0.0	0	0	0	0	1
11/01/2020 14:00	0.0	0	0	0	0	1
11/01/2020 15:00	0.0	0	0	0	0	1
11/01/2020 16:00	0.0	0	0	0	0	1
11/01/2020 17:00	0.0	0	0	0	0	1
11/01/2020 18:00	0.0	0	0	0	0	1
11/01/2020 19:00	0.0	0	0	0	0	1
11/01/2020 20:00	0.0	0	0	0	0	1
11/01/2020 21:00	0.0	0	0	0	0	1
11/01/2020 22:00	0.0	0	0	0	0	1
11/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2020 00:00	0.0	0	0	0	0	1
11/02/2020 01:00	0.0	0	0	0	0	1
11/02/2020 02:00	0.0	0	0	0	0	1
11/02/2020 03:00	0.0	0	0	0	0	1
11/02/2020 04:00	0.0	0	0	0	0	1
11/02/2020 05:00	0.0	0	0	0	0	1
11/02/2020 06:00	0.0	0	0	0	0	1
11/02/2020 07:00	0.0	0	0	0	0	1
11/02/2020 08:00	0.0	0	0	0	0	1
11/02/2020 09:00	0.0	0	0	0	0	1
11/02/2020 10:00	0.0	0	0	0	0	1
11/02/2020 11:00	0.0	0	0	0	0	1
11/02/2020 12:00	0.0	0	0	0	0	1
11/02/2020 13:00	0.0	0	0	0	0	1
11/02/2020 14:00	0.0	0	0	0	0	1
11/02/2020 15:00	0.0	0	0	0	0	1
11/02/2020 16:00	0.0	0	0	0	0	1
11/02/2020 17:00	0.0	0	0	0	0	1
11/02/2020 18:00	0.0	0	0	0	0	1
11/02/2020 19:00	0.0	0	0	0	0	1
11/02/2020 20:00	0.0	0	0	0	0	1
11/02/2020 21:00	0.0	0	0	0	0	1
11/02/2020 22:00	0.0	0	0	0	0	1
11/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2020 00:00	0.0	0	0	0	0	1
11/03/2020 01:00	0.0	0	0	0	0	1
11/03/2020 02:00	0.0	0	0	0	0	1
11/03/2020 03:00	0.0	0	0	0	0	1
11/03/2020 04:00	0.0	0	0	0	0	1
11/03/2020 05:00	0.0	0	0	0	0	1
11/03/2020 06:00	0.0	0	0	0	0	1
11/03/2020 07:00	0.0	0	0	0	0	1
11/03/2020 08:00	0.0	0	0	0	0	1
11/03/2020 09:00	0.0	0	0	0	0	1
11/03/2020 10:00	0.0	0	0	0	0	1
11/03/2020 11:00	0.0	0	0	0	0	1
11/03/2020 12:00	0.0	0	0	0	0	1
11/03/2020 13:00	0.0	0	0	0	0	1
11/03/2020 14:00	0.0	0	0	0	0	1
11/03/2020 15:00	0.0	0	0	0	0	1
11/03/2020 16:00	0.0	0	0	0	0	1
11/03/2020 17:00	0.0	0	0	0	0	1
11/03/2020 18:00	0.0	0	0	0	0	1
11/03/2020 19:00	0.0	0	0	0	0	1
11/03/2020 20:00	0.0	0	0	0	0	1
11/03/2020 21:00	0.0	0	0	0	0	1
11/03/2020 22:00	0.0	0	0	0	0	1
11/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2020 00:00	0.0	0	0	0	0	1
11/04/2020 01:00	0.0	0	0	0	0	1
11/04/2020 02:00	0.0	0	0	0	0	1
11/04/2020 03:00	0.0	0	0	0	0	1
11/04/2020 04:00	0.0	0	0	0	0	1
11/04/2020 05:00	0.0	0	0	0	0	1
11/04/2020 06:00	0.0	0	0	0	0	1
11/04/2020 07:00	0.0	0	0	0	0	1
11/04/2020 08:00	0.0	0	0	0	0	1
11/04/2020 09:00	0.0	0	0	0	0	1
11/04/2020 10:00	0.0	0	0	0	0	1
11/04/2020 11:00	0.0	0	0	0	0	1
11/04/2020 12:00	0.0	0	0	0	0	1
11/04/2020 13:00	0.0	0	0	0	0	1
11/04/2020 14:00	0.0	0	0	0	0	1
11/04/2020 15:00	0.0	0	0	0	0	1
11/04/2020 16:00	0.0	0	0	0	0	1
11/04/2020 17:00	0.0	0	0	0	0	1
11/04/2020 18:00	0.0	0	0	0	0	1
11/04/2020 19:00	0.0	0	0	0	0	1
11/04/2020 20:00	0.0	0	0	0	0	1
11/04/2020 21:00	0.0	0	0	0	0	1
11/04/2020 22:00	0.0	0	0	0	0	1
11/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2020 00:00	0.0	0	0	0	0	1
11/05/2020 01:00	0.0	0	0	0	0	1
11/05/2020 02:00	0.0	0	0	0	0	1
11/05/2020 03:00	0.0	0	0	0	0	1
11/05/2020 04:00	0.0	0	0	0	0	1
11/05/2020 05:00	0.0	0	0	0	0	1
11/05/2020 06:00	0.0	0	0	0	0	1
11/05/2020 07:00	0.0	0	0	0	0	1
11/05/2020 08:00	0.0	0	0	0	0	1
11/05/2020 09:00	0.0	0	0	0	0	1
11/05/2020 10:00	0.0	0	0	0	0	1
11/05/2020 11:00	0.0	0	0	0	0	1
11/05/2020 12:00	0.0	0	0	0	0	1
11/05/2020 13:00	0.0	0	0	0	0	1
11/05/2020 14:00	0.0	0	0	0	0	1
11/05/2020 15:00	0.0	0	0	0	0	1
11/05/2020 16:00	0.0	0	0	0	0	1
11/05/2020 17:00	0.0	0	0	0	0	1
11/05/2020 18:00	0.0	0	0	0	0	1
11/05/2020 19:00	0.0	0	0	0	0	1
11/05/2020 20:00	0.0	0	0	0	0	1
11/05/2020 21:00	0.0	0	0	0	0	1
11/05/2020 22:00	0.0	0	0	0	0	1
11/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2020 00:00	0.0	0	0	0	0	1
11/06/2020 01:00	0.0	0	0	0	0	1
11/06/2020 02:00	0.0	0	0	0	0	1
11/06/2020 03:00	0.0	0	0	0	0	1
11/06/2020 04:00	0.0	0	0	0	0	1
11/06/2020 05:00	0.0	0	0	0	0	1
11/06/2020 06:00	0.0	0	0	0	0	1
11/06/2020 07:00	0.0	0	0	0	0	1
11/06/2020 08:00	0.0	0	0	0	0	1
11/06/2020 09:00	0.0	0	0	0	0	1
11/06/2020 10:00	0.0	0	0	0	0	1
11/06/2020 11:00	0.0	0	0	0	0	1
11/06/2020 12:00	0.0	0	0	0	0	1
11/06/2020 13:00	0.0	0	0	0	0	1
11/06/2020 14:00	0.0	0	0	0	0	1
11/06/2020 15:00	0.0	0	0	0	0	1
11/06/2020 16:00	0.0	0	0	0	0	1
11/06/2020 17:00	0.0	0	0	0	0	1
11/06/2020 18:00	0.0	0	0	0	0	1
11/06/2020 19:00	0.0	0	0	0	0	1
11/06/2020 20:00	0.0	0	0	0	0	1
11/06/2020 21:00	0.0	0	0	0	0	1
11/06/2020 22:00	0.0	0	0	0	0	1
11/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2020 00:00	0.0	0	0	0	0	1
11/07/2020 01:00	0.0	0	0	0	0	1
11/07/2020 02:00	0.0	0	0	0	0	1
11/07/2020 03:00	0.0	0	0	0	0	1
11/07/2020 04:00	0.0	0	0	0	0	1
11/07/2020 05:00	0.0	0	0	0	0	1
11/07/2020 06:00	0.0	0	0	0	0	1
11/07/2020 07:00	0.0	0	0	0	0	1
11/07/2020 08:00	0.0	0	0	0	0	1
11/07/2020 09:00	0.0	0	0	0	0	1
11/07/2020 10:00	0.0	0	0	0	0	1
11/07/2020 11:00	0.0	0	0	0	0	1
11/07/2020 12:00	0.0	0	0	0	0	1
11/07/2020 13:00	0.0	0	0	0	0	1
11/07/2020 14:00	0.0	0	0	0	0	1
11/07/2020 15:00	0.0	0	0	0	0	1
11/07/2020 16:00	0.0	0	0	0	0	1
11/07/2020 17:00	0.0	0	0	0	0	1
11/07/2020 18:00	0.0	0	0	0	0	1
11/07/2020 19:00	0.0	0	0	0	0	1
11/07/2020 20:00	0.0	0	0	0	0	1
11/07/2020 21:00	0.0	0	0	0	0	1
11/07/2020 22:00	0.0	0	0	0	0	1
11/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2020 00:00	0.0	0	0	0	0	1
11/08/2020 01:00	0.0	0	0	0	0	1
11/08/2020 02:00	0.0	0	0	0	0	1
11/08/2020 03:00	0.0	0	0	0	0	1
11/08/2020 04:00	0.0	0	0	0	0	1
11/08/2020 05:00	0.0	0	0	0	0	1
11/08/2020 06:00	0.0	0	0	0	0	1
11/08/2020 07:00	0.0	0	0	0	0	1
11/08/2020 08:00	0.0	0	0	0	0	1
11/08/2020 09:00	0.0	0	0	0	0	1
11/08/2020 10:00	0.0	0	0	0	0	1
11/08/2020 11:00	0.0	0	0	0	0	1
11/08/2020 12:00	0.0	0	0	0	0	1
11/08/2020 13:00	0.0	0	0	0	0	1
11/08/2020 14:00	0.0	0	0	0	0	1
11/08/2020 15:00	0.0	0	0	0	0	1
11/08/2020 16:00	0.0	0	0	0	0	1
11/08/2020 17:00	0.0	0	0	0	0	1
11/08/2020 18:00	0.0	0	0	0	0	1
11/08/2020 19:00	0.0	0	0	0	0	1
11/08/2020 20:00	0.0	0	0	0	0	1
11/08/2020 21:00	0.0	0	0	0	0	1
11/08/2020 22:00	0.0	0	0	0	0	1
11/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2020 00:00	0.0	0	0	0	0	1
11/09/2020 01:00	0.0	0	0	0	0	1
11/09/2020 02:00	0.0	0	0	0	0	1
11/09/2020 03:00	0.0	0	0	0	0	1
11/09/2020 04:00	0.0	0	0	0	0	1
11/09/2020 05:00	0.0	0	0	0	0	1
11/09/2020 06:00	0.0	0	0	0	0	1
11/09/2020 07:00	0.0	0	0	0	0	1
11/09/2020 08:00	0.0	0	0	0	0	1
11/09/2020 09:00	0.0	0	0	0	0	1
11/09/2020 10:00	0.0	0	0	0	0	1
11/09/2020 11:00	0.0	0	0	0	0	1
11/09/2020 12:00	0.0	0	0	0	0	1
11/09/2020 13:00	0.0	0	0	0	0	1
11/09/2020 14:00	0.0	0	0	0	0	1
11/09/2020 15:00	0.0	0	0	0	0	1
11/09/2020 16:00	0.0	0	0	0	0	1
11/09/2020 17:00	0.0	0	0	0	0	1
11/09/2020 18:00	0.0	0	0	0	0	1
11/09/2020 19:00	0.0	0	0	0	0	1
11/09/2020 20:00	0.0	0	0	0	0	1
11/09/2020 21:00	0.0	0	0	0	0	1
11/09/2020 22:00	0.0	0	0	0	0	1
11/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2020 00:00	0.0	0	0	0	0	1
11/10/2020 01:00	0.0	0	0	0	0	1
11/10/2020 02:00	0.0	0	0	0	0	1
11/10/2020 03:00	0.0	0	0	0	0	1
11/10/2020 04:00	0.0	0	0	0	0	1
11/10/2020 05:00	0.0	0	0	0	0	1
11/10/2020 06:00	0.0	0	0	0	0	1
11/10/2020 07:00	0.0	0	0	0	0	1
11/10/2020 08:00	0.0	0	0	0	0	1
11/10/2020 09:00	0.0	0	0	0	0	1
11/10/2020 10:00	0.0	0	0	0	0	1
11/10/2020 11:00	0.0	0	0	0	0	1
11/10/2020 12:00	0.0	0	0	0	0	1
11/10/2020 13:00	0.0	0	0	0	0	1
11/10/2020 14:00	0.0	0	0	0	0	1
11/10/2020 15:00	0.0	0	0	0	0	1
11/10/2020 16:00	0.0	0	0	0	0	1
11/10/2020 17:00	0.0	0	0	0	0	1
11/10/2020 18:00	0.0	0	0	0	0	1
11/10/2020 19:00	0.0	0	0	0	0	1
11/10/2020 20:00	0.0	0	0	0	0	1
11/10/2020 21:00	0.0	0	0	0	0	1
11/10/2020 22:00	0.0	0	0	0	0	1
11/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2020 00:00	0.0	0	0	0	0	1
11/11/2020 01:00	0.0	0	0	0	0	1
11/11/2020 02:00	0.0	0	0	0	0	1
11/11/2020 03:00	0.0	0	0	0	0	1
11/11/2020 04:00	0.0	0	0	0	0	1
11/11/2020 05:00	0.0	0	0	0	0	1
11/11/2020 06:00	0.0	0	0	0	0	1
11/11/2020 07:00	0.0	0	0	0	0	1
11/11/2020 08:00	0.0	0	0	0	0	1
11/11/2020 09:00	0.0	0	0	0	0	1
11/11/2020 10:00	0.0	0	0	0	0	1
11/11/2020 11:00	0.0	0	0	0	0	1
11/11/2020 12:00	0.0	0	0	0	0	1
11/11/2020 13:00	0.0	0	0	0	0	1
11/11/2020 14:00	0.0	0	0	0	0	1
11/11/2020 15:00	0.0	0	0	0	0	1
11/11/2020 16:00	0.0	0	0	0	0	1
11/11/2020 17:00	0.0	0	0	0	0	1
11/11/2020 18:00	0.0	0	0	0	0	1
11/11/2020 19:00	0.0	0	0	0	0	1
11/11/2020 20:00	0.0	0	0	0	0	1
11/11/2020 21:00	0.0	0	0	0	0	1
11/11/2020 22:00	0.0	0	0	0	0	1
11/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2020 00:00	0.0	0	0	0	0	1
11/12/2020 01:00	0.0	0	0	0	0	1
11/12/2020 02:00	0.0	0	0	0	0	1
11/12/2020 03:00	0.0	0	0	0	0	1
11/12/2020 04:00	0.0	0	0	0	0	1
11/12/2020 05:00	0.0	0	0	0	0	1
11/12/2020 06:00	0.0	0	0	0	0	1
11/12/2020 07:00	0.0	0	0	0	0	1
11/12/2020 08:00	0.0	0	0	0	0	1
11/12/2020 09:00	0.0	0	0	0	0	1
11/12/2020 10:00	0.0	0	0	0	0	1
11/12/2020 11:00	0.0	0	0	0	0	1
11/12/2020 12:00	0.0	0	0	0	0	1
11/12/2020 13:00	0.0	0	0	0	0	1
11/12/2020 14:00	0.0	0	0	0	0	1
11/12/2020 15:00	0.0	0	0	0	0	1
11/12/2020 16:00	0.0	0	0	0	0	1
11/12/2020 17:00	0.0	0	0	0	0	1
11/12/2020 18:00	0.0	0	0	0	0	1
11/12/2020 19:00	0.0	0	0	0	0	1
11/12/2020 20:00	0.0	0	0	0	0	1
11/12/2020 21:00	0.0	0	0	0	0	1
11/12/2020 22:00	0.0	0	0	0	0	1
11/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2020 00:00	0.0	0	0	0	0	1
11/13/2020 01:00	0.0	0	0	0	0	1
11/13/2020 02:00	0.0	0	0	0	0	1
11/13/2020 03:00	0.0	0	0	0	0	1
11/13/2020 04:00	0.0	0	0	0	0	1
11/13/2020 05:00	0.0	0	0	0	0	1
11/13/2020 06:00	0.0	0	0	0	0	1
11/13/2020 07:00	0.0	0	0	0	0	1
11/13/2020 08:00	0.0	0	0	0	0	1
11/13/2020 09:00	0.0	0	0	0	0	1
11/13/2020 10:00	0.0	0	0	0	0	1
11/13/2020 11:00	0.0	0	0	0	0	1
11/13/2020 12:00	0.0	0	0	0	0	1
11/13/2020 13:00	0.0	0	0	0	0	1
11/13/2020 14:00	0.0	0	0	0	0	1
11/13/2020 15:00	0.0	0	0	0	0	1
11/13/2020 16:00	0.0	0	0	0	0	1
11/13/2020 17:00	0.0	0	0	0	0	1
11/13/2020 18:00	0.0	0	0	0	0	1
11/13/2020 19:00	0.0	0	0	0	0	1
11/13/2020 20:00	0.0	0	0	0	0	1
11/13/2020 21:00	0.0	0	0	0	0	1
11/13/2020 22:00	0.0	0	0	0	0	1
11/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2020 00:00	0.0	0	0	0	0	1
11/14/2020 01:00	0.0	0	0	0	0	1
11/14/2020 02:00	0.0	0	0	0	0	1
11/14/2020 03:00	0.0	0	0	0	0	1
11/14/2020 04:00	0.0	0	0	0	0	1
11/14/2020 05:00	0.0	0	0	0	0	1
11/14/2020 06:00	0.0	0	0	0	0	1
11/14/2020 07:00	0.0	0	0	0	0	1
11/14/2020 08:00	0.0	0	0	0	0	1
11/14/2020 09:00	0.0	0	0	0	0	1
11/14/2020 10:00	0.0	0	0	0	0	1
11/14/2020 11:00	0.0	0	0	0	0	1
11/14/2020 12:00	0.0	0	0	0	0	1
11/14/2020 13:00	0.0	0	0	0	0	1
11/14/2020 14:00	0.0	0	0	0	0	1
11/14/2020 15:00	0.0	0	0	0	0	1
11/14/2020 16:00	0.0	0	0	0	0	1
11/14/2020 17:00	0.0	0	0	0	0	1
11/14/2020 18:00	0.0	0	0	0	0	1
11/14/2020 19:00	0.0	0	0	0	0	1
11/14/2020 20:00	0.0	0	0	0	0	1
11/14/2020 21:00	0.0	0	0	0	0	1
11/14/2020 22:00	0.0	0	0	0	0	1
11/14/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2020 00:00	0.0	0	0	0	0	1
11/15/2020 01:00	0.0	0	0	0	0	1
11/15/2020 02:00	0.0	0	0	0	0	1
11/15/2020 03:00	0.0	0	0	0	0	1
11/15/2020 04:00	0.0	0	0	0	0	1
11/15/2020 05:00	0.0	0	0	0	0	1
11/15/2020 06:00	0.0	0	0	0	0	1
11/15/2020 07:00	0.0	0	0	0	0	1
11/15/2020 08:00	0.0	0	0	0	0	1
11/15/2020 09:00	0.0	0	0	0	0	1
11/15/2020 10:00	0.0	0	0	0	0	1
11/15/2020 11:00	0.0	0	0	0	0	1
11/15/2020 12:00	0.0	0	0	0	0	1
11/15/2020 13:00	0.0	0	0	0	0	1
11/15/2020 14:00	0.0	0	0	0	0	1
11/15/2020 15:00	0.0	0	0	0	0	1
11/15/2020 16:00	0.0	0	0	0	0	1
11/15/2020 17:00	0.0	0	0	0	0	1
11/15/2020 18:00	0.0	0	0	0	0	1
11/15/2020 19:00	0.0	0	0	0	0	1
11/15/2020 20:00	0.0	0	0	0	0	1
11/15/2020 21:00	0.0	0	0	0	0	1
11/15/2020 22:00	0.0	0	0	0	0	1
11/15/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2020 00:00	0.0	0	0	0	0	1
11/16/2020 01:00	0.0	0	0	0	0	1
11/16/2020 02:00	0.0	0	0	0	0	1
11/16/2020 03:00	0.0	0	0	0	0	1
11/16/2020 04:00	0.0	0	0	0	0	1
11/16/2020 05:00	0.0	0	0	0	0	1
11/16/2020 06:00	0.0	0	0	0	0	1
11/16/2020 07:00	0.0	0	0	0	0	1
11/16/2020 08:00	0.0	0	0	0	0	1
11/16/2020 09:00	0.0	0	0	0	0	1
11/16/2020 10:00	0.0	0	0	0	0	1
11/16/2020 11:00	0.0	0	0	0	0	1
11/16/2020 12:00	0.0	0	0	0	0	1
11/16/2020 13:00	0.0	0	0	0	0	1
11/16/2020 14:00	0.0	0	0	0	0	1
11/16/2020 15:00	0.0	0	0	0	0	1
11/16/2020 16:00	0.0	0	0	0	0	1
11/16/2020 17:00	0.0	0	0	0	0	1
11/16/2020 18:00	0.0	0	0	0	0	1
11/16/2020 19:00	0.0	0	0	0	0	1
11/16/2020 20:00	0.0	0	0	0	0	1
11/16/2020 21:00	0.0	0	0	0	0	1
11/16/2020 22:00	0.0	0	0	0	0	1
11/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2020 00:00	0.0	0	0	0	0	1
11/17/2020 01:00	0.0	0	0	0	0	1
11/17/2020 02:00	0.0	0	0	0	0	1
11/17/2020 03:00	0.0	0	0	0	0	1
11/17/2020 04:00	0.0	0	0	0	0	1
11/17/2020 05:00	0.0	0	0	0	0	1
11/17/2020 06:00	0.0	0	0	0	0	1
11/17/2020 07:00	0.0	0	0	0	0	1
11/17/2020 08:00	0.0	0	0	0	0	1
11/17/2020 09:00	0.0	0	0	0	0	1
11/17/2020 10:00	0.0	0	0	0	0	1
11/17/2020 11:00	0.0	0	0	0	0	1
11/17/2020 12:00	0.0	0	0	0	0	1
11/17/2020 13:00	0.0	0	0	0	0	1
11/17/2020 14:00	0.0	0	0	0	0	1
11/17/2020 15:00	0.0	0	0	0	0	1
11/17/2020 16:00	0.0	0	0	0	0	1
11/17/2020 17:00	0.0	0	0	0	0	1
11/17/2020 18:00	0.0	0	0	0	0	1
11/17/2020 19:00	0.0	0	0	0	0	1
11/17/2020 20:00	0.0	0	0	0	0	1
11/17/2020 21:00	0.0	0	0	0	0	1
11/17/2020 22:00	0.0	0	0	0	0	1
11/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2020 00:00	0.0	0	0	0	0	1
11/18/2020 01:00	0.0	0	0	0	0	1
11/18/2020 02:00	0.0	0	0	0	0	1
11/18/2020 03:00	0.0	0	0	0	0	1
11/18/2020 04:00	0.0	0	0	0	0	1
11/18/2020 05:00	0.0	0	0	0	0	1
11/18/2020 06:00	0.0	0	0	0	0	1
11/18/2020 07:00	0.0	0	0	0	0	1
11/18/2020 08:00	0.0	0	0	0	0	1
11/18/2020 09:00	0.0	0	0	0	0	1
11/18/2020 10:00	0.0	0	0	0	0	1
11/18/2020 11:00	0.0	0	0	0	0	1
11/18/2020 12:00	0.0	0	0	0	0	1
11/18/2020 13:00	0.0	0	0	0	0	1
11/18/2020 14:00	0.0	0	0	0	0	1
11/18/2020 15:00	0.0	0	0	0	0	1
11/18/2020 16:00	0.0	0	0	0	0	1
11/18/2020 17:00	0.0	0	0	0	0	1
11/18/2020 18:00	0.0	0	0	0	0	1
11/18/2020 19:00	0.0	0	0	0	0	1
11/18/2020 20:00	0.0	0	0	0	0	1
11/18/2020 21:00	0.0	0	0	0	0	1
11/18/2020 22:00	0.0	0	0	0	0	1
11/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2020 00:00	0.0	0	0	0	0	1
11/19/2020 01:00	0.0	0	0	0	0	1
11/19/2020 02:00	0.0	0	0	0	0	1
11/19/2020 03:00	0.0	0	0	0	0	1
11/19/2020 04:00	0.0	0	0	0	0	1
11/19/2020 05:00	0.0	0	0	0	0	1
11/19/2020 06:00	0.0	0	0	0	0	1
11/19/2020 07:00	0.0	0	0	0	0	1
11/19/2020 08:00	0.0	0	0	0	0	1
11/19/2020 09:00	0.0	0	0	0	0	1
11/19/2020 10:00	0.0	0	0	0	0	1
11/19/2020 11:00	0.0	0	0	0	0	1
11/19/2020 12:00	0.0	0	0	0	0	1
11/19/2020 13:00	0.0	0	0	0	0	1
11/19/2020 14:00	0.0	0	0	0	0	1
11/19/2020 15:00	0.0	0	0	0	0	1
11/19/2020 16:00	0.0	0	0	0	0	1
11/19/2020 17:00	0.0	0	0	0	0	1
11/19/2020 18:00	0.0	0	0	0	0	1
11/19/2020 19:00	0.0	0	0	0	0	1
11/19/2020 20:00	0.0	0	0	0	0	1
11/19/2020 21:00	0.0	0	0	0	0	1
11/19/2020 22:00	0.0	0	0	0	0	1
11/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2020 00:00	0.0	0	0	0	0	1
11/20/2020 01:00	0.0	0	0	0	0	1
11/20/2020 02:00	0.0	0	0	0	0	1
11/20/2020 03:00	0.0	0	0	0	0	1
11/20/2020 04:00	0.0	0	0	0	0	1
11/20/2020 05:00	0.0	0	0	0	0	1
11/20/2020 06:00	0.0	0	0	0	0	1
11/20/2020 07:00	0.0	0	0	0	0	1
11/20/2020 08:00	0.0	0	0	0	0	1
11/20/2020 09:00	0.0	0	0	0	0	1
11/20/2020 10:00	0.0	0	0	0	0	1
11/20/2020 11:00	0.0	0	0	0	0	1
11/20/2020 12:00	0.0	0	0	0	0	1
11/20/2020 13:00	0.0	0	0	0	0	1
11/20/2020 14:00	0.0	0	0	0	0	1
11/20/2020 15:00	0.0	0	0	0	0	1
11/20/2020 16:00	0.0	0	0	0	0	1
11/20/2020 17:00	0.0	0	0	0	0	1
11/20/2020 18:00	0.0	0	0	0	0	1
11/20/2020 19:00	0.0	0	0	0	0	1
11/20/2020 20:00	0.0	0	0	0	0	1
11/20/2020 21:00	0.0	0	0	0	0	1
11/20/2020 22:00	0.0	0	0	0	0	1
11/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2020 00:00	0.0	0	0	0	0	1
11/21/2020 01:00	0.0	0	0	0	0	1
11/21/2020 02:00	0.0	0	0	0	0	1
11/21/2020 03:00	0.0	0	0	0	0	1
11/21/2020 04:00	0.0	0	0	0	0	1
11/21/2020 05:00	0.0	0	0	0	0	1
11/21/2020 06:00	0.0	0	0	0	0	1
11/21/2020 07:00	0.0	0	0	0	0	1
11/21/2020 08:00	0.0	0	0	0	0	1
11/21/2020 09:00	0.0	0	0	0	0	1
11/21/2020 10:00	0.0	0	0	0	0	1
11/21/2020 11:00	0.0	0	0	0	0	1
11/21/2020 12:00	0.0	0	0	0	0	1
11/21/2020 13:00	0.0	0	0	0	0	1
11/21/2020 14:00	0.0	0	0	0	0	1
11/21/2020 15:00	0.0	0	0	0	0	1
11/21/2020 16:00	0.0	0	0	0	0	1
11/21/2020 17:00	0.0	0	0	0	0	1
11/21/2020 18:00	0.0	0	0	0	0	1
11/21/2020 19:00	0.0	0	0	0	0	1
11/21/2020 20:00	0.0	0	0	0	0	1
11/21/2020 21:00	0.0	0	0	0	0	1
11/21/2020 22:00	0.0	0	0	0	0	1
11/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2020 00:00	0.0	0	0	0	0	1
11/22/2020 01:00	0.0	0	0	0	0	1
11/22/2020 02:00	0.0	0	0	0	0	1
11/22/2020 03:00	0.0	0	0	0	0	1
11/22/2020 04:00	0.0	0	0	0	0	1
11/22/2020 05:00	0.0	0	0	0	0	1
11/22/2020 06:00	0.0	0	0	0	0	1
11/22/2020 07:00	0.0	0	0	0	0	1
11/22/2020 08:00	0.0	0	0	0	0	1
11/22/2020 09:00	0.0	0	0	0	0	1
11/22/2020 10:00	0.0	0	0	0	0	1
11/22/2020 11:00	0.0	0	0	0	0	1
11/22/2020 12:00	0.0	0	0	0	0	1
11/22/2020 13:00	0.0	0	0	0	0	1
11/22/2020 14:00	0.0	0	0	0	0	1
11/22/2020 15:00	0.0	0	0	0	0	1
11/22/2020 16:00	0.0	0	0	0	0	1
11/22/2020 17:00	0.0	0	0	0	0	1
11/22/2020 18:00	0.0	0	0	0	0	1
11/22/2020 19:00	0.0	0	0	0	0	1
11/22/2020 20:00	0.0	0	0	0	0	1
11/22/2020 21:00	0.0	0	0	0	0	1
11/22/2020 22:00	0.0	0	0	0	0	1
11/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2020 00:00	0.0	0	0	0	0	1
11/23/2020 01:00	0.0	0	0	0	0	1
11/23/2020 02:00	0.0	0	0	0	0	1
11/23/2020 03:00	0.0	0	0	0	0	1
11/23/2020 04:00	0.0	0	0	0	0	1
11/23/2020 05:00	0.0	0	0	0	0	1
11/23/2020 06:00	0.0	0	0	0	0	1
11/23/2020 07:00	0.0	0	0	0	0	1
11/23/2020 08:00	0.0	0	0	0	0	1
11/23/2020 09:00	0.0	0	0	0	0	1
11/23/2020 10:00	0.0	0	0	0	0	1
11/23/2020 11:00	0.0	0	0	0	0	1
11/23/2020 12:00	0.0	0	0	0	0	1
11/23/2020 13:00	0.0	0	0	0	0	1
11/23/2020 14:00	0.0	0	0	0	0	1
11/23/2020 15:00	0.0	0	0	0	0	1
11/23/2020 16:00	0.0	0	0	0	0	1
11/23/2020 17:00	0.0	0	0	0	0	1
11/23/2020 18:00	0.0	0	0	0	0	1
11/23/2020 19:00	0.0	0	0	0	0	1
11/23/2020 20:00	0.0	0	0	0	0	1
11/23/2020 21:00	0.0	0	0	0	0	1
11/23/2020 22:00	0.0	0	0	0	0	1
11/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2020 00:00	0.0	0	0	0	0	1
11/24/2020 01:00	0.0	0	0	0	0	1
11/24/2020 02:00	0.0	0	0	0	0	1
11/24/2020 03:00	0.0	0	0	0	0	1
11/24/2020 04:00	0.0	0	0	0	0	1
11/24/2020 05:00	0.0	0	0	0	0	1
11/24/2020 06:00	0.0	0	0	0	0	1
11/24/2020 07:00	0.0	0	0	0	0	1
11/24/2020 08:00	0.0	0	0	0	0	1
11/24/2020 09:00	0.0	0	0	0	0	1
11/24/2020 10:00	0.0	0	0	0	0	1
11/24/2020 11:00	0.0	0	0	0	0	1
11/24/2020 12:00	0.0	0	0	0	0	1
11/24/2020 13:00	0.0	0	0	0	0	1
11/24/2020 14:00	0.0	0	0	0	0	1
11/24/2020 15:00	0.0	0	0	0	0	1
11/24/2020 16:00	0.0	0	0	0	0	1
11/24/2020 17:00	0.0	0	0	0	0	1
11/24/2020 18:00	0.0	0	0	0	0	1
11/24/2020 19:00	0.0	0	0	0	0	1
11/24/2020 20:00	0.0	0	0	0	0	1
11/24/2020 21:00	0.0	0	0	0	0	1
11/24/2020 22:00	0.0	0	0	0	0	1
11/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2020 00:00	0.0	0	0	0	0	1
11/25/2020 01:00	0.0	0	0	0	0	1
11/25/2020 02:00	0.0	0	0	0	0	1
11/25/2020 03:00	0.0	0	0	0	0	1
11/25/2020 04:00	0.0	0	0	0	0	1
11/25/2020 05:00	0.0	0	0	0	0	1
11/25/2020 06:00	0.0	0	0	0	0	1
11/25/2020 07:00	0.0	0	0	0	0	1
11/25/2020 08:00	0.0	0	0	0	0	1
11/25/2020 09:00	0.0	0	0	0	0	1
11/25/2020 10:00	0.0	0	0	0	0	1
11/25/2020 11:00	0.0	0	0	0	0	1
11/25/2020 12:00	0.0	0	0	0	0	1
11/25/2020 13:00	0.0	0	0	0	0	1
11/25/2020 14:00	0.0	0	0	0	0	1
11/25/2020 15:00	0.0	0	0	0	0	1
11/25/2020 16:00	0.0	0	0	0	0	1
11/25/2020 17:00	0.0	0	0	0	0	1
11/25/2020 18:00	0.0	0	0	0	0	1
11/25/2020 19:00	0.0	0	0	0	0	1
11/25/2020 20:00	0.0	0	0	0	0	1
11/25/2020 21:00	0.0	0	0	0	0	1
11/25/2020 22:00	0.0	0	0	0	0	1
11/25/2020 23:00	1.4	0	0	0	1	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2020 00:00	0.0	0	0	0	0	0
11/26/2020 01:00	0.0	0	0	0	0	0
11/26/2020 02:00	0.0	0	0	0	0	0
11/26/2020 03:00	0.0	0	0	0	0	0
11/26/2020 04:00	0.0	0	0	0	0	0
11/26/2020 05:00	0.0	0	0	0	0	0
11/26/2020 06:00	0.0	0	0	0	0	0
11/26/2020 07:00	0.0	0	0	0	0	0
11/26/2020 08:00	0.0	0	0	0	0	0
11/26/2020 09:00	0.0	0	0	0	0	0
11/26/2020 10:00	0.0	0	0	0	0	0
11/26/2020 11:00	0.0	0	0	0	0	0
11/26/2020 12:00	0.0	0	0	0	0	0
11/26/2020 13:00	0.0	0	0	0	0	0
11/26/2020 14:00	0.0	0	0	0	0	0
11/26/2020 15:00	0.0	0	0	0	0	0
11/26/2020 16:00	0.0	0	0	0	0	0
11/26/2020 17:00	0.0	0	0	0	0	0
11/26/2020 18:00	0.0	0	0	0	0	0
11/26/2020 19:00	0.0	0	0	0	0	0
11/26/2020 20:00	0.0	0	0	0	0	0
11/26/2020 21:00	0.0	0	0	0	0	0
11/26/2020 22:00	0.0	0	0	0	0	0
11/26/2020 23:00	73.6	0	1	0	0	0
Average/Sum#:	73.6 #	0 #	1 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	73.6	0	1	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2020 00:00	40.4	0	1	0	0	0
11/27/2020 01:00	38.9	0	1	0	0	0
11/27/2020 02:00	0.0	0	0	0	0	1
11/27/2020 03:00	0.0	0	0	0	0	1
11/27/2020 04:00	0.0	0	0	0	0	1
11/27/2020 05:00	0.0	0	0	0	0	1
11/27/2020 06:00	0.0	0	0	0	0	1
11/27/2020 07:00	0.0	0	0	0	0	1
11/27/2020 08:00	0.0	0	0	0	0	1
11/27/2020 09:00	0.0	0	0	0	0	1
11/27/2020 10:00	0.0	0	0	0	0	1
11/27/2020 11:00	0.0	0	0	0	0	1
11/27/2020 12:00	0.0	0	0	0	0	1
11/27/2020 13:00	0.0	0	0	0	0	1
11/27/2020 14:00	0.0	0	0	0	0	1
11/27/2020 15:00	0.0	0	0	0	0	1
11/27/2020 16:00	0.0	0	0	0	0	1
11/27/2020 17:00	0.0	0	0	0	0	1
11/27/2020 18:00	0.0	0	0	0	0	1
11/27/2020 19:00	0.0	0	0	0	0	1
11/27/2020 20:00	0.0	0	0	0	0	1
11/27/2020 21:00	0.0	0	0	0	0	1
11/27/2020 22:00	0.0	0	0	0	0	1
11/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.3 #	0 #	2 #	0 #	0 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2020 00:00	0.0	0	0	0	0	1
11/28/2020 01:00	0.0	0	0	0	0	1
11/28/2020 02:00	0.0	0	0	0	0	1
11/28/2020 03:00	0.0	0	0	0	0	1
11/28/2020 04:00	0.0	0	0	0	0	1
11/28/2020 05:00	0.0	0	0	0	0	1
11/28/2020 06:00	0.0	0	0	0	0	1
11/28/2020 07:00	0.0	0	0	0	0	1
11/28/2020 08:00	0.0	0	0	0	0	1
11/28/2020 09:00	0.0	0	0	0	0	1
11/28/2020 10:00	0.0	0	0	0	0	1
11/28/2020 11:00	0.0	0	0	0	0	1
11/28/2020 12:00	0.0	0	0	0	0	1
11/28/2020 13:00	0.0	0	0	0	0	1
11/28/2020 14:00	0.0	0	0	0	0	1
11/28/2020 15:00	0.0	0	0	0	0	1
11/28/2020 16:00	0.0	0	0	0	0	1
11/28/2020 17:00	0.0	0	0	0	0	1
11/28/2020 18:00	0.0	0	0	0	0	1
11/28/2020 19:00	0.0	0	0	0	0	1
11/28/2020 20:00	0.0	0	0	0	0	1
11/28/2020 21:00	0.0	0	0	0	0	1
11/28/2020 22:00	0.0	0	0	0	0	1
11/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2020 00:00	0.0	0	0	0	0	1
11/29/2020 01:00	0.0	0	0	0	0	1
11/29/2020 02:00	0.0	0	0	0	0	1
11/29/2020 03:00	0.0	0	0	0	0	1
11/29/2020 04:00	0.0	0	0	0	0	1
11/29/2020 05:00	0.0	0	0	0	0	1
11/29/2020 06:00	0.0	0	0	0	0	1
11/29/2020 07:00	0.0	0	0	0	0	1
11/29/2020 08:00	0.0	0	0	0	0	1
11/29/2020 09:00	0.0	0	0	0	0	1
11/29/2020 10:00	0.0	0	0	0	0	1
11/29/2020 11:00	0.0	0	0	0	0	1
11/29/2020 12:00	0.0	0	0	0	0	1
11/29/2020 13:00	0.0	0	0	0	0	1
11/29/2020 14:00	0.0	0	0	0	0	1
11/29/2020 15:00	0.0	0	0	0	0	1
11/29/2020 16:00	0.0	0	0	0	0	1
11/29/2020 17:00	0.0	0	0	0	0	1
11/29/2020 18:00	0.0	0	0	0	0	1
11/29/2020 19:00	0.0	0	0	0	0	1
11/29/2020 20:00	0.0	0	0	0	0	1
11/29/2020 21:00	0.0	0	0	0	0	1
11/29/2020 22:00	0.0	0	0	0	0	1
11/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2020 00:00	0.0	0	0	0	0	1
11/30/2020 01:00	0.0	0	0	0	0	1
11/30/2020 02:00	0.0	0	0	0	0	1
11/30/2020 03:00	0.0	0	0	0	0	1
11/30/2020 04:00	0.0	0	0	0	0	1
11/30/2020 05:00	0.0	0	0	0	0	1
11/30/2020 06:00	0.0	0	0	0	0	1
11/30/2020 07:00	0.0	0	0	0	0	1
11/30/2020 08:00	0.0	0	0	0	0	1
11/30/2020 09:00	0.0	0	0	0	0	1
11/30/2020 10:00	0.0	0	0	0	0	1
11/30/2020 11:00	0.0	0	0	0	0	1
11/30/2020 12:00	0.0	0	0	0	0	1
11/30/2020 13:00	0.0	0	0	0	0	1
11/30/2020 14:00	0.0	0	0	0	0	1
11/30/2020 15:00	0.0	0	0	0	0	1
11/30/2020 16:00	0.0	0	0	0	0	1
11/30/2020 17:00	0.0	0	0	0	0	1
11/30/2020 18:00	0.0	0	0	0	0	1
11/30/2020 19:00	0.0	0	0	0	0	1
11/30/2020 20:00	0.0	0	0	0	0	1
11/30/2020 21:00	0.0	0	0	0	0	1
11/30/2020 22:00	0.0	0	0	0	0	1
11/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2020 00:00	0.0	0	0	0	0	1
12/01/2020 01:00	0.0	0	0	0	0	1
12/01/2020 02:00	0.0	0	0	0	0	1
12/01/2020 03:00	0.0	0	0	0	0	1
12/01/2020 04:00	0.0	0	0	0	0	1
12/01/2020 05:00	0.0	0	0	0	0	1
12/01/2020 06:00	0.0	0	0	0	0	1
12/01/2020 07:00	0.0	0	0	0	0	1
12/01/2020 08:00	0.0	0	0	0	0	1
12/01/2020 09:00	0.0	0	0	0	0	1
12/01/2020 10:00	0.0	0	0	0	0	1
12/01/2020 11:00	0.0	0	0	0	0	1
12/01/2020 12:00	0.0	0	0	0	0	1
12/01/2020 13:00	0.0	0	0	0	0	1
12/01/2020 14:00	0.0	0	0	0	0	1
12/01/2020 15:00	0.0	0	0	0	0	1
12/01/2020 16:00	0.0	0	0	0	0	1
12/01/2020 17:00	0.0	0	0	0	0	1
12/01/2020 18:00	0.0	0	0	0	0	1
12/01/2020 19:00	0.0	0	0	0	0	1
12/01/2020 20:00	0.0	0	0	0	0	1
12/01/2020 21:00	0.0	0	0	0	0	1
12/01/2020 22:00	0.0	0	0	0	0	1
12/01/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2020 00:00	0.0	0	0	0	0	1
12/02/2020 01:00	0.0	0	0	0	0	1
12/02/2020 02:00	0.0	0	0	0	0	1
12/02/2020 03:00	0.0	0	0	0	0	1
12/02/2020 04:00	0.0	0	0	0	0	1
12/02/2020 05:00	0.0	0	0	0	0	1
12/02/2020 06:00	0.0	0	0	0	0	1
12/02/2020 07:00	0.0	0	0	0	0	1
12/02/2020 08:00	0.0	0	0	0	0	1
12/02/2020 09:00	0.0	0	0	0	0	1
12/02/2020 10:00	0.0	0	0	0	0	1
12/02/2020 11:00	0.0	0	0	0	0	1
12/02/2020 12:00	0.0	0	0	0	0	1
12/02/2020 13:00	0.0	0	0	0	0	1
12/02/2020 14:00	0.0	0	0	0	0	1
12/02/2020 15:00	0.0	0	0	0	0	1
12/02/2020 16:00	0.0	0	0	0	0	1
12/02/2020 17:00	0.0	0	0	0	0	1
12/02/2020 18:00	0.0	0	0	0	0	1
12/02/2020 19:00	0.0	0	0	0	0	1
12/02/2020 20:00	0.0	0	0	0	0	1
12/02/2020 21:00	0.0	0	0	0	0	1
12/02/2020 22:00	0.0	0	0	0	0	1
12/02/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2020 00:00	0.0	0	0	0	0	1
12/03/2020 01:00	0.0	0	0	0	0	1
12/03/2020 02:00	0.0	0	0	0	0	1
12/03/2020 03:00	0.0	0	0	0	0	1
12/03/2020 04:00	0.0	0	0	0	0	1
12/03/2020 05:00	0.0	0	0	0	0	1
12/03/2020 06:00	0.0	0	0	0	0	1
12/03/2020 07:00	0.0	0	0	0	0	1
12/03/2020 08:00	0.0	0	0	0	0	1
12/03/2020 09:00	0.0	0	0	0	0	1
12/03/2020 10:00	0.0	0	0	0	0	1
12/03/2020 11:00	0.0	0	0	0	0	1
12/03/2020 12:00	0.0	0	0	0	0	1
12/03/2020 13:00	0.0	0	0	0	0	1
12/03/2020 14:00	0.0	0	0	0	0	1
12/03/2020 15:00	0.0	0	0	0	0	1
12/03/2020 16:00	0.0	0	0	0	0	1
12/03/2020 17:00	0.0	0	0	0	0	1
12/03/2020 18:00	0.0	0	0	0	0	1
12/03/2020 19:00	0.0	0	0	0	0	1
12/03/2020 20:00	0.0	0	0	0	0	1
12/03/2020 21:00	0.0	0	0	0	0	1
12/03/2020 22:00	0.0	0	0	0	0	1
12/03/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2020 00:00	0.0	0	0	0	0	1
12/04/2020 01:00	0.0	0	0	0	0	1
12/04/2020 02:00	0.0	0	0	0	0	1
12/04/2020 03:00	0.0	0	0	0	0	1
12/04/2020 04:00	0.0	0	0	0	0	1
12/04/2020 05:00	0.0	0	0	0	0	1
12/04/2020 06:00	0.0	0	0	0	0	1
12/04/2020 07:00	0.0	0	0	0	0	1
12/04/2020 08:00	0.0	0	0	0	0	1
12/04/2020 09:00	0.0	0	0	0	0	1
12/04/2020 10:00	0.0	0	0	0	0	1
12/04/2020 11:00	0.0	0	0	0	0	1
12/04/2020 12:00	0.0	0	0	0	0	1
12/04/2020 13:00	0.0	0	0	0	0	1
12/04/2020 14:00	0.0	0	0	0	0	1
12/04/2020 15:00	0.0	0	0	0	0	1
12/04/2020 16:00	0.0	0	0	0	0	1
12/04/2020 17:00	0.0	0	0	0	0	1
12/04/2020 18:00	0.0	0	0	0	0	1
12/04/2020 19:00	0.0	0	0	0	0	1
12/04/2020 20:00	0.0	0	0	0	0	1
12/04/2020 21:00	0.0	0	0	0	0	1
12/04/2020 22:00	0.0	0	0	0	0	1
12/04/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2020 00:00	0.0	0	0	0	0	1
12/05/2020 01:00	0.0	0	0	0	0	1
12/05/2020 02:00	0.0	0	0	0	0	1
12/05/2020 03:00	0.0	0	0	0	0	1
12/05/2020 04:00	0.0	0	0	0	0	1
12/05/2020 05:00	0.0	0	0	0	0	1
12/05/2020 06:00	0.0	0	0	0	0	1
12/05/2020 07:00	0.0	0	0	0	0	1
12/05/2020 08:00	0.0	0	0	0	0	1
12/05/2020 09:00	0.0	0	0	0	0	1
12/05/2020 10:00	0.0	0	0	0	0	1
12/05/2020 11:00	0.0	0	0	0	0	1
12/05/2020 12:00	0.0	0	0	0	0	1
12/05/2020 13:00	0.0	0	0	0	0	1
12/05/2020 14:00	0.0	0	0	0	0	1
12/05/2020 15:00	0.0	0	0	0	0	1
12/05/2020 16:00	0.0	0	0	0	0	1
12/05/2020 17:00	0.0	0	0	0	0	1
12/05/2020 18:00	0.0	0	0	0	0	1
12/05/2020 19:00	0.0	0	0	0	0	1
12/05/2020 20:00	0.0	0	0	0	0	1
12/05/2020 21:00	0.0	0	0	0	0	1
12/05/2020 22:00	0.0	0	0	0	0	1
12/05/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2020 00:00	0.0	0	0	0	0	1
12/06/2020 01:00	0.0	0	0	0	0	1
12/06/2020 02:00	0.0	0	0	0	0	1
12/06/2020 03:00	0.0	0	0	0	0	1
12/06/2020 04:00	0.0	0	0	0	0	1
12/06/2020 05:00	0.0	0	0	0	0	1
12/06/2020 06:00	0.0	0	0	0	0	1
12/06/2020 07:00	0.0	0	0	0	0	1
12/06/2020 08:00	0.0	0	0	0	0	1
12/06/2020 09:00	0.0	0	0	0	0	1
12/06/2020 10:00	0.0	0	0	0	0	1
12/06/2020 11:00	0.0	0	0	0	0	1
12/06/2020 12:00	0.0	0	0	0	0	1
12/06/2020 13:00	0.0	0	0	0	0	1
12/06/2020 14:00	0.0	0	0	0	0	1
12/06/2020 15:00	0.0	0	0	0	0	1
12/06/2020 16:00	0.0	0	0	0	0	1
12/06/2020 17:00	0.0	0	0	0	0	1
12/06/2020 18:00	0.0	0	0	0	0	1
12/06/2020 19:00	0.0	0	0	0	0	1
12/06/2020 20:00	0.0	0	0	0	0	1
12/06/2020 21:00	0.0	0	0	0	0	1
12/06/2020 22:00	0.0	0	0	0	0	1
12/06/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2020 00:00	0.0	0	0	0	0	1
12/07/2020 01:00	0.0	0	0	0	0	1
12/07/2020 02:00	0.0	0	0	0	0	1
12/07/2020 03:00	0.0	0	0	0	0	1
12/07/2020 04:00	0.0	0	0	0	0	1
12/07/2020 05:00	0.0	0	0	0	0	1
12/07/2020 06:00	0.0	0	0	0	0	1
12/07/2020 07:00	0.0	0	0	0	0	1
12/07/2020 08:00	0.0	0	0	0	0	1
12/07/2020 09:00	0.0	0	0	0	0	1
12/07/2020 10:00	0.0	0	0	0	0	1
12/07/2020 11:00	0.0	0	0	0	0	1
12/07/2020 12:00	0.0	0	0	0	0	1
12/07/2020 13:00	0.0	0	0	0	0	1
12/07/2020 14:00	0.0	0	0	0	0	1
12/07/2020 15:00	0.0	0	0	0	0	1
12/07/2020 16:00	0.0	0	0	0	0	1
12/07/2020 17:00	0.0	0	0	0	0	1
12/07/2020 18:00	0.0	0	0	0	0	1
12/07/2020 19:00	0.0	0	0	0	0	1
12/07/2020 20:00	0.0	0	0	0	0	1
12/07/2020 21:00	0.0	0	0	0	0	1
12/07/2020 22:00	0.0	0	0	0	0	1
12/07/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2020 00:00	0.0	0	0	0	0	1
12/08/2020 01:00	0.0	0	0	0	0	1
12/08/2020 02:00	0.0	0	0	0	0	1
12/08/2020 03:00	0.0	0	0	0	0	1
12/08/2020 04:00	0.0	0	0	0	0	1
12/08/2020 05:00	0.0	0	0	0	0	1
12/08/2020 06:00	0.0	0	0	0	0	1
12/08/2020 07:00	0.0	0	0	0	0	1
12/08/2020 08:00	0.0	0	0	0	0	1
12/08/2020 09:00	0.0	0	0	0	0	1
12/08/2020 10:00	0.0	0	0	0	0	1
12/08/2020 11:00	0.0	0	0	0	0	1
12/08/2020 12:00	0.0	0	0	0	0	1
12/08/2020 13:00	0.0	0	0	0	0	1
12/08/2020 14:00	0.0	0	0	0	0	1
12/08/2020 15:00	0.0	0	0	0	0	1
12/08/2020 16:00	0.0	0	0	0	0	1
12/08/2020 17:00	0.0	0	0	0	0	1
12/08/2020 18:00	0.0	0	0	0	0	1
12/08/2020 19:00	0.0	0	0	0	0	1
12/08/2020 20:00	0.0	0	0	0	0	1
12/08/2020 21:00	0.0	0	0	0	0	1
12/08/2020 22:00	0.0	0	0	0	0	1
12/08/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2020 00:00	0.0	0	0	0	0	1
12/09/2020 01:00	0.0	0	0	0	0	1
12/09/2020 02:00	0.0	0	0	0	0	1
12/09/2020 03:00	0.0	0	0	0	0	1
12/09/2020 04:00	0.0	0	0	0	0	1
12/09/2020 05:00	0.0	0	0	0	0	1
12/09/2020 06:00	0.0	0	0	0	0	1
12/09/2020 07:00	0.0	0	0	0	0	1
12/09/2020 08:00	0.0	0	0	0	0	1
12/09/2020 09:00	0.0	0	0	0	0	1
12/09/2020 10:00	0.0	0	0	0	0	1
12/09/2020 11:00	0.0	0	0	0	0	1
12/09/2020 12:00	0.0	0	0	0	0	1
12/09/2020 13:00	0.0	0	0	0	0	1
12/09/2020 14:00	0.0	0	0	0	0	1
12/09/2020 15:00	0.0	0	0	0	0	1
12/09/2020 16:00	0.0	0	0	0	0	1
12/09/2020 17:00	0.0	0	0	0	0	1
12/09/2020 18:00	0.0	0	0	0	0	1
12/09/2020 19:00	0.0	0	0	0	0	1
12/09/2020 20:00	0.0	0	0	0	0	1
12/09/2020 21:00	0.0	0	0	0	0	1
12/09/2020 22:00	0.0	0	0	0	0	1
12/09/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2020 00:00	0.0	0	0	0	0	1
12/10/2020 01:00	0.0	0	0	0	0	1
12/10/2020 02:00	0.0	0	0	0	0	1
12/10/2020 03:00	0.0	0	0	0	0	1
12/10/2020 04:00	0.0	0	0	0	0	1
12/10/2020 05:00	0.0	0	0	0	0	1
12/10/2020 06:00	0.0	0	0	0	0	1
12/10/2020 07:00	0.0	0	0	0	0	1
12/10/2020 08:00	0.0	0	0	0	0	1
12/10/2020 09:00	0.0	0	0	0	0	1
12/10/2020 10:00	0.0	0	0	0	0	1
12/10/2020 11:00	0.0	0	0	0	0	1
12/10/2020 12:00	0.0	0	0	0	0	1
12/10/2020 13:00	0.0	0	0	0	0	1
12/10/2020 14:00	0.0	0	0	0	0	1
12/10/2020 15:00	0.0	0	0	0	0	1
12/10/2020 16:00	0.0	0	0	0	0	1
12/10/2020 17:00	0.0	0	0	0	0	1
12/10/2020 18:00	0.0	0	0	0	0	1
12/10/2020 19:00	0.0	0	0	0	0	1
12/10/2020 20:00	0.0	0	0	0	0	1
12/10/2020 21:00	0.0	0	0	0	0	1
12/10/2020 22:00	0.0	0	0	0	0	1
12/10/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2020 00:00	0.0	0	0	0	0	1
12/11/2020 01:00	0.0	0	0	0	0	1
12/11/2020 02:00	0.0	0	0	0	0	1
12/11/2020 03:00	0.0	0	0	0	0	1
12/11/2020 04:00	0.0	0	0	0	0	1
12/11/2020 05:00	0.0	0	0	0	0	1
12/11/2020 06:00	0.0	0	0	0	0	1
12/11/2020 07:00	0.0	0	0	0	0	1
12/11/2020 08:00	0.0	0	0	0	0	1
12/11/2020 09:00	0.0	0	0	0	0	1
12/11/2020 10:00	0.0	0	0	0	0	1
12/11/2020 11:00	0.0	0	0	0	0	1
12/11/2020 12:00	0.0	0	0	0	0	1
12/11/2020 13:00	0.0	0	0	0	0	1
12/11/2020 14:00	0.0	0	0	0	0	1
12/11/2020 15:00	0.0	0	0	0	0	1
12/11/2020 16:00	0.0	0	0	0	0	1
12/11/2020 17:00	0.0	0	0	0	0	1
12/11/2020 18:00	0.0	0	0	0	0	1
12/11/2020 19:00	0.0	0	0	0	0	1
12/11/2020 20:00	0.0	0	0	0	0	1
12/11/2020 21:00	0.0	0	0	0	0	1
12/11/2020 22:00	0.0	0	0	0	0	1
12/11/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2020 00:00	0.0	0	0	0	0	1
12/12/2020 01:00	0.0	0	0	0	0	1
12/12/2020 02:00	0.0	0	0	0	0	1
12/12/2020 03:00	0.0	0	0	0	0	1
12/12/2020 04:00	0.0	0	0	0	0	1
12/12/2020 05:00	0.0	0	0	0	0	1
12/12/2020 06:00	0.0	0	0	0	0	1
12/12/2020 07:00	0.0	0	0	0	0	1
12/12/2020 08:00	0.0	0	0	0	0	1
12/12/2020 09:00	0.0	0	0	0	0	1
12/12/2020 10:00	0.0	0	0	0	0	1
12/12/2020 11:00	0.0	0	0	0	0	1
12/12/2020 12:00	0.0	0	0	0	0	1
12/12/2020 13:00	0.0	0	0	0	0	1
12/12/2020 14:00	0.0	0	0	0	0	1
12/12/2020 15:00	0.0	0	0	0	0	1
12/12/2020 16:00	0.0	0	0	0	0	1
12/12/2020 17:00	0.0	0	0	0	0	1
12/12/2020 18:00	0.0	0	0	0	0	1
12/12/2020 19:00	0.0	0	0	0	0	1
12/12/2020 20:00	0.0	0	0	0	0	1
12/12/2020 21:00	0.0	0	0	0	0	1
12/12/2020 22:00	0.0	0	0	0	0	1
12/12/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2020 00:00	0.0	0	0	0	0	1
12/13/2020 01:00	0.0	0	0	0	0	1
12/13/2020 02:00	0.0	0	0	0	0	1
12/13/2020 03:00	0.0	0	0	0	0	1
12/13/2020 04:00	0.0	0	0	0	0	1
12/13/2020 05:00	0.0	0	0	0	0	1
12/13/2020 06:00	0.0	0	0	0	0	1
12/13/2020 07:00	0.0	0	0	0	0	1
12/13/2020 08:00	0.0	0	0	0	0	1
12/13/2020 09:00	0.0	0	0	0	0	1
12/13/2020 10:00	0.0	0	0	0	0	1
12/13/2020 11:00	0.0	0	0	0	0	1
12/13/2020 12:00	0.0	0	0	0	0	1
12/13/2020 13:00	0.0	0	0	0	0	1
12/13/2020 14:00	0.0	0	0	0	0	1
12/13/2020 15:00	0.0	0	0	0	0	1
12/13/2020 16:00	0.0	0	0	0	0	1
12/13/2020 17:00	0.0	0	0	0	0	1
12/13/2020 18:00	0.0	0	0	0	0	1
12/13/2020 19:00	0.0	0	0	0	0	1
12/13/2020 20:00	0.0	0	0	0	0	1
12/13/2020 21:00	0.0	0	0	0	0	1
12/13/2020 22:00	0.0	0	0	0	0	1
12/13/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2020 00:00	0.9	0	0	0	1	0
12/14/2020 01:00	0.0	0	0	0	0	0
12/14/2020 02:00	0.0	0	0	0	0	0
12/14/2020 03:00	0.0	0	0	0	0	0
12/14/2020 04:00	0.0	0	0	0	0	0
12/14/2020 05:00	0.0	0	0	0	0	0
12/14/2020 06:00	0.0	0	0	0	0	0
12/14/2020 07:00	0.0	0	0	0	0	0
12/14/2020 08:00	0.0	0	0	0	0	0
12/14/2020 09:00	0.0	0	0	0	0	0
12/14/2020 10:00	0.0	0	0	0	0	0
12/14/2020 11:00	0.0	0	0	0	0	0
12/14/2020 12:00	0.0	0	0	0	0	0
12/14/2020 13:00	0.0	0	0	0	0	0
12/14/2020 14:00	0.0	0	0	0	0	0
12/14/2020 15:00	0.0	0	0	0	0	0
12/14/2020 16:00	0.0	0	0	0	0	0
12/14/2020 17:00	0.0	0	0	0	0	0
12/14/2020 18:00	0.0	0	0	0	0	0
12/14/2020 19:00	0.0	0	0	0	0	0
12/14/2020 20:00	0.0	0	0	0	0	0
12/14/2020 21:00	0.0	0	0	0	0	0
12/14/2020 22:00	0.0	0	0	0	0	0
12/14/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2020 00:00	0.0	0	0	0	0	0
12/15/2020 01:00	0.0	0	0	0	0	0
12/15/2020 02:00	0.0	0	0	0	0	0
12/15/2020 03:00	0.0	0	0	0	0	0
12/15/2020 04:00	0.0	0	0	0	0	0
12/15/2020 05:00	0.0	0	0	0	0	0
12/15/2020 06:00	0.0	0	0	0	0	0
12/15/2020 07:00	0.0	0	0	0	0	0
12/15/2020 08:00	0.0	0	0	0	0	0
12/15/2020 09:00	0.0	0	0	0	0	0
12/15/2020 10:00	0.0	0	0	0	0	0
12/15/2020 11:00	0.0	0	0	0	0	0
12/15/2020 12:00	0.0	0	0	0	0	0
12/15/2020 13:00	0.0	0	0	0	0	0
12/15/2020 14:00	0.0	0	0	0	0	0
12/15/2020 15:00	0.0	0	0	0	0	0
12/15/2020 16:00	0.0	0	0	0	0	0
12/15/2020 17:00	0.0	0	0	0	0	0
12/15/2020 18:00	0.0	0	0	0	0	0
12/15/2020 19:00	0.0	0	0	0	0	0
12/15/2020 20:00	0.0	0	0	0	0	0
12/15/2020 21:00	0.0	0	0	0	0	0
12/15/2020 22:00	0.0	0	0	0	0	0
12/15/2020 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2020 00:00	0.0	0	0	0	0	0
12/16/2020 01:00	0.0	0	0	0	0	0
12/16/2020 02:00	0.0	0	0	0	0	0
12/16/2020 03:00	0.0	0	0	0	0	0
12/16/2020 04:00	0.0	0	0	0	0	0
12/16/2020 05:00	0.0	0	0	0	0	0
12/16/2020 06:00	0.0	0	0	0	0	0
12/16/2020 07:00	0.0	0	0	0	0	0
12/16/2020 08:00	0.0	0	0	0	0	0
12/16/2020 09:00	0.0	0	0	0	0	0
12/16/2020 10:00	0.0	0	0	0	0	0
12/16/2020 11:00	0.0	0	0	0	0	0
12/16/2020 12:00	0.0	0	0	0	0	0
12/16/2020 13:00	0.0	0	0	0	0	0
12/16/2020 14:00	0.0	0	0	0	0	0
12/16/2020 15:00	56.3	0	1	0	0	0
12/16/2020 16:00	76.1	0	1	0	0	0
12/16/2020 17:00	0.0	0	0	0	0	1
12/16/2020 18:00	0.0	0	0	0	0	1
12/16/2020 19:00	0.0	0	0	0	0	1
12/16/2020 20:00	0.0	0	0	0	0	1
12/16/2020 21:00	0.0	0	0	0	0	1
12/16/2020 22:00	0.0	0	0	0	0	1
12/16/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	132.4 #	0 #	2 #	0 #	0 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	76.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2020 00:00	0.0	0	0	0	0	1
12/17/2020 01:00	0.0	0	0	0	0	1
12/17/2020 02:00	0.0	0	0	0	0	1
12/17/2020 03:00	0.0	0	0	0	0	1
12/17/2020 04:00	0.0	0	0	0	0	1
12/17/2020 05:00	0.0	0	0	0	0	1
12/17/2020 06:00	0.0	0	0	0	0	1
12/17/2020 07:00	0.0	0	0	0	0	1
12/17/2020 08:00	0.0	0	0	0	0	1
12/17/2020 09:00	0.0	0	0	0	0	1
12/17/2020 10:00	0.0	0	0	0	0	1
12/17/2020 11:00	0.0	0	0	0	0	1
12/17/2020 12:00	0.0	0	0	0	0	1
12/17/2020 13:00	0.0	0	0	0	0	1
12/17/2020 14:00	0.0	0	0	0	0	1
12/17/2020 15:00	0.0	0	0	0	0	1
12/17/2020 16:00	0.0	0	0	0	0	1
12/17/2020 17:00	0.0	0	0	0	0	1
12/17/2020 18:00	0.0	0	0	0	0	1
12/17/2020 19:00	0.0	0	0	0	0	1
12/17/2020 20:00	0.0	0	0	0	0	1
12/17/2020 21:00	0.0	0	0	0	0	1
12/17/2020 22:00	0.0	0	0	0	0	1
12/17/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2020 00:00	0.0	0	0	0	0	1
12/18/2020 01:00	0.0	0	0	0	0	1
12/18/2020 02:00	0.0	0	0	0	0	1
12/18/2020 03:00	0.0	0	0	0	0	1
12/18/2020 04:00	0.0	0	0	0	0	1
12/18/2020 05:00	0.0	0	0	0	0	1
12/18/2020 06:00	0.0	0	0	0	0	1
12/18/2020 07:00	0.0	0	0	0	0	1
12/18/2020 08:00	0.0	0	0	0	0	1
12/18/2020 09:00	0.0	0	0	0	0	1
12/18/2020 10:00	0.0	0	0	0	0	1
12/18/2020 11:00	0.0	0	0	0	0	1
12/18/2020 12:00	0.0	0	0	0	0	1
12/18/2020 13:00	0.0	0	0	0	0	1
12/18/2020 14:00	0.0	0	0	0	0	1
12/18/2020 15:00	0.0	0	0	0	0	1
12/18/2020 16:00	0.0	0	0	0	0	1
12/18/2020 17:00	0.0	0	0	0	0	1
12/18/2020 18:00	0.0	0	0	0	0	1
12/18/2020 19:00	0.0	0	0	0	0	1
12/18/2020 20:00	0.0	0	0	0	0	1
12/18/2020 21:00	0.0	0	0	0	0	1
12/18/2020 22:00	0.0	0	0	0	0	1
12/18/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2020 00:00	0.0	0	0	0	0	1
12/19/2020 01:00	0.0	0	0	0	0	1
12/19/2020 02:00	0.0	0	0	0	0	1
12/19/2020 03:00	0.0	0	0	0	0	1
12/19/2020 04:00	0.0	0	0	0	0	1
12/19/2020 05:00	0.0	0	0	0	0	1
12/19/2020 06:00	0.0	0	0	0	0	1
12/19/2020 07:00	0.0	0	0	0	0	1
12/19/2020 08:00	0.0	0	0	0	0	1
12/19/2020 09:00	0.0	0	0	0	0	1
12/19/2020 10:00	0.0	0	0	0	0	1
12/19/2020 11:00	0.0	0	0	0	0	1
12/19/2020 12:00	0.0	0	0	0	0	1
12/19/2020 13:00	0.0	0	0	0	0	1
12/19/2020 14:00	0.0	0	0	0	0	1
12/19/2020 15:00	0.0	0	0	0	0	1
12/19/2020 16:00	0.0	0	0	0	0	1
12/19/2020 17:00	0.0	0	0	0	0	1
12/19/2020 18:00	0.0	0	0	0	0	1
12/19/2020 19:00	0.0	0	0	0	0	1
12/19/2020 20:00	0.0	0	0	0	0	1
12/19/2020 21:00	0.0	0	0	0	0	1
12/19/2020 22:00	0.0	0	0	0	0	1
12/19/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2020 00:00	0.0	0	0	0	0	1
12/20/2020 01:00	0.0	0	0	0	0	1
12/20/2020 02:00	0.0	0	0	0	0	1
12/20/2020 03:00	0.0	0	0	0	0	1
12/20/2020 04:00	0.0	0	0	0	0	1
12/20/2020 05:00	0.0	0	0	0	0	1
12/20/2020 06:00	0.0	0	0	0	0	1
12/20/2020 07:00	0.0	0	0	0	0	1
12/20/2020 08:00	0.0	0	0	0	0	1
12/20/2020 09:00	0.0	0	0	0	0	1
12/20/2020 10:00	0.0	0	0	0	0	1
12/20/2020 11:00	0.0	0	0	0	0	1
12/20/2020 12:00	0.0	0	0	0	0	1
12/20/2020 13:00	0.0	0	0	0	0	1
12/20/2020 14:00	0.0	0	0	0	0	1
12/20/2020 15:00	0.0	0	0	0	0	1
12/20/2020 16:00	0.0	0	0	0	0	1
12/20/2020 17:00	0.0	0	0	0	0	1
12/20/2020 18:00	0.0	0	0	0	0	1
12/20/2020 19:00	0.0	0	0	0	0	1
12/20/2020 20:00	0.0	0	0	0	0	1
12/20/2020 21:00	0.0	0	0	0	0	1
12/20/2020 22:00	0.0	0	0	0	0	1
12/20/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2020 00:00	0.0	0	0	0	0	1
12/21/2020 01:00	0.0	0	0	0	0	1
12/21/2020 02:00	0.0	0	0	0	0	1
12/21/2020 03:00	0.0	0	0	0	0	1
12/21/2020 04:00	0.0	0	0	0	0	1
12/21/2020 05:00	0.0	0	0	0	0	1
12/21/2020 06:00	0.0	0	0	0	0	1
12/21/2020 07:00	0.0	0	0	0	0	1
12/21/2020 08:00	0.0	0	0	0	0	1
12/21/2020 09:00	0.0	0	0	0	0	1
12/21/2020 10:00	0.0	0	0	0	0	1
12/21/2020 11:00	0.0	0	0	0	0	1
12/21/2020 12:00	0.0	0	0	0	0	1
12/21/2020 13:00	0.0	0	0	0	0	1
12/21/2020 14:00	0.0	0	0	0	0	1
12/21/2020 15:00	0.0	0	0	0	0	1
12/21/2020 16:00	0.0	0	0	0	0	1
12/21/2020 17:00	0.0	0	0	0	0	1
12/21/2020 18:00	0.0	0	0	0	0	1
12/21/2020 19:00	0.0	0	0	0	0	1
12/21/2020 20:00	0.0	0	0	0	0	1
12/21/2020 21:00	0.0	0	0	0	0	1
12/21/2020 22:00	0.0	0	0	0	0	1
12/21/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2020 00:00	0.0	0	0	0	0	1
12/22/2020 01:00	0.0	0	0	0	0	1
12/22/2020 02:00	0.0	0	0	0	0	1
12/22/2020 03:00	0.0	0	0	0	0	1
12/22/2020 04:00	0.0	0	0	0	0	1
12/22/2020 05:00	0.0	0	0	0	0	1
12/22/2020 06:00	0.0	0	0	0	0	1
12/22/2020 07:00	0.0	0	0	0	0	1
12/22/2020 08:00	0.0	0	0	0	0	1
12/22/2020 09:00	0.0	0	0	0	0	1
12/22/2020 10:00	0.0	0	0	0	0	1
12/22/2020 11:00	0.0	0	0	0	0	1
12/22/2020 12:00	0.0	0	0	0	0	1
12/22/2020 13:00	0.0	0	0	0	0	1
12/22/2020 14:00	0.0	0	0	0	0	1
12/22/2020 15:00	0.0	0	0	0	0	1
12/22/2020 16:00	0.0	0	0	0	0	1
12/22/2020 17:00	0.0	0	0	0	0	1
12/22/2020 18:00	0.0	0	0	0	0	1
12/22/2020 19:00	0.0	0	0	0	0	1
12/22/2020 20:00	0.0	0	0	0	0	1
12/22/2020 21:00	0.0	0	0	0	0	1
12/22/2020 22:00	0.0	0	0	0	0	1
12/22/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2020 00:00	0.0	0	0	0	0	1
12/23/2020 01:00	0.0	0	0	0	0	1
12/23/2020 02:00	0.0	0	0	0	0	1
12/23/2020 03:00	0.0	0	0	0	0	1
12/23/2020 04:00	0.0	0	0	0	0	1
12/23/2020 05:00	0.0	0	0	0	0	1
12/23/2020 06:00	0.0	0	0	0	0	1
12/23/2020 07:00	0.0	0	0	0	0	1
12/23/2020 08:00	0.0	0	0	0	0	1
12/23/2020 09:00	0.0	0	0	0	0	1
12/23/2020 10:00	0.0	0	0	0	0	1
12/23/2020 11:00	0.0	0	0	0	0	1
12/23/2020 12:00	0.0	0	0	0	0	1
12/23/2020 13:00	0.0	0	0	0	0	1
12/23/2020 14:00	0.0	0	0	0	0	1
12/23/2020 15:00	0.0	0	0	0	0	1
12/23/2020 16:00	0.0	0	0	0	0	1
12/23/2020 17:00	0.0	0	0	0	0	1
12/23/2020 18:00	0.0	0	0	0	0	1
12/23/2020 19:00	0.0	0	0	0	0	1
12/23/2020 20:00	0.0	0	0	0	0	1
12/23/2020 21:00	0.0	0	0	0	0	1
12/23/2020 22:00	0.0	0	0	0	0	1
12/23/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2020 00:00	0.0	0	0	0	0	1
12/24/2020 01:00	0.0	0	0	0	0	1
12/24/2020 02:00	0.0	0	0	0	0	1
12/24/2020 03:00	0.0	0	0	0	0	1
12/24/2020 04:00	0.0	0	0	0	0	1
12/24/2020 05:00	0.0	0	0	0	0	1
12/24/2020 06:00	0.0	0	0	0	0	1
12/24/2020 07:00	0.0	0	0	0	0	1
12/24/2020 08:00	0.0	0	0	0	0	1
12/24/2020 09:00	0.0	0	0	0	0	1
12/24/2020 10:00	0.0	0	0	0	0	1
12/24/2020 11:00	0.0	0	0	0	0	1
12/24/2020 12:00	0.0	0	0	0	0	1
12/24/2020 13:00	0.0	0	0	0	0	1
12/24/2020 14:00	0.0	0	0	0	0	1
12/24/2020 15:00	0.0	0	0	0	0	1
12/24/2020 16:00	0.0	0	0	0	0	1
12/24/2020 17:00	0.0	0	0	0	0	1
12/24/2020 18:00	0.0	0	0	0	0	1
12/24/2020 19:00	0.0	0	0	0	0	1
12/24/2020 20:00	0.0	0	0	0	0	1
12/24/2020 21:00	0.0	0	0	0	0	1
12/24/2020 22:00	0.0	0	0	0	0	1
12/24/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2020 00:00	0.0	0	0	0	0	1
12/25/2020 01:00	0.0	0	0	0	0	1
12/25/2020 02:00	0.0	0	0	0	0	1
12/25/2020 03:00	0.0	0	0	0	0	1
12/25/2020 04:00	0.0	0	0	0	0	1
12/25/2020 05:00	0.0	0	0	0	0	1
12/25/2020 06:00	0.0	0	0	0	0	1
12/25/2020 07:00	0.0	0	0	0	0	1
12/25/2020 08:00	0.0	0	0	0	0	1
12/25/2020 09:00	0.0	0	0	0	0	1
12/25/2020 10:00	0.0	0	0	0	0	1
12/25/2020 11:00	0.0	0	0	0	0	1
12/25/2020 12:00	0.0	0	0	0	0	1
12/25/2020 13:00	0.0	0	0	0	0	1
12/25/2020 14:00	0.0	0	0	0	0	1
12/25/2020 15:00	0.0	0	0	0	0	1
12/25/2020 16:00	0.0	0	0	0	0	1
12/25/2020 17:00	0.0	0	0	0	0	1
12/25/2020 18:00	0.0	0	0	0	0	1
12/25/2020 19:00	0.0	0	0	0	0	1
12/25/2020 20:00	0.0	0	0	0	0	1
12/25/2020 21:00	0.0	0	0	0	0	1
12/25/2020 22:00	0.0	0	0	0	0	1
12/25/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2020 00:00	0.0	0	0	0	0	1
12/26/2020 01:00	0.0	0	0	0	0	1
12/26/2020 02:00	0.0	0	0	0	0	1
12/26/2020 03:00	0.0	0	0	0	0	1
12/26/2020 04:00	0.0	0	0	0	0	1
12/26/2020 05:00	0.0	0	0	0	0	1
12/26/2020 06:00	0.0	0	0	0	0	1
12/26/2020 07:00	0.0	0	0	0	0	1
12/26/2020 08:00	0.0	0	0	0	0	1
12/26/2020 09:00	0.0	0	0	0	0	1
12/26/2020 10:00	0.0	0	0	0	0	1
12/26/2020 11:00	0.0	0	0	0	0	1
12/26/2020 12:00	0.0	0	0	0	0	1
12/26/2020 13:00	0.0	0	0	0	0	1
12/26/2020 14:00	0.0	0	0	0	0	1
12/26/2020 15:00	0.0	0	0	0	0	1
12/26/2020 16:00	0.0	0	0	0	0	1
12/26/2020 17:00	0.0	0	0	0	0	1
12/26/2020 18:00	0.0	0	0	0	0	1
12/26/2020 19:00	0.0	0	0	0	0	1
12/26/2020 20:00	0.0	0	0	0	0	1
12/26/2020 21:00	0.0	0	0	0	0	1
12/26/2020 22:00	0.0	0	0	0	0	1
12/26/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2020 00:00	0.0	0	0	0	0	1
12/27/2020 01:00	0.0	0	0	0	0	1
12/27/2020 02:00	0.0	0	0	0	0	1
12/27/2020 03:00	0.0	0	0	0	0	1
12/27/2020 04:00	0.0	0	0	0	0	1
12/27/2020 05:00	0.0	0	0	0	0	1
12/27/2020 06:00	0.0	0	0	0	0	1
12/27/2020 07:00	0.0	0	0	0	0	1
12/27/2020 08:00	0.0	0	0	0	0	1
12/27/2020 09:00	0.0	0	0	0	0	1
12/27/2020 10:00	0.0	0	0	0	0	1
12/27/2020 11:00	0.0	0	0	0	0	1
12/27/2020 12:00	0.0	0	0	0	0	1
12/27/2020 13:00	0.0	0	0	0	0	1
12/27/2020 14:00	0.0	0	0	0	0	1
12/27/2020 15:00	0.0	0	0	0	0	1
12/27/2020 16:00	0.0	0	0	0	0	1
12/27/2020 17:00	0.0	0	0	0	0	1
12/27/2020 18:00	0.0	0	0	0	0	1
12/27/2020 19:00	0.0	0	0	0	0	1
12/27/2020 20:00	0.0	0	0	0	0	1
12/27/2020 21:00	0.0	0	0	0	0	1
12/27/2020 22:00	0.0	0	0	0	0	1
12/27/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2020 00:00	0.0	0	0	0	0	1
12/28/2020 01:00	0.0	0	0	0	0	1
12/28/2020 02:00	0.0	0	0	0	0	1
12/28/2020 03:00	0.0	0	0	0	0	1
12/28/2020 04:00	0.0	0	0	0	0	1
12/28/2020 05:00	0.0	0	0	0	0	1
12/28/2020 06:00	0.0	0	0	0	0	1
12/28/2020 07:00	0.0	0	0	0	0	1
12/28/2020 08:00	0.0	0	0	0	0	1
12/28/2020 09:00	0.0	0	0	0	0	1
12/28/2020 10:00	0.0	0	0	0	0	1
12/28/2020 11:00	0.0	0	0	0	0	1
12/28/2020 12:00	0.0	0	0	0	0	1
12/28/2020 13:00	0.0	0	0	0	0	1
12/28/2020 14:00	0.0	0	0	0	0	1
12/28/2020 15:00	0.0	0	0	0	0	1
12/28/2020 16:00	0.0	0	0	0	0	1
12/28/2020 17:00	0.0	0	0	0	0	1
12/28/2020 18:00	0.0	0	0	0	0	1
12/28/2020 19:00	0.0	0	0	0	0	1
12/28/2020 20:00	0.0	0	0	0	0	1
12/28/2020 21:00	0.0	0	0	0	0	1
12/28/2020 22:00	0.0	0	0	0	0	1
12/28/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2020 00:00	0.0	0	0	0	0	1
12/29/2020 01:00	0.0	0	0	0	0	1
12/29/2020 02:00	0.0	0	0	0	0	1
12/29/2020 03:00	0.0	0	0	0	0	1
12/29/2020 04:00	0.0	0	0	0	0	1
12/29/2020 05:00	0.0	0	0	0	0	1
12/29/2020 06:00	0.0	0	0	0	0	1
12/29/2020 07:00	0.0	0	0	0	0	1
12/29/2020 08:00	0.0	0	0	0	0	1
12/29/2020 09:00	0.0	0	0	0	0	1
12/29/2020 10:00	0.0	0	0	0	0	1
12/29/2020 11:00	0.0	0	0	0	0	1
12/29/2020 12:00	0.0	0	0	0	0	1
12/29/2020 13:00	0.0	0	0	0	0	1
12/29/2020 14:00	0.0	0	0	0	0	1
12/29/2020 15:00	0.0	0	0	0	0	1
12/29/2020 16:00	0.0	0	0	0	0	1
12/29/2020 17:00	0.0	0	0	0	0	1
12/29/2020 18:00	0.0	0	0	0	0	1
12/29/2020 19:00	0.0	0	0	0	0	1
12/29/2020 20:00	0.0	0	0	0	0	1
12/29/2020 21:00	0.0	0	0	0	0	1
12/29/2020 22:00	0.0	0	0	0	0	1
12/29/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2020 00:00	0.0	0	0	0	0	1
12/30/2020 01:00	0.0	0	0	0	0	1
12/30/2020 02:00	0.0	0	0	0	0	1
12/30/2020 03:00	0.0	0	0	0	0	1
12/30/2020 04:00	0.0	0	0	0	0	1
12/30/2020 05:00	0.0	0	0	0	0	1
12/30/2020 06:00	0.0	0	0	0	0	1
12/30/2020 07:00	0.0	0	0	0	0	1
12/30/2020 08:00	0.0	0	0	0	0	1
12/30/2020 09:00	0.0	0	0	0	0	1
12/30/2020 10:00	0.0	0	0	0	0	1
12/30/2020 11:00	0.0	0	0	0	0	1
12/30/2020 12:00	0.0	0	0	0	0	1
12/30/2020 13:00	0.0	0	0	0	0	1
12/30/2020 14:00	0.0	0	0	0	0	1
12/30/2020 15:00	0.0	0	0	0	0	1
12/30/2020 16:00	0.0	0	0	0	0	1
12/30/2020 17:00	0.0	0	0	0	0	1
12/30/2020 18:00	0.0	0	0	0	0	1
12/30/2020 19:00	0.0	0	0	0	0	1
12/30/2020 20:00	0.0	0	0	0	0	1
12/30/2020 21:00	0.0	0	0	0	0	1
12/30/2020 22:00	0.0	0	0	0	0	1
12/30/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:00 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2020 00:00	0.0	0	0	0	0	1
12/31/2020 01:00	0.0	0	0	0	0	1
12/31/2020 02:00	0.0	0	0	0	0	1
12/31/2020 03:00	0.0	0	0	0	0	1
12/31/2020 04:00	0.0	0	0	0	0	1
12/31/2020 05:00	0.0	0	0	0	0	1
12/31/2020 06:00	0.0	0	0	0	0	1
12/31/2020 07:00	0.0	0	0	0	0	1
12/31/2020 08:00	0.0	0	0	0	0	1
12/31/2020 09:00	0.0	0	0	0	0	1
12/31/2020 10:00	0.0	0	0	0	0	1
12/31/2020 11:00	0.0	0	0	0	0	1
12/31/2020 12:00	0.0	0	0	0	0	1
12/31/2020 13:00	0.0	0	0	0	0	1
12/31/2020 14:00	0.0	0	0	0	0	1
12/31/2020 15:00	0.0	0	0	0	0	1
12/31/2020 16:00	0.0	0	0	0	0	1
12/31/2020 17:00	0.0	0	0	0	0	1
12/31/2020 18:00	0.0	0	0	0	0	1
12/31/2020 19:00	0.0	0	0	0	0	1
12/31/2020 20:00	0.0	0	0	0	0	1
12/31/2020 21:00	0.0	0	0	0	0	1
12/31/2020 22:00	0.0	0	0	0	0	1
12/31/2020 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Hr Per Event Report

CT2 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:05 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	1.0	483.5		
10/03/2020 12:25 10/03/2020 13:33 Warm Start - Gas	69	31.2	373.6		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	0.9	483.5		
10/04/2020 13:08 10/04/2020 14:13 Warm Start - Gas	66	38.7	373.6		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	0.9	483.5		
10/06/2020 11:16 10/06/2020 12:20 Warm Start - Gas	65	26.0	373.6		
10/07/2020 23:24 10/07/2020 23:29 Shut Down - Gas	6	0.4	483.5		
10/11/2020 01:18 10/11/2020 04:52 Cold Start - Gas	215	259.6	429.6		
11/14/2020 00:19 11/14/2020 00:24 Shut Down - Gas	6	1.1	483.5		
11/14/2020 05:29 11/14/2020 06:46 Hot Start - Gas	78	43.2	370.3		
11/23/2020 02:49 11/23/2020 02:54 Shut Down - Gas	6	0.9	483.5		
11/23/2020 05:18 11/23/2020 06:27 Hot Start - Gas	70	39.5	370.3		
11/25/2020 23:24 11/25/2020 23:29 Shut Down - Gas	6	0.8	483.5		

Pound Per Hr Per Event Report

CT2 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:05 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
11/27/2020 04:05 11/27/2020 05:35 Warm Start - Gas	91	91.2	373.6		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	1.0	483.5		
12/14/2020 05:21 12/14/2020 06:22 Hot Start - Gas	62	37.0	370.3		

No excess emissions were found in the reporting period.

Pound Per Hr Per Event Report

CT2 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:05 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Hr Per Event Report

CT2 - CO LbPerHr

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:05 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/03/2020 00:24 10/03/2020 00:29 Shut Down - Gas	6	0.68	115.00		
10/03/2020 12:25 10/03/2020 13:33 Warm Start - Gas	69	79.97	456.20		
10/03/2020 22:39 10/03/2020 22:44 Shut Down - Gas	6	0.40	115.00		
10/04/2020 13:08 10/04/2020 14:13 Warm Start - Gas	66	89.66	456.20		
10/05/2020 22:24 10/05/2020 22:29 Shut Down - Gas	6	0.50	115.00		
10/06/2020 11:16 10/06/2020 12:20 Warm Start - Gas	65	90.03	456.20		
10/07/2020 23:24 10/07/2020 23:29 Shut Down - Gas	6	0.36	115.00		
10/11/2020 01:18 10/11/2020 04:52 Cold Start - Gas	215	236.69	779.10		
11/14/2020 00:19 11/14/2020 00:24 Shut Down - Gas	6	0.44	115.00		
11/14/2020 05:29 11/14/2020 06:46 Hot Start - Gas	78	48.18	259.90		
11/23/2020 02:49 11/23/2020 02:54 Shut Down - Gas	6	0.36	115.00		
11/23/2020 05:18 11/23/2020 06:27 Hot Start - Gas	70	36.54	259.90		
11/25/2020 23:24 11/25/2020 23:29 Shut Down - Gas	6	0.53	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/27/2020 04:05 11/27/2020 05:35 Warm Start - Gas	91	123.86	456.20		
12/14/2020 00:10 12/14/2020 00:15 Shut Down - Gas	6	0.64	115.00		
12/14/2020 05:21 12/14/2020 06:22 Hot Start - Gas	62	49.67	259.90		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/05/2021 11:01 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.98 Hours

Non-Operating Time: 154.02 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:02 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/03/2020 01:00	10/03/2020 07:00	7
10/03/2020 23:00	10/04/2020 08:00	10
10/05/2020 23:00	10/06/2020 05:00	7
10/08/2020 00:00	10/12/2020 11:00	108
10/18/2020 19:00	10/18/2020 20:00	2
11/26/2020 00:00	11/26/2020 22:00	23
12/14/2020 01:00	12/16/2020 14:00	62

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:02 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	219.00 Hour(s)
Offline Percentage:	9.92 %
Total Online:	1,989.00 Hour(s)
Online Percentage:	90.08 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:02 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/03/2020 08:00	10/03/2020 09:00	Warm Startup	2
2	10/04/2020 09:00	10/04/2020 10:00	Warm Startup	2
3	10/06/2020 06:00	10/06/2020 07:00	Warm Startup	2
4	10/12/2020 12:00	10/12/2020 14:00	Cold Startup	3
5	10/18/2020 21:00	10/18/2020 22:00	Hot Startup	2
6	11/26/2020 23:00	11/27/2020 01:00	Warm Startup	3
7	12/16/2020 15:00	12/16/2020 16:00	Warm Startup	2

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:02 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	3	0.15
Hot Startup/Startup Shutdown Event Text 02 Add	1	2	0.10
Warm Startup	5	11	0.55
Total Process Events:	7	16	0.8

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,989 Hour(s)
Total Startup Time:	16 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	16 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.80 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:03 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/03/2020 01:00	10/03/2020 11:00	11
10/03/2020 23:00	10/04/2020 12:00	14
10/05/2020 23:00	10/06/2020 10:00	12
10/08/2020 00:00	10/11/2020 00:00	73
11/14/2020 01:00	11/14/2020 04:00	4
11/23/2020 03:00	11/23/2020 04:00	2
11/26/2020 00:00	11/27/2020 03:00	28
12/14/2020 01:00	12/14/2020 04:00	4

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:03 **Location:** Maxwell, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	148.00 Hour(s)
Offline Percentage:	6.70 %
Total Online:	2,060.00 Hour(s)
Online Percentage:	93.30 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:03 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/03/2020 12:00	10/03/2020 13:00	Warm startup	2
2	10/04/2020 13:00	10/04/2020 14:00	Warm startup	2
3	10/06/2020 11:00	10/06/2020 12:00	Warm startup	2
4	10/11/2020 01:00	10/11/2020 04:00	Cold Startup	4
5	11/14/2020 05:00	11/14/2020 06:00	Hot Startup	2
6	11/23/2020 05:00	11/23/2020 06:00	Hot Startup	2
7	11/27/2020 04:00	11/27/2020 05:00	Warm startup	2
8	12/14/2020 05:00	12/14/2020 06:00	Hot Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/05/2021 11:03 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	1	4	0.19
Hot Startup	3	6	0.29
Warm startup	4	8	0.39
Total Process Events:	8	18	0.87

Total Report Time:	2,208 Hour(s)
Total Operating Time:	2,060 Hour(s)
Total Startup Time:	18 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	18 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.87 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater
did not operate in the 4th Quarter of 2020.