

DOCKETED	
Docket Number:	07-AFC-09C
Project Title:	Canyon Power Plant - Compliance
TN #:	236727
Document Title:	Canyon Power Plant Compliance Annual Report 2020
Description:	Annual Compliance Report
Filer:	Bertha A Hernandez
Organization:	City of Anaheim
Submitter Role:	Public Agency
Submission Date:	2/10/2021 1:41:25 PM
Docketed Date:	2/10/2021

Annual Compliance Report

**City of Anaheim
Canyon Power Plant**

Anaheim, California

**SCAQMD
Facility ID: 153992**

**CEC Permit Number:
800-2010-001-CMF**

**Docket Number:
07-AFC-9C**

2020

Period Range

January 1, 2020 through December 31, 2020

Review and Certification

I have reviewed both technically and editorially all details, calculations, results conclusions and other appropriate written material contained herein and hereby certify that to the best of my knowledge the material presented is true, accurate and complete.

I certify that the information contained in this report is true, accurate, and complete.

Ronald Hoffard

Name



Signature

Generation Plant Manager

Title

2/08/2021

Date

Canyon Power Plant
Annual Compliance Report
Table of Contents

Acronyms and Abbreviations

Facility Description

List of Attachments

Compliance Matrix.....	Attachment	1
Facility Operational Status.....	Attachment	2
CEC Approved Post Certification Changes	Attachment	3
Missed Submittal Deadlines.....	Attachment	4
Permit Filings and Permits Issued 2016 Year	Attachment	5
Projected Compliance Testing in 2017 Year	Attachment	6
Additions to On-Site Compliance File	Attachment	7
Evaluation of the “Un-Planned” Facility Closure Plan	Attachment	8
NOV’s Issued 2016 Year	Attachment	9
Condition HAZ-1.....	Attachment	10
Condition HAZ-8.....	Attachment	11
Soil & Water Use Report-7.....	Attachment	12
Soil & Water Use Report-8.....	Attachment	13
Surface Treatment of Project Structures & Buildings (VIS-4).....	Attachment	14
Landscape Screening (VIS-5)	Attachment	15
AQ-9 NH3 Slip Testing AQ-9.....	Attachment	16
AQ-14 & AQ-24 RTC Inventory	Attachment	17
AQ-17 NH3 Flow Meter Accuracy Reports	Attachment	18
AQ-18 SCR Inlet Temperature Sensor Calibration Reports.....	Attachment	19

AQ-19 SCR Differential Pressure Sensor Calibration Report	Attachment	20
WASTE-10 Cooling Tower Sludge Testing	Attachment	21

Acronyms and Abbreviations

BHP	Break horse power
Btu	British thermal unit
BACT	Best available control technology
CARB	California Air Resources Board
CFR	Code of Federal Regulations
CO	Carbon Monoxide
CO ₂	Carbon Dioxide
COA	City of Anaheim
CFR	Code of Federal Regulations
CPP	Canyon Power Plant
CT	Combustion turbine
DAHS	Data acquisition and handling
TDS	Total dissolved solids
DPF	Diesel particulate filter
EPA	Environmental Protection Agency
F.	Fahrenheit
ICE	Internal combustion engine
lbs/hr	pounds per hour
lb/lb-mol	pound per pound mol
MW	mega watts
MMBtu	million British thermal units
mmcf	million cubic feet
NH ₃	ammonia
NO	Nitrogen Oxide
NO _x	Oxides of Nitrogen
NO ₂	Nitrogen Dioxide
O ₂	Oxygen
ppm	parts per million
ppmc	parts per million corrected to 15% O ₂
RATA	relative accuracy test audit
ROG	Reactive Organic Compounds
RTU	remote terminal unit
scf	standard cubic feet (standard temperature = 68 degrees F)
SCR	selective catalytic reactor
SCAQMD	South Coast Air Quality Management District
unit	The term unit refers to the boiler/steam turbine
VOC	Volatile Organic Compounds

1.0 Facility Description:

The City of Anaheim's (COA) Canyon Power Plant (CPP) facility is located at 3071 Miraloma Avenue in Anaheim California.

The facility consists of four natural gas fired General Electric, Model LM6000PC Sprint, simple cycle combustion turbine with water injection. The gas turbine was designed with a maximum heat input of 479 MMBtu per hour with a 46 degree Fahrenheit (F.) inlet air temperature. The units are equipped with an inlet air chiller designed to maintain the gas turbine inlet temperature at 46 degrees F. at full load.

Each unit is capable of generating 50.95 megawatts.

Carbon Monoxide (CO) emission from the gas turbine are controlled by utilizing a CO oxidation catalyst located between the gas turbine and the selective catalytic reactor (SCR). The CO oxidation catalyst controls the unit's CO and volatile organic compounds (VOC) emissions. The catalyst is guaranteed to reduce the unit's CO emission rate to a maximum of 4 ppm corrected to 15% O₂ (ppmc) and the VOC to 2 ppmc, both emission rates are based on a one (1) hour averages, dry basis at 15% O₂. The CO catalyst system was designed and supplied by Englehard/BASF.

The NO_x emissions from the gas turbine are controlled by the utilizing two (2) independent systems or techniques in series. The first system utilized on this unit is the water injection system.

Water is injected into the combustor suppressing the flame temperature and reducing the 1-hour average NO_x concentration to approximately 25 ppmc at 15% oxygen prior to entry into the SCR.

The second NO_x control system utilized by the unit is the NH₃/SCR system. After passing through the CO catalyst, the exhaust gases pass through an ammonia injection grid on its way to the SCR. The ammonia (NH₃) used at this facility is in the form a 19% by weight solution of ammonium hydroxide.

The SCR catalyst utilized by the unit for NO_x control was provided by Cormetech. The reaction between the NH₃ and the SCR catalyst reduces the existing NO_x to elemental nitrogen and water, resulting in NO_x concentrations in the exhaust gas at no greater than 2.5 ppmv at 15% O₂ on a 1-hour average. The ammonia slip must be maintained below 5 ppm at 15% O₂. Each SCR is vented through a dedicated stack, which is 11.8 ft diameter and 86 ft high.

The facility is also equipped with an 1141 BHP diesel emergency internal combustion engine (ICE) (black start engine) will be used to start up the plant in the event of a loss of grid power.

The ICE, is a Caterpillar, Model C-27, rated at 1141 BHP and fired on ultra low sulfur diesel fuel. The ICE, will serve to provide power to the plant during blackout conditions. The engine is certified by the SCAQMD as an EPA Tier 2 engine on 12/31/2010. The engine is required to be permitted, rather than registered, because CPP is a RECLAIM/Title V facility.

The black start engine will be used only in emergency situations where grid power from the COA's 69 kV system is unavailable to start the CTs. The black start engine will provide power to the turbine starter motors and various other necessary pieces of support equipment to get one of the gas turbines started. Once one of the turbines has been started and providing power to the

grid, the black start engine will be shut down.

The SCAQMD's rules limit operation of an emergency ICE to 50 hours per year.

The black start engine incorporates a diesel particulate filter (DPF), which is required by LAER. The Caterpillar DPF is designed to control the particulate emissions from diesel engines. The DPF consists of 2 filters, each 15-inches diameter by 15-inches long. The DPF system has been verified by CARB under Executive Order DE-14-006-01 to reduce emissions of diesel particulate matter consistent with a Level 3 device (greater than or equal to 85 percent reduction), when used with ultra low sulfur diesel with 15 ppm or lower sulfur content. As the DPF is CARB verified, a source test is not required. With the DPF, the particulate matter emissions from the engine is reduced from 0.15 g/bhp-hr to 0.0225 g/bhp-hr.

The DPF consists of a catalyzed cordierite ceramic honeycomb with hundreds of parallel channels, is designed to reduce emissions of particulate, carbon monoxide and hydrocarbons. The catalyst on the ceramic walls oxidizes carbon monoxide into carbon dioxide, and hydrocarbons into water and carbon dioxide. The arrangement of the channels is such that the exhaust gases carrying the carbon particles are forced through the fine pores of the walls, which filter out the particles. As the carbon particles are collected on the ceramic walls, the backpressure on the engine will increase. When the temperature of the exhaust is equal to or greater than 300 °C (572 °F) for at least 30% of the duty cycle, the catalyst interacts with the collected particulates to burn the particulates into carbon dioxide and water vapor, which will pass through the DPF.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 1
COMPLIANCE MATRIX

CY 2020 SCAQMD COMPLIANCE

[illegible]

CANYON POWER PLANT COMPLIANCE MATRIX
CY 2020 SCAQMD 500-N REPORTS

No.	Unit No.	Description	AQMD Permit Limit	Actual Emissions	Duration	Date of Episode	Reported to AQMD	500N sent to AQMD	Inspector Site Visit	Notice of Violation	Responsible	Resolution/Comments
58	Unit 2	Fuel Flow converter malfunction	COlbs>11.6	13.10lbs	15 min	5/30/20	5/30/20	6/3/20	No	No	Hoffard/Hernandez	Replaced converter
59	Unit 3	H2O injection valve issue	NOx lbs > 14.27 lbs	36 lbs	60 min	11/2/20	11/2/20	11/4/20	No	No	Hoffard/Hernandez	Replaced two relays to the valves electronic control system

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 ENFORCEMENT ACTION NOTICES

NTC or NOV	No.	Description	Date Issued	Compliance Due Date	Response Submitted	Responsible	Resolution/Comments
------------------	-----	-------------	-------------	------------------------	-----------------------	-------------	---------------------

No NOV or NC issued in 2020

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 CEC REPORTING

CEC Requirement	Period	Last Done	Next Due	Responsibility	Comments
CEC 1304	varies one to two months after the quarter	1/25/21	4/30/21	Hoffard/Hernandez	
CEC 1306C	Semi-Annual	1/28/21	4/30/21	Stambler/Hoffard	
CEC Annual Report	30 days at end of calender year	1/30/20	1/31/21	Hoffard/Hernandez	
CEC Quarterly Operations Report	30 days at end of each quarter	1/30/21	4/30/21	Hoffard/Hernandez	
Building and structure inspection	Semi-annually	12/30/20	6/30/21	Hoffard/Hernandez	
Legionella/TDS - PM10 calculation	Quarterly	12/1/20	3/31/21	Hoffard/Truesdail	

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 CEC REPORTING

CEC Requirement	Period	Last Done	Next Due	Responsibility	Comments
CEC 1304	varies one to two months after the quarter	1/25/21	4/30/21	Hoffard/Hernandez	
CEC 1306C	Semi-Annual	1/28/21	4/30/21	Stambler/Hoffard	
CEC Annual Report	30 days at end of calender year	1/30/20	1/31/21	Hoffard/Hernandez	
CEC Quarterly Operations Report	30 days at end of each quarter	1/30/21	4/30/21	Hoffard/Hernandez	
Building and structure inspection	Semi-annually	12/30/20	6/30/21	Hoffard/Hernandez	
Legionella/TDS - PM10 calculation	Quarterly	12/1/20	3/31/21	Hoffard/Truesdail	

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 CAL ARP

California Accidental Release Prevention Program	Period	Last Done	Next Due	Responsibility
Hazard Review - 19% Aqua Ammonia System	Every 5 years	06/01/16	6/30/21	Hoffard/AFD
Compliance Audit	Every three years	2/19/20	2/19/23	Ralph McCaffrey
Ammonia Refresher Training	Every three years	N/A	N/A	Hoffard/McCaffrey

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 CAL RMP REPORTING

Limit	Period	Last Done	Next Due	Responsible
Not Applicable	Due Annually (March 1 Each Year)	2/18/20	3/1/21	Hernandez/Hoffard
Not Applicable	Due Annually	9/7/20	6/30/21	Hernandez/Hoffard

California Air Resources Board

Stationary Equipment Refrigerant Management Program (RMP)

Canyon Power Plant (CPP) Compliance Guidance

Compliance Year: 2020

Facility Size Classification: Large (at least 1 unit w/≥ 2000 lbs high GWP-refrigerant capacity)

Annual Fee: \$370.00 (Fees must be paid annually by the reporting deadline)

No. of Refrigeration Systems: 2 (CH-100, CH-200)

Location(s): Both chillers are located in the Northeast portion of facility footprint, just South of two water storage tanks.

Refrigeration System Specifications

CH-100: Centrifugal Chiller w/5200 lbs R-123 (full charge), Trane, Model No. CDHF3000, Serial No. L10B00882;

> ALDS ID: 301-IRF A: Vulcain/Honeywell, Model No. 301-EM, Concentration Monitor (Direct System), 2 Infrared Sensors

		Done	
Last System Audit:	Next audit target: 6/30/2020	9/4/20	Deadline: 12/31/2020
Last Calibration:	Next calibration target: 6/30/2020	9/8/20	Deadline: 12/31/2020

CH-100: Centrifugal Chiller w/5200 lbs R-123 (full charge), Trane, Model No. CDHF3000, Serial No. L10A00350;

>ALDS ID: 301-IRF B: Vulcain/Honeywell, Model No. 301-EM, Concentration Monitor (Direct System), 2 Infrared Sensors

Last System Audit:	Next audit target: 6/30/2020	9/4/20	Deadline: 12/31/2020
Last Calibration:	Next calibration target: 6/30/2020	9/8/20	Deadline: 12/31/2020

CARB Reporting (due by 3/1 each year)

Last CARB Report: 2/28/2020 for 2019 **Next reporting deadline:** 3/1/2021 (Fee payment due on or before this date)

Automatic Leak Detection System Requirements

● Each system must be audited and calibrated using manufacturer's recommended procedures to ensure that the system:

- 1.) accurately detects a concentration level of 10 parts per million of vapor of the specific refrigerant used in the system; and
- 2.) alerts the operator when a refrigerant concentration of 100 parts per million of vapor of the specific refrigerant is reached.

● **The audit and calibration must be completed on each leak detection system at least once per calendar year.**

- If an automatic leak detection system alerts plant operators, a leak inspection must be conducted within 24 hours after the system alert.
- This leak inspection must be completed using a calibrated refrigerant leak detection device or a bubble test to confirm a refrigerant leak and to determine the leak location(s).
- If during a required leak inspection or at any time oil residue is observed indicating a refrigerant leak, a leak inspection must be conducted using a calibrated refrigerant leak detection device or a bubble test to confirm the leak.
- A leak inspection must be conducted using a calibrated refrigerant leak detection device, a bubble test, or observation of oil residue, each time an additional refrigerant charge equal to or greater than 5 pounds, or one percent of the refrigeration system full charge (whichever is greater), is added to the system.

Leak Repairs and Subsequent Leak Inspection Requirements

● A refrigerant leak must be repaired by an EPA-certified technician holding a current and active C38 - Refrigeration Contractor's license, or by an employee of a contractor with these qualifications.

> A contractor's license is not required if:

- 1.) a City employee services or repairs the system and wages are sole compensation; or
- 2.) the City performs the service or repair through one undertaking, or by one or more contracts, and the aggregate contract price for labor, materials, and all other items is less than \$500; or
- 3.) the service or repair is performed pursuant to a contract entered into before 1/1/2011, by the City.

● **Leaks must be repaired within 14 days of detection, unless a longer time period is allowed (*)**

* 45-day allowance if ANY of the following criteria is met:

- 1.) A certified technician is not available to complete the repair or replace the component(s). This must be documented in writing per recordkeeping requirements;
- 2.) The parts necessary to repair a refrigerant leak are unavailable, and the operator obtains a written statement from the refrigeration system or component manufacturer or distributor stating that the parts are unavailable. This must be documented in writing per recordkeeping requirements; or
- 3.) The refrigerant leak repair requires an industrial process shutdown that results in a process temporarily ceasing to manufacture the intermediate or final product that is produced when the industrial process refrigeration appliance is in operation.

* 120-day allowance if ALL of the following criteria is met:

- 1.) The facility is an entity subject to Mandatory Greenhouse Gas Emissions Reporting requirements;
- 2.) The refrigeration system is an industrial process refrigeration appliance;
- 3.) The refrigerant leak repair requires an industrial process shutdown that results in a process temporarily ceasing to manufacture the intermediate or final product that is produced when the industrial process refrigeration appliance is in operation; and
- 4.) Written records are maintained to document that all of the conditions are met.

● An initial verification test must be performed upon completion of refrigerant leak repairs.

● A follow-up verification test must be conducted on the complete refrigeration system after the initial verification test.

- > If the system was evacuated during the refrigerant leak repair, then this test should be conducted when the system is operating at normal operating characteristics and conditions.
- > If the system was not evacuated during the refrigerant leak repair, then the follow-up verification test requirement is satisfied once the required changes are made to return the refrigeration system to normal operating characteristics and conditions.

● If either the initial or follow-up verification tests indicate that a refrigerant leak is still occurring, the leak must be repaired within 14 days (unless a longer time period is allowed*).

- > A retrofit or retirement plan may also be prepared in lieu of this repair.

● If a follow-up verification test indicates that a refrigerant leak has not been successfully repaired within the 14 days allowed, and no exemption has been received, then:

- > successfully repair the leak within 45 days of the initial leak detection; or
- > prepare a retrofit or retirement plan within 60 days of the initial leak detection.

● If a follow-up verification test indicates that a refrigerant leak has not been successfully repaired within the 45 days allowed (*), and no exemption has been received, then:

- > prepare a retrofit or retirement plan within 60 days of the initial leak detection.

● If a follow-up verification test indicates that a refrigerant leak has not been successfully repaired within the 120 days allowed (*), and no exemption has been received, then:

- > prepare a retrofit or retirement plan within 135 days of the initial leak detection.

Retrofit or Retirement Plan Requirements

● If required to prepare a retirement or retrofit plan, the plan must establish a schedule to retrofit or retire the leaking system no later than six months after the initial leak detection, and all work must be completed during the 6-month period.

● The plan must be kept on-site where the leaking system is located.

● If a refrigeration system is to be retired and replaced, the plan must include information specific to the new refrigeration system to be constructed or installed. (**)

● If a refrigeration system is to be retrofitted, the plan must include information specific to the refrigeration system after the retrofit has been completed. (**)

*** A retrofit or retirement plan must include the following information:

- 1.) The system identification number of the refrigeration system being retired or retrofitted;
- 2.) equipment type;
- 3.) equipment manufacturer;
- 4.) equipment model or description;
- 5.) intended physical location of the refrigeration system through schematic or floor plan with locations clearly noted;
- 6.) temperature classification (i.e., low, medium, other);
- 7.) full charge of refrigeration system;
- 8.) type of refrigerant used;
- 9.) if the refrigeration system is to be retired and replaced, a plan to dispose of the retired system;
- 10.) a timetable which includes, at a minimum:
 - > the date installation, construction, or retrofit of the refrigeration system is expected to begin, and
 - > the expected completion date of the installation, construction, or retrofit of the refrigeration system; and
- 11.) A signature by a representative of the facility, including the date.

● If the system is being mothballed, these requirements do not apply until the day that the refrigeration system resumes operation at a facility.

● If an exemption has been received, then the preparation and implementation of a retrofit or retirement plan is not required during the exemption time period. If an exemption request has been submitted, then the plan preparation or implementation is not required until a final exemption determination is made.

Recordkeeping Requirements

● Maintain the following records for a minimum of 5 years:

- 1.) All registration information required by the rule;
- 2.) documentation of all leak detection systems, leak inspections, and automatic leak detection system annual audit and calibrations;
- 3.) records of refrigeration system service and refrigerant leak repairs, and any documentation of conditions allowing repair to be

conducted more than 14 days after leak detection;

- 4.) retrofit or retirement plans;
- 5.) all CARB reports;
- 6.) any application for exemption, and any notification of an exemption approved, denied, revoked, or modified;
- 7.) invoices for all refrigerant purchases;
- 8.) records of all shipments of refrigerants for reclamation or destruction, to include:
 - > Name and address of the person the refrigerant was shipped to;
 - > Weight in pounds of refrigerant shipped;
 - > type of refrigerant shipped;
 - > date of shipment;
 - > purpose of shipment (i.e., reclamation, destruction, etc.);
- 9.) records of all refrigeration systems component data, measurements, calculations and assumptions used to determine the full charge.

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 CITY REPORTING

Anaheim Requirement	Period	Last Done	Next Due	Responsibility
Certified (Facility) Fire Protection Systems Inspection	Semi-Annual	5/15/20	5/20/21	Hoffard
Electric protection relays	5-years	5/1/16	5/1/21	Hoffard
8-Hour refresher HAZWOPER	Annual	6/17/20	6/17/21	Hoffard/Ralph McCaffrey
Oil Spill Prevention, Control and Countermeasure Plan	5-years	12/7/16	12/7/21	McCaffrey/Hoffard
Hazardous Materials Business Plans (CERS)	Annual	3/24/20	3/24/21	McCaffrey/Hoffard

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 EIA REPORTING

EIA Requirement	Period	Last Done	Next Due	Responsibility	Comments
EIA 860-A	Annual	2/11/20	3/9/21	Hoffard/Hernandez	
EIA-923-M	Monthly	1/19/21	2/28/21	Hoffard/Hernandez	

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 OSHA REPORTING

OSHA Requirement	Period	Unit 1 Done	Unit 1 Due	Unit 2 Done	Unit 2 Due	Unit 3 Done	Unit 3 Due	Unit 4 Done	Unit 4 Due	Canyon Site Done	Canyon Site Due	Responsible
LM6000 Overhead Crane inspection	Annually	1/10/20	1/10/21	1/16/20	1/16/21	1/17/20	1/17/21	1/17/20	1/17/21			Hoffard
Warehouse Crane inspection	Annually									1/16/20	1/23/21	Hoffard
LM6000 Overhead Crane load test	Every 4 years	12/9/20	12/9/24	12/11/20	12/11/24	11/14/16	11/14/20	10/12/20	10/12/24			Hoffard
Warehouse Crane load test	Every 4 years									12/16/20	12/16/24	Hoffard
Fuel Gas system safeties - CTG	Tri-Annual									5/27/19	5/27/22	Hoffard
Fuel Gas system safeties - Gas Yard	Tri-Annual									5/27/19	5/27/22	Hoffard
Instrument Air system safeties	Every 5 years									10/17/16	10/17/21	Hoffard
Ammonia tank system safeties	Updated Every 4 years									11/8/16	11/30/20	Hoffard
Air Pressure tank inspection / permit renewal	Every 5 years									9/16/16	9/16/21	Hoffard/HSB insurance

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 EPA REPORTING

EPA Requirement	Period	Unit 1 Done	Unit 1 Due	Unit 2 Done	Unit 2 Due	Unit 3 Done	Unit 3 Due	Unit 4 Done	Unit 4 Due	Responsible
Linearity Test	anytime within the quarter	10/5/20	3/31/21	10/6/20	3/31/21	10/7/20	3/31/21	11/3/20	3/31/21	Montrose/Hoffard/Hernandez
Electronic Data Report (EDR)	15 days at the end of the Quarter	1/21/21	4/30/21	1/21/21	4/30/21	1/21/21	4/30/21	1/21/21	4/30/21	B&W/Hernandez/Hoffard
Greenhouse gas monitoring report	Annually	3/12/20	3/31/21	3/12/20	3/31/21	3/12/20	3/31/21	3/12/20	3/31/21	Hernandez/Hoffard
EPA Form 500 ACC	Annually	2/28/20	3/1/21	2/28/20	3/1/21	2/28/20	3/1/21	2/28/20	3/1/21	Hernandez/Hoffard

Spill Prevention, Control and Countermeasures Plan	Period	Last Done	Next Due	Responsibility	Comments
SPCC Facility Inspection	Monthly	12/3/20	1/30/21	Hernandez	

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 FIRE CODE REPORTING

Fire Code Requirement	Period	Last Done	Next Due	Responsibility
Fire detection system certification	Annual	5/14/20	5/20/21	Hoffard/Fire Protection Systems
Fire detection system inspection	Semi-annual	11/20/20	5/20/21	Hoffard/Fire Protection Systems
CO 2 cylinder (weight)	Annual	5/13/20	5/20/21	Hoffard/Fire Protection Systems

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 OCSD REPORTING

OCSD Requirement	Period	Last Done	Next Due	Responsibility
Permit # 1-600296				
Effluent Meter reading Report	Monthly	1/1/21	2/1/21	Operator/Hoffard/Hernandez
Effluent Sample collection (BOD/TSS)	semi-annual	10/28/20	4/30/21	Sanks/Hernandez/Hoffard
Effluent Meter Certification	Annual	1/20/21	1/10/22	Sanks/Hernandez/Hoffard
Class I Permit Renewal	every 2 years	3/31/19	3/31/21	Sanks/Hernandez/Hoffard
Backflow Inspection	Annual	11/3/20	11/30/21	Hernandez/Hoffard
Reclaim Water Testing (City of Anaheim)	Every 3 years	12/16/20	12/30/23	Hoffard/Hernandez

CANYON POWER PLANT COMPLIANCE MATRIX

CY 2020 WQMP REPORTING

Storm Drain Systems	Period	Last Done	Next Due	Responsibility
Catch Basins (25) inspection	Semi-Annual (in-house)	6/9/20	6/30/21	Hernandez/Hoffard
Infiltration Vault	Annual Inspection	6/9/20	6/30/21	Hernandez/Hoffard
Contech Storm Filters	Annual Inspection	6/9/20	6/30/21	Hernandez/Hoffard

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 2
FACILITY OPERATIONAL STATUS REPORT

Overall Project Status

Canyon Power Plant construction was completed in August 2011. Units 3 and 4 were ready for commercial operation on July 27, 2011. Units 1 and 2 were ready for commercial operation on September 15, 2011. All four gas turbines completed commissioning and were in commercial operation for the entire compliance year 2020.

No changes to the operational status of the facility implemented or planned in 2020 year.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 3
CEC APPROVED POST CERTIFICATION CHANGES

No California Energy Commission (CEC) approved post certification changes

A Title V permit renewal in CY 2020 was initiated and Canyon Power Plant is waiting for the final Title V facility permit to be issued by SCAQMD.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 4
MISSED SUBMITTAL DEADLINES

Canyon Power Plant submitted all required compliance reports on the due dates and no missed submittal deadlines for CY 2020.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 5
PERMIT FILINGS AND PERMITS ISSUED
DURING THE PERIOD

**Canyon Power Plant submitted a Title V Renewal application to SCAQMD
and is awaiting the issuance of the permit.**

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 6
PROJECTED COMPLIANCE TESTING
FOR THE NEXT YEAR

Projected Environmental Compliance Testing schedule in CY 2020:

Compliance Test	Frequency	Scheduled Quarter
NH3 Slip Test	Annual	3Q; 4Q
RATA Test	Annual or Semi-Annual	2Q; 3Q; 4Q
Cooling Tower TDS/PM10	Quarterly	All four Quarters
Cooling Tower Legionella	Quarterly	All four Quarters
Fuel H ₂ S Test	Monthly	January through December
Fuel Flow Accuracy	Annual	2Q; 3Q
SCR Differential Pressure	Annual	2Q
SCR Inlet Temperature	Annual	2Q
NH3 Flow Meter Calibration	Annual	2Q
Linearity/CGA Test	Quarterly	All four Quarters
PM10/SO ₂ /VOC	Triennial	None

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 7
ADDITIONS TO ON-SITE COMPLIANCE FILE

GENERAL PLANT

Cooling Tower Legionella test report
Cooling Tower PM10 test reports
Monthly Waste Water reports
Monthly Potable water use reports
Monthly Reclaim water use reports
Monthly natural gas burn records
Monthly natural H₂S gas test reports
Refrigerant monitor calibration report
RECLAIM RTC holdings records

CEC

Quarterly reports
Quarterly 1304 Report
Annual report
Potable water use records

CAISO

Certificate of Compliance

CARB

Greenhouse gas records
Annual refrigerant report
Annual SF₆ use report

DIESEL ENGINE

Maintenance Reports
Fuel purchase records
Engine run-time records
HiBack calibration report
Engine tune up report

EIA

Annual/Monthly EIA 923 report
Annual EIA 860 report

EPA

Part 98 Greenhouse Gas reports
Certificate of Representation forms

RECLAIM

Daily submittals
Monthly submittals
Quarterly submittals
SCAQMD QCER Forms
SCAQMD 500-N Forms

SCAQMD 500-SAM Forms
SCAQMD 500-ACC Form
SCAQMD APEP Form
SCAQMD AER Report
SCAQMD Rule 218 Semi-annual reports

SCAQMD

NOV & NTCs issued by the SCAQMD
SCAQMD responses to 500-N forms

UNIT 1:**EPA**

Quarterly Acid Rain report
Quarterly Acid Rain report & feedback report
Annual Form 500-ACC

Calibration Records

Fuel flow meter calibration report
Water flow meter calibration report
NH₃ flow meter calibration report
SCR DP transducer calibration report
SCR inlet temperature transducer Cal report
SCR outlet temperature transducer Cal report

Calibration gas logs

Linearity test reports
Part 75 RATA test reports
RECLAIM RATA test reports
Rule 218 (CO) RATA test reports
NH₃ slip test reports

Tri-ennial compliance testing:
VOC emissions;
PM₁₀ emissions; and
ROG emissions

UNIT 2:

EPA

Quarterly Acid Rain report
Quarterly Acid Rain report & feedback report
Annual Form 500-ACC

Calibration Records

Fuel flow meter calibration report
Water flow meter calibration report
NH3 flow meter calibration report
SCR DP transducer calibration report
SCR inlet temperature transducer Cal report
SCR outlet temperature transducer Cal report

Calibration gas logs
Linearity test reports
Part 75 RATA test reports
RECLAIM RATA test reports
Rule 218 (CO) RATA test reports
NH3 slip test reports

Tri-annual compliance testing:
VOC emissions;
PM10 emissions; and
ROG emissions

UNIT 3:

EPA

Quarterly Acid Rain report
Quarterly Acid Rain report & feedback report
Annual Form 500-ACC

Calibration Records

Fuel flow meter calibration report
Water flow meter calibration report
NH3 flow meter calibration report
SCR DP transducer calibration report
SCR inlet temperature transducer Cal report
SCR outlet temperature transducer Cal report

Calibration gas logs
Linearity test reports
Part 75 RATA test reports
RECLAIM RATA test reports

Rule 218 (CO) RATA test reports
NH3 slip test reports

Tri-annual compliance testing:
VOC emissions;
PM10 emissions; and
ROG emissions

UNIT 4:

EPA

Quarterly Acid Rain report
Quarterly Acid Rain report & feedback report
Annual Form 500-ACC

Calibration Records

Fuel flow meter calibration report
Water flow meter calibration report
NH3 flow meter calibration report
SCR DP transducer calibration report
SCR inlet temperature transducer Cal report
SCR outlet temperature transducer Cal report

Calibration gases logs
Linearity test reports
Part 75 RATA test reports
RECLAIM RATA test reports
Rule 218 (CO) RATA test reports
NH3 slip test reports

Tri-annual compliance testing:
VOC emissions;
PM10 emissions; and
ROG emissions

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 8
UN-PLANNED FACILITY CLOSURE PLAN REVIEW

An “Un-Planned Facility Closure Plan” was drafted and submitted to the California Energy Commission (CEC) in the First Quarter of 2014. At this time, no revisions or changes are required.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 9

Notice of Violation Notice to Comply
Issued in CY 2020

No Notices of Violation
Issued by a Regulatory Agency in the CY 2020

No Notices to Comply
Issued by a Regulatory Agency in the CY 2020

SCAQMD FORM 500-N
Title V – Deviations, Emergencies & Breakdowns
Submitted by Canyon Power Plant



South Coast Air Quality Management District

Form 500-N

Title V - Deviations, Emergencies & Breakdowns

*This written report is in addition to requirements to verbally report certain types of incidents. Verbal reports may be made by calling AQMD at 1-800-288-7664 (1-800-CUT-SMOG) or AQMD enforcement personnel.

Mail To:
SCAQMD- Compliance & Enforcement
P.O. Box 4941
Diamond Bar, CA 91765-0941
Tel: (909) 396-3385
www.aqmd.gov

Section I - Operator Information

1. Facility Name (Business Name of Operator That Appears On Permit): CANYON POWER PLANT U3 (D13)		2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD): 153992	
3. Address: (where incident occurred)			
3071 E. MIRALOMA AVENUE		Street Address	
ANAHEIM		CA	92806
City		State	Zip
4. Mailing Address: (if different from item 3)			
Street Address		City	State Zip
5. Provide the name, title, and phone number of the person to contact for further information:			
RONALD HOFFARD		GENERATION PLANT MGR	(714) 765-4536
Name		Title	Phone #

Section II - Reporting of Breakdowns, Deviations, and Emergencies

1. This written notification is to report a(n):			
Type of Incident	Verbal Report Due*	Written Report Due	
a. <input type="checkbox"/> Emergency under Rule 3002(g)	Within 1 hour of discovery	Within 2 working days from when the emission limit was exceeded.	
b. <input checked="" type="checkbox"/> Breakdown under:		For Rules 430 & 2004 - Within 7 calendar days after breakdown is corrected, but no later than 30 days from start of the breakdown, unless a written extension is granted.	
<input type="checkbox"/> Rule 430 (Non-RECLAIM)	For Rules 430 & 2004 - Within 1 hour of discovery.		
<input checked="" type="checkbox"/> Rule 2004 (RECLAIM)	For Rule 218 - Within 24 hours or next business day for failure/shutdown exceeding 24 hours	For Rule 218 - With required semi-annual reports.	
<input type="checkbox"/> Rule 218 (Non-RECLAIM) [See Rule 218(f)(3)]			
c. <input type="checkbox"/> Deviation with excess emissions [See Title V Permit, Section K, Condition No. 22B]	Within 72 hours of discovery of the deviation or shorter reporting period if required by an applicable State or Federal Regulation.	Within 14 days of discovery of the deviation.	
d. <input type="checkbox"/> Other Deviation [See Title V Permit, Section K, Condition Nos. 22D & 23]	None	With required semi-annual monitoring reports.	
2. The incident was first discovered by: ALVIN MARQUEZ on 11/02/2020 04:15 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Name Date Time			
3. The incident was first reported by: OPERATOR #6 on 11/02/2020 04:58 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Name of AQMD Staff Person Date Time			
a. <input checked="" type="radio"/> Via Phone			
b. <input type="radio"/> In Person			
Notification Number (Required): 631471			
4. When did the incident actually occur? 11/02/2020 04:11 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Date Time			


AQMD USE ONLY	Received By:		Assigned By:		Inspector:	
	Date/Time Received:		Date/Time Assigned:		Date/Time Received Assignment:	
	Date Delivered To Team:		Date Reviewed Inspector Report:		Date Inspected Facility:	
	Team:	Sector:	Breakdown/Deviation Notification No.		Date Completed Report:	
	Recommended Action:		Cancel Notification	Grant Relief	Issue NOV No.	Other:
	Final Action:		Cancel Notification	Grant Relief	Issue NOV No.	Other:

5. Has the incident stopped? a. ☒ Yes, on: 11/02/2020 04:17 ☐ AM ☒ PM b. ☐ No
Date Time
6. What was the total duration of the incident? 06
Days Hours
7. For equipment with an operating cycle, as defined in Rule 430 (b)(3)(A), when was the end of the operating cycle during which the incident occurred? _____
Date Time ☐ AM ☒ PM
8. Describe the incident and identify each piece of equipment (by permit, application, or device number) affected. Attach photos (when available) of the affected equipment and attach additional pages as necessary.
SEE ATTACHED
9. The incident may have resulted in a:
a. ☒ Violation of Permit Condition(s): A99.1
b. ☐ Violation of AQMD Rule(s): _____
10. What was the probable cause of the incident? Attach additional pages as necessary.
SEE ATTACHED
11. Did the incident result in excess emissions? ☐ No ☒ Yes (Complete the following and attach calculations.)
☐ VOC _____ lbs ☒ NOx 21.730 lbs ☐ SOx _____ lbs ☐ H2S _____ lbs
☐ CO _____ lbs ☐ PM _____ lbs ☐ Other: _____ lbs pollutant
12. For RECLAIM facilities Subject to Rule 2004 (i)(3) ONLY: If excess emissions of NOx and/or SOx were reported in Item 11, do you want these emissions to be counted when determining compliance with your annual allocations?
a. ☒ Yes, for: ☒ NOx ☐ SOx b. ☐ No, for: ☐ NOx ☐ SOx
If box 12(b) above is checked, include all information specified in Rule 2004(i)(3)(B) and (C), as applicable.
13. Describe the steps taken to correct the problem (i.e., steps taken to mitigate excess emissions, equipment repairs, etc.) and the preventative measures employed to avoid future incidents. Include photos of the failed equipment if available and attach additional pages as necessary.
SEE ATTACHED
14. Was the facility operating properly prior to the incident?
a. ☒ Yes b. ☐ No, because: _____
15. Did the incident result from operator error, neglect or improper operation or maintenance procedures?
a. ☐ Yes b. ☒ No, because: **OPERATOR FOLLOWED PROCEDURE AND MAINTENANCE WAS N/A**
16. Has the facility returned to compliance?
a. ☐ No, because: _____
b. ☒ Yes (Attach evidence such as emissions calculations, contemporaneous operating logs or other credible evidence.)

Section III - Certification Statement

I certify under penalty of law that based on information and belief formed after reasonable inquiry, the statements and information in this document and in all attachments and other materials are true, accurate, and complete.

For Title V Facilities ONLY: ☒ I also certify under penalty of law that I am the responsible official for this facility as defined in AQMD Regulation XXX.

1. Signature of Responsible Official: 	2. Title of Responsible Official: GENERATION PLANT MANAGER
3. Print Name: RONALD HOFFARD	4. Date: 11/04/2020
5. Phone #: (714) 765-4536	6. Fax #:
7. Address of Responsible Official: 3071 E. MIRALOMA AVENUE ANAHEIM CA 92806	
Street #	City State Zip

AQMD 500N Episode Date: 11/02/2020
Identify issue: Water Injection Valve Failed
Canyon Power Plant: Unit 3 (D13) ID# 153992
Notification: 631471

Question 8 - Describe the incident and identify each piece of equipment:

Unit 3 Combustion Turbine was in startup at 1556 hours and the unit was shut down at 1617 hours after the technician identified that U3 startup NOx lbs emissions was increasing and that the water injection flow had failed to respond (**see attachment 1: DAHS data**). The turbine's NOx emissions are controlled utilizing two independent systems, (1) water injection system injects water into the combustor suppressing the flame temperature and reduce the 1-hour average NOx concentration to approximately 25ppm, then (2) Ammonia/SCR system where ammonia is injected into the exhaust gas duct work through an injection grid located upstream of the SCR. The ammonia injection will further reduce the NOx emissions to less than 2.5ppmv. However, during the first ten minutes of Unit 3 Turbine operation the Technician noticed the DAHS displaying high NOx concentration and NOx lbs. The Technician investigated the issue and further noticed the water injection demand was at zero. The Technician immediately initiated a shutdown command on minute 1607. The shutdown was a gradual shutdown and took approximately 10 minutes for the unit to stop where no natural gas was flowing into the turbine. The unit was placed in an outage after shut down until noon on Tuesday, November 3, 2020 for breakdown investigation.

After Unit 3 was shutdown, staff investigated the breakdown and preliminary findings show the problem may have been caused by a water injection valve or valves failure to respond (**see attachment 2: Water Injection Trend Analysis**). The instrument technician was informed of the issue and would continue investigation in the morning of November 3, 2020.

Question 10 – What was the probable cause of the incident?

Staff believes the breakdown was caused by a water injection valve or valves failure to respond during the startup period.

Question 13 – Describe the steps taken to correct the problem:

The instrument technician conducted an investigation of U3 water injection flow system. During troubleshooting, the instrument technician determined no issues with the valves and valve solenoids. Troubleshooting of the valves electric control systems revealed failure of two relays that energize the solenoids. The relays were identified as K97 and rely K11, which were unstable due to worn contacts. Both relays were replaced and tested (**see attachment 3: Relay components**), and all wirings were checked and tested. Unit 3 was cleared for operational testing.

Question 16 – Facility returned to compliance?

U3 Turbine was tested November 3, 2020. The unit was in startup at 1005 hours and the water flow injection operated as expected. The unit came into compliance for all emissions in minute of 1018 hours. An online passing calibration was performed and Unit 3 was shutdown at 1111 hours. Unit 3 was determined to be in compliance (**see attachment 4: DAHS data**).

Date/Time	Unit 3 DAHS Data										Unit 4 DAHS Data					
	3_Startup		3_GasFlow		3_NH3_Flow		3_H2O_FLOW		3_NOxlb_SU		4_NH3_Flow		4_H2O_FLOW		4_NOxlb_SU	
	1=ON	status	kscf/hr	status	#/hr	status	k#/hr	status	#/hr	status	#/hr	status	k#/hr	status	#/hr	status
11/02/2020 15:50	0	P	0.2	P	0	P	0	P	0	P	0.02	P	0	P	0	P
11/02/2020 15:51	0	P	0	P	0	P	0	P	0	P	0.03	P	0	P	0	P
11/02/2020 15:52	0	P	0	P	0	P	0	P	0	P	0.04	P	0	P	0	P
11/02/2020 15:53	0	P	0.1	P	0	P	0	P	0	P	0.05	P	0	P	0	P
11/02/2020 15:54	0	P	0.1	P	0	P	0	P	0	P	0.03	P	0	P	0	P
11/02/2020 15:55	0	P	37.6	P	0	P	0	P	0	P	0.03	P	0	P	0	P
11/02/2020 15:56	1		110		0		0		0.92		0.01		0		0	
11/02/2020 15:57	1		114.7		0		0		10.84		0.03		0		4.94	
11/02/2020 15:58	1		134		0		0		14.91		0.03		0.3		16.65	
11/02/2020 15:59	1		193.7		0		0		16.27		0.03		3.1		20.22	
11/02/2020 16:00	1		256.6		0		0		24.78		0.01		5.8		19.62	
11/02/2020 16:01	1		326.6		0		0		78.52		0.03		10.9		21.07	
11/02/2020 16:02	1		396.5		57.12		0		152.37		21.1		17.5		31.02	
11/02/2020 16:03	1		427.1		86.05		0		258.34		95.49		22.1		39.89	
11/02/2020 16:04	1		435		90.4		0		247.59		106.27		22.3		16.8	
11/02/2020 16:05	1		435		91.02		0		235.25		108.55		22		3.96	
11/02/2020 16:06	1		435.2		90.83		0		233.07		109.16		21.9		2.48	
11/02/2020 16:07	1		434.8		90.96		0		232.81		109.31		21.5		2.48	
11/02/2020 16:08	1		394.9		81.76		0		216.42		109.38		21.3		2.47	
11/02/2020 16:09	1		324.4		68.01		0		176.77		108.95		21.3		2.48	
11/02/2020 16:10	1		257.3		56.71		0		122.13		108.55		21.6		2.97	
11/02/2020 16:11	1		182.1		64.36		0		69.41		107.83		21.9		2.97	
11/02/2020 16:12	1		125.1		75.3		0		34.43		107.42		22.2		2.97	
11/02/2020 16:13	1		112.9		77.48		0		16.12		106.88		22.4		2.48	
11/02/2020 16:14	1		112.9		78.31		0		7.23		106.2		22.1		2.47	
11/02/2020 16:15	1		112.8		78.34		0		5.21		105.13		21.9		2.47	
11/02/2020 16:16	1		112.8		78.35		0		4.14		104.51		21.6		2.47	
11/02/2020 16:17	1		75.7		52.45		0		2.39		103.64		21.5		0	C
11/02/2020 16:18	0	P	0	P	0	P	0	P	0	P	103.66		21.5		0	C
11/02/2020 16:19	0	P	0.1	P	0	P	0	P	0	P	103.71		21.5		0	C
11/02/2020 16:20	0	P	0.1	P	0	P	0	P	0	PCI	103.72		21.5		0	C
11/02/2020 16:21	0	P	0.2	P	0	P	0	P	0	PCI	103.63		21.5		0	CZ
11/02/2020 16:22	0	P	0.2	P	0	P	0	P	0	PCI	103.77		21.5		0	CZ
11/02/2020 16:23	0	P	0.2	P	0	P	0	P	0	PCI	103.73		21.5		0	C
11/02/2020 16:24	0	P	0.1	P	0	P	0	P	0	PCI	103.77		21.5		0	C
11/02/2020 16:25	0	P	0.2	P	0	P	0	P	0	PCI	103.6		21.6		0	CS
11/02/2020 16:26	0	P	0	P	0	P	0	P	0	PCI	103.56		21.5		0	C
11/02/2020 16:27	0	P	0.1	P	0	P	0	P	0	PCI	103.76		21.6		0	C
11/02/2020 16:28	0	P	0	P	0	P	0	P	0	PCI	103.58		21.5		0	CS
11/02/2020 16:29	0	P	0.1	P	0	P	0	P	0	PCI	103.86		21.5		0	CS
11/02/2020 16:30	0	P	0.2	P	0.01	P	0	P	0	PC	103.49		21.6		0	C
11/02/2020 16:31	0	P	0.2	P	0	P	0	P	0	PC	103.7		21.6		0	C
11/02/2020 16:32	0	P	0.3	P	0	P	0	P	0	PC	103.59		21.6		0	C
11/02/2020 16:33	0	P	0.2	P	0	P	0	P	0	PC	103.6		21.6		0	C
11/02/2020 16:34	0	P	0	P	0	P	0	P	0	PC	103.56		21.6		0	C
11/02/2020 16:35	0	P	0.1	P	0	P	0	P	0	PC	103.59		21.8		3.95	
11/02/2020 16:36	0	P	0.1	P	0	P	0	P	0	P	104.39		22.1		3.95	
11/02/2020 16:37	0	P	0.1	P	0	P	0	P	0	P	105.18		22.2		3.46	
11/02/2020 16:38	-9999	U	-999.9	U	0	P	0	P	0	U	105.69		22.1		3.46	
11/02/2020 16:39	-9999	U	-999.9	U	0	P	0	P	0	U	105.7		21.8		2.96	
11/02/2020 16:40	-9999	U	-999.9	U	0	P	0	P	0	U	105.11		21.6		2.96	
11/02/2020 16:41	-9999	U	-999.9	U	0	P	0	P	0	U	105.04		21.5		2.96	
11/02/2020 16:42	-9999	U	-999.9	U	0	P	0	P	0	U	104.6		21.6		3.45	
11/02/2020 16:43	-9999	U	-999.9	U	0	P	0	P	0	U	104.85		21.8		3.94	
11/02/2020 16:44	-9999	U	-999.9	U	0	P	0	P	0	U	105.09		22.1		3.95	

Date/Time	Unit 3 DAHS Data						Unit 4 DAHS Data					
	3_Startup		3_GasFlow		3_NH3_Flow		3_H2O_FLOW		3_NOxlb_SU		4_NH3_Flow	
	1=ON	status	kscf/h	status	#/hr	status	k#/hr	status	#/hr	status	#/hr	status
11/02/2020 16:45	-9999	U	-999.9	U	0	P	0	P	0	U	106.06	22.3
11/02/2020 16:46	-9999	U	-999.9	U	0	P	0	P	0	U	106.31	22.2
11/02/2020 16:47	-9999	U	-999.9	U	0	P	0	P	0	U	105.81	21.9
11/02/2020 16:48	-9999	U	-999.9	U	0	P	0	P	0	U	105.2	21.6
11/02/2020 16:49	-9999	U	-999.9	U	0	P	0	P	0	U	104.76	21.5
11/02/2020 16:50	-9999	U	-999.9	U	0	P	0	P	0	U	104.08	21.5
11/02/2020 16:51	-9999	U	-999.9	U	0	P	0	P	0	U	104.28	21.7
11/02/2020 16:52	-9999	U	-999.9	U	0	P	0	P	0	U	104.69	22.1
11/02/2020 16:53	-9999	U	-999.9	U	0	P	0	P	0	U	105.36	22.3
11/02/2020 16:54	-9999	U	-999.9	U	0	P	0	P	0	U	105.65	22.2
11/02/2020 16:55	-9999	U	-999.9	U	0	P	0	P	0	U	105.68	22
11/02/2020 16:56	-9999	U	-999.9	U	0	P	0	P	0	U	105.35	21.7
11/02/2020 16:57	-9999	U	-999.9	U	0	P	0	P	0	U	104.46	21.4
11/02/2020 16:58	-9999	U	-999.9	U	0	P	0	P	0	U	104.38	21.5
11/02/2020 16:59	-9999	U	-999.9	U	0	P	0	P	0	U	104.16	21.7
11/02/2020 17:00	-9999	U	-999.9	U	0	P	0	P	0	U	104.52	22
11/02/2020 17:01	-9999	U	-999.9	U	0	P	0	P	0	U	104.91	22.1
11/02/2020 17:02	-9999	U	-999.9	U	0	P	0	P	0	U	105.68	22.3
11/02/2020 17:03	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.64	21.9
11/02/2020 17:04	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	104.93	21.6
11/02/2020 17:05	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.5	21.5
11/02/2020 17:06	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.45	21.6
11/02/2020 17:07	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.37	21.9
11/02/2020 17:08	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.02	22.3
11/02/2020 17:09	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.53	22.3
11/02/2020 17:10	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.56	22.2
11/02/2020 17:11	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.42	21.9
11/02/2020 17:12	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.67	21.6
11/02/2020 17:13	-9999	U	-999.9	U	0	P	-999.9	U	0	U	103.93	21.5
11/02/2020 17:14	-9999	U	-999.9	U	0	P	-999.9	U	0	U	103.92	21.6
11/02/2020 17:15	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.49	21.9
11/02/2020 17:16	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.37	22.2
11/02/2020 17:17	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.68	22.2
11/02/2020 17:18	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.01	22.2
11/02/2020 17:19	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.88	21.8
11/02/2020 17:20	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.17	21.6
11/02/2020 17:21	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.85	21.6
11/02/2020 17:22	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.1	21.8
11/02/2020 17:23	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.44	22.1
11/02/2020 17:24	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.7	22.3
11/02/2020 17:25	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.59	22.2
11/02/2020 17:26	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.77	22.1
11/02/2020 17:27	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.27	21.7
11/02/2020 17:28	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.01	21.6
11/02/2020 17:29	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.48	21.7
11/02/2020 17:30	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.52	21.9
11/02/2020 17:31	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.93	22.2
11/02/2020 17:32	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.55	22.3
11/02/2020 17:33	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.59	22.3
11/02/2020 17:34	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.47	22
11/02/2020 17:35	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.68	21.7
11/02/2020 17:36	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.24	21.5
11/02/2020 17:37	-9999	U	-999.9	U	0	P	-999.9	U	0	U	103.89	21.6
11/02/2020 17:38	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.57	21.9
11/02/2020 17:39	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.96	22.2
11/02/2020 17:40	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.74	22.4

36 lbs

Date/Time	Unit 3 DAHS Data						Unit 4 DAHS Data					
	3_Startup		3_GasFlow		3_NH3_Flow		3_H2O_FLOW		3_NOxlb_SU		4_NH3_Flow	
	1=ON	status	kscfh	status	#/hr	status	k#/hr	status	#/hr	status	#/hr	status
11/02/2020 17:41	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.96	22.3
11/02/2020 17:42	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.85	22.1
11/02/2020 17:43	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.42	21.8
11/02/2020 17:44	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.78	21.4
11/02/2020 17:45	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104	21.4
11/02/2020 17:46	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.32	21.5
11/02/2020 17:47	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.92	21.9
11/02/2020 17:48	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.72	22.1
11/02/2020 17:49	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.26	22.5
11/02/2020 17:50	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.99	22.4
11/02/2020 17:51	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.92	22.1
11/02/2020 17:52	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.13	21.8
11/02/2020 17:53	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.96	21.5
11/02/2020 17:54	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.4	21.6
11/02/2020 17:55	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.14	21.6
11/02/2020 17:56	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.71	21.9
11/02/2020 17:57	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.42	22.2
11/02/2020 17:58	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.63	22.3
11/02/2020 17:59	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.91	22.2
11/02/2020 18:00	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.98	21.8
11/02/2020 18:01	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.29	21.5
11/02/2020 18:02	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.7	21.5
11/02/2020 18:03	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.5	21.3
11/02/2020 18:04	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.9	21.6
11/02/2020 18:05	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.44	22
11/02/2020 18:06	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.33	22.3
11/02/2020 18:07	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.79	22.5
11/02/2020 18:08	-9999	U	-999.9	U	0	P	-999.9	U	0	U	107.06	22.3
11/02/2020 18:09	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.6	21.9
11/02/2020 18:10	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.72	21.5
11/02/2020 18:11	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.63	21.5
11/02/2020 18:12	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.6	21.4
11/02/2020 18:13	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.22	21.7
11/02/2020 18:14	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.69	22.1
11/02/2020 18:15	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.55	22.3
11/02/2020 18:16	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.81	22.3
11/02/2020 18:17	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.99	22.1
11/02/2020 18:18	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	105.68	21.8
11/02/2020 18:19	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.85	21.5
11/02/2020 18:20	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.5	21.4
11/02/2020 18:21	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.59	21.5
11/02/2020 18:22	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.93	21.7
11/02/2020 18:23	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.68	22.1
11/02/2020 18:24	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.27	22.3
11/02/2020 18:25	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.6	22.3
11/02/2020 18:26	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.81	22
11/02/2020 18:27	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.4	21.8
11/02/2020 18:28	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	105.25	21.4
11/02/2020 18:29	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	105.03	21.4
11/02/2020 18:30	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.72	21.5
11/02/2020 18:31	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	105.27	21.8
11/02/2020 18:32	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.71	22.1
11/02/2020 18:33	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.19	22.3
11/02/2020 18:34	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.78	22.3
11/02/2020 18:35	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.5	22
11/02/2020 18:36	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.72	21.7

Date/Time	3_Startup		3_GasFlow		Unit 3 DAHS Data						Unit 4 DAHS Data					
					3_NH3_Flow		3_H2O_FLOW		3_NOxlb_SU		4_NH3_Flow		4_H2O_FLOW		4_NOxlb_SU	
	1=ON	status	kscfh	status	#/hr	status	k#/hr	status	#/hr	status	#/hr	status	k#/hr	status	#/hr	status
11/02/2020 18:37	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	104.69		21.4		0	P
11/02/2020 18:38	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	104.16		21.3		0	P
11/02/2020 18:39	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.32		21.6		0	P
11/02/2020 18:40	-9999	U	-999.9	U	-0.03	P	-999.9	U	0	U	104.42		21.9		0	P
11/02/2020 18:41	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.23		22.1		0	P
11/02/2020 18:42	-9999	U	-999.9	U	-0.02	P	-999.9	U	0	U	105.87		22.3		0	P
11/02/2020 18:43	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.37		22.2		0	P
11/02/2020 18:44	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.94		21.9		0	P
11/02/2020 18:45	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.37		21.6		0	P
11/02/2020 18:46	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.52		21.4		0	P
11/02/2020 18:47	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.38		21.5		0	P
11/02/2020 18:48	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	104.2		21.7		0	P
11/02/2020 18:49	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.1		22.1		0	P
11/02/2020 18:50	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.7		22.3		0	P
11/02/2020 18:51	-9999	U	-999.9	U	0	P	-999.9	U	0	U	106.23		22.2		0	P
11/02/2020 18:52	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.86		22		0	P
11/02/2020 18:53	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.74		21.7		0	P
11/02/2020 18:54	-9999	U	-999.9	U	0	P	-999.9	U	0	U	105.27		21.4		0	P
11/02/2020 18:55	-9999	U	-999.9	U	0	P	-999.9	U	0	U	104.27		21.3		0	P
11/02/2020 18:56	-9999	U	-999.9	U	0	P	-999.9	U	0	U	93.04		18.4		0	P
11/02/2020 18:57	-9999	U	-999.9	U	0	P	-999.9	U	0	U	73.92		13.4		0	P
11/02/2020 18:58	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	67.8		8.3		0	P
11/02/2020 18:59	-9999	U	-999.9	U	0	P	-999.9	U	0	U	64.78		3.9		0	P
11/02/2020 19:00	-9999	U	-999.9	U	0	P	-999.9	U	0	U	57.67		1.7		0	P
11/02/2020 19:01	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	51.91		1.1		0	P
11/02/2020 19:02	-9999	U	-999.9	U	-0.01	P	-999.9	U	0	U	56.47		1.1		0	P
11/02/2020 19:03	-9999	U	-999.9	U	0	P	-999.9	U	0	U	60.03		1		0	P
11/02/2020 19:04	-9999	U	-999.9	U	0	P	-999.9	U	0	U	64.38		1.1		0	P
11/02/2020 19:05	-9999	U	-999.9	U	0	P	-999.9	U	0	U	68.25		0.9		0	P
11/02/2020 19:06	-9999	U	-999.9	U	0	P	-999.9	U	0	U	0	P	0	P	0	P
11/02/2020 19:07	-9999	U	-999.9	U	0	P	-999.9	U	0	U	0.01	P	0	P	0	P

Invalid Status Legend:

U - Untouched
P - Process OFF
E - Data Error
C - In Calibration
F - Calibration Failure
Z - Zero Step
S - Span Step
O - Out of Control
I - Ignore/Discard Data
L - Old Data
M - Communication Failure
H - Hardware Failure
T - Task Error
* - Substituted (common use)

Exceedance	36 lbs
Limit	<u>14.27 lbs</u>
Over limit	21.73 lbs


ATTACHMENT #3

CANYON POWER PLANT
ID# 153752
NOTIFICATION # 631471

U3 K11/K12 Relay



U3 K97 Relay



		U3 DAHS Data - Testing Run							
	Date/Time	3_Startup		3_GasFlow		3_H2O_FLOW		3_NH3_Flow	
		1=ON	status	kscfh	status	k#/hr	status	#/hr	status
Startup	11/03/2020 10:00	0	P	0.2	P	0	P	-0.01	P
	11/03/2020 10:01	0	P	0.1	P	0	P	-0.01	P
	11/03/2020 10:02	0	P	0	P	0	P	-0.01	P
	11/03/2020 10:03	0	P	0.1	P	0	P	-0.03	P
	11/03/2020 10:04	0	P	34.7	P	0	P	-0.03	P
H2O	11/03/2020 10:05	1		113.8		0		1.06	
	11/03/2020 10:06	1		117.2		0		13.24	
	11/03/2020 10:07	1		142		1.4	-0.01	16.22	
	11/03/2020 10:08	1		205.7		4.9	0	18.82	
	11/03/2020 10:09	1		261.5		7.5	0	13.11	
	11/03/2020 10:10	1		264.2		7.4	0	14.61	
	11/03/2020 10:11	1		264.1		7.4	14.85	16.93	
	11/03/2020 10:12	1		263.7		7.3	56.16	17.77	
	11/03/2020 10:13	1		263.3		7.2	60.9	12.11	
	11/03/2020 10:14	1		263.3		7.2	60.89	4.95	
	11/03/2020 10:15	1		263.6		7.2	60.99	3.56	
	11/03/2020 10:16	1		263.7		7.3	60.96	2.94	
	11/03/2020 10:17	1		263.7		7.4	60.84	2.35	
	11/03/2020 10:18	1		264.1		7.4	61.47	1.94	
	11/03/2020 10:19	1		263.5		7.4	62.27	1.86	
	11/03/2020 10:20	1		264.3		7.4	63	1.75	
	11/03/2020 10:21	1		264.1		7.3	63.62	1.57	
	11/03/2020 10:22	1		264.2		7.3	63.91	1.46	
	11/03/2020 10:23	1		263.9		7.2	64	1.36	
	11/03/2020 10:24	1		264		7.2	64.11	1.31	
	11/03/2020 10:25	1		263.8		7.2	64.25	1.29	
	11/03/2020 10:26	1		264.1		7.2	64.11	1.26	
	11/03/2020 10:27	1		263.6		7.2	64.18	1.24	
	11/03/2020 10:28	1		264		7.3	63.91	1.23	
	11/03/2020 10:29	1		264.3		7.3	63.85	1.23	
	11/03/2020 10:30	1		263.7		7.2	63.81	1.24	
	11/03/2020 10:31	1		264		7.3	63.7	1.24	
	11/03/2020 10:32	1		263.9		7.3	63.56	1.25	
Cal	11/03/2020 10:33	1		264.3		7.3	63.47	2.59	C
	11/03/2020 10:34	1		263.8		7.3	63.54	4.81	C
	11/03/2020 10:35	1		263.8		7.3	63.57	0.08	C
	11/03/2020 10:36	1		264.1		7.3	63.57	0.05	C
	11/03/2020 10:37	1		264.2		7.4	63.59	0.02	CZ
	11/03/2020 10:38	1		264.2		7.3	63.59	0.02	CZ
	11/03/2020 10:39	1		264		7.3	63.66	8.95	C
	11/03/2020 10:40	0		264.2		7.3	63.57	9.19	C
	11/03/2020 10:41	0		263.9		7.3	63.47	9.19	CS
	11/03/2020 10:42	0		264.2		7.4	63.54	123.12	C
	11/03/2020 10:43	0		263.7		7.4	63.67	179.26	C
	11/03/2020 10:44	0		263.5		7.3	63.63	179.65	CS
	11/03/2020 10:45	0		263.9		7.4	63.7	179.65	CS
	11/03/2020 10:46	0		264		7.3	63.7	11.94	C
	11/03/2020 10:47	0		264.1		7.4	63.6	2.36	C
	11/03/2020 10:48	0		263.8		7.4	63.7	1.94	C
	11/03/2020 10:49	0		264		7.4	63.61	1.88	C
End Cal	11/03/2020 10:50	0		263.6		7.4	63.7	1.83	C
	11/03/2020 10:51	0		263.9		7.4	75.09	1.76	
	11/03/2020 10:52	0		264.2		7.5	98.9	1.69	
	11/03/2020 10:53	0		264.2		7.6	104.71	1.47	
	11/03/2020 10:54	0		264.3		7.7	104.65	1.1	
	11/03/2020 10:55	0		264.5		7.7	104.67	0.89	

Date/Time		3_Startup		3_GasFlow		U3 DAHS Data - Testing Run					
		1=ON	status	kscfh	status	3_H2O_FLOW	3_NH3_Flow	3_NOXPPM	3_NOxlb_SU		
						k#/hr	#/hr	ppm	#/hr	status	
	11/03/2020 10:56	0		264.3		7.7	104.49	0.81	1.11		
	11/03/2020 10:57	0		264.3		7.7	102.81	0.77	1.11		
	11/03/2020 10:58	0		264.3		7.6	101.4	0.76	1.11		
	11/03/2020 10:59	0		264.1		7.6	101.56	0.75	1.11		
	11/03/2020 11:00	0		264.2		7.6	101.5	0.75	1.11		
	11/03/2020 11:01	0		264.1		7.6	101.41	0.75	1.11		
	11/03/2020 11:02	0		263.9		7.6	101.42	0.74	1.11		
	11/03/2020 11:03	0		264		7.6	101.39	0.72	1.11		
Shutdown	11/03/2020 11:04	0		262.3		7.4	101.49	0.71	0 P		
	11/03/2020 11:05	0		208.4		4.3	101.47	0.72	0 P		
	11/03/2020 11:06	0		143		1.8	101.39	0.73	0 P		
	11/03/2020 11:07	0		112.5		1.2	101.6	0.78	0 P		
	11/03/2020 11:08	0		112.5		1.2	101.51	0.88	0 P		
	11/03/2020 11:09	0		112.5		1.2	101.41	0.92	0 P		
	11/03/2020 11:10	0		112.7		1.2	101.52	0.92	0 P		
	11/03/2020 11:11	0		112.6		1	101.5	0.92	0 P		
	11/03/2020 11:12	0 P		0.1 P		0 P	0 P	0.91 P	0 P		
	11/03/2020 11:13	0 P		0.1 P		0 P	0 P	0.57 P	0 P		
	11/03/2020 11:14	0 P		0 P		0 P	0 P	0.09 P	0 P		
	11/03/2020 11:15	0 P		0 P		0 P	-0.01 P	0.05 P	0 P		
	11/03/2020 11:16	0 P		0 P		0 P	0 P	0.05 P	0 P		
	11/03/2020 11:17	0 P		0 P		0 P	0 P	0.04 P	0 P		
	11/03/2020 11:18	0 P		0 P		0 P	0 P	0.03 P	0 P		
	11/03/2020 11:19	0 P		0.1 P		0 P	0 P	0.02 P	0 P		
	11/03/2020 11:20	0 P		0.2 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:21	0 P		0.2 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:22	0 P		0.1 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:23	0 P		0 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:24	0 P		0 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:25	0 P		0 P		0 P	0 P	0 P	0 P		
	11/03/2020 11:26	0 P		0.1 P		0 P	0 P	0 P	0 P		
	11/03/2020 11:27	0 P		0 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:28	0 P		0 P		0 P	0 P	0.01 P	0 P		
	11/03/2020 11:29	0 P		0.1 P		0 P	0 P	0.01 P	0 P		

Invalid Status Legend:

- U - Untouched
- P - Process OFF
- E - Data Error
- C - In Calibration
- F - Calibration Failure
- Z - Zero Step
- S - Span Step
- O - Out of Control
- I - Ignore/Discard Data
- L - Old Data
- M - Communication Failure
- H - Hardware Failure
- T - Task Error
- * - Substituted (common use)



South Coast Air Quality Management District

Form 500-N

Title V - Deviations, Emergencies & Breakdowns

*This written report is in addition to requirements to verbally report certain types of incidents. Verbal reports may be made by calling AQMD at 1-800-288-7664 (1-800-CUT-SMOG) or AQMD enforcement personnel.

Mail To:
SCAQMD
P.O. Box 4941
Diamond Bar, CA 91765-0941

Tel: (909) 396-3385
www.aqmd.gov

Section I - Operator Information

1. Facility Name (Business Name of Operator That Appears On Permit):		2. Valid AQMD Facility ID (Available On Permit Or Invoice Issued By AQMD):	
CANYON POWER PLANT Unit 2 (D7)		153992	
3. Address: 3071 E. Miraloma Avenue			
(where incident occurred)		Street Address	
Anaheim		CA	92806
City		State	Zip
4. Mailing Address:			
(if different from Item 3)		Street Address	
City		State	Zip
5. Provide the name, title, and phone number of the person to contact for further information:			
Ronald Hoffard		Generation Plant Manager	
Name		Title	
		(714) 765-4536	
		Phone #	

Section II - Reporting of Breakdowns, Deviations, and Emergencies

1. This written notification is to report a(n):			
Type of Incident	Verbal Report Due*	Written Report Due	
a. <input type="checkbox"/> Emergency under Rule 3002(g)	Within 1 hour of discovery	Within 2 working days from when the emission limit was exceeded.	
b. <input checked="" type="checkbox"/> Breakdown under:		For Rules 430 & 2004 - Within 7 calendar days after breakdown is corrected, but no later than 30 days from start of the breakdown, unless a written extension is granted.	
<input type="checkbox"/> Rule 430 (Non-RECLAIM)	For Rules 430 & 2004 - Within 1 hour of discovery.		
<input checked="" type="checkbox"/> Rule 2004 (RECLAIM)			
<input type="checkbox"/> Rule 218 (Non-RECLAIM)	For Rule 218 - Within 24 hours or next business day for failure/shutdown exceeding 24 hours	For Rule 218 - With required semi-annual reports.	
[See Rule 218(f)(3)]			
c. <input type="checkbox"/> Deviation with excess emissions	Within 72 hours of discovery of the deviation or shorter reporting period if required by an applicable State or Federal Regulation.	Within 14 days of discovery of the deviation.	
[See Title V Permit, Section K, Condition No. 22B]			
d. <input type="checkbox"/> Other Deviation	None	With required semi-annual monitoring reports.	
[See Title V Permit, Section K, Condition Nos. 22D & 23]			
2. The incident was first discovered by: Theodore Nguyen on 05/30/2020 06:00 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Name Date Time			
3. The incident was first reported by: Voicemail left at 1800-CUT-SMOG on 05/30/2020 06:47 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Name of AQMD Staff Person Date Time			
a. <input checked="" type="radio"/> Via Phone			
b. <input type="radio"/> In Person			
Notification Number (Required): 612815			
4. When did the incident actually occur? 05/30/2020 05:23 <input type="radio"/> AM <input checked="" type="radio"/> PM			
Date Time			


AQMD USE ONLY	Received By:		Assigned By:		Inspector:	
	Date/Time Received:		Date/Time Assigned:		Date/Time Received Assignment:	
	Date Delivered To Team:		Date Reviewed Inspector Report:		Date Inspected Facility:	
	Team:	Sector:	Breakdown/Deviation Notification No.		Date Completed Report:	
	Recommended Action:		Issue NOV No.		Other:	
	Cancel Notification		Grant Relief			
	Final Action:		Issue NOV No.		Other:	
Cancel Notification		Grant Relief				

5. Has the incident stopped? a. ☒ Yes, on: 05/30/2020 04:37 ☐ AM ☒ PM b. ☐ No
Date Time
6. What was the total duration of the incident? 15
Days Hours MIN
7. For equipment with an operating cycle, as defined in Rule 430 (b)(3)(A), when was the end of the operating cycle during which the incident occurred? _____
Date Time ☐ AM ☒ PM
8. Describe the incident and identify each piece of equipment (by permit, application, or device number) affected. Attach photos (when available) of the affected equipment and attach additional pages as necessary.
9. The incident may have resulted in a:
a. ☒ Violation of Permit Condition(s): A99.2 CO ppm > 11.6 lbs
b. ☐ Violation of AQMD Rule(s): _____
10. What was the probable cause of the incident? Attach additional pages as necessary.
11. Did the incident result in excess emissions? ☐ No ☒ Yes (Complete the following and attach calculations.)
☐ VOC _____ lbs ☐ NOx _____ lbs ☐ SOx _____ lbs ☐ H2S _____ lbs
☒ CO 1.500 lbs ☐ PM _____ lbs ☐ Other: _____ lbs pollutant
12. For RECLAIM facilities Subject to Rule 2004 (i)(3) ONLY: If excess emissions of NOx and/or SOx were reported in Item 11, do you want these emissions to be counted when determining compliance with your annual allocations?
a. ☒ Yes, for: ☐ NOx ☐ SOx b. ☐ No, for: ☐ NOx ☐ SOx
If box 12(b) above is checked, include all information specified in Rule 2004(i)(3)(B) and (C), as applicable.
13. Describe the steps taken to correct the problem (i.e., steps taken to mitigate excess emissions, equipment repairs, etc.) and the preventative measures employed to avoid future incidents. Include photos of the failed equipment if available and attach additional pages as necessary.
14. Was the facility operating properly prior to the incident?
a. ☒ Yes b. ☐ No, because: _____
15. Did the incident result from operator error, neglect or improper operation or maintenance procedures?
a. ☐ Yes b. ☒ No, because: _____
16. Has the facility returned to compliance?
a. ☐ No, because: _____
b. ☒ Yes (Attach evidence such as emissions calculations, contemporaneous operating logs or other credible evidence.)

Section III - Certification Statement

I certify under penalty of law that based on information and belief formed after reasonable inquiry, the statements and information in this document and in all attachments and other materials are true, accurate, and complete.

For Title V Facilities ONLY: ☒ I also certify under penalty of law that I am the responsible official for this facility as defined in AQMD Regulation XXX.

1. Signature of Responsible Official: 	2. Title of Responsible Official: GENERATION PLANT MANAGER
3. Print Name: RONALD HOFFARD	4. Date: 6/3/2020
5. Phone #: (714) 765-4653	6. Fax #:
7. Address of Responsible Official: 3071 E. MIRALOMA AVENUE Anaheim CA 92806 Street # City State Zip	

AQMD 500N Episode Date:

Identify issue: Fuel Flow converter malfunction

Canyon Power Plant: Unit 2/(D7) ID# 153992

Notification:

Question 8 - Describe the incident and identify each piece of equipment:

The U2 Turbine was in startup promptly at 1623 hours and shut down at 1637 hours after the technician identified that U2 had the potential to exceed the startup CO pounds per hour parameter (see **attachment 1: DAHS data**). Technicians are trained to use an Emissions Compliance Log for all units during Startup, prior to Calibration and prior Shutdown to verify the NOx/CO lbs per hour readings are within the compliance range. The log is a tool used by the technicians to evaluate minute data to prevent a NOx or CO emission exceedance.

The technician operating U2 Turbine on May 30, 2020, recognized a possible CO exceedance at the 5th minute mark (11.86 lbs/hr > 7 lbs/hr) the unit was in operation (see **attachment 2: Emission Compliance Log**). The unit was gradually shutdown and successfully stopped at 1637 hours. At 1700 hours, an episode was registered in the DAHS. The technician proceeded to contact South Coast AQMD at 1747 hours to report the breakdown via telephone call at 1800-CUT-SMOG. The startup data for CO lbs per hour revealed that the startup and shutdown period exceeded the CO 11.6 lbs permit limit.

Question 10 – What was the probable cause of the incident?

Staff reviewed CO lbs per hour data and discovered that the CO lbs per hour for Unit 2 was unusually higher than normal compared to previous runs and to the other three units. Further data investigation revealed that the Gas Flow, a component in the calculation of the CO lbs per hour, was higher than usual. In addition, the technician that operated U2 on May 30, 2020 stated that the NH3 control was increasing output to higher amounts than required. The NH3 component uses fuel flow as an input to control NOx.

Question 13 – Describe the steps taken to correct the problem:

The instrument technician conducted an investigation of U2 fuel flow system and monitors. During the troubleshooting, the instrument technician verified that there was no issues with the fuel flow element, however, the fuel flow output frequency sent to the converter that converts frequency to mA was transmitting a higher value than usual. This investigation revealed that U2 converter was reading higher value than usual and was becoming unstable (see **attachment 3: Trends**). The U2 trend on 5/29 show a stable fuel flow rate at 30 MW; however, the trend on 5/30 show the fuel flow signal to the converter had become unstable and at 25 MW the fuel converter sent a higher fuel flow value. The converter was replaced, reconfigured and tested to ensure the output signal from fuel flow to the converter was stable. The U2 trend for 6/2 returned to normal and the converter is reading a normal value at 49 MW.

Question 16 – Facility returned to compliance?

U2 came into compliance June, 1, 2020.

Canyon Power Plant ID# 153992
5/30/2020

First Run

	2_CO_LBHR #/hr	2_COlb_SUH pounds
16:23	224.14	3.74
16:24	424.22	10.81
16:25	39.73	11.42
16:26	10.11	11.64
16:27	7.28	11.22
16:28	5.49	11.86
16:29	4.15	11.93
16:30	3.57	11.99
16:31	2.79	12.03
16:32	2.19	12.07
16:33	3.62	12.13
16:34	12.88	12.35
16:35	14.32	12.58
16:36	14.38	12.82
16:37	16.62	13.1
16:38		
16:39		
16:40		
16:41		
16:42		
16:43		
16:44		
16:45		
16:46		
16:47		
16:48		
16:49		
16:50		
16:51		
16:52		
16:53		
16:54		
16:55		
16:56		
16:57		
16:58		

Canyon Power Plant Emission Compliance Log

5/30/20

ALL HRS OF OPERATION ACCORDING TO DAHS CLOCK		Unit 1		Unit 2		Unit 3		Unit 4	
		1st Start	2nd Start	1st Start	2nd Start	1st Start	2nd Start	1st Start	2nd Start
OPERATOR	UNIT	T.W.		T.W.	T.W.	T.W.	T.W.	T.W.	
Time On	DAHS TIME	1623		1623	1736	1623	1839	1623	
NOx LBS SUH during first 5 min. Startup	LBS	279		249	.92	1.4	.37	1.12	
CO LBS SUH during first 5 min. Startup	LBS	338		11.86	3.07	2.96	1.85	3.36	
NOx Corr after Compliance (< 2.5 PPM)	DAHS TIME	1639		1747	1642			1638	
	PPM	2.43		2.36	2.34			2.24	
CO Corr after Compliance (< 4.0 PPM)	DAHS TIME	1629		1742	1631	1846	1631		
	PPM	3.84		3.3	2.44	3.70	3.41		
Online Calibration (start 15 minutes prior to the end of hour)									
	DAHS TIME								
NOxC_1hr [Prior to Calibration < 2.5 PPM]	PPM								
COC_1hr [Prior to Calibration < 4.0 PPM]	PPM								
SHUTDOWN HOUR									
	DAHS TIME	2031			1820	1758	1831	2024	
NOxC_1hr [PRIOR TO SHUTDOWN < 2.5 PPM]	PPM	1.71			1.38	1.62	1.74	1.81	
COC_1hr [PRIOR TO SHUTDOWN < 4.0 PPM]	PPM	1.90			1.61	2.71	2.01	2.01	
NOxlb60m [PRIOR TO SHUTDOWN < 4.07 LBS]	LBS	1.91			3.46	1.77	1.75	1.81	
COlb60m [PRIOR TO SHUTDOWN < 4.15 LBS]	LBS	1.22			6.29	1.79	1.99	1.29	
Time Off	DAHS TIME				1925	1806			
OPERATOR	UNIT	T.W.			T.W.	T.W.	T.W.	T.W.	


	2_CO_LBHR #/hr	2_COlb_SUH pounds
16:59	0	
17:00	0	
17:01	0	
17:02	0	
17:03	0	
17:04	0	
17:05	0	
17:06	0	
17:07	0	
17:08	0	
17:09	0	
17:10	0	
17:11	0	
17:12	0	
17:13	0	
17:14	0	
17:15	0	
17:16	0	
17:17	0	
17:18	0	
17:19	0	
17:20	0	
17:21	0	
17:22	0	13.10 CO lbs/hr DAHS
17:23	0	11.6 CO lbs/hr permit limit
17:24	0	1.50 CO lbs/hr exceedance
17:25	0	
17:26	0	
17:27	0	
17:28	0	
17:29	0	
17:30	0	
17:31	0	
17:32	0	
17:33	0	
17:34	0	
17:35	0	
17:36	58.08	1.25
17:37	102.76	2.68
17:38	11.81	2.88
17:39	6.22	2.99
17:40	4.14	3.02
17:41	3.3	3.07
17:42	2.19	3.11
17:43	1.58	3.13
17:44	1.29	3.16
17:45	1.14	3.18
17:46	1.06	3.19
17:47	1.03	3.21
17:48	1.01	3.23
17:49	0.98	3.24

Second Run


Canyon Power Plant Emission Compliance Log

5/30/20

ALL HRS OF OPERATION ACCORDING TO DAHS CLOCK			UNIT 1		Unit 2		UNIT 3		Unit 4	
			1st Start	2nd Start	1st Start	2nd Start	1st Start	2nd Start	1st Start	2nd Start
OPERATOR	INITIALS		T-N		T-N	T-W	T-N	T-W	T-N	
Flame On	DAHS TIME		1623		1623	1736	1623	1839	1623	
NOx LBS SUH during first 5 min. Startup	LBS	If < 7 then OK to Proceed	0.79		2.49	.92	.64	.37	1.12	
CO LBS SUH during first 5 min. Startup	LBS	If < 7 then OK to Proceed	3.38		11.86	3.07	2.96	1.85	3.36	
NOx Corr after Compliance (< 2.5 PPM)	DAHS TIME		1639			1747	1642		1638	
	PPM		2.43			2.36	2.34		2.24	
CO Corr after Compliance (< 4.0 PPM)	DAHS TIME		1629			1742	1631	1846	1631	
	PPM		3.84			3.70	3.44	3.70	3.41	
Online Calibration (start 15 minutes prior to the end of hour)										
	DAHS TIME									
NOxC_1hr [Prior to Calibration < 2.5 PPM]	PPM									
COC_1hr [Prior to Calibration < 4.0 PPM]	PPM									
SHUTDOWN HOUR										
	DAHS TIME		2031			1830	1758	2031	2034	
NoxC_1hr [PRIOR TO SHUTDOWN < 2.5 PPM]	PPM		1.79			1.38	1.62	1.74	1.81	
COC_1hr [PRIOR TO SHUTDOWN < 4.0 PPM]	PPM		1.90			1.61	2.71	2.01	2.01	
Noxlb60m [PRIOR TO SHUTDOWN < 4.07 LBS]	LBS		1.91			3.46	1.77	1.75	1.81	
COlb60m [PRIOR TO SHUTDOWN < 4.15 LBS]	LBS		1.22			6.29	1.79	1.99	1.29	
Flame Off	DAHS TIME					1835	1806			
OPERATOR	INITIALS		T-N			T-N	T-W	T-W	T-N	

[illegible]

CEMS_DATA_TREND




5/30/2020 6:45:00 PM

5/30/2020 7:45:00 PM

[illegible]

1-800-



6/2/2020 7:00:00 PM

[illegible]

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 10
CONDITION HAZ-1

List of Hazardous Materials contained at the facility:

- **Aqua Ammonia 19%**
- **Batteries**
- **Bromine**
- **Calibration gases for the CEMS**
- **CO₂**
- **Diesel Fuel**
- **Fire suppression chemicals**
- **Florescent light bulbs**
- **Freon for the chiller systems R-123**
- **Gas Turbine oil**
- **Gas compressor oil**
- **Reagents for the water treatment system**
- **SF₆ in switch gear**
- **Anti-scalent RL 9007**
- **Sodium Hydroxide**
- **ChemTreat BL124**
- **Microbiocide ChemTreat CL2156**
- **Closed System Buffer Formula 6150**
- **ChemTreat CL6855**
- **12.5% Sodium Hypochlorite Solution**
- **RL 1125**
- **Simple Green**
- **ChemTreat CL41**
- **ChemTreat CL6855**
- **Formula 2530LT**
- **Conntect 5000**
- **Powerback Concentrate with Anti-Foam Agent**

[illegible]



CALIFORNIA
AIR RESOURCES BOARD
Phone: 1 (916) 324-2517
Email: reftrackinfo@arb.ca.gov



File Report for "Canyon Power Plant"

Year of Filing: 2019

Submitted Date: 02/18/2020

Company Profile

Company Name : City of Anaheim Federal tax ID : *****970

Contact Person Details

Person Name : Mr. Ronald Hoffard (Generation Manager)
Phone : Contact: 7147654536
Email : rhoffard@anaheim.net

Mailing Address Information

3071 East Miraloma Ave.
Anaheim, 92806
CA

Billing Address Information

3071 East Miraloma Ave.
Anaheim, 92806
Anaheim

Facility Profile

Facility Name : Canyon Power Plant Federal tax ID : *****970

Contact Person Details

Person Name : Mr. Ronald Hoffard (Generation Manager)
Phone : Contact: 7147654536
Email : rhoffard@anaheim.net

Mailing Address Information

3071 East Miraloma Ave.
Anaheim, 92806
CA

Billing Address Information

3071 East Miraloma Ave.
Anaheim, 92806
Anaheim

Refrigeration System Listing

Number	System ID	Full Charge (lbs)	Refrigerant Type	Installation Date	Temperature Class	Equipment Type	Manufacturer	Operational Status	Model	Model Year	Serial Number	Location	Floor Plan (Y/N)
1	CH-100	5200.00	R-123	05/12/2011	Medium	Chiller (Refrigeration/Industrial Process Cooling)	Trane	Normal Operation	CDHF3000	2011	L10A00350	North side of facility, in dedicated chiller enclosure.	Y
2	CH-200	5200.00	R-123	05/12/2011	Medium	Chiller (Refrigeration/Industrial Process Cooling)	Trane	Normal Operation	CDHF3000	2011	L10B00882	North side of facility, in dedicated chiller enclosure.	Y

Leak detection System

Number	ALD ID	Refrigeration System ID	Installation Date	ALD Type	Detection Limit	Alarm Set Point	Concentration Monitor Type	Manufacturer	Number of Sensors	Sensor Type	Sensor Manufacturer	Location of Sensors/Inlets
1	301-IRF A	CH-100CH-200	05/12/2011	Concentration Monitor (Direct System)	10.00	100	0	Honeywell	2	Infra red	Vulcain/honeywell	1 foot above floor

Refrigeration System Inspection and Servicing

Number	Service Date	System ID	Leaks Detected?	Date Leak Detected	Date Leak Repaired	Number of Days	Refrigerant Added (lbs)	Cause of Leak	Service Provided	Date of Initial VT	Date of Follow-up VT	Purpose of Added Refrigerant	Technician Name	Certificate #	Certificate Type
1	04/16/2019	CH-100	No			0	0.00								
2	04/16/2019	CH-200	No			0	0.00								
3	09/26/2019	CH-200	No			0	0.00								
4	09/29/2019	CH-100	No			0	0.00								
5	10/03/2019	CH-100	No			0	0.00								
6	10/03/2019	CH-200	No			0	0.00								
7	10/08/2019	CH-100	No			0	0.00								
8	10/08/2019	CH-200	No			0	0.00								
9	11/07/2019	CH-200	No			0	0.00								
10	11/07/2019	CH-100	Yes	11/06/2019	11/06/2019	0	0.00	Purge - Solenoids Valves		11/07/2019	11/07/2019		Gilbert Chavez, Jr.	000223692	Universal

Leak Detection System Inspection and Servicing

Number	Service Date	ALD ID	Service Type	Description of Service
1	08/06/2019	301-IRF A	Callibration	Performed calibration test on Ref Monitor and calibrated both sensors.

Refrigerant Purchase Information

Type	Total Purchased (lbs.)	Total Charged (lbs.)	Total Recovered (lbs.)	Total Stored (lbs.)	Total Shipped (lbs.)
R-123	0.00	0.00	0.00	0.00	0.00

Comment

Submitted By: Ronald Hoffard



CALIFORNIA
AIR RESOURCES BOARD
Phone: (916) 324-2517
Email: rmp@arb.ca.gov
URL: www.arb.ca.gov/rmp/rmp.htm

Invoice Detail

Invoice No: 117679

Invoice For Year: 2019

ARB REFERENCE CODE: RMP

Dated: 02/18/2020

City of Anaheim			
#	Facility Name	Amount Due(\$)	Total (\$)
1	Canyon Power Plant (CIT003-001)	370.00	370.00
TOTAL CHARGES			370.00

Please return a copy on the invoice with your payment to the address below.

"Checks should be made payable to the California Air Resources Board.

If required for your company records, the CARB Federal Tax ID is 68-0288069. A \$10 service fee may apply for returned checks."

Air Resources Board

Attn: Accounting

P.O. Box 1436

1001 I St., Floor 20

Sacramento, CA 95812-1436



CALIFORNIA
AIR RESOURCES BOARD
Phone: (916) 324-2517
Email: reftrackinfo@arb.ca.gov



Online Payment Receipt

Invoice No: 117679

Dated: 2020-02-18

Invoice For Year: 2019

Payment Amount: \$370.00

ARB Reference Code: RMP

Transaction Time: 02/18/2020 12:34:43 PM

Payment Transaction Id: 180220AC0-DF26D133-CADF-4763-9A24-998B7691A613

Payment Result: APPROVAL

Payment Approval Code: 018368

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 11
CONDITION HAZ-8

In the annual compliance report, the project owner shall include the following statements:

“All current project employee and appropriate contractor background investigations have been performed and that updated certification statements have been appended to the operations security plan”.

All current project employee and appropriate contractor background investigations have been performed and that updated certification statements have been appended to the operations security plan.

“The operations security plan includes all current hazardous materials transport vendor certifications for security plans and employee background investigations”.

The operations security plan includes all current hazardous materials transport vendor certifications for security plans and employee background investigations.

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 12
SOIL & WATER USE REPORT-7

Monthly Water Reading Reports

Company: City of Anaheim/Canyon Power Plant
 Plant Location: 3071 E. Miraloma Ave.
 City/State/Zip: Anaheim, CA 92806

Period Start: 1/1/2020
 Period End: 12/31/2020

Recycle Water Usage

Annual Total Gallons	Annual Total Acre Feet	Monthly Average Gallons	Monthly Average Acre Feet	Monthly Minimum Gallons	Monthly Minimum Acre Feet	Monthly Maximum Gallons	Monthly Maximum Acre Feet	Average Gallons Per Day
21,643,884	66.42	1,803,657	5.54	513,791	1.58	4,192,820	12.87	59,519

Company: City of Anaheim/Canyon Power Plant
 Plant Location: 3071 E. Miraloma Ave.
 City/State/Zip: Anaheim, CA 92806

Period Start: 1/1/2020
 Period End: 12/31/2020

Potable Water Usage

Annual Total Gallons	Annual Total Acre Feet	Monthly Average Gallons	Monthly Average Acre Feet	Monthly Minimum Gallons	Monthly Minimum Acre Feet	Monthly Maximum Gallons	Monthly Maximum Acre Feet	Average Gallons Per Day
1,033,962	3.17	43,082	0.13	0.00	0.00	664,268	2.04	1,402

Annual Data

	Recycle Water		Portable Water	
	Annual Total Acre Feet	Annual Total Gallons	Annual Total Acre Feet	Annual Total Gallons
2018	73.09	23,817,912	6.99	2,277,132
2019	60.04	19,563,004	0.33	106,201
2020	66.42	21,643,884	3.17	1,033,962
Average	66.52	21,674,933	3.50	1,139,098
Min	60.04	19,563,004	0.33	106,201
Max	73.09	23,817,912	6.99	2,277,132

Company: City of Anaheim
Plant Location: 3071 E. Miraloma Ave.
City/State/Zip: Anaheim, CA 92806

Period Start: 1/1/2020
Period End: 12/31/2020

Recycled Water Usage

Date	Start Cubic-ft	End Cubic-ft	Total Cubic-ft	Month gal	Daily gal	Month Acre-ft
1/1/2019	20,249,100	20,809,600	560,500	4,192,820.25	135,252.27	12.87
2/1/2019	20,809,600	21,210,000	400,400	2,995,192.20	106,971.15	9.19
3/1/2019	21,210,000	21,325,100	115,100	861,005.55	27,774.37	2.64
4/1/2019	21,325,100	21,433,300	108,200	809,390.10	26,979.67	2.48
5/1/2019	21,433,300	21,529,200	95,900	717,379.95	23,141.29	2.20
6/1/2019	21,529,200	21,656,000	126,800	948,527.40	31,617.58	2.91
7/1/2019	21,656,000	21,963,800	307,800	2,302,497.90	74,274.13	7.07
8/1/2019	21,963,800	22,360,299	396,499	2,966,010.77	95,677.77	9.10
9/1/2019	22,360,299	22,703,700	343,401	2,568,811.18	85,627.04	7.88
10/1/2019	22,703,700	22,945,500	241,800	1,808,784.90	58,347.90	5.55
11/1/2019	22,945,500	23,073,790	128,290	959,673.35	31,989.11	2.95
12/1/2019	23,073,790	23,142,474	68,684	513,790.66	16,573.89	1.58
Annual Total:			2,893,374.00	21,643,884.21		66.42
Average:			241,114.50	1,803,657.02	59,518.85	5.54
Monthly Minimum:			68,684.00	513,790.66		1.58
Monthly Maximum:			560,500.00	4,192,820.25		12.87

Company: City of Anaheim
Plant Location: 3071 E. Miraloma Ave.
City/State/Zip: Anaheim, CA 92806

Period Start: 1/1/2020
Period End: 12/31/2020

Potable Water Usage

HCF-1

Date	Start Cubic-ft	End Cubic-ft	Total Cubic-ft	Month gal	Daily gal	Month Acre-ft
1/1/2020	828,600	828,600	0.00	0.00	0.00	0.00
2/1/2020	828,600	828,700	100.00	748.05	26.72	0.00
3/1/2020	828,700	828,700	0.00	0.00	0.00	0.00
4/1/2020	828,700	856,400	27,700.00	207,209.85	6,907.00	0.64
5/1/2020	856,400	945,200	88,800.00	664,268.40	21,428.01	2.04
6/1/2020	945,200	945,400	200.00	1,496.10	49.87	0.00
7/1/2020	945,400	945,400	0.00	0.00	0.00	0.00
8/1/2020	945,400	945,400	0.00	0.00	0.00	0.00
9/1/2020	945,400	945,476	76.00	568.52	18.95	0.00
10/1/2020	945,476	945,478	2.00	14.96	0.48	0.00
11/1/2020	945,478	945,480	2.00	14.96	0.50	0.00
12/1/2020	945,480	945,484	4.00	29.92	0.97	0.00
Annual Total:			116,884.00	874,350.76		2.68
Average:			9,740.33	72,862.56	2,369.37	0.22
Monthly Minimum:			0.00	0.00		0.00
Monthly Maximum:			88,800.00	664,268.40		2.04

HCF-2

Date	Start Cubic-ft	End Cubic-ft	Total Cubic-ft	Month gal	Daily gal	Month Acre-ft
1/1/2020	225,859.00	226,293.00	434.00	3,246.54	104.73	0.01
2/1/2020	226,293.00	226,888.00	595.00	4,450.90	158.96	0.01
3/1/2020	226,888.00	227,661.00	773.00	5,782.43	186.53	0.02
4/1/2020	227,661.00	230,162.00	2,501.00	18,708.73	623.62	0.06
5/1/2020	230,162.00	236,939.00	6,777.00	50,695.35	1,635.33	0.16
6/1/2020	236,939.00	238,203.00	1,264.00	9,455.35	315.18	0.03
7/1/2020	238,203.00	240,696.00	2,493.00	18,648.89	601.58	0.06
8/1/2020	240,696.00	242,209.00	1,513.00	11,318.00	365.10	0.03
9/1/2020	242,209.00	243,774.00	1,565.00	11,706.98	390.23	0.04
10/1/2020	243,774.00	245,514.00	1,740.00	13,016.07	419.87	0.04
11/1/2020	245,514.00	246,579.00	1,065.00	7,966.73	265.56	0.02
12/1/2020	246,579.00	247,196.00	617.00	4,615.47	148.89	0.01
Annual Total:			21,337.00	159,611.43		0.49
Average:			1,778.08	13,300.95	434.63	0.04
Monthly Minimum:			434.00	3,246.54		0.01
Monthly Maximum:			6,777.00	50,695.35		0.16

Summary for both meters

Annual Total:	138,221.00	1,033,962.19		3.17
Average:	5759.21	43081.76	1402.00	0.13
Monthly Minimum:	0.00	0.00		0.00
Monthly Maximum:	88,800.00	664,268.40		2.04

OCWD/Anaheim Distribution & Sale of GWRS Water Supplied

TO	Anaheim Public Utilities Dept.	CUSTOMER ID:	20250	METER ID:	21024735
	Attn: Al Shaikh	RATE:	\$602 / AF	UNIT:	GALLONS
	201 S. Anaheim Blvd. Suite #601	ACCOUNT:	1001.41500	MULTIPLIER:	X1000
	Anaheim, CA 92805	AGMT NO:	6075	FISCAL YEAR:	2019-2020
				READ DATE:	3/31/2020

LOCATION:	CANYON POWER PLANT (CPP)					
MONTH:	JULY 2019	AUGUST 2019	SEPT 2019	OCT 2019	NOV 2019	DEC 2019
(1) Beginning Read	160,867	162,779	164,926	166,194	168,196	169,901
(2) Ending Read	162,779	164,926	166,194	168,196	169,901	172,311
Total Units (Gallons x1000)	1,912,000	2,147,000	1,268,000	2,002,000	1,705,000	2,410,000
Total Acre Feet	5.87	6.59	3.89	6.15	5.23	7.40
AMOUNT DUE:	\$3,533.74	\$3,967.18	\$2,341.78	\$3,702.30	\$3,148.46	\$4,448.78

LOCATION:	CANYON POWER PLANT (CPP)					
MONTH:	JAN 2020	FEB 2020	MAR 2020	APR 2020	MAY 2020	JUNE 2020
(1) Beginning Read	172,311	175,470	178,835	178,835	179,444	180,941
(2) Ending Read	175,470	178,835	181,277	179,444	180,941	182,495
Total Units (Gallons x1000)	3,159,000	3,365,000	2,442,000	609,000	1,497,000	1,554,000
Total Acre Feet	9.70	10.33	7.50	1.87	4.61	4.77
AMOUNT DUE:	\$5,839.40	\$6,218.66	\$4,515.00	\$1,125.74	\$2,775.22	\$2,871.54

OCWD/Anaheim Distribution & Sale of GWRS Water Supplied

TO Anaheim Public Utilities Dept.	CUSTOMER ID: 20250	METER ID: 21024735
Attn: Al Shaikh	RATE: \$689 / AF	UNIT: GALLONS
201 S. Anaheim Blvd. Suite #601	ACCOUNT: 1001.41500	MULTIPLIER: X1000
Anaheim, CA 92805	AGMT NO: 6075	FISCAL YEAR: 2020-2021
		READ DATE: 12/31/2020

LOCATION:	CANYON POWER PLANT (CPP)					
MONTH:	JULY 2020	AUGUST 2020	SEPT 2020	OCT 2020	NOV 2020	DEC 2020
(1) Beginning Read	182,495	184,549	187,998	190,542	192,539	193,254
(2) Ending Read	184,549	187,998	190,542	192,539	193,254	194,216
Total Units (Gallons x1000)	2,054,000	3,449,000	2,544,000	1,997,000	715,000	962,000
Total Acre Feet	6.31	10.59	7.81	6.13	2.20	2.95
Old Rate \$602/AF:	\$3,798.62	\$6,375.18	\$0.00			
New Rate \$689/AF:	\$4,347.59	\$7,296.51	\$5,381.09	\$4,223.57	\$1,515.80	\$2,032.55
Difference:	\$548.97	\$921.33	\$5,381.09			

LOCATION:	CANYON POWER PLANT (CPP)					
MONTH:	JAN 2021	FEB 2021	MAR 2021	APR 2021	MAY 2021	JUNE 2021
(1) Beginning Read						
(2) Ending Read						
Total Units (Gallons x1000)						
Total Acre Feet						
AMOUNT DUE:						

Wastewater Flow Meter Calibration Report

January 22, 2021

Ms. Bertha A. Hernandez
Environmental Services Specialist
3071 E. Miraloma Ave.
Anaheim, CA 92806

Subject: Effluent Flow Meter Hydraulic Calibration Report
(Ref: Job # F17M1652)

Facility: City of Anaheim
Canyon Power Plant
3071 E. Miraloma Ave.
Anaheim, CA 92806
I.W. Permit No. 1-600296

Dear Ms. Hernandez,

Enclosed are two copies of your wastewater flow meter calibration report for the hydraulic test conducted on January 20, 2021. Please sign the original report on the last page where indicated and mail it to the Orange County Sanitation District with the cover letter addressed to Mila Kleinbergs. An envelope with a mailing label is also enclosed for your convenience.

We will contact you in advance of the next scheduled calibration. Once again, let me thank you for entrusting The Conservtech Group and its Flowtrace Division with your environmental needs. If you have any questions about this report or any of the environmental engineering services that we provide, I hope that you will not hesitate to contact me. I can be reached via e-mail at bob@conservtechgroup.com or by phone at 323-867-9044.

Best regards,



Robert J. MacDonald, P.E., CPP
President & Principal Engineer

enclosures

January 22, 2021

Ms. Mila Kleinbergs
Source Control Program
Orange County Sanitation Districts
10844 Ellis Avenue
Fountain Valley, CA 92708

Subject: Effluent Flow Meter Hydraulic Calibration Report


Facility: City of Anaheim
Canyon Power Plant
3071 E. Miraloma Ave.
Anaheim, CA 92806
I.W. Permit No. 1-600296

Dear Ms. Kleinbergs,

Enclosed is our report on the effluent flow meter hydraulic calibration completed at the subject facility on January 20, 2021. The calibration was conducted in accordance with requirements of the Orange County Sanitation District, and the meter was determined to be operating within $\pm 5\%$ accuracy limits for the entire range tested.

If you have any questions regarding this calibration report, please contact me directly, or Bertha A. Hernandez, Environmental Services Specialist.

Sincerely,



Robert J. MacDonald, P.E., CPP
President & Principal Engineer

Enclosures

cc: Bertha A. Hernandez, Environmental Services Specialist

**WASTEWATER FLOW METER
HYDRAULIC CALIBRATION**

PREPARED BY



FOR

**City of Anaheim
Canyon Power Plant
3071 E. Miraloma Ave.
Anaheim, CA 92806**

I.W. Permit No. 1-600296

January 20, 2021



EFFLUENT FLOW METER CALIBRATION REPORT

Company Name: City of Anaheim

Permit No.: 1-600296

Discharge Address: 3071 E. Miraloma Ave. Anaheim, CA 92806

Mailing Address: 201 S. Anaheim Blvd. Suite 1101 Anaheim, CA 92805

Meter Location *[Use Meter Location Form (page 3) to identify location]*

☐ a ☐ b ☐ c ☐ d ☒ Other: (Attach sketch)

Effluent Meter Description

Open Channel

A. Flume:

- ☐ Parshall Flume
☐ Palmer-Bowlus Flume
☐ Trapezoidal
☐ Other, Specify: _____

B. Weir.

- ☐ V-notch
☐ Rectangular
☐ Trapezoidal
☐ Other, Specify: _____

C. Other

Description: _____

In-line

- ☒ Magnetic
☐ Propeller
☐ Ultrasonic
☐ Other, Specify: _____

Effluent Meter Description

Primary Element

Size: 4"

Manufacturer: Badger

Meter Series 2000

Secondary Element

Manufacturer: N/A

Recorder's 100% span = N/A GPM

Totalizer Units: = 1 Gallons per Count

Sampling Signal Contact Closure Frequency: 1 closure per N/A gallons discharged.

Current Facility Wastewater Discharge Rate to Sewer Determined by Calibration Engineer

Average 200 GPM

Peak 300 GPM



EFFLUENT FLOW METER CALIBRATION REPORT

5. Calibration Results

Type of Calibration: ☒ Hydraulic ☐ Instrument

Calibration System		Existing Meter				Error (%)	
Flow Rate GPM	Total Discharge Gallons	Primary Element's Head	Flow Rate, GPM		Total Discharge Gallons	Recorder	Totalizer
			Indicator	Recorder			
287	890	--	290	--	902	--	1.3%
249	767	--	252	--	780	--	1.7%
199	611	--	203	--	622	--	1.8%
150	468	--	152	--	476	--	1.7%
103	316	--	105	--	323	--	2.2%

A copy of all data collected and of any calculations performed must be attached to this form.

6. Method of Calibration Results *(attach additional sheets if necessary)*

Hydraulic: (For in line flow meters describe calibration/simulator system)





Various flow rates were achieved using 150' of 2.5" fire hose from a local hydrant to the test meter. A 2" Halliburton turbine was used to measure the water flow. At each rate tested, the meter totalizer was timed using an electronic stopwatch for a number of counts. The accumulated volume was then compared to the actual volume to determine the totalizer accuracy.

Instrument:

7. Corrective Measures *(describe condition of flow meter prior to calibration and state if any adjustments were made):*

No corrective measures were required.

EFFLUENT FLOW METER LOCATION FORM




☒ Other

Please provide a schematic of the location of the effluent flow meter

Attachment:

Effluent Flow Meter Location





EFFLUENT FLOW METER MAINTENANCE RECORDS

Company Name: City of Anaheim

Permit No.: 1-600296

Discharge Address: 3071 E. Miraloma Ave., Anaheim, CA 92806

Mailing Address: 201 S. Anaheim Blvd., Suite 1101, Anaheim, CA 92805

Name of Responsible Person : Bertha A Hernandez

Telephone No. 714-765-4536

Recorder's 100% span = N/A GPM

Totalizer: 1 Gallons per Count

Type of Flow Meter: 4" Badger Meter Series 2000

Recorder Chart Change Frequency: ☐ Daily ☐ Weekly ☐ Monthly *(not applicable)*


REGULAR CLEANING MAINTENANCE				
Primary Element Cleaned	Level Measuring Equipment Cleaned	Other (describe)	Date	By
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	02/11/15	Yip / Paz
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	02/11/16	Yip / Paz
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	02/09/17	Yip / Paz
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	01/10/18	Yip / Vitug
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	01/10/19	Paz / Gomez
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	01/10/20	Yip / Gomez
N/A	N/A	Hydraulic Calibration by Flowtrace Division of The Conservtech Group	01/20/21	Yip / Gomez



CERTIFICATION OF CALIBRATION CHECK

(Certification of Test Results by a California Registered Professional Engineer)

I hereby certify that I am knowledgeable in the field of wastewater flow measurement and that I have supervised the calibration of the flow monitoring system as described on the previous page, and also have reviewed and approved all details of the method of calibration. I consider the calibration method and procedures used to be technically sound, and assume professional responsibility for the validity and accuracy of the results reported.


(Signature)

Robert J. MacDonald, P.E.
(Full Name – Please Print or Type)



M29874 Expires 6/30/22
(California Professional
Engineering Certification No.)

Mechanical
(Engineering Discipline)


1/22/2021
(Date)

CERTIFICATION OF TEST RESULTS BY AN ADMINISTRATIVE OFFICIAL OF THE COMPANY

City of Anaheim
(Company Name)

1-600296
(Permit No.)

I hereby certify that the flow monitoring system certified as properly calibrated above is so arranged and operated, so as to accurately measure and record the industrial wastewater flow to the sewer system.


(Signature)

RON HOFFARD
(Full Name – Please Print or Type)

GENERATION PLANT MGR.
(Administrative Position in Company)

1/25/2021
(Date)

Appendix:


Calculations Sheet
Field Calibration Data
Calibration Certificate

CERTIFICATE OF CALIBRATION

CUSTOMER: CONSERVTECH COMMERCE, CA
PO NUMBER: 9354
INST. MANUFACTURER: HALLIBURTON
INST. DESCRIPTION: TURBINE METER
MODEL NUMBER: 458.99101 (2")
SERIAL NUMBER: 2SBF3677
RATED UNCERTAINTY: +/- 0.5% RD
UNCERTAINTY GIVEN: TOTAL measurement uncertainty +/- .186% RD K=2
CALIBRATION DATE: 08/20/20
CALIBRATION DUE: 08/20/21
PROCEDURE: NAVAIR17-20MG, NIST250
CALIBRATION FLUID: H2O @ 70F
STANDARD(S) USED: A710, A14 DUE 4-2021
NIST TRACE # S: 1446135470, 1453296155
AMBIENT CONDITIONS: 763mm HGA 44 % RH 74°F
CERTIFICATE FILE #: 420148.3677.20

NOTES: AS RECEIVED / AS LEFT WITHIN SPECS. **CALIBRATED WITH DMC SENSOR COIL **

TEST POINT NUMBER	UUT INDICATED FREQ(HZ)	ACTUAL DM STD GPM	ACTUAL K.FACTOR PUL/GAL.	ACTUAL DM STD GPM	ACTUAL K.FACTOR PUL/GAL.
1	17.664	19.684	53.8438	20.080	53.9087
2	37.518	41.599	54.1137	37.480	54.1025
3	43.914	48.603	54.2113	47.590	54.2087
4	55.842	61.694	54.3089	58.080	54.3012
5	67.726	74.792	54.3317	70.223	54.3287
6	80.312	88.661	54.3501	90.057	54.3568
7	99.708	110.034	54.3694	114.308	54.3807
8	127.511	140.661	54.3906	145.547	54.4001
9	149.595	164.991	54.4013	177.547	54.3958
10	187.451	206.776	54.3924	213.308	54.3887
11	234.478	258.663	54.3899	248.958	54.3879
12	266.238	293.714	54.3872	291.110	54.3868



All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NC SL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 11133 Winners Circle • Los Alamitos, CA 90720
 Phone (714) 827-1215 • Fax (714) 827-0823

This Calibration Certificate shall not be re-used, except in full, without approval of DICK MUNN'S COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date:

Approved By:

Calibration Technician:

Recorder: MAX = <u> -- </u> GPM AVG = <u> 200 </u> PK = <u> 300 </u>	Totalizer: Finish: <u> 96899119 </u> Start: <u> 96893222 </u> Diff: <u> 5897 </u> MULT: <u> 1 </u> Total: <u> 5897 </u> gallons	Client: <u>City of Anaheim - Canyon Power Plant</u> Date: <u>1/20/21</u> IW#: <u>1-600296</u> Element: <u>4" Pipe</u> Instrument: <u>4" Badger Meter M2000</u> Recorder: <u> ✓ </u>
Sampler: Contact Closure = <u> N/A </u> gallons/pulse		

Calibrated Flows and Data									Meter		Recorder			Totalizer	
Turbine		Manometer - inches					Duration	Total	W.C.	Flow	Reading		Error	Total	Error
cycles	gpm	+	-	Δ	w.c.	gpm	min	gal	in.	gpm	%	gpm	%	gal	%
	287						3.10	890		290				902	1.3
	249						3.08	767		252				780	1.7
	199						3.07	611		203				622	1.8
	150						3.12	468		152				476	1.7
	103						3.07	316		105				323	2.2

Calibration Type <div style="margin-left: 100px;"> <u> </u> Instrumentation <u> X </u> Hydraulic </div>	Hydraulic Meter Used: <u> </u> Turbine Meter, 1", Haliburton, Threaded <u> </u> Turbine Meter, 1.5", XO Technologies, 150# Flange <u> X </u> Turbine Meter, 2", Haliburton, flanged <u> </u> Turbine Meter, 4", XO Technologies, 150# Flange <u> </u> Turbine Meter, 4", Haliburton, flanged Other: <u> </u> K: 4.86
---	--

Notes: <div style="display: flex; justify-content: space-around;"> <div style="text-align: left;"> ① - $\begin{array}{r} 95610 \\ - 94708 \\ \hline 902 \end{array} @ 3:06$ </div> <div style="text-align: left;"> ② - $\begin{array}{r} 96883 \\ - 96103 \\ \hline 780 \end{array} @ 3:05$ </div> </div> <div style="display: flex; justify-content: space-around; margin-top: 20px;"> <div style="text-align: left;"> ③ - $\begin{array}{r} 97786 \\ - 97164 \\ \hline 622 \end{array} @ 3:04$ </div> <div style="text-align: left;"> ④ - $\begin{array}{r} 98512 \\ - 98036 \\ \hline 476 \end{array} @ 3:07$ </div> </div> <div style="display: flex; justify-content: space-around; margin-top: 20px;"> <div style="text-align: left;"> ⑤ - $\begin{array}{r} 99026 \\ - 98703 \\ \hline 323 \end{array} @ 3:04$ </div> </div>	
--	--

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 13
SOIL & WATER REPORTS-8

**OCSD Wastewater Quality Semi-Annual
Monitoring Reports**

TX Result Report

P 1

04/22/2020 13:52

Serial No. A7PY011022705

TC: 45610

Addressee	Start Time	Time	Prints	Result	Note
OCSD	04-22 13:45	00:06:38	008/008	OK	

Note TMR:Timer TX, POL:Polling, ORG:Original Size Setting, FME:Frame Erase TX,
 DPS:Page Separation TX, RIX:Mix of Original TX, CALL:Manual TX, CSAC:CSAC,
 FWD:Forward, PC:PC-FAX, BND:Double-Sided Binding Direction, Sp:Special Original,
 FCODE:F-code, RTX:Re-TX, RLV:Relay, MBX:Confidential, BUL:Bulletin, SIP:SIP Fax,
 IPADR:IP Address Fax, I-FAX:Internet Fax

Result OK: Communication OK, S-OK: Stop Communication, PW-OFF: Power Switch OFF,
 TEL: RX from TEL, NG: Other Error, Cont: Continue, No Ans: No Answer,
 Refuse: Receipt Refused, Busy: Busy, H-Full:Memory Full, LOVR:Receiving length over,
 POVR:Receiving page over, FIL:File Error, DC:Decode Error, MDN:MDN Response Error,
 DSN:DSN Response Error, PRINT:Compulsory Memory Document Print,
 DEL:Compulsory Memory Document Delete, SEND:Compulsory Memory Document Send.



CITY OF ANAHEIM
PUBLIC UTILITIES DEPARTMENT
 Environmental Services
 Letter of Transmittal

To:	Ms. Mila Kleinbergs Orange County Sanitation District Resource Protection Division 10844 Ellis Avenue Fountain Valley, CA 92708-7018	Date:	04/22/2020
		Project	Canyon Power Plant 3071 E. Miraloma Ave. Anaheim, CA 92806
		Subject:	Semi-Annual Self-Monitoring

We are sending you:

Copy of Original	Description
1	Completed Semi-Annual Form OCSD Self-Monitoring Form for City of Anaheim Canyon Power Plant (Permit No. 1-800296).

These are transmitted:

<input checked="" type="checkbox"/> 1	As requested	<input type="checkbox"/>	For your action	<input type="checkbox"/>	For your files
<input type="checkbox"/>	For approval	<input type="checkbox"/>	For your review	<input type="checkbox"/>	For your information

Via: ☐ US Mail ☒ FAX # 8 of pgs. ☐ Hand Delivery
 (714) 593-7799

Remarks: Please contact me at (714) 765-7481 or bhernandez@anaheim.net if you have any questions regarding this submittal.

By: Bertha A Hernandez, Environmental Services Specialist



CITY OF ANAHEIM
PUBLIC UTILITIES DEPARTMENT
Environmental Services
Letter of Transmittal

To:	Ms. Mila Kleinbergs Orange County Sanitation District Resource Protection Division 10844 Ellis Avenue Fountain Valley, CA 92708-7018	Date:	04/22/2020
		Project	Canyon Power Plant 3071 E. Miraloma Ave. Anaheim, CA 92806
		Subject:	Semi-Annual Self-Monitoring

We are sending you:

Copy of Original	Description
1	Completed Semi-Annual Form OCSD Self-Monitoring Form for City of Anaheim Canyon Power Plant (Permit No. 1-600296).

These are transmitted:

<input checked="" type="checkbox"/> 1	As requested	<input type="checkbox"/>	For your action	<input type="checkbox"/>	For your files
<input type="checkbox"/>	For approval	<input type="checkbox"/>	For your review	<input type="checkbox"/>	For your information

Via: ☐ US Mail ☒ FAX # 8 of pgs. ☐ Hand Delivery
(714) 593-7799

Remarks:

Please contact me at (714) 765-7481 or bhernandez@anaheim.net if you have any questions regarding this submittal.

By:  Bertha A Hernandez, Environmental Services Specialist



ORANGE COUNTY SANITATION DISTRICT SELF-MONITORING FORM

March 15, 2020

Ronald Hoffard, GENERATION PLANT MANAGER
City of Anaheim, Canyon Power Plant
3071 E Miraloma Ave.
Anaheim, CA 92806

Subject: **REMINDER TO CONDUCT SELF-MONITORING**
Permit No. 1-600296

Please be reminded that Self-Monitoring must be conducted between **April 01, 2020 -- April 16, 2020** in accordance with your company's permit requirements. Self-Monitoring must be conducted during a production day in accordance with the guidelines detailed in your company's permit.

It is your responsibility to comply with the requirements set forth in your company's permit. Failure to comply with all the directives, conditions, and requirements of the permit may result in enforcement action against your company.

If your company's permit shows a self-monitoring requirement for total toxic organics (TTOs) and your company has received a waiver from this self-monitoring, you are now required to submit a signed TTOs SMR form to us to comply with the TTO waiver requirements of the U.S. Environmental Protection Agency. Please indicate in the "Sample Comments" that you have received a TTOs self-monitoring waiver from us.

For permittees that have monthly as well as quarterly and/or semi-annual self-monitoring requirements, the forms may list more than the SMR constituents required for the monthly self-monitoring. We ask that you adhere to your permit's self-monitoring requirements and sample only for the constituent(s) required on a monthly basis except when the quarterly and semi-annual self-monitoring are also required in the same month, in which case all constituents listed on the form must be analyzed for as specified in your permit.

Finally, for those who are required to submit meter readings, a list of the meter readings submitted within the last year is attached to the SMR form for your reference and comparison to current readings.

Thank you for your patience and cooperation. If you have any questions, please contact Mila Kleinbergs at 714-593-7408.

Mila Kleinbergs
Senior Engineer



ORANGE COUNTY SANITATION DISTRICT SELF-MONITORING FORM

SMR No.: S-145452

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

Sampling Dates: 04/01/2020 to 04/16/2020Submit By Date: 04/30/2020Sample Start Date: 04/08/2020Sample End Date: 04/09/2020Sample Start Time: 1300 PMSample End Time: 1300 PM

Sampling Point Location: Sampling Structure located in the center of the site

Contact Person:

RONALD HOFFARD

Contact Phone:

714-765-4536

Contact Email:

RHOFFARD@ANAHEIM.NET
☐ No Discharge

Water Meter Readings: (If this is a batch discharge, enter volume only)

Location	Meter Type	Meter ID	Stop Reading	Start Reading	Volume	Units	Digits	Int
Center of site adjacent to the final clarifier/vault	Effluent Flow Meter	EM-1-600296	<u>91636048</u>	<u>91616086</u>	<u>19962</u>	G	9	

Composite

Sample Results: (If constituent is not detected or is less than detection limit, enter as reported in the lab results.)

Constituent	Result	Units	EPA Method
BOD T	<u>11.0</u>	mg/L	<u>SM 5210B</u>
TSS	<u>N.D</u>	mg/L	<u>SM 2540D</u>

Sample Comments:

To Submit Data - Fax: (714) 593-7799 or
Mail: Orange County Sanitation District, Resource
 Protection Division, 10844 Ellis Avenue, Fountain Valley,
 CA, 92708-7018



Questions: Contact Isabel Melendez at 714-593-7313

Ronald Hoffard, please initial each page and submit all pages



**ORANGE COUNTY SANITATION DISTRICT
SELF-MONITORING FORM**

SMR No.: S-145452

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

**This form must be completely filled out and Laboratory Analysis Report
and Chain of Custody must be attached.**

Please check if composite sample was obtained using an automatic sampling device: () Yes () No

In accordance with 40 CFR 403.12, the results presented herein must be verified and signed under penalty of perjury by: (i) a responsible corporate officer; (ii) general partner or proprietor; or (iii) a representative who has responsibility for the overall operation of the permitted facility, who has been authorized by the corporate officer, general partner or proprietor to sign such reports, and such authorization has been made in writing and submitted to the District.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. [40 C.F.R. § 403.6(a)(2)(ii) (2005)]

R. Hoffard
Signature (Ronald Hoffard)

Title (GENERATION PLANT MANAGER)

4/22/20
Date

RONALD HOFFARD

Print Name

To Submit Data - Fax: (714) 593-7799 or
Mail: Orange County Sanitation District, Resource
Protection Division, 10844 Ellis Avenue, Fountain Valley,
CA, 92708-7018

Questions: Contact Isabel Melendez at 714-593-7313



Ronald Hoffard, please initial each page and submit all pages



**ORANGE COUNTY SANITATION DISTRICT
SELF-MONITORING FORM**

SMR No.: S-145452

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

Sample Location: Compliance

<u>Meter Type</u>	<u>Equipment Name</u>	<u>Event ID</u>	<u>Start - End Date</u>	<u>End</u>	<u>Reading</u>	<u>Start</u>	<u>Vol</u>	
EFFLUENT	EM-1-600296	145451	10/7/2019 - 10/8/2019	82189068 Gallon	82165784 Gallon	23284	GPD	
EFFLUENT	EM-1-600296	145450	4/8/2019 - 4/9/2019	76362506 Gallon	76322767 Gallon	38928	GPD	

To Submit Data - Fax: (714) 593-7799 or
Mail: Orange County Sanitation District, Resource
 Protection Division, 10844 Ellis Avenue, Fountain Valley,
 CA, 92708-7018

Questions: Contact Isabel Melendez at 714-593-7313



Ronald Hoffard, please initial each page and submit all pages



TRUESDAIL
LABORATORIES, INC.

ALS - Truesdail Laboratories
3337 Michelson Drive, Suite CN750
Irvine, CA 92612
I +1 714 730 6239

Report

Client: City of Anaheim - Canyon Water Power Plant
3071 E Miraloma Ave
Anaheim, CA 92806

Work Order No.: 20D0072

Printed: 04/21/2020

Attention: Bertha Hernandez

Project Name: Canyon Power Plant Semi-Annually Wastewater

Project Number: Canyon Power Plant

P.O. Number: MA-106-491110 (exp 8/31/18)

CASE NARRATIVE

Date & Time Installed: 04/08/2020; 13:00 PM

Date & Time Removed: 04/09/2020; 13:00 PM

Flow Start Number: 91616086 GAL

Flow Stop Number: 91636048 GAL

Total Flow, GPD: 19962

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
52-2-758 Composite	20D0072-01	Wastewater	Composite	04/09/2020 13:00	04/09/2020 14:00

DEFINITIONS

Symbol	Definition
C	GCA recovery was below the method acceptance limit.
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Shelly Brady

Customer Service Manager

This report applies to the sample(s), or product(s), investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed. This report shall not be reproduced without the written consent of ALS-Truesdail Laboratories, Inc., and must be reproduced in its entirety.



TRUESDAIL
LABORATORIES, INC.

Client: City of Anaheim - Canyon Water Power Pl

Project Name: Canyon Power Plant Semi-Annually Wastewater

Project Number: Canyon Power Plant

Printed: 04/21/2020

52-2-758 Composite
20D0072-01 (Wastewater)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

ALS Truesdail

Field Measurements

pH	6.97	0.01	N/A	1	2004462	04/09/2020 13:00	SMB	EPA 150.2	
Temperature (Celsius)	22.2		°C	1	2004462	04/09/2020 13:00	SMB	Field	

Wet Chemistry

Total Dissolved Solids	70.0	12.5	mg/L	1	2004330	04/17/2020 16:25	SMC	SM 2540 C	
Total Suspended Solids	ND	2.50	mg/L	1	2004326	04/17/2020 10:30	SMC	SM 2540 D	

General Chemistry

Biochemical Oxygen Demand	11.0	2.00	mg/L	1	2004238	04/16/2020 16:58	SMC	SM 5210B - 5 Day	C
---------------------------	------	------	------	---	---------	------------------	-----	------------------	---

This report applies to the sample(s), or product(s), investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed. This report shall not be reproduced without the written consent of ALS-Truesdail Laboratories, Inc., and must be reproduced in its entirety.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612
(714) 730-6239 - FAX (714) 730-6462

CHAIN OF CUSTODY

200072

METHODS

☒ **TURNAROUND TIME** Normal TAT
 DATE: 4/8 - 4/9/20 PAGE: 1 OF 1

[illegible]

Chain of Custody Signature Record

1.	 Relinquished Signature	 Company/ Agency	4-9-20 14:00 Date/ Time
2.	 Received Signature	 Company/ Agency	4/9/2020 14:00 Date/ Time
3.	_____ Relinquished Signature	_____ Company/ Agency	_____ Date/ Time
4.	_____ Received Signature	_____ Company/ Agency	_____ Date/ Time
	_____ Relinquished Signature	_____ Company/ Agency	_____ Date/ Time
	_____ Received Signature	_____ Company/ Agency	_____ Date/ Time

Page

LABORATORY SAMPLE LOG-IN
(Enter following line items on invoice):

1. *Journal of the American Medical Association*, 1997; 277: 1033-1036.

TOTAL NUMBER OF CONTAINERS

SAMPLE CONDITIONS:

RECEIVED

Cool ☒ Warm ☐
$$\underline{1.6} \overline{) 9.7}$$

1.9/1.03

Yes ☐ No ☐**SPECIAL REQUIREMENTS:**

TX Result Report

P 1
10/28/2020 09:51
Serial No. 07PY011022705
TC: 50717

Addressee	Start Time	Time	Prints	Result	Note
917143781277	10-28 09:50	00:01:21	008/008	OK	

Note THA:Timer TX, POL:Polling, ORG:Original Size Setting, FME:Frame Erase TX, DPB:Page Separation TX, MIX:Mixed Original TX, CALL:Manual TX, CSAC:CSAC, FWD:Forward, PCIP:PC-FAX, BND:Double-Sided Binding Direction, SP:Special Original, FCODE:F-code, RTX:Re-TX, BLV:Relay, MBX:Confidential, BUL:Bulletin, SIP:SIP Fax, IPADR:IP Address Fax, I-FAX:Internet Fax

Result OK: Communication OK, S-OK: Stop Communication, PW-OFF: Power Switch OFF, TEL: RX from TEL, NS: Other Error, CONT: Continue, No Ans: No Answer, Refuse: Receipt Refused, Busy: Busy, N-FULL:Memory Full, LDR:Receiving length Over, PDVR:Receiving page Over, FIL:File Error, DC:Decode Error, MDN:MDN Response Error, DSN:DSN Response Error, PRINT:Compulsory Memory Document Print, DEL:Compulsory Memory Document Delete, SEND:Compulsory Memory Document Send.



CITY OF ANAHEIM
PUBLIC UTILITIES DEPARTMENT
Environmental Services
Letter of Transmittal

To:	Ms. Mila Kleinbergs Orange County Sanitation District Resource Protection Division 10844 Ellis Avenue Fountain Valley, CA 92708-7018	Date:	10/28/2020
		Project	Canyon Power Plant 3071 E. Miraloma Ave. Anaheim, CA 92606
		Subject:	Semi-Annual Self-Monitoring

We are sending you:

Copy of Original	Description
1	Completed Semi-Annual Form OCSD Self-Monitoring Form for City of Anaheim Canyon Power Plant (Permit No. 1-600296).

These are transmitted:

<input type="checkbox"/> 1	As requested	<input type="checkbox"/>	For your action	<input type="checkbox"/>	For your files
<input type="checkbox"/>	For approval	<input type="checkbox"/>	For your review	<input type="checkbox"/>	For your information

Via: ☐ US Mail ☒ FAX # 8 of pgs. ☐ Hand Delivery
(714) 593-7799

Remarks:

Please contact me at (714) 765-7481 or bhernandez@anaheim.net if you have any questions regarding this submittal.

By: Bertha A Hernandez, Environmental Services Specialist



CITY OF ANAHEIM
PUBLIC UTILITIES DEPARTMENT
Environmental Services
Letter of Transmittal

To:	Ms. Mila Kleinbergs Orange County Sanitation District Resource Protection Division 10844 Ellis Avenue Fountain Valley, CA 92708-7018	Date:	10/28/2020
		Project:	Canyon Power Plant 3071 E. Miraloma Ave. Anaheim, CA 92806
		Subject:	Semi-Annual Self-Monitoring

We are sending you:

Copy of Original	Description
1	Completed Semi-Annual Form OCSD Self-Monitoring Form for City of Anaheim Canyon Power Plant (Permit No. 1-600296).


These are transmitted:

<input checked="" type="checkbox"/> 1	As requested	<input type="checkbox"/>	For your action	<input type="checkbox"/>	For your files
<input type="checkbox"/>	For approval	<input type="checkbox"/>	For your review	<input type="checkbox"/>	For your information

Via: ☐ US Mail ☒ FAX # 8 of pgs. ☐ Hand Delivery
(714) 593-7799

Remarks:

Please contact me at (714) 765-7481 or bhernandez@anaheim.net if you have any questions regarding this submittal.

By:  Bertha A Hernandez, Environmental Services Specialist



ORANGE COUNTY SANITATION DISTRICT SELF-MONITORING FORM

September 15, 2020

Ronald Hoffard, GENERATION PLANT MANAGER
City of Anaheim, Canyon Power Plant
3071 E Miraloma Ave.
Anaheim, CA 92806

Subject: **REMINDER TO CONDUCT SELF-MONITORING**
Permit No. 1-600296

Please be reminded that Self-Monitoring must be conducted between **October 01, 2020 -- October 16, 2020** in accordance with your company's permit requirements. Self-Monitoring must be conducted during a production day in accordance with the guidelines detailed in your company's permit.

It is your responsibility to comply with the requirements set forth in your company's permit. Failure to comply with all the directives, conditions, and requirements of the permit may result in enforcement action against your company.

If your company's permit shows a self-monitoring requirement for total toxic organics (TTOs) and your company has received a waiver from this self-monitoring, you are now required to submit a signed TTOs SMR form to us to comply with the TTO waiver requirements of the U.S. Environmental Protection Agency. Please indicate in the "Sample Comments" that you have received a TTOs self-monitoring waiver from us.

For permittees that have monthly as well as quarterly and/or semi-annual self-monitoring requirements, the forms may list more than the SMR constituents required for the monthly self-monitoring. We ask that you adhere to your permit's self-monitoring requirements and sample only for the constituent(s) required on a monthly basis except when the quarterly and semi-annual self-monitoring are also required in the same month in which case all constituents listed on the form must be analyzed for as specified in your permit.

Finally, for those who are required to submit meter readings, a list of the meter readings submitted within the last year is attached to the SMR form for your reference and comparison to current readings.

Thank you for your patience and cooperation. If you have any questions, please contact Mila Kleinbergs at 714-593-7408.

Mila Kleinbergs
Senior Engineer



ORANGE COUNTY SANITATION DISTRICT SELF-MONITORING FORM

SMR No.: S-145453

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

Sampling Dates: 10/01/2020 to 10/16/2020 Submit By Date: 10/31/2020
 Sample Start Date: 10/12/2020 Sample End Date: 10/13/2020
 Sample Start Time: 11:10 AM Sample End Time: 11:30 AM
 Sampling Point Location: Sampling Structure located in the center of the site

Contact Person: RONALD HOFFARD Contact Phone: 714 765-4536
 Contact Email: RHOFFARD@ANAHEIM.NET

☐ No Discharge

Water Meter Readings: (If this is a batch discharge, enter volume only)

Location	Meter Type	Meter ID	Stop Reading	Start Reading	Volume	Units	Digits	Int
Center of site adjacent to the final clarifier/vault	Effluent Flow Meter	EM-1-600296	<u>95804724</u>	<u>95766786</u>	<u>37938</u>	G	9	

Composite

Sample Results: (If constituent is not detected or is less than detection limit, enter as reported in the lab results.)

Constituent	Result	Units	EPA Method
BOD T	<u>ND</u>	mg/L	<u>SM 5210B</u>
TSS	<u>ND</u>	mg/L	<u>SM 2540D</u>

Sample Comments: _____

Please note that OCSD's fax number has changed. Please use the new fax number (714) 378-1277 effective immediately if submitting completed form by fax.

To Submit Data - Fax: (714) 378-1277 or
Mail: Orange County Sanitation District, Resource Protection Division, 10844 Ellis Avenue, Fountain Valley, CA, 92708-7018



Questions: Contact Isabel Melendez at 714-593-7313

RH

Ronald Hoffard, please initial each page and submit all pages

**ORANGE COUNTY SANITATION DISTRICT
SELF-MONITORING FORM****SMR No.: S-145453**

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

**This form must be completely filled out and Laboratory Analysis Report
and Chain of Custody must be attached.**

Please check if composite sample was obtained using an automatic sampling device: () Yes () No

In accordance with 40 CFR 403.12, the results presented herein must be verified and signed under penalty of perjury by: (i) a responsible corporate officer; (ii) general partner or proprietor; or (iii) a representative who has responsibility for the overall operation of the permitted facility, who has been authorized by the corporate officer, general partner or proprietor to sign such reports, and such authorization has been made in writing and submitted to the District.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. [40 C.F.R. § 403.6(a)(2)(ii) (2005)]

Signature (Ronald Hoffard)

Title (GENERATION PLANT MANAGER)

Date

RONALD HOFFARD

Print Name

To Submit Data - Fax: (714) 378-1277 or
Mail: Orange County Sanitation District, Resource
Protection Division, 10844 Ellis Avenue,
Fountain Valley, CA, 92708-7018

Questions: Contact Isabel Melendez at
714-593-7313

RH

Ronald Hoffard, please initial each page and submit all pages



ORANGE COUNTY SANITATION DISTRICT SELF-MONITORING FORM

SMR No.: S-145453

SMR Type: Standard

City of Anaheim, Canyon Power Plant

General Pretreatment Regulations For Existing And New Sources Of Pollution

Permit No. 1-600296

Sample Location: Compliance

<u>Meter Type</u>	<u>Equipment</u>		<u>Event ID</u>	<u>Start - End Date</u>	<u>Reading</u>		<u>Vol</u>	
	<u>Name</u>	<u>End</u>			<u>Start</u>	<u>End</u>		
EFFLUENT	EM-1-600296		145452	4/8/2020 - 4/9/2020	91636048 Gallon	91616086 Gallon	19962	GPD
EFFLUENT	EM-1-600296		145451	10/7/2019 - 10/8/2019	82189068 Gallon	82165784 Gallon	23284	GPD

To Submit Data - Fax: (714) 378-1277 or
Mail: Orange County Sanitation District, Resource
 Protection Division, 10844 Ellis Avenue,
 Fountain Valley, CA, 92708-7018

Questions: Contact Isabel Melendez at
 714-593-7313

Ronald Hoffard, please initial each page and submit all pages



ALS - Truesdail Laboratories
3337 Michelson Drive, Suite CN750
Irvine, CA 92612
T +1 714 730 6239

Report

Client: Canyon Power Plant
3071 E Miraloma Ave
Anaheim, CA 92806

Work Order No.: 20J0154
Printed: 10/22/2020

Attention: Bertha Hernandez

Project Name: Canyon Power Plant Semi-Annually Wastewater

Project Number: Canyon Power Plant

P.O. Number: MA-106-491110 (exp 8/31/18)

CASE NARRATIVE

Date & Time Installed: 10/12/2020; 11:10 AM
Date & Time Removed: 10/13/2020; 11:30 AM

Flow Start Number: 95766786 GAL
Flow Stop Number: 95804724 GAL
Total Flow, GPD: 37938

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
Semi-Annually Composite	20J0154-01	Wastewater	Composite	10/13/2020 11:30	10/13/2020 15:57

DEFINITIONS

Symbol	Definition
C	GGA (BS1) recovery was below the method acceptance limit.
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Shelly Brady
Customer Service Manager

This report applies to the sample(s), or product(s), investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed. This report shall not be reproduced without the written consent of ALS-Truesdail Laboratories, Inc., and must be reproduced in its entirety.



TRUESDAIL
LABORATORIES, INC.

Client: Canyon Power Plant

Project Name: Canyon Power Plant Semi-Annually Wastewater

Project Number: Canyon Power Plant

Printed: 10/22/2020

Semi-Annually Composite

20J0154-01 (Wastewater)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

ALS Truesdail

Wet Chemistry

Total Dissolved Solids	224	50.0	mg/L	1	2010279	10/15/2020 17:45	SMC	SM 2540 C	
Total Suspended Solids	ND	2.78	mg/L	1	2010303	10/16/2020 11:55	HHT	SM 2540 D	

General Chemistry

Biochemical Oxygen Demand	ND	2.00	mg/L	1	2010289	10/19/2020 17:01	SMC	SM 5210B - 5 Day	C
---------------------------	----	------	------	---	---------	------------------	-----	------------------	---

This report applies to the sample(s), or product(s), investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed. This report shall not be reproduced without the written consent of ALS-Truesdail Laboratories, Inc., and must be reproduced in its entirety.



20J0154 METHODS

☒ TURNAROUND TIME Normal TAT
DATE: 10/12 - 10/13/20 PAGE: 1 OF 1

Page 3 of 3

OC Sanitation District
No Violations or Corrective Actions
to report for CY 2020

CANYON POWER PLANT

ANNUAL COMPLIANCE REPORT

ATTACHMENT 14

VIS-4

**SURFACE TREATMENT OF PROJECT
STRUCTURES AND BUILDINGS**

VIS-4: Surface Treatment of Project Structures and Buildings

Condition of Certification VIS-4 requires a status report of the surface treatment maintenance for the structures and buildings in the Annual Compliance Report. The report shall specify the following:

1. The condition of surfaces of all structures and buildings at the end of the reporting year 2018:

- a. Butler Building (Administrative and Warehouse)
- b. Main Electrical Enclosure (MEE)
- c. Balance of Plan (BOPEE)
- d. Substation Building
- e. Chiller
- f. RO Skid (open wall with roof sheet metal covering)
 - i. The exterior building material is fabricated sheet metal. The colors and finishes do not create excessive glare and consistent with local policies and ordinances. All structure and buildings visual inspection showed no trouble items and all are in good working order.
- g. Gas Turbines (4 identical units)

2. Maintenance activities that occurred in CY 2020:

- a. May Planned Outage
 - i. Semi-annual maintenance performed
- b. December Planned Outage
 - i. Semi-annual maintenance performed

3. Schedule maintenance activities for CY 2021:

- a. May 2021 Planned Outage
 - i. Semi-annual maintenance
- b. December 2021 Planned Outage
 - i. Semi-annual maintenance

Status report regarding condition of Structures and Buildings

The photographs below shows the surface treatment of project structures and buildings. All buildings comply with condition VIS-4.




Warehouse Building (02/03/21)



Administrative Building (02/03/21)



Main Electrical Enclosure Building (02/03/21)



Substation Building (02/03/21)



Chiller Building (02/03/21)



RO Skid Structure (02/03/21)



Balance of Plant Building (02/03/21)



LM 6000 Turbines (02/03/21)

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 15
LANDSCAPE SCREENING

VIS-5: Landscape Screening

Condition of Certification VIS-5 requires a status report in the Annual Compliance Report regarding landscape maintenance activities. At the Canyon Power Plant the landscape maintenance activities were performed according to the contract and consistent with policies and requirements of the City of Anaheim plan and zoning ordinance.

The contracted company performed the following landscape maintenance activities:

Contracted Landscape Services – Landscape West Mgmt. Service, Inc. (Period: Jan 1, through December 31, 2020).


Activity Type	Frequency
<u>Weed Control</u> Landscape areas Hardscape areas Gravel areas	2x/wk. 1x/Mo
<u>Fertilization</u> Shrubs Ground cover Trees	2x/year
<u>Pest Control</u> Rodents	As needed
<u>Irrigation Maintenance</u> Inspect all Sprinklers/Systems	As needed
<u>Trees</u> Canopy Trees	As needed
<u>Maintenance/Clean-Up</u> Ground Cover and Shrubs Trash & Litter at Landscape area Trash & Litter at enclosed gravel areas Monthly Inspection	2x/wk.

The photographs below taken by staff on 2/02/2021 of the landscape maintenance demonstrating compliance pursuant VIS-5 condition:


Landscaping - Exterior Plants



Miraloma Avenue, south wall



Miraloma Avenue, south wall



Miraloma Avenue, south wall




East-wall ivy

Landscaping - Interior Plant



Administration Building Planter



Admin and Warehouse Building Planter



Warehouse Building Planter

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 16

AQ-9
NH3 SLIP TESTING

**TEST REPORT FOR
3Q20 AMMONIA SLIP TEST
AT CANYON POWER PLANT UNIT 1
FACILITY ID: 153992, DEVICE ID: D1**

Prepared For:

Canyon Power Plant
3071 E. Mira Loma Avenue
Anaheim, California 92806

For Submittal To:

South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765-4178

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
(714) 282-8240

Sean Donovan

Test Date: **July 21, 2020**
Production Date: **August 18, 2020**
Report Number: **W002AS-682102-RT-1480**



CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature: Sean Donovan Date: 8/18/2020

Name: Sean Donovan Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: Mike Chowsanitphon Date: 8/18/2020

Name: Mike Chowsanitphon Title: Reporting Manager

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY	5
2.0 UNIT AND CEMS DESCRIPTION	6
2.1 UNIT DESCRIPTION	6
2.2 TEST CONDITIONS	7
2.3 SAMPLE LOCATION	7
3.0 TEST DESCRIPTION	8
4.0 TEST RESULTS AND OVERVIEW	9
4.1 TEST RESULTS	9
4.2 TEST OVERVIEW	9

LIST OF APPENDICES

A RAW DATA	10
A.1 Sample Data Sheets	11
A.2 Laboratory Data	15
A.3 QA/QC Data	22
B FACILITY CEMS DATA	26
C CALCULATIONS	31
C.1 General Emissions Calculations	32
C.2 Spreadsheet Summaries	36
D QUALITY ASSURANCE	39
D.1 Quality Assurance Program Summary	40
D.2 SCAQMD and STAC Certifications	46
D.3 Individual QI Certificate	49
E APPLICABLE PERMIT SECTIONS	51

LIST OF TABLES

1-1 AMMONIA SLIP TEST RESULTS SUMMARY	5
4-1 AMMONIA SLIP TEST RESULTS	9

LIST OF FIGURES

2-1 UNIT BLOCK DIAGRAM	6
3-1 SCAQMD METHOD 207.1 SAMPLE EQUIPMENT	8

1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) was contracted by the Canyon Power Plant to perform an ammonia slip test at Unit 1 as required by the facility Permit (Facility ID 153992) Condition Number D29.2. This report documents the results of the ammonia slip tests performed on July 21, 2020. The test was performed by Sean Donovan, Danny Avila, Rik Dupont, and Robert Howard of MAQS. Sean Donovan was the on-site Qualified Individual for MAQS. Bertha Hernandez coordinated the test for Canyon Power Plant.

The test consisted of duplicate ammonia tests performed at 49 MW. The test program followed the procedures described in the initial compliance test protocol (MAQS document R038842). The results of the test are summarized in Table 1-1. The table shows that the ammonia slip from this unit was less than the permitted limit of 5 ppm corrected to 15% O₂.

TABLE 1-1
AMMONIA SLIP TEST RESULTS SUMMARY
CANYON POWER PLANT UNIT 1
JULY 21, 2020

Parameter/Units	Result ⁽¹⁾	Limit
NH ₃		
ppm	1.6	--
ppmc	1.5	5

(1) Maximum of duplicate runs, as required by SCAQMD Method 207.1


Section 2 of this document provides a brief description of the unit, test conditions, sample location, and CEMS. Details of the test procedures are provided in Section 3. Section 4 provides the results of each individual test. All raw data, calculations, quality assurance data, unit operating conditions, and CEMS data are provided in the appendices.

2.0 UNIT AND CEMS DESCRIPTION

2.1 UNIT DESCRIPTION

The City of Anaheim Canyon Power Plant is located at 3071 E. Mira Loma Avenue, Anaheim, California 92806. The facility consists of four identical generating units. Each unit consists of a natural gas fired, GE Model LM6000PC Sprint simple cycle, gas turbine. The units are natural gas fired with a rated heat input of 479 MMBtu per hour at 46°F, with water injection. The units are equipped with a CO catalyst and Selective Catalytic Reduction (SCR) system for NO_x control. Figure 2-1 presents a block diagram of the unit.

**FIGURE 2-1
UNIT BLOCK DIAGRAM
CANYON POWER PLANT**



Stack Inside Diameter:	11 feet, 8 inches
Distance from Upstream Disturbance:	23 feet, 4 inches (2.0 Diameters)
Distance from Stack Exit:	16 feet, 6 inches (1.4 Diameters)

2.2 TEST CONDITIONS

The tests were performed with the unit operating at an average load of 49 MW. Tests were performed while the unit was firing natural gas and operating under normal conditions. Unit operation was established by the Canyon Power Plant operators.

2.3 SAMPLE LOCATION


The measurements were made from sample ports located on the exhaust stack. There are four sample ports equally spaced at this location. The stack inside diameter at the sample plane is 11 feet, 8 inches. The sample ports are located 23 feet, 4 inches (2.0 diameters) downstream of the nearest flow disturbance and 16 feet, 6 inches (1.4 diameters) from the stack exit.

3.0 TEST DESCRIPTION

Flue gas samples were collected non-isokinetically using a SCAQMD Method 207.1 sample train. The samples were collected using a 12-point traverse at the exhaust stack location. Each test was performed over a 60 minute interval. The sample gas was drawn through a glass probe, Teflon sample line, two impingers each containing 100 ml of 0.1N H₂SO₄, an empty impinger, an impinger containing silica gel, and a dry gas meter. The optional nozzle and filter were not used since the source is natural gas fired. The contents of the sample line and the first three impingers were recovered and analyzed by SCAQMD Method 207.1 for ammonia concentration by Ion Specific Electrode analysis. Figure 3-1 presents a diagram of the sampling equipment.

Stack O₂ and NO_x concentrations and stack volumetric flow rate data were recorded from the Continuous Emission Monitoring System (CEMS) which is installed on the unit. These data were used to correct the ammonia concentration to 15% O₂.

FIGURE 3-1
SCAQMD METHOD 207.1 SAMPLE EQUIPMENT



4.0 TEST RESULTS AND OVERVIEW

4.1 TEST RESULTS

The results of the test are summarized in Table 4-1. The results show that the ammonia slip was 1.5 ppm @ 15% O₂ which is less than the permitted limit of 5 ppm @ 15% O₂.

**TABLE 4-1
AMMONIA SLIP TEST RESULTS
CANYON POWER PLANT UNIT 1
JULY 21, 2020**

Parameter/Units	Run 1	Run 2	Average	Maximum ⁽¹⁾	Limit
Test	1-NH ₃ -U1	2-NH ₃ -U1			--
Date	7/21/2020	7/21/2020			--
Time	2041/2144	2205/2308			--
O₂, %⁽²⁾	14.45	14.47	14.46	--	--
Stack Flow , dscfm @ T _{ref} ⁽²⁾	233,902	234,000	233,951	--	--
NO_x , ppmc ⁽²⁾	2.2	2.2	2.2	--	2.5
NH₃					
ppm	1.6	1.5	1.5	1.6	--
ppmc	1.5	1.4	1.4	1.5	5
lb/hr	1.0	0.9	1.0	1.0	--
lb/MMBtu	0.002	0.002	0.002	0.002	--
lb/MMSCF	2.1	1.9	2	2.1	--

(1) Maximum of duplicate test runs, as required by SCAQMD Method 207.1

(2) From facility CEMS

4.2 TEST OVERVIEW

The test program was successful in meeting the program objectives. The sample train was leak checked before and after the test and all QA/QC requirements of SCAQMD Method 207.1 were satisfied.

APPENDIX A RAW DATA

Appendix A.1

Sample Data Sheets

CLIENT: *City of Anaheim*
LOCATION: *Canyon 1*
DATE: *7/21/20*
RUN NO: *FB-NHTJ-VI*
OPERATOR: *RH*
METER BOX NO: *35-WCS*
METER Yd: *286*

CEMS Heated Line Temp: NA
CEMS Knock Out Temp: NA
CHECK WEIGHT: 999.8 / 500g

AMBIENT TEMPERATURE: 70°
 BAROMETRIC PRESSURE: 29.58
 ASSUMED MOISTURE : NA
 PITOT TUBE COEFF, Cp: NA
 PROBE ID NO/MATERIAL: NA / Ti
 PROBE LENGTH: 8'
 PRE-TEST LEAK RATE : 20.005 CFM@ 15 in. Hg
 POST-TEST LEAK RATE : CFM@ in. Hg
 PITOT LEAK CHECK - PRE: NA POST: NA

Imp. #	Contents	Post-Test	- Pre-Test = Difference
1	H₂SO₄	789.3	689.5
2	H₂SO₄	609.4	609.4
3	mt	632.1	632.2
4	SG	936.7	936.7
Total:	LR	100	100

[illegible]

Comments:

CLIENT: City of Anaheim
LOCATION: Canyon 1
DATE: 7/21/20
RUN NO: 1-NH3-1
OPERATOR: RV
METER BOX NO: 38-wcs
METER ΔH @: 1.730 @ 1 = 0.972
METER Yd: 0.980
STACK AREA, FT²: 106.90
TRAVERSE POINTS, MIN/POINT: 5/12
 $\Delta H = \underline{NA} \times \Delta P$:
Probe Condition, pre/post test: \checkmark/\checkmark
Silica Gel Expended, Y/N: N
Filter Condition after Test: NA
Check Weight: 149.9/500.0

AMBIENT TEMPERATURE: 70
 BAROMETRIC PRESSURE: 29.58
 ASSUMED MOISTURE: -12%
 PITOT TUBE COEFF, Cp: 2.74
 PROBE ID NO/MATERIAL: NA / T1
 PROBE LENGTH: 8'
 NOZZLE ID NO/ MATERIAL: NA
 NOZZLE DIAMETER: NA
 FILTER NO/TYPE:
 PRE-TEST LEAK RATE: : 0.005 CFM@ 18 in. Hg.
 POST-TEST LEAK RATE: : 0.005 CFM@ 18 in. Hg.
 PITOT LEAK CHECK - PRE: 2.74 POST: 2.74
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN: TC
 SAMPLER: RW
 SAMPLE CUSTODIAN: TB

1	H₂SO₄	916.8	702.1
2	H₂SO₄	610.6	606.6
3	MT	630.6	629.9
4	SG	956.0	943.0
LR		Ø	100
Total:			

[illegible]

Comments:

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: City of Anaheim
 LOCATION: Canyon 1
 DATE: 1/21/20
 RUN NO: 2-21-H3
 OPERATOR: RM
 METER BOX NO: 38-WCS
 METER ΔH @: 1.720 @ 1=0.572
 METER Yd: 0.986
 STACK AREA, FT²:
 TRAVERSE POINTS, MIN/POINT: 5/12
 $\Delta H = \frac{NA}{X} \times \Delta P$:
 Probe Condition, pre/post test: ✓/✓
 Silica Gel Expended, Y/N: N
 Filter Condition after Test: NA
 Check Weight: 499.8/580.0

AMBIENT TEMPERATURE: 70
 BAROMETRIC PRESSURE: 29.58
 ASSUMED MOISTURE: 11.5
 PITOT TUBE COEFF, Cp: NA
 PROBE ID NO/MATERIAL: 8' TA
 PROBE LENGTH: 8'
 NOZZLE ID NO/ MATERIAL: NA
 NOZZLE DIAMETER: NA
 FILTER NO/TYPE:
 PRE-TEST LEAK RATE: : 10005 CFM@ 18 in. Hg.
 POST-TEST LEAK RATE: : 10005 CFM@ 19 in. Hg.
 PITOT LEAK CHECK - PRE: NA POST: NA
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN JB
 SAMPLER RM
 SAMPLE CUSTODIAN JB

Imp. # Contents Post-Test - Pre-Test = Difference

1 H₂SO₄ 845.7 675.4
 2 H₂SO₄ 731.8 685.4
 3 MT 630.5 628.5
 4 SG 939.2 927.1
 LR Ø 100
 Total:

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
3	2205	673.400	NA	2.0	NA	NA	NA	56	74	72	7		NA
2	2210	—						—	—	—	—		
1	2215	—						—	—	—	—		
PL	2220	685.357						—	—	—	—		
3	2221	685.357						53	75	73	7		
2	2226	—						—	—	—	—		
1	2231	—						—	—	—	—		
PL	2236	697.916						—	—	—	—		
3	2237	697.916						52	75	73	7		
2	2242	—						—	—	—	—		
1	2247	—						—	—	—	—		
PL	2252	709.484						—	—	—	—		
3	2253	709.484						53	75	72	7		
2	2258	—						—	—	—	—		
1	2303	—						—	—	—	—		
END	2308	721.481						—	—	—	—		
		RM 7-21-2020											
Average:													

Comments:

Appendix A.2 Laboratory Data

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS

Project #: 002AS-682102 District Method: SCAQMD 207.1 Sample Date: 7/21/2020
 Client/Location: SCPPA - Canyon Calibration Date: 7/27/2020 Analysis Date: 7/27/2020
 Sample Location: Stack U1 Calibration Curve: $y = -54.2597x + 79.3597$ Analyst's Initials: LM
 Test #'s: 1-2-NH₃ R²: 0.9999 Room Temperature (°C): 22.0

Sample	Total Vol. (mL)	Electrode Potential (mV)	Conc. $\mu\text{g NH}_3 - \text{N / ml}$	Cavg ($\mu\text{g NH}_3 - \text{N / ml}$)	$\mu\text{g NH}_3 / \text{sample}$	T (°C)	Blue after + ISA (Y/N)	pH	% R
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	1.6	27.108	27.166	—	22.6	Y	—	-2.979
		1.5	27.224			22.6	Y		
1-NH ₃	580.3	61.5	2.134	2.152	1518.040	22.5	Y	<2	—
		61.1	2.170			22.5	Y		
2-NH ₃	614.1	65.0	1.839	1.855	1384.730	22.5	Y	<2	—
		64.6	1.871			22.5	Y		
Spike: 1-NH ₃ +2ml 1000ppm NH ₃	—	8.5	20.227	20.313	—	22.5	Y	—	94.65
		8.3	20.400			22.5	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	0.9	27.926	27.985	—	22.6	Y	—	-0.054
		0.8	28.044			22.6	Y		
Reagent Blank 0.1N H ₂ SO ₄	—	141.6	0.071	0.071	—	23.3	Y	—	—
		141.6	0.071			23.3	Y		
DI H ₂ O Blank	—	144.4	0.063	0.063	—	23.3	Y	—	—
		144.5	0.063			23.3	Y		
Field Blank	435.1	119.4	0.183	0.181	95.685	22.5	Y	<2	—
		119.9	0.179			22.5	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	1.3	27.456	27.750	—	22.6	Y	—	-0.853
		0.8	28.044			22.6	Y		

Notes: Total volume of samples and standards used: 100 ml
 Volume of pH adjusting ISA used in ml: 2 ml
 Absorbing solution: 0.1N H₂SO₄

Calculations: Conc. ($\mu\text{g NH}_3 - \text{N / ml}$) = $10^{(P-B)/M}$; (P = electrode potential, B = y-intercept and M = slope)
 Cavg = average result of duplicate analyses ($\mu\text{g NH}_3 - \text{N / ml}$) = $(C1+C2)/2$
 $\mu\text{g NH}_3 / \text{sample} = \text{Cavg} \times 17.03 / 14.01 \times \text{TV}$
 $\text{mg / sample} = \mu\text{g / sample} \div 1000$
 $\text{ppm NH}_3 = \text{mg NH}_3 / \text{sample} \times 1 / \text{Vmstd} \times 1 / 454000 \times \text{SV} / 17 \times 10^6$

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALCULATION

Project Number: 002AS-682102
 Client/ Location: SCPPA-Canyon Power Plant
 Sample Location: Stack U1
 District Method: SCAQMD 207.1
 Sample Date: 7/21/2020
 Analysis Date: 7/27/2020
 Analyst's Initials: LM
 Calibration Curve Slope -54.2597
 Y-intercept 79.3597
 R² 0.9999

Sample	P mV	Conc. µg NH ₃ /ml as N	C avg as N	TV (ml)	C avg as NH ₃	µg NH ₃ / sample
28 ug NH ₃ / ml as N	1.6	27.108				
Repeat 28 ug NH ₃ /ml as N	1.5	27.224	27.166	NA	33.022	NA
1-NH ₃	61.5	2.134				
Repeat 1- NH ₃	61.1	2.170	2.152	580.3	2.616	1518.040
2-NH ₃	65.0	1.839				
Repeat 2- NH ₃	64.6	1.871	1.855	614.1	2.255	1384.730
spike 1-NH ₃	8.5	20.227				
Repeat 1-NH ₃ spike	8.3	20.400	20.313	NA	24.692	NA
28 NH ₃ /ml as N	0.9	27.926				
Repeat 28 ug NH ₃ /ml as N	0.8	28.044	27.985	NA	34.017	NA
Reagent Blank	141.6	0.071				
Repeat Reagent Blank	141.6	0.071	0.071	NA	0.087	NA
Field Blank	119.4	0.183				
Repeat Field Blank	119.9	0.179	0.181	435.1	0.220	95.685
DI H ₂ O Blank	144.4	0.063				
Repeat DI H ₂ O Blank	144.5	0.063	0.063	NA	0.077	NA
28 NH ₃ /ml as N	1.3	27.456				
Repeat 28 ug NH ₃ /ml as N	0.8	28.044	27.750	NA	33.732	NA

Notes:

Measured Concentration of Ammonia (C) in µg NH₃ / ml as N

$$C=10^{(P-B)/M}$$

P = electrode potential (mV), M=slope and B=intercept

Average Measured Ammonia Concentration (Cavg) = (C1 + C2)/2

where C1, C2 results from duplicate analyses (µg NH₃ /ml as N)

Cavg (µg NH₃/ml as NH₃) = Cavg (µg NH₃/ ml as N) * 17.03/ 14.01

µg NH₃ / sample = Cavg (µg NH₃/ml as NH₃) * TV

Used 100 ml of samples and standards with 2 ml ISA and constant stirring rate.

All solutions turned blue and remained blue with ISA unless otherwise indicated.

Sample PH and Temperatures can be found on the laboratory datasheet.

Maximum samples (including blanks) between 28 ug/ml check standard is 5 samples analyzed in duplicate.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS QUALITY CONTROL

Project Number: 002AS-682102
 Client/ Location: SCPPA-Canyon Power Plant
 Sample Location: Stack U1
 District Method: SCAQMD 207.1
 Sample Date: 7/21/2020
 Analysis Date: 7/27/2020
 Analyst's Initials: LM

Sample	% recovery	RPD %	RPA %
28 ug NH3 / ml as N Repeat 28 ug NH3/ml as	NA	-0.42	-2.979
1-NH3 Repeat 1- NH3	NA	-1.70	NA
2-NH3 Repeat 2- NH3	NA	-1.70	NA
spike 1-NH3 Repeat 1-NH3 spike	94.65	-0.85	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as	NA	-0.42	-0.054
Reagent Blank Repeat Reagent Blank	NA	0.00	NA
Field Blank Repeat Field Blank	NA	2.12	NA
DI H2O Blank Repeat DI H2O Blank	NA	0.42	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as	NA	-2.12	-0.893

Notes:

spike: 100 ml sample + 2 ml (1000 µg NH₃ / ml as N)

Matrix Spike Percent Recovery (%R)

%R = (C spike*0.104 - Csample*0.102)/2 *100

Cspike = average result of matrix spike (µg NH₃/ ml as N)

Relative Percent Difference (RPD) = (C1-C2)/ Cavg *100 (must be 5% or less)

Relative Percent Accuracy (RPA) (must be 10% or less)

RPA = (Cavg-theoretical value of standard)/ theoretical value of standard * 100



AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALIBRATION DATA

District Method: SCAQMD 207.1

Calibration Date: 7/27/2020

Calibration Curve: $y = -54.2597x + 79.3597$

R² 0.9999

Analyst's Initials: LM

Thermometer #: 1

ISE Electrode #: B

Calibration Standard (µg NH ₃ / ml as N)	Electrode Potential (mV)	Solution Temperature (°C)	Room Temperature (°C)
1	79.1	22.6	22.0
5	41.6	22.6	22.0
20	9.2	22.6	22.0
100	-29.5	22.6	22.0

Notes:

Total volume of samples and standards used: 100 ml

Volume of pH adjusting ISA used in ml: 2 ml

Absorbing solution: 0.04 N H₂SO₄


Slope of the calibration curve shall be between -54 to -60

R² must be 0.9997 or greater

Calibration solutions, sample solutions and Calibration Verification standard temperature within ± 2°C

AMMONIA ELECTRODE CALIBRATION CURVE

NH ₃ concentration (μg NH ₃ / ml as N)	log NH ₃ concentration	Electrode potential (mV)	Sample Temperature (C)	Room Temperature (C)
1	0.000	79.1	22.6	22
5	0.699	41.6	22.6	22
20	1.301	9.2	22.6	22
100	2.000	-29.5	22.6	22



```
slope      -54.2597
y-intercept 79.3597
```

Concentration ($\mu\text{g NH}_3$ / ml as N)	Value LR line	Difference	% Difference
1	1.0111	0.0111	1.1083
5	4.9649	-0.0351	-0.7028
20	19.6352	-0.3648	-1.8241
100	101.4545	1.4545	1.4545

Calculation:

Regression Line: $P = M \cdot \log(\mu\text{g of NH}_3 / \text{ml as N}) + B$

Measured Concentration of Ammonia (C) in $\mu\text{g} / \text{ml NH}_3$ as N: $C=10^{(P-B)/M}$

where P = electrode potential, M= slope (must be -57 ± 3) and B= intercept

All standards were prepared in 0.04N H₂SO₄ and allowed to equilibrate to room temperature.

CHAIN OF CUSTODY

CLIENT: SCPPA - Canyon Power PlantPROJECT #: W002AS-682102TEST DATE(S): 7/21/2020LOCATION: U1SAMPLER(S): RH/DA/RDSAMPLE LOCATION: StackPROJECT MANAGER: SDTEST METHOD(S): SCAQMD 207.1DATE DUE: 7/28/2020OUTSIDE LAB REQUIRED?: NoCOMPLIANCE TEST?: Yes

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
7/21/2020	2041/2144	1-NH3-U1	Probe, Line, Impingers	1	RH/DA/RD	
7/21/2020	2205/2308	2-NH3-U1	Probe, Line, Impingers	1	RH/DA/RD	
7/21/2020		Reagent Blank	0.1 N H ₂ SO ₄	1	SD	
7/21/2020		Reagent Blank	DI H ₂ O	1	SD	
7/21/2020		FB-NH3-U1	Probe, Line, Impingers	1	RH/DA/RD	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
<i>Ed Howard / LAB</i>	<i>7-24-2020 / 2243</i>	<i>[Signature]</i>	<i>7/27/20 0838</i>

ANALYSIS REQUIRED: NH₃ by SCAQMD 207.1 (ISE)

Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

Appendix A.3

QA/QC Data

SCAQMD METHOD 207.1 - AMMONIA DETERMINATION OF SAMPLE TIME

Source: Canyon U1
Date: 7/21/2020
Performed by: SD

Constants:

	1,000	mg/gram
	454	grams/lb
	35.315	SCF/SCM
	379.5	SCF/lb-mole
	1,000,000	parts/million parts
MW _{NH3}	17.03	lb/lb-mole
MW _{N2}	14.01	lb/lb-mole

Variables:

Target concentration	5	ppm @ O ₂ correction factor
O ₂ correction factor	15	% O ₂
Expected Flue Gas O ₂	14.5	% O ₂
F	2	Safety Factor
P	128.5	electrode potential corresponding to minimum value on calibration curve (mV)
B	128.83	y-intercept
M	-58.676	slope
V _r	0.5	Assumed liquid volume of probe rinse and first impinger (L)
Q @ dH = 1	0.55	cfm

Calculated Values:

Target concentration	5.4	ppm - raw
Target concentration	3.90	mg/dscm
C ₁	1.013	Lowest concentration on a calibration curve (mg NH ₃ -N/L)
RL	0.616	analytical mass reporting limit, mg
PSV	0.316	Planned sample volume, cubic meters
PSV	11.144	Planned sample volume, cubic feet
VSR	33.0	achievable volumetric sampling rate (dscf/hr)

PST	20.3	Planned sample time, minutes (minimum)
------------	-------------	---

Notes:

- 1) A minimum of 1 hour sample time is required for any mass per hour limits.
- 2) Facility Permit or Rule may specify sample time

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Office Method - Triplicate Runs/Four Calibration Points
English Meter Box Units, English K Factor
Filename: M:\Santa Ana\Equipment\Test Equipment\Calibrations\Dry Gas Meters\38-wcs\2020\semi annual cal 38wcs 2-27-20.xlsx\W Date: 2/27/2020
File Modified From: APEX 522 Series Meter box Calibration
Revised: 4/8/2005

ID #: c-5000
38-wcs
2/27/2020
Bar. Pressure: 30.17 (in. Hg)
Performed By: R. Howard
Meter Serial #:

DRY GAS METER READINGS										CRITICAL ORIFICE READINGS					
dH (in H2O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature			
		Initial (cu ft)	Final (cu ft)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)	
0.13	26.00	463.700	469.149	5.449	69.0	66.0	71.0	68.0	33	0.1551	18.0	64.0	64.0	64.0	
0.13	26.00	469.149	474.592	5.443	71.0	68.0	72.0	69.0	33	0.1551	18.0	64.0	64.0	64.0	
0.13	26.00	474.592	480.032	5.440	72.0	69.0	72.0	70.0	33	0.1551	18.0	64.0	64.0	64.0	
0.59	12.00	447.400	452.664	5.264	66.0	65.0	66.0	64.0	48	0.3345	16.0	62.0	62.0	62.0	
0.59	12.00	452.664	457.895	5.231	66.0	64.0	68.0	65.0	48	0.3345	16.0	62.0	62.0	62.0	
0.59	12.00	457.895	463.127	5.232	68.0	65.0	69.0	65.0	48	0.3345	16.0	62.0	62.0	62.0	
1.80	7.00	482.500	488.027	5.527	72.0	70.0	73.0	70.0	63	0.5915	14.0	65.0	65.0	65.0	
1.80	7.00	488.027	493.551	5.524	73.0	70.0	74.0	70.0	63	0.5915	14.0	65.0	65.0	65.0	
1.80	7.00	493.551	499.086	5.535	74.0	70.0	74.0	71.0	63	0.5915	14.0	65.0	65.0	65.0	
3.10	5.00	499.900	504.949	5.049	75.0	71.0	76.0	72.0	73	0.7678	11.0	66.0	66.0	66.0	
3.10	5.00	504.949	509.993	5.044	76.0	72.0	76.0	71.0	73	0.7678	11.0	66.0	66.0	66.0	
3.10	5.00	509.993	515.044	5.051	76.0	71.0	76.0	71.0	73	0.7678	11.0	66.0	66.0	66.0	

DRY GAS METER				ORIFICE				DRY GAS METER				ORIFICE			
VOLUME		CORRECTED		VOLUME		CORRECTED		CALIBRATION FACTOR		CALIBRATION FACTOR		CALIBRATION FACTOR		CALIBRATION FACTOR	
Vm(std) (cu ft)	Vm(std) (liters)	Vm(std) (cu ft)	Vm(std) (liters)	Vm(std) (cu ft)	Vm(std) (liters)	Vm(std) (cu ft)	Vm(std) (liters)	Y Value (number)	dH@ Value (in H2O)	Individual Run	Ymax - Ymin < 1.05?	Individual Orifice	Orifice Average	Ymax - Ymin < 1.02?	Orifice Average
5.489	155.4	5.315	150.5	5.233	150.5	5.233	150.5	0.968	1.768	Pass	0.95 < Y < 1.05?	Pass	Pass	0.98 < Y/Yd < 1.02?	dH@ - dH@av < 0.155?
5.467	154.8	5.315	150.5	5.233	150.5	5.233	150.5	0.972	1.763	Pass		Pass	Pass		
5.457	154.5	5.315	150.5	5.233	150.5	5.233	150.5	0.974	1.759	Pass		Pass	Pass		
				Average		Average		0.971	1.763	Pass		Pass		Pass	
5.341	151.3	5.300	150.1	5.198	150.1	5.198	150.1	0.992	1.727	Pass		Pass	Pass		
5.303	150.2	5.300	150.1	5.198	150.1	5.198	150.1	0.999	1.727	Pass		Pass	Pass		
5.294	149.9	5.300	150.1	5.198	150.1	5.198	150.1	1.001	1.725	Pass		Pass	Pass		
				Average		Average		0.998	1.726	Pass		Pass		Pass	
5.561	157.5	5.452	154.4	5.379	154.4	5.379	154.4	0.980	1.676	Pass		Pass	Pass		
5.553	157.3	5.452	154.4	5.379	154.4	5.379	154.4	0.982	1.676	Pass		Pass	Pass		
5.559	157.4	5.452	154.4	5.379	154.4	5.379	154.4	0.981	1.675	Pass		Pass	Pass		
				Average		Average		0.981	1.676	Pass		Pass		Pass	
5.075	143.7	5.050	143.0	4.992	143.0	4.992	143.0	0.995	1.712	Pass		Pass	Pass		
5.067	143.5	5.050	143.0	4.992	143.0	4.992	143.0	0.997	1.712	Pass		Pass	Pass		
5.077	143.8	5.050	143.0	4.992	143.0	4.992	143.0	0.995	1.714	Pass		Pass	Pass		
				Average		Average		0.996	1.713	Pass		Pass		Pass	
				Average Yd:		Average Yd:		0.986	dH@:	1.720		Q @ dH = 1:		0.572	

SIGNED: Signature on File

Date:

2/27/2020



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 38-wcs
 Readout Description: Control Box
 Date: 7/2/2020
 Performed By: JG/DH/LO/DA

Calibrated Thermocouple ID: TC-CAL
 T1 Reference Thermometer ID: 492956
 T2 Reference Thermometer ID: 242196
 T3 Reference Thermometer ID: 242167

T/C I.D. TC-CAL	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference		
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T3 (OIL)	38-wcs	349	349	349	349	350	350	350	350	1.0	0.1%	Pass
T2 (Boiling H ₂ O)	38-wcs	214	214	214	214	212	212	212	212	2.0	0.3%	Pass
T1 (Ice/Water)	38-wcs	34	34	34	34	32	32	32	32	2.0	0.4%	Pass

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N		T/C - Readout °F				T/C Source °F				Difference		
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	S/N 106970	651	651	651	651	650	650	650	650	1.0	0.1%	Pass
T3 (~370 F)	S/N 106970	368	368	368	368	365	365	365	365	3.0	0.4%	Pass
T2 (~212 F)	S/N 106970	213	212	213	213	212	212	212	212	0.7	0.1%	Pass
T1 (~32 F)	S/N 106970	35	35	35	35	32	32	32	32	3.0	0.6%	Pass

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

APPENDIX B FACILITY CEMS DATA

Average Values Report
Generated: 7/21/2020 22:05Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 1Period Start: 7/21/2020 20:42
Period End: 7/21/2020 21:44
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 1_O2 %	Average 1_NOXPPM ppm	Average 1_NOX_CORR ppm	Average 1_NOX_LBHR #/hr	Average 1_NOX_LBMM #/MBTU	Average 1_GasFlow kscfh	Average 1_LOAD MW	Average 1_STACKFLW kscfm	Average 1_COPPM ppm	Average 1_CO_CORR ppm	Average 1_CO_LBHR #/hr
07/21/2020 20:42	14.45	2.49	2.28	4.05	0.008	481.7	49.55	237.9	3.52	3.22	3.64
07/21/2020 20:43	14.45	2.48	2.27	4.05	0.008	481.6	49.46	237.9	3.52	3.22	3.64
07/21/2020 20:44	14.45	2.48	2.27	4.04	0.008	481.3	49.47	237.7	3.51	3.21	3.64
07/21/2020 20:45	14.45	2.47	2.26	4.05	0.008	481.6	49.48	237.9	3.50	3.20	3.64
07/21/2020 20:46	14.45	2.47	2.26	4.04	0.008	481.4	49.49	237.8	3.51	3.21	3.64
07/21/2020 20:47	14.45	2.47	2.26	4.04	0.008	481.3	49.45	237.7	3.53	3.23	3.64
07/21/2020 20:48	14.45	2.47	2.26	4.04	0.008	480.7	49.39	237.4	3.51	3.21	3.63
07/21/2020 20:49	14.45	2.46	2.25	4.04	0.008	481.2	49.44	237.7	3.50	3.20	3.64
07/21/2020 20:50	14.45	2.46	2.25	4.05	0.008	481.7	49.56	237.9	3.47	3.17	3.59
07/21/2020 20:51	14.45	2.47	2.26	4.04	0.008	481.2	49.48	237.7	3.50	3.20	3.64
07/21/2020 20:52	14.45	2.47	2.26	4.04	0.008	481.3	49.45	237.7	3.51	3.21	3.64
07/21/2020 20:53	14.45	2.47	2.26	4.04	0.008	481.4	49.47	237.8	3.50	3.20	3.64
07/21/2020 20:54	14.45	2.47	2.26	4.04	0.008	481.1	49.42	237.6	3.48	3.18	3.59
07/21/2020 20:55	14.45	2.48	2.27	4.05	0.008	481.6	49.50	237.9	3.47	3.17	3.59
07/21/2020 20:56	14.45	2.49	2.28	4.05	0.008	481.8	49.54	238.0	3.46	3.16	3.59
07/21/2020 20:57	14.45	2.50	2.29	4.03	0.008	480.2	49.32	237.2	3.47	3.17	3.58
07/21/2020 20:58	14.45	2.49	2.28	4.04	0.008	481.4	49.47	237.8	3.47	3.17	3.59
07/21/2020 20:59	14.45	2.48	2.27	4.03	0.008	479.4	49.20	236.8	3.47	3.17	3.57
07/21/2020 21:00	14.45	2.47	2.26	4.03	0.008	479.8	49.24	237.0	3.45	3.16	3.58
07/21/2020 21:01	14.45	2.46	2.25	4.04	0.008	480.5	49.37	237.3	3.44	3.15	3.58
07/21/2020 21:02	14.45	2.46	2.25	4.04	0.008	480.4	49.30	237.3	3.40	3.11	3.53
07/21/2020 21:03	14.45	2.47	2.26	4.03	0.008	479.4	49.23	236.8	3.38	3.09	3.47
07/21/2020 21:04	14.45	2.48	2.27	4.03	0.008	480.2	49.30	237.2	3.39	3.10	3.53
07/21/2020 21:05	14.44	2.46	2.25	4.04	0.008	480.7	49.37	237.0	3.43	3.13	3.53
07/21/2020 21:06	14.45	2.47	2.26	4.02	0.008	479.0	49.12	236.6	3.45	3.16	3.57
07/21/2020 21:07	14.45	2.49	2.28	4.01	0.008	477.7	48.91	235.9	3.44	3.15	3.56
07/21/2020 21:08	14.45	2.44	2.23	4.03	0.008	479.8	49.23	237.0	3.39	3.10	3.53
07/21/2020 21:09	14.44	2.39	2.18	4.02	0.008	478.6	49.03	236.0	3.38	3.09	3.47
07/21/2020 21:10	14.45	2.40	2.20	4.02	0.008	478.6	49.11	236.4	3.41	3.12	3.52
07/21/2020 21:11	14.45	2.39	2.19	4.04	0.008	480.5	49.31	237.3	3.43	3.14	3.53
07/21/2020 21:12	14.45	2.39	2.19	4.04	0.008	480.9	49.39	237.5	3.45	3.16	3.58
07/21/2020 21:13	14.44	2.43	2.22	4.04	0.008	481.0	49.36	237.2	3.50	3.20	3.64
07/21/2020 21:14	14.44	2.44	2.23	4.04	0.008	481.4	49.45	237.4	3.50	3.20	3.64
07/21/2020 21:15	14.44	2.43	2.22	4.05	0.008	481.6	49.43	237.5	3.52	3.21	3.64
07/21/2020 21:16	14.44	2.43	2.22	4.04	0.008	481.3	49.41	237.4	3.54	3.23	3.69
07/21/2020 21:17	14.44	2.43	2.22	4.05	0.008	481.8	49.43	237.6	3.58	3.27	3.69
07/21/2020 21:18	14.44	2.42	2.21	4.04	0.008	481.5	49.43	237.5	3.58	3.27	3.69
07/21/2020 21:19	14.44	2.42	2.21	4.05	0.008	481.9	49.43	237.6	3.59	3.28	3.74
07/21/2020 21:20	14.44	2.42	2.21	4.05	0.008	481.6	49.43	237.5	3.58	3.27	3.69
07/21/2020 21:21	14.44	2.42	2.21	4.05	0.008	481.7	49.42	237.6	3.56	3.25	3.69
07/21/2020 21:22	14.45	2.42	2.21	4.04	0.008	481.3	49.39	237.7	3.57	3.27	3.69
07/21/2020 21:23	14.44	2.41	2.20	4.04	0.008	481.4	49.41	237.4	3.62	3.31	3.74
07/21/2020 21:24	14.45	2.40	2.20	4.04	0.008	481.3	49.42	237.7	3.61	3.30	3.74
07/21/2020 21:25	14.45	2.40	2.20	4.04	0.008	481.5	49.41	237.8	3.61	3.30	3.74
07/21/2020 21:26	14.45	2.40	2.20	4.04	0.008	481.3	49.39	237.7	3.63	3.32	3.74
07/21/2020 21:27	14.45	2.40	2.20	4.04	0.008	481.2	49.37	237.7	3.67	3.36	3.79
07/21/2020 21:28	14.45	2.40	2.20	4.05	0.008	481.6	49.41	237.9	3.66	3.35	3.79
07/21/2020 21:29	14.45	2.41	2.20	4.04	0.008	481.4	49.41	237.8	3.64	3.33	3.79
07/21/2020 21:30	14.45	2.41	2.20	4.04	0.008	481.1	49.36	237.6	3.62	3.31	3.74

Period Start:	Average 1_O2 %	Average 1_NOXPPM ppm	Average 1_NOX_CORR ppm	Average 1_NOX_LBHR #/hr	Average 1_NOX_LBMM #/MBTU	Average 1_GasFlow kscfh	Average 1_LOAD MW	Average 1_STACKFLW kscfm	Average 1_COPPM ppm	Average 1_CO_CORR ppm	Average 1_CO_LBHR #/hr
07/21/2020 21:31	14.45	2.42	2.21	4.04	0.008	481.4	49.36	237.8	3.60	3.29	3.74
07/21/2020 21:32	14.45	2.41	2.20	4.04	0.008	481.3	49.36	237.7	3.60	3.29	3.74
07/21/2020 21:33	14.45	2.40	2.20	4.04	0.008	481.1	49.37	237.6	3.60	3.29	3.74
07/21/2020 21:34	14.45	2.41	2.20	4.04	0.008	481.1	49.35	237.6	3.57	3.27	3.69
07/21/2020 21:35	14.45	2.42	2.21	4.04	0.008	481.2	49.37	237.7	3.54	3.24	3.69
07/21/2020 21:36	14.45	2.42	2.21	4.04	0.008	481.3	49.39	237.7	3.54	3.24	3.69
07/21/2020 21:37	14.45	2.42	2.21	4.04	0.008	481.1	49.38	237.6	3.55	3.25	3.69
07/21/2020 21:38	14.45	2.41	2.20	4.04	0.008	481.1	49.38	237.6	3.54	3.24	3.69
07/21/2020 21:39	14.45	2.42	2.21	4.04	0.008	481.4	49.40	237.8	3.54	3.24	3.69
07/21/2020 21:40	14.45	2.44	2.23	4.04	0.008	481.2	49.40	237.7	3.57	3.27	3.69
07/21/2020 21:41	14.45	2.45	2.24	4.04	0.008	480.9	49.40	237.5	3.61	3.30	3.74
07/21/2020 21:42	14.45	2.44	2.23	4.04	0.008	481.3	49.39	237.7	3.59	3.28	3.74
07/21/2020 21:43	14.45	2.45	2.24	4.04	0.008	481.3	49.41	237.7	3.56	3.26	3.69
07/21/2020 21:44	14.45	2.44	2.23	4.04	0.008	481.2	49.40	237.7	3.54	3.24	3.69
Daily Average*	14.45	2.44	2.23	4.04	0.008	481.0	49.38	237.5	3.52	3.22	3.65
Maximum*	14.45	2.50	2.29	4.05	0.008	481.9	49.56	238.0	3.67	3.36	3.79
	07/21/2020 21:44	07/21/2020 20:57	07/21/2020 20:57	07/21/2020 21:28	07/21/2020 21:44	07/21/2020 21:19	07/21/2020 20:50	07/21/2020 20:56	07/21/2020 21:27	07/21/2020 21:27	07/21/2020 21:29
Minimum*	14.44	2.39	2.18	4.01	0.008	477.7	48.91	235.9	3.38	3.09	3.47
	07/21/2020 21:23	07/21/2020 21:12	07/21/2020 21:09	07/21/2020 21:07	07/21/2020 21:44	07/21/2020 21:07	07/21/2020 21:07	07/21/2020 21:07	07/21/2020 21:09	07/21/2020 21:09	07/21/2020 21:09

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 7/21/2020 23:19

Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 1

Period Start: 7/21/2020 22:06
Period End: 7/21/2020 23:08
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 1_O2 %	Average 1_NOXPPM ppm	Average 1_NOX_CORR ppm	Average 1_NOX LBHR #/hr	Average 1_NOX LBMM #/MBTU	Average 1_GasFlow kscfh	Average 1_LOAD MW	Average 1_STACKFLW kscfm	Average 1_COPPM ppm	Average 1_CO_CORR ppm	Average 1_CO LBHR #/hr
07/21/2020 22:06	14.45	2.36	2.16	4.05	0.008	481.9	49.40	238.0	3.70	3.38	3.85
07/21/2020 22:07	14.45	2.36	2.16	4.05	0.008	482.1	49.40	238.1	3.71	3.39	3.85
07/21/2020 22:08	14.45	2.36	2.16	4.05	0.008	482.1	49.44	238.1	3.72	3.40	3.85
07/21/2020 22:09	14.45	2.37	2.17	4.05	0.008	482.1	49.42	238.1	3.70	3.38	3.85
07/21/2020 22:10	14.45	2.38	2.18	4.05	0.008	482.0	49.42	238.1	3.70	3.38	3.85
07/21/2020 22:11	14.44	2.39	2.18	4.05	0.008	481.7	49.42	237.6	3.69	3.37	3.84
07/21/2020 22:12	14.45	2.39	2.19	4.05	0.008	481.7	49.40	237.9	3.65	3.34	3.79
07/21/2020 22:13	14.45	2.40	2.20	4.05	0.008	481.9	49.44	238.0	3.61	3.30	3.74
07/21/2020 22:14	14.45	2.41	2.20	4.04	0.008	481.5	49.39	237.8	3.57	3.27	3.69
07/21/2020 22:15	14.45	2.40	2.20	4.05	0.008	481.9	49.44	238.0	3.61	3.30	3.74
07/21/2020 22:16	14.45	2.40	2.20	4.05	0.008	482.0	49.43	238.1	3.64	3.33	3.80
07/21/2020 22:17	14.45	2.40	2.20	4.05	0.008	481.8	49.40	238.0	3.65	3.34	3.79
07/21/2020 22:18	14.45	2.40	2.20	4.05	0.008	481.9	49.38	238.0	3.62	3.31	3.74
07/21/2020 22:19	14.45	2.40	2.20	4.05	0.008	481.9	49.40	238.0	3.61	3.30	3.74
07/21/2020 22:20	14.45	2.38	2.18	4.05	0.008	481.7	49.40	237.9	3.63	3.32	3.74
07/21/2020 22:21	14.45	2.38	2.18	4.05	0.008	482.0	49.40	238.1	3.65	3.34	3.80
07/21/2020 22:22	14.45	2.39	2.19	4.04	0.008	481.4	49.40	237.8	3.66	3.35	3.79
07/21/2020 22:23	14.45	2.39	2.19	4.05	0.008	481.9	49.42	238.0	3.64	3.33	3.80
07/21/2020 22:24	14.45	2.40	2.20	4.04	0.008	481.5	49.39	237.8	3.64	3.33	3.79
07/21/2020 22:25	14.45	2.40	2.20	4.04	0.008	481.4	49.40	237.8	3.64	3.33	3.79
07/21/2020 22:26	14.45	2.41	2.20	4.05	0.008	481.8	49.41	238.0	3.63	3.32	3.74
07/21/2020 22:27	14.45	2.41	2.20	4.04	0.008	481.5	49.38	237.8	3.62	3.31	3.74
07/21/2020 22:28	14.45	2.41	2.20	4.04	0.008	481.5	49.40	237.8	3.62	3.31	3.74
07/21/2020 22:29	14.45	2.40	2.20	4.05	0.008	482.0	49.39	238.1	3.64	3.33	3.80
07/21/2020 22:30	14.45	2.40	2.20	4.05	0.008	481.8	49.42	238.0	3.65	3.34	3.79
07/21/2020 22:31	14.45	2.40	2.20	4.05	0.008	482.2	49.43	238.2	3.66	3.35	3.80
07/21/2020 22:32	14.45	2.41	2.20	4.05	0.008	482.2	49.43	238.2	3.64	3.33	3.80
07/21/2020 22:33	14.45	2.42	2.21	4.05	0.008	481.8	49.40	238.0	3.65	3.34	3.79
07/21/2020 22:34	14.45	2.42	2.21	4.05	0.008	482.0	49.41	238.1	3.64	3.33	3.80
07/21/2020 22:35	14.45	2.40	2.20	4.05	0.008	482.0	49.41	238.1	3.66	3.35	3.80
07/21/2020 22:36	14.45	2.40	2.20	4.05	0.008	481.8	49.43	238.0	3.69	3.38	3.84
07/21/2020 22:37	14.45	2.40	2.20	4.05	0.008	482.2	49.40	238.2	3.71	3.39	3.85
07/21/2020 22:38	14.45	2.40	2.20	4.05	0.008	482.0	49.39	238.1	3.68	3.37	3.85
07/21/2020 22:39	14.45	2.40	2.20	4.05	0.008	482.2	49.40	238.2	3.67	3.36	3.80
07/21/2020 22:40	14.45	2.40	2.20	4.05	0.008	482.0	49.40	238.1	3.65	3.34	3.80
07/21/2020 22:41	14.45	2.40	2.20	4.05	0.008	481.8	49.35	238.0	3.64	3.33	3.79
07/21/2020 22:42	14.49	2.41	2.22	4.00	0.008	475.8	48.62	236.5	3.63	3.34	3.75
07/21/2020 22:43	14.50	2.34	2.16	4.00	0.008	476.8	48.74	237.3	3.79	3.49	3.90
07/21/2020 22:44	14.49	2.20	2.02	3.50	0.007	476.8	48.72	236.9	3.86	3.55	4.00
07/21/2020 22:45	14.51	2.17	2.00	3.50	0.007	476.0	48.64	237.3	3.87	3.57	4.00
07/21/2020 22:46	14.51	2.16	1.99	3.50	0.007	475.8	48.64	237.2	3.88	3.58	4.00
07/21/2020 22:47	14.51	2.09	1.93	3.50	0.007	476.4	48.68	237.5	4.00	3.69	4.15
07/21/2020 22:48	14.51	2.06	1.90	3.51	0.007	477.0	48.79	237.8	4.05	3.74	4.21
07/21/2020 22:49	14.49	2.08	1.91	3.51	0.007	477.3	48.82	237.2	4.00	3.68	4.16
07/21/2020 22:50	14.50	2.20	2.03	3.51	0.007	477.0	48.77	237.5	3.81	3.51	3.96
07/21/2020 22:51	14.48	2.50	2.30	4.00	0.008	476.7	48.74	236.5	3.62	3.33	3.75
07/21/2020 22:52	14.51	2.69	2.48	4.50	0.009	476.1	48.70	237.4	3.57	3.30	3.70
07/21/2020 22:53	14.50	2.72	2.51	4.51	0.009	477.0	48.76	237.5	3.70	3.41	3.86
07/21/2020 22:54	14.48	2.59	2.38	4.51	0.009	477.0	48.78	236.7	3.83	3.52	3.96

Period Start:	Average 1_O2 %	Average 1_NOXPPM ppm	Average 1_NOX_CORR ppm	Average 1_NOX_LBHR #/hr	Average 1_NOX_LBMM #/MBTU	Average 1_GasFlow kscfh	Average 1_LOAD MW	Average 1_STACKFLW kscfm	Average 1_COPPM ppm	Average 1_CO_CORR ppm	Average 1_CO_LBHR #/hr
07/21/2020 22:55	14.50	2.56	2.36	4.51	0.009	477.5	48.85	237.7	3.86	3.56	4.01
07/21/2020 22:56	14.48	2.60	2.39	4.51	0.009	477.6	48.85	237.0	3.82	3.51	3.96
07/21/2020 22:57	14.47	2.61	2.39	4.51	0.009	477.1	48.80	236.4	3.79	3.48	3.91
07/21/2020 22:58	14.49	2.66	2.45	4.50	0.009	476.2	48.73	236.7	3.72	3.42	3.85
07/21/2020 22:59	14.53	2.66	2.46	4.49	0.009	475.3	48.64	237.7	3.75	3.47	3.89
07/21/2020 23:00	14.50	2.50	2.30	4.00	0.008	476.3	48.72	237.1	3.98	3.67	4.10
07/21/2020 23:01	14.46	2.34	2.14	4.01	0.008	477.4	48.85	236.2	3.95	3.62	4.06
07/21/2020 23:02	14.49	2.42	2.23	4.00	0.008	476.7	48.81	236.9	3.73	3.43	3.85
07/21/2020 23:03	14.50	2.48	2.29	4.00	0.008	476.0	48.69	236.9	3.63	3.35	3.75
07/21/2020 23:04	14.53	2.43	2.25	3.99	0.008	475.1	48.63	237.6	3.75	3.47	3.89
07/21/2020 23:05	14.54	2.31	2.14	3.98	0.008	474.4	48.52	237.6	4.03	3.74	4.18
07/21/2020 23:06	14.49	2.24	2.06	3.97	0.008	472.8	48.32	235.0	4.11	3.78	4.22
07/21/2020 23:07	14.49	2.36	2.17	4.00	0.008	476.5	48.79	236.8	3.86	3.55	4.00
07/21/2020 23:08	14.52	2.56	2.37	4.49	0.009	474.9	48.57	237.1	3.48	3.22	3.59
Daily Average*	14.47	2.40	2.20	4.04	0.008	479.5	49.11	237.6	3.72	3.42	3.86
Maximum*	14.54	2.72	2.51	4.51	0.009	482.2	49.44	238.2	4.11	3.78	4.22
	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020
	23:05	22:53	22:53	22:57	23:08	22:39	22:15	22:39	23:06	23:06	23:06
Minimum*	14.44	2.06	1.90	3.50	0.007	472.8	48.32	235.0	3.48	3.22	3.59
	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020	07/21/2020
	22:11	22:48	22:48	22:47	22:50	23:06	23:06	23:06	23:08	23:08	23:08

* Does not include Invalid Averaging Periods ("N/A")

W002AS-682102-RT-1480

30 of 56

APPENDIX C CALCULATIONS

Appendix C.1

General Emissions Calculations

GENERAL EMISSION CALCULATIONS

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^\circ R}{T_{ref}}$$

VII. Particulate emissions

- (a) Grain loading, gr/dscf
 $C = 0.01543 (M_n/V_{mstd})$
- (b) Grain loading at 12% CO₂, gr/dscf
 $C_{12\% CO_2} = C (12/\% CO_2)$
- (c) Mass emissions, lb/hr
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$
- (d) Particulate emission factor
 $\text{lb}/10^6 \text{ Btu} = C * \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% O_2}$

Nomenclature:

A_s	= stack area, ft ²
B_{wo}	= flue gas moisture content, dimensionless
$C_{12\%CO_2}$	= particulate grain loading, gr/dscf corrected to 12% CO ₂
C	= particulate grain loading, gr/dscf
C_p	= pitot calibration factor, dimensionless
D_n	= nozzle diameter, in.
F	= fuel F-Factor, dscf/MMBtu @ 0% O ₂
H	= orifice differential pressure, iwg
I	= % isokinetics
M_n	= mass of collected particulate, mg
M_i	= mass emission rate of specie i, lb/hr
MW	= molecular weight of flue gas, lb/lb-mole
M_{wi}	= molecular weight of specie i: SO ₂ : 64 NO _x : 46 CO: 28 HC: 16
t	= sample time, min.
ΔP	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	= barometric pressure, inches Hg
P_s	= stack absolute pressure, inches Hg
P_{sg}	= stack static pressure, iwb
Q	= wet stack flow rate at actual conditions, wacfm
Q_{sd}	= dry standard stack flow rate, dscfm
SV	= specific molar volume of an ideal gas at standard conditions, ft ³ /lb-mole
T_m	= meter temperature, °R
T_{ref}	= reference temperature, °R
T_s	= stack temperature, °R
V_s	= stack gas velocity, ft/sec
V_{lc}	= volume of liquid collected in impingers, ml
V_m	= uncorrected dry meter volume, dcf
V_{mstd}	= dry meter volume at standard conditions, dscf
V_{wstd}	= volume of water vapor at standard conditions, scf
Y_d	= meter calibration coefficient

Appendix C.2

Spreadsheet Summaries

SCAQMD METHOD 207.1 DATA WORKSHEET AND SUMMARY

Facility.....	Canyon		Parameter.....	NH₃	
Unit.....	U1		Fuel.....	Natural gas	
Sample Location.....	Stack		Data By.....	SD	
Test Number.....	1-NH3-U1	2-NH3-U1	Average	Maximum	Limit
Reference Temperature (°F).....	60	60			
Test Date.....	7/21/2020	7/21/2020			
Test Method.....	SCAQMD 207.1	SCAQMD 207.1			
Sample Train.....	38-WCS	38-WCS			
Meter Calibration Factor.....	0.986	0.986			
Stack Area (ft ²).....	106.90	106.90			
Sample Time (Minutes).....	60	60			
Barometric Pressure ("Hg).....	29.58	29.58			
Start/Stop Time	2041/2144	2205/2308			
Meter Volume (acf).....	48.990	48.081			
Meter Temperature (°F).....	74.0	73.6			
Meter Pressure (iwg).....	2.0	2.0			
Liquid Volume (ml).....	132.1	130.8			
Stack O ₂ (%).....	14.45	14.47	14.46	(from facility CEMS)	
Unit Load (MW).....	49	49	49.2		
Standard Sample Volume (SCF).....	46.731	45.898			
Moisture Fraction.....	0.116	0.117			
Stack Flow Rate (dscfm, 68 °F).....	237,500	237,600	237,550	(from facility CEMS)	
Stack Flow Rate (@ Tref).....	233,902	234,000	233,951		
Gas Constant (ft-lbf/lb-mole-R).....	1545.33	1545.33			
Molecular Weight NH ₃ (lb/lb-mole).....	17.03	17.03			
Specific Molar Volume (ft ³ /lb-mole).....	379.5	379.5			
F-Factor (dscf/MMBtu).....	8,710	8,710			
HHV(Btu/SCF).....	1,050	1,050			
Mass Conversion (lb/ug).....	2.2046E-09	2.2046E-09			
O ₂ Correction Factor (%).....	15	15			
Mass NH ₃ (ug).....	1,518	1,385			
Mass NH ₃ (lb).....	3.35E-06	3.05E-06			
NH ₃ (ppmv, flue gas).....	1.6	1.5	1.5	1.6	
NH ₃ (ppmv @ O ₂ Correction Factor).....	1.5	1.4	1.4	1.5	5
NH ₃ (lb/hr).....	1.0	0.9	1.0	1.0	
NH ₃ (lb/MMBtu).....	0.002	0.002	0.002	0.002	
NH ₃ (lb/MMSCF).....	2.1	1.9	2.0	2.1	

Note: SCAQMD Method 207.1 requires the higher of the duplicate runs be reported as the test result.

SCAQMD 207.1 EXAMPLE CALCULATION

TEST NUMBER: 1-NH3-U1

Identifier	Description	Units	Equation	Value
A	Reference Temperature	F	--	60
B	Reference Temperature	R	$A + 460$	520
C	Meter Calibration Factor (Yd)	--	--	0.986
D	Barometric Pressure	" Hg	--	29.58
E	Meter Volume	acf	--	48.990
F	Meter Temperature	F	--	74.0
G	Meter Temperature	R	$F + 460$	534.0
H	Delta H	" H ₂ O	--	2.0
I	Meter Volume (standard)	dscf	$0.03342 * E * (D + H/13.6) * B/G * C$	46.731
J	Liquid Collected	grams	--	132.1
K	Water vapor volume	scf	$0.0472 * J * B/528$	6.141
L	Moisture Content	--	$K/(K + I)$	0.116
M	Gas Constant	ft-lbf/lb-mole-R	--	1545.33
N	Specific Molar Volume	SCF/lb-mole	$385.3 * B / 528$	379.5
O	F-Factor	dscf/MMBtu	--	8,710
P	HHV	Btu/SCF	--	1,050
Q	Mass Conversion Factor	lb/ug	--	2.2046E-09
R	O ₂ Correction Factor	--	--	15
S	Stack Flow Rate @ 68 F	dscfm	--	237,500
T	Stack Flow Rate @ Tref	dscfm	$S * B/528$	233,902
U	Mass NH ₃	ug	--	1,518
V	Mass NH ₃	lb	$U * Q$	3.35E-06
W	MW of NH ₃	lb/lb-mole	--	17.03
X	NH ₃	ppm	$(V * N * 10^6)/(I * W)$	1.6
Y	Flue Gas O ₂	%	--	14.45
Z	NH ₃	ppmc	$X * (20.9 - R)/(20.9 - Y)$	1.5
AA	NH ₃	lb/hr	$X * T * W * 60/(N * 10^6)$	1.0
AB	NH ₃	lb/MMBtu	$(X * W * O)/(385.3 * 10^6) * 20.9/(20.9 - Y)$	0.002
AC	NH ₃	lb/MMSCF	$AB * P$	2.1

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

APPENDIX D

QUALITY ASSURANCE

Appendix D.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, will be present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)

The following safety measures will be followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO _x Analyzer	Daily	NO ₂ -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	+/- 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	+/- 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for $\Delta H@$	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	+/- 1.5%

Note: Calibration requirements that meet applicable regulatory agency requirements will be used.

Appendix D.2

SCAQMD and STAC Certifications



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 6, 2019

Mr. John Peterson
Montrose Air Quality Services, LLC
1631 E. Saint Andrew Place
Santa Ana, CA 92705

Subject: LAP Approval Notice
Reference # 96LA1220

Dear Mr. Peterson:

We have reviewed your renewal letter under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning September 30, 2019, and ending September 30, 2020 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

Methods 1-4	Methods 5.1, 5.2, 5.3, 6.1
Methods 10.1 and 100.1	Methods 25.1 and 25.3 (Sampling)
USEPA CTM-030 and ASTM D6522-00	Rule 1121/ 1146.2 Protocol
Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling	

Your LAP approval to perform nitrogen oxide emissions compliance testing for Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler 1510 North Spring Street Los Angeles, CA 90012	Noritz America Corp. 11160 Grace Avenue Fountain Valley, CA 92708	Ajax Boiler, Inc. 2701 S. Harbor Blvd. Santa Ana, CA 92704
---	---	--

Laundry Building of VA Greater Los Angeles Healthcare System
508 Constitution Avenue
Los Angeles, CA 90049

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerely,

A handwritten signature in black ink that reads 'D. Sarkar'.

Dipankar Sarkar
Program Supervisor
Source Test Engineering

DS:GK/gk
Attachment

190906 LapRenewalRev.doc



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 11th day of February 2020.



Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3925.01
Valid to February 28, 2022

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

Appendix D.3

Individual QI Certificate

CERTIFICATE OF COMPLETION

Sean Donovan

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

SCAQMD Method 207.1

Certificate Number: 002-2016-06

Tate Strickler

Tate Strickler, Accreditation Director

DATE OF ISSUE:

11/30/16

DATE OF

EXPIRATION:

11/30/21



MONTROSE
ENVIRONMENTAL

APPENDIX E APPLICABLE PERMIT SECTIONS



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: POWER GENERATION					
GAS TURBINE, NO. 1, NATURAL GAS, GENERAL ELECTRIC, MODEL LM6000PC SPRINT, SIMPLE CYCLE, 479 MMBTU/HR AT 46 DEG F, WITH INLET CHILLING, WITH WATER INJECTION WITH A/N: 555828	D1	C3	NOX: MAJOR SOURCE**	CO: 4 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV NATURAL GAS (5) [RULE 407, 4-2-1982]; NOX: 2.5 PPMV NATURAL GAS (4) [RULE 2005, 6-3-2011]; NOX: 25 PPMV NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; PM10: 0.01 GRAINS/SCF NATURAL GAS (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM10: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409, 8-7-1981]; PM10: 1.67 LBS/HR NATURAL GAS (5C) [RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]; PM10: 11 LBS/HR NATURAL GAS (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 0.06 LBS/MMBTU NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; VOC: 2 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A63.1, A99.1, A99.2, A99.3, A195.1, A195.2, A195.3, A327.1, B61.1, D12.1, D29.2, D29.3, D82.1, D82.2, E193.1, H23.1, I298.1, K40.1
GENERATOR, 50.95 MW					

- * (1) (1A) (1B) Denotes RECLAIM emission factor (2) (2A) (2B) Denotes RECLAIM emission rate
(3) Denotes RECLAIM concentration limit (4) Denotes BACT emission limit
(5) (5A) (5B) Denotes command and control emission limit (6) Denotes air toxic control rule limit
(7) Denotes NSR applicability limit (8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(9) See App B for Emission Limits (10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: POWER GENERATION					
CO OXIDATION CATALYST, NO. 1, BASF, 110 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 476654	C3	D1 C4			
SELECTIVE CATALYTIC REDUCTION, NO. 1, CORMETECH CMHT-21, 1012 CU.FT.; WIDTH: 2 FT 6 IN; HEIGHT: 25 FT 9 IN; LENGTH: 18 FT WITH A/N: 476654 AMMONIA INJECTION	C4	C3 S6		NH3: 5 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]	A195.4, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
STACK, TURBINE NO. 1, HEIGHT: 86 FT ; DIAMETER: 11 FT 8 IN A/N: 555828	S6	C4			

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : C4, C10, C16, C22]

- D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[**RULE 1110.2, 2-1-2008; RULE 1110.2, 9-7-2012; RULE 1303(b)(2)-Offset, 5-10-1996;**
RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 9-10-2010; RULE 1470, 5-4-2012;
RULE 2012, 5-6-2005; 40CFR 60 Subpart III, 1-30-2013]

[Devices subject to this condition : D25]

- D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test(s) shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

If the turbine is not in operation during one calendar year, then no testing is required during that calendar year.

The NO_x concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted and the results submitted to the District within 60 days after the test date.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1, D7, D13, D19]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Sampling Time	Test Location
SOX emissions	AQMD Laboratory Method 307-91	Not Applicable	Fuel sample
VOC emissions	District Method 25.3	1 hour	Outlet of the SCR serving this equipment
PM emissions	District method 5.1	4 hours	Outlet of the SCR serving this equipment

THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Sean Donovan
Title: Client Project Manager
Region: West
Email: SDonovan@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: West
Email: MMccune@montrose-env.com
Phone: (714) 279-6777

**TEST REPORT FOR
3Q20 AMMONIA SLIP TEST
AT CANYON POWER PLANT UNIT 2
FACILITY ID: 153992, DEVICE ID: D7**

Prepared For:

Canyon Power Plant
3071 E. Mira Loma Avenue
Anaheim, California 92806

For Submittal To:

South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765-4178

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
(714) 282-8240

Sean Donovan

Test Date: **July 23, 2020**
Production Date: **August 18, 2020**
Report Number: **W002AS-682102-RT-1481**



CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature: Sean Donovan Date: 8/18/2020
Name: Sean Donovan Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: Mike Chowsanitphon Date: 8/18/2020
Name: Mike Chowsanitphon Title: Reporting Manager

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY	5
2.0 UNIT AND CEMS DESCRIPTION	6
2.1 UNIT DESCRIPTION	6
2.2 TEST CONDITIONS	7
2.3 SAMPLE LOCATION	7
3.0 TEST DESCRIPTION	8
4.0 TEST RESULTS AND OVERVIEW	9
4.1 TEST RESULTS	9
4.2 TEST OVERVIEW	9

LIST OF APPENDICES

A RAW DATA	10
A.1 Sample Data Sheets	11
A.2 Laboratory Data	15
A.3 QA/QC Data	22
B FACILITY CEMS DATA	26
C CALCULATIONS	31
C.1 General Emissions Calculations	32
C.2 Spreadsheet Summaries	36
D QUALITY ASSURANCE	39
D.1 Quality Assurance Program Summary	40
D.2 SCAQMD and STAC Certifications	46
D.3 Individual Qi Certificate	49
E APPLICABLE PERMIT SECTIONS	51

LIST OF TABLES

1-1 AMMONIA SLIP TEST RESULTS SUMMARY	5
4-1 AMMONIA SLIP TEST RESULTS	9

LIST OF FIGURES

2-1 UNIT BLOCK DIAGRAM	6
3-1 SCAQMD METHOD 207.1 SAMPLE EQUIPMENT	8

1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS), was contracted by the Canyon Power Plant to perform an ammonia slip test at Unit 2 as required by the facility Permit (Facility ID 153992) Condition Number D29.2. This report documents the results of the ammonia slip tests performed on July 23, 2020. The test was performed by Sean Donovan, Danny Avila, Rik Dupont, and Robert Howard. Sean Donovan was the on-site Qualified Individual for MAQS. Bertha Hernandez coordinated the test for Canyon Power Plant.

The test consisted of duplicate ammonia tests performed at 50 MW. The test program followed the procedures described in the initial compliance test protocol (MAQS document R038842). The results of the test are summarized in Table 1-1. The table shows that the ammonia slip from this unit was less than the permitted limit of 5 ppm corrected to 15% O₂.

**TABLE 1-1
AMMONIA SLIP TEST RESULTS SUMMARY
CANYON POWER PLANT UNIT 2
JULY 23, 2020**

Parameter	Result ⁽¹⁾	Limit
NH ₃		
ppm	2.4	--
ppmc	2.3	5

(1) Maximum of duplicate runs, as required by SCAQMD Method 207.1


Section 2 of this document provides a brief description of the unit, test conditions, sample location, and CEMS. Details of the test procedures are provided in Section 3. Section 4 provides the results of each individual test. All raw data, calculations, quality assurance data, unit operating conditions, and CEMS data are provided in the appendices.

2.0 UNIT AND CEMS DESCRIPTION

2.1 UNIT DESCRIPTION

The City of Anaheim Canyon Power Plant is located at 3071 E. Mira Loma Avenue, Anaheim, California 92806. The facility consists of four identical generating units. Each unit consists of a natural gas fired, GE Model LM6000PC Sprint simple cycle, gas turbine. The units are natural gas fired with a rated heat input of 479 MMBtu per hour at 46°F, with water injection. The units are equipped with a CO catalyst and Selective Catalytic Reduction (SCR) system for NO_x control. Figure 2-1 presents a block diagram of the unit.

**FIGURE 2-1
UNIT BLOCK DIAGRAM
CANYON POWER PLANT**



Stack Inside Diameter:	11 feet, 8 inches
Distance from Upstream Disturbance:	23 feet, 4 inches (2.0 Diameters)
Distance from Stack Exit:	16 feet, 6 inches (1.4 Diameters)

2.2 TEST CONDITIONS

The tests were performed with the unit operating at an average load of 50 MW. Tests were performed while the unit was firing natural gas and operating under normal conditions. Unit operation was established by the Canyon Power Plant operators.

2.3 SAMPLE LOCATION


The measurements were made from sample ports located on the exhaust stack. There are four sample ports equally spaced at this location. The stack inside diameter at the sample plane is 11 feet, 8 inches. The sample ports are located 23 feet, 4 inches (2.0 diameters) downstream of the nearest flow disturbance and 16 feet, 6 inches (1.4 diameters) from the stack exit.

3.0 TEST DESCRIPTION

Flue gas samples were collected non-isokinetically using a SCAQMD Method 207.1 sample train. The samples were collected using a 12-point traverse at the exhaust stack location. Each test was performed over a 60 minute interval. The sample gas was drawn through a glass probe, Teflon sample line, two impingers each containing 100 ml of 0.1N H₂SO₄, an empty impinger, an impinger containing silica gel, and a dry gas meter. The optional nozzle and filter were not used since the source is natural gas fired. The contents of the sample line and the first three impingers were recovered and analyzed by SCAQMD Method 207.1 for ammonia concentration by Ion Specific Electrode analysis. Figure 3-1 presents a diagram of the sampling equipment.

Stack O₂ and NO_x concentrations and stack volumetric flow rate data were recorded from the Continuous Emission Monitoring System (CEMS) which is installed on the unit. These data were used to correct the ammonia concentration to 15% O₂.

FIGURE 3-1
SCAQMD METHOD 207.1 SAMPLE EQUIPMENT



4.0 TEST RESULTS AND OVERVIEW

4.1 TEST RESULTS

The results of the test are summarized in Table 4-1. The results show that the ammonia slip was 2.3 ppm @ 15% O₂ which is less than the permitted limit of 5 ppm @ 15% O₂.

**TABLE 4-1
AMMONIA SLIP TEST RESULTS
CANYON POWER PLANT UNIT 2
JULY 23, 2020**

Parameter/Units	Run 1	Run 2	Average	Maximum ⁽¹⁾	Limit
Test	1-NH ₃ -U2	2-NH ₃ -U2			--
Date	7/23/2020	7/23/2020			--
Time	2010/2118	2141/2244			--
O₂, %⁽²⁾	14.65	14.61	14.63	--	--
Stack Flow, dscfm @ T_{ref}⁽²⁾	236,265	235,576	235,920	--	--
NO_x, ppmc⁽²⁾	2.2	2.2	2.2	--	2.5
NH₃					
ppm	2.4	1.7	2.1	2.4	--
ppmc	2.3	1.6	1.9	2.3	5
lb/hr	1.5	1.1	1.3	1.5	--
lb/MMBtu	0.003	0.002	0.003	0.003	--
lb/MMSCF	3.3	2.3	2.8	3.3	--

(1) Maximum of duplicate test runs, as required by SCAQMD Method 207.1

(2) From facility CEMS

4.2 TEST OVERVIEW

The test program was successful in meeting the program objectives. The sample train was leak checked before and after the test and all QA/QC requirements of SCAQMD Method 207.1 were satisfied.

APPENDIX A RAW DATA

Appendix A.1

Sample Data Sheets

CLIENT: SCPPA
LOCATION: Canyon 2
DATE: 7/23/20
RUN NO: EB-NH3
OPERATOR: RH
METER BOX NO: 35 WCC
METER Yd: 0.980

CEMS Heated Line Temp: NA
CEMS Knock Out Temp: NA
CHECK WEIGHT: 499.8
7270 499.8 / 500.0

AMBIENT TEMPERATURE: 70°
 BAROMETRIC PRESSURE: 29.64
 ASSUMED MOISTURE : NA
 PITOT TUBE COEFF, Cp: NA
 PROBE ID NO/MATERIAL: NA / T1
 PROBE LENGTH: 8'
 PRE-TEST LEAK RATE 2005 CFM@ 14 in. Hg
 POST-TEST LEAK RATE : CFM@ in. Hg
 PITOT LEAK CHECK - PRE: POST:

Imp. #	Contents	Post-Test	Pre-Test	Difference
1	H ₂ SO ₄	764.0	664.2	
2	H ₂ SO ₄	653.3	683.3	
3	MT	630.4	630.4	
4	SB	990.4	990.3	
Total:	LR		1800	

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In Out		Vacuum in. Hg.	Pstatic in. H ₂ O
FIELD												
BLANK												
N/A												
Average:												

Comments: _____

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: SCPPA
LOCATION: Campan 2
DATE: 7/23/20
RUN NO: 2-NH3-2
OPERATOR: RU
METER BOX NO: 38-WCS
METER Yd: 0.980

CEMS Heated Line Temp: 281
CEMS Knock Out Temp: 00.2
CHECK WEIGHT: 499.8 / 500.0

AMBIENT TEMPERATURE: 70
BAROMETRIC PRESSURE: 29.61
ASSUMED MOISTURE: -12%
PITOT TUBE COEFF, Cp: NA
PROBE ID NO/MATERIAL: NA/Ti
PROBE LENGTH: 8'
PRE-TEST LEAK RATE: 0.005 CFM@ 14 in. Hg
POST-TEST LEAK RATE: 0.005 CFM@ 18 in. Hg

PITOT LEAK CHECK - PRE: NA POST: NA

Imp. # Contents Post-Test - Pre-Test = Difference

1 H2SO4 939.8 723.8
2 H2SO4 716.0 712.7
3 MT 670.6 669.5
4 SG 890.2 881.0
Total: LR Ø 1001

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	Pstatic in. H ₂ O
3	2141	919.200	NA	2.0	NA	NA	NA	54	74	72	5	
2	2146	-						-	-	-	-	
1	2151	-						-	-	-	-	
PL	2156	930.857						-	-	-	-	
-	-	-						-	-	-	-	
3	2157	930.857						52	75	72	5	
2	2202	-						-	-	-	-	
1	2207	-						-	-	-	-	
PL	2217	942.524						-	-	-	-	
-	2218 2220	-						-	-	-	-	
3	2213	942.524						50	73	71	5	
2	2216	-						-	-	-	-	
1	2223	-						-	-	-	-	
PL	2228	954.570						-	-	-	-	
-	-	-						-	-	-	-	
3	2229	954.570						52	74	72	5	
2	2234	-						-	-	-	-	
1	2239	-						-	-	-	-	
END	2244	967.117						-	-	-	-	
Average:												

Comments: _____

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: City of Anaheim
LOCATION: Canyon 2
DATE: 7/21/20
RUN NO: 1-NH₃-42
OPERATOR: RH 31-000 RH = 23-2020
METER BOX NO: B-WCS
METER Yd: 0.986

CEMS Heated Line Temp: 276
CEMS Knock Out Temp: 00.3
CHECK WEIGHT: 499.8/500.0

AMBIENT TEMPERATURE: 70
BAROMETRIC PRESSURE: 29.64
ASSUMED MOISTURE: ~12%
PITOT TUBE COEFF, Cp: NH
PROBE ID NO/MATERIAL: T-2
PROBE LENGTH: 10'
PRE-TEST LEAK RATE: 0.005 CFM@ 18 in. Hg
POST-TEST LEAK RATE: 0.005 CFM@ 19 in. Hg

PITOT LEAK CHECK - PRE: NH POST: NH

Imp. # Contents Post-Test - Pre-Test = Difference

1 H₂SO₄ 879.9 669.7
2 H₂SO₄ 682.2 681.3
3 MT 631.5 630.8
4 SO 1004.9 939.2 990.3
Total: LR P 56 7/21/20
100

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Meter Temp, °F Out	Vacuum in. Hg.	Pstatic in. H ₂ O
3	2010	869.200	N/A	2.6	N/A	N/A	N/A	56	75	74	7	
2	2015	—						—	—	—	—	
1	2020	—						—	—	—	—	
PL	2025	881.303						—	—	—	—	
3	2026	881.303						55	76	74	7	
2	2031	—						—	—	—	—	
1	2036	—						—	—	—	—	
PL	2041	893.664						—	—	—	—	
3	2044	893.664						53	75	71	7	
2	2049	—						—	—	—	—	
1	2054	—						—	—	—	—	
PL	2059	905.763						—	—	—	—	
3	2103	905.763						54	75	71	7	
2	2108	—						—	—	—	—	
1	2112	—						—	—	—	—	
END	2118	917.797						—	—	—	—	
Average:												

Comments: _____

Appendix A.2 Laboratory Data



AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS

Project #: W02AS-682102 District Method: SCAQMD 207.1 Sample Date: 7/23/2020
 Client/Location: SCPPA Canyon River Calibration Date: 7/27/2020 Analysis Date: 7/27/2020
 Sample Location: Stack U2 Calibration Curve: $y = 34.2597x + 79.3547$ Analyst's Initials: CM
 Test #'s: 1-2-1115 R²: 0.9999 Room Temperature (°C): 22.0

Sample	Total Vol. (mL)	Electrode Potential (mV)	Conc. $\mu\text{g NH}_3 - \text{N / ml}$	Cavg ($\mu\text{g NH}_3 - \text{N / ml}$)	$\mu\text{g NH}_3 / \text{sample}$	T (°C)	Blue after + ISA (Y/N)	pH	% R
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	1.3 27.456	27.456	27.750	—	22.6	Y	—	0.893
		0.8	28.044			22.6	Y		
1-NH ₃	526.8	49.3	3.581	3.566	2283.390	22.5	Y	C2	—
		49.5	3.551			22.5	Y		
2-NH ₃	561.2	59.5	2.323	2.308	1574.529	22.5	Y	C2	—
		59.8	2.293			22.5	Y		
Spike: 1-NH ₃ +2ml 1000ppm NH ₃	—	7.1	21.465	21.420	—	22.5	Y	—	93.20
		7.2	21.374			22.5	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	1.0	27.807	27.807	—	22.6	Y	—	0.688
		1.0	27.807			22.6	Y		
Reagent Blank 0.1N H ₂ SO ₄	—	141.6	0.071	0.071	—	23.0	Y	—	—
		141.6	0.071			23.0	Y		
DI H ₂ O Blank	—	144.5	0.063	0.063	—	23.0	Y	—	—
		144.4	0.063			23.0	Y		
Field Blank	428.3	120.4	0.175	0.174	90.657	23.0	Y	C2	—
		120.7	0.173			23.0	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	0.8	28.044	28.164	—	22.6	Y	—	0.585
		0.6	28.283			22.6	Y		

Notes: Total volume of samples and standards used: 100 ml

Volume of pH adjusting ISA used in ml: 2 ml

Absorbing solution: 0.1N H₂SO₄

Calculations: Conc. ($\mu\text{g NH}_3 - \text{N / ml}$) = $10^{(P-B)/M}$; (P = electrode potential, B = y-intercept and M = slope)

Cavg = average result of duplicate analyses ($\mu\text{g NH}_3 - \text{N / ml}$) = $(C1+C2)/2$

$\mu\text{g NH}_3 / \text{sample} = \text{Cavg} \times 17.03 / 14.01 \times \text{TV}$

mg / sample = $\mu\text{g / sample} \div 1000$

ppm NH₃ = $\text{mg NH}_3 / \text{sample} \times 1 / \text{Vstd} \times 1 / 454000 \times \text{SV} / 17 \times 10^6$

* CM
7/27/20



AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALCULATION

Project Number: 002AS-682102
 Client/ Location: SCPPA-Canyon Power Plant
 Sample Location: Stack U2
 District Method: SCAQMD 207.1
 Sample Date: 7/23/2020
 Analysis Date: 7/27/2020
 Analyst's Initials: LM
 Calibration Curve Slope -54.2597
 Y-intercept 79.3597
 R² 0.9999

Sample	P mV	Conc. µg NH ₃ /ml as N	C avg as N	TV (ml)	C avg as NH ₃	µg NH ₃ / sample
28 ug NH ₃ / ml as N	1.3	27.456				
Repeat 28 ug NH ₃ /ml as N	0.8	28.044	27.750	NA	33.732	NA
1-NH ₃	49.3	3.581				
Repeat 1- NH ₃	49.5	3.551	3.566	526.8	4.334	2283.390
2-NH ₃	59.5	2.323				
Repeat 2- NH ₃	59.8	2.293	2.308	561.2	2.806	1574.529
spike 1-NH ₃	7.1	21.465				
Repeat 1-NH ₃ spike	7.2	21.374	21.420	NA	26.037	NA
28 NH ₃ /ml as N	1.0	27.807				
Repeat 28 ug NH ₃ /ml as N	1.0	27.807	27.807	NA	33.802	NA
Reagent Blank	141.6	0.071				
Repeat Reagent Blank	141.6	0.071	0.071	NA	0.087	NA
Field Blank	120.4	0.175				
Repeat Field Blank	120.7	0.173	0.174	428.3	0.212	90.657
DI H ₂ O Blank	144.4	0.063				
Repeat DI H ₂ O Blank	144.5	0.063	0.063	NA	0.077	NA
28 NH ₃ /ml as N	0.8	28.044				
Repeat 28 ug NH ₃ /ml as N	0.6	28.283	28.164	NA	34.235	NA

Notes:

Measured Concentration of Ammonia (C) in µg NH₃ / ml as N

$$C=10^{(P-B)/M}$$

P = electrode potential (mV), M=slope and B=intercept

Average Measured Ammonia Concentration (Cavg) = (C1 + C2)/2

where C1, C2 results from duplicate analyses (µg NH₃/ml as N)

Cavg (µg NH₃/ml as NH₃) = Cavg (µg NH₃/ ml as N) * 17.03/ 14.01

µg NH₃ / sample = Cavg (µg NH₃/ml as NH₃) * TV

Used 100 ml of samples and standards with 2 ml ISA and constant stirring rate.

All solutions turned blue and remained blue with ISA unless otherwise indicated.

Sample PH and Temperatures can be found on the laboratory datasheet.

Maximum samples (including blanks) between 28 ug/ml check standard is 5 samples analyzed in duplicate.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS QUALITY CONTROL

Project Number: 002AS-682102
 Client/ Location: SCPPA-Canyon Power Plant
 Sample Location: Stack U2
 District Method: SCAQMD 207.1
 Sample Date: 7/23/2020
 Analysis Date: 7/27/2020
 Analyst's Initials: LM

Sample	% recovery	RPD %	RPA %
28 ug NH3 / ml as N Repeat 28 ug NH3/ml as N	NA	-2.12	-0.893
1-NH3 Repeat 1- NH3	NA	0.85	NA
2-NH3 Repeat 2- NH3	NA	1.27	NA
spike 1-NH3 Repeat 1-NH3 spike	93.20	0.42	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as N	NA	0.00	-0.688
Reagent Blank Repeat Reagent Blank	NA	0.00	NA
Field Blank Repeat Field Blank	NA	1.27	NA
DI H2O Blank Repeat DI H2O Blank	NA	0.42	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as N	NA	-0.85	0.585

Notes:

spike: 100 ml sample + 2 ml (1000 µg NH₃ / ml as N)

Matrix Spike Percent Recovery (%R)

%R = (C spike*0.104 - Csample*0.102)/2 *100

Cspike = average result of matrix spike (µg NH₃/ ml as N)


Relative Percent Difference (RPD) = (C1-C2)/ Cavg *100 (must be 5% or less)

Relative Percent Accuracy (RPA) (must be 10% or less)

RPA = (Cavg-theoretical value of standard)/ theoretical value of standard * 100

AMMONIA ELECTRODE CALIBRATION CURVE

NH ₃ concentration (µg NH ₃ / ml as N)	log NH ₃ concentration	Electrode potential (mV)	Sample Temperature (C)	Room Temperature (C)
1	0.000	79.1	22	22
5	0.699	41.6	22	22
20	1.301	9.2	22	22
100	2.000	-29.5	22	22



slope -54.2597
y-intercept 79.3597

Concentration (µg NH ₃ / ml as N)	Value LR line	Difference	% Difference
1	1.0111	0.0111	1.1083
5	4.9649	-0.0351	-0.7028
20	19.6352	-0.3648	-1.8241
100	101.4545	1.4545	1.4545

Calculation:

Regression Line: $P = M \cdot \log(\mu\text{g of NH}_3 / \text{ml as N}) + B$

Measured Concentration of Ammonia (C) in µg / ml NH₃ as N: $C = 10^{(P-B)/M}$

where P = electrode potential, M= slope (must be -57 ± 3) and B= intercept

All standards were prepared in 0.04N H₂SO₄ and allowed to equilibrate to room temperature.



AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALIBRATION DATA

District Method: SCAQMD 207.1

Calibration Date: 7/27/2020

Calibration Curve: $y = -54.2597x + 79.3597$

R² 0.9999

Analyst's Initials: LM

Thermometer #: 1

ISE Electrode #: B

Calibration Standard (µg NH ₃ / ml as N)	Electrode Potential (mV)	Solution Temperature (°C)	Room Temperature (°C)
1	79.1	22.6	22.0
5	41.6	22.6	22.0
20	4.2	22.6	22.0
100	-29.5	22.6	22.0

Notes:

Total volume of samples and standards used: 100 ml

Volume of pH adjusting ISA used in ml: 2 ml

Absorbing solution: 0.04 N H₂SO₄

Slope of the calibration curve shall be between -54 to -60

R² must be 0.9997 or greater

Calibration solutions, sample solutions and Calibration Verification standard temperature within ± 2°C

CHAIN OF CUSTODY

CLIENT: SCPPA - Canyon Power PlantPROJECT #: W002AS-682102TEST DATE(S): 7/23/2020LOCATION: U2SAMPLER(S): RH/DA/RDSAMPLE LOCATION: StackPROJECT MANAGER: SDTEST METHOD(S): SCAQMD 207.1DATE DUE: 7/30/2020OUTSIDE LAB REQUIRED?: NoCOMPLIANCE TEST?: Yes

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
7/23/2020	2010/2118	1-NH3-U2	Probe, Line, Impingers	1	RH/DA/RD	
7/23/2020	2141/2244	2-NH3-U2	Probe, Line, Impingers	1	RH/DA/RD	
7/23/2020		FB-NH3-U2	Probe, Line, Impingers	1	RH/DA/RD	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
R. Howard / LAB	7-24-2020 / 2244	<i>[Signature]</i>	7/27/20 0837

ANALYSIS REQUIRED: NH₃ by SCAQMD 207.1 (ISE)

Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

Appendix A.3

QA/QC Data

SCAQMD METHOD 207.1 - AMMONIA DETERMINATION OF SAMPLE TIME

Source: Canyon U2
Date: 7/23/2020
Performed by: SD

Constants:

	1,000	mg/gram
	454	grams/lb
	35.315	SCF/SCM
	379.5	SCF/lb-mole
	1,000,000	parts/million parts
MW _{NH3}	17.03	lb/lb-mole
MW _{N2}	14.01	lb/lb-mole

Variables:

Target concentration	5	ppm @ O ₂ correction factor
O ₂ correction factor	15	% O ₂
Expected Flue Gas O ₂	14.5	% O ₂
F	2	Safety Factor
P	128.5	electrode potential corresponding to minimum value on calibration curve (mV)
B	128.83	y-intercept
M	-58.676	slope
V _r	0.5	Assumed liquid volume of probe rinse and first impinger (L)
Q @ dH = 1	0.55	cfm

Calculated Values:

Target concentration	5.4	ppm - raw
Target concentration	3.90	mg/dscm
C ₁	1.013	Lowest concentration on a calibration curve (mg NH ₃ -N/L)
RL	0.616	analytical mass reporting limit, mg
PSV	0.316	Planned sample volume, cubic meters
PSV	11.144	Planned sample volume, cubic feet
VSR	33.0	achievable volumetric sampling rate (dscf/hr)

PST	20.3	Planned sample time, minutes (minimum)
------------	-------------	---

Notes:

- 1) A minimum of 1 hour sample time is required for any mass per hour limits.
- 2) Facility Permit or Rule may specify sample time

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Office Method - Triplicate Runs/Four Calibration Points
English Meter Box Units, English K Factor
Filename: M:\Santa Ana\Equipment\Test Equipment\Calibrations\Dry Gas Meters\38-wcs\2020\semi annual cal 38wcs 2-27-20.xlsx\Wt Date:
File Modified From: APEX 522 Series Meter box Calibration
Revised: 4/8/2005

ID #: c-5000
38-wcs
2/27/2020
Bar. Pressure: 30.17 (in. Hg)
Performed By: R. Howard
Meter Serial #:

DRY GAS METER READINGS										CRITICAL ORIFICE READINGS					
dH (in H2O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature			
		Initial (cu ft)	Final (cu ft)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)	
0.13	26.00	463.700	469.149	5.449	69.0	66.0	71.0	68.0	33	0.1551	18.0	64.0	64.0	64.0	
0.13	26.00	469.149	474.592	5.443	71.0	68.0	72.0	69.0	33	0.1551	18.0	64.0	64.0	64.0	
0.13	26.00	474.592	480.032	5.440	72.0	69.0	72.0	70.0	33	0.1551	18.0	64.0	64.0	64.0	
0.59	12.00	447.400	452.664	5.264	66.0	65.0	66.0	64.0	48	0.3345	16.0	62.0	62.0	62.0	
0.59	12.00	452.664	457.895	5.231	66.0	64.0	68.0	65.0	48	0.3345	16.0	62.0	62.0	62.0	
0.59	12.00	457.895	463.127	5.232	68.0	65.0	69.0	65.0	48	0.3345	16.0	62.0	62.0	62.0	
1.80	7.00	482.500	488.027	5.527	72.0	70.0	73.0	70.0	63	0.5915	14.0	65.0	65.0	65.0	
1.80	7.00	488.027	493.551	5.524	73.0	70.0	74.0	70.0	63	0.5915	14.0	65.0	65.0	65.0	
1.80	7.00	493.551	499.086	5.535	74.0	70.0	74.0	71.0	63	0.5915	14.0	65.0	65.0	65.0	
3.10	5.00	499.900	504.949	5.049	75.0	71.0	76.0	72.0	73	0.7678	11.0	66.0	66.0	66.0	
3.10	5.00	504.949	509.993	5.044	76.0	72.0	76.0	71.0	73	0.7678	11.0	66.0	66.0	66.0	
3.10	5.00	509.993	515.044	5.051	76.0	71.0	76.0	71.0	73	0.7678	11.0	66.0	66.0	66.0	

DRY GAS METER				ORIFICE			DRY GAS METER			ORIFICE						
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vr(std) (cu ft)	VOLUME CORRECTED Vr(std) (liters)	VOLUME CORRECTED Vc(std) (cu ft)	VOLUME CORRECTED Vc(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	Y Value (number)	dH@ Value (in H2O)	Individual Run	Individual Orifice	Orifice Average	Orifice Average				
5.489	155.4	5.315	5.233	5.315	5.233	5.233	0.968	1.768	Pass							
5.467	154.8	5.315	5.233	5.315	5.233	5.233	0.972	1.763	Pass							
5.457	154.5	5.315	5.233	5.315	5.233	5.233	0.974	1.759	Pass							
Average							0.971	1.763		Pass	Pass	Pass				
5.341	151.3	5.300	5.198	5.300	5.198	5.198	0.992	1.727	Pass							
5.303	150.2	5.300	5.198	5.300	5.198	5.198	0.999	1.727	Pass							
5.294	149.9	5.300	5.198	5.300	5.198	5.198	1.001	1.725	Pass							
Average							0.998	1.726		Pass	Pass	Pass				
5.561	157.5	5.452	5.379	5.452	5.379	5.379	0.980	1.676	Pass							
5.553	157.3	5.452	5.379	5.452	5.379	5.379	0.982	1.676	Pass							
5.559	157.4	5.452	5.379	5.452	5.379	5.379	0.981	1.675	Pass							
Average							0.981	1.676		Pass	Pass	Pass				
5.075	143.7	5.050	4.992	5.050	4.992	4.992	0.995	1.712	Pass							
5.067	143.5	5.050	4.992	5.050	4.992	4.992	0.997	1.712	Pass							
5.077	143.8	5.050	4.992	5.050	4.992	4.992	0.995	1.714	Pass							
Average							0.996	1.713		Pass	Pass	Pass				
Average Yd: 0.986													0.986	dH@: 1.720		
													Q @ dH = 1: 0.572			

SIGNED: Signature on File

Date: 2/27/2020



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 38-wcs
 Readout Description: Control Box
 Date: 7/2/2020
 Performed By: JG/DH/LO/DA

Calibrated Thermocouple ID: TC-CAL
 T1 Reference Thermometer ID: 492956
 T2 Reference Thermometer ID: 242196
 T3 Reference Thermometer ID: 242167

T/C I.D. TC-CAL	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference		
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T3 (OIL)	38-wcs	349	349	349	349	350	350	350	350	1.0	0.1%	Pass
T2 (Boiling H ₂ O)	38-wcs	214	214	214	214	212	212	212	212	2.0	0.3%	Pass
T1 (Ice/Water)	38-wcs	34	34	34	34	32	32	32	32	2.0	0.4%	Pass

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N		T/C - Readout °F				T/C Source °F				Difference		
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	S/N 106970	651	651	651	651	650	650	650	650	1.0	0.1%	Pass
T3 (~370 F)	S/N 106970	368	368	368	368	365	365	365	365	3.0	0.4%	Pass
T2 (~212 F)	S/N 106970	213	212	213	213	212	212	212	212	0.7	0.1%	Pass
T1 (~32 F)	S/N 106970	35	35	35	35	32	32	32	32	3.0	0.6%	Pass

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

APPENDIX B FACILITY CEMS DATA

Average Values Report
Generated: 7/23/2020 21:46

1-NA3-2

Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 2

Period Start: 7/23/2020 20:11
Period End: 7/23/2020 21:18
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 2_O2 %	Average 2_NOXPPM ppm	Average 2_NOX_CORR ppm	Average 2_NOX_LBHR #/hr	Average 2_NOX_LBMM #/MBTU	Average 2_GasFlow kscfh	Average 2_LOAD MW	Average 2_STACKFLW kscfm	Average 2_COPPM ppm	Average 2_CO_CORR ppm	Average 2_CO_LBHR #/hr
07/23/2020 20:11	14.62	2.47	2.32	4.42	0.009	467.9	49.62	237.4	3.30	3.10	3.44
07/23/2020 20:12	14.66	2.49	2.35	4.42	0.009	467.9	49.78	238.9	3.29	3.11	3.44
07/23/2020 20:13	14.66	2.40	2.27	3.92	0.008	467.2	49.82	238.5	3.35	3.17	3.48
07/23/2020 20:14	14.65	2.36	2.23	3.93	0.008	467.4	49.78	238.3	3.40	3.21	3.53
07/23/2020 20:15	14.64	2.42	2.28	3.94	0.008	468.7	49.75	238.5	3.32	3.13	3.44
07/23/2020 20:16	14.64	2.48	2.34	4.42	0.009	467.6	49.63	238.0	3.29	3.10	3.44
07/23/2020 20:17	14.66	2.47	2.34	4.43	0.009	468.6	49.82	239.2	3.28	3.10	3.44
07/23/2020 20:18	14.65	2.47	2.33	4.43	0.009	469.2	49.72	239.2	3.35	3.16	3.50
07/23/2020 20:19	14.65	2.42	2.28	3.94	0.008	469.2	49.71	239.2	3.39	3.20	3.55
07/23/2020 20:20	14.65	2.38	2.25	3.94	0.008	468.7	49.60	238.9	3.43	3.24	3.59
07/23/2020 20:21	14.65	2.43	2.29	3.94	0.008	469.4	49.76	239.3	3.38	3.19	3.55
07/23/2020 20:22	14.64	2.40	2.26	3.94	0.008	469.5	50.02	238.9	3.42	3.22	3.55
07/23/2020 20:23	14.64	2.35	2.21	3.95	0.008	470.4	49.96	239.4	3.49	3.29	3.65
07/23/2020 20:24	14.65	2.40	2.27	3.94	0.008	469.2	49.70	239.2	3.51	3.31	3.65
07/23/2020 20:25	14.64	2.39	2.25	3.95	0.008	470.2	49.96	239.3	3.53	3.33	3.70
07/23/2020 20:26	14.66	2.38	2.25	3.94	0.008	469.5	49.81	239.7	3.56	3.37	3.75
07/23/2020 20:27	14.64	2.36	2.22	3.95	0.008	470.0	49.76	239.2	3.59	3.38	3.75
07/23/2020 20:28	14.65	2.31	2.18	3.95	0.008	470.2	49.90	239.7	3.60	3.40	3.75
07/23/2020 20:29	14.63	2.34	2.20	3.95	0.008	470.5	49.88	239.0	3.57	3.36	3.71
07/23/2020 20:30	14.64	2.36	2.22	3.96	0.008	472.0	49.92	240.2	3.52	3.32	3.67
07/23/2020 20:31	14.63	2.37	2.23	3.96	0.008	471.7	49.67	239.7	3.57	3.36	3.71
07/23/2020 20:32	14.65	2.30	2.17	3.96	0.008	471.7	49.76	240.4	3.67	3.46	3.86
07/23/2020 20:33	14.67	2.24	2.12	3.96	0.008	471.2	49.83	241.0	3.83	3.63	4.01
07/23/2020 20:34	14.67	2.23	2.11	3.95	0.008	470.6	49.77	240.6	3.91	3.70	4.10
07/23/2020 20:35	14.65	2.23	2.11	3.97	0.008	472.4	49.74	240.8	3.89	3.67	4.07
07/23/2020 20:36	14.65	2.27	2.14	3.96	0.008	471.3	49.58	240.2	3.82	3.61	4.01
07/23/2020 20:37	14.66	2.26	2.14	3.97	0.008	472.4	49.60	241.2	3.78	3.57	3.97
07/23/2020 20:38	14.65	2.27	2.14	3.96	0.008	471.6	49.81	240.4	3.79	3.58	3.96
07/23/2020 20:39	14.66	2.26	2.14	3.96	0.008	471.7	49.98	240.8	3.84	3.63	4.01
07/23/2020 20:40	14.67	2.20	2.08	3.96	0.008	471.3	49.62	241.0	3.91	3.70	4.11
07/23/2020 20:41	14.65	2.25	2.12	3.97	0.008	472.7	49.98	240.9	3.86	3.64	4.07
07/23/2020 20:42	14.65	2.28	2.15	3.96	0.008	471.8	49.76	240.5	3.83	3.62	4.01
07/23/2020 20:43	14.65	2.24	2.11	3.97	0.008	472.7	49.71	240.9	3.83	3.62	4.02
07/23/2020 20:44	14.64	2.28	2.15	3.97	0.008	472.9	49.82	240.6	3.83	3.61	4.02
07/23/2020 20:45	14.66	2.27	2.15	3.96	0.008	472.0	49.41	241.0	3.87	3.66	4.06
07/23/2020 20:46	14.65	2.19	2.07	3.96	0.008	471.4	49.74	240.3	3.97	3.75	4.16
07/23/2020 20:47	14.65	2.21	2.09	3.97	0.008	472.6	49.73	240.9	3.88	3.66	4.07
07/23/2020 20:48	14.65	2.26	2.13	3.96	0.008	472.0	49.73	240.6	3.85	3.63	4.06
07/23/2020 20:49	14.67	2.22	2.10	3.96	0.008	471.1	49.41	240.9	3.89	3.68	4.11
07/23/2020 20:50	14.67	2.19	2.07	3.93	0.008	468.3	49.27	239.5	3.96	3.75	4.13
07/23/2020 20:51	14.63	2.26	2.13	3.94	0.008	469.5	49.59	238.6	3.79	3.57	3.94
07/23/2020 20:52	14.61	2.32	2.18	3.97	0.008	472.9	49.64	239.5	3.59	3.37	3.77
07/23/2020 20:53	14.63	2.34	2.20	3.97	0.008	472.7	49.54	240.2	3.56	3.35	3.72
07/23/2020 20:54	14.67	2.27	2.15	3.97	0.008	472.6	50.12	241.6	3.77	3.57	3.97
07/23/2020 20:55	14.67	2.18	2.06	3.96	0.008	471.9	49.51	241.3	3.97	3.76	4.16
07/23/2020 20:56	14.68	2.16	2.05	3.96	0.008	472.0	49.80	241.7	4.07	3.86	4.31
07/23/2020 20:57	14.67	2.15	2.04	3.96	0.008	472.0	49.71	241.4	4.12	3.90	4.36

W002AS-682102-RT-1481

27 of 56

Period Start:	Average 2_O2 %	Average 2_NOXPPM ppm	Average 2_NOX_CORR ppm	Average 2_NOX_LBHR #/hr	Average 2_NOX_LBMM #/MBTU	Average 2_GasFlow kscfh	Average 2_LOAD MW	Average 2_STACKFLW kscfm	Average 2_COPPM ppm	Average 2_CO_CORR ppm	Average 2_CO_LBHR #/hr
07/23/2020 20:58	14.65	2.13	2.01	3.47	0.007	472.4	49.98	240.8	4.14	3.91	4.36
07/23/2020 20:59	14.64	2.16	2.04	3.97	0.008	472.3	49.94	240.3	4.04	3.81	4.22
07/23/2020 21:00	14.63	2.20	2.07	3.96	0.008	471.0	49.49	239.3	3.89	3.66	4.06
07/23/2020 21:01	14.64	2.30	2.17	3.96	0.008	471.2	49.65	239.8	3.71	3.50	3.86
07/23/2020 21:02	14.65	2.36	2.23	3.95	0.008	470.4	49.83	239.8	3.66	3.46	3.85
07/23/2020 21:03	14.65	2.34	2.21	3.95	0.008	470.6	49.68	239.9	3.68	3.47	3.85
07/23/2020 21:04	14.65	2.32	2.19	3.95	0.008	470.3	49.62	239.7	3.70	3.49	3.85
07/23/2020 21:05	14.66	2.37	2.24	3.95	0.008	470.2	49.77	240.0	3.60	3.40	3.75
07/23/2020 21:06	14.67	2.38	2.25	3.95	0.008	469.9	49.79	240.3	3.63	3.44	3.80
07/23/2020 21:07	14.65	2.30	2.17	3.95	0.008	470.2	49.88	239.7	3.68	3.47	3.85
07/23/2020 21:08	14.67	2.29	2.17	3.95	0.008	470.0	49.80	240.3	3.68	3.49	3.85
07/23/2020 21:09	14.65	2.36	2.23	3.95	0.008	470.8	49.77	240.0	3.62	3.42	3.81
07/23/2020 21:10	14.65	2.33	2.20	3.95	0.008	470.1	49.84	239.6	3.63	3.43	3.80
07/23/2020 21:11	14.67	2.36	2.23	3.95	0.008	470.5	49.68	240.6	3.63	3.44	3.80
07/23/2020 21:12	14.63	2.39	2.25	3.95	0.008	470.4	49.95	239.0	3.61	3.40	3.75
07/23/2020 21:13	14.68	2.32	2.20	3.95	0.008	470.0	49.69	240.7	3.63	3.44	3.80
07/23/2020 21:14	14.64	2.34	2.21	3.95	0.008	470.7	49.79	239.5	3.62	3.41	3.81
07/23/2020 21:15	14.65	2.39	2.26	3.96	0.008	470.9	49.60	240.0	3.56	3.36	3.71
07/23/2020 21:16	14.66	2.35	2.22	3.96	0.008	470.9	49.73	240.4	3.65	3.45	3.81
07/23/2020 21:17	14.69	2.28	2.17	3.96	0.008	470.9	49.89	241.5	3.74	3.55	3.96
07/23/2020 21:18	14.64	2.24	2.11	3.94	0.008	469.5	49.61	238.9	3.86	3.64	4.04
Daily Average*	14.65	2.31	2.18	3.98	0.008	470.6	49.75	239.9	3.68	3.47	3.85
Maximum*	14.69	2.49	2.35	4.43	0.009	472.9	50.12	241.7	4.14	3.91	4.36
	07/23/2020 21:17	07/23/2020 20:12	07/23/2020 20:12	07/23/2020 20:18	07/23/2020 20:18	07/23/2020 20:52	07/23/2020 20:54	07/23/2020 20:56	07/23/2020 20:58	07/23/2020 20:58	07/23/2020 20:58
Minimum*	14.61	2.13	2.01	3.47	0.007	467.2	49.27	237.4	3.28	3.10	3.44
	07/23/2020 20:52	07/23/2020 20:58	07/23/2020 20:58	07/23/2020 20:58	07/23/2020 20:58	07/23/2020 20:13	07/23/2020 20:50	07/23/2020 20:11	07/23/2020 20:17	07/23/2020 20:17	07/23/2020 20:17

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 7/23/2020 23:17

Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 2

Period Start: 7/23/2020 21:42
Period End: 7/23/2020 22:44
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 2_O2 %	Average 2_NOXPPM ppm	Average 2_NOX_CORR ppm	Average 2_NOX_LBHR #/hr	Average 2_NOX_LBMM #/MBTU	Average 2_GasFlow kscfh	Average 2_LOAD MW	Average 2_STACKFLW kscfm	Average 2_COPPM ppm	Average 2_CO_CORR ppm	Average 2_CO_LBHR #/hr
07/23/2020 21:42	14.64	2.29	2.16	3.94	0.008	469.0	49.81	238.7	3.46	3.26	3.60
07/23/2020 21:43	14.66	2.27	2.15	3.94	0.008	468.8	49.69	239.3	3.58	3.38	3.74
07/23/2020 21:44	14.67	2.30	2.18	3.94	0.008	468.8	49.88	239.7	3.65	3.46	3.84
07/23/2020 21:45	14.65	2.32	2.19	3.93	0.008	468.3	49.73	238.7	3.74	3.53	3.88
07/23/2020 21:46	14.63	2.33	2.19	3.94	0.008	469.3	49.68	238.5	3.69	3.47	3.84
07/23/2020 21:47	14.63	2.42	2.28	3.94	0.008	468.6	49.66	238.1	3.54	3.33	3.69
07/23/2020 21:48	14.70	2.42	2.30	3.92	0.008	466.1	49.39	239.5	3.57	3.40	3.72
07/23/2020 21:49	14.67	2.28	2.16	3.92	0.008	466.5	49.41	238.5	3.82	3.62	3.97
07/23/2020 21:50	14.60	2.28	2.14	3.94	0.008	469.5	49.61	237.4	3.77	3.53	3.89
07/23/2020 21:51	14.57	2.40	2.24	3.96	0.008	471.3	49.74	237.2	3.52	3.28	3.66
07/23/2020 21:52	14.57	2.42	2.26	3.96	0.008	471.4	49.83	237.3	3.38	3.15	3.51
07/23/2020 21:53	14.57	2.37	2.21	3.97	0.008	472.2	49.79	237.6	3.46	3.22	3.57
07/23/2020 21:54	14.56	2.34	2.18	3.95	0.008	470.3	49.50	236.3	3.53	3.29	3.65
07/23/2020 21:55	14.56	2.35	2.19	3.96	0.008	471.3	49.68	236.8	3.53	3.29	3.66
07/23/2020 21:56	14.55	2.36	2.19	3.97	0.008	473.0	49.79	237.3	3.49	3.24	3.63
07/23/2020 21:57	14.56	2.36	2.20	3.97	0.008	473.1	49.69	237.7	3.49	3.25	3.63
07/23/2020 21:58	14.59	2.30	2.15	3.96	0.008	471.9	49.78	238.2	3.64	3.40	3.77
07/23/2020 21:59	14.61	2.28	2.14	3.96	0.008	471.7	49.62	238.9	3.74	3.51	3.91
07/23/2020 22:00	14.62	2.32	2.18	3.96	0.008	471.7	49.71	239.3	3.81	3.58	3.96
07/23/2020 22:01	14.62	2.31	2.17	3.96	0.008	471.8	49.67	239.3	3.83	3.60	4.01
07/23/2020 22:02	14.64	2.28	2.15	3.96	0.008	471.6	49.84	240.0	3.88	3.66	4.06
07/23/2020 22:03	14.63	2.28	2.15	3.96	0.008	472.0	49.74	239.8	3.91	3.68	4.11
07/23/2020 22:04	14.65	2.29	2.16	3.96	0.008	472.0	49.75	240.6	3.94	3.72	4.11
07/23/2020 22:05	14.64	2.28	2.15	3.96	0.008	471.3	49.70	239.9	4.01	3.78	4.21
07/23/2020 22:06	14.64	2.25	2.12	3.96	0.008	471.6	49.78	240.0	4.06	3.83	4.26
07/23/2020 22:07	14.63	2.22	2.09	3.96	0.008	471.9	49.65	239.8	4.03	3.79	4.21
07/23/2020 22:08	14.62	2.23	2.10	3.97	0.008	472.4	49.90	239.6	3.94	3.70	4.12
07/23/2020 22:09	14.61	2.26	2.12	3.98	0.008	473.4	49.67	239.8	3.87	3.63	4.03
07/23/2020 22:10	14.61	2.28	2.14	3.96	0.008	471.9	49.61	239.0	3.82	3.58	3.96
07/23/2020 22:11	14.61	2.28	2.14	3.96	0.008	471.7	49.80	238.9	3.85	3.61	4.01
07/23/2020 22:12	14.61	2.27	2.13	3.97	0.008	472.7	49.81	239.4	3.86	3.62	4.02
07/23/2020 22:13	14.62	2.24	2.10	3.96	0.008	471.4	49.40	239.1	3.89	3.65	4.06
07/23/2020 22:14	14.64	2.24	2.11	3.96	0.008	471.4	49.70	239.9	3.90	3.68	4.06
07/23/2020 22:15	14.62	2.25	2.11	3.97	0.008	472.9	49.72	239.9	3.93	3.69	4.12
07/23/2020 22:16	14.58	2.23	2.08	3.97	0.008	472.7	49.70	238.3	3.92	3.66	4.07
07/23/2020 22:17	14.59	2.26	2.11	3.96	0.008	471.8	49.65	238.2	3.83	3.58	3.96
07/23/2020 22:18	14.60	2.36	2.21	3.96	0.008	471.4	49.53	238.4	3.69	3.46	3.86
07/23/2020 22:19	14.56	2.43	2.26	3.96	0.008	471.2	49.57	236.8	3.59	3.34	3.71
07/23/2020 22:20	14.55	2.42	2.25	3.96	0.008	471.9	49.44	236.7	3.50	3.25	3.62
07/23/2020 22:21	14.55	2.39	2.22	3.98	0.008	473.7	49.82	237.7	3.44	3.20	3.58
07/23/2020 22:22	14.55	2.33	2.16	3.98	0.008	473.8	49.84	237.7	3.48	3.23	3.63
07/23/2020 22:23	14.57	2.31	2.15	3.98	0.008	473.2	49.74	238.2	3.59	3.35	3.73
07/23/2020 22:24	14.58	2.30	2.15	3.97	0.008	472.3	49.86	238.1	3.69	3.44	3.82
07/23/2020 22:25	14.60	2.33	2.18	3.96	0.008	471.9	49.84	238.6	3.72	3.48	3.86
07/23/2020 22:26	14.60	2.34	2.19	3.97	0.008	472.5	49.70	238.9	3.76	3.52	3.92
07/23/2020 22:27	14.59	2.31	2.16	3.97	0.008	472.3	49.74	238.4	3.76	3.52	3.92
07/23/2020 22:28	14.61	2.37	2.22	3.96	0.008	471.4	49.69	238.8	3.71	3.48	3.86

W002AS-682102-RT-1481

Period Start:	Average 2_O2 %	Average 2_NOXPPM ppm	Average 2_NOX_CORR ppm	Average 2_NOX_LBHR #/hr	Average 2_NOX_LBMM #/MBTU	Average 2_GasFlow kscfh	Average 2_LOAD MW	Average 2_STACKFLW kscfm	Average 2_COPPM ppm	Average 2_CO_CORR ppm	Average 2_CO_LBHR #/hr
07/23/2020 22:29	14.62	2.35	2.21	3.96	0.008	471.7	49.68	239.3	3.75	3.52	3.91
07/23/2020 22:30	14.63	2.27	2.14	3.97	0.008	472.3	49.93	240.0	3.88	3.65	4.07
07/23/2020 22:31	14.64	2.23	2.10	3.98	0.008	473.5	49.75	241.0	4.03	3.80	4.23
07/23/2020 22:32	14.63	2.18	2.05	3.98	0.008	473.6	49.73	240.6	4.19	3.94	4.38
07/23/2020 22:33	14.64	2.10	1.98	3.48	0.007	473.6	49.89	241.0	4.38	4.13	4.62
07/23/2020 22:34	14.64	2.06	1.94	3.48	0.007	474.1	49.85	241.3	4.47	4.21	4.73
07/23/2020 22:35	14.63	2.08	1.96	3.49	0.007	474.2	49.81	240.9	4.43	4.17	4.68
07/23/2020 22:36	14.64	2.12	2.00	3.49	0.007	474.4	49.58	241.4	4.38	4.13	4.63
07/23/2020 22:37	14.65	2.18	2.06	3.98	0.008	473.8	49.90	241.5	4.25	4.01	4.48
07/23/2020 22:38	14.64	2.37	2.23	3.99	0.008	474.6	49.58	241.5	4.02	3.79	4.24
07/23/2020 22:39	14.62	2.48	2.33	4.48	0.009	474.6	49.74	240.7	3.76	3.53	3.94
07/23/2020 22:40	14.63	2.53	2.38	4.48	0.009	473.8	49.54	240.7	3.66	3.44	3.83
07/23/2020 22:41	14.63	2.59	2.44	4.49	0.009	474.7	49.76	241.2	3.62	3.41	3.79
07/23/2020 22:42	14.63	2.52	2.37	4.49	0.009	474.8	50.10	241.2	3.63	3.42	3.84
07/23/2020 22:43	14.63	2.34	2.20	3.99	0.008	475.4	49.64	241.6	3.78	3.56	3.99
07/23/2020 22:44	14.63	2.21	2.08	3.99	0.008	474.5	49.72	241.1	3.90	3.67	4.09
Daily Average*	14.61	2.31	2.17	3.96	0.008	472.0	49.72	239.2	3.79	3.56	3.96
Maximum*	14.70	2.59	2.44	4.49	0.009	475.4	50.10	241.6	4.47	4.21	4.73
	07/23/2020 21:48	07/23/2020 22:41	07/23/2020 22:41	07/23/2020 22:42	07/23/2020 22:42	07/23/2020 22:43	07/23/2020 22:42	07/23/2020 22:43	07/23/2020 22:34	07/23/2020 22:34	07/23/2020 22:34
Minimum*	14.55	2.06	1.94	3.48	0.007	466.1	49.39	236.3	3.38	3.15	3.51
	07/23/2020 22:22	07/23/2020 22:34	07/23/2020 22:34	07/23/2020 22:34	07/23/2020 22:36	07/23/2020 21:48	07/23/2020 21:48	07/23/2020 21:54	07/23/2020 21:52	07/23/2020 21:52	07/23/2020 21:52

* Does not include Invalid Averaging Periods ("N/A")

30 of 56

APPENDIX C CALCULATIONS

Appendix C.1

General Emissions Calculations

GENERAL EMISSION CALCULATIONS

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^{\circ}R}{T_{ref}}$$

VII. Particulate emissions

- (a) Grain loading, gr/dscf
 $C = 0.01543 (M_n/V_{mstd})$
- (b) Grain loading at 12% CO₂, gr/dscf
 $C_{12\% CO_2} = C (12/\% CO_2)$
- (c) Mass emissions, lb/hr
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$
- (d) Particulate emission factor
 $\text{lb}/10^6 \text{ Btu} = C * \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% O_2}$

Nomenclature:

A_s	= stack area, ft ²
B_{wo}	= flue gas moisture content, dimensionless
$C_{12\%CO_2}$	= particulate grain loading, gr/dscf corrected to 12% CO ₂
C	= particulate grain loading, gr/dscf
C_p	= pitot calibration factor, dimensionless
D_n	= nozzle diameter, in.
F	= fuel F-Factor, dscf/MMBtu @ 0% O ₂
H	= orifice differential pressure, iwg
I	= % isokinetics
M_n	= mass of collected particulate, mg
M_i	= mass emission rate of specie i, lb/hr
MW	= molecular weight of flue gas, lb/lb-mole
M_{wi}	= molecular weight of specie i: SO ₂ : 64 NO _x : 46 CO: 28 HC: 16
t	= sample time, min.
ΔP	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	= barometric pressure, inches Hg
P_s	= stack absolute pressure, inches Hg
P_{sg}	= stack static pressure, iwb
Q	= wet stack flow rate at actual conditions, wacfm
Q_{sd}	= dry standard stack flow rate, dscfm
SV	= specific molar volume of an ideal gas at standard conditions, ft ³ /lb-mole
T_m	= meter temperature, °R
T_{ref}	= reference temperature, °R
T_s	= stack temperature, °R
V_s	= stack gas velocity, ft/sec
V_{lc}	= volume of liquid collected in impingers, ml
V_m	= uncorrected dry meter volume, dcf
V_{mstd}	= dry meter volume at standard conditions, dscf
V_{wstd}	= volume of water vapor at standard conditions, scf
Y_d	= meter calibration coefficient

Appendix C.2

Spreadsheet Summaries

SCAQMD METHOD 207.1 DATA WORKSHEET AND SUMMARY

Facility.....	Canyon		Parameter.....	NH₃	
Unit.....	U2		Fuel.....	Natural gas	
Sample Location.....	Stack		Data By.....	SD	
Test Number.....	1-NH3-U2	2-NH3-U2	Average	Maximum	Limit
Reference Temperature (°F).....	60	60			
Test Date.....	7/23/2020	7/23/2020			
Test Method.....	SCAQMD 207.1	SCAQMD 207.1			
Sample Train.....	38-WCS	38-WCS			
Meter Calibration Factor.....	0.986	0.986			
Stack Area (ft ²).....	106.90	106.90			
Sample Time (Minutes).....	60	60			
Barometric Pressure ("Hg).....	29.64	29.64			
Start/Stop Time	2010/2118	2141/2244			
Meter Volume (acf).....	48.597	47.917			
Meter Temperature (°F).....	73.9	72.9			
Meter Pressure (iwg).....	2.0	2.0			
Liquid Volume (ml).....	126.4	129.6			
Stack O ₂ (%).....	14.65	14.61	14.63	(from facility CEMS)	
Unit Load (MW).....	50	50	49.7		
Standard Sample Volume (SCF).....	46.458	45.894			
Moisture Fraction.....	0.112	0.116			
Stack Flow Rate (dscfm, 68 °F).....	239,900	239,200	239,550	(from facility CEMS)	
Stack Flow Rate (@ Tref).....	236,265	235,576	235,920		
Gas Constant (ft-lbf/lb-mole-R).....	1545.33	1545.33			
Molecular Weight NH ₃ (lb/lb-mole).....	17.03	17.03			
Specific Molar Volume (ft ³ /lb-mole).....	379.5	379.5			
F-Factor (dscf/MMBtu).....	8,710	8,710			
HHV(Btu/SCF).....	1,050	1,050			
Mass Conversion (lb/ug).....	2.2046E-09	2.2046E-09			
O ₂ Correction Factor (%).....	15	15			
Mass NH ₃ (ug).....	2,283	1,575			
Mass NH ₃ (lb).....	5.03E-06	3.47E-06			
NH ₃ (ppmv, flue gas).....	2.4	1.7	2.1	2.4	
NH ₃ (ppmv @ O ₂ Correction Factor).....	2.3	1.6	1.9	2.3	5
NH ₃ (lb/hr).....	1.5	1.1	1.3	1.5	
NH ₃ (lb/MMBtu).....	0.003	0.002	0.003	0.003	
NH ₃ (lb/MMSCF).....	3.3	2.3	2.8	3.3	

Note: SCAQMD Method 207.1 requires the higher of the duplicate runs be reported as the test result.

SCAQMD 207.1 EXAMPLE CALCULATION

TEST NUMBER: 1-NH3-U2

Identifier	Description	Units	Equation	Value
A	Reference Temperature	F	--	60
B	Reference Temperature	R	$A + 460$	520
C	Meter Calibration Factor (Yd)	--	--	0.986
D	Barometric Pressure	" Hg	--	29.64
E	Meter Volume	acf	--	48,597
F	Meter Temperature	F	--	73.9
G	Meter Temperature	R	$F + 460$	533.9
H	Delta H	" H ₂ O	--	2.0
I	Meter Volume (standard)	dscf	$0.03342 * E * (D + H/13.6) * B/G * C$	46.458
J	Liquid Collected	grams	--	126.4
K	Water vapor volume	scf	$0.0472 * J * B/528$	5.876
L	Moisture Content	--	$K/(K + I)$	0.112
M	Gas Constant	ft-lbf/lb-mole-R	--	1545.33
N	Specific Molar Volume	SCF/lb-mole	$385.3 * B / 528$	379.5
O	F-Factor	dscf/MMBtu	--	8,710
P	HHV	Btu/SCF	--	1,050
Q	Mass Conversion Factor	lb/ug	--	2.2046E-09
R	O ₂ Correction Factor	--	--	15
S	Stack Flow Rate @ 68 F	dscfm	--	239,900
T	Stack Flow Rate @ Tref	dscfm	$S * B/528$	236,265
U	Mass NH ₃	ug	--	2,283
V	Mass NH ₃	lb	$U * Q$	5.03E-06
W	MW of NH ₃	lb/lb-mole	--	17.03
X	NH ₃	ppm	$(V * N * 10^6)/(I * W)$	2.4
Y	Flue Gas O ₂	%	--	14.65
Z	NH ₃	ppmc	$X * (20.9 - R)/(20.9 - Y)$	2.3
AA	NH ₃	lb/hr	$X * T * W * 60/(N * 10^6)$	1.5
AB	NH ₃	lb/MMBtu	$(X * W * O)/(385.3 * 10^6) * 20.9/(20.9 - Y)$	0.003
AC	NH ₃	lb/MMSCF	$AB * P$	3.3

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

APPENDIX D

QUALITY ASSURANCE

Appendix D.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, will be present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)

The following safety measures will be followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO _x Analyzer	Daily	NO ₂ -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	+/- 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	+/- 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for $\Delta H@$	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	+/- 1.5%

Note: Calibration requirements that meet applicable regulatory agency requirements will be used.

Appendix D.2

SCAQMD and STAC Certifications



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 6, 2019

Mr. John Peterson
Montrose Air Quality Services, LLC
1631 E. Saint Andrew Place
Santa Ana, CA 92705

Subject: LAP Approval Notice
Reference # 96LA1220

Dear Mr. Peterson:

We have reviewed your renewal letter under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning September 30, 2019, and ending September 30, 2020 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

Methods 1-4	Methods 5.1, 5.2, 5.3, 6.1
Methods 10.1 and 100.1	Methods 25.1 and 25.3 (Sampling)
USEPA CTM-030 and ASTM D6522-00	Rule 1121/ 1146.2 Protocol
Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling	

Your LAP approval to perform nitrogen oxide emissions compliance testing for Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler 1510 North Spring Street Los Angeles, CA 90012	Noritz America Corp. 11160 Grace Avenue Fountain Valley, CA 92708	Ajax Boiler, Inc. 2701 S. Harbor Blvd. Santa Ana, CA 92704
---	---	--

Laundry Building of VA Greater Los Angeles Healthcare System
508 Constitution Avenue
Los Angeles, CA 90049

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerely,

A handwritten signature in black ink that reads 'D. Sarkar'.

Dipankar Sarkar
Program Supervisor
Source Test Engineering

DS:GK/gk
Attachment

190906 LapRenewalRev.doc



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 11th day of February 2020.



Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3925.01
Valid to February 28, 2022

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

Appendix D.3

Individual Qi Certificate

CERTIFICATE OF COMPLETION

Sean Donovan

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

SCAQMD Method 207.1

Certificate Number: 002-2016-06

Tate Strickler

Tate Strickler, Accreditation Director

DATE OF ISSUE:

11/30/16

DATE OF

EXPIRATION:

11/30/21



MONTROSE
ENVIRONMENTAL

APPENDIX E

APPLICABLE PERMIT SECTIONS



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: POWER GENERATION					
GAS TURBINE, NO. 2, NATURAL GAS, GENERAL ELECTRIC, MODEL LM6000PC SPRINT, SIMPLE CYCLE, 479 MMBTU/HR AT 46 DEG F, WITH INLET CHILLING, WITH WATER INJECTION WITH A/N: 555829	D7	C9	NOX: MAJOR SOURCE**	CO: 4 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV NATURAL GAS (5) [RULE 407, 4-2-1982]; NOX: 2.5 PPMV NATURAL GAS (4) [RULE 2005, 6-3-2011]; NOX: 25 PPMV NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; PM10: 0.01 GRAINS/SCF NATURAL GAS (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM10: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409, 8-7-1981]; PM10: 1.67 LBS/HR NATURAL GAS (5C) [RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]; PM10: 11 LBS/HR NATURAL GAS (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 0.06 LBS/MMBTU NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; VOC: 2 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A63.1, A99.1, A99.2, A99.3, A195.1, A195.2, A195.3, A327.1, B61.1, D12.1, D29.2, D29.3, D82.1, D82.2, E193.1, H23.1, I298.2, K40.1
GENERATOR, 50.95 MW					

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process 1: POWER GENERATION					
CO OXIDATION CATALYST, NO. 2, BASF, 110 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 476657	C9	D7 C10			
SELECTIVE CATALYTIC REDUCTION, NO. 2, CORMETECH CMHT-21, 1012 CU.FT.; WIDTH: 2 FT 6 IN; HEIGHT: 25 FT 9 IN; LENGTH: 18 FT WITH A/N: 476657 AMMONIA INJECTION	C10	C9 S12		NH3: 5 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.5, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
STACK, TURBINE NO. 2, HEIGHT: 86 FT ; DIAMETER: 11 FT 8 IN A/N: 555829	S12	C10			

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : C4, C10, C16, C22]

- D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[**RULE 1110.2, 2-1-2008; RULE 1110.2, 9-7-2012; RULE 1303(b)(2)-Offset, 5-10-1996;**
RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 9-10-2010; RULE 1470, 5-4-2012;
RULE 2012, 5-6-2005; 40CFR 60 Subpart III, 1-30-2013]

[Devices subject to this condition : D25]

- D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test(s) shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

If the turbine is not in operation during one calendar year, then no testing is required during that calendar year.

The NO_x concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted and the results submitted to the District within 60 days after the test date.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1, D7, D13, D19]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Sampling Time	Test Location
SOX emissions	AQMD Laboratory Method 307-91	Not Applicable	Fuel sample
VOC emissions	District Method 25.3	1 hour	Outlet of the SCR serving this equipment
PM emissions	District method 5.1	4 hours	Outlet of the SCR serving this equipment

THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Sean Donovan
Title: Client Project Manager
Region: West
Email: SDonovan@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: West
Email: MMccune@montrose-env.com
Phone: (714) 279-6777

**TEST REPORT FOR
AMMONIA SLIP TEST
AT CANYON POWER PLANT UNIT 3
FACILITY ID: 153992, DEVICE ID: D13**

Prepared For:

Canyon Power Plant
3071 E. Mira Loma Avenue
Anaheim, California 92806

For Submittal To:

South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765-4178

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
(714) 282-8240

John Groenenboom

Test Date: **October 13, 2020**
Production Date: **December 1, 2020**
Report Number: **W002AS-004299-RT-1759**




CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:  Date: 12/1/2020
Name: John Groenenboom Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.


Signature:  Date: 12/1/2020
Name: Marshall Clark Title: Reporting/QC Specialist

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY	5
2.0 UNIT AND CEMS DESCRIPTION	6
2.1 UNIT DESCRIPTION	6
2.2 TEST CONDITIONS.....	7
2.3 SAMPLE LOCATION	7
3.0 TEST DESCRIPTION	8
4.0 TEST RESULTS	9

LIST OF APPENDICES

A RAW DATA	10
A.1 Sample Data Sheets	11
A.2 Laboratory Data.....	15
A.3 QA/QC Data	21
B FACILITY CEMS DATA	25
C CALCULATIONS.....	30
C.1 General Emissions Calculations.....	31
C.2 Spreadsheet Summaries	35
D QUALITY ASSURANCE	38
D.1 Quality Assurance Program Summary	39
D.2 SCAQMD and STAC Certifications	45
D.3 Individual QI Certificate	48
E APPLICABLE PERMIT SECTIONS	50

LIST OF TABLES

1-1 AMMONIA SLIP TEST RESULTS SUMMARY	5
4-1 AMMONIA SLIP TEST RESULTS	9

LIST OF FIGURES

2-1 UNIT BLOCK DIAGRAM.....	6
3-1 SCAQMD METHOD 207.1 SAMPLE TRAIN	8

1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) was contracted the Canyon Power Plant to perform an ammonia slip test at Unit 3 as required by the facility Permit (Facility ID 153992) Condition Number D29.2. This report documents the results of the ammonia slip tests performed on October 13, 2020. The test was performed by John Groenenboom, Bryce Quinney, and David Hoang. John Groenenboom was the on-site Qualified Individual for MAQS. Ms. Bertha Hernandez coordinated the test for Canyon Power Plant.

The test consisted of duplicate ammonia tests performed at 50 MW. The test program followed the procedures described in the initial compliance test protocol (MAQS document R038842). The results of the test are summarized in Table 1-1. The table shows that the ammonia slip from this unit was less than the permitted limit of 5 ppm corrected to 15% O₂.

**TABLE 1-1
AMMONIA SLIP TEST RESULTS SUMMARY
CANYON POWER PLANT UNIT 3
OCTOBER 13, 2020**

Parameter/Units	Result ⁽¹⁾	Limit
NH ₃		
ppm	1.7	--
ppm @ 15% O ₂	1.5	5

(1) Maximum of duplicate runs, as required by SCAQMD Method 207.1.


Section 2 of this document provides a brief description of the unit, test conditions, sample location, and CEMS. Details of the test procedures are provided in Section 3. Section 4 provides the results of each individual test. All raw data, calculations, quality assurance data, unit operating conditions, and CEMS data are provided in the appendices.

2.0 UNIT AND CEMS DESCRIPTION

2.1 UNIT DESCRIPTION

The City of Anaheim Canyon Power Plant is located at 3071 E. Mira Loma Avenue, Anaheim, California 92806. The facility consists of four identical generating units. Each unit consists of a natural gas fired, GE Model LM6000PC Sprint simple cycle, gas turbine. The units are natural gas fired with a rated heat input of 479 MMBtu per hour at 46°F, with water injection. The units are equipped with a CO catalyst and Selective Catalytic Reduction (SCR) system for NO_x control. Figure 2-1 presents a block diagram of the unit.

**FIGURE 2-1
UNIT BLOCK DIAGRAM
CANYON POWER PLANT**



Stack Inside Diameter:	11 feet, 8 inches
Distance from Upstream Disturbance:	23 feet, 4 inches (2.0 Diameters)
Distance from Stack Exit:	16 feet, 6 inches (1.4 Diameters)

2.2 TEST CONDITIONS

The tests were performed with the unit operating at an average load of 50 MW. Tests were performed while the unit was firing natural gas and operating under normal conditions. Unit operation was established by the Canyon Power Plant operators.

2.3 SAMPLE LOCATION


The measurements were made from sample ports located on the exhaust stack. There are four sample ports equally spaced at this location. The stack inside diameter at the sample plane is 11 feet, 8 inches. The sample ports are located 23 feet, 4 inches (2.0 diameters) downstream of the nearest flow disturbance and 16 feet, 6 inches (1.4 diameters) from the stack exit.

3.0 TEST DESCRIPTION

Flue gas samples were collected non-isokinetically using a SCAQMD Method 207.1 sample train. The samples were collected using a 12-point traverse at the exhaust stack location. Each test was performed over a 60 minute interval. The sample gas was drawn through a glass probe, Teflon sample line, two impingers each containing 100 ml of 0.1N H₂SO₄, an empty impinger, an impinger containing silica gel, and a dry gas meter. The optional nozzle and filter were not used since the source is natural gas fired. The contents of the sample line and the first three impingers were recovered and analyzed by SCAQMD Method 207.1 for ammonia concentration by Ion Specific Electrode analysis. Figure 3-1 presents a diagram of the sample train.

Stack NO_x and O₂ concentrations and stack volumetric flow rate data were recorded from the Continuous Emission Monitoring System (CEMS) which is installed on the unit. These data were used to correct the ammonia concentration to 15% O₂.

FIGURE 3-1
SCAQMD METHOD 207.1 SAMPLE TRAIN



4.0 TEST RESULTS

The results of the test are summarized in Table 4-1. The results show that the maximum ammonia slip was 1.5 ppm @ 15% O₂ which is less than the permitted limit of 5 ppm @ 15% O₂.

**TABLE 4-1
AMMONIA SLIP TEST RESULTS
CANYON POWER PLANT UNIT 3
OCTOBER 13, 2020**

Parameter/Units	Run 1	Run 2	Average	Maximum ⁽¹⁾	Limit
Test	1-NH ₃ -U3	2-NH ₃ -U3			--
Date	10/13/2020	10/13/2020			--
Time	1813/1916	1947/2050			--
O₂, %⁽²⁾	14.54	14.51	14.53	--	--
Stack Flow , dscfm @ T _{ref} ⁽²⁾	239,417	239,909	239,663	--	--
NO_x , ppmc ⁽²⁾	2.4	2.3	2.3	--	2.5
NH₃					
ppm	1.7	1.6	1.6	1.7	--
ppm @ 15% O ₂	1.5	1.5	1.5	1.5	5
lb/hr	1.1	1.0	1.1	1.1	--
lb/MMBtu	0.002	0.002	0.002	0.002	--
lb/MMSCF	2.2	2.1	2.2	2.2	--


(1) Maximum of duplicate test runs, as required by SCAQMD Method 207.1

(2) From facility CEMS

APPENDIX A RAW DATA

Appendix A.1

Sample Data Sheets



13 of 55

Imp. #	Contents	Post-Test	Pre-Test	= Difference
1	H2SO4	933.1	731.4	
2	H2SO4	725.0	721.7	
3	MT	622.3	621.2	
4	SG	917.9	907.3	
	LR	0	100	
Total:				

Comments:

1-NH3-U3

Point	Meter Volume	Delta H	Tm In	Tm Out
6	976.200	1.5	90	86
5			89	84
4			87	85
3			85	82
2				
1				
Stop				
6				
5				
4				
3				
2				
1				
Stop	1019.858			
Result	43.658	1.5	86.0	

Impinger Weights

#	Post-Test	Pre-Test	Difference
1	919.7	716.7	203.0
2	725.6	723.8	1.8
3	590.1	588.8	1.3
4	939.6	925.9	13.7
Line Rinse	0.0	100.0	-100.0
			119.8

2-NH3-U3

Point	Meter Volume	Delta H	Tm In	Tm Out
6	20.850	1.5	81	76
5			80	75
4			78	74
3			77	73
2				
1				
Stop				
6				
5				
4				
3				
2				
1				
Stop	63.915			
Result	43.065	1.5	76.8	

Impinger Weights

#	Post-Test	Pre-Test	Difference
1	933.1	731.4	201.7
2	725.0	721.7	3.3
3	622.3	621.2	1.1
4	917.9	907.3	10.6
Line Rinse	0.0	100.0	-100.0
			116.7

Appendix A.2 Laboratory Data

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS

Project #: 002AS-1680102 District Method: SCAQMD 207.1 Sample Date: 10/13/2020
 Client/Location: SCPPA Calibration Date: 10/16/2020 Analysis Date: 10/16/2020
 Sample Location: U3 Calibration Curve: $y = -58.0294x + 104.0544$ Analyst's Initials: HS
 Test #s: NH₃-U3 R²: 1.0000 Room Temperature (C°): 20

Sample	Total Vol. (mL)	Electrode Potential (mV)	Conc. $\mu\text{g NH}_3 - \text{N / ml}$	Cavg ($\mu\text{g NH}_3 - \text{N / ml}$)	$\mu\text{g NH}_3 / \text{sample}$	T (C°)	Blue after + ISA (Y/N)	pH	% R
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$		19.0	29.222	28.992		19.2	Y		104%
		19.4	28.762			19.2	Y		
1-NH ₃ -U3	637.4	89.0	1.817	1.810	1402.476	19.0	Y	42	
		89.2	1.803			19.2	Y		
2-NH ₃ -U3	619.4	88.9	1.825	1.817	1368.289	19.1	Y	42	
		89.1	1.810			19.2	Y		
Spike: 2-NH ₃ + 2ml 1000ppm NH ₃		27.0	21.274	21.274		19.0	Y		101%
		27.0	21.274			19.3	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$		20.6	27.425	27.589		19.0	Y		99%
		20.3	27.753			19.0	Y		
Reagent Blank 0.1N H ₂ SO ₄		191.1	0.032	0.032		19.1	Y		
		191.5	0.031			19.3	Y		
DI H ₂ O Blank		197.4	0.025	0.025		19.2	Y		
		197.7	0.024			19.4	Y		
Field Blank	426.4	187.8	0.036	0.036		19.1	Y		
		188.1	0.036			19.0	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$		20.5	27.534	27.317		19.2	Y		98%
		20.9	27.100			19.0	Y		

Notes:

 Total volume of samples and standards used: 100ml

 Volume of pH adjusting ISA used in ml: 2ml

 Absorbing solution: 0.1N H₂SO₄
Calculations:

 Conc. ($\mu\text{g NH}_3 - \text{N / ml}$) = $10^{(P-B)/M}$; (P = electrode potential, B = y-intercept and M = slope)

 Cavg = average result of duplicate analyses ($\mu\text{g NH}_3 - \text{N / ml}$) = $(C1+C2)/2$
 $\mu\text{g NH}_3 / \text{sample} = \text{Cavg} \times 17.03 / 14.01 \times \text{TV}$
 $\text{mg / sample} = \mu\text{g / sample} \div 1000$
 $\text{ppm NH}_3 = \text{mg NH}_3 / \text{sample} \times 1 / \text{Vmstd} \times 1 / 454000 \times \text{SV} / 17 \times 10^6$

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALCULATION

Client/ Location: SCPPA
Sample Location: U3
District Method: SCAQMD 207.1
Sample Date: 10/13/2020
Analysis Date: 10/16/2020
Analyst's Initials: HS
Calibration Curve Slope -58.0294
Y-intercept 104.0544
R²

Sample	P mV	Conc. µg NH ₃ /ml as N	C avg as N	TV (ml)	C avg as NH ₃	µg NH ₃ / sample
28 ug NH ₃ / ml as N	19.0	29.222				
repeat 28 ug NH ₃ /ml as N	19.4	28.762	28.992	NA	35.242	NA
1-NH ₃	89.0	1.817				
repeat 1- NH ₃	89.2	1.803	1.810	637.4	2.200	1402.476
2-NH ₃	88.9	1.825				
repeat 2- NH ₃	89.1	1.810	1.817	619.4	2.209	1368.289
spike 2-NH ₃	27.0	21.274				
repeat spike	27.0	21.274	21.274	NA	25.860	NA
28 NH ₃ /ml as N	20.6	27.425				
repeat 28 ug NH ₃ /ml as N	20.3	27.753	27.589	NA	33.536	NA
Field Blank	187.8	0.036				
repeat Field Blank	188.1	0.036	0.036	426.4	0.044	NA
Reagent Blank	191.1	0.032				
repeat Reagent Blank	191.5	0.031	0.032	NA	0.039	NA
DI H ₂ O Blank	197.4	0.025				
Repeat DI H ₂ O Blank	197.7	0.024	0.025	NA	0.030	NA
28 NH ₃ /ml as N	20.5	27.534				
repeat 28 ug NH ₃ /ml as N	20.9	27.100	27.317	NA	33.205	NA

Notes:

Measured Concentration of Ammonia (C) in µg NH₃ / ml as N

$$C=10^{(P-B)/M}$$

P = electrode potential (mV), M=slope and B=intercept

Average Measured Ammonia Concentration (Cavg) = (C1 + C2)/2

where C1, C2 results from duplicate analyses (µg NH₃/ml as N)

Cavg (µg NH₃/ml as NH₃) = Cavg (µg NH₃/ ml as N) * 17.03/ 14.01

µg NH₃ / sample = Cavg (µg NH₃/ml as NH₃) * TV

Used 100 ml of samples and standards with 2 ml ISA and constant stirring rate.

All solutions turned blue and remained blue with ISA unless otherwise indicated.

Sample PH and Temperatures can be found on the laboratory datasheet.

Maximum samples (including blanks) between 28 ug/ml check standard is 5 samples analyzed in duplicate.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS QUALITY CONTROL

Client/ Location: SCPPA
Sample Location: U3
District Method: SCAQMD 207.1
Sample Date: 10/13/2020
Analysis Date: 10/16/2020
Analyst's Initials: HS

Sample	% recovery	RPD %	RPA %
28 ug NH ₃ / ml as N repeat 28 ug NH ₃ /ml as N	NA	1.59	3.543
1-NH3 repeat 1- NH3	NA	0.79	NA
2-NH3 repeat 2- NH3	NA	0.79	NA
spike 2-NH3 repeat spike	101.36	0.00	NA
28 NH ₃ /ml as N repeat 28 ug NH ₃ /ml as N	NA	-1.19	-1.469
Field Blank repeat Field Blank	NA	1.19	NA
Reagent Blank repeat Reagent Blank	NA	1.56	NA
DI H2O Blank Repeat DI H2O Blank	NA	1.17	NA
28 NH ₃ /ml as N repeat 28 ug NH ₃ /ml as N	NA	1.59	-2.440

Notes:

spike: 100 ml sample + 2 ml (1000 µg NH₃ / ml as N)

Matrix Spike Percent Recovery (%R)

%R = (C spike*0.104 - Csample*0.102)/2 *100

Cspike = average result of matrix spike (µg NH₃/ ml as N)


Relative Percent Difference (RPD) = (C1-C2)/ Cavg *100 (must be 5% or less)

Relative Percent Accuracy (RPA) (must be 10% or less)

RPA = (Cavg-theoretical value of standard)/ theoretical value of standard * 100

AMMONIA ELECTRODE CALIBRATION CURVE

NH ₃ concentration (μg NH ₃ / ml as N)	log NH ₃ concentration	Electrode potential (mV)	Sample Temperature (C)	Room Temperature (C)
1	0.000	103.8	19	20
5	0.699	63.7	19	20
20	1.301	28.9	19	20
100	2.000	-12.3	19	20



slope	-58.0294
y-intercept	104.0544

Concentration ($\mu\text{g NH}_3$ / ml as N)	Value LR line	Difference	% Difference
1	1.0101	0.0101	1.0144
5	4.9592	-0.0408	-0.8157
20	19.7292	-0.2708	-1.3541
100	101.1800	1.1800	1.1800

Calculation:

Regression Line: $P = M \cdot \log(\mu\text{g of NH}_3 / \text{ml as N}) + B$

Measured Concentration of Ammonia (C) in $\mu\text{g} / \text{ml NH}_3$ as N: $C=10^{(P-B)/M}$

where P = electrode potential, M= slope (must be -57 ± 3) and B= intercept

All standards were prepared in 0.04N H₂SO₄ and allowed to equilibrate to room temperature.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALIBRATION DATA

District Method: SCAQMD 207.1

Calibration Date: 10/16/2020
 Calibration Curve: $y = -58.0294x + 104.0544$
 R^2 1.0000
 Analyst's Initials: HS
 Thermometer #: 1
 ISE Electrode #: 8

Calibration Standard ($\mu\text{g NH}_3$ / ml as N)	Electrode Potential (mV)	Solution Temperature ($^{\circ}\text{C}$)	Room Temperature ($^{\circ}\text{C}$)
1	103.8	19	20
5	63.7	19	20
20	28.9	19	20
100	-12.3 ^{HS 10/16/20} -12.3	19	20

Notes: Total volume of samples and standards used: 100 ml
 Volume of pH adjusting ISA used in ml: 2 ml
 Absorbing solution: 0.04 H₂SO₄
 Slope of the calibration curve shall be between -54 to -60
 R^2 must be 0.9997 or greater
 Calibration solutions, sample solutions and Calibration Verification standard temperature within $\pm 2^{\circ}\text{C}$

Appendix A.3

QA/QC Data

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Orifice Method - Triplicate Runs/Four Calibration Points
 English Meter Box Units, English K Factor
 Filename: M:\Santa Ana\Equipment\Test Equipment\Calibrations\Dry Gas Meters\10-P&M\2020\Semi-Annual Meter Calibration -10-P&M 7-17-2020
 File Modified From: APEX 522 Series Meter box Calibration
 Revised: 4/8/2005

Model #: 10 P&M
 ID #: 7/17/2020
 Date: 7/17/2020
 Bar. Pressure: 30.00 (in. Hg)
 Performed By: R. Howard
 Meter Serial #: 13464167

DRY GAS METER READINGS									CRITICAL ORIFICE READINGS					
dH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps Inlet Outlet (deg F) (deg F)		Final Temps Inlet Outlet (deg F) (deg F)		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature Initial Final Average (deg F) (deg F) (deg F)		
0.13	26.00	701.003	701.203	5.203	76.0	76.0	76.0	76.0	33	0.1551	18.0	75.0	75.0	75.0
0.13	26.00	701.203	706.405	5.202	76.0	76.0	76.0	76.0	33	0.1551	18.0	75.0	75.0	75.0
0.13	26.00	706.405	711.610	5.205	76.0	76.0	76.0	76.0	33	0.1551	18.0	75.0	75.0	75.0
0.60	12.00	712.500	717.687	5.187	77.0	77.0	79.0	77.0	48	0.3345	16.0	75.0	75.0	75.0
0.60	12.00	717.687	722.872	5.185	79.0	77.0	79.0	78.0	48	0.3345	16.0	75.0	75.0	75.0
0.60	12.00	722.872	728.061	5.189	79.0	78.0	78.0	78.0	48	0.3345	16.0	75.0	75.0	75.0
1.70	7.00	729.000	734.573	5.573	82.0	79.0	85.0	79.0	63	0.5915	14.0	76.0	76.0	76.0
1.70	7.00	734.573	740.147	5.574	85.0	79.0	85.0	81.0	63	0.5915	14.0	76.0	76.0	76.0
1.70	7.00	740.147	745.719	5.571	86.0	81.0	86.0	81.0	63	0.5915	14.0	76.0	76.0	76.0
3.00	5.00	747.200	752.413	5.213	87.0	85.0	91.0	87.0	73	0.7678	13.0	76.0	76.0	76.0
3.00	5.00	752.413	757.629	5.216	91.0	87.0	92.0	89.0	73	0.7678	13.0	76.0	76.0	76.0
3.00	5.00	757.629	762.838	5.209	92.0	89.0	93.0	90.0	73	0.7678	13.0	76.0	76.0	76.0

DRY GAS METER		ORIFICE		DRY GAS METER CALIBRATION FACTOR		ORIFICE CALIBRATION FACTOR		Individual Run	Individual Orifice	Orifice Average	Orifice Average
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	Y Value (number)	dH@ Value (in H ₂ O)		0.95 < Y < 1.05?	Ymax - Ymin < 0.010?	0.98 < Y/Yd < 1.02?	dH@ - dH@ av < 0.155?
5.139	145.5	5.230	148.1	5.288	1.018	1.785		Pass			
5.138	145.5	5.230	148.1	5.288	1.018	1.785		Pass			
5.141	145.6	5.230	148.1	5.288	1.017	1.785		Pass			
Average					1.018	1.785			Pass	Pass	Pass
5.114	144.8	5.206	147.4	5.263	1.018	1.768		Pass			
5.105	144.6	5.206	147.4	5.263	1.020	1.768		Pass			
5.109	144.7	5.206	147.4	5.263	1.019	1.768		Pass			
Average					1.019	1.766			Pass	Pass	Pass
5.474	155.0	5.366	152.0	5.435	0.980	1.600		Pass			
5.457	154.6	5.366	152.0	5.435	0.983	1.596		Pass			
5.447	154.3	5.366	152.0	5.435	0.985	1.593		Pass			
Average					0.983	1.596			Pass	Pass	Pass
5.076	143.7	4.975	140.9	5.039	0.980	1.653		Pass			
5.058	143.2	4.975	140.9	5.039	0.984	1.647		Pass			
5.040	142.7	4.975	140.9	5.039	0.987	1.642		Pass			
Average					0.984	1.647			Pass	Pass	Pass

Average Yd: 1.001 dH@: 1.699

Q @ dH = 1: 0.675

SIGNED: Signature on File

Date: 7/17/2020



23 of 55

Imp. #	Contents	Post-Test	Pre-Test	= Difference
1	H ₂ SO ₄	815.2	714.9	
2	H ₂ SO ₄	719.7	719.7	
3	MT	615.5	615.5	
4	SG	923.1	923.0	
LR			100	
Total:				

Comments:

CHAIN OF CUSTODY

CLIENT: SCPPAPROJECT #: W002AS-680102TEST DATE(S): 10/13/2020LOCATION: U3SAMPLER(S): BQ/DHSAMPLE LOCATION: StackPROJECT MANAGER: JGTEST METHOD(S): SCAQMD 207.1DATE DUE: 10/20/2020OUTSIDE LAB REQUIRED?: NoCOMPLIANCE TEST?: Yes

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
10/13/2020	1813/1916	1-NH3-U3	Probe, Line, Impingers	1	BQ/DH	
10/13/2020	1947/2050	2-NH3-U3	Probe, Line, Impingers	1	BQ/DH	
10/13/2020		Reagent Blank	0.1 N H ₂ SO ₄	1	JG	
10/13/2020		Reagent Blank	DI H ₂ O	1	JG	
10/13/2020		Field Blank	Probe, Line, Impingers	1	BQ/DH	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
	10/14/20 1850		10/14/20 1850
	10/14/20 1940		10/15/20 0820

ANALYSIS REQUIRED: NH₃ by SCAQMD 207.1 (ISE)

Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

APPENDIX B FACILITY CEMS DATA

Average Values Report
Generated: 10/13/2020 20:16Company: City Of Anaheim
Plant: 3071 Miraloma Ave.
City/St: Anaheim, CA, 92806
Source: 3Period Start: 10/13/2020 18:13
Period End: 10/13/2020 19:16
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 3_O2 %	Average 3_NOXPPM ppm	Average 3_NOX_CORR ppm	Average 3_NOX_LBHR #/hr	Average 3_NOX_LBMM #/MBTU	Average 3_COPPM ppm	Average 3_CO_CORR ppm	Average 3_CO_LBHR #/hr	Average 3_CO_LBMM #/MBTU	Average 3_GasFlow kscfh	Average 3_LOAD MW	Average 3_STACKFLW kscfm
10/13/2020 18:13	14.55	2.47	2.29	4.07	0.008	4.07	3.78	4.33	0.0085	484.9	49.64	243.2
10/13/2020 18:14	14.55	2.44	2.27	4.07	0.008	4.12	3.83	4.38	0.0086	485.0	49.58	243.3
10/13/2020 18:15	14.55	2.40	2.23	4.08	0.008	4.19	3.89	4.43	0.0087	485.1	49.76	243.4
10/13/2020 18:16	14.56	2.38	2.21	4.08	0.008	4.20	3.91	4.48	0.0088	485.1	49.53	243.8
10/13/2020 18:17	14.56	2.36	2.20	4.07	0.008	4.21	3.92	4.48	0.0088	484.7	49.57	243.5
10/13/2020 18:18	14.56	2.41	2.24	4.07	0.008	4.16	3.87	4.43	0.0087	484.9	49.68	243.6
10/13/2020 18:19	14.56	2.50	2.33	4.58	0.009	4.07	3.79	4.33	0.0085	484.8	49.63	243.6
10/13/2020 18:20	14.56	2.54	2.36	4.58	0.009	3.99	3.71	4.23	0.0083	485.1	49.54	243.8
10/13/2020 18:21	14.53	2.50	2.32	4.59	0.009	3.97	3.68	4.18	0.0082	485.3	49.82	242.7
10/13/2020 18:22	14.54	2.53	2.35	4.58	0.009	3.91	3.63	4.13	0.0081	485.0	49.80	243.0
10/13/2020 18:23	14.54	2.58	2.39	4.58	0.009	3.88	3.60	4.13	0.0081	485.1	49.75	243.0
10/13/2020 18:24	14.53	2.58	2.39	4.59	0.009	3.87	3.58	4.08	0.0080	485.4	49.80	242.8
10/13/2020 18:25	14.53	2.59	2.40	4.59	0.009	3.86	3.58	4.08	0.0080	485.3	49.62	242.7
10/13/2020 18:26	14.54	2.59	2.40	4.59	0.009	3.85	3.57	4.08	0.0080	485.4	49.73	243.1
10/13/2020 18:27	14.53	2.59	2.40	4.59	0.009	3.87	3.58	4.08	0.0080	485.8	49.60	243.0
10/13/2020 18:28	14.51	2.54	2.35	4.59	0.009	3.84	3.55	4.08	0.0080	485.7	49.49	242.1
10/13/2020 18:29	14.52	2.52	2.33	4.59	0.009	3.75	3.47	3.98	0.0078	485.6	49.72	242.5
10/13/2020 18:30	14.52	2.53	2.34	4.59	0.009	3.72	3.44	3.93	0.0077	485.5	49.71	242.4
10/13/2020 18:31	14.54	2.48	2.30	4.08	0.008	3.78	3.51	4.03	0.0079	485.6	49.70	243.2
10/13/2020 18:32	14.55	2.45	2.28	4.07	0.008	3.80	3.53	4.02	0.0079	485.0	49.67	243.3
10/13/2020 18:33	14.56	2.46	2.29	4.07	0.008	3.87	3.60	4.12	0.0081	484.8	49.82	243.6
10/13/2020 18:34	14.56	2.32	2.16	4.07	0.008	4.07	3.79	4.33	0.0085	484.9	49.83	243.6
10/13/2020 18:35	14.56	2.21	2.06	4.08	0.008	4.29	3.99	4.59	0.0090	485.2	49.60	243.8
10/13/2020 18:36	14.55	2.19	2.03	3.57	0.007	4.35	4.04	4.64	0.0091	485.2	49.64	243.4
10/13/2020 18:37	14.54	2.16	2.00	3.57	0.007	4.41	4.09	4.69	0.0092	485.2	49.60	243.1
10/13/2020 18:38	14.55	2.14	1.99	3.57	0.007	4.42	4.11	4.69	0.0092	485.2	49.55	243.4
10/13/2020 18:39	14.54	2.29	2.12	4.08	0.008	4.32	4.01	4.59	0.0090	485.5	49.68	243.2
10/13/2020 18:40	14.54	3.13	2.90	5.60	0.011	3.96	3.67	4.18	0.0082	485.2	49.66	243.1
10/13/2020 18:41	14.55	3.44	3.20	6.12	0.012	3.53	3.28	3.77	0.0074	485.3	49.67	243.5
10/13/2020 18:42	14.54	2.73	2.53	4.59	0.009	3.30	3.06	3.52	0.0069	485.4	49.60	243.1
10/13/2020 18:43	14.54	2.51	2.33	4.59	0.009	3.37	3.13	3.57	0.0070	485.5	49.66	243.2
10/13/2020 18:44	14.52	3.00	2.77	5.11	0.010	3.53	3.26	3.73	0.0073	486.2	49.81	242.8
10/13/2020 18:45	14.47	3.08	2.83	5.11	0.010	3.63	3.33	3.83	0.0075	486.4	49.78	241.0
10/13/2020 18:46	14.49	2.99	2.75	5.10	0.010	3.73	3.43	3.93	0.0077	486.1	49.65	241.6
10/13/2020 18:47	14.51	2.71	2.50	4.59	0.009	3.83	3.54	4.03	0.0079	485.7	49.58	242.1
10/13/2020 18:48	14.51	2.56	2.36	4.59	0.009	3.91	3.61	4.13	0.0081	485.4	49.69	242.0
10/13/2020 18:49	14.52	2.58	2.39	4.59	0.009	3.91	3.62	4.13	0.0081	485.2	49.82	242.3
10/13/2020 18:50	14.54	2.56	2.37	4.59	0.009	3.93	3.65	4.18	0.0082	485.3	49.75	243.1
10/13/2020 18:51	14.55	2.51	2.33	4.59	0.009	4.00	3.72	4.23	0.0083	485.2	49.66	243.4
10/13/2020 18:52	14.57	2.48	2.31	4.58	0.009	4.07	3.79	4.33	0.0085	485.1	49.60	244.2
10/13/2020 18:53	14.57	2.44	2.27	4.08	0.008	4.13	3.85	4.38	0.0086	485.2	49.83	244.2
10/13/2020 18:54	14.57	2.40	2.24	4.07	0.008	4.25	3.96	4.53	0.0089	485.0	49.60	244.1
10/13/2020 18:55	14.57	2.36	2.20	4.08	0.008	4.31	4.02	4.59	0.0090	485.2	49.75	244.2
10/13/2020 18:56	14.56	2.36	2.20	4.08	0.008	4.29	3.99	4.59	0.0090	485.3	49.59	243.9
10/13/2020 18:57	14.55	2.41	2.24	4.08	0.008	4.12	3.83	4.39	0.0086	485.8	49.81	243.7
10/13/2020 18:58	14.55	2.46	2.29	4.08	0.008	3.98	3.70	4.23	0.0083	485.6	49.68	243.6
10/13/2020 18:59	14.55	2.48	2.30	4.08	0.008	3.89	3.61	4.13	0.0081	485.4	49.47	243.5
10/13/2020 19:00	14.54	2.51	2.33	4.59	0.009	3.84	3.56	4.08	0.0080	485.9	49.66	243.4
10/13/2020 19:01	14.53	2.53	2.34	4.59	0.009	3.85	3.57	4.08	0.0080	486.0	49.72	243.1
10/13/2020 19:02	14.53	2.50	2.32	4.59	0.009	3.89	3.60	4.13	0.0081	485.5	49.68	242.8
10/13/2020 19:03	14.53	2.50	2.32	4.59	0.009	3.94	3.65	4.18	0.0082	485.8	49.75	243.0
10/13/2020 19:04	14.53	2.49	2.31	4.08	0.008	3.93	3.64	4.18	0.0082	485.9	49.77	243.0

1-NH3

Period Start:	Average 3_O2 %	Average 3_NOXPPM ppm	Average 3_NOX_CORR ppm	Average 3_NOX_LBHR #/hr	Average 3_NOX_LBMM #/MBTU	Average 3_COPPM ppm	Average 3_CO_CORR ppm	Average 3_CO_LBHR #/hr	Average 3_CO_LBMM #/MBTU	Average 3_GasFlow kscfh	Average 3_LOAD MW	Average 3_STACKFLOW kscfm
10/13/2020 19:05	14.53	2.48	2.30	4.08	0.008	3.94	3.65	4.18	0.0082	485.6	49.52	242.9
10/13/2020 19:06	14.53	2.48	2.30	4.08	0.008	3.94	3.65	4.18	0.0082	485.9	49.59	243.0
10/13/2020 19:07	14.52	2.48	2.29	4.09	0.008	3.92	3.63	4.15	0.0081	487.4	50.01	243.4
10/13/2020 19:08	14.51	2.52	2.33	4.62	0.009	3.87	3.57	4.10	0.0080	488.6	50.05	243.6
10/13/2020 19:09	14.50	2.63	2.42	4.61	0.009	3.74	3.45	3.95	0.0077	488.3	49.94	243.1
10/13/2020 19:10	14.50	2.80	2.58	5.13	0.010	3.57	3.29	3.79	0.0074	488.2	50.01	243.0
10/13/2020 19:11	14.50	2.89	2.66	5.12	0.010	3.49	3.22	3.69	0.0072	487.8	49.83	242.8
10/13/2020 19:12	14.50	2.77	2.55	4.61	0.009	3.56	3.28	3.79	0.0074	487.9	49.77	242.9
10/13/2020 19:13	14.51	2.70	2.49	4.60	0.009	3.64	3.36	3.84	0.0075	487.1	49.77	242.9
10/13/2020 19:14	14.51	2.63	2.43	4.62	0.009	3.69	3.41	3.90	0.0076	488.5	49.85	243.5
10/13/2020 19:15	14.51	2.61	2.41	4.61	0.009	3.71	3.43	3.95	0.0077	488.0	49.99	243.3
10/13/2020 19:16	14.50	2.64	2.43	4.61	0.009	3.71	3.42	3.94	0.0077	487.4	49.83	242.6
Daily Average*	14.54	2.55	2.36	4.44	0.009	3.92	3.63	4.16	0.0081	485.8	49.71	243.1
Maximum*	14.57	3.44	3.20	6.12	0.012	4.42	4.11	4.69	0.0092	488.6	50.05	244.2
10/13/2020 18:55	18:41	18:41	18:41	18:41	18:41	18:38	18:38	18:38	18:38	19:08	19:08	18:55
Minimum*	14.47	2.14	1.99	3.57	0.007	3.30	3.06	3.52	0.0069	484.7	49.47	241.0
10/13/2020 18:45	18:38	18:38	18:38	18:38	18:38	18:42	18:42	18:42	18:42	18:17	18:59	18:45

* Does not include Invalid Averaging Periods ("N/A")

W002AS-004299-RT-1759

27 of 55

Average Values Report
Generated: 10/13/2020 22:02Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 3Period Start: 10/13/2020 19:47
Period End: 10/13/2020 20:50
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 3_O2 %	Average 3_NOXPPM ppm	Average 3_NOX_CORR ppm	Average 3_NOX_LBHR #/hr	Average 3_NOX_LBMM #/MBTU	Average 3_COPPM ppm	Average 3_CO_CORR ppm	Average 3_CO_LBHR #/hr	Average 3_CO_LBMM #/MBTU	Average 3_GasFlow kscfh	Average 3_LOAD MW	Average 3_STACKPLW kscfm
10/13/2020 19:47	14.51	2.42	2.23	4.10	0.008	3.85	3.55	4.10	0.0080	487.8	49.79	243.2
10/13/2020 19:48	14.51	2.41	2.23	4.10	0.008	3.85	3.55	4.10	0.0080	487.7	49.89	243.1
10/13/2020 19:49	14.51	2.41	2.23	4.10	0.008	3.86	3.56	4.10	0.0080	488.3	49.95	243.4
10/13/2020 19:50	14.50	2.41	2.22	4.10	0.008	3.88	3.58	4.10	0.0080	488.1	49.78	243.0
10/13/2020 19:51	14.50	2.40	2.21	4.10	0.008	3.90	3.60	4.15	0.0081	488.4	49.88	243.1
10/13/2020 19:52	14.51	2.41	2.23	4.10	0.008	3.87	3.57	4.10	0.0080	488.3	49.85	243.4
10/13/2020 19:53	14.51	2.45	2.26	4.10	0.008	3.81	3.52	4.05	0.0079	488.4	49.80	243.5
10/13/2020 19:54	14.51	2.49	2.30	4.10	0.008	3.75	3.46	4.00	0.0078	488.3	49.71	243.4
10/13/2020 19:55	14.51	2.50	2.31	4.61	0.009	3.71	3.43	3.95	0.0077	488.2	49.84	243.4
10/13/2020 19:56	14.51	2.49	2.30	4.10	0.008	3.70	3.42	3.95	0.0077	488.2	49.96	243.4
10/13/2020 19:57	14.51	2.50	2.31	4.61	0.009	3.70	3.42	3.95	0.0077	488.2	49.97	243.4
10/13/2020 19:58	14.51	2.50	2.31	4.61	0.009	3.70	3.42	3.95	0.0077	488.1	49.92	243.3
10/13/2020 19:59	14.51	2.52	2.33	4.61	0.009	3.69	3.41	3.90	0.0076	488.3	49.90	243.4
10/13/2020 20:00	14.51	2.54	2.35	4.61	0.009	3.68	3.40	3.90	0.0076	488.1	49.81	243.3
10/13/2020 20:01	14.51	2.53	2.34	4.62	0.009	3.71	3.43	3.95	0.0077	488.4	49.70	243.5
10/13/2020 20:02	14.51	2.52	2.33	4.62	0.009	3.74	3.45	3.95	0.0077	488.8	50.01	243.7
10/13/2020 20:03	14.51	2.48	2.29	4.11	0.008	3.75	3.46	4.00	0.0078	488.8	49.91	243.7
10/13/2020 20:04	14.51	2.48	2.29	4.10	0.008	3.73	3.44	3.95	0.0077	488.6	49.85	243.6
10/13/2020 20:05	14.51	2.49	2.30	4.10	0.008	3.73	3.44	3.95	0.0077	488.5	49.94	243.5
10/13/2020 20:06	14.51	2.47	2.28	4.10	0.008	3.74	3.45	3.95	0.0077	488.2	49.78	243.4
10/13/2020 20:07	14.51	2.47	2.28	4.10	0.008	3.74	3.45	3.95	0.0077	488.6	49.78	243.6
10/13/2020 20:08	14.51	2.49	2.30	4.11	0.008	3.75	3.46	4.00	0.0078	488.8	50.00	243.7
10/13/2020 20:09	14.50	2.48	2.29	4.10	0.008	3.75	3.46	4.00	0.0078	488.6	49.86	243.2
10/13/2020 20:10	14.51	2.48	2.29	4.11	0.008	3.77	3.48	4.00	0.0078	488.8	49.69	243.7
10/13/2020 20:11	14.51	2.47	2.28	4.10	0.008	3.79	3.50	4.05	0.0079	488.6	49.91	243.6
10/13/2020 20:12	14.50	2.48	2.29	4.10	0.008	3.80	3.50	4.05	0.0079	488.5	50.00	243.1
10/13/2020 20:13	14.51	2.49	2.30	4.11	0.008	3.79	3.50	4.06	0.0079	488.9	49.99	243.7
10/13/2020 20:14	14.51	2.48	2.29	4.11	0.008	3.79	3.50	4.06	0.0079	489.0	49.80	243.8
10/13/2020 20:15	14.51	2.50	2.31	4.62	0.009	3.79	3.50	4.06	0.0079	488.9	49.93	243.7
10/13/2020 20:16	14.51	2.50	2.31	4.62	0.009	3.79	3.50	4.06	0.0079	488.9	50.03	243.7
10/13/2020 20:17	14.51	2.50	2.31	4.62	0.009	3.79	3.50	4.05	0.0079	488.7	50.01	243.6
10/13/2020 20:18	14.51	2.49	2.30	4.11	0.008	3.79	3.50	4.06	0.0079	488.9	49.90	243.7
10/13/2020 20:19	14.51	2.49	2.30	4.11	0.008	3.79	3.50	4.05	0.0079	488.8	49.74	243.7
10/13/2020 20:20	14.51	2.49	2.30	4.11	0.008	3.79	3.50	4.06	0.0079	489.0	50.11	243.8
10/13/2020 20:21	14.50	2.48	2.29	4.11	0.008	3.81	3.51	4.06	0.0079	488.9	49.89	243.3
10/13/2020 20:22	14.51	2.48	2.29	4.11	0.008	3.83	3.54	4.06	0.0079	488.9	49.84	243.7
10/13/2020 20:23	14.51	2.49	2.30	4.11	0.008	3.81	3.52	4.05	0.0079	488.8	49.98	243.7
10/13/2020 20:24	14.51	2.49	2.30	4.11	0.008	3.79	3.50	4.05	0.0079	488.8	49.91	243.7
10/13/2020 20:25	14.51	2.47	2.28	4.11	0.008	3.77	3.48	4.00	0.0078	488.9	49.98	243.7
10/13/2020 20:26	14.50	2.48	2.29	4.11	0.008	3.75	3.46	4.01	0.0078	489.0	49.89	243.4
10/13/2020 20:27	14.50	2.51	2.31	4.62	0.009	3.75	3.46	4.01	0.0078	489.2	49.95	243.5
10/13/2020 20:28	14.50	2.52	2.32	4.62	0.009	3.76	3.47	4.00	0.0078	488.9	49.92	243.3
10/13/2020 20:29	14.50	2.51	2.31	4.62	0.009	3.79	3.49	4.00	0.0078	488.9	49.88	243.3
10/13/2020 20:30	14.51	2.49	2.30	4.11	0.008	3.80	3.51	4.06	0.0079	489.4	49.90	244.0
10/13/2020 20:31	14.51	2.50	2.31	4.62	0.009	3.78	3.49	4.01	0.0078	489.1	49.88	243.9
10/13/2020 20:32	14.51	2.61	2.41	4.61	0.009	3.65	3.37	3.90	0.0076	488.1	50.01	243.3
10/13/2020 20:33	14.51	2.74	2.53	4.62	0.009	3.53	3.26	3.75	0.0073	488.9	50.07	243.7
10/13/2020 20:34	14.51	2.65	2.45	4.62	0.009	3.61	3.33	3.85	0.0075	489.2	49.83	243.9
10/13/2020 20:35	14.51	2.45	2.26	4.11	0.008	3.78	3.49	4.01	0.0078	489.2	49.88	243.9
10/13/2020 20:36	14.51	2.36	2.18	4.11	0.008	3.83	3.54	4.06	0.0079	489.8	49.89	244.2
10/13/2020 20:37	14.52	2.33	2.15	4.09	0.008	3.82	3.53	4.04	0.0079	486.5	49.79	242.9
10/13/2020 20:38	14.53	2.46	2.28	4.11	0.008	3.74	3.46	4.01	0.0078	489.2	49.90	244.7

Period Start:	Average 3_O2 %	Average 3_NOXPPM ppm	Average 3_NOX_CORR ppm	Average 3_NOX_LBHR #/hr	Average 3_NOX_LBMM #/MBTU	Average 3_COPPM ppm	Average 3_CO_CORR ppm	Average 3_CO_LBHR #/hr	Average 3_CO_LBMM #/MBTU	Average 3_GasFlow kscfh	Average 3_LOAD MW	Average 3_STACKFLW kscfm
10/13/2020 20:39	14.51	2.54	2.35	4.62	0.009	3.71	3.43	3.95	0.0077	488.8	49.94	243.7
10/13/2020 20:40	14.50	2.50	2.30	4.11	0.008	3.75	3.46	4.00	0.0078	488.9	49.81	243.3
10/13/2020 20:41	14.50	2.44	2.25	4.11	0.008	3.85	3.55	4.11	0.0080	489.0	49.89	243.4
10/13/2020 20:42	14.51	2.43	2.24	4.11	0.008	3.86	3.56	4.11	0.0080	489.0	49.91	243.8
10/13/2020 20:43	14.51	2.44	2.25	4.10	0.008	3.83	3.54	4.05	0.0079	488.6	49.95	243.6
10/13/2020 20:44	14.52	2.47	2.28	4.11	0.008	3.79	3.50	4.06	0.0079	489.5	49.80	244.4
10/13/2020 20:45	14.51	2.48	2.29	4.10	0.008	3.78	3.49	4.00	0.0078	488.4	49.87	243.5
10/13/2020 20:46	14.52	2.48	2.29	4.11	0.008	3.77	3.49	4.01	0.0078	489.0	49.92	244.2
10/13/2020 20:47	14.52	2.48	2.29	4.11	0.008	3.77	3.49	4.01	0.0078	489.2	49.93	244.3
10/13/2020 20:48	14.51	2.48	2.29	4.11	0.008	3.79	3.50	4.06	0.0079	489.3	50.07	244.0
10/13/2020 20:49	14.52	2.48	2.29	4.11	0.008	3.80	3.51	4.06	0.0079	489.0	50.02	244.2
10/13/2020 20:50	14.52	2.50	2.31	4.63	0.009	3.79	3.50	4.06	0.0079	489.6	49.85	244.5
Daily Average*	14.51	2.48	2.29	4.26	0.008	3.77	3.48	4.02	0.0078	488.7	49.90	243.6
Maximum*	14.53	2.74	2.53	4.63	0.009	3.90	3.60	4.15	0.0081	489.8	50.11	244.7
10/13/2020 20:38	10/13/2020 20:33	10/13/2020 20:33	10/13/2020 20:33	10/13/2020 20:50	10/13/2020 20:50	10/13/2020 19:51	10/13/2020 19:51	10/13/2020 19:51	10/13/2020 19:51	10/13/2020 20:36	10/13/2020 20:20	10/13/2020 20:38
Minimum*	14.50	2.33	2.15	4.09	0.008	3.53	3.26	3.75	0.0073	486.5	49.69	242.9
10/13/2020 20:41	10/13/2020 20:37	10/13/2020 20:37	10/13/2020 20:37	10/13/2020 20:37	10/13/2020 20:49	10/13/2020 20:33	10/13/2020 20:33	10/13/2020 20:33	10/13/2020 20:33	10/13/2020 20:37	10/13/2020 20:10	10/13/2020 20:37

* Does not include Invalid Averaging Periods (*N/A*)

W002AS-004299-RT-1759

29 of 55

APPENDIX C CALCULATIONS

Appendix C.1

General Emissions Calculations

GENERAL EMISSION CALCULATIONS

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^{\circ}R}{T_{ref}}$$

VII. Particulate emissions

- (a) Grain loading, gr/dscf
 $C = 0.01543 (M_n/V_{mstd})$
- (b) Grain loading at 12% CO₂, gr/dscf
 $C_{12\% CO_2} = C (12/\% CO_2)$
- (c) Mass emissions, lb/hr
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$
- (d) Particulate emission factor
 $\text{lb}/10^6 \text{ Btu} = C * \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% O_2}$

Nomenclature:

A_s	= stack area, ft ²
B_{wo}	= flue gas moisture content, dimensionless
$C_{12\%CO_2}$	= particulate grain loading, gr/dscf corrected to 12% CO ₂
C	= particulate grain loading, gr/dscf
C_p	= pitot calibration factor, dimensionless
D_n	= nozzle diameter, in.
F	= fuel F-Factor, dscf/MMBtu @ 0% O ₂
H	= orifice differential pressure, iwg
I	= % isokinetics
M_n	= mass of collected particulate, mg
M_i	= mass emission rate of specie i, lb/hr
MW	= molecular weight of flue gas, lb/lb-mole
M_{wi}	= molecular weight of specie i:
	SO ₂ : 64
	NO _x : 46
	CO: 28
	HC: 16
t	= sample time, min.
ΔP	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	= barometric pressure, inches Hg
P_s	= stack absolute pressure, inches Hg
P_{sg}	= stack static pressure, iwbg
Q	= wet stack flow rate at actual conditions, wacfm
Q_{sd}	= dry standard stack flow rate, dscfm
SV	= specific molar volume of an ideal gas at standard conditions, ft ³ /lb-mole
T_m	= meter temperature, °R
T_{ref}	= reference temperature, °R
T_s	= stack temperature, °R
V_s	= stack gas velocity, ft/sec
V_{lc}	= volume of liquid collected in impingers, ml
V_m	= uncorrected dry meter volume, dcf
V_{mstd}	= dry meter volume at standard conditions, dscf
V_{wstd}	= volume of water vapor at standard conditions, scf
Y_d	= meter calibration coefficient

Appendix C.2

Spreadsheet Summaries

SCAQMD 207.1 EXAMPLE CALCULATION
TEST NUMBER: 1-NH3-U3

002AS-004299-RT-1759

Identifier	Description	Units	Equation	Value
A	Reference Temperature	F	--	60
B	Reference Temperature	R	$A + 460$	520
C	Meter Calibration Factor (Yd)	--	--	1.001
D	Barometric Pressure	" Hg	--	29.68
E	Meter Volume	acf	--	43.658
F	Meter Temperature	F	--	86.0
G	Meter Temperature	R	$F + 460$	546.0
H	Delta H	" H ₂ O	--	1.5
I	Meter Volume (standard)	dscf	$0.03342 * E * (D + H/13.6) * B/G * C$	41.437
J	Liquid Collected	grams	--	119.8
K	Water vapor volume	scf	$0.0472 * J * B/528$	5.569
L	Moisture Content	--	$K/(K + I)$	0.118
M	Gas Constant	ft-lbf/lb-mole-R	--	1545.33
N	Specific Molar Volume	SCF/lb-mole	$385.3 * B / 528$	379.5
O	F-Factor	dscf/MMBtu	--	8,710
P	HHV	Btu/SCF	--	1,050
Q	Mass Conversion Factor	lb/ug	--	2.2046E-09
R	O ₂ Correction Factor	--	--	15
S	Stack Flow Rate @ 68 F	dscfm	--	243,100
T	Stack Flow Rate @ Tref	dscfm	$S * B/528$	239,417
U	Mass NH ₃	ug	--	1,402
V	Mass NH ₃	lb	$U * Q$	3.09E-06
W	MW of NH ₃	lb/lb-mole	--	17.03
X	NH ₃	ppm	$(V * N * 10^9)/(I * W)$	1.7
Y	Flue Gas O ₂	%	--	14.54
Z	NH ₃	ppmc	$X * (20.9 - R)/(20.9 - Y)$	1.5
AA	NH ₃	lb/hr	$X * T * W * 60/(N * 10^9)$	1.1
AB	NH ₃	lb/MMBtu	$(X * W * O)/(385.3 * 10^9) * 20.9/(20.9 - Y)$	0.002
AC	NH ₃	lb/MMSCF	$AB * P$	2.2

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

SCAQMD METHOD 207.1 DATA WORKSHEET AND SUMMARY

Facility.....	Canyon		Parameter.....		NH₃
Unit.....	U3		Fuel.....		Natural gas
Sample Location.....	Stack		Data By.....		JG
Test Number.....	1-NH3-U3	2-NH3-U3	Average	Maximum	Limit
Reference Temperature (°F).....	60	60			
Test Date.....	10/13/2020	10/13/2020			
Test Method.....	SCAQMD 207.1	SCAQMD 207.1			
Sample Train.....	10-P&M	10-P&M			
Meter Calibration Factor.....	1.001	1.001			
Stack Area (ft ²).....	106.90	106.90			
Sample Time (Minutes).....	60	60			
Barometric Pressure ("Hg).....	29.68	29.68			
Start/Stop Time	1813/1916	1947/2050			
Meter Volume (acf).....	43.658	43.065			
Meter Temperature (°F).....	86.0	76.8			
Meter Pressure (iwg).....	1.5	1.5			
Liquid Volume (ml).....	119.8	116.7			
Stack O ₂ (%).....	14.54	14.51	14.53	(from facility CEMS)	
Unit Load (MW).....	50	50	49.8		
Standard Sample Volume (SCF).....	41.437	41.575			
Moisture Fraction.....	0.118	0.115			
Stack Flow Rate (dscfm, 68 °F).....	243,100	243,600	243,350	(from facility CEMS)	
Stack Flow Rate (@ Tref).....	239,417	239,909	239,663		
Gas Constant (ft-lbf/lb-mole-R).....	1545.33	1545.33			
Molecular Weight NH ₃ (lb/lb-mole).....	17.03	17.03			
Specific Molar Volume (ft ³ /lb-mole).....	379.5	379.5			
F-Factor (dscf/MMBtu).....	8,710	8,710			
HHV(Btu/SCF).....	1,050	1,050			
Mass Conversion (lb/ug).....	2.2046E-09	2.2046E-09			
O ₂ Correction Factor (%).....	15	15			
Mass NH ₃ (ug).....	1,402	1,368			
Mass NH ₃ (lb).....	3.09E-06	3.02E-06			
NH ₃ (ppmv, flue gas).....	1.7	1.6	1.6	1.7	
NH ₃ (ppmv @ O ₂ Correction Factor).....	1.5	1.5	1.5	1.5	5
NH ₃ (lb/hr).....	1.1	1.0	1.1	1.1	
NH ₃ (lb/MMBtu).....	0.002	0.002	0.002	0.002	
NH ₃ (lb/MMSCF).....	2.2	2.1	2.2	2.2	

Note: SCAQMD Method 207.1 requires the higher of the duplicate runs be reported as the test result.

APPENDIX D QUALITY ASSURANCE

Appendix D.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (MAQS) ASTM D7036-04 certification, MAQS is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. MAQS quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: MAQS has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: MAQS has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of MAQS QA efforts. The manual is revised upon periodic review and as MAQS adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. MAQS training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the MAQS QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of MAQS emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: MAQS maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: MAQS maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to MAQS source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to MAQS office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, will be present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)

The following safety measures will be followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO _x Analyzer	Daily	NO ₂ -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	+/- 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	+/- 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for $\Delta H@$	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	+/- 1.5%

Note: Calibration requirements will be used that meet applicable regulatory agency requirements.

Appendix D.2

SCAQMD and STAC Certifications



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 9, 2020

Mr. John Peterson
Montrose Air Quality Services, LLC
1631 E. Saint Andrew Place
Santa Ana, CA 92705

Subject: LAP Approval Notice
Reference # 96LA1220

Dear Mr. Peterson:

We have reviewed your renewal letter under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning September 30, 2020, and ending September 30, 2021 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

Methods 1-4	Methods 5.1, 5.2, 5.3, 6.1
Methods 10.1 and 100.1	Methods 25.1 and 25.3 (Sampling)
USEPA CTM-030 and ASTM D6522-00	Rule 1121/ 1146.2 Protocol
Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling	

Your LAP approval to perform nitrogen oxide emissions compliance testing for Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler 1510 North Spring Street Los Angeles, CA 90012	Noritz America Corp. 11160 Grace Avenue Fountain Valley, CA 92708	Ajax Boiler, Inc. 2701 S. Harbor Blvd. Santa Ana, CA 92704
---	---	--

Laundry Building of VA Greater Los Angeles Healthcare System
508 Constitution Avenue
Los Angeles, CA 90049

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerely,

A handwritten signature in black ink that reads 'D. Sarkar'.

Dipankar Sarkar
Program Supervisor
Source Test Engineering

DS:GK/gk
Attachment

200909 LapRenewalRev.doc

Keeping the air that we breathe...



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 11th day of February 2020.



Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3925.01
Valid to February 28, 2022

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

Appendix D.3

Individual QI Certificate

CERTIFICATE OF COMPLETION

John Groenenboom

This document certifies that this individual has passed a comprehensive examination and is now a **Qualified Individual (QI)** as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

SCAQMD Method 207.1

Certificate Number: 002-2017-51

Tate Strickler

Tate Strickler, Accreditation Director

DATE OF ISSUE:

1/17/17

DATE OF
EXPIRATION:

1/17/22



MONTROSE
ENVIRONMENTAL

APPENDIX E APPLICABLE PERMIT SECTIONS



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: POWER GENERATION					
GAS TURBINE, NO. 3, NATURAL GAS, GENERAL ELECTRIC, MODEL LM6000PC SPRINT, SIMPLE CYCLE, 479 MMBTU/HR AT 46 DEG F, WITH INLET CHILLING, WITH WATER INJECTION WITH A/N: 555830	D13	C15	NOX: MAJOR SOURCE**	CO: 4 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]; CO: 2000 PPMV NATURAL GAS (5) [RULE 407, 4-2-1982]; NOX: 2.5 PPMV NATURAL GAS (4) [RULE 2005, 6-3-2011]; NOX: 25 PPMV NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; PM10: 0.01 GRAINS/SCF NATURAL GAS (5A) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; PM10: 0.1 GRAINS/SCF NATURAL GAS (5) [RULE 409, 8-7-1981]; PM10: 1.67 LBS/HR NATURAL GAS (5C) [RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 12-6-2002]; PM10: 11 LBS/HR NATURAL GAS (5B) [RULE 475, 10-8-1976; RULE 475, 8-7-1978]; SO2: (9) [40CFR 72 - Acid Rain Provisions, 11-24-1997]; SOX: 0.06 LBS/MMBTU NATURAL GAS (8) [40CFR 60 Subpart KKKK, 7-6-2006]; VOC: 2 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A63.1, A99.1, A99.2, A99.3, A195.1, A195.2, A195.3, A327.1, B61.1, D12.1, D29.2, D29.3, D82.1, D82.2, E193.1, H23.1, I298.3, K40.1
GENERATOR, 50.95 MW					

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section E and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions* And Requirements	Conditions
Process I: POWER GENERATION					
CO OXIDATION CATALYST, NO. 3, BASF, 110 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 476660	C15	D13 C16			
SELECTIVE CATALYTIC REDUCTION, NO. 3, CORMETECH CMHT-21, 1012 CU.FT.; WIDTH: 2 FT 6 IN; HEIGHT: 25 FT 9 IN; LENGTH: 18 FT WITH A/N: 476660	C16	C15 S18		NH3: 5 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]	A195.6, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
AMMONIA INJECTION					
STACK, TURBINE NO. 3, HEIGHT: 86 FT; DIAMETER: 11 FT 8 IN A/N: 555830	S18	C16			

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits

- (2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements

** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : C4, C10, C16, C22]

- D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[RULE 1110.2, 2-1-2008; RULE 1110.2, 9-7-2012; RULE 1303(b)(2)-Offset, 5-10-1996;
RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 9-10-2010; RULE 1470, 5-4-2012;
RULE 2012, 5-6-2005; 40CFR 60 Subpart IIII, 1-30-2013]

[Devices subject to this condition : D25]

- D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

The test(s) shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter. The AQMD shall be notified of the date and time of the test at least 10 days prior to the test.

If the turbine is not in operation during one calendar year, then no testing is required during that calendar year.

The NO_x concentration, as determined by the CEMS, shall be simultaneously recorded during the ammonia slip test. If the CEMS is inoperable, a test shall be conducted to determine the NO_x emissions using District Method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted and the results submitted to the District within 60 days after the test date.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 12-6-2002]

[Devices subject to this condition : D1, D7, D13, D19]

D29.3 The operator shall conduct source test(s) for the pollutant(s) identified below

Pollutant(s) to be tested	Required Test Method(s)	Sampling Time	Test Location
SOX emissions	AQMD Laboratory Method 307-91	Not Applicable	Fuel sample
VOC emissions	District Method 25.3	1 hour	Outlet of the SCR serving this equipment
PM emissions	District method 5.1	4 hours	Outlet of the SCR serving this equipment

THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. John Groenenboom
Title: Client Project Manager
Region: West
Email: JGroenenboom@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: West
Email: MMccune@montrose-env.com
Phone: (714) 279-6777

TEST REPORT FOR 4Q20 AMMONIA SLIP TEST AT CANYON POWER PLANT UNIT 4 FACILITY ID 153992, DEVICE ID D19

Prepared For:

Canyon Power Plant
3071 E. Mira Loma Avenue.
Anaheim, California 92806

For Submittal To:

South Coast Air Quality Management District
21865 Copley Drive
Diamond Bar, California 91765-4178

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
(714) 279-6777

John Groenenboom

Test Date: **November 4, 2020**
Production Date: **December 11, 2020**
Report Number: **W002AS-004299-RT-1866**




CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.

REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature:  Date: 12/14/2020
Name: John Groenenboom Title: Client Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.


Signature:  Date: 12/14/2020
Name: Marshall Clark Title: Reporting/QC Specialist

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY	5
2.0 UNIT AND CEMS DESCRIPTION	6
2.1 UNIT DESCRIPTION	6
2.2 TEST CONDITIONS.....	7
2.3 SAMPLE LOCATION	7
3.0 TEST DESCRIPTION	8
4.0 RESULTS AND OVERVIEW.....	9
4.1 TEST RESULTS.....	9
4.2 TEST OVERVIEW.....	9

LIST OF APPENDICES

A RAW DATA	10
A.1 Sample Data Sheets	11
A.2 Laboratory Data.....	14
A.3 QA/QC Data	20
B FACILITY CEMS DATA	24
C CALCULATIONS.....	29
C.1 General Emissions Calculations.....	30
C.2 Spreadsheet Summaries	34
D QUALITY ASSURANCE	38
D.1 Quality Assurance Program Summary	39
D.2 SCAQMD and STAC Certifications	45
D.3 Individual QI Certificate	48
E APPLICABLE PERMIT SECTIONS	50

LIST OF TABLES

1-1 AMMONIA SLIP TEST RESULTS	5
4-1 AMMONIA SLIP TEST RESULTS	9

LIST OF FIGURES

2-1 UNIT BLOCK DIAGRAM.....	6
3-1 SCAQMD METHOD 207.1 SAMPLING EQUIPMENT	8

1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) was contracted by the Canyon Power Plant to perform an ammonia slip test at Unit 4 as required by the facility Permit (Facility ID 153992) Condition Number D29.2. This report documents the results of the ammonia slip tests performed on November 4, 2020. The test was performed by John Groenenboom, Daniel Avila, and Nestor Gonzalez. John Groenenboom was the on-site Qualified Individual for MAQS. Ms. Bertha Hernandez coordinated the test for Canyon Power Plant.

The test consisted of duplicate ammonia tests performed at 50 MW. The test program followed the procedures described in the initial compliance test protocol (MAQS document R038842). The results of the test are summarized in Table 1-1. The table shows that the ammonia slip from this unit was less than the permitted limit of 5 ppm corrected to 15% O₂.

**TABLE 1-1
AMMONIA SLIP TEST RESULTS
CANYON POWER PLANT UNIT 4
NOVEMBER 4, 2020**

Parameter	Result ⁽¹⁾	Limit
NH ₃		
ppm	1.1	--
ppmc	1.0	5

(1) Maximum of duplicate runs, as required by SCAQMD Method 207.1


Section 2 of this document provides a brief description of the unit, test conditions, sample location, and CEMS. Details of the test procedures are provided in Section 3. Section 4 provides the results of each individual test. All raw data, calculations, quality assurance data, unit operating conditions, and CEMS data are provided in the appendices.

2.0 UNIT AND CEMS DESCRIPTION

2.1 UNIT DESCRIPTION

The City of Anaheim Canyon Power Plant is located at 3071 E. Mira Loma Avenue, Anaheim, California 92806. The facility consists of four identical generating units. Each unit consists of a natural gas fired, GE Model LM6000PC Sprint simple cycle, gas turbine. The units are natural gas fired with a rated heat input of 479 MMBtu per hour at 46°F, with water injection. The units are equipped with a CO catalyst and Selective Catalytic Reduction (SCR) system for NO_x control. Figure 2-1 presents a block diagram of the unit.

**FIGURE 2-1
UNIT BLOCK DIAGRAM
CANYON POWER PLANT**



Stack Inside Diameter:	11 feet, 8 inches
Distance from Upstream Disturbance:	23 feet, 4 inches (2.0 Diameters)
Distance from Stack Exit:	16 feet, 6 inches (1.4 Diameters)

2.2 TEST CONDITIONS

The tests were performed with the unit operating at an average load of 50 MW. Tests were performed while the unit was firing natural gas and operating under normal conditions. Unit operation was established by the Canyon Power Plant operators.

2.3 SAMPLE LOCATION


The measurements were made from sample ports located on the exhaust stack. There are four sample ports equally spaced at this location. The stack inside diameter at the sample plane is 11 feet, 8 inches. The sample ports are located 23 feet, 4 inches (2.0 diameters) downstream of the nearest flow disturbance and 16 feet, 6 inches (1.4 diameters) from the stack exit.

3.0 TEST DESCRIPTION

Flue gas samples were collected non-isokinetically using a SCAQMD Method 207.1 sample train. The samples were collected using a 12-point traverse at the exhaust stack location. Each test was performed over a 60 minute interval. The sample gas was drawn through a glass probe, Teflon sample line, two impingers each containing 100 ml of 0.1N H₂SO₄, an empty impinger, an impinger containing silica gel, and a dry gas meter. The optional nozzle and filter were not used since the source is natural gas fired. The contents of the sample line and the first three impingers were recovered and analyzed by SCAQMD Method 207.1 for ammonia concentration by Ion Specific Electrode analysis. Figure 3-1 presents a diagram of the sampling equipment.

Stack O₂ and NO_x concentrations and stack volumetric flow rate data were recorded from the Continuous Emission Monitoring System (CEMS) which is installed on the unit. These data were used to correct the ammonia concentration to 15% O₂.

FIGURE 3-1
SCAQMD METHOD 207.1 SAMPLING EQUIPMENT



4.0 RESULTS AND OVERVIEW

4.1 TEST RESULTS

The results of the test are summarized in Table 4-1. The results show that the maximum ammonia slip was 1.0 ppm @ 15% O₂ which is less than the permitted limit of 5 ppm @ 15% O₂.

**TABLE 4-1
AMMONIA SLIP TEST RESULTS
CANYON POWER PLANT UNIT 4
NOVEMBER 4, 2020**

Parameter/Units	Run 1	Run 2	Average	Maximum ⁽¹⁾	Limit
Test	1-NH ₃ -U4	2-NH ₃ -U4			--
Date	11/4/2020	11/4/2020			--
Time	1622/1728	1801/1907			--
O₂, %⁽²⁾	14.43	14.45	14.44	--	--
Stack Flow , dscfm @ T _{ref} ⁽²⁾	232,720	233,803	233,261	--	--
NO_x , ppmc ⁽²⁾	2.1	2.2	2.2	--	2.5
NH₃					
ppm	1.1	1.1	1.1	1.1	--
ppmc	1.0	1.0	1.0	1.0	5
lb/hr	0.7	0.7	0.7	0.7	--
lb/MMBtu	0.001	0.001	0.001	0.001	--
lb/MMSCF	1.5	1.5	1.5	1.5	--

(1) Maximum of duplicate test runs, as required by SCAQMD Method 207.1

(2) From facility CEMS

4.2 TEST OVERVIEW

The test program was successful in meeting the program objectives. The QA/QC requirements of SCAQMD Method 207.1 were met. The results are considered representative of the source at the time of the tests.

APPENDIX A RAW DATA

Appendix A.1

Sample Data Sheets



13 of 54

Imp. # Contents Post-Test - Pre-Test = Difference

1	H ₂ SO ₄	936.8	720.0
2	H ₂ SO ₄	706.7	704.7
3	mt	592.1	590.8
4	SG	932.1	921.9
LR		0	100
Total:			

Average:

Comments:

Appendix A.2 Laboratory Data

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS

Project #: PROJ-004299 District Method: SCAQMD 207.1 Sample Date: 11/14/2020
 Client/Location: SCPPA Calibration Date: 11/9/2020 Analysis Date: 11/9/2020
 Sample Location: Unit 14 Calibration Curve: $y = -56.7829x + 91.1329$ Analyst's Initials: W
 Test #'s: 1-2-1011 R²: 0.9998 Room Temperature (°C): 18.0

Sample	Total Vol. (mL)	Electrode Potential (mV)	Conc. $\mu\text{g NH}_3 - \text{N / ml}$	Cavg ($\mu\text{g NH}_3 - \text{N / ml}$)	$\mu\text{g NH}_3 / \text{sample}$	T (°C)	Blue after + ISA (Y/N)	pH	% R
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	9.1	28.505	28.564	—	18.0	Y	—	2.013
		9.0	28.622			18.0	Y		
1-NH ₃	541.3	82.0	1.452	1.437	945.764	18.0	Y	22	—
		82.5	1.423			18.0	Y		
2-NH ₃	570.2	82.5	1.423	1.429	990.131	18.0	Y	22	—
		82.3	1.434			18.0	Y		
Spike: <u>1000</u> +2ml 1000ppm NH ₃	—	17.7	20.063	20.063	—	18.0	Y	—	97.00
		17.7	20.063			18.0	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	8.5	29.212	29.212	—	18.0	Y	—	4.330
		8.5	29.212			18.0	Y		
Reagent Blank 0.1N H ₂ SO ₄	—	173.3	0.035	0.035	—	18.0	Y	—	—
		173.8	0.034			18.0	Y		
DI H ₂ O Blank	—	188.4	0.019	0.019	—	18.0	Y	—	—
		188.8	0.014			18.0	Y		
Field Blank	433.7	167.0	0.045	0.045	23550	18.0	Y	22	—
		167.5	0.044			18.0	Y		
Standard Check: 28 $\mu\text{g NH}_3/\text{ml}$	—	8.3	29.452	29.512	—	18.0	Y	—	5.401
		8.2	29.572			18.0	Y		

Notes:

 Total volume of samples and standards used: 100 ml

 Volume of pH adjusting ISA used in ml: 2-1

 Absorbing solution: 0.1N H₂SO₄
Calculations:

 Conc. ($\mu\text{g NH}_3 - \text{N / ml}$) = $10^{(P-B)/M}$; (P = electrode potential, B = y-intercept and M = slope)


 Cavg = average result of duplicate analyses ($\mu\text{g NH}_3 - \text{N / ml}$) = $(C1+C2)/2$
 $\mu\text{g NH}_3 / \text{sample} = \text{Cavg} \times 17.03 / 14.01 \times \text{TV}$

 mg / sample = $\mu\text{g} / \text{sample} \div 1000$

 ppm NH₃ = $\text{mg NH}_3 / \text{sample} \times 1 / \text{Vstd} \times 1 / 454000 \times \text{SV} / 17 \times 10^6$

AMMONIA ELECTRODE CALIBRATION CURVE

NH ₃ concentration (µg NH ₃ / ml as N)	log NH ₃ concentration	Electrode potential (mV)	Sample Temperature (C)	Room Temperature (C)
1	0.000	90.7	18	18
5	0.699	52.0	18	18
20	1.301	18.5	18	18
100	2.000	-22.2	18	18



slope -56.3829
y-intercept 91.1329

Concentration (µg NH ₃ / ml as N)	Value LR line	Difference	% Difference
1	1.0178	0.0178	1.7836
5	4.9437	-0.0563	-1.1251
20	19.4182	-0.5818	-2.9092
100	102.3430	2.3430	2.3430

Calculation:

Regression Line: $P = M \cdot \log(\mu\text{g of NH}_3 / \text{ml as N}) + B$

Measured Concentration of Ammonia (C) in µg / ml NH₃ as N: $C = 10^{(P-B)/M}$

where P = electrode potential, M = slope (must be -57 ± 3) and B = intercept

All standards were prepared in 0.04N H₂SO₄ and allowed to equilibrate to room temperature.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALCULATION

Project Number: PROJ_004299
 Client/ Location: SCPPA
 Sample Location: U4
 District Method: SCAQMD 207.1
 Sample Date: 11/4/2020
 Analysis Date: 11/9/2020
 Analyst's Initials: LM
 Calibration Curve Slope -56.3829
 Y-intercept 91.1329
 R² 0.9998

Sample	P mV	Conc. µg NH ₃ /ml as N	C avg as N	TV (ml)	C avg as NH ₃	µg NH ₃ / sample
28 ug NH ₃ / ml as N	9.1	28.505				
Repeat 28 ug NH ₃ /ml as N	9	28.622	28.564	NA	34.721	NA
1-NH ₃	82.0	1.452				
Repeat 1- NH ₃	82.5	1.423	1.437	541.3	1.747	945.764
2-NH ₃	82.5	1.423				
Repeat 2- NH ₃	82.3	1.434	1.429	570.2	1.736	990.131
spike 1-NH ₃	17.7	20.063				
Repeat 1-NH ₃ spike	17.7	20.063	20.063	NA	24.388	NA
28 NH ₃ /ml as N	8.5	29.212				
Repeat 28 ug NH ₃ /ml as N	8.5	29.212	29.212	NA	35.509	NA
Reagent Blank	173.3	0.035				
Repeat Reagent Blank	173.8	0.034	0.035	NA	0.042	NA
Field Blank	167.0	0.045				
Repeat Field Blank	167.5	0.044	0.045	433.7	0.054	23.550
DI H ₂ O Blank	188.8	0.019				
Repeat DI H ₂ O Blank	188.8	0.019	0.019	NA	0.023	NA
28 NH ₃ /ml as N	8.3	29.452				
Repeat 28 ug NH ₃ /ml as N	8.2	29.572	29.512	NA	35.874	NA

Notes:

Measured Concentration of Ammonia (C) in µg NH₃ / ml as N

$$C=10^{(P-B)/M}$$

P = electrode potential (mV), M=slope and B=intercept

Average Measured Ammonia Concentration (Cavg) = (C1 + C2)/2

where C1, C2 results from duplicate analyses (µg NH₃/ml as N)

$$Cavg (\mu g NH_3/ml as NH_3) = Cavg (\mu g NH_3/ ml as N) * 17.03/ 14.01$$

$$\mu g NH_3 / sample = Cavg (\mu g NH_3/ml as NH_3) * TV$$

Used 100 ml of samples and standards with 2 ml ISA and constant stirring rate.

All solutions turned blue and remained blue with ISA unless otherwise indicated.

Sample PH and Temperatures can be found on the laboratory datasheet.

Maximum samples (including blanks) between 28 ug/ml check standard is 5 samples analyzed in duplicate.

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS QUALITY CONTROL

Project Number: PROJ_004299
 Client/ Location: SCPPA
 Sample Location: U4
 District Method: SCAQMD 207.1
 Sample Date: 11/4/2020
 Analysis Date: 11/9/2020
 Analyst's Initials: LM

Sample	% recovery	RPD %	RPA %
28 ug NH3 / ml as N Repeat 28 ug NH3/ml as	NA	-0.41	2.013
1-NH3 Repeat 1- NH3	NA	2.04	NA
2-NH3 Repeat 2- NH3	NA	-0.82	NA
spike 1-NH3 Repeat 1-NH3 spike	97.00	0.00	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as	NA	0.00	4.330
Reagent Blank Repeat Reagent Blank	NA	2.04	NA
Field Blank Repeat Field Blank	NA	2.04	NA
DI H2O Blank Repeat DI H2O Blank	NA	0.00	NA
28 NH3/ml as N Repeat 28 ug NH3/ml as	NA	-0.41	5.401

Notes:

spike: 100 ml sample + 2 ml (1000 µg NH₃ / ml as N)

Matrix Spike Percent Recovery (%R)

%R = (C spike*0.104 - Csample*0.102)/2 *100

Cspike = average result of matrix spike (µg NH₃/ ml as N)

Relative Percent Difference (RPD) = (C1-C2)/ Cavg *100 (must be 5% or less)

Relative Percent Accuracy (RPA) (must be 10% or less)

RPA = (Cavg-theoretical value of standard)/ theoretical value of standard * 100

AMMONIA BY ION SELECTIVE ELECTRODE ANALYSIS CALIBRATION DATA

District Method: SCAQMD 207.1

Calibration Date: 11/09/2020

Calibration Curve: $y = -56.3829x + 91.1329$

R² 0.9998

Analyst's Initials: CM

Thermometer #: NA

ISE Electrode #: 14

Calibration Standard (µg NH ₃ / ml as N)	Electrode Potential (mV)	Solution Temperature (°C)	Room Temperature (°C)
1	90.7	18.0	18.0
5	52.0	18.0	18.0
20	18.5	18.0	18.0
100	-22.2	18.0	18.0

Notes:

Total volume of samples and standards used: 100 ml

Volume of pH adjusting ISA used in ml: 2 ml

Absorbing solution: 0.046 M SA

Slope of the calibration curve shall be between -54 to -60

R² must be 0.9997 or greater

Calibration solutions, sample solutions and Calibration Verification standard temperature within ± 2°C

Appendix A.3

QA/QC Data

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Orifice Method - Triplicate Runs/Four Calibration Points

English Meter Box Units, English K' Factor

Filename: M:\Santa Ana\Equipment\Test Equipment\Calibrations\Dry Gas Meters\10-P&M\2020\Semi-Annual Meter Calibration -10-P&M 7-17-2020

File Modified From: APEX 522 Series Meter box Calibration

Revised: 4/9/2005

Model #:

ID #: 10 P&M

Date: 7/17/2020

Bar Pressure: 30.00 (in. Hg)

Performed By: R. Howard

Meter Serial #: 13464167

DRY GAS METER READINGS									CRITICAL ORIFICE READINGS			Ambient Temperature		
dH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Initial (deg F)	Final (deg F)	Average (deg F)
0.13	26.00	696.000	701.203	5.203	Inlet	Outlet	Inlet	Outlet	33	0.1551	18.0	75.0	75.0	75.0
0.13	26.00	701.203	706.405	5.202	76.0	76.0	76.0	76.0	33	0.1551	18.0	75.0	75.0	75.0
0.13	26.00	706.405	711.610	5.205	76.0	76.0	76.0	76.0	33	0.1551	18.0	75.0	75.0	75.0
0.60	12.00	712.500	717.687	5.187	77.0	77.0	79.0	77.0	48	0.3345	16.0	75.0	75.0	75.0
0.60	12.00	717.687	722.872	5.185	79.0	77.0	79.0	78.0	48	0.3345	16.0	75.0	75.0	75.0
0.60	12.00	722.872	728.061	5.189	79.0	76.0	79.0	76.0	48	0.3345	16.0	75.0	75.0	75.0
1.70	7.00	729.000	734.573	5.573	82.0	78.0	85.0	79.0	63	0.5915	14.0	76.0	76.0	76.0
1.70	7.00	734.573	740.147	5.574	85.0	79.0	86.0	81.0	63	0.5915	14.0	76.0	76.0	76.0
1.70	7.00	740.147	745.719	5.571	86.0	81.0	86.0	81.0	63	0.5915	14.0	76.0	76.0	76.0
3.00	5.00	747.200	752.413	5.213	87.0	85.0	91.0	87.0	73	0.7678	13.0	76.0	76.0	76.0
3.00	5.00	752.413	757.629	5.216	91.0	87.0	92.0	89.0	73	0.7678	13.0	76.0	76.0	76.0
3.00	5.00	757.629	762.838	5.209	92.0	89.0	93.0	90.0	73	0.7678	13.0	76.0	76.0	76.0

DRY GAS METER		ORIFICE		DRY GAS METER CALIBRATION FACTOR		ORIFICE CALIBRATION FACTOR		Individual Run	Individual Orifice	Orifice Average	Orifice Average
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	Y Value (number)	dH@ Value (in H ₂ O)		0.95 < Y < 1.05?	Ymax - Ymin < 0.010?	0.98 < Y/Yd < 1.02?	dH@ - dH@ av < 0.15?
5.139	145.5	5.230	148.1	5.288	1.018	1.785		Pass			
5.138	145.5	5.230	148.1	5.288	1.018	1.785		Pass			
5.141	145.6	5.230	148.1	5.288	1.017	1.785		Pass			
Average					1.018	1.785			Pass	Pass	Pass
5.114	144.8	5.206	147.4	5.263	1.018	1.768		Pass			
5.105	144.6	5.206	147.4	5.263	1.020	1.766		Pass			
5.109	144.7	5.206	147.4	5.263	1.019	1.765		Pass			
Average					1.019	1.766			Pass	Pass	Pass
5.474	155.0	5.366	152.0	5.435	0.980	1.600		Pass			
5.467	154.6	5.366	152.0	5.435	0.983	1.596		Pass			
5.447	154.3	5.366	152.0	5.435	0.985	1.593		Pass			
Average					0.983	1.596			Pass	Pass	Pass
5.076	143.7	4.975	140.9	5.039	0.980	1.653		Pass			
5.058	143.2	4.975	140.9	5.039	0.984	1.647		Pass			
5.040	142.7	4.975	140.9	5.039	0.987	1.642		Pass			
Average					0.984	1.647			Pass	Pass	Pass

Average Yd: 1.001 dH@: 1.699

Q @ dH = 1: 0.575

SIGNED: Signature on File

Date: 7/17/2020

CHAIN OF CUSTODY

CLIENT: SCPPAPROJECT #: PROJ_004299TEST DATE(S): 11/4/2020LOCATION: U4SAMPLER(S): DA, NGSAMPLE LOCATION: StackPROJECT MANAGER: JGTEST METHOD(S): SCAQMD 207.1DATE DUE: 11/11/2020OUTSIDE LAB REQUIRED?: NoCOMPLIANCE TEST?: Yes

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
11/4/2020	1622/1728	1-NH3-U4	Probe, Line, Impingers	1	DA, NG	
11/4/2020	1801/1907	2-NH3-U4	Probe, Line, Impingers	1	DA, NG	
11/4/2020		Reagent Blank	0.1 N H ₂ SO ₄	1	JG	
11/4/2020		Reagent Blank	DI H ₂ O	1	JG	
11/4/2020		Field Blank	Probe, Line, Impingers	1	DA, NG	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
<i>Nestor Gonzalez</i>	<i>11-5-20 / 19:40</i>		

ANALYSIS REQUIRED: NH₃ by SCAQMD 207.1 (ISE)

Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

23 of 54

Imp. #	Contents	Post-Test	Pre-Test	Difference
1	H ₂ SO ₄	835.9	794.2	41.7
2	H ₂ SO ₄	735.4	735.4	0
3	NT	607.1	607.0	0.1
4	SG	927.7	927.7	0
LR		100		
Total:				

Comments: _____

APPENDIX B FACILITY CEMS DATA

Average Values Report
Generated: 11/4/2020 21:05Company: City Of Anaheim
Plant: 3071 Miraloma Ave.
City/St: Anaheim, CA, 92806
Source: 4Period Start: 11/4/2020 16:22
Period End: 11/4/2020 17:27
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 4_O2 %	Average 4_NOXPPM ppm	Average 4_NOX_CORR ppm	Average 4_NOX_LBMM #/MBTU	Average 4_NOX_LBHR #/hr	Average 4_COPPM ppm	Average 4_CO_CORR ppm	Average 4_CO_LBHR #/hr	Average 4_CO_LBMM #/MBTU	Average 4_GasFlow kscfh	Average 4_LOAD MW	Average 4_STACKFLW kscfm
11/04/2020 16:22	14.42	2.39	2.18	0.008	4.04	3.59	3.27	3.69	0.0073	480.9	50.09	236.4
11/04/2020 16:23	14.42	2.40	2.19	0.008	4.04	3.59	3.27	3.68	0.0073	480.7	50.10	236.3
11/04/2020 16:24	14.42	2.40	2.19	0.008	4.04	3.59	3.27	3.68	0.0073	480.6	50.06	236.3
11/04/2020 16:25	14.42	2.39	2.18	0.008	4.04	3.59	3.27	3.69	0.0073	480.8	50.01	236.4
11/04/2020 16:26	14.42	2.39	2.18	0.008	4.04	3.61	3.29	3.73	0.0074	480.5	50.20	236.2
11/04/2020 16:27	14.42	2.39	2.18	0.008	4.04	3.64	3.31	3.73	0.0074	480.5	50.04	236.2
11/04/2020 16:28	14.42	2.39	2.18	0.008	4.04	3.65	3.32	3.78	0.0075	480.6	49.99	236.3
11/04/2020 16:29	14.42	2.38	2.17	0.008	4.04	3.65	3.32	3.78	0.0075	480.5	49.97	236.2
11/04/2020 16:30	14.42	2.36	2.15	0.008	4.04	3.65	3.32	3.78	0.0075	480.5	49.95	236.2
11/04/2020 16:31	14.42	2.35	2.14	0.008	4.04	3.65	3.32	3.78	0.0075	480.5	50.04	236.2
11/04/2020 16:32	14.42	2.35	2.14	0.008	4.04	3.65	3.32	3.78	0.0075	480.4	49.99	236.2
11/04/2020 16:33	14.42	2.34	2.13	0.008	4.04	3.66	3.33	3.78	0.0075	480.4	50.19	236.2
11/04/2020 16:34	14.42	2.33	2.12	0.008	4.04	3.68	3.35	3.78	0.0075	480.4	50.02	236.2
11/04/2020 16:35	14.42	2.33	2.12	0.008	4.04	3.69	3.36	3.78	0.0075	480.6	49.92	236.3
11/04/2020 16:36	14.42	2.34	2.13	0.008	4.04	3.69	3.36	3.78	0.0075	480.5	49.96	236.2
11/04/2020 16:37	14.42	2.34	2.13	0.008	4.03	3.69	3.36	3.78	0.0075	480.2	49.97	236.1
11/04/2020 16:38	14.42	2.33	2.12	0.008	4.03	3.69	3.36	3.78	0.0075	480.3	50.13	236.1
11/04/2020 16:39	14.42	2.31	2.10	0.008	4.03	3.70	3.37	3.83	0.0076	480.2	50.10	236.1
11/04/2020 16:40	14.42	2.31	2.10	0.008	4.03	3.70	3.37	3.83	0.0076	480.3	49.94	236.1
11/04/2020 16:41	14.42	2.32	2.11	0.008	4.03	3.69	3.36	3.78	0.0075	480.2	49.96	236.1
11/04/2020 16:42	14.42	2.32	2.11	0.008	4.03	3.68	3.35	3.78	0.0075	480.1	49.94	236.0
11/04/2020 16:43	14.42	2.32	2.11	0.008	4.03	3.69	3.36	3.78	0.0075	480.2	50.02	236.1
11/04/2020 16:44	14.42	2.32	2.11	0.008	4.04	3.69	3.36	3.78	0.0075	480.4	49.98	236.2
11/04/2020 16:45	14.42	2.31	2.10	0.008	4.03	3.71	3.38	3.83	0.0076	480.3	49.88	236.1
11/04/2020 16:46	14.43	2.31	2.11	0.008	4.03	3.72	3.39	3.83	0.0076	480.2	50.06	236.4
11/04/2020 16:47	14.42	2.30	2.09	0.008	4.03	3.74	3.41	3.83	0.0076	480.0	49.92	236.0
11/04/2020 16:48	14.43	2.28	2.08	0.008	4.03	3.73	3.40	3.83	0.0076	480.1	50.07	236.4
11/04/2020 16:49	14.43	2.28	2.08	0.008	4.03	3.72	3.39	3.83	0.0076	480.1	49.89	236.4
11/04/2020 16:50	14.43	2.28	2.08	0.008	4.03	3.72	3.39	3.83	0.0076	480.0	50.02	236.3
11/04/2020 16:51	14.44	2.27	2.07	0.008	4.03	3.73	3.41	3.83	0.0076	480.0	49.94	236.7
11/04/2020 16:52	14.44	2.26	2.06	0.008	4.03	3.75	3.42	3.88	0.0077	479.9	50.27	236.7
11/04/2020 16:53	14.44	2.24	2.05	0.008	4.03	3.80	3.47	3.93	0.0078	479.8	49.89	236.6
11/04/2020 16:54	14.44	2.21	2.02	0.007	3.53	3.84	3.51	3.98	0.0079	479.8	50.01	236.6
11/04/2020 16:55	14.44	2.24	2.05	0.008	4.03	3.80	3.47	3.93	0.0078	479.9	49.93	236.7
11/04/2020 16:56	14.44	2.30	2.10	0.008	4.03	3.72	3.40	3.83	0.0076	479.9	50.08	236.7
11/04/2020 16:57	14.43	2.34	2.13	0.008	4.03	3.64	3.32	3.73	0.0074	479.9	50.05	236.3
11/04/2020 16:58	14.42	2.35	2.14	0.008	4.03	3.61	3.29	3.73	0.0074	479.8	49.94	235.9
11/04/2020 16:59	14.42	2.36	2.15	0.008	4.03	3.58	3.26	3.68	0.0073	479.8	49.92	235.9
11/04/2020 17:00	14.42	2.37	2.16	0.008	4.03	3.58	3.26	3.68	0.0073	479.8	50.25	235.9
11/04/2020 17:01	14.42	2.38	2.17	0.008	4.03	3.60	3.28	3.73	0.0074	480.0	49.96	236.0
11/04/2020 17:02	14.42	2.38	2.17	0.008	4.03	3.60	3.28	3.73	0.0074	479.8	49.97	235.9
11/04/2020 17:03	14.42	2.36	2.15	0.008	4.03	3.60	3.28	3.73	0.0074	479.9	49.88	235.9
11/04/2020 17:04	14.44	2.35	2.15	0.008	4.03	3.59	3.28	3.73	0.0074	479.8	50.15	236.6
11/04/2020 17:05	14.43	2.34	2.13	0.008	4.03	3.59	3.27	3.68	0.0073	479.8	49.96	236.2
11/04/2020 17:06	14.44	2.34	2.14	0.008	4.03	3.58	3.27	3.68	0.0073	479.8	49.93	236.6
11/04/2020 17:07	14.43	2.35	2.14	0.008	4.03	3.58	3.26	3.68	0.0073	479.7	49.96	236.2
11/04/2020 17:08	14.44	2.35	2.15	0.008	4.03	3.59	3.28	3.73	0.0074	479.7	50.24	236.6
11/04/2020 17:09	14.44	2.36	2.16	0.008	4.03	3.59	3.28	3.73	0.0074	479.8	49.93	236.6
11/04/2020 17:10	14.44	2.36	2.16	0.008	4.03	3.60	3.29	3.72	0.0074	479.2	49.98	236.3
11/04/2020 17:11	14.44	2.33	2.13	0.008	4.03	3.63	3.32	3.73	0.0074	479.6	50.05	236.5
11/04/2020 17:12	14.44	2.30	2.10	0.008	4.03	3.64	3.32	3.78	0.0075	479.6	49.92	236.5
11/04/2020 17:13	14.44	2.31	2.11	0.008	4.03	3.62	3.31	3.73	0.0074	479.6	49.92	236.5

Period Start:	Average 4_O2 %	Average 4_NOXPPM ppm	Average 4_NOX_CORR ppm	Average 4_NOX_LBMM #/MBTU	Average 4_NOX_LBHR #/hr	Average 4_COPPM ppm	Average 4_CO_CORR ppm	Average 4_CO_LBHR #/hr	Average 4_CO_LBMM #/MBTU	Average 4_GasFlow kscfh	Average 4_LOAD MW	Average 4_STACKFLW kscfm
11/04/2020 17:14	14.44	2.33	2.13	0.008	4.03	3.60	3.29	3.73	0.0074	479.6	49.98	236.5
11/04/2020 17:15	14.44	2.34	2.14	0.008	4.03	3.59	3.28	3.73	0.0074	479.7	49.92	236.6
11/04/2020 17:16	14.44	2.33	2.13	0.008	4.03	3.58	3.27	3.67	0.0073	479.3	49.98	236.4
11/04/2020 17:17	14.44	2.33	2.13	0.008	4.03	3.60	3.29	3.72	0.0074	479.3	49.96	236.4
11/04/2020 17:18	14.44	2.32	2.12	0.008	4.03	3.62	3.31	3.73	0.0074	479.4	49.91	236.4
11/04/2020 17:19	14.44	2.31	2.11	0.008	4.03	3.63	3.32	3.72	0.0074	479.2	49.93	236.3
11/04/2020 17:20	14.44	2.30	2.10	0.008	4.02	3.64	3.32	3.77	0.0075	478.9	49.84	236.1
11/04/2020 17:21	14.45	2.30	2.10	0.008	4.02	3.64	3.33	3.77	0.0075	478.8	49.86	236.5
11/04/2020 17:22	14.45	2.35	2.15	0.008	4.02	3.55	3.25	3.67	0.0073	479.1	49.98	236.7
11/04/2020 17:23	14.45	2.46	2.25	0.008	4.02	3.44	3.15	3.57	0.0071	478.9	49.95	236.5
11/04/2020 17:24	14.45	2.49	2.28	0.008	4.03	3.39	3.10	3.52	0.0070	479.4	49.95	236.8
11/04/2020 17:25	14.45	2.50	2.29	0.008	4.03	3.39	3.10	3.52	0.0070	479.3	49.99	236.7
11/04/2020 17:26	14.45	2.47	2.26	0.008	4.03	3.43	3.14	3.52	0.0070	479.2	49.92	236.7
11/04/2020 17:27	14.45	2.38	2.18	0.008	4.02	3.54	3.24	3.67	0.0073	479.0	49.92	236.6
Daily Average*	14.43	2.34	2.14	0.008	4.02	3.64	3.32	3.75	0.0074	479.9	49.99	236.3
Maximum*	14.45	2.50	2.29	0.008	4.04	3.84	3.51	3.98	0.0079	480.9	50.27	236.8
11/04/2020 17:27	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020
Minimum*	14.42	2.21	2.02	0.007	3.53	3.39	3.10	3.52	0.0070	478.8	49.84	235.9
11/04/2020 17:03	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020	11/04/2020
	17:03	16:54	16:54	16:54	16:54	17:25	17:25	17:26	17:26	17:21	17:20	17:03

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 11/4/2020 19:12Company: City Of Anaheim
Plant: 3071 Miraloma Ave.,
City/St: Anaheim, CA, 92806
Source: 4Period Start: 11/4/2020 18:01
Period End: 11/4/2020 19:06
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average 4_O2 %	Average 4_NOXPPM ppm	Average 4_NOX_CORR ppm	Average 4_NOX_LBMM #/MBTU	Average 4_NOX_LBHR #/hr	Average 4_CO2PPM ppm	Average 4_CO2_CORR ppm	Average 4_CO2_LBHR #/hr	Average 4_CO2_LBMM #/MBTU	Average 4_GasFlow kscfh	Average 4_LOAD MW	Average 4_STACKFLW kscfm
11/04/2020 18:01	14.45	2.63	2.41	0.009	4.54	3.28	3.00	3.38	0.0067	479.9	50.08	237.0
11/04/2020 18:02	14.43	2.61	2.38	0.009	4.54	3.32	3.03	3.43	0.0068	480.9	50.09	236.8
11/04/2020 18:03	14.43	2.49	2.27	0.008	4.03	3.46	3.16	3.58	0.0071	480.1	50.12	236.4
11/04/2020 18:04	14.44	2.28	2.08	0.008	4.03	3.70	3.38	3.83	0.0076	479.8	50.18	236.6
11/04/2020 18:05	14.44	2.22	2.03	0.007	3.53	3.81	3.48	3.93	0.0078	480.0	50.26	236.7
11/04/2020 18:06	14.44	2.30	2.10	0.008	4.03	3.70	3.38	3.83	0.0076	480.2	50.08	236.8
11/04/2020 18:07	14.47	2.48	2.28	0.008	4.03	3.50	3.21	3.63	0.0072	480.1	49.98	237.9
11/04/2020 18:08	14.44	2.59	2.37	0.009	4.54	3.36	3.07	3.48	0.0069	480.4	50.13	236.9
11/04/2020 18:09	14.44	2.53	2.31	0.009	4.54	3.40	3.11	3.53	0.0070	480.2	50.06	236.8
11/04/2020 18:10	14.44	2.36	2.16	0.008	4.04	3.62	3.31	3.73	0.0074	480.4	50.23	236.9
11/04/2020 18:11	14.44	2.17	1.98	0.007	3.53	3.87	3.53	3.98	0.0079	480.3	50.23	236.8
11/04/2020 18:12	14.44	2.17	1.98	0.007	3.53	3.92	3.58	4.03	0.0080	480.3	50.32	236.8
11/04/2020 18:13	14.44	2.30	2.10	0.008	4.04	3.77	3.44	3.88	0.0077	480.4	50.18	236.9
11/04/2020 18:14	14.44	2.39	2.18	0.008	4.03	3.62	3.31	3.73	0.0074	480.1	50.03	236.8
11/04/2020 18:15	14.44	2.47	2.26	0.008	4.04	3.50	3.20	3.63	0.0072	480.8	50.23	237.1
11/04/2020 18:16	14.44	2.49	2.27	0.008	4.04	3.46	3.16	3.58	0.0071	480.9	50.28	237.1
11/04/2020 18:17	14.44	2.52	2.30	0.008	4.04	3.44	3.14	3.53	0.0070	480.8	50.12	237.1
11/04/2020 18:18	14.44	2.58	2.36	0.009	4.54	3.40	3.11	3.53	0.0070	480.7	50.28	237.0
11/04/2020 18:19	14.44	2.59	2.37	0.009	4.53	3.41	3.11	3.53	0.0070	479.6	50.12	236.5
11/04/2020 18:20	14.44	2.46	2.25	0.008	4.04	3.55	3.24	3.69	0.0073	480.9	50.14	237.1
11/04/2020 18:21	14.44	2.33	2.13	0.008	4.05	3.68	3.36	3.79	0.0075	481.8	50.09	237.6
11/04/2020 18:22	14.46	2.29	2.10	0.008	4.02	3.72	3.41	3.82	0.0076	479.0	50.06	237.0
11/04/2020 18:23	14.45	2.35	2.15	0.008	4.04	3.66	3.35	3.79	0.0075	480.7	50.18	237.4
11/04/2020 18:24	14.44	2.34	2.14	0.008	4.04	3.66	3.34	3.78	0.0075	480.5	50.11	236.9
11/04/2020 18:25	14.44	2.29	2.09	0.008	4.04	3.72	3.40	3.84	0.0076	480.7	50.08	237.0
11/04/2020 18:26	14.44	2.32	2.12	0.008	4.04	3.73	3.41	3.83	0.0076	480.6	50.22	237.0
11/04/2020 18:27	14.44	2.33	2.13	0.008	4.04	3.73	3.41	3.84	0.0076	480.8	50.12	237.1
11/04/2020 18:28	14.44	2.34	2.14	0.008	4.04	3.73	3.41	3.84	0.0076	480.7	50.12	237.0
11/04/2020 18:29	14.44	2.33	2.13	0.008	4.04	3.73	3.41	3.83	0.0076	480.6	50.08	237.0
11/04/2020 18:30	14.45	2.32	2.12	0.008	4.04	3.75	3.43	3.89	0.0077	480.7	50.11	237.4
11/04/2020 18:31	14.45	2.33	2.13	0.008	4.04	3.77	3.45	3.88	0.0077	480.5	50.12	237.3
11/04/2020 18:32	14.45	2.33	2.13	0.008	4.04	3.78	3.46	3.94	0.0078	480.8	50.46	237.5
11/04/2020 18:33	14.45	2.32	2.12	0.008	4.04	3.78	3.46	3.94	0.0078	480.6	50.22	237.4
11/04/2020 18:34	14.45	2.32	2.12	0.008	4.04	3.78	3.46	3.94	0.0078	480.7	49.94	237.4
11/04/2020 18:35	14.45	2.31	2.11	0.008	4.04	3.78	3.46	3.94	0.0078	481.2	50.26	237.7
11/04/2020 18:36	14.45	2.31	2.11	0.008	4.04	3.79	3.47	3.94	0.0078	480.7	50.18	237.4
11/04/2020 18:37	14.46	2.32	2.13	0.008	4.04	3.80	3.48	3.94	0.0078	480.6	50.17	237.7
11/04/2020 18:38	14.46	2.34	2.14	0.008	4.04	3.80	3.48	3.94	0.0078	480.6	50.17	237.7
11/04/2020 18:39	14.46	2.35	2.15	0.008	4.04	3.80	3.48	3.94	0.0078	480.7	50.13	237.8
11/04/2020 18:40	14.46	2.34	2.14	0.008	4.04	3.81	3.49	3.93	0.0078	480.4	50.04	237.6
11/04/2020 18:41	14.46	2.33	2.13	0.008	4.04	3.83	3.51	3.99	0.0079	481.0	50.12	238.0
11/04/2020 18:42	14.45	2.34	2.14	0.008	4.04	3.84	3.51	3.99	0.0079	481.0	50.08	237.6
11/04/2020 18:43	14.46	2.35	2.15	0.008	4.04	3.83	3.51	3.99	0.0079	480.9	50.17	237.9
11/04/2020 18:44	14.46	2.35	2.15	0.008	4.04	3.82	3.50	3.99	0.0079	480.6	50.06	237.7
11/04/2020 18:45	14.46	2.35	2.15	0.008	4.04	3.83	3.51	3.99	0.0079	480.5	50.10	237.7
11/04/2020 18:46	14.46	2.34	2.14	0.008	4.04	3.85	3.53	3.99	0.0079	480.7	50.18	237.8
11/04/2020 18:47	14.46	2.34	2.14	0.008	4.04	3.84	3.52	3.99	0.0079	480.5	50.27	237.7
11/04/2020 18:48	14.46	2.37	2.17	0.008	4.04	3.80	3.48	3.94	0.0078	480.7	50.25	237.8
11/04/2020 18:49	14.46	2.39	2.19	0.008	4.04	3.75	3.44	3.89	0.0077	480.7	50.14	237.8
11/04/2020 18:50	14.46	2.39	2.19	0.008	4.04	3.74	3.43	3.89	0.0077	480.7	50.42	237.8
11/04/2020 18:51	14.46	2.40	2.20	0.008	4.04	3.76	3.44	3.89	0.0077	480.7	50.14	237.8
11/04/2020 18:52	14.45	2.40	2.20	0.008	4.04	3.76	3.44	3.88	0.0077	480.4	50.23	237.3

Period Start:	Average 4_O2 %	Average 4_NOXPPM ppm	Average 4_NOX_CORR ppm	Average 4_NOX_LBMM #/MBTU	Average 4_NOX_LBHR #/hr	Average 4_COPPM ppm	Average 4_CO_CORR ppm	Average 4_CO_LBHR #/hr	Average 4_CO_LBMM #/MBTU	Average 4_GasFlow kscfh	Average 4_LOAD MW	Average 4_STACKFLW kscfm
11/04/2020 18:53	14.47	2.41	2.21	0.008	4.04	3.75	3.44	3.89	0.0077	480.7	50.09	238.1
11/04/2020 18:54	14.45	2.41	2.20	0.008	4.04	3.75	3.43	3.89	0.0077	480.7	50.27	237.4
11/04/2020 18:55	14.46	2.41	2.21	0.008	4.04	3.74	3.43	3.89	0.0077	480.7	49.99	237.8
11/04/2020 18:56	14.46	2.40	2.20	0.008	4.04	3.74	3.43	3.88	0.0077	480.5	50.08	237.7
11/04/2020 18:57	14.46	2.40	2.20	0.008	4.04	3.74	3.43	3.89	0.0077	480.7	50.07	237.8
11/04/2020 18:58	14.46	2.40	2.20	0.008	4.04	3.73	3.42	3.88	0.0077	480.4	50.16	237.6
11/04/2020 18:59	14.47	2.40	2.20	0.008	4.04	3.74	3.43	3.88	0.0077	480.5	50.14	238.0
11/04/2020 19:00	14.47	2.40	2.20	0.008	4.04	3.75	3.44	3.88	0.0077	480.5	50.09	238.0
11/04/2020 19:01	14.47	2.40	2.20	0.008	4.04	3.76	3.45	3.89	0.0077	480.6	50.14	238.1
11/04/2020 19:02	14.46	2.38	2.18	0.008	4.04	3.76	3.44	3.89	0.0077	480.6	50.19	237.7
11/04/2020 19:03	14.46	2.38	2.18	0.008	4.04	3.75	3.44	3.89	0.0077	480.8	50.28	237.8
11/04/2020 19:04	14.46	2.40	2.20	0.008	4.04	3.74	3.43	3.89	0.0077	480.6	49.99	237.7
11/04/2020 19:05	14.47	2.40	2.20	0.008	4.04	3.73	3.42	3.89	0.0077	480.9	50.08	238.2
11/04/2020 19:06	14.46	2.40	2.20	0.008	4.04	3.73	3.42	3.89	0.0077	481.0	50.02	238.0
Daily Average*	14.45	2.38	2.18	0.008	4.06	3.70	3.39	3.83	0.0076	480.6	50.15	237.4
Maximum*	14.47	2.63	2.41	0.009	4.54	3.92	3.58	4.03	0.0080	481.8	50.46	238.2
Minimum*	14.43	2.17	1.98	0.007	3.53	3.28	3.00	3.38	0.0067	479.0	49.94	236.4

* Does not include Invalid Averaging Periods ("N/A")

APPENDIX C CALCULATIONS

Appendix C.1

General Emissions Calculations

GENERAL EMISSION CALCULATIONS

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \%CO_2 + 0.32 * \%O_2 + 0.28 * \%N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 2.9 * C_p * \sqrt{\Delta P} * \sqrt{T_s} * \sqrt{\frac{29.92 * 28.95}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.03342 * V_m * (P_{bar} + \frac{\Delta H}{13.6}) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.0472 * V_{lc} * \frac{T_{ref}}{528 ^\circ R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack gas volumetric flow rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * MW_i * Q_{sd} * 60}{SV * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * MW_i * F}{SV * 10^6} * \frac{20.9}{20.9 - \%O_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{mstd})}{(1-Bwo) * 0 * V_s * P_s * Dn2} * \frac{520^{\circ}R}{T_{ref}}$$

VII. Particulate emissions

- (a) Grain loading, gr/dscf
 $C = 0.01543 (M_n/V_{mstd})$
- (b) Grain loading at 12% CO₂, gr/dscf
 $C_{12\% CO_2} = C (12/\% CO_2)$
- (c) Mass emissions, lb/hr
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$
- (d) Particulate emission factor
 $\text{lb}/10^6 \text{ Btu} = C * \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% O_2}$

Nomenclature:

A_s	= stack area, ft ²
B_{wo}	= flue gas moisture content, dimensionless
$C_{12\%CO_2}$	= particulate grain loading, gr/dscf corrected to 12% CO ₂
C	= particulate grain loading, gr/dscf
C_p	= pitot calibration factor, dimensionless
D_n	= nozzle diameter, in.
F	= fuel F-Factor, dscf/MMBtu @ 0% O ₂
H	= orifice differential pressure, iwg
I	= % isokinetics
M_n	= mass of collected particulate, mg
M_i	= mass emission rate of specie i, lb/hr
MW	= molecular weight of flue gas, lb/lb-mole
M_{wi}	= molecular weight of specie i:
	SO ₂ : 64
	NO _x : 46
	CO: 28
	HC: 16
t	= sample time, min.
ΔP	= average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	= barometric pressure, inches Hg
P_s	= stack absolute pressure, inches Hg
P_{sg}	= stack static pressure, iwb
Q	= wet stack flow rate at actual conditions, wacfm
Q_{sd}	= dry standard stack flow rate, dscfm
SV	= specific molar volume of an ideal gas at standard conditions, ft ³ /lb-mole
T_m	= meter temperature, °R
T_{ref}	= reference temperature, °R
T_s	= stack temperature, °R
V_s	= stack gas velocity, ft/sec
V_{lc}	= volume of liquid collected in impingers, ml
V_m	= uncorrected dry meter volume, dcf
V_{mstd}	= dry meter volume at standard conditions, dscf
V_{wstd}	= volume of water vapor at standard conditions, scf
Y_d	= meter calibration coefficient

Appendix C.2

Spreadsheet Summaries

SCAQMD 207.1 EXAMPLE CALCULATION

TEST NUMBER: 1-NH3-U4

Identifier	Description	Units	Equation	Value
A	Reference Temperature	F	—	60
B	Reference Temperature	R	$A + 460$	520
C	Meter Calibration Factor (Yd)	—	—	1.001
D	Barometric Pressure	" Hg	—	29.75
E	Meter Volume	acf	—	43.683
F	Meter Temperature	F	—	91.0
G	Meter Temperature	R	$F + 460$	551.0
H	Delta H	" H ₂ O	—	1.5
I	Meter Volume (standard)	dscf	$0.03342 * E * (D + H/13.6) * B/G * C$	41.181
J	Liquid Collected	grams	—	132.4
K	Water vapor volume	scf	$0.0472 * J * B/528$	6.155
L	Moisture Content	—	$K/(K + I)$	0.130
M	Gas Constant	ft-lbf/lb-mole-R	—	1545.33
N	Specific Molar Volume	SCF/lb-mole	$385.3 * B / 528$	379.5
O	F-Factor	dscf/MMBtu	—	8,710
P	HHV	Btu/SCF	—	1,050
Q	Mass Conversion Factor	lb/ug	—	2.2046E-09
R	O ₂ Correction Factor	—	—	15
S	Stack Flow Rate @ 68 F	dscfm	—	236,300
T	Stack Flow Rate @ Tref	dscfm	$S * B/528$	232,720
U	Mass NH ₃	ug	—	946
V	Mass NH ₃	lb	$U * Q$	2.09E-06
W	MW of NH ₃	lb/lb-mole	—	17.03
X	NH ₃	ppm	$(V * N * 10^6)/(I * W)$	1.1
Y	Flue Gas O ₂	%	—	14.43
Z	NH ₃	ppmc	$X * (20.9 - R)/(20.9 - Y)$	1.0
AA	NH ₃	lb/hr	$X * T * W * 60/(N * 10^6)$	0.7
AB	NH ₃	lb/MMBtu	$(X * W * O)/(385.3 * 10^6) * 20.9/(20.9 - Y)$	0.001
AC	NH ₃	lb/MMSCF	$AB * P$	1.5

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

SCAQMD METHOD 207.1 DATA WORKSHEET AND SUMMARY

Facility.....	Canyon		Parameter.....	NH₃	
Unit.....	U4		Fuel.....	Natural gas	
Sample Location.....	Stack		Data By.....	JG	
Test Number.....	1-NH3-U4	2-NH3-U4	Average	Maximum	Limit
Reference Temperature (°F).....	60	60			
Test Date.....	11/4/2020	11/4/2020			
Test Method.....	SCAQMD 207.1	SCAQMD 207.1			
Sample Train.....	10 P&M	10 P&M			
Meter Calibration Factor.....	1.001	1.001			
Stack Area (ft ²).....	106.90	106.90			
Sample Time (Minutes).....	60	60			
Barometric Pressure ("Hg).....	29.75	29.75			
Start/Stop Time	1622/1728	1801/1907			
Meter Volume (acf).....	43.683	45.531			
Meter Temperature (°F).....	91.0	86.0			
Meter Pressure (iwg).....	1.5	1.5			
Liquid Volume (ml).....	132.4	130.3			
Stack O ₂ (%).....	14.43	14.45	14.44	(from facility CEMS)	
Unit Load (MW).....	50.0	50.2	50.1		
Standard Sample Volume (SCF).....	41.181	43.316			
Moisture Fraction.....	0.130	0.123			
Stack Flow Rate (dscfm, 68 °F).....	236,300	237,400	236,850	(from facility CEMS)	
Stack Flow Rate (@ Tref).....	232,720	233,803	233,261		
Gas Constant (ft-lbf/lb-mole-R).....	1545.33	1545.33			
Molecular Weight NH ₃ (lb/lb-mole).....	17.03	17.03			
Specific Molar Volume (ft ³ /lb-mole)....	379.5	379.5			
F-Factor (dscf/MMBtu).....	8,710	8,710			
HHV(Btu/SCF).....	1,050	1,050			
Mass Conversion (lb/ug).....	2.2046E-09	2.2046E-09			
O ₂ Correction Factor (%).....	15	15			
Mass NH ₃ (ug).....	946	990			
Mass NH ₃ (lb).....	2.09E-06	2.18E-06			
NH ₃ (ppmv, flue gas).....	1.1	1.1	1.1	1.1	
NH ₃ (ppmv @ O ₂ Correction Factor)...	1.0	1.0	1.0	1.0	5
NH ₃ (lb/hr).....	0.7	0.7	0.7	0.7	
NH ₃ (lb/MMBtu).....	0.001	0.001	0.001	0.001	
NH ₃ (lb/MMSCF).....	1.5	1.5	1.5	1.5	

Note: SCAQMD Method 207.1 requires the higher of the duplicate runs be reported as the test result.

1-NH3-U4

Point	Meter Volume	Delta H	Tm In	Tm Out
6	83.442	1.5	94	89
5			94	88
4			93	88
3			93	89
2				
1				
Stop				
6				
5				
4				
3				
2				
1				
Stop	127.125			
Result	43.683	1.5	91.0	

Impinger Weights

#	Post-Test	Pre-Test	Difference
1	951.6	737.3	214.3
2	729.7	727.6	2.1
3	608.4	607.9	0.5
4	952.0	936.5	15.5
Line Rinse	0.0	100.0	-100.0
			132.4

2-NH3-U4

Point	Meter Volume	Delta H	Tm In	Tm Out
6	131.696	1.5	87	85
5			88	85
4			87	84
3			88	84
2				
1				
Stop				
6				
5				
4				
3				
2				
1				
Stop	177.227			
Result	45.531	1.5	86.0	

Impinger Weights

#	Post-Test	Pre-Test	Difference
1	936.8	720.0	216.8
2	706.7	704.7	2.0
3	592.1	590.8	1.3
4	932.1	921.9	10.2
Line Rinse	0.0	100.0	-100.0
			130.3

APPENDIX D QUALITY ASSURANCE

Appendix D.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (MAQS) ASTM D7036-04 certification, MAQS is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. MAQS quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: MAQS has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: MAQS has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of MAQS QA efforts. The manual is revised upon periodic review and as MAQS adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. MAQS training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the MAQS QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of MAQS emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: MAQS maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: MAQS maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to MAQS source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to MAQS office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, will be present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)

The following safety measures will be followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO _x Analyzer	Daily	NO ₂ -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	+/- 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	+/- 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	+/- 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	+/- 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	+/- 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for $\Delta H@$	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	+/- 1.5%

Note: Calibration requirements will be used that meet applicable regulatory agency requirements.

Appendix D.2

SCAQMD and STAC Certifications



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

September 9, 2020

Mr. John Peterson
Montrose Air Quality Services, LLC
1631 E. Saint Andrew Place
Santa Ana, CA 92705

Subject: LAP Approval Notice
Reference # 96LA1220

Dear Mr. Peterson:

We have reviewed your renewal letter under the South Coast Air Quality Management District's Laboratory Approval Program (LAP). We are pleased to inform you that your firm is approved for the period beginning September 30, 2020, and ending September 30, 2021 for the following methods, subject to the requirements in the LAP Conditions For Approval Agreement and conditions listed in the attachment to this letter:

Methods 1-4	Methods 5.1, 5.2, 5.3, 6.1
Methods 10.1 and 100.1	Methods 25.1 and 25.3 (Sampling)
USEPA CTM-030 and ASTM D6522-00	Rule 1121/ 1146.2 Protocol
Rule 1420/1420.1/1420.2 – (Lead) Source and Ambient Sampling	

Your LAP approval to perform nitrogen oxide emissions compliance testing for Rule 1121/ 1146.2 Protocols includes satellite facilities located at:

McKenna Boiler	Noritz America Corp.	Ajax Boiler, Inc.
1510 North Spring Street	11160 Grace Avenue	2701 S. Harbor Blvd.
Los Angeles, CA 90012	Fountain Valley, CA 92708	Santa Ana, CA 92704

Laundry Building of VA Greater Los Angeles Healthcare System
508 Constitution Avenue
Los Angeles, CA 90049

Thank you for participating in the LAP. Your cooperation helps us to achieve the goal of the LAP: to maintain high standards of quality in the sampling and analysis of source emissions. You may direct any questions or information to LAP Coordinator, Glenn Kasai. He may be reached by telephone at (909) 396-2271, or via e-mail at gkasai@aqmd.gov.

Sincerely,

A handwritten signature in black ink that reads 'D. Sarkar'.

Dipankar Sarkar
Program Supervisor
Source Test Engineering

DS:GK/gk
Attachment

200909 LapRenewalRev.doc

Keeping the air that we breathe...



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 11th day of February 2020.



Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3925.01
Valid to February 28, 2022

This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

Appendix D.3

Individual QI Certificate

CERTIFICATE OF COMPLETION

John Groenenboom

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

SCAQMD Method 207.1

Certificate Number: 002-2017-51

Tate Strickler

Tate Strickler, Accreditation Director

DATE OF ISSUE: 1/17/17

DATE OF
EXPIRATION: 1/17/22



MONTROSE
ENVIRONMENTAL

APPENDIX E APPLICABLE PERMIT SECTIONS



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: POWER GENERATION					
CO OXIDATION CATALYST, NO. 4, BASF, 110 CUBIC FEET OF TOTAL CATALYST VOLUME A/N: 476663	C21	D19 C22			
SELECTIVE CATALYTIC REDUCTION, NO. 4, CORMETECH CMHT-21, 1012 CU.FT.; WIDTH: 2 FT 6 IN; HEIGHT: 25 FT 9 IN; LENGTH: 18 FT WITH A/N: 476663	C22	C21 S24		NH3: 5 PPMV NATURAL GAS (4) [RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1) -BACT, 12-6-2002]	A195.7, D12.2, D12.3, D12.4, E179.1, E179.2, E193.1
AMMONIA INJECTION					
STACK, TURBINE NO. 4, HEIGHT: 86 FT ; DIAMETER: 11 FT 8 IN A/N: 555831	S24	C22			
System 2: INTERNAL COMBUSTION ENGINE					

- * (1) (1A) (1B) Denotes RECLAIM emission factor
(3) Denotes RECLAIM concentration limit
(5) (5A) (5B) Denotes command and control emission limit
(7) Denotes NSR applicability limit
(9) See App B for Emission Limits
(2) (2A) (2B) Denotes RECLAIM emission rate
(4) Denotes BACT emission limit
(6) Denotes air toxic control rule limit
(8) (8A) (8B) Denotes 40 CFR limit (e.g. NSPS, NESHAPS, etc.)
(10) See section J for NESHAP/MACT requirements
- ** Refer to section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

[Devices subject to this condition : C4, C10, C16, C22]

- D12.5 The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the engine.

[**RULE 1110.2, 2-1-2008; RULE 1110.2, 9-7-2012; RULE 1303(b)(2)-Offset, 5-10-1996;**
RULE 1303(b)(2)-Offset, 12-6-2002; RULE 1401, 9-10-2010; RULE 1470, 5-4-2012;
RULE 2012, 5-6-2005; 40CFR 60 Subpart III, 1-30-2013]

[Devices subject to this condition : D25]

- D29.2 The operator shall conduct source test(s) for the pollutant(s) identified below.

Pollutant(s) to be tested	Required Test Method(s)	Averaging Time	Test Location
NH3 emissions	District method 207.1 and 5.3 or EPA method 17	1 hour	Outlet of the SCR serving this equipment

THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. John Groenenboom
Title: Client Project Manager
Region: West
Email: JGroenenboom@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: West
Email: MMccune@montrose-env.com
Phone: (714) 279-6777

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 17

AQ-14 & AQ-24
RTC INVENTORY



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

December 26, 2019

Shawn Smith
Integrated Resources Manager
Canyon Power Plant (ID: 153992)
3071 E Miraloma Ave
Anaheim, CA 92806

Dear Shawn Smith:

Enclosed is your re-issued Facility Permit for Compliance Year 2020 (January 1, 2020 – December 31, 2020). This reissuance is an Administrative Permit Revision to your RECLAIM/Title V Facility Permit and includes the Title Page, Table of Contents, and Section B (RECLAIM Annual Emission Allocations) in accordance with Rule 2002(b)(4).

Please review the enclosed Section B carefully, as it will be part of your official Facility Permit. The changes are stated below. Please note that the South Coast Air Quality Management District (South Coast AQMD) rules allow you to appeal the terms and conditions of any sections of the enclosed Facility Permit by petitioning the Hearing Board within thirty days of receipt of the permit.

We recently sent you an invoice for the annual operating renewal fee for your facility permit. This must be paid on or before the due date indicated on the invoice or your facility permit will expire due to non-payment of fees.

A. Facility Permit

The enclosed Facility Permit contains changes described as follows:

1. The revision numbers and dates of the Title Page and the Table of Contents have been updated to reflect the reissuance of the relevant permit sections.
2. Section B – RECLAIM Annual Emission Allocation

Section B has been updated to reflect all approved RECLAIM Trading Credit (RTC) transactions approved as of December 20, 2019. Therefore, if you have submitted any RTC transactions in December, please review your records carefully to ensure that you take into account any RTC transactions that have not been approved as of that date and make necessary changes to your facility's RTC balances when reconciling your facility's emissions.

In addition, the South Coast AQMD has updated Section B of the Facility Permit to list your facility's allocation balances for the next fifteen years pursuant to Rule

2002(b)(4). Also, your facility's Starting Allocation and Non-Tradable RTCs in Compliance Year 1994 are listed within this section. This establishes the level used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) – Trading Zone Restrictions.

B. Appeals

As previously mentioned, if you determine that certain changes or clarifications need to be made to the enclosed permit, you may appeal the terms and conditions by petitioning the Hearing Board within thirty days of receipt. If you determine there are administrative errors in these permit sections, please notify South Coast AQMD staff within thirty days of receipt of your permit sections. Your facility is still bound by the requirements of your entire Facility Permit while your appeal is under consideration by South Coast AQMD staff and/or Hearing Board.

Any comments or questions regarding your RECLAIM Facility Permit may be directed to Charles Tupac, Supervising Air Quality Engineer at (909) 396-2684 or ctupac@aqmd.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Chandan", with a horizontal line underneath.

Bhaskar Chandan, P.E., QEP
Sr. Air Quality Engineering Manager
Engineering and Permitting

Enclosure

cc: Gerardo C. Rios, USEPA (via CDX or email to R9AirPermits_SC@epa.gov)
Rafael Reynosa, Sr. Enforcement Manager – Compliance
Scott Caso, Sr. Enforcement Manager – Compliance



South Coast Air Quality Management District
21865 Copley Drive, Diamond Bar, CA 91765-4178

Title Page
Facility ID: 153992
Revision #: 15
Date: January 01, 2020

FACILITY PERMIT TO OPERATE


**CANYON POWER PLANT
3071 E MIRALOMA AVE
ANAHEIM, CA 92806**

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Wayne Nastri
Executive Officer

By 
Amir Dejbakhsh
Deputy Executive Officer
Engineering and Permitting



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	2	11/06/2015
B	RECLAIM Annual Emission Allocation	12	01/01/2020
C	Facility Plot Plan	TO BE DEVELOPED	
D	Facility Description and Equipment Specific Conditions	3	11/06/2015
E	Administrative Conditions	1	11/06/2015
F	RECLAIM Monitoring and Source Testing Requirements	1	11/06/2015
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	1	11/06/2015
H	Permit To Construct and Temporary Permit to Operate	3	11/06/2015
I	Compliance Plans & Schedules	1	11/06/2015
J	Air Toxics	1	11/06/2015
K	Title V Administration	1	11/06/2015
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	1	11/06/2015
B	Rule Emission Limits	1	11/06/2015



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO_x RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO_x emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)		Zone	NO _x RTC Initially Allocated	NO _x RTC ¹ Holding as of 01/01/2020 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
7/2017	6/2018	Coastal	0	7462	0
1/2018	12/2018	Coastal	0	6985	1648
7/2018	6/2019	Coastal	0	24585	1292
1/2019	12/2019	Coastal	0	40532	1648
7/2019	6/2020	Coastal	0	31792	1292
1/2020	12/2020	Coastal	0	37283	3248
7/2020	6/2021	Coastal	0	29245	2548
1/2021	12/2021	Coastal	0	33988	3295
7/2021	6/2022	Coastal	0	26660	2585
1/2022	12/2022	Coastal	0	27445	6543
7/2022	6/2023	Coastal	0	21527	5133
1/2023	12/2023	Coastal	0	27445	0
7/2023	6/2024	Coastal	0	21527	0
1/2024	12/2024	Coastal	0	27445	0
7/2024	6/2025	Coastal	0	21527	0
1/2025	12/2025	Coastal	0	27445	0
7/2025	6/2026	Coastal	0	21527	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO_x RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO_x emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NO _x RTC Initially Allocated	NO _x RTC ¹ Holding as of 01/01/2020 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
1/2026 12/2026	Coastal	0	27445	0
7/2026 6/2027	Coastal	0	21527	0
1/2027 12/2027	Coastal	0	27445	0
7/2027 6/2028	Coastal	0	21527	0
1/2028 12/2028	Coastal	0	27445	0
7/2028 6/2029	Coastal	0	21527	0
1/2029 12/2029	Coastal	0	27445	0
7/2029 6/2030	Coastal	0	21527	0
1/2030 12/2030	Coastal	0	27445	0
7/2030 6/2031	Coastal	0	21527	0
1/2031 12/2031	Coastal	0	27445	0
7/2031 6/2032	Coastal	0	21527	0
1/2032 12/2032	Coastal	0	27445	0
7/2032 6/2033	Coastal	0	21527	0
1/2033 12/2033	Coastal	0	27445	0
7/2033 6/2034	Coastal	0	21527	0
1/2034 12/2034	Coastal	0	27445	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO_x RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO_x emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NO _x RTC Initially Allocated	NO _x RTC ¹ Holding as of 01/01/2020 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
7/2034 6/2035	Coastal	0	21527	0
1/2035 12/2035	Coastal	0	27445	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE CANYON POWER PLANT

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. If the facility submits a permit application to increase in an annual allocation to a level greater than the facility's starting Allocation plus Non-Tradable credits as listed below, the application will be evaluated for compliance with Rule 2005 (c)(4). Rule 2005 (e) - Trading Zone Restrictions applies if an annual allocation is increased to a level greater than the facility's Starting Allocation plus Non-Tradable Credits:

Year		Zone	RTC	Non-Tradable
Begin	End		Starting Allocation	Credits(NTC)
(month/year)			(pounds)	(pounds)

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 18

AQ-17
NH3 FLOW METER ACCURACY REPORTS

HOMER R. DULIN CO.
729 EAST WILLOW STREET
SIGNAL HILL, CALIFORNIA 90755
(562) 424-8533 FAX (562) 426-7707
CERT. NO. 4-118-20

CALIBRATION CERTIFICATION

SUBMITTED BY: CITY OF ANAHEIM

FLOWMETER SERIAL NO.:

MFG. SERIAL NO: 14236418

MANUFACTURER: MICRO MOTION

MODEL: CMF025M313NQBUEZZZ

TUBE NO: .

FLOAT NO: .

DATA IS: As Found/As Left ; In Tolerance

See Remarks ☐

Calibrated @ customer's facility ☐

REMARKS: DIRECT READING ELECTRONIC INDICATOR TRANSMITTER S/N: 14138117, CALIBRATED IN LBS/HR H2O
@ 75°F. SP.GR. 1.0

ACCURACY \pm 1% RATE

INDICATED		ACTUAL	
LB/H		LBS/HR	
151.77		151.62	
132.00		131.82	
114.65		114.36	
94.00		93.84	
74.80		74.64	
55.13		55.02	
37.34		37.38	
27.21		27.24	
19.20		19.15	

Flowmeter Certified with HOMER R. DULIN CO.

Equip. No. 11605

Accuracy 0.005%

Equip. Cal. Date: 8/29/18

Cal. Due: 8/29/21

NIST Cert. No. TEST# MS 15560

Procedure No: ISA:RP 16.6

Our standards are certified by or are traceable to the National Institute of Standards and Technology and systems comply with MIL-STD 45662A, ANSI/NCSL Z540.3, ISO/IEC 17025, and ISO 10012. The collective uncertainty of the standards used in this calibration does not exceed 25% of the certified accuracy of the instrument under test. This document may not be reproduced, except in full, without prior written approval of the Homer R. Dulin Co. Rev.1 Dated 8/19/14

P.O. No .

Shipper No. .

4-6-20

CALIBRATION DATE


4-6-21

RECALIBRATION DUE

R. MARTINEZ

CALIBRATION TECHNICIAN

Rogelio Martinez



CALIBRATION CURVE BY
HOMER R. DULIN CO. Certificate #4-118-20
 Submitted By: CITY OF ANAHEIM
 Flowmeter S/N: .
 Mfr. S/N: MICRO MOTION 14236418
 Tube:
 Model: CMF025M313NQBUEZZZ
 Date: 4-6-20
 Technician: R. MARTINEZ
 Accuracy: ± 1% RATE

HOMER R. DULIN CO.

729 EAST WILLOW STREET

SIGNAL HILL, CALIFORNIA 90755

(562) 424-8533

FAX (562) 426-7707

CERT. NO. 4-106-20

CALIBRATION CERTIFICATION

SUBMITTED BY: CITY OF ANAHEIM

FLOWMETER SERIAL NO: .

MFG. SERIAL NO: 14139410

MANUFACTURER: MICRO MOTION

MODEL: CMF025M313NQBUEZZZ

TUBE NO: .

FLOAT NO: .

DATA IS: As Found/As Left ; In Tolerance

See Remarks ☐

Calibrated @ customer's facility ☐

REMARKS: DIRECT READING ELECTRONIC INDICATOR TRANSMITTER S/N: 14139410, CALIBRATED IN LBS/HR H2O @ 75° F. SP.GR. 1.0

ACCURACY \pm 1% RATE

INDICATED		ACTUAL	
LB/HR		LBS/HR	
150.40		149.28	
130.85		129.79	
112.80		112.02	
93.56		93.24	
70.92		70.68	
55.73		55.38	
36.66		36.36	
29.00		28.80	
19.40		19.24	
0.00		0.00	

Flowmeter Certified with HOMER R. DULIN CO.

Equip. No. 11605

Accuracy 0.005%

Equip. Cal. Date: 8/29/18

Cal. Due: 8/29/21

NIST Cert. No. TEST# MS 15560

Procedure No: ISA:RP 16.6

Our standards are certified by or are traceable to the National Institute of Standards and Technology and systems comply with MIL-STD 45662A, ANSI/NCSL Z540.3, ISO/IEC 17025, and ISO 10012. The collective uncertainty of the standards used in this calibration does not exceed 25% of the certified accuracy of the instrument under test. This document may not be reproduced, except in full, without prior written approval of the Homer R. Dulin Co. Rev.1 Dated 8/19/14

P.O. No. .

Shipper No. .

4-2-20

CALIBRATION DATE


4-2-21

RECALIBRATION DUE

P. HARRISON

CALIBRATION TECHNICIAN

Paul Harrison



CALIBRATION CURVE BY
HOMER R. DULIN CO. Certificate #4-106-20
Submitted By: CITY OF ANAHEIM

Flowmeter S/N: .

Mfr. S/N: MICRO MOTION 14139410

Tube: .

Model: CMF025M313NQBUEZZZ

Date: 4-2-20

Technician: P. HARRISON

Accuracy: ± 1% RATE

HOMER R. DULIN CO.

729 EAST WILLOW STREET

SIGNAL HILL, CALIFORNIA 90755

(562) 424-8533

FAX (562) 426-7707

CERT. NO. 3-359-20

CALIBRATION CERTIFICATIONSUBMITTED BY: CITY OF ANAHEIM

FLOWMETER SERIAL NO: .

MFG. SERIAL NO: 14134531MANUFACTURER: MICRO MOTIONMODEL: CMF025M313NQBUEZZZTUBE NO: N/AFLOAT NO: N/A

DATA IS: As Found/As Left ; In Tolerance

See Remarks ☒Calibrated @ customer's facility ☐REMARKS: DIRECT READING ELECTRONIC INDICATOR TRANSMITTER S/N: 14134531, CALIBRATED IN LBS/HR H₂O
@ 75°F. SP.GR. 1.0 METER UNSTABLE BELOW 19.20 LB/HR INDICATED.ACCURACY \pm 1% RATE

INDICATED		ACTUAL	
LB/H		LBS/HR	
150.60		150.60	
131.50		131.93	
112.20		112.86	
94.75		95.50	
76.73		77.43	
56.82		57.29	
38.47		38.66	
28.61		28.64	
19.20		19.23	
0.00		0.00	

Flowmeter Certified with HOMER R. DULIN CO.

Equip. No. 6209 YYYAccuracy 0.20%Equip. Cal. Date: 1/02/20(INSP)Cal. Due: 1/02/21(INSP)NIST Cert. No. 822/264157Procedure No: ISA:RP 16.6

Our standards are certified by or are traceable to the National Institute of Standards and Technology and systems comply with MIL-STD 45662A, ANSI/NCSL Z540.3, ISO/IEC 17025, and ISO 10012. The collective uncertainty of the standards used in this calibration does not exceed 25% of the certified accuracy of the instrument under test. This document may not be reproduced, except in full, without prior written approval of the Homer R. Dulin Co. Rev.1 Dated 8/19/14

P.O. No. .

Shipper No. .

3-26-20


CALIBRATION DATE

3-26-21

RECALIBRATION DUE

R. MARTINEZ

CALIBRATION TECHNICIAN



CALIBRATION CURVE BY
HOMER R. DULIN CO. Certificate #3-359-20
 Submitted By: CITY OF ANAHEIM
 Flowmeter S/N: .
 Mfr. S/N: MICRO MOTION 14134531
 Tube: N/A
 Model: CMF025M313NQBUEZZZ
 Date: 3-26-20
 Technician: R. MARTINEZ
 Accuracy: ± 1% RATE

HOMER R. DULIN CO.
729 EAST WILLOW STREET
SIGNAL HILL, CALIFORNIA 90755
(562) 424-8533 FAX (562) 426-7707
CERT. NO. 3-292-20

CALIBRATION CERTIFICATION

SUBMITTED BY: CITY OF ANAHEIM

FLOWMETER SERIAL NO: .

MFG. SERIAL NO: 14832375

MANUFACTURER: MICRO MOTION

MODEL: CMF025M313N2BAEZZZ

TUBE NO: N/A

FLOAT NO: N/A

DATA IS: As Found/As Left ; In Tolerance

See Remarks ☒

Calibrated @ customer's facility ☐

REMARKS: DIRECT READING ELECTRONIC INDICATOR TRANSMITTER S/N: 14832375,
CALIBRATED IN LBS/HR H₂O @ 75° F. SP.GR. 1.0 FIRST CALIBRATION

ACCURACY \pm 1% RATE

INDICATED		ACTUAL	
LB/HR		LBS/HR	
150.8		150.6	
131.7		131.4	
113.2		112.9	
94.1		93.8	
75.6		75.2	
57.1		56.7	
37.4		37.2	
20.3		20.5	
0.0		0.0	

Flowmeter Certified with HOMER R. DULIN CO.

Equip. No. 11605

Accuracy 0.005%

Equip. Cal. Date: 8/29/18

Cal. Due: 8/29/21

NIST Cert. No. TEST# MS 15560

Procedure No: ISA:RP 16.6

Our standards are certified by or are traceable to the National Institute of Standards and Technology and systems comply with MIL-STD 45662A, ANSI/NCSL Z540.3, ISO/IEC 17025, and ISO 10012. The collective uncertainty of the standards used in this calibration does not exceed 25% of the certified accuracy of the instrument under test. This document may not be reproduced, except in full, without prior written approval of the Homer R. Dulin Co. Rev.1 Dated 8/19/14

P.O. No .

Shipper No. .

3-20-20


CALIBRATION DATE

3-20-21

RECALIBRATION DUE

R. MARTINEZ

CALIBRATION TECHNICIAN



CALIBRATION CURVE BY
HOMER R. DULIN CO. Certificate #3-292-20
 Submitted By: CITY OF ANAHEIM
 Flowmeter S/N: .
 Mfr. S/N: MICRO MOTION 14832375
 Tube: N/A
 Model: CMF025M313N2BAEZZZ
 Date: 3-20-20
 Technician: R. MARTINEZ
 Accuracy: ± 1% RATE

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 19

AQ-18
SCR INLET TEMPERATURE SENSOR
CALIBRATION REPORTS

Calibration: SCR Inlet Temperature
Unit 1 TE-403A-403D

Calibration Certificate

Certificate Number:
Position ID: 1-TE-403A

Printed: 1/16/2020 8:23:28 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U1/

Device

Device ID 1-TE-403A
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U1 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 8:14:42 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -1.106 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	99.95	100.0	90.000	-1.106
550.0	549.98	550.0	542.000	-0.887
1000.0	999.99	1000.0	992.500	-0.832

2. As Left

PASSED, DO NOT ADJUST

Maximum Error: -1.003 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.03	100.0	91.000	-1.003
550.0	550.04	550.0	542.500	-0.838
1000.0	1000.02	1000.0	993.000	-0.780

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 8:14:42 AM

Calibration Certificate

Certificate Number:
Position ID: 1-TE-403B

Printed: 1/16/2020 8:23:28 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U1/

Device

Device ID 1-TE-403B
Serial Number
Manufacturer
Rangeability
Operating Operating Humidity

Function

Name U1 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 8:25:23 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -1.392 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.03	100.0	87.500	-1.392
550.0	550.04	550.0	540.000	-1.116
1000.0	1000.02	1000.0	990.500	-1.058

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 8:25:23 AM

Calibration Certificate

Certificate Number:
Position ID: 1-TE-403C

Printed: 1/16/2020 8:23:28 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U1/

Device

Device ID 1-TE-403C
Serial Number
Manufacturer
Rangeability
Operating Operating Humidity

Function

Name U1 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 8:29:00 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.613 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.02	100.0	85.500	-1.613
550.0	550.02	550.0	538.000	-1.336
1000.0	1000.01	1000.0	988.500	-1.279

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 8:29:00 AM

Calibration Certificate

Certificate Number:
Position ID: 1-TE-403D

Printed: 1/16/2020 8:23:28 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U1/

Device

Device ID 1-TE-403D
Serial Number
Manufacturer
Rangeability
Operating Operating Humidity

Function

Name U1 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 8:32:15 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.723 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.01	100.0	84.500	-1.723
550.0	550.02	550.0	537.500	-1.391
1000.0	1000.02	1000.0	988.000	-1.336

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 8:32:15 AM

Calibration: SCR Inlet Temperature
Unit 2 TE-403A-403D

Calibration Certificate

Certificate Number:
Position ID: 2-TE-403A

Printed: 1/16/2020 8:26:24 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U2/

Device

Device ID 2-TE-403A
Serial Number
Manufacturer
Rangeability
Operating Operating Humidity

Function

Name U2 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 8:57:15 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.777 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	99.99	100.0	84.000	-1.777
550.0	550.03	550.0	536.500	-1.503
1000.0	1000.01	1000.0	988.000	-1.334

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 8:57:15 AM

Calibration Certificate

Certificate Number:
Position ID: 2-TE-403B

Printed: 1/16/2020 8:26:24 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U2/

Device

Device ID 2-TE-403B
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U2 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 9:00:55 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -1.446 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.01	100.0	87.000	-1.446
550.0	550.01	550.0	538.000	-1.334
1000.0	1000.01	1000.0	989.500	-1.168

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 9:00:55 AM

Calibration Certificate

Certificate Number:
Position ID: 2-TE-403C

Printed: 1/16/2020 8:26:24 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U2/

Device

Device ID 2-TE-403C
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U2 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 9:04:08 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.778 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.00	100.0	84.000	-1.778
550.0	550.01	550.0	535.500	-1.612
1000.0	1000.01	1000.0	986.000	-1.557

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 9:04:08 AM

Calibration Certificate

Certificate Number:
Position ID: 2-TE-403D

Printed: 1/16/2020 8:26:24 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U2/

Device

Device ID 2-TE-403D
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U2 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 9:30:11 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.889 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.00	100.0	83.000	-1.889
550.0	550.01	550.0	535.000	-1.668
1000.0	1000.00	1000.0	985.000	-1.667

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 9:30:11 AM

Calibration: SCR Inlet Temperature
Unit 3 TE-403A-403D

Calibration Certificate

Certificate Number:
Position ID: 3-TE-403A

Printed: 1/16/2020 8:29:45 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U3/

Device

Device ID 3-TE-403A
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U3 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 9:57:26 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator
Output Module Due Date:



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -1.497 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	99.97	100.0	86.500	-1.497
550.0	550.00	550.0	539.000	-1.222
1000.0	1000.04	1000.0	990.000	-1.116

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 9:57:26 AM

Calibration Certificate

Certificate Number:
Position ID: 3-TE-403B

Printed: 1/16/2020 8:29:45 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U3/

Device

Device ID 3-TE-403B
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U3 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:00:58 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -1.338 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.04	100.0	88.000	-1.338
550.0	550.02	550.0	540.500	-1.058
1000.0	1000.02	1000.0	991.000	-1.002

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:00:58 AM

Calibration Certificate

Certificate Number:
Position ID: 3-TE-403C

Printed: 1/16/2020 8:29:45 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U3/

Device

Device ID 3-TE-403C
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U3 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:04:43 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.723 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.01	100.0	84.500	-1.723
550.0	550.01	550.0	536.500	-1.501
1000.0	1000.00	1000.0	988.000	-1.333

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:04:43 AM

Calibration Certificate

Certificate Number:
Position ID: 3-TE-403D

Printed: 1/16/2020 8:29:45 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U3/

Device

Device ID 3-TE-403D
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U3 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:07:54 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.611 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.00	100.0	85.500	-1.611
550.0	550.01	550.0	538.500	-1.279
1000.0	1000.02	1000.0	989.500	-1.169

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:07:54 AM

Calibration: SCR Inlet Temperature
Unit 4 TE-403A-403D

Calibration Certificate

Certificate Number:
Position ID: 4-TE-403A

Printed: 1/16/2020 8:31:17 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U4/

Device

Device ID 4-TE-403A
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U4 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:41:19 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2.5 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -2.002 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.02	100.0	82.000	-2.002
550.0	550.01	550.0	534.000	-1.779
1000.0	1000.01	1000.0	985.000	-1.668

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:41:19 AM

Calibration Certificate

Certificate Number:
Position ID: 4-TE-403B

Printed: 1/16/2020 8:31:17 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U4/

Device

Device ID 4-TE-403B
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U4 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:44:55 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -1.836 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.02	100.0	83.500	-1.836
550.0	550.01	550.0	536.000	-1.557
1000.0	1000.02	1000.0	986.000	-1.558

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:44:55 AM

Calibration Certificate

Certificate Number:
Position ID: 4-TE-403C

Printed: 1/16/2020 8:31:17 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U4/

Device

Device ID 4-TE-403C
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U4 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:48:38 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2.5 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -2.110 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	99.99	100.0	81.000	-2.110
550.0	549.99	550.0	533.500	-1.832
1000.0	1000.00	1000.0	984.000	-1.778

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:48:38 AM

Calibration Certificate

Certificate Number:
Position ID: 4-TE-403D

Printed: 1/16/2020 8:31:17 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name SCR INLET TEMP
Work Order Number
Location NH3 INJ SKID
Plant CANYON/ERU/U4/

Device

Device ID 4-TE-403D
Serial Number
Manufacturer
Rangeability
Operating
Operating Humidity

Function

Name U4 SCR INLET TEMP (ud)
Transfer Function Linear
Range 100 ... 1000 °F 100 ... 1000 °F

Calibration Event


Calibration time 1/15/2020 10:52:36 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 2.5 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module TC-R-OUT/ TC1 : 65279 Due Date: 4/17/2020
Output Calibrator Due Date:
Output Module Due Date:



1. As Found

PASSED, ADJUST

Maximum Error: -2.058 % of span

Nominal Input [°F]	Actual Input [°F]	Nominal Output [°F]	Actual Output [°F]	Found Error [% of span]
100.0	100.02	100.0	81.500	-2.058
550.0	550.01	550.0	534.500	-1.723
1000.0	1000.01	1000.0	984.500	-1.723

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/15/2020 10:52:36 AM

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 20

AQ-19
SCR DIFFERENTIAL PRESSURE SENSOR
CALIBRATION REPORTS

Calibration Certificate

Certificate Number:
Position ID: 1-PDIT-403

Printed: 1/16/2020 8:21:24 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name U1 SCR DP
Work Order Number
Location U1 ERU
Plant CANYON/ERU/U1/

Device

Device ID 1-PDIT-403
Serial Number
Manufacturer Rosemount 3051S2CD1A2F12A1AB3E5L4M5Q4
Rangeability
Operating Operating Humidity

Function

Name U1 SCR DP (ud)
Transfer Function Linear
Range 0 ... 10 inH2O (G) 4 ... 20 mA

Calibration Event


Calibration time 1/14/2020 10:55:36 AM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 1 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module P2C : 69381 Due Date: 4/17/2020
Output Calibrator MC6 : 605835 Due Date: 4/16/2020
Output Module IN : 25613 Due Date: 4/16/2020



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: -0.582 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.01	4.0000	3.9229	-0.582
2.500	2.54	8.000	7.9876	-0.478
5.000	5.03	12.000	11.9738	-0.464
7.500	7.48	16.000	15.9093	-0.367
10.000	9.99	20.000	19.9229	-0.382
7.500	7.55	16.000	16.0179	-0.388
5.000	5.11	12.000	12.1087	-0.421
2.500	2.55	8.000	8.0165	-0.397
0.0000	0.01	4.0000	3.9438	-0.451

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/14/2020 10:55:36 AM

Calibration Certificate

Certificate Number:
Position ID: 2-PDIT-403

Printed: 1/16/2020 8:25:29 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name U2 SCR DP
Work Order Number
Location U2 ERU
Plant CANYON/ERU/U2/

Device

Device ID 2-PDIT-403
Serial Number
Manufacturer Rosemount 3051S2CD1A2F12A1AB3E5L4M5Q4
Rangeability
Operating Operating Humidity

Function

Name U2 SCR DP (ud)
Transfer Function Linear
Range 0 ... 10 inH2O (G) 4 ... 20 mA

Calibration Event


Calibration time 1/14/2020 12:08:27 PM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 1 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module P2C : 69381 Due Date: 4/17/2020
Output Calibrator MC6 : 605835 Due Date: 4/16/2020
Output Module IN : 25613 Due Date: 4/16/2020



1. As Found

FAILED

Maximum Error: 1.178 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.00	4.0000	4.0587	0.367
2.500	2.68	8.000	8.3781	0.563
5.000	5.08	12.000	12.2587	0.817
7.500	7.52	16.000	16.1812	0.933
10.000	10.08	20.000	20.3164	1.178
7.500	7.58	16.000	16.2790	0.944
5.000	5.07	12.000	12.2369	0.781
2.500	2.44	8.000	7.9957	0.573
0.0000	0.01	4.0000	4.0633	0.296

2. As Left

PASSED, DO NOT ADJUST

Maximum Error: -0.105 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.01	4.0000	3.9992	-0.105
2.500	2.56	8.000	8.0969	0.006
5.000	4.84	12.000	11.7345	-0.059
7.500	7.58	16.000	16.1172	-0.068
10.000	10.02	20.000	20.0241	-0.049
7.500	7.57	16.000	16.1028	-0.058
5.000	5.12	12.000	12.1882	-0.024
2.500	2.59	8.000	8.1393	-0.029
0.0000	0.01	4.0000	4.0027	-0.083

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/14/2020 12:08:27 PM

Calibration Certificate

Certificate Number:
Position ID: 3-PDIT-403

Printed: 1/16/2020 8:27:01 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name U3 SCR DP
Work Order Number
Location U3 ERU
Plant CANYON/ERU/U3/

Device

Device ID 3-PDIT-403
Serial Number
Manufacturer Rosemount 3051S2CD1A2F12A1AB3E5L4M5Q4
Rangeability
Operating Operating Humidity

Function

Name U3 SCR DP (ud)
Transfer Function Linear
Range 0 ... 10 inH2O (G) 4 ... 20 mA

Calibration Event


Calibration time 1/14/2020 1:42:26 PM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 1 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module P2C : 69381 Due Date: 4/17/2020
Output Calibrator MC6 : 605835 Due Date: 4/16/2020
Output Module IN : 25613 Due Date: 4/16/2020



1. As Found

PASSED, DO NOT ADJUST

Maximum Error: 0.596 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.00	4.0000	4.0888	0.555
2.500	2.51	8.000	8.1113	0.596
5.000	4.94	12.000	11.9963	0.577
7.500	7.49	16.000	16.0758	0.574
10.000	10.04	20.000	20.1499	0.537
7.500	7.63	16.000	16.3015	0.584
5.000	5.16	12.000	12.3389	0.518
2.500	2.61	8.000	8.2594	0.521
0.0000	0.00	4.0000	4.0879	0.549

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/14/2020 1:42:26 PM

Calibration Certificate

Certificate Number:
Position ID: 4-PDIT-403

Printed: 1/16/2020 8:30:25 AM
Printed by: vnguyen
CMX Version: 2.11.214.0 (2.11)

Position

Name U4 SCR DP
Work Order Number
Location U4 ERU
Plant CANYON/ERU/U4/

Device

Device ID 4-PDIT-403
Serial Number 393481
Manufacturer Rosemount 3051C
Rangeability
Operating Operating Humidity

Function

Name U4 SCR DP (ud)
Transfer Function Linear
Range 0 ... 10 inH2O (G) 4 ... 20 mA

Calibration Event


Calibration time 1/14/2020 2:45:52 PM
Next Calibration
Environment Environment

Calibration Procedure

Due Date Interval 0
Reject If Error > 1 % of span
Adjust To Error < 40 % of Reject If Error Classification
Calibration Strategy

Calibrators

Input Calibrator MC6 : 605835 Due Date: 4/16/2020
Input Module P2C : 69381 Due Date: 4/17/2020
Output Calibrator MC6 : 605835 Due Date: 4/16/2020
Output Module IN : 25613 Due Date: 4/16/2020



1. As Found

FAILED

Maximum Error: -1.366 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.00	4.0000	3.9011	-0.618
2.500	2.45	8.000	7.7031	-1.356
5.000	5.09	12.000	11.9297	-1.339
7.500	7.50	16.000	15.7944	-1.285
10.000	9.90	20.000	19.6214	-1.366
7.500	7.56	16.000	15.8792	-1.355
5.000	5.04	12.000	11.8635	-1.253
2.500	2.39	8.000	7.6213	-1.267
0.0000	0.00	4.0000	3.9011	-0.618

2. As Left

PASSED, DO NOT ADJUST

Maximum Error: -0.108 % of span

Nominal Input [inH2O]	Actual Input [inH2O]	Nominal Output [mA]	Actual Output [mA]	Found Error [% of span]
0.0000	0.00	4.0000	4.0076	0.048
2.500	2.48	8.000	7.9688	0.005
5.000	4.87	12.000	11.7818	-0.064
7.500	7.41	16.000	15.8455	-0.066
10.000	10.09	20.000	20.1356	-0.053
7.500	7.59	16.000	16.1267	-0.108
5.000	5.07	12.000	12.1031	-0.056
2.500	2.58	8.000	8.1261	-0.012
0.0000	0.01	4.0000	4.0182	0.014

Calibration Note:

Calibrated by: VINCENT NGUYEN
1/14/2020 2:45:52 PM

CANYON POWER PLANT
ANNUAL COMPLIANCE REPORT

ATTACHMENT 21

WASTE-10
COOLING TOWER SLUDGE TESTING

No Sludge developed for CY 2020